NRC FORM 658 (9-1999)			U.S. NUCLEAR REGULATORY COMMISSION	
TRANSMITTAL OF MEETING HANDOUT MATERIALS FOR IMMEDIATE PLACEMENT IN THE PUBLIC DOMAIN				
This form is to person who iss materials, will l circumstances Do not includ	be filled out (typed or hand-print sued the meeting notice). The c be sent to the Document Contro will this be done later than the v e proprietary materials.	ted) by omplet I Desk vorking	the person who announced the meeting (i.e., the ed form, and the attached copy of meeting handout on the same day of the meeting; under no g day after the meeting.	
DATE OF MEETING 01/23/2002	01/23/2002 The attached document(s), which was/were handed out in this meeting, is/are to be placed in the public domain as soon as possible. The minutes of the meeting will be issued in the near future. Following are administrative details regarding this meeting:			
	Docket Number(s) 50-346		346	
	Plant/Facility Name	Dav	vis-Besse Nuclear Power Station	
TAC Number(s) (if available) MB-2626		3-2626		
	Reference Meeting Notice	ML020110146		
	Purpose of Meeting			
			if noncentry of the reactor vessel hard Control Dad Drive Machanesim r	
If necessary, of the r		Austin 2001 01		
Stephen P. Sands			Project Manager	
			1	
DIVISION				
DLPM				
BRANCH PD3-2				
<u>Distribution of thi</u> Docket File/Cent PUBLIC	is form and attachments: ral File		DFOI	

Why We're Here

☆ Discuss Davis-Besse CRDM nozzle inspection and repair plans.

☆ Discuss application of flaw evaluation criteria at Davis-Besse.

☆ Answer NRC questions and assure that all requested information is provided.

☆ Identify methods/requirements for continuing communications.





Goal of Inspections and Repairs

☆ Assure safe operation of Davis-Besse until 14RFO in 2004, when RPV head replacement is planned.





Inspection Schedule

☆ Shutdown
 ☆ Start Visual Inspection
 ☆ UT Inspection
 ☆ Start Repairs
 ☆ Startup

February 16 February 21 February 22 - 26 February 24 March 22





Inspection and Repair Commitments

☆ Qualified visual examination

- Qualified personnel
- Capable equipment
- Governed by a procedure
- Plant specific gap analysis
- Nozzle un-obscured
- ☆ Ultrasonic testing of 100% of nozzles

☆ Supplemental examination of nozzles 1-4 and obscured nozzles

☆ Dye penetrant test of nozzles with verified leak path
☆ Characterize flaws through destructive examination
consistent with ALARA

☆ Meet with NRC prior to 13RFO





Inspection Plans

☆ Perform qualified visual examination of unobscured nozzles

- Framatome procedure
- Improved videotape of inspection
- ☆ Perform ultrasonic testing of 100% of nozzles
 - Framatome under-head blade probe UT utilizing ARAMIS delivery system

- Framatome top down rotating probe UT for open nozzles





Inspection Plans

☆ Characterization of nozzles with leak path verified by visual inspection.

- Framatome top down rotating probe UT
- Remote PT of weld and OD of nozzle
- ☆ Flaw characterization
 - No remote destructive examination technology available

- Current dose estimate (14 man-rem) may preclude manual destructive examination





Flaw Evaluation Guidelines

Reference: November 21, 2001 NRC Proposed Flaw Evaluation Guidelines

- ☆ Pressure boundary flaws
 - Utilize the MRP recommended crack growth rate
 - Base material repair in accordance with ASME section XI and approved relief requests
- ☆ Non-pressure boundary flaws
 - Utilize the MRP recommended crack growth rate
 - Projection of axial flaws to bottom of weld





<u>Repair Plans</u>

☆ Utilize Framatome ambient temperature temper-bead repair

- Low dose
- Industry experience
- Longevity

☆ ASME relief requests submitted for NRC review January 14, 2002







Davis-Besse 13RFO Reactor Head Nozzle Inspection Flow Chart



•



Flaw Evaluation Flow Chart

¥

FENO

.



