

July 26, 1984

Docket No. 50-324

Mr. E. E. Utley
Executive Vice President
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27062

Dear Mr. Utley:

SUBJECT: CORRECTION OF CLERICAL ERROR

Re: Brunswick Steam Electric Plant, Unit 2

On May 22, 1984 we issued Amendment No. 97 to the Technical Specifications. Through a clerical error, a change made in Amendment No. 95, issued on March 28, 1984, was eliminated. The enclosed page corrects this error. Please use the enclosed page 3/4 3-29 in place of the one now in your Technical Specifications.

Sincerely,

Original signed by/

Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION

Docket File
NRC PDR
Local PDR
ORB#2 Rdg
DEisenhut

SNorris
MGrotenhuis
OELD
LJHarmon
ELJordan

JNGrace
TBarnhart (4)
WJones
DBrinkman
ACRS (10)

OPA, CMiles
RDiggs
Gray File
Extra - 5

DL:ORB#2
SNorris:ajs
07/24/84

DL:ORB#2
MGrotenhuis
07/26/84

DL:ORB#2
DVassallo
07/26/84

8408070016 840726
PDR ADDCK 05000324
P PDR

Mr. E. E. Utley
Carolina Power & Light Company
Brunswick Steam Electric Plant, Units 1 and 2

cc:

Richard E. Jones, Esquire
Carolina Power & Light Company
336 Fayetteville Street
Raleigh, North Carolina 27602

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. Charles R. Dietz
Plant Manager
Post Office Box 458
Southport, North Carolina 28461

Mr. Franky Thomas, Chairman
Board of Commissioners
Post Office Box 249
Bolivia, North Carolina 28422

Mrs. Chrys Baggett
State Clearinghouse
Budget and Management
116 West Jones Street
Raleigh, North Carolina 27603

U. S. Environmental Protection
Agency
Region IV Office
Regional Radiation Representative
345 Courtland Street, N. W.
Atlanta, Georgia 30308

Resident Inspector
U. S. Nuclear Regulatory Commission
Star Route 1
Post Office Box 208
Southport, North Carolina 28461

James P. O'Reilly
Regional Administrator
Region II Office
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dayne H. Brown, Chief
Radiation Protection Branch
Division of Facility Services
Department of Human Resources
Post Office Box 12200
Raleigh, North Carolina 27605

TABLE 4.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED</u>
6. HPCI Turbine Exhaust Diaphragm Pressure - High (E41-PSH-N012A,B,C,D)	NA	M	Q	1, 2, 3
7. HPCI Steam Line Ambient Temp - High (E51-TS-N603C,D)	NA	M	R	1, 2, 3
8. HPCI Steam Line Area Δ Temp - High (E51-dTS-N604C,D)	NA	M	R	1, 2, 3
9. Emergency Area Cooler Temp - High (E41-TS-N602A,B)	NA	M	Q	1, 2, 3
b. Reactor Core Isolation Cooling System Isolation				
1. RCIC Steam Line Flow - High (E51-PDT-N017; E51-PDT-N018)	NA ^(a)	NA	R ^(b)	1, 2, 3
(E51-PDTM-N017-2; E51-PDTM-N018-2)	D	M	M	1, 2, 3
2. RCIC Steam Line High Flow Time Delay Relay (E51-TDR-K32; E51-TDR-K12)	NA	R	R	1, 2, 3
3. RCIC Steam Supply Pressure - Low (E51-PS-N019A,B,C,D)	NA	M	Q	1, 2, 3

BRUNSWICK - UNIT 2

3/4 3-29

Amendment No. 97

8408070018 840726
PDR ADOCK 05000324
PDR