BYRON INITIAL LICENSE EXAM

OCTOBER 29 and NOVEMBER 5-9, 2001

ES-201-2

"Examination Outline Quality Checklist," along with the operating test outline(s).

(See the October, 2001 Braidwood postexam retention package for the written exam outlines) ES-201

Examination Outline Quality Checklist

Facility:	Date of Examination:		Toitiale					
ltem	Task Description	a	b*	c#				
1.	a. Verify that the outline(s) fit(s) the appropriate model per ES-401.	Gun	en	2h				
R I	b. Assess whether the outline was systematically and randomly prepared in accordance with Section D.1 of ES-401 and whether all KA categories are appropriately sampled.	GLW	eme	Dr.				
T	c. Assess whether the outline over-emphasizes any systems, evolutions, or generic topics.	GIW	Rnu	Pť.				
E N	d. Assess whether the justification for deselected or rejected K/A statements are appropriate.	Gend	Enve	6hr				
2.	 a. Using Form ES-301-5, verify that the proposed scenario sets cover the required number of normal evolutions, instrument and component failures, and major transients. 	64)	EMAN	by				
S I M	b. Assess whether there are enough scenario sets (and spares) to test the projected number and mix of applicants in accordance with the expected crew composition and rotation schedule without compromising exam integrity; ensure each applicant can be tested using at least one new or significantly modified scenario, that no scenarios are duplicated from the applicants' audit test(s)*, and scenarios will not be repeated over successive days.	GLW	im	ØR				
	c. To the extent possible, assess whether the outline(s) conform(s) with the qualitative and quantitative criteria specified on Form ES-301-4 and described in Appendix D.	Gui	Toma	ØŴ				
3. W / T	 a. Verify that: (1) the outline(s) contain(s) the required number of control room and in-plant tasks, (2) no more than 30% of the test material is repeated from the last NRC examination, (3)* no tasks are duplicated from the applicants' audit test(s), and (4) no more than 80% of any operating test is taken directly from the licensee's exam banks. 	GLW	1 min	ρ¶				
	 b. Verify that: (1) the tasks are distributed among the safety function groupings as specified in ES-301, (2) one task is conducted in a low-power or shutdown condition, (3) 40% of the tasks require the applicant to implement an alternate path procedure, (4) one in-plant task tests the applicant's response to an emergency or abnormal condition, and (5) the in-plant walk-through requires the applicant to enter the RCA. 	Gen	Jone -	Dri				
	c. Verify that the required administrative topics are covered, with emphasis on performance-based activities.	GLW	Pan	QA				
	d. Determine if there are enough different outlines to test the projected number and mix of applicants and ensure that no items are duplicated on successive days.	<i>i</i> cw)	par	M				
4.	 Assess whether plant-specific priorities (including PRA and IPE insights) are covered in the appropriate exam section. 	GW	for	246				
GE	b. Assess whether the 10 CFR 55.41/43 and 55.45 sampling is appropriate.	GW	(mar)	ÔN.				
E	c. Ensure that K/A importance ratings (except for plant-specific priorities) are at least 2.5.	GW	6m	0A				
A	d. Check for duplication and overlap among exam sections.	Gen	and a	14				
-	e. Check the entire exam for balance of coverage.	GLW	Elsen .	<u>DN</u>				
	f. Assess whether the exam fits the appropriate job level (RO or SRO).	GW	por 1	99				
a. Author b. Facility Reviewer (*) c. NRC Chief Examiner (#) d. NRC Supervisor Date T-5-01 David L. PELTON/Conf. Chillon David L. PELTON/Conf. Chillon David L. H. K. Baul & Guilla SI 7/01 SI 7/01 SI 7/01 SI 7/01								
NOTE: * Not applicable for NRC-developed examinations. # Independent NRC Reviewer initial items in Column "c" chief examiner concurrence required.								

NUREG-1021, Revision 8, Supplement 1

ES-301

Administrative Topics Outline

Form ES-301-1

Facili Exan	ity: <u>Byron</u> nination Level (circle	e one): RO/ SRO	Date of Examination: Operating Test Number: _2001		
	Administrative Topic/Subject Description	Describe method of evaluation: 1. ONE Administrative JPM, OR 2. TWO Administrative Questions			
A.1	Conduct of Operations/ Plant Parameter Verification	1. NEW JPM - K/A 2.1.19 - Description - Perform PDMS	RO rating 3.0 Operability Weekly Surveillance		
	Conduct of Operations/ Plant Notification of Fire	1. NEW JPM - K/A 2.1.14 - Description - Respond to a D	RO rating 2.5)eluge Alarm		
A.2	Equipment Control/ Surveillance Testing	1. NEW JPM - K/A 2.2.12 - Description - Perform Valve S	RO rating 3.0 Stroke Test of Containment Isol. VIv.		
A.3	Radiation Control/ Guard Against Personnel Exposure	1. NEW JPM - K/A 2.3.10 - Description - Respond to Hi I	RO rating 2.9 Radiation in Aux Building		
A.4	Emergency Plan/ RO Knowledge and Responsibilities	Question #1 - K/A 2.4.39 - R Description - Actions for perfo Question #2 - K/A 2.4.29 - R Description - Assembly locati	O rating 3.3 orming a Site Assembly O rating 2.6 ion and title for operators		

21 of 26 NUREG-1021, Revision 8, Supplement 1

ES-301

Administrative Topics Outline

Form ES-301-1

Facili Exan	ty: <u>Byron</u> nination Level (circle	e one): RO (SRO	Date of Examination: Operating Test Number: _2001	
	Administrative Topic/Subject Description	Describe method of evaluation: 1. ONE Administrative JPM, OR 2. TWO Administrative Questions		
A.1	Conduct of Operations/ Operability Determination	1. NEW JPM - K/A 2.1.7 Description - Review Qua	- SRO rating 4.4 drant Power Tilt Ratio Surveillance	
	Conduct of Operations/ Apply Technical Specifications	1. NEW JPM - 2.1.12 - S Description – Initiate a LC	RO rating 4.0 OAR	
A.2	Equipment Control/ Surveillance Testing Requirements	1. NEW JPM - K/A 2.2.2 Description – Determine F	I - SRO rating 3.5 Post Maintenance Testing Requirements	
A.3	Radiation Control/ Control of Radiation Releases	1. Byron 2000 NRC - K/A Description – Review & A	2.3.6 - SRO rating 3.1 pprove a Gas Release Package	
A.4	Emergency Plan/ Emergency Classifications	1. NEW JPM - K/A 2.4.4 Description – Classify Eve	I SRO - rating 4.1 ent and fill out NARS Form	

ES-301 Control Room Systems and Facility Walk-Through Test Outline Form ES-301-2

Facility: <u>Byron</u> Exam Level (circle one): RO / SRO(I) (SRO(U)	amination: est Number: _2001							
R.1. Control Room Sustamo								
System / JPM Title		Type Code*	Safety Function					
a.								
b. Emergency Core Cooling System (ECCS) / 1A Safet Pump ASME Startup with High Motor Amps	y Injection	N, A, S, L	3					
c. Residual Heat Removal System / Place Shutdown C Service (JPM N-20)	ooling in	D, S, L	4					
d.								
е.								
f.			:					
g.								
B.2 Facility Walk-Through								
a. Engineered Safety Features Actuation System / Loc Feedwater Isolation Signal (JPM N-43)	al Reset of	D, L	2					
b. Hydrogen Recombiner / Startup of a Hydrogen Rec (JPM N-31)	ombiner	D, R	5					
c. Fire Protection System / Operate the Fire Detection System, Manual Initiation of CO2 to DG Room (JPM	& Alarm N-49a)	D, A	8					
* Type Codes: (D)irect from bank, (M)odified from bank, (N)ew, (A)Iternate path, (C)ontrol room, (S)imulator, (L)ow Power, (R)CA								

22 of 26 NUREG-1021, Revision 8, Supplement 1

ES-301 Control Room Systems and Facility Walk-Through Test Outline Form ES-301-2

Facility: Byron Date of Examination: Exam Level (circle one): RO / SRO(I); SRO(U) Operating Test Number: 2001								
B.1 Control Room Systems								
System / JPM Title	Type Code*	Safety Function						
a. Chemical and Volume Control System / Perform Emergency Boration (Plugged RC Filter) (JPM N-27b)	D, A, S	1						
b. Emergency Core Cooling System (ECCS) / 1A Safety Injection Pump ASME Startup with High Motor Amps	N, A, S, L	3						
c. Residual Heat Removal System / Place Shutdown Cooling in Service (JPM N-20)	D, S, L	4						
d. Containment Spray System / Align Containment Spray System for Cold Leg Recirculation	N, S, L	5						
e. Emergency Diesel Generators (DG) / Remove DG from Parallel Operation (JPM N-06)	D, S	6						
f. Engineered Safety Features Actuation System / Align for Containment Vent Release (failure of ESFAS isolation signal)	N, A, S	2						
g. Liquid Rad Waste System / Perform Process Rad Monitor Adjustment for Liquid Release	N, S	9						
B.2 Facility Walk-Through								
a. Engineered Safety Features Actuation System / Local Reset of Feedwater Isolation Signal (JPM N-43)	D, L	2						
b. Hydrogen Recombiner / Startup of a Hydrogen Recombiner (JPM N-31)	D, R	5						
c. Fire Protection System / Operate the Fire Detection & Alarm System, Manual Initiation of CO2 to DG Room (JPM N-49a)	D, A	8						
* Type Codes: (D)irect from bank, (M)odified from bank, (N)ew, (A)Iternate path, (C)ontrol room, (S)imulator, (L)ow Power, (R)CA								

22 of 26 NUREG-1021, Revision 8, Supplement 1

	. <u>Dyron</u>		Scenario No.:	<u> </u>	Op-Test No.:	2001	
Examin	ers:			Operators: _		SRO	
				_		<u>RO</u>	
						BOP	
Initial Conditions: IC-16; 50% power, BOL, equilibrium Xenon, steady state, 1B Diesel Generator (DG) OOS, 1C HD pump OOS, U-2 SAC OOS. Turnover: The Unit is at 50% power, BOL, equilibrium Xenon, steady state. The 1B Diesel Generator is OOS							
	for replac returned t replaceme returned t at 5 MW/	ement of Turbo o service by the ent. Unit 2 Stati o service by the min.	Charger. The DG h end of the shift. 1C on Air Compressor (end of the shift. Ele	as been OOS fo Heater Drain I SAC) is OOS ectrical Operati	or 18 hours and is expec Pump (HD) is OOS for r for an oil change and is ons has requested a ram	ted to be notor bearing expected to be p to full power	
Event No.	Malf. No.	Event Type*		De	Event escription		
Preload	RF EG09 MAINT_O		1B DG OOS	101-101-1 101-101-1			
1		N BOP SRO	Raise turbine load	Raise turbine load to full power at 5 MW/min.			
		R RO	Raise reactor power using rods and/or dilution.				
2	RX13A	I RO SRO	Controlling Pressu	rizer (PZR) lev	vel channel fails low.		
3	TP01B, RF TP14 OPEN	C BOP SRO	Stator Cooling (Ge auto start.	C) Water Pump	trip with failure of stan	dby pump to	
4	CC03B CC01C CC02A	I BOP SRO	Component Coolir results in auto mak auto start on low h	ng (CC) Surge ⁷ teup and 1B CC eader pressure.	Fank level transmitter le C pump trip with failure	vel tree leak of 1A CC pump	
5	TH10A&B, OR ZDI1PK455C	C RO SRO	PZR Spray Valves Spray Valve contro manual control for	1RY455B&C oller failed in a 1RY455B ava	failed open (TH10A&B uto (IOR ZDI1PK455C ilable).	, 100, 10) PZR AUTO with	
6	RP02A&B TC03 RP35 & 61	M RO BOP SRO	ATWS with failure auto close. Coincident with n	e of main turbin next event.	ne to auto trip and failur	e of MSIVs to	
7	OR ZDI1MS001B MS03B&F	M RO BOP SRO	Pressure transient of Steam Break on the	causes steam bi e 1B SG - 2 MS	reak (1B MSIV fails clo S safeties stuck open).	sed causes	

Appendix D

Scenario Outline

Form ES-D-1

Facility	Byron			Scenario No.: 2	Op-Test No.:
Examiners:			Operato	ors: <u>SRO</u>	
					RO
	<u>,</u>				<u></u>
Initial C	onditions: <u>IC</u> <u>U</u>	C-18; 7 -2 SA	<u>75% powe</u> C OOS.	r BOL, Equilibrium Xenon,	1B Diesel Generator OOS, 1C HD pump OOS,
Turnove	er: <u>The Unit</u> <u>DG has be</u> Heater Dr	<u>is at 7:</u> een O(ain Pu	5% power OS for 18 mp is OO	The 1B Diesel Generator is hours and is expected to be for motor bearing replace	s OOS for replacement of Turbo Charger. The returned to service by the end of the shift. 1C ment. Unit 2 SAC is OOS for an oil change and
	is expecte	d to be	e returned	to service by the end of the	shift. Directions have been received to
	increase p	ower t	to 100% a	t 5 MW/min.	<u> </u>
Event	Malf	Ī	Tvent		Fyont
No.	No.	Ι 1 Γ	Vpe*		Description
Preload	RF EG09		<u></u>	1B DG OOS	
	MAINT_O				
1		N	BOP	Raise Turbine load to full	power at 5 MW/min
			SRO		
		R	RO	Raise reactor power using	rods and/or dilution
2	NI09A	I	RO	Power Range N41 fails high	gh
			SRO	Coincident with next eve	nt
3	RD09		RO	Auto Rod Speed failure to	0, Rods fail to move in AUTO
4	FW16	T T	BOP	FW Header Discharge Pre	ssure PT-508 fails low on a 5 second ramp
-	1 10 10		SRO	i w neader Discharge i ie	ssure 1 1-508 rans low on a 5 second ramp
5	FW02B,	C	BOP	1C Main Feedwater pump	trips with failure of 1A Motor Driven
	FW01		SRO	Feedwater pump failure to	start
6	RF TC03	M	BOP	Inadvertent turbine trip	
			RO	· · · · · · · · · · · · · · · · ·	
			SRO		
7	ED15D	C	BOP	Loss of Offsite Power (Sw	vitchyard Bus 6 fault)
			RO		
0	ECORA		SKO DOD	Less of all AC server 1	
0	EGU8A		BOR	Loss of all AC power due	to TA DG failure 90 sec after start
			SRO		
*(N)ormal	, (R)eactiv	vity	(I)nstrum	ent, (C)omponent, (M)	ajor Transient

Scenario Outline

Form ES-D-1

Facility:	Byron	1	-	Scenario No.:	3	Op-Test No.:	2001			
Examine	rs:				Operators:		SRO			
							RO			
							BOP			
In the I C	Initial Conditions: IC 21: 100% nouver POL consilibrium Versus start unter ID Dis 1.C									
Initial Co	Initial Conditions: <u>IC-21; 100% power, BOL, equilibrium Xenon, steady state, 1B Diesel Generator OOS, 1C</u> HD pump OOS, U-2 SAC OOS.									
Turnover: 100% nower POL equilibrium Yanon steady state. The 1B Discel Concertant's COS for										
Turnover	replaceme	nt of T	<u>furbo Char</u>	ger. The DG has be	een OOS for 1	8 hours and is expected to	<u>tor</u> be returned to			
	service by	the en	nd of the sh	ift. 1C Heater Drai	in Pump is OC	OS for motor bearing replace	ement. Unit 2			
	SAC is O	<u>OS for</u>	an oil cha	nge and is expected	l to be returned	to service by the end of the	ne shift.			
Event	Malf.]	Event			Event	·····			
No.	No.		Гуре*		Γ	Description				
Preload	RF EG09			1B DG OOS						
1	TH03C		PO	Steam Generator	1C Tuba Loak	(25 mm)				
1	mose		BOP	Steam Generator	IC TUDE LEAK	(25 gpm)				
			SRO							
2		N	BOP	Reduce Turbine I	Load for Unit S	Shutdown due to SG leakag	ge > Tech			
		р	SRO	Spec		and/antanation				
		R -	<u></u>	Lower reactor po	wer using rods	and/or boration				
3	RX18A	I	RO	IA RCS loop Tee	old RTD failed	High				
4	EG03	С	BOP	Voltage Regulato	r malfunction	Field Forcing				
			SRO			B				
5	RX06L	Ι	BOP	Steam Generator	1C controlling	level channel 1LT558 Fai	led High on a			
(CV/01A		SRO	3 sec ramp.	·					
0	CVUIA		RU SRO	Centrifugal Charg	ging Pump Trip	þ				
7	TH03C	M	RO	Steam Generator	1C Tube Rupt	ure (460 gpm)				
			BOP		F					
			SRO							
8	ED11A	C	RO	Loss of Instrumer	nt Bus 111 coir	ncident with Reactor Trip				
			SRO							
9	RF RP84	C	RO	1B SI Pump fails	to start autom	atically. Manually start an S	SI pump and			
	RP15D		BOP	Manually Align tr	rain A ECCS f	or Injection due to failure t	o auto start			
			SRO	from loss of instru	ument bus 111	-				

*(N)ormal, (R)eactivity (I)nstrument, (C)omponent, (M)ajor Transient

Appendix D

Facility:	<u>Byron</u>		Scenario No.:	4	Op-Test No.:	_2001				
Examiner	·s:			Operators:		<u>SRO</u>				
						RO				
						BOP				
Initial Co	Initial Conditions: IC-21: 100% power, BOL equilibrium Xenon steady state 1B Diesel Cenerator OOS 1C									
	HD	pump OOS, 1	J-2 SAC OOS. PZR	PORV 1RY45	6 control switch is in CL	OSE and Block				
	Valve 1RY8000B is closed and deenergized.									
Turnover	Turnover: The Unit is at 100%, BOL, equilibrium Xenon, steady state. The block valve 1RY8000B) for									
	Pressurizer	(PZR) PORV	<u>1RY456 is closed and it</u>	nd deenergized	. A leak had developed of	<u>on PORV</u>				
	Electrical M	faintenance is	investigating. The l	<u>Impped after ti</u> Block valve ha	s been de-energized close	observed.				
	The 1B Die	sel Generator	is OOS for replacem	ent of Turbo (Charger. The DG has bee	<u>n OOS for 18</u>				
	hours and is	s expected to b	be returned to service	by the end of	the shift. 1C Heater Dra	in (HD) Pump				
	<u>is OOS for </u>	motor bearing	replacement. Unit 2	<u>Station Air C</u>	ompressor (SAC) is OOS	for an oil				
Event	Malf.	Event		~	Event					
INO.		Type*			escription					
Pleioad	MAINT O		IB DG 008							
Preload	RF ED065D OPEN		PZR PORV 1RY	456 Block Val	ve 1RY8000B breaker tri	pped.				
1	TH11A &	C RO	PZR PORV 1RY	455A fails ope	n requiring the block valu	/e 1RY8000A				
	RF ED058C	SRO	to be closed and t	he breaker for	1RY8000A will trip whe	n closed.				
2	CV16	I RO	Volume Control 7	Fank (VCT) le	vel channel 11 T-CV112	fails high				
	- /	SRO				ans ingn				
3		N BOP	Reduce Turbine I	load for Unit S	hutdown due to inoperab	le PZR PORVs				
		R RO	Lower reactor po	ver using rods	and/or boration					
1	PYOIN		Eteem Company	1D santus Ilin s	Sterm Derailon	<u> </u>				
-+	MAUIK	SRO	Steam Generator	1D controlling	Steam Pressure channel	lans low.				
5	PA0123	C BOP	Essential Service	Water Pump o	il pressure malfunction.					
		SRO								
6	TUO2D	RO N RO			400					
0	10050	ROP	requiring a reactor	ID Tube Ruph	ire – 400 gpm ramped ov	er 60 sec.				
		SRO								
7	RF RP78, 79,	I BOP	Feedwater Isolation	on signal fails :	requiring manual operation	on of FW				
	RF FW150 & FW151	SRO	components		-					
	REMOVED									
8	MS07D	M BOP	1D SG faulted (st	eam break) ins	ide containment on React	or trip				
		SRO								
[∗] (N)ormal,	(R)eactivity	/ (I)nstrun	nent, (C)omponent	, (M)ajor Tra	insient					