



**TXU Electric**  
**Comanche Peak**  
**Steam Electric Station**  
P.O. Box 1002  
Glen Rose, TX 76043  
Tel: 254 897 8920  
Fax: 254 897 6652  
lterry1@txu.com

**C. Lance Terry**  
Senior Vice President & Principal Nuclear Officer

Ref: 10CFR50.46

CPSES-200200080  
Log # TXX-02007  
File # 10010

January 8, 2002

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555

**SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)**  
**DOCKET NOS. 50-445 AND 50-446**  
**ANNUAL REPORT OF CHANGES IN**  
**PEAK CLADDING TEMPERATURE**

Gentlemen:

In accordance with the requirements of 10CFR50.46(a)(3)(ii), TXU Electric submits the attached changes or errors discovered in the Emergency Core Cooling System (ECCS) evaluation model used to calculate peak cladding temperature (PCT) and the estimated effect of these changes or errors on the limiting ECCS analysis. As in the previous year, the analyses for Unit 1 were performed with a Steam Generator Tube Plugging allowance of 10% and those for Unit 2 with an allowance of 5%.

A member of the **STARS** (Strategic Teaming and Resource Sharing) Alliance

Callaway • Comanche Peak • Diablo Canyon • South Texas Project • Wolf Creek

DD29

TXX-02007  
Page 2 of 2

This communication contains no new licensing basis commitments regarding CPSES Units 1 and 2.

Sincerely,

C. L. Terry

By:   
Roger D. Walker  
Regulatory Affairs Manager

JDS/js

Attachment

c - E. W. Merschoff, Region IV  
C. E. Johnson, Region IV  
D. H. Jaffe, NRR  
Resident Inspectors, CPSES

CPSES Units 1 and 2  
Peak Clad Temperatures

Analysis/Evaluation	CPSES Unit 1 PCT (°F)	CPSES Unit 2 PCT (°F)
Limiting LOCA PCT (°F) [Large Break]	<b>1884</b>	<b>1912</b>
Small Break LOCA PCT* (°F)	<b>1859</b>	<b>1835</b>

\*An error pertaining to clad rupture at negative pressures was corrected in the Small Break LOCA hot rod response code TOODEE2 (UAPR94). The correction to the TOODEE2 code was conservatively estimated to be 11 °F. Units 1 and 2 were re-analyzed for the Small Break LOCA and the revised PCT obtained with the corrected version of the Small Break LOCA TOODEE2 code is herein reported.