

**Entergy Nuclear Northeast** 

Entergy Nuclear Operations, Inc. Indian Point Energy Center P.O. Box 308 Buchanan, NY 10511 Tel 914 736 8001 Fax 914 736 8012

Robert J. Barrett Vice President, Operations Indian Point 3

January 3, 2002 IPN-02-001

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Mail Stop O-P1-17 Washington, DC 20555-0001

SUBJECT:

Indian Point 3 Nuclear Power Plant

Docket No. 50-286 License No. DPR-64

Response to NRC Special Inspection Report 2001-006

## Dear Sir:

Entergy has read and accepted the non-cited violation of 10 CFR 50.59 for the Backup Spent Fuel Pool Cooling System (BUSFPCS) for failure to identify an increase in the probability of a malfunction of equipment important to safety. As part of our corrective action program, administrative controls were established to assure compliance with 10 CFR 50.59 by precluding operation of the BUSFPCS as a backup to the normal Spent Fuel Pool Cooling System (SFPCS). The original design as a "backup" system limited use to those periods when the SFPCS had to be taken out of service for maintenance as allowed by the FSAR. It is our intent to evaluate the BUSFPCS using the revised 10 CFR 50.59 criteria. The evaluation will be consistent with the finding of the violation, i.e., any alternative system that will perform the function of a system important to safety when that system is out of service must be evaluated as an equivalent system rather than a backup system.

Indian Point 3 is not making any new commitments associated with this letter. If you have any questions regarding this submittal, please contact Mr. J. Donnelly.

Very truly yours

Robert J. Barrett

Vice President Operations Indian Point 3 Nuclear Plant

cc: next page

Gool

Docket No. 50-286 IPN-02-001 Page 2 of 2

CC:

Mr. Hubert J. Miller Regional Administrator Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

Resident Inspector's Office Indian Point Unit 3 U.S. Nuclear Regulatory Commission 295 Broadway, Suite 3 P.O. Box 337 Buchanan, NY 10511-0308