

James F. Klapproth Manager, Engineering and Technology Nuclear Services General Electric Company 175 Curtner Avenue, MC 706, San Jose, CA 95125-1088 408 925-5434, Fax: 408 925-3837 james.klapproth@gene.ge.com

MFN 02-005

January 28, 2002

U.S Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555-0001

Chief, Information Management Branch Attention: Program Management Policy Development and Analysis Staff

Subject: Maximum Extended Load Line Limit Analysis Plus (MELLLA+) Licensing Topical Report – GE Draft Presentation Slides – Open Session

Reference: GE Licensing Topical Report NEDC-33006P, "General Electric Boiling Water Reactor Maximum Extended Load Line Limit Analysis Plus," January 2002

Attached are the non-proprietary draft presentation slides for the February 11, 2002 MELLLA+ Kickoff Meeting. The purpose of this meeting is to provide an overview of the MELLLA+ Licensing Topical Report (Reference) and to obtain Staff feedback on the review schedule. By letter dated January 15, 2002, GE previously submitted the draft proprietary slides for this same meeting.

If you have any questions about the information provided here, please contact George Stramback at (408) 925-1913, P. T. Tran at (408) 925-3348, or myself.

Sincerely,

J. F. Klapproth, Manager Engineering and Technology **GE** Nuclear Energy (408) 925-5434 james.klapproth@gene.ge.com

JE Donoghue – USNRC cc: PT Tran **GB** Stramback

1010





GE Nuclear Energy

Maximum Extended Load Line Limit Analysis Plus (MELLLA+) Licensing Topical Report

Open Session

PT Tran

February 11, 2002

GE MELLLA+ Program







Introduction MELLLA+ Design MELLLA+ LTR •Approach and format •Technical Contents Proposed Schedule Open for Questions





- To kick off NRC review of the M+ LTR
- To obtain feedback on the proposed review schedule/plan





Need Increased Operating Flexibility for Uprate >5%

For each uprated step, the current MELLLA full power operating window gets smaller:

Range for 10% PU: ~87% to maximum flow

15% PU: ~93% to maximum flow

20% PU: ~99% to maximum flow

 Maximum core flow capability is also reduced slightly by larger core pressure drop at uprated power and periodically by other potential recirculation effects (e.g., jet pump crudding)

All plants with EPU need to restore sufficient power/flow operating window






What is MELLLA+?

- An expansion of the existing MELLLA power/flow map to provide more operating flexibility for uprated_plants to achieve full core thermal power with a core flow "window"
- Objective is to increase the maximum load line by 5% to 15% over the existing MELLLA boundary

Restore Practical Full Power Core Flow Range For Extended Power Uprate Operation







February 11, 2002

GE MELLLA+ Program

Slide 6





- Decrease in core inlet enthalpy
- No increase in power level
- No increase in reactor operating dome pressure
- No increase in steam flow
- No increase in pressure drop
- No increase in decay heat
- No increase in activation source terms





Goals:

- Follow format of CPPU LTR (CLTR)
 - Same structure as CLTR Rev 2
 - Similar level of detail
- Use experience/engineering principles and evaluation to justify conclusions

Use CLTR approach to facilitate NRC review/acceptance





- M+LTR follows CLTR approach to facilitate NRC review
- All important technical areas are included in the M+LTR for NRC evaluation





B MELLLA+ Implementation Target Plan

| M+LTR Submittal | | 01/02 | 01/02 | |
|---|------------------|------------|-------|--|
| Plant Specific Su | bmittals | | | |
| | M+SAR | Expected | | |
| | <u>Submittal</u> | <u>SER</u> | | |
| – Clinton: | 04/02 | 2Q03 | | |
| – Brunswick: | 05/02 | 1Q03 | | |
| – Browns Ferry: | 01/03 | 4Q03 | | |
| NRC Comments/Feedback on M+LTR plan | | | | |
| Proposed Technical Meeting with Staff | | | | |
| NRC SER on M+LTR | | | | |