



FOR INFORMATION ONLY

NOTE: THIS PRINT IS TO BE USED FOR THE FCS LICENSE RENEWAL PROJECT ONLY. IT MAY NOT REFLECT THE MOST CURRENT REVISION OF THIS DRAWING.

146

PORTIONS OF SYSTEM WITH LICENSE RENEWAL SCOPE ARE BOUNDED BY LR-PLACES. UNLESS OTHERWISE INDICATED, VENTS, ORANGE AND TEST CONNECTIONS THAT ARE WITHIN LICENSE RENEWAL BOUNDARIES ARE INCLUDED IN LR SCOPE TO THE DISCHARGE OF THE VALVE. ALL INSTRUMENTATION LINES NORMALLY OPEN TO THE PROCESS SYSTEM THROUGH AND INCLUDING THE INSTRUMENT ARE INCLUDED IN LR SCOPE. IN GENERAL, LR PLACES ARE NOT SHOWN FOR VENTS, ORANGE, TEST CONNECTIONS OR INSTRUMENT LINES EXCEPT FOR CONTAINMENT PENETRATIONS. THE LICENSE RENEWAL BOUNDARY INCLUDES THE PIPING AND SUPPORTS UP TO THE FIRST SEISMIC SUPPORT PAST THE BLUE BOUNDARY FLAG.

FORT CALHOUN STATION	
EAF-C-00126 OF 1001	
SAFETY INJECTION AND CONTAINMENT SPRAY SYSTEM FLOW DIAGRAM P & ID	
DWG. E-23866-210-130 SH. 2A	
REV. SH. 33125	REV 8
FILE 41901	APVD 9/19/99