



50-325/324

UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

June 29, 1998

Mr. J. S. Keenan, Vice President
Carolina Power & Light Company
Brunswick Steam Electric Plant
Post Office Box 10429
Southport, North Carolina 28461

SUBJECT: CORRECTION OF DISCREPANCY IDENTIFIED IN AMENDMENT NO. 203 TO
FACILITY OPERATING LICENSE NO. DPR-71 AND AMENDMENT NO. 233
TO FACILITY OPERATING LICENSE NO. DPR-62 - BRUNSWICK STEAM
ELECTRIC PLANT, UNITS 1 AND 2 (TAC NOS. M97243 AND M97244)

Dear Mr. Keenan:

In a letter dated June 12, 1998, Carolina Power & Light Company (CP&L) identified a discrepancy in Amendment No. 203 to the facility operating license DPR-71 and Amendment No. 233 to the facility operating license DPR-62 for the Brunswick Steam Electric Plant, Units 1 and 2 (BSEP 1&2). Those amendments were issued on June 5, 1998, and approved the conversion from the current Technical Specifications (TS) to the improved TS, as contained in Revision 1 of NUREG-1433, "Standard Technical Specifications General Electric Plants, BWR/4."

As issued under those amendments, Table 3.3.6.1-1 on page 3.3-56, "Primary Containment Isolation Instrumentation," Function 4.c for isolation of the reactor core isolation cooling system (RCIC), "RCIC Steam Supply Line Pressure - Low," incorrectly requires the Allowable Value to be ≤ 53 psig. The correct Allowable Value is ≥ 53 psig.

The erroneous inequality sign was inadvertently introduced in CP&L's November 1, 1996, application for ITS conversion. Table 3.3.6.1-1, Function 4.b, of NUREG-1433 incorrectly lists the Allowable Value of the RCIC Steam Supply Line Pressure - Low function as $\leq [60]$ psig. CP&L properly incorporated the plant-specific value of 53 psig for this function, but did not identify the erroneous inequality sign. The supporting documentation provided by CP&L for the ITS conversion does not request or describe changing the allowable value in the current TS from ≥ 53 psig to ≤ 53 psig.

120084

REC FILE ORIGINAL COPY

9807060006 980629
PDR ADOCK 05000324
P PDR

11
DF01

2 June 29, 1998

As requested by CP&L in the June 12, 1998, letter, the enclosed revised pages to the BSEP 1&2 improved TS are hereby issued to correct the subject discrepancy.

Sincerely,

ORIGINAL SIGNED BY:

David C. Trimble, Project Manager
Project Directorate II-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-325
and 50-324

Enclosures: As stated

cc w/enclosure: See next page

Distribution: See next page

FILENAME - G:\BRUNSWIC\BR97243a.ltr

OFFICE	PM:PDII-1	LA:PDII-1	TSB	D:PDII-1
NAME	DTrimble <i>ET</i>	EDunnington <i>ETD</i>	<i>MW</i>	PTKuo <i>PTK</i>
DATE	6/25/98	6/25/98	6/25/98	6/29/98
COPY	(Yes/No)	(Yes/No)	Yes/No	Yes/No

OFFICIAL RECORD COPY

DISTRIBUTION:

Docket File
PUBLIC
PD II-1 Reading File
J. Zwolinski
OGC
G. Hill (4)
B. Beckner - OTSB
C. Schulten
D. Trimble
M. Weston
R. Tjader
J. Luehman
R. Giardina
M. Reardon
ACRS
OPA
OC/LFDCB
L. Plisco, R-II

cc: Brunswick Service List

Mr. J. S. Keenan
Carolina Power & Light Company

cc:

Mr. William D. Johnson
Vice President and Senior Counsel
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Mr. Jerry W. Jones, Chairman
Brunswick County Board of Commissioners
Post Office Box 249
Bolivia, North Carolina 28422

Resident Inspector
U.S. Nuclear Regulatory Commission
8470 River Road
Southport, North Carolina 28461

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303

Mr. Mel Fry, Director
Division of Radiation Protection
N.C. Department of Environment
and Natural Resources
3825 Barrett Dr.
Raleigh, North Carolina 27609-7721

Mr. J. J. Lyash
Plant Manager
Carolina Power & Light Company
Brunswick Steam Electric Plant
Post Office Box 10429
Southport, North Carolina 28461

Public Service Commission
State of South Carolina
Post Office Drawer 11649
Columbia, South Carolina 29211

Mr. Michael Ernstes
U. S. Nuclear Regulatory Commission
Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303

Brunswick Steam Electric Plant
Units 1 and 2

Ms. Karen E. Long
Assistant Attorney General
State of North Carolina
Post Office Box 629
Raleigh, North Carolina 27602

Mr. Robert P. Gruber
Executive Director
Public Staff - NCUC
Post Office Box 29520
Raleigh, North Carolina 27626-0520

Director
Site Operations
Brunswick Steam Electric Plant
Post Office Box 10429
Southport, North Carolina 28461

Mr. William H. Crowe, Mayor
City of Southport
201 East Moore Street
Southport, North Carolina 28461

Mr. Dan E. Summers
Emergency Management Coordinator
New Hanover County Department of
Emergency Management
Post Office Box 1525
Wilmington, North Carolina 28402

Ms. D. B. Alexander
Manager
Performance Evaluation and
Regulatory Affairs CPB 9
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602-1551

Mr. K. R. Jury
Manager - Regulatory Affairs
Carolina Power & Light Company
Post Office Box 10429
Southport, NC 28461-0429

Primary Containment Isolation Instrumentation
3.3.6.1

Table 3.3.6.1-1 (page 3 of 5)
Primary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
3. HPCI System Isolation (continued)					
i. HPCI Equipment Area Temperature —High	1,2,3	2	F	SR 3.3.6.1.5 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 175°F
4. Reactor Core Isolation Cooling (RCIC) System Isolation					
a. RCIC Steam Line Flow —High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 275% rated steam flow
b. RCIC Steam Line Flow —High Time Delay Relay	1,2,3	1	F	SR 3.3.6.1.6 SR 3.3.6.1.7 SR 3.3.6.1.9	≥ 4 seconds and ≤ 12 seconds
c. RCIC Steam Supply Line Pressure —Low	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.7	≥ 53 psig
d. RCIC Turbine Exhaust Diaphragm Pressure —High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 6 psig
e. Drywell Pressure —High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 1.8 psig
f. RCIC Steam Line Area Temperature —High	1,2,3	1	F	SR 3.3.6.1.5 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 175°F
g. RCIC Steam Line Tunnel Ambient Temperature —High	1,2,3	1	F	SR 3.3.6.1.5 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 200°F
h. RCIC Steam Line Tunnel and Area Temperature —High Time Delay	1,2,3	1	F	SR 3.3.6.1.5 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 30 minutes
i. RCIC Steam Line Tunnel Differential Temperature —High	1,2,3	1	F	SR 3.3.6.1.5 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 50°F
(continued)					

Primary Containment Isolation Instrumentation
3.3.6.1

Table 3.3.6.1-1 (page 3 of 5)
Primary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
3. HPCI System Isolation (continued)					
i. HPCI Equipment Area Temperature —High	1,2,3	2	F	SR 3.3.6.1.5 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 175°F
4. Reactor Core Isolation Cooling (RCIC) System Isolation					
a. RCIC Steam Line Flow —High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 275% rated steam flow
b. RCIC Steam Line Flow —High Time Delay Relay	1,2,3	1	F	SR 3.3.6.1.6 SR 3.3.6.1.7 SR 3.3.6.1.9	≥ 4 seconds and ≤ 12 seconds
c. RCIC Steam Supply Line Pressure —Low	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.7	≥ 53 psig
d. RCIC Turbine Exhaust Diaphragm Pressure —High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 6 psig
e. Drywell Pressure —High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 1.8 psig
f. RCIC Steam Line Area Temperature —High	1,2,3	1	F	SR 3.3.6.1.5 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 175°F
g. RCIC Steam Line Tunnel Ambient Temperature —High	1,2,3	1	F	SR 3.3.6.1.5 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 200°F
h. RCIC Steam Line Tunnel and Area Temperature —High Time Delay	1,2,3	1	F	SR 3.3.6.1.5 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 30 minutes
i. RCIC Steam Line Tunnel Differential Temperature —High	1,2,3	1	F	SR 3.3.6.1.5 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 50°F
(continued)					