

JUNE 11 1980

Docket Nos. 50-325
and 50-324

Mr. J. A. Jones
Senior Executive Vice President
Carolina Power & Light Company
336 Fayetteville Street
Raleigh, North Carolina 27602

Distribution:

✓ Docket
NRC PDR
Local PDR
ORB Reading
NRR Reading
RPurple
RTedesco
GLainas
TNovak
J01shinski
SNorris
JHannon
Attorney, OELD

OI&E (5)
BJones (8)
BScharf (10)
JWetmore
ACRS (16)
OPA (Claire Miles)
RDiggs
HRDenton
TERA
NSIC

R. Stephens

Dear Mr. Jones:

The Commission has issued the enclosed Amendment No. 28 to Facility Operating License No. DPR-71 and Amendment No. 51 to Facility Operating License No. DPR-62 for the Brunswick Steam Electric Plant (BSEP), Unit Nos. 1 and 2, respectively. These amendments consist of changes to the Technical Specifications in response to your applications dated October 25, December 27, 1976; July 28, 1977; January 18, February 2, March 6, March 21, April 13, April 27, May 1, May 29, October 8, November 7, December 31, 1979; February 5, February 20, April 1, April 11, April 22, May 21, and May 27, 1980.

The amendment for BSEP Unit No. 2 changes the Technical Specifications to establish revised safety and operating limits for operation in fuel Cycle No. 4, and revises the table of safety related hydraulic snubbers.

The amendments for BSEP Unit Nos. 1 and 2 change the Technical Specifications to (1) conform to the installed Degraded Grid Voltage Protection system, (2) provide for the End-of-Cycle Recirculation Pump Trip feature, (3) allow lowering the reactor vessel water level for extended maintenance during refueling outages, (4) reflect revisions on the corporate organizational structure, (5) change the operability test requirements for the RHR Service Water Pumps, and (6) clarify the reporting requirements in the Appendix B Environmental Technical Specifications. In addition, the language of the Reactor Protection System Instrumentation Specification was revised in accordance with our letter dated February 12, 1979. Other miscellaneous editorial changes were made to bring the BSEP Technical Specifications into conformance with the current GE STS.

Included with this amendment is Supplement No. 2 to the Fire Protection Safety Evaluation and related technical specifications which complete the staff's fire protection review for BSEP, Units 1 and 2.

8006270034

CP (see 50324 for encls.)

OFFICE						
SURNAME						
DATE						

JUNE 11 1980

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

Thomas A. Ippolito, Chief
Operating Reactors Branch #2
Division of Licensing

Enclosures:

1. Amendment No. 28 to DPR-71
2. Amendment No. 51 to DPR-62
3. Safety Evaluation
4. Supplement #2 to the Fire Protection SE
for Brunswick Steam Electric Plant Units
1 and 2
5. Notice

cc w/enclosures:
See next page

8006270-234

OFFICE	ORB #2	ORB #2	AD:DL	OELD	ORB #2	
SURNAME	SNorris:kk	JHannon	TNovak		Tippolito	
DATE	6/ /80	6/ /80	6/ /80	6/ /80	6/ /80	