

RECEIVED DOCKET FILE

Distribution

- ✓ Docket
- ORB #3
- NRR Reading
- Local PDR
- NRC PDR
- DEisenhut
- BGrimes
- WGammill
- RVollmer
- JMiller
- JShao
- TJCarter
- WRussell
- Tippolito
- JHannon
- BBottimore
- SSheppard

- Atty, OELD
- I&E (5)
- JBones
- JRBuchanan, NSIC
- TERA
- ACRS (16)

Docket Nos. 50-325 and 50-324

AUGUST 21 1979

Mr. J. A. Jones
 Executive Vice President
 Carolina Power & Light Company
 336 Fayetteville Street
 Raleigh, North Carolina 27602

Dear Mr. Jones:

Amendment No. 24 to Facility Operating License No. DPR-71 and Amendment No. 48 to Facility Operating License No. DPR-62 for the Brunswick Steam Electric Plant (BSEP), Units 1 and 2, respectively, were issued on May 2, 1979. Through an oversight, the Technical Specifications were issued with a typographical error on page 3/4 3-64 relating to the trip setpoint and allowable value for ATWS Recirculation Pump Trip System Instrumentation.

Please replace the previous page 3/4 3-64 with the enclosed corrected page, one for each unit.

Sincerely,

Original Signed by
 T. A. Ippolito ✓

Thomas A. Ippolito, Chief
 Operating Reactors Branch #3
 Division of Operating Reactors

Enclosure:
 Page 3/4 3-64

cc w/enclosure:
 See next page

CP

7909180562 60

OFFICE >	ORB #3	STSG	ORB #3		
SURNAME >	JHannon:mjf	BBottimore	Tippolito		
DATE >	8/ 179	8/ 179	8/ 179		

Mr. J. A. Jones
Carolina Power & Light Company

- 2 -

August 21, 1979

cc:

Richard E. Jones, Esquire
Carolina Power & Light Company
336 Fayetteville Street
Raleigh, North Carolina 27602

Georgia F. Trowbridge, Esquire
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

John J. Burney, Jr., Esquire
Burney, Burney, Sperry & Barefoot
110 North Fifth Avenue
Wilmington, North Carolina 28461

Mr. Franky Thomas, Chairman
Board of Commissioners
P. O. Box 249
Bolivia, North Carolina 28422

Denny McGuire (Ms)
State Clearinghouse
Division of Policy Development
116 West Jones Street
Raleigh, North Carolina 27603

Southport - Brunswick County Library
109 W. Moore Street
Southport, North Carolina 28461

Director, Technical Assessment Division
Office of Radiation Programs (AW-459)
US EPA
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection Agency
Region IV Office
ATTN: EIS COORDINATOR
345 Courtland Street, N. W.
Atlanta, Georgia 30308

TABLE 3.3.6.1-1

ATWS RECIRCULATION PUMP TRIP SYSTEM INSTRUMENTATION

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>MINIMUM NUMBER OPERABLE TRIP SYSTEMS PER OPERATING PUMP</u>
1. Reactor Vessel Water Level - Low Low, Level 2 (B21-LIS-N024 A, B; B21-LIS-N025 A, B)	1
2. Reactor Vessel Pressure-High (B21-PS-N045 A, B, C, D)	1

BRUNSWICK - UNIT 1

3/4 3-63

Amendment No. 24

TABLE 3.3.6.1-2ATWS RECIRCULATION PUMP TRIP SYSTEM INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
1. Reactor Vessel, Water Level - Low low, Level 2 (B21-LIS-N024 A, B; B21-LIS-N025 A, B)	\geq -38 inches	\geq -38 inches
2. Reactor Vessel Pressure-High (B21-PS-N045 A, B, C, D)	\leq 1120 psig	\leq 1120 psig

TABLE 3.3.6.1-1ATWS RECIRCULATION PUMP TRIP SYSTEM INSTRUMENTATION

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>MINIMUM NUMBER OPERABLE TRIP SYSTEMS PER OPERATING PUMP</u>
1. Reactor Vessel Water Level - Low Low, Level 2 (B21-LIS-N024 A, B; B21-LIS-N025, A, B)	1
2. Reactor Vessel Pressure-High (B21-PS-N045 A, B, C, D)	1

TABLE 3.3.6.1-2ATWS RECIRCULATION PUMP TRIP SYSTEM INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
1. Reactor Vessel, Water Level - Low low, Level 2 (B21-LIS-N024 A, B; B21-LIS-N025 A, B)	\geq -38 inches	\geq -38 inches
2. Reactor Vessel Pressure-High (B21-PS-N045 A, B, C, D)	\leq 1120 psig	\leq 1120 psig