Docket Nos. 50-325/324

Mr. E. E. Utley Executive Vice President Carolina Power & Light Company Post Office Box 1551 Raleigh, North Carolina 27602

Dear Mr. Utley:

CPate1 HDenton DISTRIBUTION LJHarmon Docket File NRC PDR ELJordan Local PDR TBarnhart (4) WJones ORB#2 Reading DBrinkman DEisenhut HShaw SNorris ACRS (10) MGrotenhuis OPA, CMiles SMacKay RDiggs **OELD** NSIČ SECY Extra - 5 Gray File

The Commission has issued the enclosed Amendment Nos. 69 and 95 to Facility Operating License Nos. DPR-71 and DPR-62 for the Brunswick Steam Electric Plant, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TSs) in response to your submittal of March 16, 1982 as supplemented June 23 and September 6, 1983 and February 28, 1984.

These amendments modify the Technical Specifications to add requirements regarding the operability, set point response time and surveillance of a time delay relay to be incorporated in the steamline break detection circuitry of the High Pressure Coolant Injection (HPCI) and Reactor Core Isolation Cooling (RCIC) Systems as recommended in Item II.K.3.15 of NUREG-0737, "Clarification of the TMI Action Plan Requirements." In addition, an administrative error is corrected.

In addition, an administrative correction is made to the existing Technical Specifications Table 3.3.2-2, Item 4.a.7, HPCI Steam Line Area Temperature-High.

A copy of the Safety Evaluation is also enclosed.

Sincerely,

Original signed by/

Domenic B. Vassallo, Chief Operating Reactors Branch #2 Division of Licensing



DL:SSPB DL:ORAB GHolahan* DBrinkman* 11/22/83 12/02/83 OELD ΩŖ

Mr. E. E. Utley Carolina Power & Light Company Brunswick Steam Electric Plant, Units 1 and 2

cc:

Richard E. Jones, Esquire Carolina Power & Light Company 336 Fayetteville Street Raleigh, North Carolina 27602

George F. Trowbridge, Esquire Shaw, Pittman, Potts and Trowbridge 1800 M Street, N. W. Washington, D. C. 20036

Mr. Charles R. Dietz Plant Manager Post Office Box 458 Southport, North Carolina 28461

Mr. Franky Thomas, Chairman Board of Commissioners Post Office Box 249 Bolivia, North Carolina 28422

Mrs. Chrys Baggett State Clearinghouse Budget and Management 116 West Jones Street Raleigh, North Carolina 27603

U. S. Environmental Protection Agency Region IV Office Regional Radiation Representative 345 Courtland Street, N. W. Atlanta, Georgia 30308

Resident Inspector U. S. Nuclear Regulatory Commission Star Route 1 Post Office Box 208 Southport, North Carolina 28461 James P. O'Reilly Regional Administrator Region II Office U. S. Nuclear Regulatory Commission 101 Marietta Street, Suite 3100 Atlanta, Georgia 30303

Dayne H. Browns, Chief Radiation Protection Branch Division of Facility Services Department of Human Resources Post Office Box 12200 Raleigh, North Carolina 27605



8404200035 8403 PDR ADOCK 05000

UNITED STATES

CAROLINA POWER & LIGHT COMPANY

DOCKET NO. 50-325

BRUNSWICK STEAM ELECTRIC PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 69 License No. DPR-71

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Carolina Power & Light Company (the licensee) dated March 16, 1982, as supplemented June 23 and September 6, 1983 and February 28, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-71 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 69, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

- with asso a

Domenic B. Vassallo, Chief Operating Reactors Branch #2 Division of Licensing

Attachment: Changes to the Technical Specifications

Date of Issuance: March 28, 1984.

- 2 -

ATTACHMENT TO LICENSE AMENDMENT NO. 69

FACILITY OPERATING LICENSE NO. DPR-71

DOCKET NO. 50-325

Revise the Appendix A Technical Specifications as follows:

Remove	Insert
3/4 3-14	3/4 3-14
3/4 3-14a	3/4 3-14a
3/4 3-15	3/4 3-15
3/4 3-19	3/4 3-19
3/4 3-20	3/4 3-20
3/4 3-21	3/4 3-21
3/4 3-22	3/4 3-22
3/4 3-23	3/4 3-23
3/4 3-24	3/4 3-24
3/4 3-24a	3/4 3-24a ,
3/4 3-24b	- 3/4 3-24b
3/4 3-28	3/4 3-28
3/4 3-29	3/4 3-29
3/4 3-29a	3/4 3-29a
-	3/4 3-29b

(BSEP-1-18)

:

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

BRUNS	•				TABLE 3.3.2-	l (Continued)		
VICK				<u>]</u>	SOLATION ACTUATI	ON INSTRUMENTATION		:
- UNIT	TRI	P FU	NCTIO	N AND INSTRUMENT NUMBER	VALVE GROUPS OPERATED BY SIGNAL(a)	MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(b)(c)	APPLICABLE OPERATIONAL CONDITION	ACTION
Ч	4.	CORI	STA	NDBY COOLING SYSTEMS ISOLATION	``			
		a.	Higl	h Pressure Coolant Injection System	n Isolation			
			1.	HPCI Steam Line Flow - High (E41-PDT-NOO4; E41-PDT-NOO5)	4	1	1, 2, 3	25
				(E41-PDTS-N004-2; E41-PDTS-N005-2)				
3/4 3-1			2.	HPCI Steam Line High Flow Time Delay Relay (E41-TDR-K33; E41-TDR-K43)	۰ <u>،</u> ۱ NA	. 1	1, 2, 3	25
4			3.	HPCI Steam Supply Pressure - Low (E41-PSL-NOOIA,B,C,D)	4	2	1, 2, 3	25
			4.	HPCI Steam Line Tunnel Temperature - High (E41-TS-3314; E41-TS-3315; E41-TS-3316; E41-TS-3317; E41-TS-3318;	4	2	1, 2, 3	25
				E41-TS-3354; E41-TS-3488; E41-TS-3489)				
8) 			5.	Bus Power Monitor (E41-K55 and E41-K56)	_{NA} (h)	l/bus	1, 2, 3	26
5 FO			6.	HPCI Turbine Exhaust Diaphragm Pressure - High (E41-PSH-NO12A,B,C,D)	4	2	1, 2, 3	25

,'

.

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

TRIP F	UNCTI	ON AND INSTRIMENT NUMBER	VALVE GROUPS OPERATED BY SIGNAL(a)	MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(b)(c)	APPLICABLE OPERATIONAL CONDITION	ACTION	
	7.	HPCI Steam Line Ambient Temperature - High (E51-TS-N603C,D)	4	1	1, 2, 3	25	1
	8.	HPCI Steam Line Area ∆ Temp High (E51-dTS-N604C,D)	4	1	1, 2, 3	25	•
	9.	Emergency Area Cooler Temperature - High (E41-TS-N602A,B)	4	1	1, 2, 3	25	
b.	Re a	actor Core Isolation Cooling System I	solation ·				
	1.	RCIC Steam Line Flow - High (E51-PDT-NO17; E51-PDT-NO18)	5	1	1, 2, 3	25	
		(E51-PDTS-NO17-2; E51-PDTS-NO18-2)					
	2.	RCLC Steam Line High Flow Time Delay Relay (E51-TDR-K32; E51-TDR-K12)	NA	1	1, 2, 3	25	
	3.	RCIC Steam Supply Pressure - Low (E51-PS-NO19A,B,C,D)	5	2	1, 2, 3 •	25	
	4.	RCIC Steam Line Tunnel Temperature - High (E51-TS-3319; E51-TS-3320; E51-TS-3321; E51-TS-3322; E51-TS-3323; E51-TS-3355; E51-TS-3487)	5	2	1, 2, 3	25	

.

۰..^{*}

ISOLATION ACTUATION INSTRUMENTATION

TRI	P FUNCTION	AND INSTRUMENT NUMBER	VALVE GROUPS OPERATED BY SIGNAL(a)	MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(b)(c)	APPLICABLE OPERATIONAL CONDITION	ACTION
	5.	Bus Power Monitor (E51-K42 and E51-K43)	_{NA} (h)	1/bus	1, 2, 3	26
	6.	RCIC Turbine Exhaust Diaphragm Pressure - High (E51-PS-NO12A,B,C,D)	5	2	1, 2, 3	25
	7.	RCIC Steam Line Ambient Temp - High (E51-TS-N603A,B)	5	1	1, 2, 3	25
	8.	RCIC Steam Line Area Δ Temp - High (E51-dTS-N604A,B)	5	1	1, 2, 3	25
	9.	RCIC Equipment Room Ambient Temp - High (E51-TS-N602A,B)	5	1 ;	1, 2, 3	25
	10.	RCIC Equipment Room Δ Temp - High (E51-dTS-N601A,B)	5	1	1, 2, 3	25
5. <u>-</u>	SHUTDOWN C	OOLING SYSTEM ISOLATION	• *			
ĕ	a. Reacto Low, (B21- (B21-	r Vešsel Water Level - Level 1 -LT-N017A-1,B-1,C-1,D-1) -LTM-N017A-1,B-1,C-1,D-1)	2, 6, 7, 8	2	1, 2, 3	27
b	• Reactor High (B32-	r Steam Dome Pressure- -PS-N018A,B)	7, 8	1	1, 2, 3	27

BRUNSWICK - UNIT

щ

- -

TABLE 3.3.2-2 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

TRI	P FUN	NCTION AND INSTRUMENT NUMBER	TRIP SETPOINT	VALUE
3.	REAC a.	CTOR WATER CLEANUP SYSTEM ISOLATION Δ Flow - High (G31-dFS-N603-1A,1B)	≤ 53 gal/min	<u><</u> 53 gal/min
	b.	Area Temperature - High (G31-TS-N600A,B,C,D,E,F)	<u><</u> 150°F	<u><</u> 150°F
	c.	Area Ventilation Temperature Δ Temp - High (G31-TS-N602A,B,C,D,E,F)	<u><</u> 50°F	<u><</u> 50°F
	d.	SLCS Initiation (C41A-S1)	NA	NA
	e.	Reactor Vessel Water Level - Low, Level 2 (B21-LTM-NO24A-1,B-1 and B21-LTM-NO25A-1,B-1)	<u>></u> + 112 inches*	<u>></u> + 112 inches*
4.	CORE	STANDBY COOLING SYSTEMS ISOLATION		
	а.	High Pressure Coolant Injection System Isolation HPCI Steam Line Flow - High (E41-PDTS-N004-2; E41-PDTS-N005-2) 	≤ 300% of rated flow	≤ 300% of rated flow
		2. HPCI Steam Line High Flow Time Delay Relay (E41-TDR-K33; E41-TDR-K43)	3 <u><</u> t <u><</u> 7 seconds	3 <u><</u> t <u><</u> 12 seconds
		3. HPCI Steam Supply Pressure - Low (E41-PSL-NO01A, B, C, D)	\geq 100 psig	<u>></u> 100 psig

.

69

...

4

TABLE 3.3.2-2 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

TRIP	FUNCTION	AND INSTRUMENT NUMBER	TRIP SETPOINT	ALLOWABLE
	4.	HPC1 Steam Line Tunnel Temperature - Hig (E41-TS-3314; E41-TS-3315; E41-TS-3316; E41-TS-3317; E41-TS-3318; E41-TS-3318; E41-TS-3354; E41-TS-3488; E41-TS-3489)	h <u><</u> 200°F	<u><</u> 200° F
	5.	Bus Power Monitor (E41-K55 and E41-K56)	. NA	NA.
	6.	HPCI Turbine Exhaust Diaphragm Pressure - High (E41-PSH-NO12A,B,C,D)	< 10 psig	<u><</u> 10 psig
	7.	HPCI Steam Line Ambient Temp - High (E51-TS-N603C,D)	<u><</u> 200°F	<u><</u> 200°F
	8.	HPCI Steam Line Area Δ Temp - High (E51-dTS-N604C,D)	<u><</u> 50°F	<u><</u> 50°F
	9.	Emergency Area Cooler Temp - High (E41-TS-N602A,B)	<u><</u> 175°F	<u><</u> 175°F
Ъ	. React	or Core Isolation Cooling System Isolation	on	, '
b	1.	RCIC Steam Line Flow - High (E51-PDTS-N017-2; E51-PDTS-N018-2)	≤ 300% of rated flow	\leq 300% of rated flow
	2.	RCÍC Steam Line High Flow Time Delay Relay (E51-TDR-K32; E51-TDR-K12)	$3 \leq t \leq 7$ seconds	$3 \leq t \leq 12$ seconds
	3.	RCIC Steam Supply Pressure - Low (E51-PS-NO19A, B, C, D)	> 50 psig	≥ 50 psig

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

TRI	P FUNCTION	AND INSTRUMENT NUMBER	TRIP SETPOINT	ALLOWABLE VALUE
	4.	RCIC Steam Line Tunnel Temp - High (E51-TS-3319; E51-TS-3320; E51-TS-3321; E51-TS-3322; E51-TS-3323; E51-TS-3355; E51-TS-3487)	<u><</u> 175°F	<u><</u> 175°F
	5.	Bus Power Monitor (E51-K42 and E51-K43)	NA	NA
	6.	RCIC Turbine Exhaust Diaphragm Pressure - High (E51-PS-NO12A,B,C,D)	<u><</u> 10 psig	<u><</u> 10 psig
	7.	RCIC Steam Line Ambient Temp - High (E51-TS-N603A,B)	<u><</u> 200°F	<u><</u> 200°F
	8.	RCIC Steam Line Area Δ Temp - High (E51-dTS-N604A,B)	<u><</u> 50°F	<u><</u> 50°F
	9.	RCIC Equipment Room Ambient Temp - High (E51-TS-N602A,B)	<u><</u> 175°F	<u><</u> 175°F
	10.	RCIC Equipment Room Δ Temp - High (E51-dTS-N601A,B)	<u><</u> 50°F	✓ <u>≤</u> 50° F
5.	SHUTDOWN C	COOLING SYSTEM ISOLATION		ŕ
á	a. React Low (B2	or Vessel Water Level - , Level 1 1-LTM-NO17A-1,B-1,C-1,D-1)	<u>></u> + 162.5 inches*	<u>></u> + 162.5 inches*
ł	o. React (B3	or Steam Dome Pressure - High 2-PS-NO18A,B)	<u><</u> 140 psig	<u><</u> 140 psig

BRUNSWICK - UNIT 1

* Vessel water levels refer to REFERENCE LEVEL ZERO.

TABLE 3.3.2-3

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

TR:	IP FU	INCTION AND INSTRUMENT NUMBER	RESPONSE TIME (Seconds)#
1.	PRI	MARY CONTAINMENT ISOLATION	· •
	a.	Reactor Vessel Water Level - 1. Low, Level 1 (B21-LT-NO17A-1, B-1, C-1, D-1) (B21-LTM-NO17A-1, B-1, C-1, D-1)	<u><1</u> 3
		<pre>2. Low, Level 2 (B21-L T-N024A-1, B-1 and B21-LT-N025A-1, B-1)</pre>	<u><1</u> .0*
		(B21-LTM-NO24A-1, B-1 and B21-LTM-NO25A-1, B-1)	
	b.	Drywell Pressure - High (C71-PT-NO02A,B,C,D) (C71-PTM-NO02A-1,B-1,C-1,D-1)	<u><1</u> 3
	c.	Main Steam Line 1. Radiation - High ^(b) (D12-RM-K603A,B,C,D)	<u><</u> 1.0*
		2. Pressure - Low (B21-PT-NO1 5A, B, C, D) (B21-PTM-NO1 5A-1, B-1, C-1, D-1)	<u><</u> 13
		3. Flow - High (B2 1-PDT-N006A, B, C, D; B21-PDT-N007A, B, C, D; B2 1-PDT-N008A, B, C, D; B21-PDT-N009A, B, C, D)	<u><</u> 0.5*
		(B21-PDTM-N006A-1, B-1, C-1, D-1; B21-PDTM-N007A-1, B-1, C-1, D-1; B21-PDTM-N008A-1, B-1, C-1, D-1; B21-PDTM-N009A-1, B-1, C-1, D-1;	
	đ.	Main Steam Line Tunnel Temperature - High (B21-TS-NO1OA, B, C, D; B21-TS-NO1IA, B, C, D; B21-TS-NO12A, B, C, D; B21-TS-NO13A, B, C, D)	<u><</u> 13
	е.	Condenser Vacuum - Low (B21-PT-N056A, B, C, D) (B21-PTM-N056A-1, B-1, C-1, D-1)	<u><</u> 1 3

. 7

:

•

TABLE 3.3.2-3 (Continued)

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

TRIP	FUNCTION AND INSTRUMENT NUMBER	RESPONSE TIME (Seconds	<u>)</u> #
PRIMA	RY CONTAINMENT ISOLATION (Continued)	••	_
f	 Turbine Building Area Temperature - High (B21-TS-3225A, B, C, D; B21-TS-3226A, B, C, D; B21-TS-3227A, B, C, D; B21-TS-3227A, B, C, D; B21-TS-3229A, B, C, D; B21-TS-3229A, B, C, D; B21-TS-3231A, B, C, D; B21-TS-3231A, B, C, D; B21-TS-3232A, B, C, D) 	NA	
2. <u>S</u>	ECONDARY CONTAINMENT ISOLATION		
a	. Reactor Building Exhaust Radiation - High ^(b) (D12-RM-NO10A,B)	<u><1</u> 3	
b	Drywell Pressure - High (C71-PT-N002A,B,C,D) (C71-PTM-N002A-1,B-1,C-1,D-1)	<u><1</u> 3	
C	Reactor Vessel Water Level - Low, Level 2 (B21-LT-N024A-1, B-1 and B21-LT-N025A-1, B-1) - (B21-LTM-N024A-1, B-1 and B21-LTM-N025A-1 B-1)	<u><</u> 1.0*	
3. <u>RI</u>	EACTOR WATER CLEANUP SYSTEM ISOLATION		
a.	Δ Flow - High (G31-dFS-N603-1A,1B)	<u><1</u> 3	
Ъ.	Area Temperature - High (G31-TS-N600A,B,C,D,E,F)	<u><1</u> 3	
c.	Area Ventilation Temperature AT - High (G31-TS-N602A,B,C,D,E,F)	<u><</u> 1 3	
d.	SLCS Initiation (C41A-S1)	NA	
e.	Reactor Vessel Water Level - Low, Level 2 (B21-LT-NO24 A-1,B-1 and B21-LT-NO25 A-1,B-1)	<u><1</u> .0*	
	(B21-LTM-NO24 A-1, B-1 and B21-LTM-NO25 A-1, B-1)		

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

TRI	P FUN	CTI	ON AND INSTRUMENT NUMBER	RESPONSE	TIME (Secon	nds)#
4.	CORE	STA	ANDBY COOLING SYSTEMS ISOLATION	·		
	а.	Hig 1.	th Pressure Coolant Injection System Isolation HPCI Steam Line Flow - High (E41-PDT-N004; E41-PDT-N005)		<u><</u> 13 ^{(a)##}	1
			(E41-PDTS-N004-2; E41-PDTS-N005-2)			
		2.	HPCI Steam Line High Flow Time Delay Relay (E41-TDR-K33; E41-TDR-K43)		NA	
		3.	HPCI Steam Supply Pressure - Low (E41-PSL-NOOIA, B, C, D)	. •	<u><1</u> 3	
		4.	HPCI Steam Line Tunnel Temperature - High (E41-TS-3314; E41-TS-3315; E41-TS-3316; E41-TS-3317; E41-TS-3318; E41-TS-3354; E41-TS-3488; E41-TS-3488; E41-TS-3489)		<u><</u> 13	
		5.	Bus Power Monitor (E41-K55 and E41-K56)		NA	ľ
		6.	HPCI Turbine Exhaust Diaphragm Pressure - High (E41-PSH-N012A, B, C, D)	L	NA	1
		7.	HPCI Steam Line Ambient Temperature - High (E51-TS-N603C,D)		NA	1
		8.	HPCI Steam Line Area (E51-dTS-N604C,D)		NA	İ
		9.	Emergency Area Cooler Temperature - High (E41-TS-602A,B)		NA	1
	b. 1	Read	ctor Core Isolation Cooling System Isolation			
		1.	RCIC Steam Line Flow - High (E51-PDT-N017; E51-PDT-N018)		<u><1</u> 3(a)###	
			(E51-PDTS-N017-2; E51-PDTS-N018-2)			

. 4 . 4 . 4, 7 .

·.

(BSEP-1-18)

TABLE 3.3.2-3 (Continued)

٠

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

TRIP	FUNCTION	AND INSTRUMENT NUMBER	RESPONSE TIME (S	econds)#
	2.	RCIC Steam Line High Flow Time Delay Relay (E51-TDR-K32; E51-TDR-K12)	NA	
	3.	RCIC Steam Supply Pressure - Low (E51-PS-N019A,B,C,D)	NA	1
	4.	RCIC Steam Line Tunnel Temp - High (E51-TS-3319; E51-TS-3320; E51-TS-3321; E51-TS-3322; E51-TS-3323; E51-TS-3355; E51-TS-3487)	NA	
	5.	Bus Power Monitor (E51-K42 and E51-K43)	NA	I
	6.	RCIC Turbine Exhaust Diaphragm Pressure - High (E51-PS-N012A,B,C,D)	NA	
	7.	RCIC Steam Line Ambient Temperature - High (E51-TS-N603A,B)	NA	1
	8.	RCIC Steam Line Area Δ Temp - High · (E51-dTS-N604A,B)	NA	
	9.	Emergency Area Cooler Temperature - High (E51-TS-N602A,B)	NA	
	10.	RCIC Equipment Room ∆ Temp - High (E51-dTS-N601A,B)	NA	
5. <u>s</u>	HUTDOWN C	COOLING SYSTEM ISOLATION		
а	React (B2 (B2	or Vessel Water Level - Low, Level 1 1-LT-N017A-1,B-1,C-1,D-1) 1-LTM-N017A-1,B-1,C-1,D-1)	NA	
Ь	• React (B3	or Steam Dome Pressure - High 2-PS-NO18A,B)	NA	

۰.

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

NOTES

- (a) The isolation system instrumentation response time shall be measured and recorded as a part of the ISOLATION SYSTEM RESPONSE TIME. Isolation system instrumentation response time specified includes the delay for diesel generator starting assumed in the accident analysis.
- (b) Radiation monitors are exempt from response time testing. Response time shall be measured from detector output or the input of the first electronic component in the channel.
 - * Isolation actuation instrumentation response time only.
 - # Isolation system instrumentation response time specified for the Trip Function actuating each valve group shall be added to isolation time shown in Table 3.6.3-1 and Table 3.6.5.2-1 for valves in each valve group to obtain ISOLATION SYSTEM RESPONSE TIME for each valve.
- ## Includes time delay added by the time delay relay (E41-TDR-K33 and E41-TDR-K43).
- ### Includes time delay added by the time delay relay (E51-TDR-K32 and E51-TDR-K12).

.'

••

TABLE 4.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

TRI	P FUN	CTIO	N AND INSTRUMENT NUMBER	CHANNEL CHECK	CHANNEL FUNCTIONAL TEST	CHANNEL CALIBRATION	OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED
4.	CORE	STA	NDBY COOLING SYSTEMS ISOLATION				
	a.	Hig	h Pressure Coolant Injection Sys	tem Isolatio	n		
		1.	HPCI Steam Line Flow - High (E41-PDT-NOO4; E41-PDT-NOO5)	_{NA} (a)	NA	_R (ь)	1, 2, 3
			(E41-PDTS-N004-2; E41-PDTS-N005-2)	D	, M	М	1, 2, 3
		2.	HPCI Steam Line High Flow Time Delay Relay (E41-TDR-K33; E41-TDR-K43)	NA	R	R	1, 2, 3
		3.	HPCI Steam Supply Pressure - Low (E41-PSL-NOO1A,B,C,D)	NA	М	R	1, 2, 3
		4.	HPCI Steam Line Tunnel Temperature - High (E41-TS-3314; E41-TS-3315;	NA	М	Q	1, 2, 3
			E41-TS-3316; E41-TS-3317; E41-TS-3318; E41-TS-3354; E41-TS-3488;				f
		5.	Bus Power Monitor (E41-K55 and E41-K56)	NA	R	NA	1, 2, 3
		6.	HPCI Turbine Exhaust Diaphragm Pressure - High (E41-PSH-NO12A,B,C,D)	NA	М	Q	1, 2, 3

.

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

TRIP FUNCTI	ON AND INSTRUMENT NUMBER	CHANNEL CHECK	CHANNEL FUNCTIONAL TEST	CHANNEL CALIBRATION	OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED
7.	HPCI Steam Line Ambient Temp - High (E51-TS-N603C,D)	NA	M	R	1, 2, 3
8.	HPCI Steam Line Area Δ Temp - High (E51-dTS-N604C,D)	NA	М	R	1, 2, 3
9.	Emergency Area Cooler Temp - High (E41-TS-N602A,B)	NA	, M	Q	1, 2, 3
b. Rea	actor Core Isolation Cooling Syst	tem Isolation			
1.	RCIC Steam Line Flow - High (E51-PDT-NO17; E51-PDT-NO18)	_{NA} (a)	NA	_R (b)	1, 2, 3
	(E51-PDTS-NO17-2; (E51-PDTS-NO18-2)	D	м	М	1, 2, 3
2.	RCIC Steam Line High Flow Time Delay Relay (E51-TDR-K32; E51-TDR-K12)	NA	R	R	1, 2, 3
3.	RCIC Steam Supp ly Pressure - Low (E51-PS-NO19A,B,C,D)	NA	м	Q	1, 2, 3

. •

(BSEP-1-18)

;

<u>, , ,</u>

TABLE 4.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

TRIP	FUNCTION	AND INSTRUMENT NUMBER	CHANNEL CHECK	CHANNEL FUNCTIONAL TEST	CHANNEL CALIBRATION	OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED
	4.	RCIC Steam Line Tunnel High Temperature (E51-TS-3319; E51-TS-3320; E51-TS-3321; E51-TS-3322; E51-TS-3323; E51-TS-3355; E51-TS-3487)	NA	М	R	1, 2, 3
	5.	Bus Power Monitor (E51-K42 and E51-K43)	NA I	R	NA	1, 2, 3
	6.	RCIC Turbine Exhaust Diaphragm Pressure - High (E51-PS-NO12A,B,C,D)	NA	M	R	1, 2, 3
	7.	RCIC Steam Line Ambient Temp - High (E51-TS-N603A,B)	NA	М	R	1, 2, 3
	8.	RCIC Steam Line Area Δ Temp - High (E51-dTS-N604A,B)	NA	М	R	1, 2, 3
	9.	RCIC Equipment Room Ambient Temp - High (E51-TS-N602A,B)	NA	м	Q	1, 2, 3
	10.	RCIC Equipment Room ∆ Temp - High (E51-dTS-N601A,B)	NA	м	Q	1, 2, 3

۰.

(BSEP - 1 - 18)

TABLE 4.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

1

TRIP FUNCTION AND INS	TRUMENT NUMBER	CHANNEL CHECK	CHANNEL FUNCTIONAL TEST	CHANNEL CALIBRATION	OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED
5. SHUTDOWN COOLING	SYSTEM ISOLATION				
a. Reactor Vess Low, Le (B21-LT (B21-LT	el Water Level - vel 1 -NO17A-1,B-1,C-1,D-1) M-NO17A-1,B-1,C-1,D-1)	NA(a) D	NA. M	_R (b) М	1, 2, 3
b. Reactor Stean High (B32-PS-	Reactor Steam Dome Pressure - High (B32-PS-NO18A,B)	NA	s/U ^(c) , M	R	1, 2, 3
		t			

* When handling irradiated fuel in the secondary containment.

When reactor steam pressure \geq 500 psig.

(a) The transmitter channel check is satisfied by the trip unit channel check.

- A separate transmitter check is not required.
- (b) Transmitters are exempted from the monthly channel calibration.
- (c) If not performed within the previous 31 days.

هسر



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

CAROLINA POWER & LIGHT COMPANY

DOCKET NO. 50-324

BRUNSWICK STEAM ELECTRIC PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 95 License No. DPR-62

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Carolina Power & Light Company (the licensee) dated March 16, 1982, as supplemented June 23 and September 6, 1983 and February 28, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-62 is hereby amended to read as follows:

(2) <u>Technical Specifications</u>

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 95, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

- 11. 2. 2. a. C

Domenic B. Vassallo, Chief Operating Reactors Branch #2 Division of Licensing

Attachment: Changes to the Technical Specifications

Date of Issuance: March 28, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 95

FACILITY OPERATING LICENSE NO. DPR-62

DOCKET NO. 50-324

Revise the Appendix A Technical Specifications as follows:

Remove	Insert
3/4 3-14	3/4 3-14
3/4 3-14a	3/4 3-14a
3/4 3-15	3/4 3-15
3/4 3-19	3/4 3-19
3/4 3-20	3/4 3-20
3/4 3-21	3/4 3-21
3/4 3-22	3/4 3-22
3/4 3-23	3/4 3-23
3/4 3-24	3/4 3-24
3/4 3-24a	3/4 3-24a
	3/4 3-24b
3/4 3-28	3/4 3-28
3/4 3-29	3/4 3-29
3/4 3-29a	3/4 3-29a
	•

(BSEP-2-18)

;

-

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

TRI	P FUN	CTION	AND INSTRUMENT NUMBER	VALVE GROUPS OPERATED BY SIGNAL(a)	MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(b)(c)	APPLICABLE OPERATIONAL CONDITION	ACTION	
4.	CORE	STAN	IDBY COOLING SYSTEMS ISOLATION				norrow	
	a.	High	Pressure Coolant Injection System	Isolation				
		1.	HPCI Steam Line Flow - High (E41-dPIS-NOO4 and E41-dPIS-NOO	4 5)	1	1, 2, 3	25	
		2.	HPCI Steam Line High Flow Time Delay Relay (E41-TDR-K33; E41-TDR-K43)	NA	1	1, 2, 3	25	
	• .	3.	HPCI Steam Supply Pressure - Low (E41-PSL-NO01A,B,C,D)	4	2	1, 2, 3	25	
		4.	HPCI Steam Line Tunnel Temperature - High (E41-TS-3314; E41-TS-3315; E41-TS-3316; E41-TS-3317; E41-TS-3318; E41-TS-3354; E41-TS-3488; E41-TS-3489)	4	2	1, 2, 3	25	
	5	• I	Bus Power Monitor (E41-K55 and E41-K56)	_{NA} (h)	l/bus	1, 2, 3	26	1
	6	• H	HPCI Turbine Exhaust Diaphragm Pressure - High (E41-PSH-NO12A,B,C,D)	i.	2	1, 2, 3	25	
	7	• H	IPCI Steam Line Ambient Temperature - High 4 (E51-TS-N603C,D)		1)	1, 2, 3 2	25	

(BSEP-2-18)

;

. 7

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

TRIP FUI	NCTIO	N AND INSTRUMENT NUMBER	VALVE GROUPS OPERATED BY SIGNAL(a)	MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(b)(c)	APPLICABLE OPERATIONAL CONDITION	ACTION	
	8.	HPCI Steam Line Area Δ Temp High (E51-dTS-N604C,D)	4	1	1, 2, 3	25	I
	9.	Emergency Area Cooler Temperature - High (E41-TS-N602A,B)	4	1	1, 2, 3	25	
b.	Read	ctor Core Isolation Cooling System I	solation				
	1.	RCIC Steam Line Flow - High (E51-dPIS-NO17 and E51-dPIS-NO18	5 / · · · ·	• 1	1, 2, 3	25	
. •	2.	RCIC Steam Line High Flow Time Delay Relay (E51-TDR-K32; E51-TDR-K12)	NA	1	1, 2, 3	25]
	3.	RCIC Steam Supply Pressure - Low (E51-PS-NO19A,B,C,D)	5	2	1, 2, 3	25 ·	
	4.	RCIC Steam Line Tunnel Temperature - High (E51-TS-3319; E51-TS-3320; E51-TS-3321; E51-TS-3322; E51-TS-3323; E51-TS-3355;	5	2	1, 2, 3	25	
	5.	Bus Power Monitor (E51-K42 and E51-K43)	_{NA} (h)	l/bus	1, 2, 3 2	:6	1
é	6. 1	RCIC Turbine Exhaust Diaphragm Pressure - High (E51-PS-NO12A,B,C,D)	5	2	1, 2, 3 [·] 2	5	

1

•

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

TRIE	FUNCTION	AND INSTRUMENT NUMBER	VALVE CROUPS OPERATED BY SIGNAL(a)	MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(b)(c)	APPLICABLE OPERATIONAL CONDITION	ACTION
	7.	RCIC Steam Line Ambient Temp - High (E51-TS-N603A,B)	5	1	1, 2, 3	25
	8.	RCIC Steam Line Area ∆ Temp - High (E51-dTS-N604A,B)	5	1	1, 2, 3	25
	9.	RCIC Equipment Room Ambient Temp - High (E51-TS-N602A,B)	5	1	1, 2, 3	25
	10	RCIC Equipment Room ∆ Temp - High (E51-dTS-N601A,B)	5	1	1, 2, 3	25
5.	SHUTDOWN (COOLING SYSTEM ISOLATION		e ¹		
·	a. Reacto Low, (B21 (B21	or Vessel Water Level - Level 1 -LT-N017A-1,B-1,C-1,D-1) -LTM-N017A-1,B-1,C-1,D-1)	2, 6, 7, 8	2	1, 2, 3	27
ł	•• Reacto High (B32	r Steam Dome Pressure- -PS-N018A,B)	7, 8	1	1, 2, 3	27

.....

TABLE 3.3.2-2 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

TR	IP FUN	NCTION AND INSTRUMENT NUMBER	TRIP SETPOINT	ALLOWABLE VALUE					
3.	REAC	CTOR WATER CLEANUP SYSTEM ISOLATION							
	a.	Δ Flow - High (G31-dFS-N603-1A,1B)	<u>≺</u> 53 gal/min	<u><</u> 53 gal/min					
	b.	Area Temperature - High (G31-TS-N600A,B,C,D,E,F)	<u><</u> 150°F	<u><</u> 150°F					
	c.	Area Ventilation Temperature Δ Temp - High (G31-TS-N602A,B,C,D,E,F)	<u><</u> 50°F	<u><</u> 50°F					
	d.	SLCS Initiation (C41A-S1)	': NA	NA					
	e.	Reactor Vessel Water Level - Low, Level 2 (B21-LTM-NO24A-1,B-1 and B21-LTM-NO25A-1,B-1)	<u>></u> + 112 inches*	<u>></u> + 112 inches*					
4.	CORE STANDBY COOLING SYSTEMS ISOLATION								
	a.	High Pressure Coolant Injection System Isolatio	on						
		 HPCI Steam Line Flow - High (E41-dPIS-NOO4 and E41-dPIS-NOO5) 	\leq 300% of rated flow	\leq 300% of rated flow					
		2. HPCI Steam Line High Flow Time Delay Relay (E41-TDR-K33; E41-TDR-K43)	$3 \leq t \leq 7$ seconds	$3 \leq t \leq 12$ seconds					
		3. HPCI Steam Supply Pressure - Low (E41-PSL-NOO1A, B, C, D)	\geq 100 psig	<u>></u> 100 psig					

Ν

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

TRIP F	UNCTIO	N AND INSTRUMENT NUMBER	TRIP SETPOINT	ALLOWABLE VALUE
	4.	HPCI Steam Line Tunnel Temperature - High (E41-TS-3314; E41-TS-3315; E41-TS-3316; E41-TS-3317; E41-TS-3318; E41-TS-3354; E41-TS-3488; E41-TS-3489)	<u>, <</u> 200°F	<u><</u> 200°F
	5.	Bus Power Monitor (E41-K55 and E41-K56)	' NA	NA
	6.	HPCI Turbine Exhaust Diaphragm Pressure - High (E41-PSH-N012A,B,C,D)	<u><</u> 10 psig	<u><</u> 10 psig
	7.	HPCI Steam Line Ambient Temp - High (E51-TS-N603C,D)	<u><</u> 200°F	<u><</u> 200°F
	8.	HPCI Steam Line Area Δ Temp - High (E51-dTS-N604C,D)	<u><</u> 50°F	<u><</u> 50°F
	9.	Emergency Area Cooler Temp - High (E41-TS-N602A,B)	<u><</u> 175°F	<u><</u> 175°F
b.	Reac	tor Core Isolation Cooling System Isolation		•
	1.	RCIC Steam Line Flow - High (E51-dPIS-N017 and E51-dPIS-N018)	≤ 300% of rated flow	300% of rated flow
	2.	RCIC Steam Line High Flow Time Delay Relay (E51-TDR-K32; E51-TDR-K12)	3 <u><</u> t <u><</u> 7 seconds	3 < t < 12 seconds
	3.	RCIC Steam Supply Pressure - Low (E51-PS-NO19A,B,C,D)	<u>></u> 50 psig	≥ 50 psig

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

Tf	RIP FUNCTIO	N AND INSTRUMENT NUMBER	TRIP SETPOINT	ALLOWABLE VALUE
	4.	RCIC Steam Line Tunnel Temp - High (E51-TS-3319; E51-TS-3320; E51-TS-3321; E51-TS-3322; E51-TS-3323; E51-TS-3355; E51-TS-3487)	<u>≺</u> 175°F	<u><</u> 175°F
	5.	Bus Power Monitor (E51-K42 and E51-K43)	·. NA	NA
	6.	RCIC Turbine Exhaust Diaphragm Pressure - High (E51-PS-NO12A,B,C,D)	<u>< 10 psig</u>	<u><</u> 10 psig
	7.	RCIC Steam Line Ambient Temp - High (E51-TS-N603A,B)	<u><</u> 200°F	<u><</u> 200°F
	8.	RCIC Steam Line Area ∆ Temp - High (E51-dTS-N604A,B)	<u><</u> 50°F	<u><</u> 50°F
	9.	RCIC Equipment Room Ambient Temp - High (E51-TS-N602A,B)	<u><</u> 175°F	<u><</u> 175°F
	10.	RCIC Equipment Room Δ Temp - High (E51-dTS-N601A,B)	<u><</u> 50°F	<u><</u> 50°F
5.	SHUTDOWN	COOLING SYSTEM ISOLATION		·
	a. Reac Lou (B)	tor Vessel Water Level - w, Level 1 21-LTM-NO17A-1,B-1,C-1,D-1)	<u>></u> + 162.5 inches*	<u>></u> + 162.5 inches*
	b. React (B)	tor Steam Dome Pressure - High 32-PS-NO18A,B)	<u><</u> 140 psig	<u><</u> 140 psig

BRUNSWICK -UNIT

N

.

.

5.

* Vessel water levels refer to REFERENCE LEVEL ZERO.

TABLE 3.3.2-3

.

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

TRI	P FU	NCTION AND INSTRUMENT NUMBER	RESPONSE TIME (Seconds)#
1.	PRI	MARY CONTAINMENT ISOLATION	···
	a.	Reactor Vessel Water Level - 1. Low, Level 1 (B21-LT-NO17A-1,B-1,C-1,D-1) (B21-LTM-NO17A-1,B-1,C-1,D-1)	<u><</u> 13
		<pre>2. Low, Level 2 (B21-LT-N024A-1, B-1 and B21-LT-N025A-1, B-1)</pre>	<u><</u> 1.0*
		(B21-LTM-NO24A-1,B-1 and B21-LTM-NO25A-1,B-1)	
	ь.	Drywell Pressure - High (C72-PS-N002A,B,C,D)	<u><</u> 13
	c.	Main Steam Line 1. Radiation - High(b) (D12-RM-K603A,B,C,D)	<u><</u> 1.0*
		<pre>2. Pressure - Low (B21-PT-N015A,B,C,D) (B21-PTM-N015A-1,B-1,C-1,D-1)</pre>	<u><</u> 13
		3. Flow - High (B21-PDT-N006A, B, C, D; B21-PDT-N007A, B, C, D; B21-PDT-N008A, B, C, D; B21-PDT-N009A, B, C, D)	<u><</u> 0.5*
		. (B21-PDTM-N006A-1, B-1, C-1, D-1; B21-PDTM-N007A-1, B-1, C-1, D-1; B21-PDTM-N008A-1, B-1, C-1, D-1; B21-PDTM-N009A-1, B-1, C-1, D-1)	
		<pre>4. Flow - High</pre>	<u><</u> 0.5*
c	1.	Main Steam Line Tunnel Temperature - High (B21-TS-NOIOA,B,C,D; B21-TS-NOIIA,B,C,D; B21-TS-NOI2A,B,C,D; B21-TS-NOI3A,B,C,D)	<u><</u> 13
e	•	Condenser Vacuum - Low (B21-PS-N056A,B,C,D)	<u><</u> 13

. -

••

.

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

TRI	LP FU	NCTION AND INSTRUMENT NUMBER	RESPONSE	TIME	(Seconds)#
	f.	Turbine Building Area Temperature - High (B21-TS-3225A,B,C,D; B21-TS-3226A,B,C,D; B21-TS-3227A,B,C,D; B21-TS-3228A,B,C,D; B21-TS-3229A,B,C,D; B21-TS-3230A,B,C,D; B21-TS-3231A,B,C,D; B21-TS-3232A,B,C,D)	· • •	NA 	
2.	SEC	ONDARY CONTAINMENT ISOLATION			
	a.	Reactor Building Exhaust Radiation - High ^(b) (D12-RM-N010A,B)		<u><</u> 13	
	b.	Drywell Pressure - High (C72-PS-N002A,B,C,D)		<u><</u> 13	
	c.	Reactor Vessel Water Level - Low, Level 2 (B21-LT-NO24A-1,B-1 and B21-LT-NO25A-1,B-1)		<u><</u> 1.0	*
		(B21-LTM-NO24A-1,B-1 and B21-LTM-NO25A-1,B-1)			
3.	REAC	TOR WATER CLEANUP SYSTEM ISOLATION			
	a.	Δ Flow - High (G31-dFS-N603-1A, 1B)		<u><</u> 13	
	b.	Area Temperature - High (G31-TS-N600A,B,C,D,E,F)		<u><</u> 13	
	c.	Area Ventilation Temperature ΔT - High (G31-TS-N602A,B,C,D,E,F)		<u><</u> 13	
	d.	SLCS Initiation (C41A-S1)		NA	
	e.	Reactor Vessel Water Level - Low, Level 2 (B21-LT-NO24 A-1,B-1 and B21-LT-NO25 A-1,B-1)		<u><</u> 1.0 [,]	*
		(B21-LTM-NO24 A-1, B-1 and B21-LTM-NO25 A-1, B-1)			

•

ø

۰.

. ..

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

TRI	P FUN	CTIO	N AND INSTRUMENT NUMBER	RESPONSE	TIME (Seco	onds)∦	
4.	CORE	STA	NDBY COOLING SYSTEMS ISOLATION	· .			
	a.	Hig	h Pressure Coolant Injection System Isolation				
		1.	HPCI Steam Line Flow - High (E41-dPIS-N004 and E41-dPIS-N005)		<u>≺</u> 13 ^{(a)##}		
		2.	HPCI Steam Line High Flow Time Delay Relay (E41-TDR-K33; E41-TDR-K43)		NA		
		3.	HPCI Steam Supply Pressure - Low (E41-PSL-N001A,B,C,D)		<u><</u> 13	1	
		4.	HPCI Steam Line Tunnel Temperature - High (E41-TS-3314; E41-TS-3315; E41-TS-3316; E41-TS-3317; E41-TS-3318; E41-TS-3354; E41-TS-3488; E41-TS-3489)	X	<u><</u> 13		
		5.	Bus Power Monitor (E41-K55 and E41-K56)		NA	1	
		6.	HPCI Turbine Exhaust Diaphragm Pressure - High (E41-PSH-N012A,B,C,D)		NA	1	
		7.	HPCI Steam Line Ambient Temperature - High (E51-TS-N603C,D)		NA	1	
		8.	HPCI Steam Line Area (E51-dTS-N604C,D)		NA	1	
		9.	Emergency Area Cooler Temperature - High (E41-TS-602A,B)		NA	I	
	b.	Reactor Core Isolation Cooling System Isolation					
		1.	RCIC Steam Line Flow - High (E51-dPIS-N017 and E51-dPIS-N018)		<u><</u> 13 ^{(a)###}		
		2.	RCIC Steam Line High Flow Time Delay Relay (E51-TDR-K32; E51-TDR-K12)		NA		
		3.	RCIC Steam Supply Pressure - Low (E51-PS-N019A,B,C,D)		NA	1	

.

•

Ţ'.

..

3/4 3-24

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

TRIP	FUNCTION	AND INSTRUMENT NUMBER	RESPONSE	TIME	(Seconds)#
	4.	RCIC Steam Line Tunnel Temp - High (E51-TS-3319; E51-TS-3320; E51-TS-3321; E51-TS-3322; E51-TS-3323; E51-TS-3355; E51-TS-3487)	• * •	NA	I
	5.	Bus Power Monitor (E51-K42 and E51-K43)		NA	1
	6.	RCIC Turbine Exhaust Diaphram Pressure - High (E51-PS-N012A,B,C,D)		NA	I
	7.	RCIC Steam Line Ambient Temperature - High (E51-TS-N603A,B)		NA	ł
	8.	RCIC Steam Line Area Δ Temp - High (E51-dTS-N604A,B)		NA	. 1
	9.	Emergency Area Cooler Temperature - High (E51-TS-N602A,B)		NA	1
	10.	RCIC Equipment Room Δ-Temp - High (E51-dTS-N601A,B)		NA	1
5. <u>s</u>	HUTDOWN C	OOLING SYSTEM ISOLATION			
а	. React (B2 (B2	or Vessel Water Level - Low, Level 1 1-LT-N017A-1,B-1,C-1,D-1) 1-LTM-N017A-1,B-1,C-1,D-1)		NA	
b	• React (B3	or Steam Dome Pressure - High 2-PS-N018A,B)		NA	

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

NOTES

- (a) The isolation system instrumentation response time shall be measured and recorded as a part of the ISOLATION SYSTEM RESPONSE TIME. Isolation system instrumentation response time specified includes the delay for diesel generator starting assumed in the accident analysis.
- (b) Radiation monitors are exempt from response time testing. Response time shall be measured from detector output or the input of the first electronic component in the channel.
 - * Isolation actuation instrumentation response time only.
 - # Isolation system instrumentation response time specified for the Trip Function actuating each valve group shall be added to isolation time shown in Table 3.6.3-1 and Table 3.6.5.2-1 for valves in each valve group to obtain ISOLATION SYSTEM RESPONSE TIME for each valve.
- ## Includes time delay added by the time delay relay (E41-TDR-K33 and E41-TDR-K43).
- ### Includes time delay added by the time delay relay
 (E51-TDR-K32 and E51-TDR-K12).

J

(BSEP-2-18)

TABLE 4.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

TRIP FUNCTION	AND INSTRUMENT NUMBER	CHANNEL CHECK	CHANNEL FUNCTIONAL TEST	CHANNEL CALIBRATION	OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED
4. CORE STAND	BY COOLING SYSTEMS ISOLATION				
a. High	Pressure Coolant Injection Syst	tem Isolatic	n		
1.	HPCI Steam Line Flow - High (E41-dPIS-NOO4; E41-dPIS-NOO5)	D	М	Q	1, 2, 3
2.	HPCI Steam Line High Flow Time Dolay Relay (E41-TDR-K33; E41-TDR-K43)	NA I	. R	R	1, 2, 3
3.	HPCI Steam Supply Pressure - Low (E41-PSL-NOO1A,B,C,D)	NA	М	, R	1, 2, 3
4 . I	HPCI Steam Line Tunnel Temperature - High (E41-TS-3314; E41-TS-3315; E41-TS-3316; E41-TS-3316; E41-TS-3318; E41-TS-3318; E41-TS-3354; E41-TS-3488; E41-TS-3489)	NA	М	Q	1, 2, 3
5. E	Bus Power Monitor (E41-K55 and E41-K56)	NA	R	NA	1, 2, 3
6. H	IPCI Turbine Exhaust Diaphragm Pressure - High (E41-PSH-NO12A,B.C,D)	NA	М	Q	1, 2, 3

Ν

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

TRIP	FUNCTION	AND INSTRUMENT NUMBER	CHANNEL CHECK	CHANNEL FUNCTIONAL TEST	CHANNEL CALIBRATION	OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED
	7.	HPCI Steam Line Ambient 'Temp - High (E51-TS-N603C,D)	NA	М	R	1, 2, 3
	8.	HPCI Steam Line Area Δ Temp - High (E51-dTS-N604C,D)	NA	М	R	1, 2, 3
	9.	Emergency Area Cooler Temp - High (E41-TS-N602A,B)	NA	й. М	Q	1, 2, 3
Ь	React	tor Core Isolation Cooling Syst	em Isolation	, I		
	1.	RCIC Steam Line Flow - High (E51-dPIS-NO17 and E51-dPIS-NO18)	NA	М	, Q	1, 2, 3
	2.	RCIC Steam Line High Flow Time Delay Relay (E51-TDR-K32; E51-TDR-K12)	NA	R	R	1, 2, 3
	3.	RCIC Steam Supply Pressure - Low (E51-PS-NO19A,B,C,D)	NA	M ·	Q	1, 2, 3
	4.	RCIC Steam Line Tunnel High Temperature (E51-TS-3319; E51-TS-3320; E51-TS-3321; E51-TS-3322; E51-TS-3323; E51-TS-3355; E51-TS-3487)	NA	М	R	1, 2, 3

(BSEP-2-18)

۲**.**

TABLE 4.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

TR	IP F	UNCTION	AND INSTRUMENT NUMBER	CHANNEL CHECK	CHANNEL FUNCTIONAL TEST	CHANNEL CALIBRATION	OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED
		5.	Bus Power Monitor (E51-K42 and E51-K43)	NA	R	NA	1, 2, 3
		6.	RCIC Turbine Exhaust Diaphragm Pressure - High (E51-PS-NO12A,B,C,D)	NA	М	R	1, 2, 3
		7.	RCIC Steam Line Ambient Temp - High (E51-TS-N603A,B)	NA	М	R	1, 2, 3
		8.	RCIC Steam Line Area ∆ Temp - High (E51-dTS-N604A,B)	NA	M	R	1, 2, 3
		9.	RCIC Equipment Room Ambient Temp - High (E51-TS-N602A,B)	NA	M	Q	1, 2, 3
		10.	RCIC Equipment Room ∆ Temp - High (E51-dTS-N601A,B)	NA	м	,' Q	1, 2, 3
5.	<u>SHU</u>	TDOWN C	OOLING SYSTEM ISOLATION				
	a.	React	or Vessel Water Level - Low, Level l (B21-LT-NO17A-1,B-1,C-1,D-1)	_{NA} (a)	NA	_p (b)	
	b.	Reacto	(B21-LTM-NO17A-1, B-1, C-1, D-1)	D	М	M	1, 2, 3 1, 2, 3
		1	ligh (B32-PS-NO18A,B)	NA	s/U ^(c) , м	R	1, 2, 3
* # (a)	When When The A se	handli reacto transmi parate	ng irradiated fuel in the secon r steam pressure > 500 psig. tter channel check is satisfied transmitter check is not requir	ndary contain I by the trip red.	nment. o unit channel c	heck.	· · · · · · · ·

(b) Transmitters are exempted from the monthly channel calibration.(c) If not performed within the previous 31 days.

.

ŝ



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

SUPPORTING AMENDMENT NO. 69 TO FACILITY LICENSE NO. DPR-71 AND

AMENDMENT NO. 95 TO FACILITY LICENSE NO. DPR-62

CAROLINA POWER & LIGHT COMPANY

BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2

DOCKET NOS. 50-325 AND 50-324

1.0 Introduction

By letter dated March 16, 1982, as supplemented June 23 and September 6, 1983 and February 28, 1984, the Carolina Power & Light Company (the licensee) submitted proposed changes to the Technical Specifications appended to Facility Operating License Nos. DPR-71 and DPR-62 for the Brunswick Steam Electric Plant (BSEP), Units 1 and 2.

The staff issued its notice of the proposed license amendment in the Federal Register on August 23, 1983, prior to receiving CP&L's revised requests of June 23 and September 9, 1983 and February 28, 1984. In that notice the staff proposed a determination of no significant hazards consideration.

The June 23, 1983 submittal was in response to the NRC Generic Letter 83-02 dated January 10, 1983 which contained guidance in the form of model Technical Specifications and recommended instrument response times. Although the changes were fully described in the June 23, 1983 submittal, inadvertently the implementing Technical Specification pages pertaining to II.K.3.15 were omitted from the June 23, 1983 submittal. This omission was corrected by the September 9, 1983 submittal. During the staff review, discussions with the licensee made it apparent that the method used to incorporate the time delays into response times was incorrect. This was corrected in the February 28, 1984 submittal.

Based on the above discussion we conclude that the changes subsequently proposed are consistent with the August 23, 1983 notice. The notice pointed out that the changes were necessary adminsistrative follow up actions essential to the implementation of II.K.3.15 as previously approved. The changes by the subsequent amendments are consistent in that they are insignificant changes to the time delay numbers and still within the guidance limits provided in NUREG-0737, are similarly adminstrative and fall well within the scope of that notice. Therefore, the staff's previously proposed determination of no significant hazards consideration remains valid.



These amendments would modify the Technical Specifications to correct an erroneous instrument number and add requirements regarding the operability, set point response time and surveillance of a time delay relay to be incorporated in the steam line break detection circuitry of the High Pressure Coolant Injection (HPCI) and Reactor Core Isolation Cooling (RCIC) Systems as recommended in Item II.K.3.15 of NUREG-0737, "Clarification of the TMI Action Plan Requirements." The technical review of TMI Action Item II.K.3.15 was completed with the NRC letter dated July 28, 1982 to the licensee which transmitted the staff Safety Evaluation. That Safety Evaluation is incorporated by reference. This amendment administratively incorporates the changes approved by the Safety Evaluation dated July 28, 1982.

In addition, an administrative correction would be made to the existing Technical Specifications Table 3.3.2-2, Item 4.a.7, HPCI Steam Line Area Temperature-High.

2.0 Requirement as Stated in NUREG-0737

The high-pressure coolant injection (HPCI) and reactor core isolation cooling (RCIC) systems use differential pressure sensors on elbow taps in the steam lines in their turbine drives to detect and isolate pipe breaks in the systems. The pipe break detection circuitry has resulted in spurious isolation of the HPCI and RCIC systems due to the pressure spike which accompanies startup of the systems. The pipe-break-detection circuitry should be modified so that pressure spikes resulting from HPCI and RCIC system initiation will not cause inadvertent system isolation.

3.0 Evaluation of Modifications

The licensee has proposed a 3 to 7-second time delay range based on the model Technical Specifications provided as guidance in Generic Letter 83-02 dated January 10, 1983. Tests of the installed relay at plants using the time delay relays have shown that a 3-second delay is sufficient to prevent spurious isolation. Delay times up to 13 seconds could be allowed without violating the design bases for the HPCI/RCIC isolation systems. This is because the design bases assume that the DC power isolation valve fails and that no offsite AC power is available to the AC valve. The diesel-generator start sequence is assumed by the licensee to require 10 seconds. As noted in footnote "a" to pages 3/4 3-24 of the proposed TS change, the 13-second specification includes the delay for diesel generator starting. We have reviewed the licensee proposal and based on the above, we find that the proposed specification acceptable for items 4.a.1 and 4.b.1 of Tables 3.3.2-1, 3.3.2-2, 3.3.2-3, and 4.3.2-1 of the Technical Specifications for BSEP Units 1 and 2.

3.0 Environmental Considerations

We have determined that the amendments do not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendments involve an action which is insignificant from the standpoint of environmental impact and pursuant to 10 CFR 51.5(d)(4), that an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of these amendments.

4.0 Conclusions

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: L. L. Wheeler and M. Grotenhuis

Dated: March 28, 1984