

November 28, 1983

Docket Nos. 50-325 and 50-324

Mr. E. E. Utley
Executive Vice President
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27062

Dear Mr. Utley:

DISTRIBUTION

Docket File
NRC PDR
Local PDR
ORB#2 Reading
DEisenhut
SMackKay
MGrotenhuis
SNorris
OELD
SECY
Gray File

Extra - 5
HDenton
NSIC
LJHarmon
ELJordan
JMTaylor
TBarnhart (4)
WJones
DBrinkman
JCarter
DHoffman
ACRS (10)
OPA, CMiles
RDiggs

The Commission has issued the enclosed Amendment Nos. 58 and 84 to Facility Operating License Nos. DPR-71 and DPR-62 for the Brunswick Steam Electric Plant, Units 1 and 2. The amendments consist of changes to the Technical Specifications in response to your submittal of December 13, 1982.

The amendments change the Technical Specifications to correct an administrative discrepancy that exists between the actual Brunswick plant design/configuration and the Technical Specifications for certain High Pressure Coolant Injection System and Reactor Core Isolation Cooling System isolation actuation instruments.

A copy of the related Safety Evaluation is also enclosed.

Sincerely,



Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Enclosures:

- 1. Amendment No. 58 to DPR-71
- 2. Amendment No. 84 to DPR-62
- 3. Safety Evaluation

cc w/enclosures:

See next page

DM
ORB#2:DL
MGrotenhuis:dk
11/16/83

SM
ORB#2:DL
SMackKay
11/16/83

DLH
SSPB:DL
DHoffman
11/16/83

DM
ORB#2:DL
DVassallo
11/16/83

J
AD:DR:DL
GLinas
11/21/83

DLH
OELD
11/18/83
[Signature]

ORB#2:DL
SNorris
11/16/83

DLH
SSPB:DL
DBRINKMAN
11/16/83

Mr. E. E. Utley
Carolina Power & Light Company
Brunswick Steam Electric Plant, Units 1 and 2

cc:

Richard E. Jones, Esquire
Carolina Power & Light Company
336 Fayetteville Street
Raleigh, North Carolina 27602

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. Charles R. Dietz
Plant Manager
Post Office Box 458
Southport, North Carolina 28461

Mr. Franky Thomas, Chairman
Board of Commissioners
Post Office Box 249
Bolivia, North Carolina 28422

Mrs. Chrys Baggett
State Clearinghouse
Budget and Management
116 West Jones Street
Raleigh, North Carolina 27603

U. S. Environmental Protection
Agency
Region IV Office
Regional Radiation Representative
345 Courtland Street, N. W.
Atlanta, Georgia 30308

Resident Inspector
U. S. Nuclear Regulatory Commission
Star Route 1
Post Office Box 208
Southport, North Carolina 28461

James P. O'Reilly
Regional Administrator
Region II Office
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dayne H. Browns, Chief
Radiation Protection Branch
Division of Facility Services
Department of Human Resources
Post Office Box 12200
Raleigh, North Carolina 27605



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

CAROLINA POWER & LIGHT COMPANY

DOCKET NO. 50-325

BRUNSWICK STEAM ELECTRIC PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 58
License No. DPR-71

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Carolina Power & Light Company (the licensee) dated December 13, 1982 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-71 is hereby amended to read as follows:


8312090123 831128
PDR ADOCK 05000324
PDR

2. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 58, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Attachment:
Changes to the
Technical Specifications

Date of Issuance: November 28, 1983

ATTACHMENT TO LICENSE AMENDMENT NO. 58

FACILITY OPERATING LICENSE NO. DPR-71

DOCKET NO. 50-325

Revise the Appendix A Technical Specifications as follows:

Remove

3/4 3-14
3/4 3-14a

Insert

3/4 3-14
3/4 3-14a

TABLE 3.3.2-1 (Continued)

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>		<u>VALVE GROUPS OPERATED BY SIGNAL(a)</u>	<u>MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(b)(c)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
4. CORE STANDBY COOLING SYSTEMS ISOLATION					
a. High Pressure Coolant Injection System Isolation					
1.	HPCI Steam Line Flow - High (E41-dPIS-NO04 and E41-dPIS-NO05)	4	1	1, 2, 3	25
2.	HPCI Steam Supply Pressure - Low (E41-PSL-NO01A,B,C,D)	4	2	1, 2, 3	25
3.	HPCI Steam Line Tunnel Temperature - High (E41-TS-3314; E41-TS-3315; E41-TS-3316; E41-TS-3317; E41-TS-3318; E41-TS-3354; E41-TS-3488; E41-TS-3489)	4	2	1, 2, 3	25
4.	Bus Power Monitor (E41-K55 and E41-K56)	NA ^(h)	1/bus	1, 2, 3	26
5.	HPCI Turbine Exhaust Diaphragm Pressure - High (E41-PSH-NO12A,B,C,D)	4	2	1, 2, 3	25
6.	HPCI Steam Line Ambient Temperature - High (E51-TS-N603C,D)	4	1	1, 2, 3	25
7.	HPCI Steam Line Area Δ Temp. - High (E51-dTS-N604C,D)	4	1	1, 2, 3	25
8.	Emergency Area Cooler Temperature - High (E41-TS-N602A,B)	4	1	1, 2, 3	25

TABLE 3.3.2-1 (Continued)

<u>ISOLATION ACTUATION INSTRUMENTATION</u>				
<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>VALVE GROUPS OPERATED BY SIGNAL(a)</u>	<u>MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(b)(c)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
b. Reactor Core Isolation Cooling System Isolation				
1. RCIC Steam Line Flow - High (E51-dPIS-N017 and E51-dPIS-N018)	5	1	1, 2, 3	25
2. RCIC Steam Supply Pressure - Low (E51-PS-N019A,B,C,D)	5	2	1, 2, 3	25
3. RCIC Steam Line Tunnel Temperature - High (E51-TS-3319; E51-TS-3320; E51-TS-3321; E51-TS-3322; E51-TS-3323; E51-TS-3355; E51-TS-3487)	5	2	1, 2, 3	25
4. Bus Power Monitor (E51-K42 and E51-K43)	NA (h)	1/bus	1, 2, 3	26
5. RCIC Turbine Exhaust Diaphragm Pressure - High (E51-PS-N012A,B,C,D)	5	2	1, 2, 3	25
6. RCIC Steam Line Ambient Temp - High (E51-TS-N603A,B)	5	1	1, 2, 3	25
7. RCIC Steam Line Area Δ Temp - High (E51-dTS-N604A,B)	5	1	1, 2, 3	25
8. RCIC Equipment Room Ambient Temp - High (E51-TS-N602A,B)	5	1	1, 2, 3	25
9. RCIC Equipment Room Δ Temp - High (E51-dTS-N601A,B)	5	1	1, 2, 3	25



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

CAROLINA POWER & LIGHT COMPANY

DOCKET NO. 50-324

BRUNSWICK STEAM ELECTRIC PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 84
License No. DPR-62

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Carolina Power & Light Company (the licensee) dated December 13, 1982 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-62 is hereby amended to read as follows:

8312090125 831128
PDR ADOCK 05000324
P PDR

2. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 84, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Attachment:
Changes to the
Technical Specifications

Date of Issuance: November 28, 1983

ATTACHMENT TO LICENSE AMENDMENT NO. 84

FACILITY OPERATING LICENSE NO. DPR-62

DOCKET NO. 50-324

Revise the Appendix A Technical Specifications as follows:

Remove

3/4 3-14
3/4 3-14a

Insert

3/4 3-14
3/4 3-14a

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>VALVE GROUPS OPERATED BY SIGNAL(a)</u>	<u>MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(b)(c)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
4. CORE STANDBY COOLING SYSTEMS ISOLATION				
a. High Pressure Coolant Injection System Isolation				
1. HPCI Steam Line Flow - High (E41-dPIS-N004 and E41-dPIS-N005)	4	1	1, 2, 3	25
2. HPCI Steam Supply Pressure - Low (E41-PSL-N001A,B,C,D)	4	2	1, 2, 3	25
3. HPCI Steam Line Tunnel Temperature - High (E41-TS-3314; E41-TS-3315; E41-TS-3316; E41-TS-3317; E41-TS-3318; E41-TS-3354; E41-TS-3488; E41-TS-3489)	4	2	1, 2, 3	25
4. Bus Power Monitor (E41-K55 and E41-K56)	NA ^(h)	1/bus	1, 2, 3	26
5. HPCI Turbine Exhaust Diaphragm Pressure - High (E41-PSH-N012A,B,C,D)	4	2	1, 2, 3	25
6. HPCI Steam Line Ambient Temperature - High (E51-TS-N603C,D)	4	1	1, 2, 3	25
7. HPCI Steam Line Area Δ Temp. - High (E51-dTS-N604C,D)	4	1	1, 2, 3	25
8. Emergency Area Cooler Temperature - High (E41-TS-N602A,B)	4	1	1, 2, 3	25

TABLE 3.3.2-1 (Continued)

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>		<u>VALVE GROUPS OPERATED BY SIGNAL(a)</u>	<u>MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(b)(c)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
b. Reactor Core Isolation Cooling System Isolation					
1.	RCIC Steam Line Flow - High (E51-dPIS-N017 and E51-dPIS-N018)	5	1	1, 2, 3	25
2.	RCIC Steam Supply Pressure - Low (E51-PS-N019A,B,C,D)	5	2	1, 2, 3	25
3.	RCIC Steam Line Tunnel Temperature - High (E51-TS-3319; E51-TS-3320; E51-TS-3321; E51-TS-3322; E51-TS-3323; E51-TS-3355; E51-TS-3487)	5	2	1, 2, 3	25
4.	Bus Power Monitor (E51-K42 and E51-K43)	NA (h)	1/bus	1, 2, 3	26
5.	RCIC Turbine Exhaust Diaphragm Pressure - High (E51-PS-N012A,B,C,D)	5	2	1, 2, 3	25
6.	RCIC Steam Line Ambient Temp - High (E51-TS-N603A,B)	5	1	1, 2, 3	25
7.	RCIC Steam Line Area Δ Temp - High (E51-dTS-N604A,B)	5	1	1, 2, 3	25
8.	RCIC Equipment Room Ambient Temp - High (E51-TS-N602A,B)	5	1	1, 2, 3	25
9.	RCIC Equipment Room Δ Temp - High (E51-dTS-N601A,B)	5	1	1, 2, 3	25



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
SUPPORTING AMENDMENT NO. 58 TO FACILITY LICENSE NO. DPR-71 AND
AMENDMENT NO. 84 TO FACILITY LICENSE NO. DPR-62
CAROLINA POWER & LIGHT COMPANY
BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2
DOCKET NOS. 50-325 AND 50-324

1.0 Introduction

By letter dated December 13, 1982, the Carolina Power & Light Company (the licensee) submitted proposed changes to the Technical Specifications appended to Facility Operating License Nos. DPR-71 and DPR-62 for the Brunswick Steam Electric Plant (BSEP), Units 1 and 2. The proposed changes revise the Technical Specifications to reflect a change in the identified number of operable channels per trip system for the following different functions, all related to "Isolation Actuation Instrumentation": (1) High Pressure Coolant Injection (HPCI) Steam Line Flow - High, (2) HPCI Steam Line Ambient Temperature - High, (3) HPCI Steam Line Area Differential Temperature - High, (4) Emergency Area Cooler Temperature - High, (5) Reactor Core Isolation Cooling (RCIC) Steam Line Flow - High, (6) RCIC Steam Line Ambient Temperature - High, (7) RCIC Steam Line Area Differential Temperature - High, (8) RCIC Equipment Room Ambient Temperature - High, and (9) RCIC Equipment Room Differential Temperature - High. The changes are administrative in nature and correct the technical specifications so they will represent the plant as it is today, and as it was designed and constructed. The changes will provide consistency in the use of terms and numbers on a table in the technical specification which presents the various trip functions, the minimum number of operable channels per trip system, and other unchanged requirements.

2.0 Evaluation

Each of the nine identified proposed changes would change the "minimum number of operable channels per trip system" from "2" to "1". The proposed changes do not involve either the addition, deletion or modification of plant instrumentation. The change is purely one of clarification of terminology, i.e., administrative.

In each of the nine functions, two switches are provided. Each of these switches supplies a signal to one of two logic systems. Therefore, the proper description for each function is that there is one channel for each of two logic systems, either of which is able to provide the required protective action. Therefore, the change is acceptable since it correctly states the instrument arrangement actually in existence.

3.0 Environmental Consideration

We have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR 51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

4.0 Conclusion

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors:

J. Carter
D. Hoffman

Dated: November 28, 1983