

July 8, 1985

DO NOT REMOVE

*Posted
Amdt. 85
to DPR-71*

Docket Nos. 50-325/324

Mr. E. E. Utley
Executive Vice President
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Dear Mr. Utley:

The Commission has issued the enclosed Amendment Nos. 85 and 111 to Facility Operating License Nos. DPR-71 and DPR-62 for the Brunswick Steam Electric Plant, Units 1 and 2. The amendments consist of changes to the Technical Specifications in response to your submittal of March 6, 1985.

The amendments change the Technical Specifications (TS) for Unit 1 with regard to Tables 3.3.5.3-1 and 4.3.5.3-1 (Accident Monitoring Instrumentation) and Section 3/4.6.2.1 (Suppression Chamber) to incorporate the inclusion of a suppression pool temperature monitoring system (SPTMS) which meets the acceptance criteria of NUREG-0661, Appendix A. The channel check for item 4.3.5.3-1.4 is being changed from monthly to daily to provide consistency with TS 4.6.2.1.d.1 for Unit 1 and Unit 2. In addition, TS sections 3/4.6.2.1 and 3/4.6.4.1 (Drywell-Suppression Chamber Vacuum Breakers) have been modified to more closely conform to the guidance of the BWR-4 Standard Technical Specifications (STS), NUREG-0123. The other Unit 2 change is made to eliminate redundancy in Surveillance Requirement 4.6.2.1.b.2.b.

A copy of the Safety Evaluation is also enclosed.

Sincerely,

Original signed by/

Marshall Grotenhuis, Project Manager
Operating Reactors Branch #2
Division of Licensing

Enclosures: *see 50-324*

1. Amendment No. 85 to License No. DPR-71
2. Amendment No. 111 to License No. DPR-62
3. Safety Evaluation

cc w/enclosures:
See next page

DISTRIBUTION

Docket File
NRC PDR
Local PDR
ORB#2 Reading
HThompson

Feltawila
SNorris
MGrotenhuis
OELD
LJHarmon
ELJordan

BGrimes
TBarnhart (8)
WJones
MVirgilio
ACRS (10)

OPA, CMiles
RDiggs
Gray File
Extra - 5
JPartlow

DL:ORB#2
SNorris:ajs
06/28/85

DL:ORB#2
MGrotenhuis
06/21/85

DL:ORB#2
DVassallo
06/28/85

J. Harman
OELD
07/1/85

DL:AD-OR
GLamas
06/18/85

Mr. E. E. Utley
Carolina Power & Light Company
Brunswick Steam Electric Plant, Units 1 and 2

cc:

Richard E. Jones, Esquire
Carolina Power & Light Company
336 Fayetteville Street
Raleigh, North Carolina 27602

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. Charles R. Dietz
Plant Manager
Post Office Box 458
Southport, North Carolina 28461

Mr. Franky Thomas, Chairman
Board of Commissioners
Post Office Box 249
Bolivia, North Carolina 28422

Mrs. Chrys Baggett
State Clearinghouse
Budget and Management
116 West Jones Street
Raleigh, North Carolina 27603

Resident Inspector
U. S. Nuclear Regulatory Commission
Star Route 1
Post Office Box 208
Southport, North Carolina 28461

J. Nelson Grace
Regional Administrator
Region II Office
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dayne H. Brown, Chief
Radiation Protection Branch
Division of Facility Services
Department of Human Resources
Post Office Box 12200
Raleigh, North Carolina 27605