



*Pacific Gas and
Electric Company*

James R. Becker
Station Director

Diablo Canyon Power Plant
Mail Code 104/5/504
P.O. Box 56
Avila Beach, CA 93424

805.545.3462
Fax: 805.545.4234

January 15, 2002

PG&E Letter DCL-02-003

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Docket No. 50-275, DPR-80
Docket No. 50-323, DPR-82
Diablo Canyon Units 1 and 2
Monthly Operating Report for December 2001

Dear Commissioners and Staff:

Attached is the Monthly Operating Report for Diablo Canyon Power Plant, Units 1 and 2, for December 2001. This report is submitted in accordance with Technical Specification 5.6.4 and NRC Generic Letter 97-02.

Sincerely,

James R. Becker

cc: Robert D. Glynn, Jr.
Kurt Larson
Barbara Lewis
Ellis W. Merschoff
David L. Proulx
Girija S. Shukla
Gregory M. Rueger
INPO Record Center

Enclosures

LMP/1713/R0227863

IE 24

**DECEMBER 2001, OPERATION SUMMARIES
DIABLO CANYON POWER PLANT
UNITS 1 AND 2**

Summary of Unit 1 Operation

Unit 1 began December in Mode 1 (Power Operation), at approximately 100 percent power. On December 20, 2001, as a precaution for forecasted high ocean swells and ocean debris, operators reduced power to approximately 20 percent. On December 21, 2001, operators returned the unit to approximately 100 percent power.

Summary of Unit 2 Operation

Unit 2 began December in Mode 1 at approximately 100 percent power. On December 20, 2001, as a precaution for forecasted high ocean swells and ocean debris, operators reduced power to approximately 20 percent. On December 21, 2001, operators returned the unit to approximately 100 percent power.

Actuations of Safety or Pressurizer Power Operated Relief Valves

There were no challenges to the pressurizer power operated relief valves, pressurizer safety valves, or steam generator safety valves.

OPERATING DATA REPORT

DOCKET NO.: 50-275
UNIT NAME: Diablo Canyon Unit 1
DATE: 01/02/2002
COMPLETED BY: L. Parker
TELEPHONE: (805) 545-3386

REPORT MONTH: December 2001

1.	Design Electrical Rating (MWe - Net):	1103
2.	Maximum Dependable Capacity (MWe - Net):	1087

		This Month	YTD	Cumulative
3.	Number of Hours Reactor Critical:	744.0	8760.0	127420.0
4.	Number of Hours Generator On-Line:	744.0	8708.5	126042.3
5.	Unit Reserve Shutdown Hours:	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWH):	812620	9504586	130158089

UNIT SHUTDOWNS

DOCKET NO.: 50-275
UNIT NAME: Diablo Canyon Unit 1
DATE: 01/02/2002
COMPLETED BY: L. Parker
TELEPHONE: (805) 545-3386

REPORT MONTH: December 2001

NO.	DATE	TYPE F (Forced) S (Scheduled)	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE & CORRECTIVE ACTIONS COMMENTS
N/A						There were no shutdowns this month.

1. Reason

A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training/License Examination
F- Administrative
G-Operational Error (Explain)
H-Other (Explain)

2. Method

1-Manual
2-Manual Trip/Scram
3-Automatic Trip/Scram
4-Continuation from Previous Month
5-Other

OPERATING DATA REPORT

DOCKET NO.: 50-323
UNIT NAME: Diablo Canyon Unit 2
DATE: 01/02/2002
COMPLETED BY: L. Parker
TELEPHONE: (805) 545-3386

REPORT MONTH: December 2001

1.	Design Electrical Rating (MWe - Net):	1119
2.	Maximum Dependable Capacity (MWe - Net):	1087

		This Month	YTD	Cumulative
3.	Number of Hours Reactor Critical:	744.0	8122.0	122681.8
4.	Number of Hours Generator On-Line:	744.0	8052.6	121224.0
5.	Unit Reserve Shutdown Hours:	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWH):	805038	8658372	127405932

UNIT SHUTDOWNS

DOCKET NO.: 50-323
UNIT NAME: Diablo Canyon Unit 2
DATE: 01/02/2002
COMPLETED BY: L. Parker
TELEPHONE: (805) 545-3386

REPORT MONTH: December 2001

NO.	DATE	TYPE F (Forced) S (Scheduled)	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE & CORRECTIVE ACTIONS COMMENTS
N/A						There were no shutdowns this month.

1. Reason

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F- Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

2. Method

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation from Previous Month
- 5-Other