

December 29, 1989

Mr. W. G. Hairston, III
Senior Vice President -
Nuclear Operations
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

Dear Mr. Hairston:

SUBJECT: ISSUANCE OF AMENDMENT NO. 105 TO FACILITY OPERATING LICENSE NPF-5 -
EDWIN I. HATCH NUCLEAR PLANT, UNIT 2 (TAC 75024)

The Commission has issued the enclosed Amendment No. 105 to Facility Operating License NPF-5 for the Edwin I. Hatch Nuclear Plant, Unit 2. The amendment consists of changes to the Technical Specifications (TS) in response to your application dated September 18, 1989.

The amendment reduces the TS Minimum Critical Power Ratio (MCPR) safety limit for Unit 2 from the current value of 1.07 to 1.04 for two-loop operation and from 1.08 to 1.05 for single-loop operation, and in addition, changes the associated Bases.

A copy of our related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register Notice.

Sincerely,

Original Signed By:

Lawrence P. Crocker, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 105 to NPF-5
- 2. Safety Evaluation

cc w/ enclosures:
See next page

OFC	: LA: PDII-3	: PM: PDII-3	: SRXB	: OGD	: D: PDII-3	:
---	: <i>ni</i>	: <i>12/1/89/MLC</i>	: <i>HR</i>	: <i>12/1/89</i>	: <i>12/1/89</i>	:
NAME	: RIngram	: LCrocker:cb	: HRichings	: <i>MLC</i>	: DMatthews	:
---	: <i>12/1/89</i>	: <i>12/1/89</i>	: <i>12/1/89</i>	: <i>12/1/89</i>	: <i>12/1/89</i>	:
DATE	: 11/21/89	: 11/22/89	: 11/22/89	: 12/4/89	: 11/28/89	:

OFFICIAL RECORD COPY
Document Name: HATCH AMEND 75024

Handwritten notes:
OGD...
STATE...
12/21/89
12
9501
111
CP-1

Mr. W. G. Hairston, III
Georgia Power Company

Edwin I. Hatch Nuclear Plant,
Units Nos. 1 and 2

cc:

Shaw, Pittman, Potts and Trowbridge
2300 N Street, N. W.
Washington, D.C. 20037

Mr. R. P. McDonald
Executive Vice President -
Nuclear Operations
Georgia Power Company
P.O. Box 1295
Birmingham, Alabama 35201

Mr. J. T. Beckham
Vice President - Plant Hatch
Georgia Power Company
P.O. Box 1295
Birmingham, Alabama 35201

Mr. Alan R. Herdt, Chief
Project Branch #3
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. S. J. Bethay
Manager Licensing - Hatch
Georgia Power Company
P.O. Box 1295
Birmingham, Alabama 35201

Mr. H. C. Nix
General Manager, Nuclear Plant
Georgia Power Company
Route 1, Box 439
Baxley, Georgia 31513

Resident Inspector
U.S. Nuclear Regulatory Commission
Route 1, Box 725
Baxley, Georgia 31513

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, Suite 2900
Atlanta, Georgia 30323

Mr. Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, S.W.
Atlanta, Georgia 30334

Mr. J. Leonard Ledbetter, Director
Environmental Protection Division
Department of Natural Resources
205 Butler Street, S.E., Suite 1252
Atlanta, Georgia 30334

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513

DATED December 29, 1989

AMENDMENT NO. 105 TO FACILITY OPERATING LICENSE NPF-5 EDWIN I. HATCH, UNIT 2

DISTRIBUTION:

Docket File

NRC PDR

Local PDR

PDII-3 R/F

Hatch R/F

S. Varga	14-E-4
G. Lainas	14-H-3
D. Matthews	14-H-25
R. Ingram	14-H-25
L. Crocker	14-H-25
D. Hagan	MNBB-3302
T. Meek (4)	P1-137
W. Jones	P-130A
ACRS (10)	P-135
OGC-WF	15-B-18
ARM/LFMB	AR-2015
GPA/PA	17-F-2
E. Butcher	11-F-23
L. Reyes	R11
E. Jordan	MNBB-3302
H. Richings	8-E-23

OF01
1/1



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

GEORGIA POWER COMPANY
OGLETHORPE POWER CORPORATION
MUNICIPAL ELECTRIC AUTHORITY OF GEORGIA
CITY OF DALTON, GEORGIA
DOCKET NO. 50-366
EDWIN I. HATCH NUCLEAR PLANT, UNIT NO. 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 105
License No. NPF-5

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Edwin I. Hatch Nuclear Plant, Unit 2 (the facility) Facility Operating License No. NPF-5 filed by Georgia Power Company, acting for itself, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, and City of Dalton, Georgia (the licensee) dated September 18, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9001050067 891229
PDR ADOCK 05000366
P PIC

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-5 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 105, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 29, 1989

ATTACHMENT TO LICENSE AMENDMENT NO. 105

FACILITY OPERATING LICENSE NO. NPF-5

DOCKET NO. 50-366

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove Pages

2-1
B 2-1
B 2-4
B 3/4 2-3

Insert Pages

2-1
B 2-1
B 2-4
B 3/4 2-3

2.0 SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

2.1 SAFETY LIMITS

THERMAL POWER (Low Pressure or Low Flow)

2.1.1 THERMAL POWER shall not exceed 25% of RATED THERMAL POWER with the reactor vessel steam dome pressure less than 785 psig or core flow less than 10% of rated flow.

APPLICABILITY: CONDITIONS 1 and 2.

ACTION:

With THERMAL POWER exceeding 25% of RATED THERMAL POWER and the reactor vessel steam dome pressure less than 785 psig or core flow less than 10% of rated flow, be in at least HOT SHUTDOWN within 2 hours.

THERMAL POWER (High Pressure and High Flow)

2.1.2 The MINIMUM CRITICAL POWER RATIO (MCPR) shall not be less than 1.04 for two-loop recirculation or 1.05 for single-loop recirculation operation with the reactor vessel steam dome pressure greater than 785 psig and core flow greater than 10% of rated flow.

APPLICABILITY: CONDITIONS 1 AND 2.

ACTION:

With MCPR less than 1.04 for two-loop recirculation or 1.05 for single-loop recirculation operation and the reactor vessel steam dome pressure greater than 785 psig and core flow greater than 10% of rated flow, be in at least HOT SHUTDOWN within 2 hours.

REACTOR COOLANT SYSTEM PRESSURE

2.1.3 The reactor coolant system pressure, as measured in the reactor vessel steam dome, shall not exceed 1325 psig.

APPLICABILITY: CONDITIONS 1, 2, 3 and 4.

ACTION:

With the reactor coolant system pressure, as measured in the reactor vessel steam dome, above 1325 psig, be in at least HOT SHUTDOWN with reactor coolant system pressure \leq 1325 psig within 2 hours.

2.1 SAFETY LIMITS

BASES

2.0 The fuel cladding, reactor pressure vessel and primary system piping are the principal barriers to the release of radioactive materials to the environs. Safety Limits are established to protect the integrity of these barriers during normal plant operations and anticipated transients. The fuel cladding integrity Safety Limit is set such that no fuel damage is calculated to occur if the limit is not violated. Because fuel damage is not directly observable, a step-back approach is used to establish a Safety Limit such that the MCPR is not less than 1.04 for two-loop operation and 1.05 for single-loop operation. These limits represent a conservative margin relative to the conditions required to maintain fuel cladding integrity. The fuel cladding is one of the physical barriers which separate the radioactive materials from the environs. The integrity of this cladding barrier is related to its relative freedom from perforations or cracking. Although some corrosion or use related cracking may occur during the life of the cladding, fission product migration from this source is incrementally cumulative and continuously measurable. Fuel cladding perforations, however, can result from thermal stresses which occur from reactor operation significantly above design conditions and the Limiting Safety System Settings. While fission product migration from cladding perforation is just as measurable as that from use related cracking, the thermally caused cladding perforations signal a threshold beyond which still greater thermal stresses may cause gross rather than incremental cladding deterioration. Therefore, the fuel cladding Safety Limit is defined with a margin to the conditions which would produce onset of transition boiling, MCPR of 1.0. These conditions represent a significant departure from the condition intended by design for planned operation.

The evaluations which justify normal operation, abnormal transient, and accident analyses for two-loop operation are discussed in detail in Reference 3. Evaluation for single-loop operation demonstrates that two-loop transient and accident analyses are more limiting than single-loop, Reference 4.

2.1.1 THERMAL POWER (Low Pressure or Low Flow)

The use of the GEXL correlation is not valid for all critical power calculations at pressures below 785 psig or core flows less than 10% of rated flow. Therefore, the fuel cladding integrity Safety Limit is established by other means. This is done by establishing a limiting condition on core THERMAL POWER with the following basis. Since the pressure drop in the bypass region is essentially all elevation head, the core pressure drop at low power and flows will always be greater than 4.5 psi. Analyses show that with a bundle flow of 28×10^3 lbs/hr, bundle pressure drop is nearly independent of bundle power and has a value of 3.5 psi. Thus, the bundle flow with a 4.5 psi driving head will be greater than 28×10^3 lbs/hr. Full scale ATLAS test data taken at pressures from 14.7 psia to 800 psia indicate that the fuel assembly critical power at this flow is approximately 3.35 MWt. With the design peaking factors, this corresponds to a THERMAL POWER of more than 50% of RATED THERMAL POWER. Thus, a THERMAL POWER limit of 25% of RATED THERMAL POWER for reactor pressure below 785 psig is conservative.

Bases Table B 2.1.2-1

UNCERTAINTIES USED IN THE DETERMINATION
OF THE FUEL CLADDING SAFETY LIMIT*

<u>Quantity</u>	<u>Standard Deviation (% of Point)</u>
Feedwater Flow	1.76
Feedwater Temperature	0.76
Reactor Pressure	0.5
Core Inlet Temperature	0.2
Core Total Flow	2.5
Channel Flow Area	3.0
Friction Factor Multiplier	10.0
Channel Friction Factor Multiplier	5.0
TIP Readings	8.7
R Factor	1.5
Critical Power	3.6

*The uncertainty analysis used to establish the core wide Safety Limit MCPR is based on the assumption of quadrant power symmetry for the reactor core.

POWER DISTRIBUTION LIMITS

BASES

3/4.2.2 APRM SETPOINTS

This section deleted.

3/4.2.3 MINIMUM CRITICAL POWER RATIO

The required operating limit MCPRs at steady state operating conditions as specified in Specification 3.2.3 are derived from the established fuel cladding integrity Safety Limit MCPR of 1.04 for two-loop operation and 1.05 for single-loop operation, and an analysis of abnormal operational transients as described in References 1 and 3. For any abnormal operating transient analysis evaluation with the initial condition of the reactor being at the steady state operating limit, it is required that the resulting MCPR does not decrease below the Safety Limit MCPR at any time during the transient assuming instrument trip setting as given in Specification 2.2.1.

To assure that the fuel cladding integrity Safety Limits are not exceeded during any anticipated abnormal operational transient, the most limiting transients have been analyzed to determine which results in the largest reduction in CRITICAL POWER RATIO (CPR). The type of transients evaluated were loss of flow, increase in pressure and power, positive reactivity insertion, and coolant temperature decrease.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

SUPPORTING AMENDMENT NO. 105 TO

FACILITY OPERATING LICENSE NPF-5

GEORGIA POWER COMPANY
OGLETHORPE POWER CORPORATION
MUNICIPAL ELECTRIC AUTHORITY OF GEORGIA
CITY OF DALTON, GEORGIA

EDWIN I. HATCH NUCLEAR PLANT, UNIT 2

DOCKET NO. 50-366

1.0 INTRODUCTION

By letter dated September 18, 1989, Georgia Power Company (the licensee) requested changes to the Technical Specification (TS) Minimum Critical Power Ratio (MCPR) safety limit for the Edwin I. Hatch Nuclear Plant, Unit 2. The requested changes would reduce the MCPR safety limit from its current value of 1.07 to 1.04 for two-loop operation and from 1.08 to 1.05 for single-loop operation, and in addition would change the associated Bases.

2.0 EVALUATION

For Cycle 8 operation of Hatch Unit 2, the licensee loaded fuel manufactured by General Electric (GE) having a high bundle R-factor (≥ 1.04). In order to achieve the maximum economic benefit from each fuel cycle, the licensee intends to load a second consecutive batch of high bundle R-factor fuel (≥ 1.04) for Cycle 9.

Using NRC-approved codes and methods, GE previously determined that the appropriate MCPR safety limit for fuel with a high initial R-factor is 1.04. The NRC staff documented its concurrence with the GE analysis in a December 27, 1987, Safety Evaluation Report (SER) for "General Electric Standard Application for Reactor Fuel" (GESTAR-II), NEDE-24011-P-A, Amendment 14. This SER approved the use of a 1.04 MCPR safety limit for two-loop operation using fuel with a high bundle R-factor and the use of a 0.01 adder to the two-loop MCPR safety limit for single-loop operation.

GE has confirmed that the reload fuel batches for both Cycle 8 and Cycle 9 of Hatch Unit 2 have bundle R-factors ≥ 1.04 , and that the previously approved MCPR safety limits of 1.04 for two-loop operation and 1.05 for single-loop operation are applicable for Cycle 9 operation of Hatch Unit 2. The licensee has stated that it will confirm that the reduced MCPR safety limits are still applicable for fuel loaded in subsequent reload batches, i.e., for Cycle 10 and beyond.

9001050068 891229
PDR ADDCK 05000366
P PDC

On the basis of the staff's previous approval for use of reduced MCPR safety limits when using fuel with an initial bundle R-factor ≥ 1.04 , and the assurance by the licensee that the reload fuel batches for Cycle 8 and Cycle 9 had initial bundle R-factors ≥ 1.04 , we find acceptable the licensee's proposal to reduce the MCPR safety limits from 1.07 to 1.04 for two-loop operation and from 1.08 to 1.05 for single-loop operation. In addition, the change placing these new values in the related Bases is acceptable.

3.0 ENVIRONMENTAL CONSIDERATION

This amendment involves changes in a requirement with respect to the installation or use of facility components located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

4.0 CONCLUSION

The Commission made a proposed determination that the amendment involves no significant hazards consideration which was published in the Federal Register on November 1, 1989 (54 FR 46149), and consulted with the State of Georgia. No public comments were received, and the State of Georgia did not have any comments.

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Lawrence P. Crocker, PDII-3/DRP-I/II

Dated: December 29, 1989