April 7, 1988

Docket No. 50-366

Mr. George F. Head Senior Vice President Georgia Power Company P.O. Box 4545 Atlanta, Georgia 30302

Dear Mr. Head:

SUBJECT: CORRECTION TO AMENDMENT NO. 91 FOR E. I. HATCH NUCLEAR PLANT, UNIT 2 (TAC 66947)

My letter dated March 12, 1988, forwarded Amendment No. 91 to Facility Operating License No. NPF-5 for the E. I. Hatch Nuclear Plant, Unit 2. Please replace page 3/4 3-15 which was forwarded with that letter with the enclosed revised page 3/4 3-15.

Sincerely,

Original signed by:

Lawrence P. Crocker, Project Manager Project Directorate II-3 Division of Reactor Projects - I/II

Enclosure: As stated

cc: See next page

DISTRIBUTION: Docket File NRC PDR Local PDR PDII-3 Reading Hatch Reading S. Varga G. Lainas M. Rood L. Crocker D. Hagan	E. Jordan J. Partlow T. Barnhart Wanda Jones E. Butcher ACRS (10) GPA/PA ARM/LFMB OGC-WF	(4)
LA; PDI I-3 MR00d 4/7/88 8804130298	M PM:PDII-3 LCrocker:pw 4/7/88 4 BB0407 05000366	M PD:PDII-3 Acting PD 7/88

Mr. George F. Head Georgia Power Company Edwin I. Hatch Nuclear Plant, Units Nos. 1 and 2

cc:

G. F. Trowbridge, Esq. Shaw, Pittman, Potts and Trowbridge 2300 N Street, N. W. Washington, D.C. 20037

Mr. L. T. Gucwa Engineering Department Georgia Power Company P. O. Box 4545 Atlanta, Georgia 30302

Nuclear Safety and Compliance Manager Edwin I. Hatch Nuclear Plant Georgia Power Company P. O. Box 442 Baxley, Georgia 31513

Mr. Louis B. Long Southern Company Services, Inc. P. O. Box 2625 Birmingham, Alabama 35202

Resident Inspector U.S. Nuclear Regulatory Commission Route 1, Box 725 Baxley, Georgia 31513

Regional Administrator, Region II U.S. Nuclear Regulatory Commission 101 Marietta Street, Suite 2900 Atlanta, Georiga 30323

Mr. Charles H. Badger Office of Planning and Budget Room 610 270 Washington Street, S.W. Atlanta, Georgia 30334

Mr. J. Leonard Ledbetter, Commissioner Department of Natural Resources 270 Washington Street, N.W. Atlanta, Georgia 30334

Chairman Appling County Commissioners County Courthouse Baxley, Georgia 31513

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION RUMENTATION

ACTION

- ACTION 20 Be in at least HOT SHUTDOWN within 6 hours and in COLD SHUTDOWN within the next 30 hours.
- ACTION 21 Be in at least STARTUP with the main steam line isolation values closed within 2 hours or be in at least HOT SHUTDOWN within 6 hours and in COLD SHUTDOWN within the next 30 hours.
- ACTION 22 Be in at least STARTUP within 2 hours,
- ACTION 23 He in at least STARTUP with the Group 1 isolation valves closed within 2 hours or in at least HOT SHUTDOWN within 6 hours.
- ACTION 24 Establ'sh SECONDARY CONTAINMENT INTEGRITY with the standby gas treatment system operating within one hour.
- ACTION 25 Isolate the reactor water cleanup system.
- ACTION 26 Close the affected system isolation valves and declare the affected system inoperable.
- ACTION 27 Verify power availability to the bus at least once per 12 hours or close the affected system isolation valves and declare the affected system inoperable.
- ACTION 28 Close the shutdown cooling supply and reactor vessel head spray isolation valves unless reactor steam dome pressure & 145 paig.
- ACTION 29 Either close the affected isolation valves within 24 hours or be in HOT SHUTDOWN within the next 5 hours and in COLD SHUTDOWN within the next 30 hours.

NOTES

- , **'**# Actuates the standby gas treatment system.
 - ** When handling irradiated fuel in the secondary containment.
- When performing inservice hydrostatic or leak testing with the reactor coolant temperature above 212* F.
- See Specification 3.6.3, Table 3.6.3-1 for valves in each valve group. .
- A channel may be placed in an inoperable status for up to 2 hours for required surveillance without placing the trip system in the tripped condition provided at least one other OPERABLE channel in the same trip Ь. system is monitoring that parameter.
- With a design providing only one channel per trip system, an inoperable channel need not be placed in the tripped condition where this would cause C. the Trip Function to occur. In these cases, the inoperable channel shall be restored to OPERABLE status within 2 hours or the ACTION required by Table 3.3.2-1 for that Trip Function shall be taken.
- d. Trips the mechanical vacuum pumps.
- A channel is OPERABLE if 2 of 4 instruments in that channel are OPERABLE.
- May be bypassed with all turbing stop valves closed. f.
- ۹. Closes only RWCU outlet isolation valve 2031-F004.
- h. Alarm only.
- Adjustable up to 60 minutes. 1.
- Isolates containment purge and vent valves. .t.

dithin 24 hours prior to the planned start of the hydrogen injection test with the reactor power at greater than 20% rated power, the normal fullk. Dower radiation background level and associated trip setpoints may be changed based on a calculated value of the radiation level expected during the test. The background radiation level and associated trip setpoints may be adjusted during the test based on either calculations or measurements of actual radiation levels resulting from hydrogen injection. The background radiation level shall be determined and associated trip setpoints shall be set within 24 hours of re-establishing normal radiation levels after completion of hydrogen injection and prior to establishing reactor power levels below 20% rated power.

HATCH + UNIT 2

8804130304 880407

PDR

ADOCK 05000366

PDR