

2.C.(9) The steam generator tube inspection surveillance requirements of Technical Specification 4.4.5.3 have been extended until the start of cycle 17, not to exceed January 31, 2001. In the event the steam generators are replaced prior to the start of cycle 17, the retired steam generators are exempted from further surveillance under T/S 4.4.5.3.

2.C.(10) Technical Specification surveillance requirements 4.6.5.3.1.b.3, 4.6.5.3.1.b.4, and 4.6.5.3.1.b.5 need not be performed until prior to ascension into Mode 4 at the completion of the fuel cycle 18 refueling outage. If Unit 1 enters Mode 5 for sufficient duration prior to the fuel cycle 18 refueling outage, I&M will perform the surveillance testing required by TS 4.6.5.3.1.b.3, 4.6.5.3.1.b.4, and 4.6.5.3.1.b.5.

2.D Physical Protection

The licensee shall fully implement and maintain in effect all provisions of the Commission-approved physical security, guard training and qualification, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The plans, which contain Safeguards Information protected under 10 CFR 73.21, are entitled: "Donald C. Cook Nuclear Plant Security Plan," with revisions submitted through July 21, 1988; "Donald C. Cook Nuclear Plant Training and Qualification Plan," with revisions submitted through December 19, 1986; and "Donald C. Cook Nuclear Plant Safeguards Contingency Plan," with revisions submitted through June 10, 1988. Changes made in accordance with 10 CFR 73.55 shall be implemented in accordance with the schedule set forth therein.

2.E. Deleted.

2.F. Deleted

2.G In all places of this license, the reference to the Indiana and Michigan Electric Company is amended to read Indiana Michigan Power Company.

2.H System Integrity

The licensee shall implement a program to reduce leakage from systems outside containment that would or could contain highly radioactive fluids during a serious transient or accident to as low as practical levels. This program shall include the following:

1. Provisions establishing preventive maintenance and periodic visual inspection requirements, and
2. Integrated leak test requirements for each system at a frequency not to exceed refueling cycle intervals.