April 26, 1985 - DMB 016

Docket No. 50-366

Mr. J. T. Beckham, Jr. Vice President - Nuclear Generation Georgia Power Company P. O. Box 4545 Atlanta, Georgia 30302

Dear Mr. Beckham:

By letter dated March 18, 1985, the Commission issued Amendment No. 45 to Facility Operating License No. NPF-5 for the Edwin I. Hatch Nuclear Plant, Unit No. 2. This amendment revised the Technical Specifications (TSs) to make them consistent with the guidelines provided in the NRC's Generic Letter 83-36 concerning a number of NUREG-0737 Items. Due to a collating error, this amendment inadvertently omitted TS page 3/4 3-54a. To correct this error, TS page 3/4 3-54a is enclosed for incorporation into your TSs. We apologize for any inconvenience this may have caused.

Sincerely,

THE STATE OF THE S

George W. Rivenbark, Project Manager Operating Reactors Branch #4 Division of Licensing

> BGrimes WJones

EButcher

RDiggs JPartlow

Enclosure: TS page 3/4 3-54a

cc w/enclosure: See next page

DISTRIBUTION
Docket File
NRC PDR
L PDR
ORB#4 Rdg
HThompson
OELD

HThompson SECY
OELD RIngram
CMiles Gray File+4
LHarmon GRivenbark
ACRS-10 EJordan
TBarnhart-4

8505070062 850426 PDR ADDCK 05000366 PDR ADDCK 05000366

ORB#4:DL/~ RIngram;cf 4/14/85 ORB#4:DL/ GRivenbark 4/1/85 ORB#4:DL JSto\z 4// /85 cc w/enclosure(s):

G. F. Trowbridge, Esq. Shaw, Pittman, Potts and Trowbridge 1800 M Street, N. W. Washington, D. C. 20036

Ruble A. Thomas Vice President P. O. Box 2625 Southern Company Services, Inc. Birmingham, Alabama 35202

Louis B. Long Southern Company Services, Inc. P. O. Rox 2625 Birmingham, Alabama 35202

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513

Mr. L. T. Gucwa Georgia Power Company Engineering Department P. O. Box 4545 Atlanta, Georgia 30302

Mr. H. C. Nix, Jr. General Manager Edwin I. Hatch Nuclear Plant Georgia Power Company P. O. Box 442 Baxley, Georgia 31513 Regional Radiation Representative EPA Region IV 345 Courtland Street, N. E. Atlanta, Georgia 30308

Resident Inspector
U. S. Nuclear Regulatory Commission
Route 1, P. O. Box 279
Baxley, Georgia 31513

Dr. J. Nelson Grace, Regional Administrator U. S. Nuclear Regulatory Commission Region II 101 Marietta Street, Suite 2900 Atlanta, Georgia 30303

Charles H. Badger Office of Planning and Budget Poom 610 270 Washington Street, S. W. Atlanta, Georgia 30334

J. Leonard Ledbetter, Commissioner Department of Natural Resources 270 Washington Street, N. W. Atlanta, Georgia 30334

- (a) If either the primary or secondary indication is inoperable, the torus temperature will be monitored at least once per shift to observe any unexplained temperature increases which might be indicative of an open SRV. With both the primary and secondary monitoring channels of an SRV inoperable, either verify that the S/RV is closed through monitoring the backup low low set logic position indicators (2B21-N302 A-H and K-M) at least once per shift or restore sufficient inoperable channels such that no more than one SRV has both primary and secondary channels inoperable within 7 days or be in at least hot shutdown within the next 12 hours.
- (b) With the number of operable channels less than required by the minimum channels operable requirements, initiate the preplanned alternate method of monitoring the appropriate parameters within 72 hours and:
 - (1) either restore the inoperable channel(s) to operable status within 7 days of the event, or
 - (2) prepare and submit a Special Report to the NRC pursuant to Specification 6.9.2 within 14 days following the event outlining the action taken, the cause of the inoperability, and the plans and schedule for restoring the system to operable status.
- A channel contains two detectors: one for mid-range noble gas and one for high range noble gas. detectors must be operable to consider the channel operable.