

MAR 28 1973

Docket No. 50-261

Carolina Power & Light Company  
ATTN: Mr. E. E. Utley  
Vice President  
Bulk Power Supply Department  
336 Fayetteville Street  
Raleigh, North Carolina 27602

Change No. 14  
License No. DPR-23

Gentlemen:

By letter dated March 14, 1973, you submitted an application for a change to the Technical Specifications appended to License No. DPR-23, as amended, for Unit No. 2 at the H. B. Robinson Steam Electric Plant. The proposed change would increase the frequency of surveillance of the boron concentration in the boron injection tank.

We have reviewed your application for the proposed change and have designated our action as Change No. 14. We conclude that Change No. 14 does not present significant hazards considerations not described or implicit in the Safety Analysis Report and that there is reasonable assurance that the health and safety of the public will not be endangered.

Pursuant to 10 CFR Part 50, Section 50.59, the Technical Specifications appended to Facility Operating License No. DPR-23 are changed as shown in Attachment A.

Sincerely,

Original Signed by  
D. J. Skovholt

Donald J. Skovholt  
Assistant Director for  
Operating Reactors  
Directorate of Licensing

Enclosure:  
see next page

14

Carolina Power & Light  
Company

- 2 -

MAR 28 1973

Enclosure:  
Attachment A - Change No. 14  
to the Technical Specifications

cc w/enclosure:  
George F. Trowbridge, Esquire  
Shaw, Pittman, Potts, Trowbridge  
& Madden  
910 - 17th Street, N. W.  
Washington, D. C. 20006

DISTRIBUTION

Docket File  
AEC PDR  
Local PDR  
RP Reading File  
Branch Reading File  
D. J. Skovholt, L:OR  
J. R. Buchanan, ORNL  
T. W. Laughlin, DTIE  
EPA (3)  
ACRS (16)  
RO (3)  
OGC  
R. J. Schemel, L:OR-1  
T. J. Carter, L:OR  
R. W. Woodruff, L:OR-1 (2)  
S. A. Teets, L:OR-1  
N. Dube, L:OPS  
M. Jinks, DRA (4)

OFFICE ▶	L:OR-1 x-7434	L:OR-1	L:OR-1	L:OR		
SURNAME ▶	RWoodruff:dc	SA Teets	RJSchemel	DJSkovholt		
DATE ▶	3/27/73	3/27/73	3/28/73	3/28/73		

ATTACHMENT A

CHANGE NO. 14 TO THE TECHNICAL SPECIFICATIONS

CAROLINA POWER & LIGHT COMPANY

DOCKET NO. 50-261

The following changes are to be made in Section 4.0, Table 4.1-2, Item 5 of the Technical Specifications:

1. Under the heading, "Frequency", change "Monthly" to "Weekly<sup>(6)</sup>".
2. Under the heading, "Maximum Time Between Tests", change "45 days" to "10 days".
3. Add the following note:

"(6) The boron concentration in the boron injection tank shall be checked immediately after any actuation of the safety injection system that might result in dilution of the boron concentration in the boron injection tank."

OFFICE ►						
SURNAME ►						
DATE ►						

MAR 28 1973

Files (Robinson-2, Docket No. 50-261) Original signed by  
THRU: R. J. Schemel, Chief, ORB #1 Robert J. Schemel

SAFETY EVALUATION FOR CHANGE NO. 14

Our memo to files dated February 27, 1973, discusses the need for increased surveillance of the boron concentration in the boron injection tank. Carolina Power & Light, in their application for Change No. 14, propose significant additional surveillance which will reduce the likelihood of violation of the limiting condition for operation regarding boron concentration.

We conclude that Change No. 14 does not present significant hazards considerations not described or implicit in the Safety Analysis Report and that there is reasonable assurance that the health and safety of the public will not be endangered.

151

R. W. Woodruff  
Operating Reactors Branch #1  
Directorate of Licensing

OFFICE ▶						
SURNAME ▶						
DATE ▶						