

FEB 19 1973

Docket No. 50-261

Carolina Power & Light Company
ATTN: Mr. E. E. Utley
Vice President
Bulk Power Supply Department
336 Fayetteville Street
Raleigh, North Carolina 27602

Change No. 12
License No. DPR-23

Gentlemen:

By letter dated February 1, 1973, you submitted an application for a change to the Technical Specifications appended to License No. DPR-23, as amended, for Unit No. 2 at the H. B. Robinson Steam Electric Plant. The proposed change would decrease the surveillance frequency for certain nuclear instrumentation, require additional staff, modify the membership of the Plant Safety Committee, and make certain editorial changes.

We have reviewed your application for the proposed change and have designated our action as Change No. 12. We conclude that Change No. 12 does not present significant hazards considerations not described or implicit in the Safety Analysis Report and that there is reasonable assurance that the health and safety of the public will not be endangered.

Pursuant to 10 CFR Part 50, Section 50.59, the Technical Specifications appended to Facility Operating License No. DPR-23 are changed as shown in Attachment A.

Sincerely,

Original Signed by
D. J. Skovholt

Donald J. Skovholt
Assistant Director for
Operating Reactors
Directorate of Licensing

Enclosure: see next page

KE

FEB 19 1973

Enclosure:

Attachment A - Change No. 12
to the Technical Specifications

cc w/enclosure:

George F. Trowbridge, Esquire
Shaw, Pittman, Potts, Trowbridge & Madden
910 - 17th Street, N. W.
Washington, D. C. 20006DISTRIBUTIONDocket File
AEC PDR
Local PDR
RP Reading
Branch Reading
JRBuchanan
TWLaughlin
DJSkovholt
TJCarter
RJSchemel
RWWoodruff (2)
SATEets
RO (3)
OGC
ACRS (16)
EPA (3)
N. Dube
M. Jinks (4)

OFFICE ▶	L:OR-1	L:OR-1	L:OR-1	L:OR		
SURNAME ▶	x-7434 RWWoodruff:dc	SATEets for	RJSchemel	DJSkovholt		
DATE ▶	2/15/73	2/16/73	2/16/73	2/16/73		

ATTACHMENT A

CHANGE NO. 12 TO THE TECHNICAL SPECIFICATIONS

CAROLINA POWER & LIGHT COMPANY

DOCKET NO. 50-261

The following changes are to be made in the Technical Specifications:

1. Section 4.0, Table 4.1-1, Item 1

- (a) Change the item under the column entitled "Calibrate" to read:

D(1) M*(3) M*(3)
A/R*(3)

- (b) In the key at the end of the table, delete:

"A/P - After each startup if not done previous week" and replace with:

"A/R - After each refueling startup".

2. Section 6.0, Paragraph 6.1.3.1

- (a) Add the following new subparagraph after subparagraph d:

"e. Administrative Supervisor

Six years of responsible power plant experience with a minimum of two years' nuclear power plant experience is required. A maximum of four years may be fulfilled by academic training in an engineering discipline or equivalent."

- (b) Change subparagraph "e", "f", "g", and "h" to "f", "g", "h", and "i".

OFFICE ►						
SURNAME ►						
DATE ►						

- (c) Add the following new subparagraph "j".

"j. Training Coordinator

Five years of responsible power plant experience with a minimum of one year nuclear power plant experience is required. A maximum of four years may be fulfilled by academic training in an engineering discipline or equivalent. Experience and training normally required for examination by the AEC for a Senior Reactor Operators' License (whether or not examination is taken) is required."

3. Section 6.0, Paragraph 6.1.4.1

- (a) Change items 1 and 3 in subparagraph "a" to read:

"1. Chairman: Plant Manager "

"3. Secretary: Administrative Supervisor"

- (b) In subparagraph "b", delete the last words that read:

" . . . and in 6.1.4.2, part b.6."

4. Section 6.1

- (a) In the following paragraphs change the title of "Plant Superintendent" to "Plant Manager" and "Manager-Bulk Power Supply Department" to "Vice President-Bulk Power Supply Department"

Paragraph 6.1.1

" 6.1.2
" 6.1.3.1.a
" 6.1.4.1.a.1
" 6.1.4.1.f.1
" 6.1.4.1.g.2
" 6.1.4.1.g.2.a
" 6.1.4.2.a.5

OFFICE ►						
SURNAME ►						
DATE ►						

FEB 19 1973

Files (Robinson-2, Docket No. 50-261)

THRU: R. J. Schemel, Chief, ORB #1, L

SAFETY EVALUATION FOR CHANGE NO. 12

The licensee's application adequately supports Change No. 12. We conclude that Change No. 12 does not present significant hazards considerations not described or implicit in the Safety Analysis Report and that there is reasonable assurance that the health and safety of the public will not be endangered.

/s/ R. W. Woodruff
Operating Reactors Branch #1
Directorate of Licensing

OFFICE ►						
SURNAME ►						
DATE ►						