

MAR 2 1982

Docket No. 50-261

Mr. J. A. Jones, Vice Chairman
Carolina Power and Light Company
336 Fayetteville Street
Raleigh, North Carolina 27602

Dear Mr. Jones:

The Commission has issued the enclosed Amendment No. 62 to Facility Operating License No. DPR-23 for the H. B. Robinson Steam Electric Plant, Unit No. 2. The amendment consists of changes to the Technical Specifications in response to your application transmitted by letter dated January 27, 1982.

The amendment revises the Technical Specifications to identify three existing hydraulic snubbers that have been included in the snubber surveillance program although not previously listed as being safety related.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

(51)

W. J. Ross, Project Manager
Operating Reactors Branch #1
Division of Licensing


Enclosures:

1. Amendment No. 62 to DPR-23
2. Safety Evaluation
3. Notice of Issuance

cc: w/enclosures
See next page

Distribution:
 Docket File
 NRC PDR
 Local PDR
 ORB #1 Rdg
 D. Eisenhut
 C. Parrish
 OELD
 SECY
 OI&E (1)
 TBarnhart
 L. Schneider
 D. Brinkman

ACRS (10)
 OPA
 R. Diggs
 NSIC
 ASLAB



8203110336 820302
 PDR ADOCK 05000261
 P PDR

FR NOTICE
 + AMENDMENT
 ONLY

OFFICE	DL:ORB#1	DL:ORB#1	DL:ORB#1	DL:OR	OELD		
SURNAME	WRoss/ms	CParrish	SAVarga	LNoyak	M. KARMA		
DATE	2/19/82	2/22/82	2/22/82	2/21/82	2/21/82		

Mr. J. A. Jones
Carolina Power and Light Company

cc: G. F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

James P. O'Reilly
Regional Administrator - Region II
101 Marietta Street Suite 3100
Atlanta, Georgia 30303

Hartsville Memorial Library
Home and Fifth Avenues
Hartsville, South Carolina 29550

Mr. McCuen Morrell, Chairman
Darlington County Board of Supervisors
County Courthouse
Darlington, South Carolina 29535

State Clearinghouse
Division of Policy Development
116 West Jones Street
Raleigh, North Carolina 27603

Attorney General
Department of Justice
Justice Building
Raleigh, North Carolina 27602

U. S. Nuclear Regulatory Commission
Resident Inspector's Office
H. B. Robinson Steam Electric Plant
Route 5, Box 266-1A
Hartsville, South Carolina 29550

Michael C. Farrar, Chairman
Atomic Safety and Licensing
Appeal Board Panel
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Richard S. Salzman
Atomic Safety and Licensing
Appeal Board Panel
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. W. Reed Johnson
Atomic Safety and Licensing
Appeal Board Panel
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Regional Radiation Representatives
EPA Region IV
345 Courtland Street, N.E.
Atlanta, Georgia 30308



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

CAROLINA POWER AND LIGHT COMPANY

DOCKET NO. 50-261

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 62
License No. DPR-23

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Carolina Power and Light Company (the licensee) dated January 27, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-23 is hereby amended to read as follows:

(B) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 62, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 2, 1982

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 62 TO FACILITY OPERATING LICENSE NO. DPR-23

DOCKET NO. 50-261

Revise Appendix A as follows:

Remove Pages

3.13-4

Insert Pages

3.13-4

Table 3.13-1 (cont'd)
SAFETY RELATED HYDRAULIC SNUBBERS

<u>Snubber No.</u>	<u>Location</u>	<u>Elevation</u>	<u>Snubbers in High Radiation Area During Shutdown*</u>	<u>Snubbers Especially Difficult to Remove</u>	<u>Snubbers Inaccessible During Normal Operation</u>	<u>Snubbers Accessible During Normal Operation</u>
21	RWST to RHR Pumps	222'				X
22	RWST to RHR Pumps	222'				X
23	Charging Line Loop 2 Cold Leg	239'				X
24	Charging Line Loop 2 Cold Leg	239'				X
25	Auxiliary Spray Line	241'				X
26	Letdown to Non-regen- erative Heat Exchanger	229'				X
27	Charging Pumps Discharge Line	234'				X
28	"A" Feedwater Line	254'				X
29	"B" Feedwater Line	250'				X
30	Steam Supply to Auxiliary Feed- water Pump	257'				X

*Modifications to this table due to changes in high radiation areas should be submitted to the NRC as part of the next license amendment.

3.13-4

Amendment No. 62



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 62 TO FACILITY OPERATING LICENSE NO. DPR-23

CAROLINA POWER AND LIGHT COMPANY

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

DOCKET NO. 50-261

Introduction

By letter dated January 27, 1982, Carolina Power and Light Company (the licensee) requested that three existing snubbers be added to the list of safety related hydraulic snubbers in Table 3.13-1. This list identifies those snubbers that are required to perform their intended functions during all modes of operation.

Evaluation

Two of the snubbers identified by the licensee are in feedwater lines and the other is related to the steam supply to the auxiliary feedwater pump. These snubbers have been reclassified as safety related; however, they have been routinely tested as part of the snubber surveillance program. This action assures that the three snubbers will continue to be inspected and is, therefore, acceptable.

Environmental Consideration

We have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR §51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

Conclusion

We have concluded, based on the considerations discussed above, that: (1) because the amendment does not involve a significant increase in the probability or consequences of accidents previously considered and does not involve a significant decrease in a safety margin, the amendment does not involve a significant hazards consideration, (2) there is reasonable

assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: March 2, 1982

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-261CAROLINA POWER AND LIGHT COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 62 to Facility Operating License No. DPR-23 issued to Carolina Power and Light Company (the licensee), which revised Technical Specifications for operation of the H. B. Robinson Steam Electric Plant, Unit No. 2 (the facility) located in Darlington County, South Carolina. The amendment is effective as of the date of issuance.

The amendment revises the Technical Specifications to identify three existing hydraulic snubbers that have been included in the snubber surveillance program although not previously listed as being safety related.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since this amendment does not involve a significant hazards consideration.


The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §1.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

- 2 -

For further details with respect to this action, see (1) the application for amendment dated January 27, 1982, (2) Amendment No. 62 to License No. DPR-23, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, NW., Washington, D. C. and at the Hartsville Memorial Library, Home and Fifth Avenues, Hartsville, South Carolina 29550. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 2nd day of March, 1982.

FOR THE NUCLEAR REGULATORY COMMISSION



Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing