

February 13, 2002

Carl Terry, BWRVIP Chairman  
Niagara Mohawk Power Company  
Post Office Box 63  
Lycoming, NY 13093

SUBJECT: REVISION TO BWRVIP-07 TABLE 1

Dear Mr. Terry:

By letter dated January 17, 2001, the BWR Vessel and Internals Project (BWRVIP) requested that the staff consider a revision to Table 1, "Core Shroud Reinspection Intervals for Category C Plants," from the Electric Power Research Institute's (EPRI) Report TR-105747, "BWR Vessel and Internals Project, Guidelines for Reinspection of BWR Core Shrouds (BWRVIP-07)." Specifically, it was requested that this Table's applicability be expanded to include Category B plants.

The staff has reviewed the advisability of this request, and concurs that the Table 1 reinspection guidance can be expanded to include both Category B and C plants.

Please contact C. E. (Gene) Carpenter, Jr., of my staff at (301) 415-2169 if you have any further questions regarding this subject.

Sincerely,

*/ra/*

William H. Bateman, Chief  
Materials and Chemical Engineering Branch  
Division of Engineering  
Office of Nuclear Reactor Regulation

cc: See next page

February 13, 2002

Carl Terry, BWRVIP Chairman  
Niagara Mohawk Power Company  
Post Office Box 63  
Lycoming, NY 13093

SUBJECT: REVISION TO BWRVIP-07 TABLE 1

Dear Mr. Terry:

By letter dated January 17, 2001, the BWR Vessel and Internals Project (BWRVIP) requested that the staff consider a revision to Table 1, "Core Shroud Reinspection Intervals for Category C Plants," from the Electric Power Research Institute's (EPRI) Report TR-105747, "BWR Vessel and Internals Project, Guidelines for Reinspection of BWR Core Shrouds (BWRVIP-07)." Specifically, it was requested that this Table's applicability be expanded to include Category B plants.

The staff has reviewed the advisability of this request, and concurs that the Table 1 reinspection guidance can be expanded to include both Category B and C plants.

Please contact C. E. (Gene) Carpenter, Jr., of my staff at (301) 415-2169 if you have any further questions regarding this subject.

Sincerely,

William H. Bateman, Chief  
Materials and Chemical Engineering Branch  
Division of Engineering  
Office of Nuclear Reactor Regulation

cc: See next page

Distribution:

EMCB R/F                      SDuraiswamy                      MEMayfield                      WLanning, R1                      JGrobe, R3  
   JLarkins                                      NCChokshi                                      CCasto, R24                                      AHowell, R

DOCUMENT NAME: C:\Program Files\Adobe\Acrobat 4.0\PDF Output\BWRVIP07 Table 1 Rev 3 Erra~.wpd

INDICATE IN BOX: "C"=COPY W/O ATTACHMENT/ENCLOSURE, "E"=COPY W/ATT/ENCL, "N"=NO COPY    EMCB:DE

EMCB:DE	E	EMCB:DE	E	EMCB:DE	E	EMCB:DE	E
CECarpenter:cec		WHKoo:whk		ALHiser:alh		WHBateman:whb	
02/05/2002		02/05/2002		02/06/2002		02/13/2002	

OFFICIAL RECORD COPY

cc:

George Vanderheyden, Executive Chair  
BWRVIP Assessment Committee  
Exelon Corp.  
200 Exelon Way (KSA 3-N)  
Kennett Square, PA 19348

Bill Eaton, Executive Chair,  
BWRVIP Inspection Focus Group  
Grand Gulf Gen. Mgr., Plant Operations  
Entergy Operations, Inc.  
PO BOX 756, Waterloo Rd  
Port Gibson, MS 39150-0756

H. Lewis Sumner, Executive Chair  
BWRVIP Mitigation Committee  
Vice President, Hatch Project  
Southern Nuclear Operating Co.  
M/S BIN B051, PO BOX 1295  
40 Inverness Center Parkway  
Birmingham, AL 35242-4809

George T. Jones, Executive Chair  
BWRVIP Repair Focus Group  
Vice President, Nuclear Engrg. & Support  
PP&L, Inc.  
M/S GENA61  
2 N 9th St  
Allentown, PA 18101-1139

Robert Carter, EPRI BWRVIP  
Assessment Manager  
Greg Selby, EPRI BWRVIP  
Inspection Manager  
EPRI NDE Center  
P. O. Box 217097  
1300 W. T. Harris Blvd.  
Charlotte, NC 28221

Robin Dyle, Technical Chairman  
BWRVIP Assessment Committee  
Southern Nuclear Operating Co.  
40 Inverness Center Parkway  
Birmingham, AL 35242

Gary Park, Chairman  
BWRVIP Inspection Focus Group  
Nuclear Management Co.  
3313 DAEC Road  
Palo, IA 52324-9646

John Wilson, Technical Chair  
BWRVIP Mitigation Committee  
AmerGen Energy Co.  
Clinton Power Station, M/C T-31C  
P.O. Box 678  
Clinton, IL 61727

Vaughn Wagoner, Technical Chair  
BWRVIP Integration Committee  
Carolina Power & Light Company  
One Hannover Square 9C1  
P.O. Box 1551  
Raleigh, NC 27612

Bruce McLeod, Technical Chair  
BWRVIP Repair Focus Group  
Southern Nuclear Operating Co.  
Post Office Box 1295  
40 Inverness Center Parkway  
Birmingham, AL 35201

Tom Mulford, EPRI BWRVIP  
Integration Manager  
Raj Pathania, EPRI BWRVIP  
Mitigation Manager  
Ken Wolfe, EPRI BWRVIP Repair Manager  
Larry Steinert, EPRI BWRVIP  
Electric Power Research Institute  
P. O. Box 10412 3412 Hillview Ave.  
Palo Alto, CA 94303