

Ocotber 29, 1984

MEMORANDUM FOR: James R. Miller, Chief
Operating Reactors Branch #3
Division of Licensing

FROM: Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE -
NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT
TO FACILITY OPERATING LICENSE AND PROPOSED NO
SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION
AND OPPORTUNITY FOR A HEARING

Distribution
Docket File
NRC PDR
Local PDR
ORB#1 Reading
Memo file
CParrish
GRequa

Carolina Power and Light Company, Docket No. 50-261, H. B. Robinson Steam
Electric Plant, Unit No. 2, Darlington, South Carolina

Date of amendment request: July 17, 1984

Description of amendment request: This amendment would revise the Technical
Specifications to allow use of Integrated Leak Rate Test (ILRT) duration
criteria contained in ANSI N45.4-1972.

Basis for proposed no significant hazards consideration determination: The
Commission has provided guidance concerning the application of its standards
set forth in 10 CFR 50.92 for no significant hazards considerations by
providing certain examples published in the Federal Register on April 6,
1983 (48 FR 14864). One of the examples of an amendment which will likely be
found to involve no significant hazards considerations is (vii)--a change to make a
license conform to changes in the regulations, where the license change
results in very minor changes to facility operations clearly in keeping with
the regulations. The amendment request matches example vii because the
change in test duration for containment integrated leak rate measurements is
being accomplished according to section 7.6 of ANSI N45.4-1972. The use of
ANSI N45.4-1972 is required by 10CCFR Part 50 Appendix J, therefore, the
minor changes are clearly in keeping with the regulations.

8411090095 841029
PDR ADDCK 05000261
P PDR

Mr. Miller

-2-

October 29, 1984

Therefore, the Commission has made a proposed determination that the amendment request involves no significant hazards consideration.

Local Public Document Room location: Hartsville Memorial Library, Home and Fifth Avenues, Hartsville, South Carolina 29535

Attorney for licensee: Shaw, Pittman, Potts, and Trowbridge, 1800 M Street, N.W., Washington, D.C. 20036

NRC Branch Chief: Steven A. Varga

/s/SAVarga

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

*See previous white for concurrence

ORB#1:DL*
CParrish
9/ /84

ORB#1:DL
GRequa/ts
9/29/84
10

~~C-ORB#1:DL*~~
SVarga
10/6/84

OELD*
9/ /84

Mr. Miller

-2-

10 CFR Part 50 Appendix J, requires all Type A tests to be conducted in accordance with ANSI N45.4-1972. Section 7.6 of ANSI N45.4-1972 allows for a shorter than 24 hour test period provided "it can be demonstrated... that the leak rate can be accurately determined during a shorter test period". Therefore, the Commission has made a proposed determination that the amendment request involves no significant hazards consideration.

Local Public Document Room location: Hartsville Memorial Library, Home and Fifth Avenues, Hartsville, South Carolina 29535

Attorney for licensee: Shaw, Pittman, Potts, and Trowbridge, 1800 M Street, N.W., Washington, D.C. 20036

NRC Branch Chief: Steven A. Varga

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

ORB#1:DL
CParrish
10/2/84

ORB#1:DL
GRequa/ts
9/1/84
10/2/84

C-ORB#1:DL
Varga
10/2/84

OELD
Bachmann
10/5/84

MEMORANDUM FOR: James R. Miller, Chief
Operating Reactors Branch #3
Division of Licensing

FROM: Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Distribution
Docket File
NRC PDR
Local PDR
ORB#1 Reading
Memo file
CParrish
GRequa

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE -
NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT
TO FACILITY OPERATING LICENSE AND PROPOSED NO
SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION
AND OPPORTUNITY FOR A HEARING

Carolina Power and Light Company, Docket No. 50-261, H. B. Robinson Steam
Electric Plant, Unit No. 2, Darlington, South Carolina

Date of amendment request: July 17, 1984

Description of amendment request: This amendment would revise the Technical Specifications to allow use of Integrated Leak Rate Test (ILRT) during criteria contained in ANSI N45.4-1972.

Basis for proposed no significant hazards consideration determination: The Commission has provided guidance concerning the application of its standards set forth in 10 CFR 50.92 for no significant hazards considerations by providing certain examples published in the Federal Register on April 6, 1983 (48 FR 14864). One of the examples of an amendment which will likely be found to involve no significant hazards considerations is a relief granted upon demonstration of acceptable operation from an operating restriction that was imposed because acceptable operation was not yet demonstrated (iv).

The amendment request is similar to example (iv) because the licensee's Technical Specification (TS) dated September 23, 1970, requires a test duration of not less than 24 hours for integrated leakage rate measurements for containment tests. Subsequent to the licensee's current TS requirement,