bee Conection letter of 3/15/85

Docket No. 50-261

November 20, 1984

DISTRIBUTION	
Docket File	NRC PDR
LPDR	Gray File
ORB#1 Rdg	CParrish
GRequa	EJordan
LHarmon	JPartlow
DEisenhut	OELD
SECY	PMcKee
TBarnhart4	ACRS 10
CMiles	RDiggs
RFerguson	RBaĺĺard
-	

Mr. E. E. Utley, Executive Vice President Power Supply and Engineering & Construction Carolina Power and Light Company Post Office Box 1551 Raleigh, North Carolina 27602

Dear Mr. Utley:

SUBJECT: CORRECTIONS TO AMENDMENT NO. 87 TECHNICAL SPECIFICATION

The enclosed Technical Specification pages are corrections for our Amendment No. 87. Amendment N. 87 dated November 7, 1984 revised the Appendix A Technical Specification as a result of the H. B. Robinson Unit No. 2 Cycle 10 core reload analysis.

Because of timing of the Cycle 10 reload requests, our issuance of this amendment, as well as Amendment No. 85 (containing requests from past several years), pagination errors were made on several of the Amendment No. 87 Technical Specification pages.

The corrected pages involved and enclosed, herewith, are:

Appendix A revision sheet

Renumbered Page Replaces November 7, 1984 Page No.

3.5-10	3.5-7
3.5-11	3.5-7a
3.5-15	3.5-10a

We apologize for any inconvenience this may have caused you.

Sincerely,

/s/GRequa

Glode Requa, Project Manager Operating Reactors Branch #1 Division of Licensing

Enclosure: As stated

cc w/enclosure: See next page

8412030692 841120 PDR ADDCK 05000261 PDR PDR



Mr. E. E. Utley Carolina Power and Light Company

1.

cc: G. F. Trowbridge, Esquire Shaw, Pittman, Potts and Trowbridge 1800 M Street, N.W. Washington, DC 20036

> Regional Radiation Representative EPA Regiona IV 345 Courtland Street, N.E. Atlanta, GA 30308

Mr. McCuen Morrell, Chairman Darlington County Board of Supervisors County Courthouse Darlington, South Carolina 29535

State Clearinghouse Division of Policy Development 116 West Jones Street Raleigh, North Carolina 27603

Attorney General Department of Justice Justice Building Raleigh, North Carolina 27602

U.S. Nuclear Regulatory Commission Resident Inspector's Office H. B. Robinson Steam Electric Plant Route 5, Box 413 Hartsville, South Carolina 29550

James P. O'Reilly Regional Administrator - Region II U.S. Nuclear Regulatory Commission Sutie 2900 101 Marietta Street Atlanta, GA 30303

Mr. R. Morgan General Manager H. B. Robinson Steam Electric Plant Post Office Box 790 Hartsville, South Carolina 29550 H. B. Robinson Steam Electric Plant 2

Mr. Dayne H. Brown, Chief Radiation Protection Branch Division of Facility Services Department of Human Resources P.O. Box 12200 Raliegh, North Carolina 27605

ATTACHMENT TO LICENSE AMENDMENT AMENDMENT NO. 87 FACILITY OPERATING LICENSE NO. DPR-23 DOCKET NO. 50-261

Revise Appendix A as follows:

Remove Pages	Insert Pages
2.1-1 thru 2.1-8	2.1-1 thru 2.1-4
2.3-1 thru 2.3-6	2.3-1 thru 2.3-6
3.1-1 thru 3.1-3a	3.1-1 thru 3.1-3b
3.1-11 thru 3.1-12	3.1-11 thru 3.1-12
3.5-10 and 3-5-11	3.5-10 and 3.5-11
3.5-15	3.5-15
3.6-1 thru 3.6-2	3.6-1 thru 3.6-2
3.6-2a	3.6-3
3.8-6	3.8-6
3.10-2 thru 3.10-7	3.10-2 thru 3.10-7b
3.10-12	3.10-12
3.10-14 thru 3.10-20	3.10-14 thru 3.10-20
3.10-22	3.10-22 thru 3.10-24
3.11-1 thru 3.11-2	3.11-1 thru 3.11-2
4.11-1 thru 4.11-3	4.11-1 thru 4.11-3
5.3-1 thru 5.3-2	5.3-1 thru 5.3-2

B412030697 B41120 PDR ADDCK 05000261 PDR PDR

TABLE 3.5-1

ENGINEERED SAFETY FEATURE SYSTEM INITIATION INSTRUMENT SETTING LIMITS

NO.	FUNCTIONAL UNIT	CHANNEL ACTION	SETTING LIMIT
1.	High Containment Pressure (HI Level)	Safety Injection*	< 5 paig
2.	High Containment Pressure (HI-HI Level)	a. Containment Spray** b. Steam Line Isolation	<u>< 25 psig</u>
3.	Pressurizer Low Pressure	Safety Injection*	<u>></u> 1700 psig
4.	High Differential Pressure Between any Steam Line and the Steam Line Header	Safety Injection*	<u><</u> 150 рві
5.	High Steam Flow in 2/3 Steam Lines***	a. Safety Injection* b. Steam Line Isolation	<pre>< 40% (at zero load) of full steam flow < 40% (at 20% load) of full steam flow < 110% (at full load) of full steam flow</pre>
	Coincident with Low T _{avg} or Low Steam Line Pressure		≥ 541°F T _{avg} ≥ 600 psig steam line pressure
6.	Loss of Power		
	а. 480V Emerg. Bus Undervoltage (Loss of Voltage) Time Delay	Trip Normal Supply Breaker	328 Volts ± 1 Volt .75 \pm .25 sec.

Amendment No. 37

3.5-10

TABLE 3.5-1 (Continued)

ENGINEERED SAFETY FEATURE SYSTEM INITIATION INSTRUMENT SETTING LIMITS

NO.	FUNCTIONAL UNIT	CHANNEL ACTION	SETTING LIMIT
6. b (Cont'd)	. 480V Emerg. Bus Undervoltage (Degraded Voltage) Time Delay	Trip Normal Supply Breaker	412 Volts <u>+</u> 1 Volt 10.0 Second Delay <u>+</u> 0.5 sec.
7. C	ontainment Radioactivity High	Ventilation Isolation	<u> < 2 X Reading at the Time</u> the Alarm is Set with Known Plant Conditions

* Initiates also containment isolation (Phase A), feedwater line isolation and starting of all containment fans.

- ** Initiates also containment isolation (Phase B).
- *** Derived from equivalent ΔP measurements.

TABLE 3.5-3 (Continued)

INSTRUMENTATION OPERATING CONDITIONS FOR ENGINEERED SAFETY FEATURES

NO.	FUNCTIONAL UNIT	l M INIM UM CHANNELS OPERABLE	2 MINIMUM DEGREE OF REDUNDANCY	3 OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
2.	CONTAINMENT SPRAY			
	a. Manual*	2	0**	Cold Shutdown
	b. High Containment Pressure* (Hi-Hi Level)	2/set	l/set	Cold Shutdown
3.	LOSS OF POWER			
	a. 480V Emerg. Bus Undervoltage (Loss of Voltage)	2/bus(a)	l/bus ^(b)	Main Hot Shutdown
	b. 480V Emerg. Bus Undervoltage (Degraded Voltage)	2/bus	l/bus	Maintain Hot Shutdown ^(c)

* Also initiates a Phase B containment isolation.

** Must actuate two switches simultaneously.

*** When primary pressure is less than 2000 psig, channels may be blocked.

**** When primary temperature is less than 547°F, channels may be blocked.

***** In this case the 2/3 high steam flow is already in the trip mode.

(a) During testing and maintenance of one channel, may be reduced to 1/bus.

(b) During testing and maintenance of one channel, may be reduced to 0/bus.

(c) The reactor may remain critical below the power operating conditions with this feature inhibited for the purpose of starting reactor coolant pumps.

87

•

 \cdot^{ω}