

Docket No. 50-261

May 14, 1985

DISTRIBUTION

Mr. E. E. Utley, Executive Vice President  
Power Supply and Engineering and Construction  
Carolina Power and Light Company  
Post Office Box 1551  
Raleigh, North Carolina 27602

<u>Docket File</u>	NRC PDR
L PDR	ORB#1 Rdg
Gray File	BDLiaw
HThompson	GRequa
OELD	CParrish
SECY	LHarmon
EJordan	BGrimes
JPartlow	TBarnhart 4
WJones	EButcher
ACRS 10	RDiggs
CMiles	RBallard

Dear Mr. Utley:

The Commission has issued the enclosed Amendment No. 91 to Facility Operating License No. DPR-23 for the H. B. Robinson Steam Electric Plant Unit No. 2. This amendment consists of changes to the Technical Specifications in response to your request dated September 12, 1984.

The amendment revises the Technical Specification to increase the minimum temperature requirement for pressurizing the secondary side of the steam generators above 200 psig from 70°F to 120°F.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular monthly Federal Register notice.

Sincerely,

/s/GRequa

Glode Requa, Project Manager  
Operating Reactors Branch #1  
Division of Licensing

Enclosures:

1. Amendment No.91 to DPR-23
2. Safety Evaluation

cc: w/enclosures  
See next page

ORB#1:DL  
CParrish  
5/8/85

ORB#1:DL  
GRequa  
5/8/85

*Park for*  
MTEB  
BDLiaw  
5/8/85

*WJ*  
ADMICET  
W Johnston  
5/8/85  
BC  
Starga  
5/9/85

OELD  
M. Karman  
5/10/85

AD-OR:DL  
GLaTnas  
5/11/85

8505240522 850514  
PDR ADCK 05000261  
PDR

Mr. E. E. Utley  
Carolina Power and Light Company

H. B. Robinson Steam Electric Plant

cc: G. F. Trowbridge, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, DC 20036

Mr. Dayne H. Brown, Chief  
Radiation Protection Branch  
Division of Facility Services  
Department of Human Resources  
P.O. Box 12200  
Raleigh, North Carolina 27605

Mr. McCuen Morrell, Chairman  
Darlington County Board of Supervisors  
County Courthouse  
Darlington, South Carolina 29535

State Clearinghouse  
Division of Policy Development  
116 West Jones Street  
Raleigh, North Carolina 27603

Attorney General  
Department of Justice  
Justice Building  
Raleigh, North Carolina 27602

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
H. B. Robinson Steam Electric Plant  
Route 5, Box 413  
Hartsville, South Carolina 29550

Dr. J. Nelson Grace  
Regional Administrator - Region II  
U.S. Nuclear Regulatory Commission  
Suite 2900  
101 Marietta Street  
Atlanta, GA 30303

Mr. R. Morgan  
General Manager  
H. B. Robinson Steam Electric Plant  
Post Office Box 790  
Hartsville, South Carolina 29550



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

CAROLINA POWER AND LIGHT COMPANY

DOCKET NO. 50-261

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 91  
License No. DPR-23

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Carolina Power and Light Company (the licensee) dated September 12, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-23 is hereby amended to read as follows:


8505240523 850514  
PDR ADOCK 05000261  
P PDR

(B) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 91, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: May 14, 1985

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 91 FACILITY OPERATING LICENSE NO. DPR-23

DOCKET NO. 50-261

Revise Appendix A as follows:

Remove Pages

Insert Pages

3.1-5

3.1-5

3.1-6

3.1-6

-----

3.1-6a

- 3.1.2.2 The secondary side of the steam generator must not be pressurized above 200 psig if the temperature of the vessel is below 120°F
- 3.1.2.3 The pressurizer shall neither exceed a maximum heatup rate of 100°F/hr. nor a cooldown rate of 200°F/hr. The spray shall not be used if the temperature difference between the pressurizer and the spray fluid is greater than 320°F.
- 3.1.2.4 Figures 3.1-1 and 3.1-2 shall be updated periodically in accordance with the following criteria and procedures before the calculated exposure of the vessel exceeds the exposure for which the figures apply.
- a. At least 60 days before the end of the integrated power period for which Figures 3.1-1 and 3.1-2 apply, the limit lines on the figures shall be updated for a new integrated power period utilizing methods derived from the ASME Boiler and Pressure Vessel Code, Section III, Appendix G and in accordance with applicable appendices of 10 CFR 50. These limit lines shall reflect any changes in predicted vessel neutron fluence over the integrated power period or changes resulting from the irradiation specimen measurement program.
  - b. The results of the examinations of the irradiation specimens and the updated heatup and cooldown curves shall be reported to the Commission within 90 days of completion of the examinations.

#### Basis

The ability of the large steel pressure vessel that contains the reactor core and its primary coolant to resist fracture constitutes an important factor in ensuring safety in the nuclear industry. The beltline region of the reactor pressure vessel is the most critical region of the vessel because it is subjected to neutron bombardment. The overall effects of fast neutron irradiation on the mechanical properties of low alloy ferritic pressure vessel

steels such as ASTM A302 Grade B parent material of the H. B. Robinson Unit No. 2 reactor pressure vessel are well documented in the literature. Generally, low alloy ferritic materials show an increase in hardness and other strength properties and a decrease in ductility and impact toughness under certain conditions of irradiation. Accompanying a decrease in impact strength is an increase in the temperature for the transition from brittle to ductile fracture.

A method for guarding against fast fracture in reactor pressure vessels has been presented in Appendix G, "Protection Against Non-Ductile Failure," to Section III of the ASME Boiler and Pressure Vessel Code. The method utilizes fracture mechanics concepts and is based on the reference nil-ductility temperature,  $RT_{NDT}$ .

$RT_{NDT}$  is defined as the greater of: 1) the drop weight nil-ductility transition temperature (NDTT per ASTM E-208) or 2) the temperature 60°F less than the 50 ft-lb (and 35 mils lateral expansion) temperature as determined from Charpy specimens oriented in a direction normal to the major working direction of the material. The  $RT_{NDT}$  of a given material is used to index that material to a reference stress intensity factor curve ( $K_{IR}$  curve) which appears in Appendix G of the ASME Code. The  $K_{IR}$  curve is a lower bound of dynamic, crack arrest, and static fracture toughness results obtained from several heats of pressure vessel steel. When a given material is indexed to the  $K_{IR}$  curve, allowable stress intensity factors can be obtained for this material as a function of temperature. Allowable operating limits can then be determined utilizing these allowable stress intensity factors.

The Certified Material Test Reports (CMTRs) for the original steam generators provided records of Charpy V-notch tests performed at +10°F. Acceptable Charpy V-notch tests of +10°F indicate  $RT_{NDT}$  is at or below this temperature. The steam generator lower assemblies were replaced in 1984 and the material tests results indicate the highest  $RT_{NDT}$  is 60°F or below. The ASME code recommends that hydrostatic tests be performed at a temperature not lower than  $RT_{NDT}$  plus 60°F, thus the pressurizing temperature for the steam generator shell is established at 120°F to provide protection against nonductile failure at the test pressure.

The value of  $RT_{NDT}$ , and in turn the operating limits of nuclear power plants, can be adjusted to account for the effects of radiation on the reactor vessel material properties. The radiation embrittlement or changes in mechanical properties of a given reactor pressure vessel still can be monitored by a surveillance program such as the Carolina Power & Light Company, H. B. Robinson Unit No. 2 Reactor Vessel Radiation Surveillance Program<sup>(1)</sup> where a surveillance capsule is periodically removed from the operating nuclear reactor and the encapsulated specimens tested. These data are compared to data from pertinent radiation effects studies and an increase in the Charpy





UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO. 91 TO FACILITY OPERATING LICENSE NO. DPR-23  
CAROLINA POWER AND LIGHT COMPANY  
H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261

Introduction

By letter dated September 12, 1984, Carolina Power and Light Company (the licensee) proposed to amend its Operating License DPR-23, for the H. B. Robinson Steam Electric Plant Unit No. 2, by submitting revisions to the Technical Specification. The licensee proposed to revise Technical Specification 3.1.2, Heatup and Cooldown with regard to the Steam Generator minimum temperature requirement prior to pressurizing the secondary side above 200 psig. In support of their request the licensee noted that the pressure boundary of the new steam generator lower assemblies, installed at HRB-2 in 1984, had NDT value of 60°F which was higher than the original steam generators NDT of 10°F. Therefore, to provide adequate protection against non-ductile failure, the licensee proposed to increase the secondary side pressurization temperature, in accordance with 10 CFR 50 Appendix G. In addition, the licensee has retained a 60°F margin of safety currently contained in the Technical Specifications.

Evaluation

The licensee replaced the three steam generator (SG) lower assemblies during 1984. The Certified Material Test Reports (CMTRs) for the original steam generators provided records of Charpy V-notch tests performed at +10°F. Acceptable Charpy V-notch tests of +10°F indicate RT<sub>NDT</sub> is at or below this temperature. The steam generator lower assemblies were replaced in 1984 and the material tests results indicate the highest RT<sub>NDT</sub> is 60°F or below.

Appendix G to 10 CFR Part 50 provides Fracture Toughness Requirements for pressure-retaining components of the reactor coolant pressure boundary that are made of ferritic materials. Section IV.A of Appendix G requires that the ". . . ferritic materials must meet the requirements of the ASME Code supplemented as follows for fracture toughness during system hydrostatic tests and any condition of normal operation, including anticipated operational occurrences."

8505240526 850514  
PDR ADOCK 05000261  
P PDR

Item 4 following IV.A requires that the minimum permissible test temperature must be 60°F above the adjusted reference temperature of the reactor vessel material in the region that is controlling. The licensee added this minimum temperature of 60°F to the NDT of 60°F to establish a minimum temperature of 120°F prior to pressurizing the SG secondary side above 200 psig.

We have reviewed the licensee's request and, as discussed above, find the requested change consistent with the requirements of 10 CFR Part 50, Appendix G. Therefore, the staff finds that requested Technical Specification change acceptable.

#### Environmental Consideration

This amendment involves a change in the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR Sec 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

#### Conclusion

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: May 14, 1985

#### Principal Contributor:

G. Requa