Correction letter to letter transmitting Amolt. 18 to DPR-23

DISTRIBUTION Docket No. 50-261 April 20, 1984 Docket File **JNGrace** NRC PDR ACRS (10) TBarnhart (4) L PDR WJones ORB#1 Rda Mr. E. E. Utley, Executive Vice President Gray File DBrinkman Power Supply and Engineering & Construction OPA CMiles CParrish Carolina Power and Light Company GRequa RDiggs Post Office Box 1551 OELD RFerguson RBallard Raleigh, North Carolina 27602 SECY LHarmon EJordan Dear Mr. Utley:

SUBJECT AMENDMENT NO. 78 - CORRECTION OF ERROR

Our letter dated March 28, 1984 transmitting Amendment No. 78 to Facility Operating License No. DPR-23 for H. B. Robinson Steam Electric Plant No. 2 contained an error. Our March 28, 1984 letter was in response to your letter dated October 14, 1983. The letter incorrectly listed changes pertinent to your letter dated October 24, 1983. The items, contained in our March 28, 1984 letter, listed after. "The amendment revises the Technical Specification as follows," should be corrected to read:

- 1. One change clarifies the qualification requirements for alternative members of the Plant Nuclear Safety Committee (PNSC).
- 2. One change revises the list of technical disciplines for the Corporate Nuclear Safety Section (CNSS) Independent Review by adding the requirement that alternates shall as a minimum meet the qualification requirements of ANSI N18.7-1976.
- 3. One change adds surveillance requirements for mechanical snubbers that were installed during the last refueling outage.
- 4. One change incorporates Standard Technical Specifications (STS) terminology regarding the Administrative Control of High Radiation Areas.
- 5. One change revises the Acceptance Criteria for the Intergrated Leak Rate Test (ILRT) to be consistant with 10 CFR 50, Appendix J which superseded the AEC Technical Safety Guide (Revised Draft-December 15, 1966) and to comply with the requirements of the NRC Standard Review Plan 6.2.6. This change deletes a redundant requirement, therefore establishing consistency within the Technical Specification and other requirements.
- 6. One change revises shift staffing specifications to be in accordance with the requirements of NUREG-0737, I.A.1.1. and 10 CFR 50.54(m)(2).

This change adds one additional auxiliary operator on shift and revises the STA availability requirements.

7. One change corrects typographical errors and inconsistencies.

We regret any inconvenience this error may have caused you.

Sincerely,

ORDGIRAL STEED BY

Glode Requa, Project Manager Operating Reactors Branch #1 Division of Licensing

cc:
See next page

0RB#12DL DeParrish 7 4/<sub>1</sub>4/84 ORB#1:DIJ GRequaxps 4//2/84 C-ORB#1:DL SVarga 4/**(**/84 Mr. E. E. Utley
Carolina Power and Light Company

H. B. Robinson Steam Electric Plant 2

cc: G. F. Trowbridge, Esquire Shaw, Pittman, Potts and Trowbridge 1800 M Street, N.W. Washington, DC 20036

> Regional Radiation Representative EPA Regiona IV 345 Courtland Street, N.E. Atlanta, GA 30308

Mr. McCuen Morrell, Chairman
Darlington County Board of Supervisors
County Courthouse
Darlington, South Carolina 29535

State Clearinghouse Division of Policy Development 116 West Jones Street Raleigh, North Carolina 27603

Attorney General
Department of Justice
Justice Building
Raleigh, North Carolina 27602

U.S. Nuclear Regulatory Commission Resident Inspector's Office H. B. Robinson Steam Electric Plant Route 5, Box 4313 Hartsville, South Carolina 29550

James P. O'Reilly Regional Administrator - Region II U.S. Nuclear Regulatory Commission 101 Marietta Street Atlanta, GA 30303

Mr. R. Morgan General Manager H. B. Robinson Steam Electric Plant Post Office Box 790 Hartsville, South Carolina 29550