

JUL 13 1992

official copy

Docket No. 50-261
License No. DPR-23

Carolina Power and Light Company
ATTN: Mr. R. A. Watson
Senior Vice President
Nuclear Generation
P. O. Box 1551
Raleigh, NC 27602

Gentlemen:

SUBJECT: TEMPORARY WAIVER OF COMPLIANCE FOR ROBINSON UNIT 2

This letter acknowledges your letter of July 11, 1992, requesting a Temporary Waiver of Compliance from Technical Specification (TS) 3.3.1.2. The action statement for this TS as related to an inoperable Safety Injection (SI) Pump permits operation at power for 24 hours. If operability cannot be established the reactor will be placed in hot shutdown. If operability is not established within 48 hours, the reactor shall be placed in Cold Shutdown.

On July 11, 1992, with the reactor in hot shutdown, you verbally requested, by phone, an extension of an additional 48 hours before proceeding to cold shutdown to permit flushing and operability testing of the "B" SI Pump. Repairs had been performed when this pump did not meet the minimum recirculation flow requirements during surveillance on July 9, 1992.

In reviewing your request we considered the minimum heat load in the core since there has been less than 15 days of operation since startup from refueling. We also considered your compensatory actions. On July 11, 1992, there were three charging pumps in service. You stated that you would assure at least two of the three pumps would remain in service during the period of the waiver. We understood that the core had been borated to cold shutdown conditions and that all on-coming shifts would be briefed on the situation.

9207220040 920713
PDR ADDCK 05000261
P PDR

CP
[Signature]
1/6

TE 26

JUL 13 1992

Carolina Power and Light Co. 2

Based on the staff's review, we have approved your request. The approval of this request was communicated to Mr. C. Dietz, Carolina Power and Light Company by phone call from J. Johnson, NRC on July 11, 1992.

We also understand that since this request was approved the unit has returned to service and therefore this waiver has been terminated. If you have any questions regarding this approval please contact Mr. D. Verrelli at (404) 331-5535.

Sincerely,

Original signed by:
Luis A. Reyes/for

Stewart D. Ebnetter
Regional Administrator

cc: C. R. Dietz
Vice President
Robinson Nuclear Project
Department
H. B. Robinson Steam
Electric Plant
P. O. Box 790
Hartsville, SC 29550

R. H. Chambers
Plant General Manager
H. B. Robinson Steam
Electric Plant
P. O. Box 790
Hartsville, SC 29550

Heyward G. Shealy, Chief
Bureau of Radiological Health
Dept. of Health and
Environmental Control
2600 Bull Street
Columbia, SC 29201

Dayne H. Brown, Director
Division of Radiation Protection
N. C. Department of Environment,
Health & Natural Resources
P. O. Box 27687
Raleigh, NC 27611-7687

(cc cont'd - See page 3)

Carolina Power and Light Co. 3

JUL 13 1992

(cc cont'd)
H. Ray Starling
Vice President - Legal Department
Carolina Power and Light Co.
P. O. Box 1551
Raleigh, NC 27602

H. A. Cole
Special Deputy Attorney General
State of North Carolina
P. O. Box 629
Raleigh, NC 27602

Robert Gruber
Executive Director
Public Staff - NCUC
P. O. Box 29520
Raleigh, NC 27626-0520

J. L. Harrison, Manager
Regulatory Compliance
H. B. Robinson Steam Electric Plant
P. O. Box 790
Hartsville, SC 29550

bcc:T. Murley, Director, NRR
S. Varga, Director, DRP I/II, NRR
J. Lieberman, Director, OE
J. Wechselberger, EDO
M. Boyle, TA, DRP I/II, NRR
B. Mozafari, NRR
H. Christensen, RII
L. Garner, SRI, Robinson
Document Control Desk

NRC Resident Inspector
U. S. Nuclear Regulatory Commission
Route 5, Box 413
Hartsville, SC 29550

RII:DRB

DVerrelli:tj
07/13/92

RII:DRS

AGibson
07/13/92

NRR

GLainas
07/11/92

RII:ELCS

GJenkins
07/13/92

*By phone
07/11/92
JOS*

RII:DRP

*J. Johnson
7/13/92*

*By phone
and phone*

