

June 16, 1992

Docket No. 50-261  
License No. DPR-23

*official  
copy*

Carolina Power and Light Company  
ATTN: Mr. R. A. Watson  
Senior Vice President  
Nuclear Generation  
P. O. Box 1551  
Raleigh, NC 27602

Gentlemen:

**SUBJECT: ROBINSON REQUEST FOR WAIVER OF COMPLIANCE**

This letter is in response to your request for Waiver of Compliance dated June 8, 1992. We are also in receipt of your June 5, 1992, license amendment request which would make changes to your previous correspondence regarding the calibration of the Containment Vessel High-Range Radiation Monitors (R-32A and B). Our initial review indicates that your proposed change would represent the NRC approved methodology for calibration of accident range area monitoring for the containment. We will therefore process your license amendment request in accordance with our normal procedures.

Our review of the action statement for the current Technical Specifications (TS Table 3.5-5, Footnote 4) indicates that compliance is possible by the submittal of a special report and that a temporary waiver until your amendment request is processed is not necessary. Should you have any questions we would be pleased to discuss them with you.

Sincerely,

Original signed by:  
Luis A. Reyes

Luis A. Reyes, Director  
Division of Reactor Projects

cc: (See page 2)

9207010244 920616  
PDR ADOCK 05000261  
P PDR

*[Handwritten signature]*  
110  
IE01

June 16, 1992

cc: C. R. Dietz  
Vice President  
Robinson Nuclear Project Department  
H. B. Robinson Steam Electric Plant  
P. O. Box 790  
Hartsville, SC 29550

R. H. Chambers  
Plant General Manager  
H. B. Robinson Steam Electric Plant  
P. O. Box 790  
Hartsville, SC 29550

Heyward G. Shealy, Chief  
Bureau of Radiological Health  
Dept. of Health and Environmental  
Control  
2600 Bull Street  
Columbia, SC 29201

Dayne H. Brown, Director  
Division of Radiation Protection  
N. C. Department of Environment,  
Health & Natural Resources  
P. O. Box 27687  
Raleigh, NC 27611-7687

McCuen Morrell, Chairman  
Darlington County Board of Supervisor  
County Courthouse  
Darlington, SC 29535

H. Ray Starling  
Manager - Legal Department  
Carolina Power and Light Co.  
P. O. Box 1551  
Raleigh, NC 27602

(cc cont'd - See page 3)

(cc cont'd)  
H. A. Cole  
Special Deputy Attorney General  
State of North Carolina  
P. O. Box 629  
Raleigh, NC 27602

Robert Gruber  
Executive Director  
Public Staff - NCUC  
P. O. Box 29520  
Raleigh, NC 27626-0520

J. D. Kloosterman, Director  
Regulatory Compliance  
H. B. Robinson Steam Electric Plant  
P. O. Box 790  
Hartsville, SC 29550

bcc: T. Murley, Director, NRR  
S. Varga, Director, DRP I/II, NRR  
J. Lieberman, Director, OE  
Technical Assistant, DRP I/II, NRR  
H. Christensen, RII  
B. Mozafari, NRR  
Document Control Desk

NRC Resident Inspector  
U.S. Nuclear Regulatory Commission  
Route 5, Box 413  
Hartsville, SC 29550

RII:DRP <i>for DJ</i> HChristensen:tj 06/16/92	RII:DRP <i>DJ</i> DVerrelli 06/16/92	RII:EICS <i>JLJ</i> GJenkins 06/15/92	RII:DRP <i>out of town</i> JJohnson 06/16/92	RII:DRSS <i>JJS</i> JPSohr 06/16/92
RII:NRR <i>By Phone from B. Moz.</i> EAdensam 06/16/92	RII:NRR GLainas 06/16/92			