

LICENSEE: DUQUESNE LIGHT CO.

SITE: BEAVER VALLEY 2

EN NUMBER: 25160

DOCKET: 05000412

EVENT DATE: 03-01-93

RX TYPE: PWR

EVENT TIME: 11:00

VENDORS: W-3-LP

NOTIFY DATE: 03-01-93

EMERGENCY CLASS: N/A REGION: 1 STATE: PA

TIME: 13:04

OPS OFFICER: DICK JOLLIFFE

10 CFR SECTION: AINC 50.72(b)(2)(iii)(C) POT UNCNTRL RAD REL

UNIT SCRAM RX INIT INITIAL MODE CURR CURRENT MODE

CODE CRIT PWR PWR

2 N Y 100 POWER OPERATION 100 POWER OPERATION

- POTENTIAL RAD RELEASE FROM VCT OUTLET CHECK VALVE FOLLOWING A
LOCA -

LICENSEE DETERMINED THAT THE FAILURE OF UNIT 2 VOLUME CONTROL
TANK

OUTLET CHECK VALVE #2-CHS-18 FOLLOWING A LOSS OF COOLANT ACCIDENT
INSIDE CONTAINMENT MEETS THE CRITERIA FOR A POTENTIAL SINGLE
FAILURE AS DESCRIBED IN WESTINGHOUSE NUCLEAR SAFETY ADVISORY
LETTER #DLW-92-701 DATED 12/29/92. BACK LEAKAGE THROUGH THIS
VALVE COULD CAUSE A RELEASE OF RADIATION EXCEEDING 10CFR100
LIMITS.

THIS EVENT IS SIMILAR TO EVENT #25098 FOR UNIT 1.

LICENSEE IS REVISING THE APPROPRIATE EMERGENCY OPERATING
PROCEDURES FOR IMMEDIATE CORRECTIVE ACTIONS AND IS EVALUATING A
SETPOINT CHANGE TO THE
VCT RELIEF VALVE FOR LONG TERM CORRECTIVE ACTIONS.

LICENSEE INFORMED THE NRC RESIDENT INSPECTOR.