

LICENSEE: WISCONSIN ELECTRIC POWER CO.

SITE: POINT BEACH 1 2

EN NUMBER:25284

DOCKET: 05000266 05000301

EVENT DATE: 03-19-93

RX TYPE: PWR PWR

EVENT TIME: 16:45

VENDORS: W-2-LP W-2-LP

NOTIFY DATE: 03-19-93

EMERGENCY CLASS: N/A REGION: 3 STATE: WI

TIME: 17:55

OPS OFFICER: CHAUNCEY GOULD

10 CFR SECTION: ADAS 50.72(b)(2)(i)

UNANALYZED COND S/D

UNIT SCRAM RX INIT INITIAL MODE

CURR CURRENT MODE

CODE

CRIT

PWR

PWR

1

N

Y

100

POWER OPERATION

100

POWER OPERATION

2

N

Y

100

POWER OPERATION

100

POWER OPERATION

THE LICENSEE IS SUBMITTING THIS AS A CONSERVATIVE RESPONSE TO WESTINGHOUSE LETTER "NSAL93005B" DATED 03/10/93 ADDRESSING "COLD OVERPRESSURE MITIGATING SYSTEM NONCONSERVATISMS".

THE LICENSEE HAS DETERMINED THAT THEIR "LTOP" SETPOINT IS IN ERROR BY APPROX. 63 PSIG. COMPENSATORY MEASURES ARE BEING CONSIDERED AND WILL BE IN PLACE PRIOR TO PLACING "LTOP" IN SERVICE. THE RI WILL BE INFORMED.