

September 23, 1991

Docket No. 50-400

DISTRIBUTION
See attached list

Mr. Lynn W. Eury
Executive Vice President
Power Supply
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Dear Mr. Eury:

SUBJECT: OMITTED BASES PAGE FROM AMENDMENT NO. 27 TO FACILITY OPERATING LICENSE NO. NPF-63 REGARDING PRESSURIZER POWER OPERATED RELIEF VALVES AND BLOCK VALVES - SHEARON HARRIS NUCLEAR POWER PLANT, UNIT 1 (TAC NO. 80506)

Bases page B3/4 4-2b was inadvertently omitted in the distribution of Amendment No. 27 to Facility Operating License No. NPF-63 for the Shearon Harris Nuclear Power Plant, Unit 1, dated September 19, 1991. Please include the enclosed page with the amendment.

Sincerely,

Original Signed By:

Brenda L. Mozafari, Project Manager
Project Directorate II-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure: As stated

cc: See next page

NRC FILE CENTER COPY

9110020073 910923
PDR ADOCK 05000400
P PDR

UFC	:LA:PD21:DRPE	:PM:PD21:DRPE	:D:PD21:DRPE	:	:
NAME	:PAnderson	:B.Mozafari:dt	:EAdensan	:	:
DATE	:9/20/91	:9/20/91	:9/20/91	:	:

OFFICIAL RECORD COPY
Document Name: CORRECTION LETTER HARRIS

250022

CP

JFO

Mr. L. W. Eury
Carolina Power & Light Company

Shearon Harris

cc:

Mr. H. Ray Starling
Manager - Legal Department
Carolina Power & Light Company
P. O. Box 1551
Raleigh, North Carolina 27602

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street
Suite 2900
Atlanta, Georgia 30323

Resident Inspector/Harris NPS
c/o U. S. Nuclear Regulatory Commission
Route 1, Box 315B
New Hill, North Carolina 27562

Mr. C. S. Hinnant
Plant General Manager
Harris Nuclear Plant
P. O. Box 165
New Hill, North Carolina 27562

Mr. R. B. Richey, Vice President
Harris Nuclear Project
Harris Nuclear Plant
P. O. Box 165
New Hill, North Carolina 27562

Mr. Dayne H. Brown, Director
Division of Radiation Protection
N. C. Department of Environmental,
Commerce & Natural Resources
P. O. Box 27687
Raleigh, North Carolina 27611-7687

Mr. H. A. Cole
Special Deputy Attorney General
State of North Carolina
P. O. Box 629
Raleigh, North Carolina 27602

CORRECTION TO AMENDMENT NO. 27 TO FACILITY OPERATING LICENSE NO. NPF-63 -
HARRIS, UNIT 1

Docket File

NRC PDR

Local PDR

PDII-1 Reading

S. Varga (14E4)

G. Lainas

E. Adensam

P. Anderson

B. Mozafari

OGC

D. Hagan (MNBB 3302)

E. Jordan (MNBB 3302)

G. Hill (4) (P1-137)

Wanda Jones (P-130A)

C. Grimes (11D3)

ACRS (10)

GPA/PA

OC/LFMB

L. Reyes, RII

cc: Harris Service List

REACTOR COOLANT SYSTEM

BASES

RELIEF VALVES (Continued)

Surveillance Requirement 4.4.4.3 provides assurance of operability of the accumulators and that the accumulators are capable of supplying sufficient air to operate the PORV(s) if they are needed for RCS pressure control and normal air and nitrogen systems are not available.

Surveillance Requirement 4.4.4.2 addresses the block valves. The block valves are exempt from the surveillance requirements to cycle the valves when they have been closed to comply with ACTION statements "b" or "c". This precludes the need to cycle the valves with a full system differential pressure or when maintenance is being performed to restore an inoperable PORV to OPERABLE status.

3/4.4.5 STEAM GENERATORS

The Surveillance Requirements for inspection of the steam generator tubes ensure that the structural integrity of this portion of the RCS will be maintained. The program for inservice inspection of steam generator tubes is based on a modification of Regulatory Guide 1.83, Revision 1. Inservice inspection of steam generator tubing is essential in order to maintain surveillance of the conditions of the tubes in the event that there is evidence of mechanical damage or progressive degradation due to design, manufacturing errors, or inservice conditions that lead to corrosion. Inservice inspection of steam generator tubing also provides a means of characterizing the nature and cause of any tube degradation so that corrective measures can be taken.

9110020075 910923
PDR ADDCK 05000400
P PDR