

August 1, 1995

Mr. W. R. Robinson, Vice President
Shearon Harris Nuclear Power Plant
Carolina Power & Light Company
Post Office Box 165, Mail Code: Zone 1
New Hill, North Carolina 27562-0165

SUBJECT: ISSUANCE OF AMENDMENT NO. 59 TO FACILITY OPERATING LICENSE
NO. NPF-63 REGARDING RELOCATION OF BORON CONCENTRATION CURVE TO
THE PLANT COLR - SHEARON HARRIS NUCLEAR POWER PLANT, UNIT 1 (TAC
NO.91597)

Dear Mr. Robinson:

The Nuclear Regulatory Commission has issued Amendment No. 59 to Facility Operating License No. NPF-63 for the Shearon Harris Nuclear Power Plant, Unit 1. This amendment changes the Technical Specifications (TS) in response to your request dated February 6, 1995.

The amendment proposes to relocate TS Figure 3.1-1, Shutdown Margin Versus Boron Concentration in TS 3.1.1.2, Shutdown Margin - Modes 3, 4, and 5, to the plant Core Operating Limits Report (COLR).

A copy of the related Safety Evaluation is enclosed. Notice of Issuance will be included in the Commission's regular bi-weekly Federal Register notice.

Sincerely,

Original signed by:

Ngoc B. Le, Project Manager
Project Directorate II-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-400

Enclosures:

1. Amendment No. 59 to NPF-63
2. Safety Evaluation

cc w/enclosures:
See next page

FILENAME: G:\HARRIS\HAR91597.AMD

OFFICE	LA:PDII-1 <i>ES</i>	PM:PDII-1	D:PDII-1 <i>W</i>	OGC <i>gfb</i>	
NAME	EDunnington	NLe <i>Te</i>	DMatthews	<i>E Holcom</i>	
DATE	07/13/95	07/13/95	07/28/95	07/21/95	
COPY	Yes/No	Yes/No	Yes/No	Yes/No	

OFFICIAL RECORD COPY

9508090093 950801
PDR ADOCK 05000400
P PDR

NRC FILE CENTER COPY

Mr. W. R. Robinson
Carolina Power & Light Company

cc:

Mr. R. E. Jones
General Counsel - Legal Department
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Resident Inspector/Harris NPS
c/o U.S. Nuclear Regulatory Commission
5421 Shearon Harris Road
New Hill, North Carolina 27562-9998

Karen E. Long
Assistant Attorney General
State of North Carolina
Post Office Box 629
Raleigh, North Carolina 27602

Public Service Commission
State of South Carolina
Post Office Drawer 11649
Columbia, South Carolina 29211

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta St., N.W. Suite 2900
Atlanta, Georgia 30323

Mr. Dayne H. Brown, Director
Division of Radiation Protection
N.C. Department of Environmental
Division of Radiation Protection
Commerce & Natural Resources
Post Office Box 27687
Raleigh, North Carolina 27611-7687

Mr. H. W. Habermeyer, Jr.
Vice President
Nuclear Services Department
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Shearon Harris Nuclear Power Plant
Unit 1

Mr. J. W. Donahue
Plant Manager - Harris Plant
Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
Post Office Box 165, MC: Zone 1
New Hill, North Carolina 27562-0165

Mr. Robert P. Gruber
Executive Director
Public Staff NCUC
Post Office Box 29520
Raleigh, North Carolina 27626

Chairman of the North Carolina
Utilities Commission
Post Office Box 29510
Raleigh, North Carolina 27626-0510

T. D. Walt
Manager, Regulatory Affairs
Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
P. O. Box 165, Mail Zone 1
New Hill, North Carolina 27562-0165

Mr. Vernon Malone, Chairman
Board of County Commissioners
of Wake County
P. O. Box 550
Raleigh, North Carolina 27602

Mr. Henry Dunlap, Chairman
Board of County Commissioners
of Chatham County
P. O. Box 111
Pittsboro, North Carolina 27312

AMENDMENT NO. 59 TO FACILITY OPERATING LICENSE NO. NPF-63 - HARRIS, UNIT 1

Distribution

Docket File

PUBLIC

PDII-1 Reading

SVarga

JZwolinski

OGC

G. Hill (2)

C. Grimes (11E22)

T. Huang

ACRS (4)

OPA

OC/LFDCB

E. Mershoff RII

cc: Harris Service List

040054

DFol
111



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

CAROLINA POWER & LIGHT COMPANY, et al.

DOCKET NO. 50-400

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 59
License No. NPF-63

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Carolina Power & Light Company, (the licensee), dated February 6, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications, as indicated in the attachment to this license amendment; and paragraph 2.C.(2) of Facility Operating License No. NPF-63 is hereby amended to read as follows:

9508090099 950801
PDR ADOCK 05000400
P PDR

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, as revised through Amendment No. 59, are hereby incorporated into this license. Carolina Power & Light Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director
Project Directorate II-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 1, 1995

ATTACHMENT TO LICENSE AMENDMENT NO. 59

FACILITY OPERATING LICENSE NO. NPF-63

DOCKET NO. 50-400

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised areas are indicated by marginal lines.

Remove Pages

iv
3/4 1-3
3/4 1-3a
3/4 1-8
3/4 1-10
3/4 1-12
6-24
6-24b
B 3/4 1-1

Insert Pages

iv
3/4 1-3
3/4 1-3a
3/4 1-8
3/4 1-10
3/4 1-12
6-24
6-24b
B 3/4 1-1

INDEX

3.0/4.0 LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.0 APPLICABILITY</u>	3/4 0-1
<u>3/4.1 REACTIVITY CONTROL SYSTEMS</u>	
3/4.1.1 BORATION CONTROL	
Shutdown Margin - MODES 1 and 2	3/4 1-1
Shutdown Margin - MODES 3, 4, and 5	3/4 1-3
FIGURE 3.1-1 (DELETED)	3/4 1-3a
Moderator Temperature Coefficient	3/4 1-4
Minimum Temperature for Criticality	3/4 1-6
3/4.1.2 BORATION SYSTEMS	
Flow Path - Shutdown	3/4 1-7
Flow Paths - Operating	3/4 1-8
Charging Pump - Shutdown	3/4 1-9
Charging Pumps - Operating	3/4 1-10
Borated Water Source - Shutdown	3/4 1-11
Borated Water Sources - Operating	3/4 1-12
3/4.1.3 MOVABLE CONTROL ASSEMBLIES	
Group Height	3/4 1-14
TABLE 3.1-1 ACCIDENT ANALYSES REQUIRING REEVALUATION IN THE EVENT OF AN INOPERABLE ROD	3/4 1-16
Position Indication Systems - Operating	3/4 1-17
Position Indication System - Shutdown	3/4 1-18
Rod Drop Time	3/4 1-19
Shutdown Rod Insertion Limit	3/4 1-20
Control Rod Insertion Limits	3/4 1-21
FIGURE 3.1-2 (DELETED)	3/4 1-22

REACTIVITY CONTROL SYSTEMS

SHUTDOWN MARGIN - MODES 3, 4, AND 5

LIMITING CONDITION FOR OPERATION

3.1.1.2 The SHUTDOWN MARGIN shall be greater than or equal to the limit specified in the CORE OPERATING LIMITS REPORT (COLR), plant procedure PLP-106.

APPLICABILITY: MODES 3, 4, AND 5.

ACTION:

With the SHUTDOWN MARGIN less than the required value immediately initiate and continue boration at greater than or equal to 30 gpm of a solution containing greater than or equal to 7000 ppm boron or equivalent until the required SHUTDOWN MARGIN is restored.

SURVEILLANCE REQUIREMENTS

4.1.1.2 The SHUTDOWN MARGIN shall be determined to be greater than or equal to the required value:

- a. Within 1 hour after detection of an inoperable control rod(s) and at least once per 12 hours thereafter while the rod(s) is inoperable. If the inoperable control rod is immovable or untrippable, the SHUTDOWN MARGIN shall be verified acceptable with an increased allowance for the withdrawn worth of the immovable or untrippable control rod(s); and
- b. At least once per 24 hours by consideration of the following factors:
 - 1) Reactor Coolant System boron concentration,
 - 2) Control rod position,
 - 3) Reactor Coolant System average temperature,
 - 4) Fuel burnup based on gross thermal energy generation,
 - 5) Xenon concentration, and
 - 6) Samarium concentration.

FIGURE 3.1-1

SHUTDOWN MARGIN VERSUS RCS BORON CONCENTRATION
MODES 3, 4, AND 5/DRAINED

This figure is deleted from Technical Specifications and is controlled by the CORE OPERATING LIMITS REPORT, plant procedure PLP-106.

REACTIVITY CONTROL SYSTEMS

FLOW PATHS - OPERATING

LIMITING CONDITION FOR OPERATION

3.1.2.2 At least two of the following three boron injection flow paths shall be OPERABLE:

- a. The flow path from the boric acid tank via a boric acid transfer pump and a charging/safety injection pump to the Reactor Coolant System (RCS), and
- b. Two flow paths from the refueling water storage tank via charging/safety injection pumps to the RCS.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

With only one of the above required boron injection flow paths to the RCS OPERABLE, restore at least two boron injection flow paths to the RCS to OPERABLE status within 72 hours or be in at least HOT STANDBY and borated to a SHUTDOWN MARGIN as specified in the CORE OPERATING LIMITS REPORT (COLR), plant procedure PLP-106 at 200°F within the next 6 hours; restore at least two flow paths to OPERABLE status within the next 7 days or be in HOT SHUTDOWN within the next 6 hours.

SURVEILLANCE REQUIREMENTS

4.1.2.2 At least two of the above required flow paths shall be demonstrated OPERABLE:

- a. At least once per 7 days by verifying that the temperature of the flow path between the boric acid tank and the charging/safety injection pump suction header tank is greater than or equal to 65°F when a flow path from the boric acid tank is used;
- b. At least once per 31 days by verifying that each valve (manual, power-operated, or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position;
- c. At least once per 18 months during shutdown by verifying that each automatic valve in the flow path actuates to its correct position on a safety injection test signal; and
- d. At least once per 18 months by verifying that the flow path required by Specification 3.1.2.2a. delivers at least 30 gpm to the RCS.

REACTIVITY CONTROL SYSTEMS

CHARGING PUMPS - OPERATING

LIMITING CONDITION FOR OPERATION

3.1.2.4 At least two charging/safety injection pumps shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

With only one charging/safety injection pump OPERABLE, restore at least two charging/safety injection pumps to OPERABLE status within 72 hours or be in at least HOT STANDBY and borated to a SHUTDOWN MARGIN as specified in the CORE OPERATING LIMITS REPORT (COLR), plant procedure PLP-106 at 200°F within the next 6 hours; restore at least two charging/safety injection pumps to OPERABLE status within the next 7 days or be in HOT SHUTDOWN within the next 6 hours.

SURVEILLANCE REQUIREMENTS

4.1.2.4 At least two charging/safety injection pumps shall be demonstrated OPERABLE by verifying, on recirculation flow or in service supplying flow to the Reactor Coolant System and reactor coolant pump seals, that a differential pressure across each pump of greater than or equal to 2446 psid is developed when tested pursuant to Specification 4.0.5.

REACTIVITY CONTROL SYSTEMS

BORATED WATER SOURCES - OPERATING

LIMITING CONDITION FOR OPERATION

3.1.2.6 As a minimum, the following borated water source(s) shall be OPERABLE as required by Specification 3.1.2.2:

- a. The boric acid tank with:
 1. A minimum contained borated water volume of 24,150 gallons, which is ensured by maintaining indicated level of greater than or equal to 74%,
 2. A boron concentration of between 7000 and 7750 ppm, and
 3. A minimum solution temperature of 65°F.
- b. The refueling water storage tank (RWST) with:
 1. A minimum contained borated water volume of 436,000 gallons, which is equivalent to 92% indicated level.
 2. A boron concentration of between 2400 and 2600 ppm,
 3. A minimum solution temperature of 40°F, and
 4. A maximum solution temperature of 125°F.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

- a. With the boric acid tank inoperable and being used as one of the above required borated water sources, restore the boric acid tank to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and borated to a SHUTDOWN MARGIN specified in the CORE OPERATING LIMITS REPORT (COLR), plant procedure PLP-106 at 200°F; restore the boric acid tank to OPERABLE status within the next 7 days or be in COLD SHUTDOWN within the next 30 hours.
- b. With the RWST inoperable, restore the tank to OPERABLE status within 1 hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

6.9.1.6 CORE OPERATING LIMITS REPORT

6.9.1.6.1 Core operating limits shall be established and documented in the CORE OPERATING LIMITS REPORT (COLR), plant procedure PLP-106, prior to each reload cycle, or prior to any remaining portion of a reload cycle, for the following:

- a. SHUTDOWN MARGIN limits for Specification 3/4.1.1.2,
- b. Moderator Temperature Coefficient Positive and Negative Limits and 300 ppm surveillance limit for Specification 3/4.1.1.3,
- c. Shutdown Bank Insertion Limits for Specification 3/4.1.3.5,
- d. Control Bank Insertion Limits for Specification 3/4.1.3.6,
- e. Axial Flux Difference Limits for Specification 3/4.2.1,
- f. Heat Flux Hot Channel Factor, F_q^{RTP} , $K(Z)$, and $V(Z)$ for Specification 3/4.2.2,
- g. Enthalpy Rise Hot Channel Factor, F_{AH}^{RTP} , and Power Factor Multiplier, PF_{AH} for Specification 3/4.2.3.
- h. Boron Concentration for Specification 3/4.9.1.

6.9.1.6.2 The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC at the time the reload analyses are performed, and the approved revision number shall be identified in the COLR.

- a. XN-75-27(A), latest Revision and Supplements, "Exxon Nuclear Neutronics Design Methods for Pressurized Water Reactors," Exxon Nuclear Company, Richland WA 99352.

(Methodology for Specification 3.1.1.2 - SHUTDOWN MARGIN - MODES 3, 4 and 5, 3.1.1.3 - Moderator Temperature Coefficient, 3.1.3.5 - Shutdown Bank Insertion Limits, 3.1.3.6 - Control Bank Insertion Limits, 3.2.1 - Axial Flux Difference, 3.2.2 - Heat Flux Hot Channel Factor, 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor, and 3.9.1 - Boron Concentration).
- b. ANF-89-151(A), latest Revision, "ANF-RELAP Methodology for Pressurized Water Reactors: Analysis of Non-LOCA Chapter 15 Events," Advanced Nuclear Fuels Corporation, Richland WA 99352.

(Methodology for Specification 3.1.1.3 - Moderator Temperature Coefficient, 3.1.3.5 - Shutdown Bank Insertion Limits, 3.1.3.6 - Control Bank Insertion Limits, 3.2.1 - Axial Flux Difference, 3.2.2 - Heat Flux Hot Channel Factor, and 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor).
- c. XN-NF-82-21(A), latest Revision, "Application of Exxon Nuclear Company PWR Thermal Margin Methodology to Mixed Core Configurations," Exxon Nuclear Company, Richland WA 99352.

(Methodology for Specification 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor).

6.9.1.6 CORE OPERATING LIMITS REPORT (Continued)

- h. ANF-88-054(A), latest Revision, "PDC-3: Advanced Nuclear Fuels Corporation Power Distribution Control for Pressurized Water Reactors and Application of PDC-3 to H. B. Robinson Unit 2," Advanced Nuclear Fuels Corporation, Richland WA 99352.

(Methodology for Specification 3.2.1 - Axial Flux Difference, and 3.2.2 - Heat Flux Hot Channel Factor).
- i. WCAP-9272-P-A, "WESTINGHOUSE RELOAD SAFETY EVALUATION METHODOLOGY", July 1985 (W Proprietary).

(Methodology for Specification 3.1.1.2 - SHUTDOWN MARGIN - MODES 3, 4 AND 5, 3.2.2 - Heat Flux Hot Channel Factor and 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor).
- j. WCAP-10266-P-A, Rev. 2, "The 1981 Version of the WESTINGHOUSE ECCS EVALUATION MODEL USING THE BASH CODE", March 1987 (W Proprietary).

(Methodology for Specification 3.2.2 - Heat Flux Hot Channel Factor).
- k. WCAP-11837-P-A, "EXTENSION OF METHODOLOGY FOR CALCULATING TRANSITION CORE DNBR PENALTIES", January 1990 (W Proprietary).

(Methodology for Specification 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor).
- l. EMF-92-081(A), latest Revision and Supplements, "Statistical Setpoint/Transient Methodology for Westinghouse Type Reactors," Siemens Power Corporation, Richland WA 99352.

(Methodology for Specification 3.1.1.3 - Moderator Temperature Coefficient, 3.1.3.5 - Shutdown Bank Insertion Limits, 3.1.3.6 - Control Bank Insertion Limits, 3.2.1 - Axial Flux Difference, 3.2.2 - Heat Flux Hot Channel Factor, and 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor).
- m. EMF-92-153(A), latest Revision and Supplements, "HTP: Departure from Nucleate Boiling Correlation for High Thermal Performance Fuel," Siemens Nuclear Power Corporation, Richland WA 99352.

(Methodology for Specification 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor).
- n. XN-NF-82-49(A), latest Revision and Supplements, "Exxon Nuclear Company Evaluation Model EXEM PWR Small Break Model," Exxon Nuclear Company, Richland WA 99352.

(Methodology for Specification 3.2.1 - Axial Flux Difference, 3.2.2 - Heat Flux Hot Channel Factor, and 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor).

3/4.1 REACTIVITY CONTROL SYSTEMS

BASES

3/4.1.1 BORATION CONTROL

3/4.1.1.1 and 3/4.1.1.2 SHUTDOWN MARGIN

A sufficient SHUTDOWN MARGIN ensures that: (1) the reactor can be made subcritical from all operating conditions, (2) the reactivity transients associated with postulated accident conditions are controllable within acceptable limits, and (3) the reactor will be maintained sufficiently subcritical to preclude inadvertent criticality in the shutdown condition.

SHUTDOWN MARGIN requirements vary throughout core life as a function of fuel depletion, RCS boron concentration, and RCS T_{avg} . In MODES 1 and 2 the most restrictive condition occurs at EOL, with T_{avg} at no load operating temperature, and is associated with a postulated steam line break accident and resulting uncontrolled RCS cooldown. In the analysis of this accident, a minimum SHUTDOWN MARGIN of 1770 pcm is required to control the reactivity transient. Accordingly, the SHUTDOWN MARGIN requirement is based upon this limiting condition and is consistent with FSAR safety analysis assumptions. In MODES 3, 4, and 5, the most restrictive condition occurs at BOL, when the boron concentration is the greatest. In these modes, the required SHUTDOWN MARGIN is composed of a constant requirement and a variable requirement, which is a function of the RCS boron concentration. The constant SHUTDOWN MARGIN requirement is based on an uncontrolled RCS cooldown from a steamline break accident, as is the case for MODES 1 and 2. The variable SHUTDOWN MARGIN requirement is based on the results of boron dilution accident analyses, where the SHUTDOWN MARGIN is varied as a function of RCS boron concentration, to guarantee a minimum of 15 minutes for operator action prior to a loss of SHUTDOWN MARGIN.

In modes 3, 4, and 5, the figure specified in the CORE OPERATING LIMITS REPORT (COLR) must be used with a curve giving the required shutdown boron concentrations for various temperatures as a function of core burnup. This cycle dependent relationship is provided for each cycle in the plant Curve Book. From the Curve Book, a required boron concentration that will provide adequate SHUTDOWN MARGIN can be determined and this concentration may be used to enter the figure specified in the COLR to determine the specific required SHUTDOWN MARGIN for that condition.

The boron dilution analysis assumed a common RCS volume and dilution flow rate for MODES 3 and 4, which differed from the volume and flow rate assumed for MODE 5 analysis. The MODE 5 conditions assumed limited mixing in the RCS and cooling with the RHR system only. In MODES 3 and 4, it was assumed that at least one reactor coolant pump was operating. If at least one reactor coolant pump is not operating in MODE 4, then the SHUTDOWN MARGIN requirements for MODE 5 shall apply, provided that the dilution flow rate assumed in the MODE 5 Boron Dilution analysis is not exceeded.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 59 TO FACILITY OPERATING LICENSE NO. NPF-63

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER PLANT, UNIT 1
DOCKET NO. 50-400

1.0 INTRODUCTION

By letter dated February 6, 1995, the Carolina Power & Light Company (the licensee) submitted a request for changes to the Shearon Harris Nuclear Power Plant, Unit 1 (SHNPP), Technical Specifications (TS). The requested changes would revise TS 6.9.1.6 to allow the relocation of the cycle-specific core operating limits of Figure 3.1-1, Shutdown Margin Versus Boron Concentration in TS 3.1.1.2, Shutdown Margin - Modes 3, 4, and 5 to the plant Core Operating Limits Report (COLR). The use of the COLR, for many SHNPP cycle-specific parameters, has been previously approved by the NRC under Amendment No. 15 which was issued on October 18, 1989.

2.0 BACKGROUND

Section 182a of the Atomic Energy Act (the "Act") requires that applicants for nuclear power plant operating licenses state TS and that these TS be included as a part of the license. The Commission's regulatory requirements related to the content of TS are set forth in 10 CFR 50.36. That regulation requires that the TS include items in five specific categories including: (1) safety limits, limiting safety system settings and limiting control settings; (2) limiting conditions for operation; (3) surveillance requirements; (4) design features; and (5) administrative controls, and it also states that the Commission may include such additional TS as it finds to be appropriate. However, the regulation does not specify the particular TS to be included in a plant's license.

The Commission has provided guidance for the contents of TS in its "Final Policy Statement on Technical Specifications Improvements for Nuclear Power Reactors" (Final Policy Statement), issued on July 22, 1993 (58 FR 39132), in which the Commission indicated that compliance with the Final Policy Statement satisfies Section 182a of the Act. In particular, the Commission indicated that certain items could be relocated from the TS to licensee-controlled documents, and consistent with this approach, the Final Policy Statement identified four criteria to be used in determining whether a particular matter is required to be included in the TS, as follows: (1) installed instrumentation that is used to detect and indicate in the control room a significant abnormal degradation of the reactor coolant pressure boundary; (2) a process variable, design feature, or operating restriction that is an initial condition of a design basis accident or transient analysis that either assumes the failure of, or presents a challenge to, the integrity of a fission

product barrier; (3) a structure, system, or component that is part of the primary success path and which functions or actuates to mitigate a design basis accident or transient that either assumes the failure of or presents a challenge to the integrity of a fission product barrier; (4) a structure, system, or component which operating experience or probabilistic safety assessment has shown to be significant to public health and safety.¹ As a result, the existing Limiting Condition for Operation (LCO) requirements that fall within or satisfy any of the criteria in the Final Policy Statement must be retained in the TS, while those LCO requirements which do not fall within or satisfy these criteria may be relocated to other appropriate licensee-controlled documents.

3.0 EVALUATION

The licensee requested TS changes in accordance with the 10 CFR 50.90 and 2.101. The revised TS were proposed as follows:

- (a) TS 3.1.1.2, 3.1.2.2, 3.1.2.4, and 3.1.2.6

The shutdown margin limit for Modes 3, 4, and 5 in Figure 3.1-1 Shutdown Margin Versus RCS Boron Concentration for this specification is specified in the COLR.

- (b) TS 6.9.1.6

The shutdown margin limit for specification 3/4.1.1.2 is added to TS 6.9.1.6.1 and its supporting methodologies are identified in references a and i of TS 6.9.1.6.2.

The bases of the affected TS have been modified by the licensee to include an appropriate reference to the COLR.

The NRC staff has determined that the relocation of the TS Figure 3.1-1, Shutdown Margin Versus RCS Boron Concentration - Mode 3, 4, and 5 does not eliminate the requirements for the licensee to ensure that the reactivity control systems are capable of performing their safety functions. Although the TS Figure 3.1-1 is relocated from the TS to the COLR, the licensee must continue to establish any changes to the shutdown margin versus boron concentration curve using the methodologies specified in TS 6.9.1.6.2, and consistent with all applicable limits in the Final Safety Analysis Report (FSAR). NRC approval and a license amendment would be required prior to using a methodology other than one approved and specified in TS 6.9.1.6.2.

1

The Commission recently promulgated a proposed change to 10 CFR 50.36, pursuant to which the rule would be amended to codify and incorporate these criteria (59 FR 48180, September 20, 1994). The Commission's Final Policy Statement specified that the Reactor Core Isolation Cooling, Isolation Condenser, Residual Heat Removal, Standby Liquid Control, and Recirculation Pump Trip are included in the TS under Criterion 4 (58 FR 39132, July 22, 1993).

NRC inspection and enforcement programs also enable the NRC staff to monitor facility and program changes and licensee adherence to FSAR commitments and to take any remedial action that may be appropriate. Furthermore, because plant operation continues to be limited in accordance with the values of cycle-specific parameter limits that are established using NRC-approved methodologies, the NRC staff has determined that the licensee provided an acceptable response to those items as addressed in the NRC guidance in Generic Letter 88-16 on modifying cycle-specific parameter limits in TS.

The NRC staff has concluded, therefore, that the relocation of the TS Figure 3.1-1 from TS 3.1.1.2, 3.1.2.2, 3.1.2.4, 3.1.2.6, and proposed changes to TS 6.9.1.6 are acceptable because (1) their inclusion in the TS is not specifically required by 10 CFR 50.36 or other regulations, (2) the TS Figure 3.1-1 has been relocated to the plant COLR, is adequately controlled by existing TS and limits in the UFSAR, and its inclusion in the TS is not required to avert an immediate threat to the public health and safety, and (3) changes that are deemed to involve an unreviewed safety question or a change in TS will require prior NRC approval in accordance with 10 CFR 50.59(c).

Based on the above review, the NRC staff concludes that the changes to related TS bases are acceptable.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the State of North Carolina official was notified of the proposed issuance of the amendment. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (60 FR 14017). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such

activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: T. Huang
N. Le

Date: August 1, 1995