

February 11, 2002
PY-CEI/NRR-2615L

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Perry Nuclear Power Plant
Docket No. 50-440
License No. NPF-58
Monthly Operating Report

Ladies and Gentlemen:

Attached is a re-issue of November 2001 Monthly Operating Report for Perry Unit 1. Page 1 contains the Operating Data Report and page 2 contains the Unit Shutdowns Report. This report was submitted in accordance with Technical Specification 5.6.4 and Generic Letter 97-02, "Revised Contents of the Monthly Operating Report" on December 12, 2001. This report is being resubmitted as the previous letter had the incorrect month's data attached.

I apologize for any inconvenience this may have caused. If you have questions or require additional information, please contact Ms. Toni Phelps at (440) 280-7660.

Very truly yours,



Gregory A. Dunn
Manager - Regulatory Affairs

Attachment

cc: NRC Region III Administrator
NRC Project Manager
NRC Resident Inspector

TE 24

OPERATING DATA REPORT

UNIT: Perry
DATE: 12/10/01

1. Docket: 50-440
2. Unit Name: Perry Nuclear Power Plant
3. Reporting Period: November 2001
4. Utility Contact: T. Phelps
5. Telephone: 440-280-7660
6. Design Electrical Rating (Net MWe): 1266*
7. Maximum Dependable Capacity (Net MWe): 1241**

	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
8. Hours Reactor was Critical	<u>720.0</u>	<u>6,285.4</u>	<u>95,894.0</u>
9. Hours Generator On-Line	<u>720.0</u>	<u>6,083.8</u>	<u>93,446.0</u>
10. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
11. Net Electrical Energy (MWeH)	<u>907,234.0</u>	<u>7,066,780.0</u>	<u>105,887,737.0</u>

- *The New Design Electrical Rating is based on the 105% uprate which was completed April of 2001.
- ** The new MDC was effective April 1, 2001.

UNIT SHUTDOWNS REPORT MONTH – NOVEMBER 2001

DOCKET NO: 50-440
 NAME: Perry Nuclear Power Plant
 DATE: 12/10/01
 CONTACT: T. Phelps
 TELEPHONE: (440) 280-7660

No.	Date	Type 1	Duration Hours	Reason 2	Method 3	Cause and Corrective Action to Prevent Recurrence

SUMMARY: The Perry plant began the month on line. The unit remained on line the entire month of November, 2001

- | | | |
|--|---|---|
| 1. TYPE:
F: Forced
S: Scheduled | 2. REASON:
A - Equipment Failure (explain)
B - Maintenance or Test
C - Refueling
D - Regulatory
E - Operating Training &
License Examination
F - Administrative
G - Operational Error (explain)
H - Other (explain) | 3. METHOD:
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continuation
5 - Other |
|--|---|---|