

LICENSEE: DUQUESNE LIGHT CO.  
SITE: BEAVER VALLEY 2 EN NUMBER: 26326  
DOCKET: 05000412 EVENT DATE: 11-06-93  
RX TYPE: PWR EVENT TIME: 13:57  
VENDORS: W-3-LP NOTIFY DATE: 11-06-93  
EMERGENCY CLASS: N/A REGION: 1 STATE: PA TIME: 15:27  
OPS OFFICER: RUDY KARSCH  
10 CFR SECTION: ADAS 50.72(b)(2)(i) DEG/UNANALYZED COND  
UNIT SCRAM RX INIT INITIAL MODE CURR CURRENT MODE  
CODE CRIT PWR PWR  
2 N N 0 REFUELING 0 REFUELING

COMMON MODE FAILURE NOTED TO BOTH STATION EMERGENCY DIESEL GENERATORS (EDGs).

ON 11/4/93 AN EDG AUTO-LOAD TEST FAILED ON THE "#1" EDG DUE TO A SEQUENCER FAILURE. A RELAY IN THE SEQUENCER WAS REPLACED AND A SATISFACTORY RETEST WAS CONDUCTED. TODAY EDG AUTO-LOAD TEST FAILED ON THE "#2" EDG DUE TO A SEQUENCER FAILURE. IT APPEARS THAT THE SAME RELAY IS THE CAUSE. THIS DISCREPANCY POINTS TO THE POSSIBILITY THAT BOTH EDGs MAY HAVE BEEN INOPERABLE WHILE THE STATION WAS IN OPERATION. THE LICENSEE'S INVESTIGATION IS ONGOING. THE LICENSEE INFORMED THE NRC RESIDENT INSPECTOR.