

LICENSEE: PENNSYLVANIA POWER & LIGHT CO.  
 SITE: SUSQUEHANNA 1 EN NUMBER: 26404  
 DOCKET: 05000387 EVENT DATE: 11-22-93  
 RX TYPE: BWR EVENT TIME: 16:28  
 VENDORS: GE-4 NOTIFY DATE: 11-22-93  
 EMERGENCY CLASS: N/A REGION: 1 STATE: PA TIME: 17:03  
 OPS OFFICER: TIM MCGINTY  
 10 CFR SECTION: APRE 50.72(b)(2)(vi) OFFSITE NOTIFICATION  
 UNIT SCRAM RX INIT INITIAL MODE CURR CURRENT MODE  
 CODE CRIT PWR PWR  
 1 N N 0 REFUELING 0 REFUELING

THE LICENSEE ISSUED A PRESS RELEASE REGARDING THE EXTENSION OF THE UNIT 1 OUTAGE.

THE LICENSEE IS EXTENDING THE CURRENT OUTAGE ABOUT 15 DAYS (UNTIL 1/1/94) TO REPLACE THE JET PUMP HOLD DOWN BEAMS, DUE TO THE PROBLEMS EXPERIENCED AT GRAND GULF. THE PRESS RELEASE INDICATED THAT ALTHOUGH ROUTINE INSPECTIONS HAVE NOT SHOWN ANY EVIDENCE OF CRACKING IN THE SUPPORT PIECES, THE LICENSEE WAS TAKING PRUDENT ACTION TO PERFORM THE REPLACEMENT AT THIS TIME. THE JET PUMP SUPPORTS FOR UNIT 2 WILL BY REPLACED DURING THE SPRING, 1994, REFUELING OUTAGE.

THE LICENSEE WILL INFORM THE RESIDENT INSPECTOR.