

NOV 23 1983

DMB 016

DISTRIBUTION

Docket File

EBlackwood  
HOrnstein

NRC PDR  
L PDR  
ORB#4 Rdg  
DEisenhut  
OELD  
CMiles  
LHarmon  
ACRS-10  
TBarnhart-4  
EJordan  
JTaylor  
WJones  
DBrinkman  
RDiggs  
RIngram  
RHernan  
Gray File

Docket No. 50-302

Mr. Walter S. Wilgus  
Vice President, Nuclear Operations  
Florida Power Corporation  
ATTN: Manager, Nuclear Licensing  
& Fuel Management  
Post Office Box 14042, M.A.C. H-2  
St. Petersburg, Florida 33733

Dear Mr. Wilgus:

On August 25, 1983, the Commission issued Amendment No. 66 to Facility Operating License No. DPR-72 for the Crystal River Unit No. 3 Nuclear Generating Plant (CR-3). This amendment revised the Technical Specifications for Cycle 5 operation of CR-3.

In issuing this amendment, however, we inadvertently omitted a footnote reference regarding channel functional testing of the steam line rupture matrix automatic actuation logic circuitry. It was our intent that one channel, not both channels, be tested on a monthly basis such that each channel is tested every other month. Please replace page 3/4 3-19 of your Technical Specifications with the attached corrected page. We regret any inconvenience caused by this oversight.

Sincerely,

"ORIGINAL SIGNED BY  
JOHN F. STOLZ"

John F. Stolz, Chief  
Operating Reactors Branch #4  
Division of Licensing

Enclosure:  
As stated

cc w/enclosure:  
See next page

ORB#4:DL *ni*  
RIngram:dk  
11/23/83

ORB#4:DL *kat*  
RHernan  
11/22/83

ORB#4:DL *JStolz*  
JStolz  
11/23/83

8312090318 831123  
PDR ADOCK 05000302  
P PDR

Crystal River Unit No. 3  
Florida Power Corporation

50-302

cc w/enclosure(s):  
Mr. S. A. Brandimore  
Florida Power Corporation  
Vice President and General Counsel  
P. O. Box 14042  
St. Petersburg, Florida 33733

Mr. Wilbur Langely, Chairman  
Board of County Commissioners  
Citrus County  
Inverness, Florida 36250

Regional Radiation Representative  
EPA Region IV  
345 Courtland Street, N.E.  
Atlanta, Georgia 30308

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
Suite 220, 7910 Woodmont Avenue  
Bethesda, Maryland 20814

Mr. Tom Stetka, Resident Inspector  
U.S. Nuclear Regulatory Commission  
Route #3, Box 717  
Crystal River, Florida 32629

Nuclear Plant Manager  
Florida Power Corporation  
P. O. Box 219  
Crystal River, Florida 32629

Bureau of Intergovernmental Relations  
660 Apalachee Parkway  
Tallahassee, Florida 32304

Uray Clark, Administrator  
Radiological Health Services  
Department of Health and  
Rehabilitative Services  
1323 Winewood Blvd.  
Tallahassee, Florida 32301

Administrator  
Department of Environmental Regulation  
Power Plant Siting Section  
State of Florida  
2600 Blair Stone Road  
Tallahassee, Florida 32301

Attorney General  
Department of Legal Affairs  
The Capitol  
Tallahassee, Florida 32304

Mr. James P. O'Reilly, Regional Administrator  
U. S. Nuclear Regulatory Commission, Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

TABLE 4.3-2 (Cont'd)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEMS INSTRUMENTATION SURVEILLANCE REQUIREMENTS

CRYSTAL RIVER - UNIT 3

3/4 3-19

Amendment No. 77, 28, 37, 55

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE REQUIRED</u>
3. REACTOR BLDG. SPRAY				
a. Reactor Bldg. Pressure High-High coincident with HPI Signal	S	R	M(4)	1, 2, 3
b. Automatic Actuation Logic	N/A	N/A	M(1)(3)(5)	1, 2, 3
4. OTHER SAFETY SYSTEMS				
a. Reactor Bldg. Purge Exhaust Duct Isolation on High Radioactivity				
1. Gaseous	S	Q	M	All Modes
b. Steam Line Rupture Matrix				
1. Low SG Pressure	N/A	R	N/A	1, 2, 3
2. Automatic Actuation Logic	N/A	N/A	M (3)	1, 2, 3
c. Emergency Feedwater				
1. Main Feedwater Pump Turbines A and B Control Oil Low	S	R	N/A	1, 2, 3
2. OTSG A and B Level Low-Low	S	R	N/A	1, 2, 3, 4