

NOV 23 1983

DMB 016

DISTRIBUTION

Docket File

EBlackwood
HOrnstein

NRC PDR
L PDR
ORB#4 Rdg
DEisenhut
OELD
CMiles
LHarmon
ACRS-10
TBarnhart-4
EJordan
JTaylor
WJones
DBrinkman
RDiggs
RIngram
RHernan
Gray File

Docket No. 50-302

Mr. Walter S. Wilgus
Vice President, Nuclear Operations
Florida Power Corporation
ATTN: Manager, Nuclear Licensing
& Fuel Management
Post Office Box 14042, M.A.C. H-2
St. Petersburg, Florida 33733

Dear Mr. Wilgus:

On August 25, 1983, the Commission issued Amendment No. 66 to Facility Operating License No. DPR-72 for the Crystal River Unit No. 3 Nuclear Generating Plant (CR-3). This amendment revised the Technical Specifications for Cycle 5 operation of CR-3.

In issuing this amendment, however, we inadvertently omitted a footnote reference regarding channel functional testing of the steam line rupture matrix automatic actuation logic circuitry. It was our intent that one channel, not both channels, be tested on a monthly basis such that each channel is tested every other month. Please replace page 3/4 3-19 of your Technical Specifications with the attached corrected page. We regret any inconvenience caused by this oversight.

Sincerely,

"ORIGINAL SIGNED BY
JOHN F. STOLZ"

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

ORB#4:DL *ni*
RIngram:dk
11/23/83

ORB#4:DL *kat*
RHernan
11/22/83

ORB#4:DL *JStolz*
JStolz
11/23/83

8312090318 831123
PDR ADOCK 05000302
P PDR

Crystal River Unit No. 3
Florida Power Corporation

50-302

cc w/enclosure(s):
Mr. S. A. Brandimore
Florida Power Corporation
Vice President and General Counsel
P. O. Box 14042
St. Petersburg, Florida 33733

Mr. Wilbur Langely, Chairman
Board of County Commissioners
Citrus County
Inverness, Florida 36250

Regional Radiation Representative
EPA Region IV
345 Courtland Street, N.E.
Atlanta, Georgia 30308

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Mr. Tom Stetka, Resident Inspector
U.S. Nuclear Regulatory Commission
Route #3, Box 717
Crystal River, Florida 32629

Nuclear Plant Manager
Florida Power Corporation
P. O. Box 219
Crystal River, Florida 32629

Bureau of Intergovernmental Relations
660 Apalachee Parkway
Tallahassee, Florida 32304

Uray Clark, Administrator
Radiological Health Services
Department of Health and
Rehabilitative Services
1323 Winewood Blvd.
Tallahassee, Florida 32301

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission, Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

TABLE 4.3-2 (Cont'd)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEMS INSTRUMENTATION SURVEILLANCE REQUIREMENTS

CRYSTAL RIVER - UNIT 3

3/4 3-19

Amendment No. 77, 28, 37, 55

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE REQUIRED</u>
3. REACTOR BLDG. SPRAY				
a. Reactor Bldg. Pressure High-High coincident with HPI Signal	S	R	M(4)	1, 2, 3
b. Automatic Actuation Logic	N/A	N/A	M(1)(3)(5)	1, 2, 3
4. OTHER SAFETY SYSTEMS				
a. Reactor Bldg. Purge Exhaust Duct Isolation on High Radioactivity				
1. Gaseous	S	Q	M	All Modes
b. Steam Line Rupture Matrix				
1. Low SG Pressure	N/A	R	N/A	1, 2, 3
2. Automatic Actuation Logic	N/A	N/A	M (3)	1, 2, 3
c. Emergency Feedwater				
1. Main Feedwater Pump Turbines A and B Control Oil Low	S	R	N/A	1, 2, 3
2. OTSG A and B Level Low-Low	S	R	N/A	1, 2, 3, 4