PILGRIM NUCLEAR POWER STATION

CONTROLLED DOCUMENT TRANSMITTAL NOTICE

DOCUMENT TITLE: C	P-DP- 100, Rev. 17: CP-dP-225, Rev. 0
mergency P	lan In plementing Procedures Manual
TO: Muller	Legulatory Commiss MAIL:
CONTROLLED COPY NO).: 1/ TRANSMITTAL NO.: 02-008 DATE: 2-15-02
	FOR DOCUMENT CONTROL USE ONLY
\overline{X} 1. The att Please Instruct return	ached controlled document(s) are transmitted for your use. insert/remove as indicated on the attached Change tion Notice. Please check Block 6, sign this form and upon receipt.
/ 2. The cor Instruc Block 7	trolled document(s) listed on the attached Change tion Notice have been retired from use. Please check , sign this form and return upon receipt.
/_/ 3. This is were the status If you copy wi	yournotice. The document(s) indicated above ansmitted to you on Please check the of your controlled copy, sign this document and return. do not have these documents, check Block 5 and a new ll be issued.
/_7 4. Your na control this fo Control	The has been removed from the Distribution List of the led document listed above. Please check Block 7, sign orm and return it with the document to the Document Supervisor.
	COPY HOLDER CHECK ONE
/_/ 5. I am no issue a	t currently in possession of the above documents. Please nother set to me.
/_/ 6. I have indicat accordi	received from the sender the material and attachments as ed above, and I have updated my controlled manual ngly.
/ 7. I am re	turning the documents listed above.
PLEASE SIGN AND RE NO ENVELOPE REQUIR	TURN TO: Controlled Document Clerk, MAIL STOP #19 ED FOR INTERNAL COMPANY MAIL Entergy, Controlled Document Clerk Pilgrim Nuclear Power Station 600 Rocky Hill Road, Support Building Plymouth, Massachusetts 02360

Signature of Holder

Controlled Copy No. A045

۳.	CUMNGE TWO IKUCI	UCTION NOTICE CERE	
i	Transmittal No.: 02-068	Date: 2-15-02	
_}}	Please update your copy of $CP-d$, with the attachments to this transf	<u>AP-100, Rev. 17</u> ; <u>CP-AP-225, Rev. 0</u> nsmittal as instructed below.	
\smile	$\frac{\frac{\text{REMOVE AND DISCARD}}{100000000000000000000000000000000000$	$\frac{1}{1} \frac{1}{1000} \frac{1}{10000} \frac{1}{10000000000000000000000000000000000$	
	<u>CP-SP-100</u> 16 	e <u>CP-2P-100</u> 17 <u>CP-2P-225</u> 0	
		_	
·			
•			
i i	1		

. . . .

	PNPS	Emergency Plan Implementing Procedure Manual	Number: N/A
--	------	---	----------------

RType H8.24

TABLE OF CONTENTS

1	ιı	ypi	10.	24

Number	Title	<u>Revision</u>	Effective Date
EP-IP-100	Emergency Classification and Notification	17	02/15/02
EP-IP-200	On-Call Emergency Director	9	02/07/01
EP-IP-201	Emergency Plant Manager	2	08/08/01
EP-IP-202	Company Spokesperson	3	02/07/01
EP-IP-210	Control Room Augmentation	7	12/12/00
EP-IP-225	Severe accident Management Support	0	02/15/02
EP-IP-220	TSC Activation and Response	11	11/15/00
EP-IP-229	TSC/OSC Equipment Operation	5	07/25/00
EP-IP-230	OSC Activation and Response	4	08/08/01
EP-IP-231	Onsite Radiation Protection	6	08/29/01
EP-IP-240	Emergency Security Organization Activation and Response	9	09/17/01
EP-IP-250	EOF Activation and Response	9	02/07/01
EP-IP-251	Offsite Radiation Protection	5	12/26/00
EP-IP-252	Facilities Support	7	02/01/01
EP-IP-253	Relocation of the EOF	3	07/13/00
EP-IP-254	Communications Support	2	12/06/00
EP-IP-259	EOF Equipment Operation	4	09/17/01
EP-IP-300	Offsite Radiological Dose Assessment	4	05/01/01
EP-IP-310	Radiation Monitoring Team Activation and Response	4	11/15/00
EP-IP-315	Personnel Monitoring Team Activation and Response	4	05/24/00
EP-IP-330	Core Damage	4	12/10/01
EP-IP-400	Protective Action Recommendations	9	10/03/01

PNPS	Emergency Plan Implementing Procedure Manual	Number: N/A

TABLE OF CONTENTS

RType H8.24

Number	Title	Revision	Effective <u>Date</u>
EP-IP-410	Evacuation/Assembly	5	09/17/01
EP-IP-420	Search and Rescue	3	02/12/01
EP-IP-440	Emergency Exposure Controls	6	08/08/02
EP-IP-501	Transport of Contaminated Injured Personnel	3	05/24/00
EP-IP-520	Transition and Recovery	5	02/07/01

PILGRIM NUCLEAR POWER STATION

Procedure No. EP-IP-100

EMERGENCY CLASSIFICATION AND NOTIFICATION



SAFETY RELATED

REVISION LOG

REVISION 17	Date Originated 1/02
Pages Affected	Description
9-11,15,31,42,43	Replace OSS with Shift Manager to reflect organizational title change.
27	Revise the sustained RPV water level from < -160 inches to < -165 inches for EAL 2.1.1.4.
27	Revise EAL wording to add "Reactor power > 3%" as one of the entry conditions for EAL 2.3.1.3.
28	Revise EAL wording to "Bulk drywell temperature cannot be restored and maintained < -280°F" and change figure reference for the HCTL curve from "Figure 3" to "Figure 2" for EAL 3.2.1.3.
28	Delete EAL 3.3.1.4, Primary Containment water level cannot be maintained < 77 feet.
28	Revise wording in EAL 3.3.1.3 to "Torus water level cannot be maintained below 175 inches (SRV Tail Pipe Level Limit (STPLL))".
28	Revise EAL wording from "Torus pressure" to "Torus Bottom pressure" and change figure reference from "EOP Figure 7" to "EOP Figure 4" for EAL 3.4.1.4.
REVISION 16	Date Originated 11/01
Pages Affected	Description
27	Revise EAL 1.4.1.4 and EAL 1.4.1.3 for Torus High Range Area Radiation Monitors due to relocation of detectors.
REVISION 15	Date Originated 5/01
Pages Affected	Description
14	Change the term from "current" to "prior" classification level for instructions when lowering a classification.
27	Revise EAL 1.4.1.4 and EAL 1.4.1.3 for Drywell and Torus High Range Area Radiation Monitors.
31	Correct Seismic Recorder Operating annunciator panel location for EAL 7.4.3.1.

TABLE OF CONTENTS

<u>Page</u>

1.0	PURF	POSE	5
2.0	REFERENCES		
3.0	DEFI	NITIONS	5
4.0	RESF	PONSIBILITIES	9
5.0	PRO	CEDURE	10
	5.1	RECOGNIZING AN EMERGENCY	10
	5.2	INITIAL DECLARATION OF AN EMERGENCY FROM THE CONTROL ROOM	10
	5.3	WHILE IN A CLASSIFIED EMERGENCY	12
	5.4	TRANSITORY EVENTS	13
	5.5	DOWNGRADING EMERGENCY CLASSIFICATIONS	14
	5.6	TRANSITION TO RECOVERY	15
	5.7	INITIAL NOTIFICATION FORM DESCRIPTION	15
	5.8	FOLLOW-UP INFORMATION FORM DESCRIPTION	17
6.0	RECO	ORDS	18
7.0	ATTA	CHMENTS	19
	ATTA	CHMENT 1 - UNUSUAL EVENT NOTIFICATIONS CHECKLIST	20
	ATTA	CHMENT 2 - ALERT NOTIFICATIONS CHECKLIST	21
	ΑΤΤΑ	CHMENT 3 - SITE AREA EMERGENCY NOTIFICATIONS CHECKLIST	23
	ΑΤΤΑ	CHMENT 4 - GENERAL EMERGENCY NOTIFICATIONS CHECKLIST.	25
	ATTA	CHMENT 5 - EMERGENCY ACTION LEVELS	27

TABLE OF CONTENTS (Continued)

<u>Page</u>

ATTACHMENT 6 - SAMPLE - INITIAL NOTIFICATION FORM	32
ATTACHMENT 7 - SAMPLE - FOLLOW-UP INFORMATION FORM	35
ATTACHMENT 8 - SAMPLE - TERMINATION CHECKLIST	38
ATTACHMENT 9 - SAMPLE - ESSENTIAL INFORMATION CHECKLIST	40
ATTACHMENT 10 - ACTIVATION OF THE EMERGENCY RESPONSE ORGANIZATION	42
ATTACHMENT 11 - DOCUMENT CROSS-REFERENCES	46
ATTACHMENT 12 - IDENTIFICATION OF COMMITMENTS	47

1.0 <u>PURPOSE</u>

This Procedure provides instruction of the entry conditions at which specific emergency classifications must be declared, guidelines for the implementation of the Emergency Plan, and the process used to notify response personnel and organizations.

2.0 <u>REFERENCES</u>

- [1] EP-AD-600, "Emergency Action Level Technical Bases"
- [2] EP-PP-01, "PNPS Emergency Plan"
- [3] PNPS Technical Specifications

3.0 **DEFINITIONS**

- [1] <u>Adequate Core Cooling</u> Heat removal from the Reactor sufficient to prevent rupturing the fuel clad. Three viable mechanisms for establishing adequate core cooling are defined: core submergence, spray cooling, and steam cooling.
 - (a) <u>Submergence</u> is the preferred method for cooling the core. The core is adequately cooled by submergence when it can be determined that RPV water level is at or above the top of the active fuel. All fuel nodes are then assumed to be covered with water and heat is removed by boiling heat transfer.
 - (b) Adequate <u>Spray Cooling</u> is provided, assuming a bounding axial power shape, when at least one Core Spray subsystem is injecting into the RPV at the design flow rate (3,600 GPM) and RPV water level is at or above the elevation of the jet pump suctions (-175 in.). The covered portion of the core is then cooled by submergence while the uncovered portion is cooled by the spray flow. The required spray flow must be supplied by a single subsystem to ensure adequate spray distribution to all fuel bundles.
 - (c) <u>Steam Cooling</u> is relied upon only if RPV water level cannot be restored and maintained above the top of the active fuel, cannot be determined, or must be intentionally lowered below the top of the active fuel. The core is adequately cooled by steam if the steam flow across the uncovered length of each fuel bundle is sufficient to maintain the hottest peak clad temperature below the appropriate limiting value; 1500°F if makeup can be injected, 1800°F if makeup cannot be injected. The covered portion of the core remains cooled by boiling heat transfer and generates the steam which cools the uncovered portion.

Steam cooling with makeup capability is established by maintaining RPV water level above the Minimum Steam Cooling RPV Water Level (-150 in.) or RPV pressure above the Minimum Alternate RPV Flooding Pressure (a function of the number of open SRVs). In either case, the peak clad temperature is limited to 1500°F, the threshold for fuel rod perforation.

Steam cooling without makeup capability is established as long as RPV water level remains above the Minimum Zero-Injection RPV Water Level (-160 in.). The peak clad temperature is permitted to rise to 1800°F, the threshold for significant metal-water reaction, to maximize the heat transfer to steam and to delay the need for RPV depressurization as long as possible. The minimum RPV water level at which adequate steam flow exists is higher when makeup capability exists because:

- The limiting fuel temperature is lower (1500°F). The higher limit of 1800°F is used only when cladding perforation cannot be avoided.
- With injection, water at the core inlet is subcooled. Some of the energy produced by the core must then be expended in raising the temperature of the liquid to saturation and less steam will be produced to cool the uncovered portions of the core.
- [2] <u>Alert</u> Events are in progress or have occurred which involve an actual or potential substantial degradation of the level of safety at PNPS. Any releases are expected to be limited to small fractions of EPA Protective Action Guideline exposure levels.
- [3] <u>BECONS</u> The PNPS community offsite notification system.
 - [4] <u>Cannot Be Determined</u> The current value or status of an identified parameter relative to that specified in the Emergency Action Level (EAL) cannot be ascertained using all available indications (direct and indirect, singly or in combination).
 - [5] <u>Cannot Be Maintained Above/Below</u> The value of the identified parameter(s) is not able to be kept above/below specified limits. This determination includes making an evaluation that considers both current and future system performance in relation to the current value and trend of the parameter(s). It does not imply that the actual value of the parameter must first pass the specified limit.
 - [6] <u>Cannot Be Restored Above/Below</u> The value of the identified parameter(s) is not able to be returned to above/below specified limits after having passed those limits. This determination includes making an evaluation that considers both current and future system performance in relation to the current value and trend of the parameter(s). It does not imply any specific time interval, but does not permit prolonged operation beyond the limit without declaring the specified emergency classification. (May be used in combination with Definition 3.0[5].)

- [7] <u>Computerized Automated Notification System (CANS)</u> A computer-assisted system that, when activated, has the following capabilities:
 - (a) Activating the emergency pager system.
 - (b) Accepting calls from authorized responders to inform them of an abnormal or emergency condition at PNPS.
 - (c) Calling response personnel at their home or work phone to inform them of an abnormal or emergency condition at PNPS.
 - (d) Maintaining an updated list of personnel responding and their estimated time of arrival at their facility.
- [8] <u>Controlled Process</u> A preplanned activity for which the conditions specified in an EAL are anticipated to be or are intentionally exceeded as part of an approved Procedure.
- [9] <u>DNN</u> Digital Notification Network.
- [10] <u>Emergency Radioactive Release is/is not in Progress</u> For purposes of offsite notification, any release of radioactivity is considered 'an emergency radioactive release in progress which:
 - Meets any EAL of Classification Subsection 5.1, Effluent Monitors

<u>OR</u>

- Involves an actual or suspected Turbine Building or unmonitored release which is associated with the emergency event.
- [11] Emergency Radioactive Release is above/below Protective Action Guides (PAGs) -PAGs are defined by the EPA as dose in excess of 1 rem TEDE or 5 rem CDE Thyroid. For purposes of offsite notification, an emergency radioactive release is considered above PAGs when:
 - General Emergency EAL 5.2.1.4 or EAL 5.2.2.4 is exceeded based on having dose projections or offsite measurements.

- In the absence of having dose projections or offsite measurements. General Emergency EAL 5.1.1.4 is exceeded.
- [12] <u>ENS</u> NRC Emergency Notification System.
- [13] <u>Essential Information Checklist</u> The form used by oncoming Emergency Director when relieving present Emergency Director of the responsibilities outlined in this Procedure. This form may also be used to provide information to Media Center and Corporate personnel.

- [14] <u>Essential Personnel</u> Those individuals assigned specific emergency response duties as identified in the PNPS Emergency Plan and Implementing Procedures.
- [15] <u>Follow-Up Information Form</u> The form used to initiate and document periodic emergency classification updates to offsite agencies.
 - [16] <u>General Emergency</u> Events are in progress or have occurred which involve actual or imminent substantial core degradation or melting with the potential for loss of containment integrity. Releases can be expected to exceed EPA Protective Action Guideline exposure levels for more than the area near the site boundary.
 - [17] <u>Initial Notification Form</u> The form used to initiate and document initial emergency classification notifications to offsite agencies.
 - [18] <u>Non-Essential Personnel</u> Personnel who are not assigned specific emergency response duties.
 - [19] <u>Primary System</u> The pipes, valves, and other equipment which connect directly to the Reactor Pressure Vessel (RPV) such that a reduction in RPV pressure will effect a decrease in the steam or water being discharged through an unisolated break in the system.
 - [20] <u>Radiation Monitor Channel A and B Above/Below EAL Threshold Readings</u> The value of both channels statements above or below a threshold reading may not apply when one channel is known to be inoperable or out of service. The determination of a valid reading on either channel that exceeds the EAL threshold constitutes that the intent of the EAL has been met and the associated classification should be declared.
 - [21] <u>Shutdown</u> As regards Reactor status, the Reactor is shutdown if the Reactor is subcritical (power decreasing) and below the heating range (IRM range 7).
 - [22] <u>Site Area Emergency</u> Events are in progress or have occurred which involve actual or likely major failures of PNPS functions needed for the protection of the public. Any releases are not expected to exceed EPA Protective Action Guidelines exposure levels except near the site boundary.
 - [23] <u>Sustained Loss</u> Loss of power supply, system or component operability for which the return to service has not been determined to be imminent. It does not imply any specific time interval, but prolonged operation is not permitted without declaring the specified emergency condition based on the potential for degraded plant safety.
 - [24] <u>Termination</u> The point at which the event is no longer considered to be an emergency. Termination of the emergency is formally identified by an Initial Notification message transmission and entry into Recovery.
 - [25] <u>Transitory Event</u> An event in which PNPS exceeded an Emergency Action Level (EAL) but conditions improved prior to classification.

[26] <u>Unusual Event</u> - Events are in progress or have occurred that indicate a potential degradation of the level of safety at PNPS. No releases of radioactive material requiring offsite response or monitoring are expected unless further degradation of safety systems occurs.

4.0 **RESPONSIBILITIES**

- [1] The Shift Manager, or the Control Room Supervisor if the Shift Manager is incapacitated or away from the Control Room, shall be responsible for the initial emergency classification declaration and implementation of this Procedure.
- [2] The Shift Manager, or Control Room Supervisor if the Shift Manager is unavailable, shall assume the role of Emergency Director upon initial declaration of any emergency classification and shall continue to function as the Emergency Director until relieved of those duties by the on-call Emergency Director or other qualified individual (i.e., Emergency Plant Operations Supervisor or off-shift Shift Manager).
- [3] The Emergency Director is the final authority for determining the emergency classification level (initial classification, downgrading, or terminating to recovery). This authority may not be delegated.
- [4] The Emergency Director is responsible for directing and overseeing notification of the on-call PNPS Emergency Response Organization.
- [5] The Control Room Operations Assistant or a designated alternate is responsible for the following:
 - (a) When directed, notifying the on-call PNPS Emergency Response Organization.
 - (b) Periodically checking on the status of personnel responding to the notification process.
 - (c) If CANS and BEEPS fail, Security is responsible for notifying on-call personnel using commercial telephone lines.

5.0 PROCEDURE

5.1 RECOGNIZING AN EMERGENCY

- [1] When indications of abnormal conditions are received, personnel will verify the symptoms/indications and then compare them with the Emergency Action Levels (Attachment 5).
- [2] Identify the highest emergency classification level (if multiple EALs are exceeded) for which an EAL has been met or exceeded considering the following:
 - (a) If conditions warrant the issuance of Protective Action Recommendations (PARs), the classification of General Emergency will be made.
 - (b) If plant conditions indicate a possible radiological release or a release is in progress or suspected, evaluate the applicability of offsite dose-based EALs (category 5.2).
 - (c) If a classification level was met or exceeded but the classifiable condition no longer exists (a lesser classification level may or may not still be appropriate), refer to Section 5.4, Transitory Events.
- 5.2 INITIAL DECLARATION OF AN EMERGENCY FROM THE CONTROL ROOM
- [1] The Shift Manager, or Control Room Supervisor if the Shift Manager is unavailable, shall announce to the Control Room operating staff:
 - (a) That an emergency has been declared.
 - (b) The emergency classification level.
 - (c) That the Shift Manager (Control Room Supervisor) has assumed the role of Emergency Director.
- [2] Conduct initial emergency notifications as follows:

<u>NOTE</u>

In the event the public address system is inoperative during notifications to Station personnel at any time, determine alternate means to disseminate information to plant personnel.

(a) For events which are classified as a General Emergency, complete the General Emergency Notifications Checklist (Attachment 4).

<u>NOTE</u>

If during the declaration process it becomes necessary to <u>upgrade</u> the emergency classification level before the actual initial notification transmittal, do not send simultaneous notifications. Generate and send a new notification form with the appropriate classification level.

- (b) For events which are classified as a Site Area Emergency, complete the Site Area Emergency Notifications Checklist (Attachment 3).
- (c) For events which are classified as an Alert, complete the Alert Notifications Checklist (Attachment 2).
- (d) For events which are classified as an Unusual Event, complete the Unusual Event Notifications Checklist (Attachment 1).
- [3] Contact (or direct an assistant to contact) the on-shift Radiation Protection Supervisor/Technician and direct them to review EP-IP-231 and assume the responsibilities of the Onsite Radiological Supervisor for emergency exposure controls until relieved by the on-call Onsite Radiological Supervisor.
- [4] Contact (or direct an assistant to contact) on-shift Maintenance personnel not already involved in the emergency and inform them to report to the Control Room or the OSC to stand by for repair and corrective action activities if necessary.
- [5] The Emergency Plant Operations Supervisor (EPOS) may relieve the Shift Manager as Emergency Director until the on-call Emergency Director assumes responsibility for the position in the EOF.
- [6] The on-shift Emergency Director will remain in the Control Room until relieved by the on-call Emergency Director.

- 5.3 WHILE IN A CLASSIFIED EMERGENCY
- [1] As soon as possible, but no later than 1 hour after event classification, ensure that the ENS or a commercial telephone line is continuously staffed with a knowledgeable individual to provide additional event notification and plant information to the NRC.
- [2] Emergency response personnel will continuously review the Emergency Action Levels (Attachment 5) to ensure proper and appropriate event classification.
 - (a) If the declaration of a higher classification is warranted, conduct initial emergency notifications as follows:
 - (1) For events which are classified as a General Emergency complete the General Emergency Notifications Checklist (Attachment 4).

<u>NOTE</u>

If during the declaration process it becomes necessary to <u>upgrade</u> the emergency classification level before the actual initial notification transmittal, do not send simultaneous notifications. Generate and send a new notification form with the appropriate classification level.

- (2) For events which are classified as a Site Area Emergency, complete the Site Area Emergency Notifications Checklist (Attachment 3).
- (3) For events which are classified as an Alert, complete the Alert Notifications Checklist (Attachment 2).
- (b) If a higher classification level was met but that classifiable condition no longer exists (a lesser classification level may or may not still be appropriate), refer to Section 5.4, Transitory Events.
- (c) If the emergency conditions support downgrading the classification level, refer to Section 5.5, Downgrading Emergency Classifications.
- (d) If the situation has been controlled and a state of emergency is no longer necessary, refer to Section 5.6, Transition to Recovery.
- [3] Provide periodic updates (hourly or whenever conditions change) to the Commonwealth and local communities using Follow-Up Information Forms (Attachment 7).
- [4] As conditions improve and additional personnel and resources become available, certain recovery activities (described in EP-IP-520) may be initiated prior to termination of the emergency.

- [5] Turnover of the Emergency Director Position
 - (a) The offgoing Emergency Director will provide the oncoming Emergency Director with a briefing of the emergency conditions and the status of offsite notifications.
 - (b) Items contained on the Essential Information Checklist (Attachment 9) will be used to facilitate the turnover briefing as follows:
 - (1) The offgoing Emergency Director may complete an essential Information Checklist and provide a copy to the oncoming Emergency Director to be used for the turnover briefing.
 - (2) The oncoming Emergency Director may complete an Essential Information Checklist while covering each item during conduct of the turnover briefing.
 - (c) Discuss any Protective Action Recommendations issued to offsite agencies as applicable.
- 5.4 TRANSITORY EVENTS
- [1] For situations which begin under non-emergency conditions then experience events which ultimately result in a classifiable emergency, enter and execute the following Attachment which corresponds to the appropriate current classification level:
 - (a) Attachment 1, Unusual Event Notifications Checklist.
 - (b) Attachment 2, Alert Notifications Checklist.
 - (c) Attachment 3, Site Area Emergency Notifications Checklist.
- [2] For situations which begin under non-emergency conditions, experience events which qualify as a classifiable emergency, and result in conditions which no longer meet a classification level:
 - (a) Consider the following items prior to entering Recovery:
 - (1) Conditions no longer meet an Emergency Action Level and it appears unlikely that conditions will deteriorate.
 - (2) Plant releases of radioactive materials to the environment are under control (within Technical Specifications) or have ceased and the potential for an uncontrolled radioactive release is acceptably low.
 - (3) The Reactor is in a stable condition and long-term core cooling is available.
 - (4) Offsite conditions do not unreasonably limit access of outside support to the Station and qualified personnel and support services are available.

- (b) Complete and distribute an Initial Notification Form to specify the transitory event classification level and signify entry into Recovery (EAL number 0.0.0.0 is used to signify entry into Recovery).
- (c) Exit this Procedure and enter EP-IP-520, "Transition and Recovery."
- [3] For situations which begin in a classified emergency then experience events which ultimately result in:
 - (a) <u>A return to the current classification level</u>

Complete and distribute an Initial Notification Form to specify the transitory event classification level and signify return to the current classification level.

<u>NOTE</u>

Transitory events which occur during an emergency cannot directly result in a downgraded classification level or entry into Recovery. These actions must be performed separately.

(b) A lower classification level or no longer meet a classification level

Complete and distribute an Initial Notification Form to specify the transitory event classification level and signify return to the prior classification level.

- [4] Return to Section 5.3.
 - 5.5 DOWNGRADING EMERGENCY CLASSIFICATIONS
 - [1] Once in an Alert or higher classification level, the decision to downgrade below the Alert level shall only be made after the TSC, OSC, and EOF have been activated.
 - [2] Have the Control Room make the following announcement over the public address system, <u>TWICE</u>:

"Attention all personnel, attention all personnel: The emergency classification level has been downgraded to a/an (applicable classification level)."

- [3] Complete and distribute an Initial Notification Form to signify entry into the lower emergency classification level.
- [4] Return to Section 5.3.

5.6 TRANSITION TO RECOVERY

- [1] If a state of emergency is no longer necessary based on plant status conditions, complete the Termination Checklist (Attachment 8) to determine whether conditions allow termination of the event and entry into Recovery.
- [2] If conditions allow for termination of the emergency and entry into Recovery, exit this Procedure and enter EP-IP-520, *"Transition and Recovery"*.
- [3] If conditions do not support termination of the emergency and entry into Recovery, continue following the guidance provided in Section 5.3 of this Procedure.
- 5.7 INITIAL NOTIFICATION FORM DESCRIPTION

<u>NOTE</u>

Upon activation of the EOF, the Control Room and EOF must coordinate the numbering sequence of notifications to ensure consecutive numbers are assigned to notification forms.

- [1] <u>Form Number</u>: Notification form numbers are assigned sequentially from the start of the emergency. The sequence includes the Initial Notification Form as well as the Follow-Up Information Form.
- [2] <u>Block 1</u>: Designation for notifications conducted as part of a drill or exercise versus an actual event.
 - [3] <u>Block 2:</u> Specifies the time, circumstance, and classification level applicable to the notification form as follows:
 - (a) The time and date denote the point at which the Emergency Director (or Shift Manager) recognized and formally declared the new event classification level.
 - (b) The "entered" check box is used when the first Initial Notification Form is completed for an emergency.
 - (c) The "transitory" check box is used to provide a location to enter the highest classification level which was met during a transitory event.
 - (d) The "upgraded to" check box is used to provide initial notification of emergencies which require the declaration of a higher classification.
 - (e) The "downgraded to" check box is used to provide initial notification of emergencies which warrant lowering the classification level.
 - (f) The classification level boxes are used to indicate the classification applicable to the notification.

- [4] <u>Block 3:</u> Provides the applicable EAL number and description for the specified classification level as follows:
 - (a) For events with more than one EAL in the highest classification level, provide the EAL number for which the event was classified on. Additional EAL numbers may be provided in the description section if desired.
 - (b) EAL number 0.0.0.0 is used to signify entry into Recovery.
 - (c) A brief non-technical description (avoiding abbreviations and acronyms) is provided in enough detail to allow an understanding of the nature of the EAL number (and the transitory event if applicable).
- [5] <u>Block 4:</u> Provides indication of an emergency radioactive release and the relative magnitude. If necessary, refer to EP-IP-400, *"Protective Actions"*, to determine whether an emergency release is in progress, whether an emergency release is above protective action guides, and what protective action recommendations are necessary.
- [6] <u>Block 5:</u> Provides the most recent meteorological data obtained from any of the available sources.
- [7] <u>Block 6:</u> Provides any applicable protective action recommendations made by PNPS ERO personnel as follows
 - (a) Protective Action Recommendations are only issued by PNPS in a General Emergency. If the classification level is not a General Emergency, the "No Protective Actions Necessary" check box shall be selected.
 - (b) If MEMA or MDPH representatives are present in the EOF and the classification level is General Emergency, the "Provided to MEMA/MDPH" check box is selected.
 - (c) If MEMA or MDPH representatives are not present in the EOF and the classification level is General Emergency, the appropriate protective action recommendations check boxes and affected subareas are selected.
- [8] <u>Block 7:</u> Indicates the time and date when transmission of the form was begun and the name of the individual performing the transmission.
- [9] <u>Block 8:</u> Indicated the time and date when transmission of the form was received and the name of the individual receiving the transmission.
- [10] <u>Block 9:</u> Provides the protective action recommendations made by PNPS ERO personnel when MEMA or MDPH representatives are present in the EOF (only applicable for General Emergency classifications).
- [11] Block 10: Emergency Director approval signature.

5.8 FOLLOW-UP INFORMATION FORM DESCRIPTION

- [1] <u>Form Number</u>: Notification form numbers are assigned sequentially from the start of the emergency. The sequence includes the Initial Notification Form as well as the Follow-Up Information Form.
- [2] <u>Block 1</u>: Designation for notifications conducted as part of a drill or exercise versus an actual event.
- [3] <u>Block 2:</u> Specifies the time and classification level applicable to the Follow-Up Information Form.
- [4] <u>Block 3:</u> Indicates the prevailing trend for conditions at the Station.
- [5] <u>Block 4:</u> Provides the applicable EAL number and description for the specified classification level as follows:
 - (a) For events with more than one EAL in the highest classification level, provide the EAL number for which the event was classified on. Additional EAL numbers may be provided in the description section if desired.
 - (b) A brief non-technical description (avoiding abbreviations and acronyms) is provided in enough detail to allow an understanding of the nature of the EAL number.
- [6] <u>Block 5:</u> Indicates whether offsite assistance has been requested, the type of assistance, and the reason for the request.
- [7] <u>Block 6:</u> Provides indication of an emergency radioactive release and the relative magnitude. If necessary, refer to EP-IP-400, *"Protective Actions"*, to determine whether an emergency release is in progress, whether an emergency release is above protective action guides, and what protective action recommendations are necessary.
- [8] <u>Block 7:</u> Provides the most recent meteorological data obtained from any of the available sources.
- [9] <u>Block 8:</u> Provides any applicable protective action recommendations made by PNPS ERO personnel as follows:
 - (a) Protective Action Recommendations are only issued by PNPS in a General Emergency. If the classification level is not a General Emergency, the "No Protective Actions Required" check box shall be selected.
 - (b) If MEMA or MDPH representatives are present in the EOF and the classification level is General Emergency, the "Provided to MEMA/MDPH" check box is selected.

- (c) If MEMA or MDPH representatives are not present in the EOF and the classification level is General Emergency, the appropriate Protective Action Recommendations check boxes and affected subareas are selected.
- [10] <u>Block 9:</u> Indicates the time and date when transmission of the form was begun and the name of the individual performing the transmission.
- [11] <u>Block 10:</u> Indicates the time and date when transmission of the form was received and the name of the individual receiving the transmission.
- [12] <u>Block 11:</u> Provides the protective action recommendations and their bases made by PNPS ERO personnel when MEMA or MDPH representatives are present in the EOF (only applicable for General Emergency classifications).
- [13] <u>Block 12:</u> Emergency Director approval signature.

6.0 <u>RECORDS</u>

- [1] The following documents are generated as a result of the implementation of this Procedure:
 - (a) Unusual Event Notifications Checklist
 - (b) Alert Notifications Checklist
 - (c) Site Area Emergency Notifications Checklist
 - (d) General Emergency Notifications Checklist
 - (e) Essential Information Checklist
 - (f) Initial Notification Form
 - (g) Follow-Up Information Form
 - (h) Termination Checklist
- [2] All records shall be forwarded to Emergency Preparedness for final disposition following the termination of the emergency.

7.0 ATTACHMENTS

ATTACHMENT 1 - UNUSUAL EVENT NOTIFICATIONS CHECKLIST

ATTACHMENT 2 - ALERT NOTIFICATIONS CHECKLIST

ATTACHMENT 3 - SITE AREA EMERGENCY NOTIFICATIONS CHECKLIST

ATTACHMENT 4 - GENERAL EMERGENCY NOTIFICATIONS CHECKLIST

ATTACHMENT 5 - EMERGENCY ACTION LEVELS

ATTACHMENT 6 - SAMPLE - INITIAL NOTIFICATION FORM

ATTACHMENT 7 - SAMPLE - FOLLOW-UP INFORMATION FORM

ATTACHMENT 8 - SAMPLE - TERMINATION CHECKLIST

ATTACHMENT 9 - SAMPLE - ESSENTIAL INFORMATION CHECKLIST

ATTACHMENT 10 - ACTIVATION OF THE EMERGENCY RESPONSE ORGANIZATION

ATTACHMENT 11 - DOCUMENT CROSS-REFERENCES

ATTACHMENT 12 - IDENTIFICATION OF COMMITMENTS

UNUSUAL EVENT

NOTIFICATION OF STATION PERSONNEL - STANDBY STATUS

CAUTION

During a security threat it may be advisable **NOT** to sound an alarm.

Sound/have the Control Room sound the Operator Recall Alarm and make the following announcement over the public-address system, <u>TWICE</u>:

- A. "Attention all personnel, attention all personnel: An Unusual Event has been declared due to (<u>brief description of initiating event</u>). All on-call members of the Emergency Response Organization stand by for further instructions. All other personnel continue with your present duties until additional instruction is given."
- B. If there is a localized emergency (for example, high radiation, fire), announce its type and location and instruct personnel to stand clear of this area.

Time Completed: _

NOTIFICATION OF THE ERO - STANDBY STATUS

Notify or direct notification of the ERO in accordance with Attachment 10, Activation of the Emergency Response Organization.

Time Completed: _

NOTIFICATION OF STATE AND LOCAL AGENCIES

Within 15 minutes of the event classification transmit an Initial Notification Form (Attachment 6) to the Commonwealth and local authorities.

Time Completed: _

NOTIFICATION OF THE NRC

Inform the NRC of the event classification using the ENS or a commercial telephone (Attachment 6 Step 4).

Time Completed:

RETURN TO THE PROCEDURE

(EITHER STEP 5.2[2] OR 5.4[1])

ALERT

SITE & PUBLIC AREA NOTIFICATION - RELEASE OF NONESSENTIAL PERSONNEL

CAUTION

During a security threat it may be advisable **NOT** to sound an alarm.

Sound/have the Control Room sound the Operator Recall Alarm and make the following announcement over the public-address system, <u>TWICE</u>:

- A. "Attention all personnel, attention all personnel: An Alert has been declared due to (<u>brief</u> <u>description of initiating event</u>). All on-call members of the Emergency Response Organization report to your designated emergency response facility. All Pilgrim Station personnel assemble in your normal office or shop area, report to your supervisor, and await instructions. All visitors, all nonessential contractor personnel, all declared pregnant females, and all persons with disabilities please leave the site at this time."
- B. If there is a localized emergency (for example, high radiation, fire), announce its type and location and instruct personnel to stand clear of this area.
- C. If there is a potential for an airborne radiological release, consider announcing that there will be no eating, drinking, or smoking until further notice.

Time Completed: _

NOTIFICATION OF THE ERO - EMERGENCY FACILITY ACTIVATION

Notify or direct notification of the ERO in accordance with Attachment 10, Activation of the Emergency Response Organization.

Time Completed:

NOTIFICATION OF STATE AND LOCAL AGENCIES

Within 15 minutes of the event classification transmit an Initial Notification Form (Attachment 6) to the Commonwealth and local authorities.

Time Completed: _

ALERT (Continued)

NOTIFICATION OF THE NRC

Inform the NRC of the event classification using the ENS or a commercial telephone (Attachment 6 Step 4).

Time Completed:

ACTION VERIFICATION

Ensure Security has evacuated and closed public access areas.

Time Completed:

RETURN TO THE PROCEDURE

(EITHER STEP 5.2[2], 5.3[2](a), OR 5.4[1])

SITE AREA EMERGENCY

ASSEMBLY AREA DESIGNATION	
Determine the Assembly Area based on meteo	rological conditions as follows:
Assembly Area	Wind Direction (° from)
Support Building Cafeteria	000°-289° or 324°-360°
Chiltonville Training Center	290°-323°
NOTIFICATION OF SECURITY (IF NOT PREVIOUSLY D	<u>ONE)</u>
 Inform Security of the location of the design time of the Site Area Emergency. 	ated Assembly Area and the official declaration
2. Direct Security to ensure that personnel in t area.	he Support Building are sent to their assembly
3. Direct Security to initiate personnel account	ability procedures.
4. Direct Security to verify public access areas	are being/have been evacuated.
	Time Notified:
SITE & PUBLIC AREA NOTIFICATION - PROTECTED	AREA EVACUATION
<u>CAU</u>	I <u>TION</u>
During a security threat it may be advisable <u>NC</u>)T to sound an alarm.
이 가는 것이 것 사람들은 것 같은 것이 같아? 것 것 가장을 통해 방법에 가지 않았다. 것 같은 것 같은 것은 것 같아? 수 방법을 받을 것 같다.	建成 사용화로 승규는 사용화로 통하여 방송을 주는 것 같은 것은 사람들이 가는 것을 하는 것을 가지고 있는 것
Consider radiological conditions when preparin be encountered, it may be better to shelter non	g to evacuate personnel. If high dose rates will -essential personnel on-site.
Consider radiological conditions when preparin be encountered, it may be better to shelter non Sound/have the Control Room sound the Emer following announcement over the public-addres	g to evacuate personnel. If high dose rates will -essential personnel on-site. gency Site Evacuation Alarm and make the ss system, <u>TWICE</u> :
 Consider radiological conditions when preparin be encountered, it may be better to shelter non Sound/have the Control Room sound the Emer following announcement over the public-addres A. If entering from no event or an Unusual Even "Attention all personnel, attention all person due to (<i>brief description of event</i>). All on-car report to your designated emergency respo (Assembly Area)." 	g to evacuate personnel. If high dose rates will -essential personnel on-site. gency Site Evacuation Alarm and make the ss system, <u>TWICE</u> : <u>ent:</u> nel: A Site Area Emergency has been declared II Emergency Response Organization members nse facility. All other personnel evacuate to

Continued on next page.

SITE AREA EMERGENCY (Continued)

SITE & PUBLIC AREA NOTIFICATION - PROTECTED AREA EVACUATION (CONTINUED)

- B. If there is a localized emergency (for example, high radiation, fire), announce its type and location and instruct personnel to stand clear of this area.
- C. If there is a potential for an airborne radiological release, consider announcing that there will be no eating, drinking, or smoking until further notice.

Time Completed: _____

NOTIFICATION OF THE ERO - EMERGENCY FACILITY ACTIVATION

If not already notified, notify or direct notification of the ERO in accordance with Attachment 10, Activation of the Emergency Response Organization.

Time Completed: _____

NOTIFICATION OF STATE AND LOCAL AGENCIES

Within 15 minutes of the event classification transmit an Initial Notification Form (Attachment 6) to the Commonwealth and local authorities.

Time Completed: _____

NOTIFICATION OF THE NRC

Inform the NRC of the event classification using the ENS or a commercial telephone (Attachment 6 Step 4).

Time Completed: ____

VERIFY ACCOUNTABILITY

Security should report within 30 minutes of declaration of a Site Area Emergency that accountability is complete and provide the names of missing persons, if any. Log the time that accountability was completed.

Time Completed: ____

ACTION VERIFICATION

Ensure Security has evacuated and closed public access areas.

Time Completed: _____

RETURN TO THE PROCEDURE

(EITHER STEP 5.2[2], 5.3[2](a), OR 5.4[1])

GENERAL EMERGENCY

Assembly Area Designation Determine the Assembly Area based on meteorological conditions as follows: Assembly Area Wind Direction (° from) Support Building Cafeteria 000°-289° or 324°-360° Chiltonville Training Center 290°-323°

- 1. Inform Security of the location of the designated Assembly Area and the official declaration time of the General Emergency
- 2. Direct Security to ensure that personnel in the Support Building are sent to their assembly area.
- 3. Direct Security to initiate personnel accountability procedures.
- 4. Direct Security to verify public access areas are being/have been evacuated.

Time Notified:

SITE & PUBLIC AREA NOTIFICATION - PROTECTED AREA EVACUATION

CAUTION

During a security threat it may be advisable **<u>NOT</u>** to sound an alarm.

Consider radiological conditions when preparing to evacuate personnel. If high dose rates will be encountered, it may be better to shelter nonessential personnel on-site.

Sound/have the Control Room sound the Emergency Site Evacuation Alarm and make the following announcement over the public-address system, <u>TWICE</u>:

A. <u>If entering into a General Emergency from an Alert or lower:</u> "Attention all personnel, attention all personnel: A General Emergency has been declared due to (<u>brief description of event</u>). All on-call members of the Emergency Response Organization report to your designated emergency response facility. All other personnel evacuate to (*Assembly Area*). There will be no eating, drinking, or smoking until further notice."

<u>If upgrading from an Site Area Emergency:</u> "Attention all personnel, attention all personnel: A General Emergency has been declared due to (*brief description of event*). There will be no eating, drinking, or smoking until further notice."

Continued on next page.

GENERAL EMERGENCY (CONTINUED)

SITE & PUBLIC AREA NOTIFICATION - PROTECTED AREA EVACUATION (CONTINUED)

B. If there is a localized emergency (for example, high radiation, fire), announce its type and location and instruct personnel to stand clear of this area.

Time Completed: _

NOTIFICATION OF THE ERO - EMERGENCY FACILITY ACTIVATION

If not already notified, notify or direct notification of the ERO in accordance with Attachment 10, Activation of the Emergency Response Organization.

Time Completed: ____

NOTIFICATION OF STATE AND LOCAL AGENCIES

Within 15 minutes of the event classification transmit an Initial Notification Form (Attachment 6) to the Commonwealth and local authorities. Protective Action Recommendations issued in accordance with EP-IP-400 are mandatory for a General Emergency classification.

Time Completed:

NOTIFICATION OF THE NRC

Inform the NRC of the event classification using the ENS or a commercial telephone (Attachment 6 Step 4).

Time Completed: _

VERIFY ACCOUNTABILITY

If not previously done, Security should report within 30 minutes of declaration of a General Emergency that accountability is complete and provide the names of missing persons, if any. Log the time that accountability was completed.

Time Completed: ____

ACTION VERIFICATION

Ensure Security has evacuated and closed public access areas.

Time Completed: ____

RETURN TO THE PROCEDURE

(EITHER STEP 5.2[2] OR 5.3[2](a))

1.0 REACTOR FUEL

	GENERAL EMERGENCY	SITE AREA EMERGENCY	ALERT	UNUSUAL EVENT
1.1 Coolant Activity	1.1.1.4 Reactor coolant system sample activity which indicates a core melt condition as determined by EP-IP-330, "Core Damage."		1.1.1.2 Reactor coolant system sample activity > 200 microcuries/ml total iodine.	1.1.1.1 Reactor coolant system sample activity > 20 microcuries/ml total iodine.
1.2 Off-gas Activity			1.2.1.2 Air ejector off-gas radiation monitors 1705-3A and B Panel 910 reading > 20.000 mR/hr.	1.2.1.1 Air ejector off-gas radiation levels approaching Technical Specification release limits as indicated by Air Ejector Off-gas Radiation Monitors 1705-3A and B Panel 910 High-High alarm which does not clear within 13 minutes.
1.3 Thermal Limits				1.3.1.1 MCPR < Technical Specification fuel cladding integrity safety limit.
1.4 Radiation Monitors	1.4.1.4 Valid Drywell High Range Area Radiation Monitor reading > 3400 R/hr (RIT-1001-606A and B) or Valid Torus High Range Area Radiation Monitor reading > 100 R/hr (RIT-1001-607A and B) due to degraded reactor fuel integrity conditions.	1.4.1.3 Valid Drywell High Range Area Radiation Monitor reading > 650 R/hr (RIT-1001-606A and B) or Valid Torus High Range Area Radiation Monitor reading > 4 R/hr (RIT-1001-607A and B) due to degraded reactor fuel integrity conditions.	1.4.1.2 Refuel Floor Ventilation Exhaust Radiation (RFVE) Monitor 1705-8 Channel A(A/C) and Channel B(B/D) High trip Panel 910. <u>AND</u> Upscale alarm on two or more of the following Area Radiation Monitors Panel 911 which cannot be attributed to a controlled process: New fuel storage area (#11) Refueling floor spent fuel pool room (#12) Refuel floor reactor basin spent fuel area (#14)	

2.0 REACTOR PRESSURE VESSEL

2.1 Reactor Water Level	2.1.1.4 Sustained RPV water level < -165 inches. <u>AND</u> No sources of RPV injection available. 2.1.2.4 RPV is depressurized and no mechanism of adequate core cooling can be established by injection into the RPV from any source (Primary Containment Flooding is required)	2.1.1.3 RPV water level cannot be maintained above -125 inches (TAF). <u>AND</u> No sources (EOP 1 Table C Injection Subsystems) of adequate capacity are available to restore water level.	2.1.1.2 RPV water level cannot be determined (RPV Flooding is required).	2.1.1.1 RPV water level cannot be restored and maintained above +12 inches.
2.2 Reactor Pressure			2.2.1.2 Sustained reactor vessel dome pressure > 1325 psig.	2.2.1.1 Reactor vessel dome pressure cannot be maintained < 1115 psig (except during RPV hydrostatic testing).
2.3 Reactor Power	 2.3.1.4 Reactor power > 3% and torus temperature above the "Boron Injection Initiation Temperature" (BIIT) EOP Figure 4. <u>AND EITHER</u> An SRV is open. <u>OR</u> Drywell pressure > 2.2 psig. 	 2.3.1.3 Reactor power > 3% and boron injection into the RPV intentionally initiated (boron injection required) with either: Standby Liquid Control System (SBLC). <u>OR</u> One or more of the methods detailed in PNPS Procedure 5.3.20, "Alternate Borate Injection." 	2.3.1.2 A reactor Scram has been initiated. <u>AND</u> The reactor is not shutdown.	



3.0 PRIMARY CONTAINMENT

3.1 Drywell Temperature		3.1.1.3 Bulk drywell temperature cannot be restored and maintained < 280°F as determined by PNPS Procedure 2.1.27, "Drywell Temperature Indication."		3.1.1.1 Bulk drywell temperature cannot be maintained < 150°F as determined by PNPS Procedure 2.1.27, "Drywell Temperature Indication."
				AND Primary containment integrity is required.
3.2 Torus water Temperature		3.2.1.3 Torus water temperature cannot be maintained below the "Heat Capacity Temperature Limit" (HCTL) Figure 2.		3.2.1.1 Torus water temperature > 110°F.
3.3 Containment Water Level		 3.3.1.3 Torus water level cannot be maintained below 175 inches (SRV Tail Pipe Level Limit (STPLL)). 3.3.2.3 Torus water level cannot be maintained > 90 inches. 	3.3.1.2 Torus water level cannot be maintained < 180 inches.	3.3.1.1 Reactor coolant system to drywell unidentified leakage > 5 gpm with reactor coolant temperature > 212°F. OR Reactor coolant system to drywell total leakage > 25 gpm with reactor coolant temperature > 212°F. 3.3.2.1 Torus water level cannot be maintained: < < 132 inches. (-1 inches. narrow range).
3.4 Primary Containment Pressure	3.4.1.4 Torus bottom pressure approaching "The Primary Containment Pressure Limit" (PCPL) EOP Figure 4 (prior to initiation of containment venting).	3.4.1.3 Torus bottom pressure cannot be maintained below the "Pressure Suppression Pressure" (PSP) EOP Figure 6 (except during testing such as ILRT, etc.).	3.4.1.2 Primary containment pressure cannot be maintained < 2.2 psig (except during testing such as ILRT, etc.)	
3.5 Containment H ₂ & O ₂ Concentration	3.5.1.4 Drywell or torus hydrogen concentration ≥ 6%. AND Drywell or torus oxygen concentration ≥ 5% (Prior to initiation of containment venting). 3.5.2.4 Drywell or torus hydrogen concentration cannot be determined to be < 6%.	3.5.1.3 Drywell or torus hydrogen concentration > 1%. <u>AND</u> Drywell or torus oxygen concentration > 4%.	3.5.1.2 Drywell or torus hydrogen concentration > 1%.	

4.0 SECONDARY CONTAINMENT

4.1 Secondary Containment Area Water Levels	4.1.1.3 Secondary containment area water levels exceed the "Maximum Safe Operating Value" in two or more areas EOP Table L. <u>AND</u> A primary system is discharging into the area. <u>AND</u> Reactor coolant temperature > 212°F with irradiated fuel in the vessel.		4.1.1.1 Secondary containment area water levels exceed the "Maximum Safe Operating Value" in two or more areas EOP Table L. <u>AND</u> Reactor coolant temperature > 212°F with irradiated fuel in the vessel.
4.2 Secondary Containment Area Temperatures	4.2.1.3 Secondary containment area temperatures exceed the "Maximum Safe Operating Value" in two or more areas EOP Table L. AND A primary system is discharging into the area. AND Reactor coolant temperature > 212°F with irradiated fuel in the vessel		4.2.1.1 Secondary containment area temperatures exceed the "Maximum Safe Operating Value" in two or more areas EOP Table L. <u>AND</u> Reactor coolant temperature > 212°F with irradiated fuel in the vessel.
4.3 Secondary Containment Area Radiation Levels	4.3.1.3 Secondary containment radiation levels exceed the "Maximum Safe Operating Value" in two or more areas EOP Table L. <u>AND</u> A primary system is discharging into the area.	4.3.1.2 General area radiation levels measured in-plant which increase by a factor of 1000 times normal as a result of airborne radioactivity which cannot be attributed to a controlled process.	

.

5.0 RADIOACTIVITY RELEASE

•••				
5.1 Effluent Monitors	5.1.1.4 Valid Main Stack Process Radiation Monitor 1705-18 A and B Panel 910 reading > 2.4E5 cps.	5.1.1.3 Valid Main Stack Process Radiation Monitor 1705-18 A and B Panel 910 reading > 2.4E4 cps.	 5.1.1.2 Valid Reactor Building Ventilation Exhaust (RBVE) monitor 1705-32A and B Panel 910 high-high alarm which does not clear within 15 minutes from the time action is taken to isolate the source. 5.1.2. Valid Main Stack Process Radiation Monitor 1705-18A and B Panel 910 reading > 10,000 cps for greater than 15 minutes. 	 5.1.1.1 Valia Reactor Building Ventilation Exhaust (RBVE) monitor 1705-32A and B Panel 910 high alarm which does not clear within 15 minutes from the time action is taken to isolate the source. 5.1.2.1 Main stack radioactivity effluents in excess of the high-high alarm setpoint for greater than 15 minutes as indicated by the Main Stack Process Radiation Monitors 1705-18A and B Panel 910. 5.1.3.1 Radwaste Effluent Radiation Monitor (1705-30) high alarm Panel 910. AND Parchardt displayments and isolated (EV 7214 A and B)
5.2 Dose Projection & Environmental Measurements	 5.2.1.4 Dose projection based on effluent monitors or actual environmental measurements which indicate doses in excess of 1000 mrem whole body or 5000 mrem thyroid at the site boundary or beyond. 5.2.2.4 Dose projection based on effluent monitors or actual environmental measurements which indicate dose rates in excess of 1000 mrem/hr whole body or 5000 mrem/hr thyroid at the site boundary or beyond. 	5.2.1.3 Dose projection based on effluent monitors or actual environmental measurements which indicate doses in excess of 100 mrem whole body or 500 mrem thyroid at the site boundary or beyond.		
5.3 Contaminated Injury				5.3.1.1 Transportation of a contaminated injured person to an offsite medical facility.

EP-IP-100 Rev. 17 Page 29 of 47

ATTACHMENT 5 Sheet 4 of 5

.

6.0 INTERNAL EVENTS

Г	GENERAL EMERGENCY	SITE AREA EMERGENCY	ALERT	UNUSUAL EVENT
6.1 Technical Specifications	······			6.1.1.1 The plant is not brought to the required operating mode within Technical Specifications LCO Action Statement time.
6.2 Safety Systems		 6.2.1.3 Evacuation of Control Room without establishment of plant control from remote shutdown stations within 15 minutes. 6.2.2.3 Steam line break outside primary containment without isolation. <u>AND</u> Reactor coolant temperature > 212°F. 6.2.3 Inability to immediately isolate any Main Steam Line following a valid PCIS signal (Group I). <u>AND</u> Bactor coolant temperature > 212°F. 	 6.2.1.2 Loss of Control Room habitability (e.g., fire, smoke, radiological hazards, etc.). 6.2.2.2 Inability to establish and maintain cold shutdown conditions as indicated by: Reactor Mode Switch in "Shutdown." AND Reactor coolant temperature cannot be maintained ≤ 212°F. 	 6.2.1.1 Failure of a reactor Safety Relief Valve (RV-203-3A thru D) to close following reduction of applicable pressure as indicated by either: Accoustic monitor ZI-203 Panel C171. OR SRV tailpipe temperature recorder TR-260-20 Panel 921. AND Reactor coolant temperature > 212°F with irradiated fuel in the vessel.
6.3 Electrical System Failures		 6.3.1.3 Sustained loss of all AC power capability as indicated by the inability to power any 4kV bus (A1 thru A6) from any source (all 4kV buses de-energized). 6.3.2.3 Sustained loss of all 125 VDC power capability as indicated by: Voltage < 105 VDC Panel D-16. <u>AND</u> Voltage < 105 VDC Panel D-17. 	6.3.1.2 Loss of all AC power capability as indicated by the inability to power any 4kV bus (A1 thru A6) from any source (all 4kV buses de-energized). 6.3.2.2 Loss of all 125 VDC power capability as indicated by: Voltage < 105 VCD Panel D-16. <u>AND</u> Voltage < 105 VDC Panel D-17.	 6.3.1.1 Loss of all vital onsite AC power capability as indicated by: Inability to power Bus A5 from any onsite generator*. AND Inability to power Bus A6 from any onsite generator*. Onsite generators are: Main Generator via Unit Auxiliary Transformer Emergency Diesel Generator A Emergency Diesel Generator B Station Blackout Diesel Generator 6.3.2.1 Loss of all vital offsite AC power capability as indicated by: Inability to immediately supply AC power to Bus A5 from any offsite power supply transformer*. AND Inability to to immediately supply AC power to Bus A6 from any offsite power supply transformer*. Coffsite power supply transformers. Startup Transformer (X1) Main Transformer (X13) Main Transformer (X13)
6.4 Loss of Indication, Alarm, or Comm Capability			6.4.1.2 Complete loss of plant process computer alarm and indications. <u>AND</u> Loss of most or all Control Room annunciators. <u>AND</u> Reactor coolant temperature is > 212°F.	 6.4.1.1 Loss of indications and/or alarms which cause a significant loss of assessment capabilities such as: Loss of indication or annunciation on safety-related equipment to an extent requiring shutdown by Technical Specifications. AND Reactor coolant temperature is > 212"F. 6.4.2.1 Loss of all ability to communicate with or adequately activate the Emergency Response Organization as indicated by the complete loss of the onsite telephone systems.

ATTACHMENT 5 Sheet 5 of 5

7.0 EXTERNAL EVENTS

	7444		17440	17444
7.1 Security Threats	An ongoing security compromise which in the judgment of the Shift Manager has led to the loss of physical control of the plant	An ongoing security compromise which in the judgment of the Shift Manager may lead to the loss of physical control of the plant.	Any ongoing security compromise (> 10 minutes) as determined by the Station Security Force.	Any attempted unauthorized entry into the Protected Area as determined by the Station Security Force.
				7.1.2.1 Any indication of attempted sabotage.
				7.1.3.1 Receipt of a credible bomb threat as determined by the Station Security Force.
7.2 Fire		7.2.1.3	7.2.1.2	7.2.1.1
	Table 7-1 Safety Systems	Any fire which has affected the ability of two or more safety systems (Table 7-1) to perform their intended function and poses a significant potential for release of	Fire burning out of control in a plant vital area.	Fire within the Protected Area lasting > 10 minutes from the time firefighting efforts begin (Fire Brigade fire fighting efforts have begun when the Fire Brigade first applies fire
	Residual Heat Removal	radioactivity. <u>AND</u> Reactor coolant temperature > 212°F.		Ignting agents on the tire.). <u>OR</u> Any fire onsite for which offsite fire fighting assistance is requested (the countried estimation of the Divergeth Fire
	Core Spray			Department for any onsite fire does not constitute a request for offsite fire fighting assistance.).
7.3 Man-made Events	Emergency Diesel Generators	7.3.1.3 Any of the following which has affected the ability of two	7.3.1.2 Any of the following events occurring which affect plant	7.3.1.1 Any of the following events occurring onsite:
	High Pressure Coolant Injection	or more safety systems (Table 7-1) to perform their intended function and poses a significant potential for	 operation: Aircraft crash on facility. Missile impact from any source on facility. Entry of toxic or flammable gas into a plant process building atmosphere (includes significant Main Generator hydrogen leaks). 	Aircraft crash. Explosion (unplanned).
	Automatic Depressurization System	release of radioactivity: Aircraft crash on facility. Micraft crash for activity.		Toxic or flammable gas release.
	Reactor Protection System	Missile impact from any source on facility. Entry of toxic or flammable gas into a plant process building atmosphere.		
	ATWS/ARI	Explosion (Unplanned). AND		
7.4 Natural Events	Primary Containment Isolation	Reactor coolant temperature > 212°F. 7.4.1.3 Any of the following which has affected the ability of two	7.4.1.2 Any of the following which causes damage to permanent	7.4.1.1 Sustained winds (> 5 minutes) in excess of 75 mph as
	Standby Gas Treatment	or more safety systems (rable 7-1) to perform their intended function and poses a significant potential for release of radioactivity:	plant structures or equipment which affect plant operation: • Earthquake • Torpado	7.4.2.1
	Standby Liquid Control	 Earthquake Tornado 	Hurricane Other Natural Phenomena	Report of a tornado onsite.
	Reactor Building Closed Cooling	Hurricane Other Natural Phenomena	7.4.2.2	Any earthquake detected by seismic instrumentation as
	Water	AND Reactor coolant temperature is > 212°F.	Any earthquake onsite which has been determined to be greater than Operating Basis Earthquake levels (0.08 g).	indicated by: Seismic monitor event alarm Panel C911.
	Service Water	7.4.2.3 Any earthquake onsite which has been determined to be greater than Safe Shutdown Earthquake levels (0.15 o)		UK • "SEISMIC RECORDER OPERATING" annunciator Panel C903 Right B1. AND
			·	Ground motion is felt by one or more plant operations personnel.

8.0 OTHER

8.1 Other	8.1.1.4 In the opinion of the Shift Manager or Emergency Director events are in progress which indicate actual or imminent core damage and the potential for a large release of radioactive material outside the site boundary.	8.1.1.3 In the opinion of the Shift Manager or Emergency Director events are in progress which indicate actual or likely failures of plant systems needed to protect the public and pose a significant radioactivity release potential.	8.1.1.2 Any event which in the opinion of the Shift Manager or Emergency Director could or has caused actual substantial degradation of the level of plant safety.	 8.1.1.1 Any event which in the opinion of the Shift Manager or Emergency Director could or has led to a potential degradation of the level of safety of the plant. 8.1.2.1 Any event which in the opinion of the Shift Manager or Emergency Director warrants the prompt notification of Commonwealth and local authorities and precautionary notification of Emergency Response Organization personnel.
-----------	---	---	---	---

EP-IP-100 Rev. 17 Page 31 of 47

	GRIM NUCLE	AR POWER NOT		TION F	ORM				No.
1	THIS IS:			A DR	ILL			AN ACTUAL	EVENT
2	AS OF:			PILGRIM	NUCLEAF	R POW	/ER STA	TION HAS:	
	ENTE HAD THEN UPGI DOW	time RED: A TRAN N ENTER RADED 1 NGRAD	date SITORY _ ED: FO: ED TO:				AN UI AN AI A SIT A GEI RECC	NUSUAL EV _ERT E AREA EMI NERAL EME DVERY	ENT ERGENCY RGENCY
3	EAL No.					BR			F EVENT:
					·····				
4	EMERGE	ENCY RA		VE RELEA	SE:				
	lıs			отт				IN	PROGRESS
		ABOVE				·····	PROTE	CTIVE ACTI	PROGRESS
5		ABOVE ROLOGIO	IS NO	DT ELOW A AS OF M°	: : TO	° A	PROTE	CTIVE ACTI	PROGRESS ON GUIDES
5 6	IS METEOF WIND PNPS'S I NO NERAL E PR	ABOVE ROLOGIO DIRECTI PROTEC PROTEC MERGE OVIDED	IS NO IS BI CAL DATA ON FROM TIVE ACT CTIVE ACT CTIVE ACT NGY AND TO MEM	DT ELOW A AS OF M° TION RECO TIONS NEG MEMA/ME A/MDPH	TO DMMENDA CESSARY DEL ARE	^ A TION: PRESI	PROTE T S (PARs) ENT IN T	IN CTIVE ACTION mph : HE EOF:	PROGRESS ON GUIDES
5 GE		ABOVE ROLOGIO DIRECTI PROTEC PROTEC MERGE OVIDED MERGE ELTER S	IS NO	DT ELOW A AS OF A AS OF M	TO TO DMMENDA CESSARY PH ARE 3 4 5 6 3 4 5 6	<u>°</u> A TION PRESI NOT P	PROTE T S (PARs) ENT IN T RESENT 10 11 10 11	IN CTIVE ACTION mph : HE EOF: IN THE EO	PROGRESS ON GUIDES
5 6 GE 7		ABOVE ROLOGIO PROTEC PROTEC MERCE OVIDED MERCE ELTER S ACUATE	IS NO	DT ELOW A AS OF M	TO TO DMMENDA CESSARY DPH ARE 3 4 5 6 3 4 5 6 3 4 5 6	° A \TION PRESI NOT F 7 8 9 7 8 9 BY [PROTE T S (PARs) ENT IN T RESENT 10 11 10 11	IN CTIVE ACTION mph : HE EOF: IN THE EO 12 (circle the affect	PROGRESS ON GUIDES
5 6 GE 7 8		ABOVE ROLOGIO DIRECTI PROTEC PROTEC MERGE OVIDED MERGE ELTER S ACUATE	IS NO	DT ELOW A AS OF M	 TO DMMENDA CESSARY DPH ARE 3 4 5 6 3 4 5 6 3 4 5 6 3 4 5 6	<u>° A</u> TION PRESI 7 8 9 7 8 9 7 8 9 8 9 8 9	PROTE T S (PARs) ENT IN T RESENT 10 11 10 11	IN CTIVE ACTION mph : IE EOF: IN THE EO 12 (circle the affect name	PROGRESS ON GUIDES

	A	TTACHMENT 6 Sheet 2 of 3
	INITIAL NOTIFICATION FORM (Cont.)	o
	<u>NOTE</u> DO NOT TRANSMIT THIS SHEET OVER DNN	
9	APPLICABLE ONLY IN A GENERAL EMERGENCY PILGRIM STATION'S PROTECTIVE ACTION RECOMMENDATIONS MEMA/MDPH REPRESENTATIVES IN THE EMERGENCY OPERATIO (circle the affected subareas):	GIVEN TO ONS FACILITY
	SHELTER SUBAREA(s) 1 2 3 4 5 6 7 8 9 10 11	
	EVACUATE SUBAREA(s) 1 2 3 4 5 6 7 8 9 10 11 12	
10	EMERGENCY DIRECTOR REVIEW AND APPROVAL:	
	THE EMERGENCY DIRECTOR SHALL REVIEW AND SIGN THESE INDICATING VERIFICATION OF AND APPROVAL FOR INFORMATI AND PROTECTIVE ACTION RECOMMENDATION (if given).	FORMS ON RELEASE

APPROVED FOR RELEASE:

Emergency Director's Signature

INITIAL NOTIFICATION FORM TRANSMISSION INSTRUCTIONS

NO: _____

ATTACHMENT 6 Sheet 3 of 3

(Check off the boxes as steps are completed.)

Step 1: TRANSMIT THE FORM

Verify Blocks 1 - 6 are complete, release is approved by signature, and then fill out Block 7 of the form. <i>For guidance on individual Block descriptions, refer to EP-IP-100.</i>				
Place only the first page of the completed form face down in the DNN fax machine.				
Follow the posted instructions at the Step 2: CONTACT THE COMMONW If notification is made on anything other BECONS), request a verification callba	e DNN fax machine. EALTH AND LOCAL er than dedicated con ack.	Proceed immediately to Step 2. <u>OFFICIALS</u> nmunication links (DNN or		
Pick up the DNN ring-down phone "Attention, attention. Please sta	and read the followin ndby for a roll call.	ng message twice: "		
Perform a roll call and check off the	e responding location	ns as they are identified.		
Middleboro State Police	Carver	Marshfield		
Framingham MEMA	Duxbury	Plymouth		
Bridgewater	Kingston	Taunton		
"This is the Pilgrim Nuclear Pow being transmitted. Obtain the tra obtain a blank form and standby Step 3: TRANSMIT THE DATA	er Station. An Initia ansmitted form from for initial notification	al Notification Form is n your telecopy machine or on data."		
Read the information in Block 1 thr	ough Block 6.			
Tell those parties who have comple information to remaining parties.	ete information to har	ng up, then provide missing		
Contact locations not answering ro (speed-dialer) and read the informa Step 4: NOTIFY THE NRC	ll call via BECONS o ation in Block 1 throu	r commercial telephone gh Block 6.		
Using the ENS or commercial phor	ne, read the informati	ion in Blocks 1 through 6.		
Name of Contact:		Time:		
Step 5: ORGANIZE THE REPORT				
Obtain the printed report from the l	DNN fax machine and	d staple it to this form.		
Inform the Emergency Director tha	t transmission was co	ompleted at time:		
COMPLETED BY:		Time		
Signature of person r		······		

EP-IP-100 Rev. 17 Page 34 of 47

ATTACHMENT	7
Sheet 1 of 3	

PIL	GRIM NUCLEAR POWER STA						
		NFORMAT	ION FC	JRIN			NO.
	THIS IS:					ACTUAL E	/ENT
2	AS OF:	PILGRIM	NUCLEAR	POWE	R STATIO	N IS STILL /	AT A:
	time c	late					
			SITE AREA E	MERG	ENCY		MERGENCY
	STATION CONDITIC	DNS ARE:	MPROVING		STABLE		
4	EAL No	<u></u>		BRIE	F DESCRI	PTION OF E	EVENI
		·····					·····
	<u> </u>					,	
				·· ··		<u></u>	<u> </u>
5	T		T	.			
Ť					NOT		UESTED
		<u>.</u>	REAS	<u>ON FOI</u>	R OUTSID	<u>E ASSISTAI</u>	<u>NCE:</u>
		MENT				<u>,</u>	
Į							<u></u>
		NACTIVE PELEA	SE:				
₽ [−]						IN PR	OGRESS
<u> </u>		IS BELOW		F	PROTECTI	VE ACTION	GUIDES
+		_ DATA AS OF	:				
	STABILITY CLASS		RECTION FR		° TO	° AT	mph
8				HONS	(PARs):		
GI		AND MEMAMD	PH ARE PI	RESEN	T IN THE	30 6:	
		MEMA/MDPH	n an				n magen de l'opportono print i reventinte a la rida (perovin
G	ENERAL EMERGENCI	(AND MEMAVMB	PH ARE N	<u>OT PRI</u>	ESENT IN	THE EOF:	
:		AREA(s) 1 2 3	34567	8 9 1	D 11		
	EVACUATE SU	BAREA(s) 1 2 3	34567	8910	0 11 12 (c	ircle the affected su	ubareas)
9	NOTIFICATION INI			BY [
		time	date			name	
+10	NOTIFICATION RE			BY [
٩		time	date			name	

	ATTACHMENT 7 Sheet 2 of 3
	FOLLOW-UP INFORMATION FORM (Cont.) No.
	<u>NOTE</u> DO NOT TRANSMIT THIS SHEET OVER DNN
11	APPLICABLE ONLY IN A GENERAL EMERGENCY PILGRIM STATION'S PROTECTIVE ACTION RECOMMENDATION GIVEN TO MEMA/MDPH REPRESENTATIVES IN THE EMERGENCY OPERATIONS FACILITY (circle the affected subareas):
	SHELTER SUBAREA(s) 1 2 3 4 5 6 7 8 9 10 11
	EVACUATE SUBAREA(s) 1 2 3 4 5 6 7 8 9 10 11 12
	SINCE PREVIOUS NOTIFICATION, THIS RECOMMENDATION HAS:
	THIS RECOMMENDATION IS BASED ON:
12	EMERGENCY DIRECTOR REVIEW AND APPROVAL:
	THE EMERGENCY DIRECTOR SHALL REVIEW AND SIGN THIS FORM INDICATING VERIFICATION OF AND APPROVAL FOR INFORMATION RELEASE AND PROTECTIVE ACTION RECOMMENDATION (if given).
	APPROVED FOR RELEASE:

Emergency Director's Signature

	ATTACHMENT 7 Sheet 3 of 3
FOLLOW-UP INFORMATION FORM TRANSMISSION INSTRUCTIONS	No:
(Check off the boxes as steps are completed.)	
Step 1: TRANSMIT THE FORM	
Verify Blocks 1 - 8 are complete, release is approved by signature, an Block 9 of the form. For guidance on individual Block descriptions, refer to EP-I	d then fill out P-100.
Place only the first page of the completed form face down in the DNN	fax machine.
Follow the posted instructions at the DNN fax machine. Proceed immediately in the posted instruction of the posted immediately in the posted instruction of the posted instruc	iately to Step 2.
Step 2: CONTACT THE COMMONWEALTH AND LOCAL OFFICIALS If notification is made on anything other than dedicated communication lin BECONS), request a verification callback.	iks (DNN or
Pick up the DNN ring-down phone and read the following message two "Attention, attention. Please standby for a roll call."	ice:
Perform a roll call and check off the responding locations as they are i	dentified.
Middleboro State Police Carver M	larshfield
□ Framingham MEMA · □ Duxbury □ P	lymouth
Bridgewater Kingston D Ta	aunton
Read the following message twice: "This is the Pilgrim Nuclear Power Station. A Follow-Up Information being transmitted. Obtain the transmitted form from your telecopy r obtain a blank form and standby for follow-up information data."	Form is nachine or
Step 3: TRANSMIT THE DATA	
Read the information in Block 1 through Block 8.	
Tell those parties who have complete information to hang up, then pro- information to remaining parties.	ovide missing
Contact locations not answering roll call via BECONS or commercial to (speed-dialer) and read the information in Block 1 through Block 8. <u>Step 4: NOTIFY THE NRC</u>	elephone
Using the ENS or commercial phone, read the information in Blocks 1	through 8.
Name of Contact: Time	:
Step 5: ORGANIZE THE REPORT	
Obtain the printed report from the DNN fax machine and staple it to th	is form.
Inform the Emergency Director that transmission was completed at tim	ne:
COMPLETED BY: Time);
Signature of person making potifications	

Signature of person making notifications

EP-IP-100 Rev. 17 Page 37 of 47

		ATT/ Sł	ACHMENT 8 neet 1 of 2
	TERMINATION C	НЕСК	LIST
1.	Conditions no longer meet an Emergency Action Level and it appears unlikely that conditions will deteriorate. List any EAL(s) which is/are still exceeded and a justification as to of emergency is no longer applicable:	True why a s	False
	EAL Justification		
	·		
			۰ ۱۰۰۰
2.	Plant releases of radioactive materials to the environment are under control (within Technical Specifications) or have ceased and the potential for an uncontrolled radioactive release is acceptably low.		
3.	The radioactive plume has dissipated and plume tracking is no longer required. The only environmental assessment activities in progress are those necessary to determine the extent of deposition resulting from passage of the plume.		
4.	In-plant radiation levels are stable or decreasing, and acceptable given the plant conditions.		
5.	The reactor is in a stable shutdown condition and long-term core cooling is available.		
6.	The integrity of the Reactor Containment Building is within Technical Specifications limits.		
7.	The operability and integrity of radioactive waste systems, decontamination facilities, power supplies, electrical equipment, and plant instrumentation including radiation monitoring equipment are acceptable.		
8.	Any fire, flood, earthquake, or similar emergency condition or threat to security no longer exists.		
9.	Any contaminated, injured person has been treated and/or transported to a medical care facility.		

EP-IP-100 Rev. 17 Page 38 of 47

False

True

TERMINATION CHECKLIST (CONTINUED)

- 10. All notifications required by the event procedures have been made.
- 11. Offsite conditions do not unreasonably limit access of outside support to the Station and qualified personnel and support services are available.
- 12. Discussions have been held with Federal, Commonwealth, and local agencies and agreement has been reached and coordination established to terminate the emergency.

It is not necessary that all responses listed above be "TRUE"; however, all items must be considered prior to event termination and entry into Recovery. For example, it is possible that some conditions remain which exceed an Emergency Action Level following a severe accident but entry into Recovery is appropriate. Additionally, other significant items not included on this list may warrant consideration such as severe weather.

Comments:

Approved:

Emergency Director

Date/Time: _____

EP-IP-100 Rev. 17 Page 39 of 47

ATTACHMENT 9 Sheet 1 of 2

ESSENTIAL INFORMATION CHECKLIST					
☐ Initial Message ☐ Update	4) Radiological Conditions				
Date: Time: am/pm Person Providing Information: Name: Location: Phone:	Emergency Radioactive Release Status: None Imminent In Progress Controlled Uncontrolled Below PAGs Above PAGs Projected Release Duration: hr(s)				
1) Classification or Status Time Declared: am/pm □ Off-Normal Event am/pm □ Unusual Event am/pm □ Alert Alert □ Site Area Emergency General Emergency □ Recovery 2) Brief Summary of Event and Mitigating Actions in Progress	Offsite Protective Actions: None Issued Provided to Commonwealth Onsite Protective Actions: None Potassium Iodide Evacuation of Nonessential Personnel Other: 5) Site Personnel Injuries: How Many No No Yes Contamination: No Minor Major Nature of injuries or contamination:				
3) Plant Conditions On-Line Off-Line Stable Unstable At Power Cooling Down Cold Shutdown Time of Reactor Shutdown: am/pm Improving Same Deteriorating Describe equipment, instrument, or other problems:	6) Offsite Agency Notification NRC Time:am/pm MEMA Time:am/pm MDPH Time:am/pm Local (last town) Time:am/pm 7) Offsite Assistance Requested am/pm None Fire Department Police Ambulance Other: Ambulance 8) News Media Notification None Press Conference 9) Signature and Title				

ATTACHMENT 9 Sheet 2 of 2



EP-IP-100 Rev. 17 Page 41 of 47

ACTIVATION OF THE EMERGENCY RESPONSE ORGANIZATION

I. Emergency Response Organization Notification Using CANS

<u>NOTE</u>

If at any time CANS cannot be contacted or does not respond as indicated, go to Section II (Notification Using Group Pages if CANS Fails) in this Attachment.

If the individual activating CANS is not the Shift Manager, Control Room Supervisor, Shift Control Room Engineer, or the Operations Assistant, it is necessary for the individual to obtain a security code (Social Security number) from one of these individuals.

- [1] Ascertain the current emergency classification from the Emergency Director.
- [2] Obtain the phone number for CANS from the Immediate Notification section of the PNPS Emergency Telephone Directory.
- [3] Attempt to contact CANS using any touch-tone phone line.
- [4] Listen for the introductory message and enter your security code (Social Security number) upon request followed by the # sign.

NOTE

For activation of the ERO for drills and exercise, precede the following classification codes with DRILL (37455 on telephone keypad). For example, for a drill classification of Alert, enter DRILL 2222 (374552222) as the emergency classification code.

- [5] Listen for verbal prompt and enter the proper code for present emergency classification. The codes are:
 - 1111 Unusual Event
 - 2222 Alert
 - 3333 Site Area Emergency
 - 4444 General Emergency
 - 0000 Termination of classifiable event/Recovery

[6] If you are NOT satisfied with the emergency classification, press the # sign to re-enter classification.

<u>OR</u>

If you are satisfied, hang up the phone to start the notification process.

[7] Verify CANS operability by checking the emergency pager located in the locker in the Shift Manager's office. Ensure that the pager is activated and indicates the proper emergency classification. Allow approximately 5 minutes for CANS to activate the pager.

<u>NOTE</u>

If communication is established with the EOF prior to initiation of Step [8], Step [8] may be omitted.

- [8] If the Emergency Operations Facility has not contacted the Control Room after approximately 35 to 40 minutes from the time the Control Room pager has activated, check on-call personnel response in the following manner:
 - (a) Obtain the CANS phone number from the Immediate Notification section of the PNPS Emergency Telephone Directory.
 - (b) Contact CANS using any available touch-tone phone. If no contact is made, pause and try again.
 - (c) Listen for the introductory message and enter your security code (Social Security number) when requested followed by the # sign.
 - (d) When prompted, enter '3' for the status of the classification scenario.
 - (e) Retrieve the CANS report from the DNN facsimile machine and review the list for unfilled positions.
 - (f) Repeat Steps (a) through (e) above as often as necessary to keep apprised of the notification process.

II. Notification Using Group Pages if CANS Fails

<u>NOTE</u>

If contact with the paging system cannot be made or the paging system does not respond as indicated, go to Section III (Notification Using Telephones if Both CANS and the Paging System Fail) of this Attachment.

- [1] Obtain the ERO pager PIN and the access telephone number from the Immediate Notification section of the PNPS Emergency Telephone Directory.
- [2] Contact the paging system by dialing the access telephone number.
- [3] Upon contact, listen for the verbal prompt to enter the PIN number. When prompted, enter the ERO pager PIN followed by the # sign. If the verbal prompt is not heard, repeat Step [2].
- [4] Listen for the verbal prompt to enter display message. When prompted, enter the proper code for present emergency classification. The codes are:
 - 1111 Unusual Event
 - 2222 Alert
 - 3333 Site Area Emergency
 - 4444 General Emergency
 - 0000 Termination of classifiable event/Recovery
- [5] Press the # sign to complete the entry.

III. Notification Using Telephones if Both CANS and the Paging System Fail

- [1] Request the Emergency Director to inform Security at the Primary Access Control Point to notify the Emergency Response Organization using the PNPS Emergency Telephone Directory and commercial telephone lines in accordance with EP-IP-240.
- [2] Call out one individual for each of the following emergency positions using the PNPS Emergency Telephone Directory. When contact is made, ask if any alcoholic beverage has been consumed within the last 5 hours. If the individual answers <u>YES</u>, inform them that an alternate shall be contacted. If the individual answers <u>NO</u>, inform them of the event and that CANS and the pager system have failed. Record the name and response time below.

Emergency Director (EOF)	
Name	Response Time (min.)
Emergency Plant Manager (TSC/OSC)	
Name	Response Time (min.)
Emergency Offsite Manager (EOF)	
Name	Response Time (min.)

DOCUMENT CROSS-REFERENCES

This Attachment lists those documents, other than source documents, which may be affected by changes to this Procedure.

Document Number	Document Title		
EP-IP-400	Protective Action Recommendations		
EP-IP-520	Transition and Recovery		
EP-AD-600*	PNPS EAL Technical Bases Document		
PNPS 2.1.27	Drywell Temperature Indication		
PNPS 5.3.20	Alternate Borate Injection		
	EAL Wall Chart		

* Any revision to Attachment 5 of EP-IP-100 shall require a corresponding revision to EP-AD-600.

EP-IP-100 Rev. 17 Page 46 of 47

ATTACHMENT 12 Sheet 1 of 1

IDENTIFICATION OF COMMITMENTS

This Attachment lists those external commitments (i.e., NRC commitments, QAA audit findings, and INPO inspection items) implemented in this Procedure.

Reference Document	Commitment	Affected		
		Section(s)/Step(s)		
NRC Inspection Finding 81-15-34	Develop and implement a system for use by the Control Room staff to aid in promptly classifying events.	Att. 5, EAL Chart		
NRC Inspection Finding 81-15-35	Provide EALs which include specific and observable Control Room instrument readings for each EAL corresponding to the respective initiating condition.	Att. 5		
NRC Inspection Finding 81-15-35, 84-41-02, 86-33-01	Provide EALs which address and conform to all pertinent initiating conditions contained in Appendix 1 of NUREG-0654.	Att. 5		
NRC Inspecting Finding 81-15-36	Revise the offsite notification procedures to specify protective action recommendations in the notification messages.	Att. 6		
NRC Inspecting Finding 81-15-41	Revise the communication procedures to ensure (verify) correct transmission.	Att. 6 & 7		
NRC Inspection Finding 84-05-04	Provide EALs based on field monitoring results and on the methods used if the effluent and containment monitors are inoperable or off-scale.	Att. 5 (Category 5.2)		
NRC Inspection Finding 84-41-01	Revise the EAL on hurricane wind speed to reflect the National Weather Service definition for hurricanes.	Att. 5 (EAL 7.4.1.1)		
NRC Inspecting Finding 84-41-06	Review the offsite notification procedure and make appropriate changes to provide a high probability of completing offsite notification.	Att 6 & 7		
QAA Audit Report 87-48 DR 1723, Issue 1	Include in the EALs all initiating conditions in Appendix 1 of NUREG-0654.	Att. 5		
QAA Audit Report 87-48 DR 1723, Item 4	Ensure public access areas are closed at an Alert or above.	Att. 2, 3, 4		
NRC Inspection Report 50-293/88-28 Item 2.4 and 7.4.2.3	Provide further clarification and quantification for earthquake EALs.	Att. 5 (EAL 7.4.2.2)		
	Modifications to transmitted portions of Initial Notification and Follow-Up Information Form shall be reviewed with the Commonwealth.			

PILGRIM NUCLEAR POWER STATION

Procedure No. EP-IP-225

SEVERE ACCIDENT MANAGEMENT SUPPORT



SAFETY RELATED

EP-IP-225 Rev. 0

REVISION LOG

REVISION 0

Date Originated 10/01

Description

Pages Affected

All

New Procedure that describes key functional responsibilities for assessing plant conditions following entry into Emergency Operations Procedures (EOPs) and provides instructions to ensure a timely transition from EOPs into Severe Accident Guidelines (SAGs) when needed.

> EP-IP-225 Rev. 0 Page 2 of 12

TABLE OF CONTENTS

<u>Page</u>

4
4
5
5
6
7
9
9
10
1 1
12
-

1.0 PURPOSE AND SCOPE

This Procedure provides instructions to the Emergency Plant Operations Supervisor, the TSC Supervisor, the Engineering Coordinator/Operations, and the TSC Staff Engineers for assessing plant conditions following entry into Emergency Operations Procedures (EOPs) or possible entry into Severe Accident Guidelines (SAGs). If entry into SAGs becomes necessary, the Procedure will also provide for a timely transition from the EOPs into the SAGs.

2.0 <u>REFERENCES</u>

- [1] BWR Owners Group Accident Management Guidelines Overview Document, Revision 0, May 1996
- [2] BWR Owners Group Emergency Procedure and Severe Accident Guidelines, Revision 2, March 2001
- [3] Emergency Response Organization Evaluation & Plant Specific Technical Support Guideline Recommendations, prepared by AMIT, May 28, 1996
- [4] EP-PP-01, PNPS Emergency Plan
- [5] EPRI Severe Accident Management Guidance Technical Basis Report, Vol. 1 and 2, EPRI TR-101869, Final Report, 12/92
- [6] PNPS Plant Specific Technical Guidelines and Severe Accident Technical Guidelines
- [7] PNPS Severe Accident Guidelines, SAG-01 and SAG-02
- [8] Procedures
 - (a) EP-SAG-100, "Severe Accident Management Organization Guidelines"

3.0 **DEFINITIONS**

- [1] <u>Emergency Operating Procedure (EOP)</u> Plant procedure flow chart (symptomatic in nature) that provides comprehensive directions and instructions used by the plant staff to mitigate or prevent off-normal plant transients from progressing to severe accident conditions.
- [2] <u>Severe Accident Guideline (SAG)</u> Plant guideline that is used by the plant staff during a severe accident to assist in determining necessary mitigating actions to be taken. They consist of:
 - SAG-01, "RPV and Primary Containment Flooding"
 - SAG-02, "Containment and Radioactivity Release Control"
- [3] <u>Technical Support Guidelines (TSGs)</u> Plant guidelines to assist the ERO staff in decision-making process related to EOP and SAG implementation to prevent or mitigate off-normal events and to mitigate events that degrade to severe accident status. They contain listings of plant parameter information that can be used to obtain the status of current plant conditions, system and equipment availability, and plant critical control parameters. Three assessment aids comprise the TSGs, which consist of the following:
 - Plant Condition Assessment (PCA)
 - Function Status Assessment (FSA)
 - Control Parameter Assessment (CPA)

4.0 DISCUSSION

None

5.0 **RESPONSIBILITIES**

- [1] The Emergency Plant Operations Supervisor (EPOS) is responsible for:
 - (a) Implementing this Procedure for the Control Room staff.
 - (b) Assisting Control Room operating staff with actions to support EOP implementation and accident mitigation strategies.
 - (c) Assessing current plant status and conditions in relation to accident mitigation strategies and providing status update to the Emergency Plant Manager and the Emergency Director regarding necessary mitigating actions.
 - (d) Making the decision to enter into Severe Accident Guidelines.
 - [2] The TSC Supervisor is responsible for:
 - (a) Implementing this Procedure for the TSC staff.
 - (b) Overseeing technical assessment in the TSC to support the Control Room operating staff with accident mitigation strategies as needed.
 - (c) Assessing current plant status and conditions and providing recommendations to the Emergency Plant Manager and the EPOS regarding recommended mitigating actions.
 - [3] The Engineering Coordinator/Operations is responsible for:
 - (a) Assigning appropriate TSC Engineering staff (Operations, Systems, and ES/TAG) to initiate Technical Support Guidelines (Plant Condition Assessment, Control Parameter Assessment, and Function Status Assessment) in support of EOP accident mitigation strategies and actions.
 - (b) Providing plant operational technical assessment to support EOP accident mitigation strategies as needed.
 - [4] Designated TSC Engineering staff (Operations, Systems, and ES/TAG) is responsible for:
 - (a) Initiating Technical Support Guidelines (Plant Condition Assessment, Control Parameter Assessment, and Function Status Assessment) in support of EOP accident mitigation strategies and actions.
 - (b) Making recommendations for necessary action to be taken to mitigate or prevent off-normal events from degrading to severe accident status.

6.0 PROCEDURE

[1] The EPOS shall:

- (a) Upon entry into EOPs <u>OR</u> upon recommendation of the TSC Supervisor, (whichever comes first), implement this Procedure in the Control Room.
- (b) Assist Control Room staff with assessing current plant status conditions to support recommended accident mitigating actions (EOP and EOP Satellite Procedure implementation).
- (c) If TSC is activated, ensure TSC staff is assessing and monitoring plant status conditions using appropriate EOPs and TSGs.
- (d) Coordinate necessary accident mitigating actions with the Control Room, the TSC, and the EOF in support of EOP implementation.
- (e) Monitor overall plant status conditions to determine when entry into the Severe Accident Guidelines is necessary using the guidance contained in Attachment 1 (EOP-to-SAG Transfer Checklist).
- (f) If it is determined that accident conditions warrant implementation of Severe Accident Guidelines, then inform the TSC, EOF, and Control Room staffs of the decision to exit this Procedure and implement functional responsibilities in accordance with EP-SAG-100, "Severe Accident Management Organization Guidelines".
- [2] The TSC Supervisor shall:
 - (a) Based on recommendations from the Engineering Coordinators (Operations/Systems) <u>OR</u> upon entry into EOPs (whichever comes first), implement this Procedure in the TSC.
 - (b) Recommend the implementation of this Procedure in the Control Room to the EPOS.
 - (c) Notify the EPOS when this Procedure has been implemented in the TSC.
 - (d) Direct the Engineering Coordinator/Operations to assign appropriate TSC Engineering staff to initiate evaluation of plant status conditions using the TSGs in support of EOP accident mitigation strategies and functions (Plant Condition Assessment, Control Parameter Assessment, and Function Status Assessment).
 - (e) Inform the Emergency Plant Manager of accident mitigation information as necessary.

- (f) If SAG implementation is directed by the EPOS, ensure that the TSC staff exits this Procedure and implements the functional responsibilities in accordance with EP-SAG-100, "Severe Accident Management Organization Guidelines", as necessary.
- [3] The Engineering Coordinator/Operations shall:
 - (a) Coordinate with the Engineering Coordinator/Systems and ES/TAG Coordinator for assigning appropriate TSC Engineering staff (Systems and ES/TAG) to initiate Function Status Assessment in accordance TSG-100, "*Function Status Assessment Guideline*", to support EOP mitigation actions and functions.
 - (b) Assign appropriate TSC Operations Engineer support staff to initiate Plant Condition Assessment and Control Parameter Assessment in accordance with TSG-200, "Plant Condition Assessment Guideline", and TSG-300, "Control Parameter Assessment Guideline", to support EOP accident mitigation actions and functions.
 - (c) Direct the technical assessment of the Technical Support Guidelines in support of EOP implementation, including potential courses of action should entry into Severe Accident Guidelines be necessary.
 - (d) Make recommendations to the EPOS and the TSC Supervisor as to when entry into Severe Accident Guidelines is necessary.
 - (e) If SAG implementation is directed, exit this Procedure and implement and redirect TSC Operations Engineering support in accordance with EP-SAG-100, "Severe Accident Management Organization Guidelines", as necessary.
- [4] Designated TSC Engineers (Systems and ES/TAG) shall:
 - (a) As directed by Engineering Coordinator/Operations, initiate Function Status Assessment in accordance with TSG-100, *"Function Status Assessment Gudeline"*, to support EOP accident mitigation strategies and functions.
 - (b) Recommend mitigating actions to the Engineering Coordinator/Operations.
 - (c) Evaluate and inform the ERO of actions that may be necessary.

- [5] The TSC Operations Engineer support staff shall:
 - (a) As directed by Engineering Coordinator/Operations, initiate Plant Condition Assessment and Control Parameter Assessment in accordance with TSG-200, "Plant Condition Assessment Guideline", and TSG-300, "Control Parameter Assessment Guideline", to support EOP accident mitigation strategies.
 - (b) Recommend mitigating actions to the Engineering Coordinator/Operations and the TSC Supervisor.
 - (c) Evaluate and inform the ERO of actions that may be necessary.

7.0 <u>RECORDS</u>

None

8.0 ATTACHMENTS

ATTACHMENT 1 - EOP-TO-SAG TRANSFER CHECKLIST

ATTACHMENT 2 - DOCUMENT CROSS-REFERENCES

ATTACHMENT 3 - IDENTIFICATION OF COMMITMENTS

EP-IP-225 Rev. 0 Page 9 of 12

EOP-TO-SAG TRANSFER CHECKLIST

- Is the TSC activated?
- Are the TSC Supervisor and Engineering Coordinator/Operations aware to exit this
 Procedure and implement the functional responsibilities in accordance with EP-SAG-100,
 "Severe Accident Management Organization Guidelines", as needed?
- Reason for SAG entry:
 - EOP-01 EOP-02 EOP-16 EOP-26
- Have the SAGs been reviewed and are TSGs in use in the TSC to support SAGs?
- Have RPV and Primary Containment flooding strategy recommendations been received?

SM	А	В	С	D	Ε	F	G
Engineering Coordinator/Operations	А	В	С	D	E	F	G

- Has a candidate RPV and Primary Containment flooding strategy been selected?
- Have the six functions performed in the candidate flooding strategy functions been reviewed?
 - RPV injection
 - ✓ Primary Containment injection
 - ✓ Primary Containment venting
 - ✓ RPV venting
 - ✓ Torus spray
 - ✓ Drywell spray
- Have SAG-02 Hydrogen and Oxygen Concentration strategies been identified?

Torus _____ Drywell _____ N/A _____

- Does the SM concur with plant status and plans for SAG use?
- Has the Emergency Director, EOM, and EPM been notified that decision-making responsibility has been assumed by the EPOS?
- Has a plant announcement been made indicating that SAGs are in use and decision-making responsibility transferred to the EPOS?

DOCUMENT CROSS-REFERENCES

This Attachment lists those documents, other than source documents, which may be affected by changes to this Procedure.

Document Number Document Title				
EP-AD-110 Emergency Preparedness Organization and Responsibilitie				
EP-AD-145	D-145 Severe Accident Management Program Maintenance			
EP-AD-210 Evaluating Changes for Impact on Training				
EP-AD-301	Emergency Preparedness Facilities and Equipment Surveillances			
EP-IP-201	Emergency Plant Manager			
EP-IP-210	Control Room Augmentation			
EP-IP-220	TSC Activation and Response			

IDENTIFICATION OF COMMITMENTS

This Attachment lists those external commitments (NRC commitments, QA audit findings, and INPO inspection items) implemented in this Procedure.

Reference Document	Commitment	Affected Section(s)/Step(s)
BECo 2.98.117	LTP #489 Severe Accident Management	All
	Initiating Document	

PLEASE NOTE:

YOU HAVE <u>4 NEW TABS</u>: EP-IP-220, 229 AND 230 PLEASE REMOVE OLD AND REPLACE WITH NEW

EP-IP-225 IS NEW

THANK YOU

EP-IP-220 TSC Activation and Response

EP-IP-225 Severe Accident Management Support

EP-IP 229 TSC/OSC Equipment Operation

EP-IP 230 OSC Activation and Response