


APRIL 16 1982

DISTRIBUTION: ORB#4 Rdg Gray File
 Docket File DEisenhut Hornstein
 NRC PDR OELD EBlackwood
 L PDR AEOD
 Docket No. 50-302 IE
 ACRS-10
 SMiner
 RIngram



Mr. John A. Hancock
 Vice President, Nuclear Operations
 Florida Power Corporation
 ATTN: Manager, Nuclear Licensing
 P. O. Box 14042, M.A.C. H-2
 St. Petersburg, Florida 33733

Dear Mr. Hancock:

This confirms our telephone authorization of April 6, 1982, with regard to the operation of the Crystal River Unit No. 3 Nuclear Generating Plant (CR-3) as requested by your telecopied letter dated April 6, 1982. On April 6, 1982, we authorized operation of CR-3 with the Reactor Coolant Pump Power Monitor (RCPPM) trip function bypassed provided four reactor coolant pumps were operating and the plant was operated at no more than 90% full power. You stated that you wish to operate with the RCPPM trip function bypassed until you can resolve the problem of the spurious reactor trip based on the RCPPMs.

Facility Operating License No. DPR-72 was amended April 6, 1982, by making the following Technical Specification change to Table 3.3.2:

Revise note "(c)" to "Table Notation" to read:

"In addition to the limits noted in (b) above, interim operation of the reactor is limited to a maximum of 90% full power while the Reactor Coolant Pump Power Monitor (RCPPM) trip is manually bypassed to resolve the problem of spurious scrams from RCPPM operation."

Copies of the license amendment, our evaluation and Federal Register Notice for the TS change will be sent to you when completed.

Sincerely,

Original signed by:
 Thomas M. Novak

Thomas M. Novak, Assistant Director
 for Operating Reactors
 Division of Licensing

CP
3

cc: See next page

8204260011

ORB#4:DL RIngram/eb	ORB#4:DL SMiner/cb	C-ORB#4:DL JStolz
4/14/82	4/14/82	4/14/82

OFFICE	AD-OR:PN			
SURNAME	TNovak			
DATE	4/15/82			

Safety Evaluation Report

Crystal River 3 Technical Specification

Change Request No. 97

Introduction

Florida Power Corp. has requested a Technical Specification change to allow operation up to 90% of full power ($2300 \text{ Mw} / 2544 \text{ Mw} = .90$) with the Reactor Coolant Pump Power Monitors out-of-service. The RCPM provides an instantaneous ^{aneous} reactor trip signal on loss of power to the reactor coolant pumps. This system was added to CR-3 as part of the recent power level upgrade (2452 Mw to 2544 Mw). Use of the system has produced some unnecessary reactor trip due to transmission grid disturbances. Florida Power Corp. therefore intends to operate CR-3 at 90% power

without the RCPPM until the system can be modified to eliminate the unnecessary trips.

Discussion

Florida Power Corp. has submitted a summary of a B+W analysis of the four pump loss of coolant flow without taking credit for the RCPPM. This analysis relied on the Flow/Flow Trip. And shows that the minimum DNBR is 1.43 for a four pump loss of flow initiated from 2300 MwT.

Evaluation

The analysis of the four pump loss of flow was done with the same codes, methods and correlation as previously used in CR-3 licensing analyses. The analysis results indicate that the minimum DNBR would be 1.43. The DNBR limit is 1.35. The analysis therefore

demonstrates acceptable results.

B+W was contacted (4/6/82 conversation with J. Castanes and others) to assure that the analyses had been performed in conformance with B+W quality assurance procedures. Technical aspects of the analysis were also discussed to assure that the results appeared reasonable and consistent with previous analyses.

Conclusion

Based on the results of the analyses submitted by Florida Power Corp., we conclude that a four pump loss of coolant flow event initiated at 2300 Mw would not exceed the applicable

regulatory limits, therefore approval of the proposed
Technical Specification changes will not result in
an undue risk to the health and safety of
the public.

Mary M. Holahan
Section Leader, System Section
ORAR, DL.

John
Jm

Crystal River Unit No. 3
Florida Power Corporation

50-302

cc w/enclosure(s):
Mr. S. A. Brandimore
Florida Power Corporation
Vice President and General Counsel
P. O. Box 14042
St. Petersburg, Florida 33733

Mr. Wilbur Langely, Chairman
Board of County Commissioners
Citrus County
Iverness, Florida 36250

Regional Radiation Representative
EPA Region IV
345 Courtland Street, N.E.
Atlanta, Georgia 30308

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Mr. Tom Stetka, Resident Inspector
U.S. Nuclear Regulatory Commission
Route #3, Box 717
Crystal River, Florida 32629

Mr. T. C. Lutkehaus
Nuclear Plant Manager
Florida Power Corporation
P. O. Box 219
Crystal River, Florida 32629

Crystal River Public Library
668 N. W. First Avenue
Crystal River, Florida 32629

Bureau of Intergovernmental Relations
660 Apalachee Parkway
Tallahassee, Florida 32304

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission, Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303