

Docket No. 50-423
Enclosure 1 to B18572

Appendix 3

Millstone Nuclear Power Station, Unit No. 3

All Indications - D Steam Generator

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
1	1				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	68			COLD
					RIC			08C	TEC	560UC	64			COLD
					RND			08H	TEC	560UC	65			COLD
1	2				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
1	3				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
1	4	3.24	176	1	NDD		TSC	08H	TEH	560UL	1			HOT
					DNG			08H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
1	5				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			07H	TEC	560UC	64			COLD
1	6	6.73	179	1	DNG		01H	08H	TEH	560UL	1			HOT
				3	NDF		01H	01H	01H	560PP	60			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	64			COLD
1	7				NDD			08C	08H	5201P	5			HOT
					NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	64			COLD
1	8				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
1	9				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
1	10				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	65			COLD
1	11				NDD			08H	TEH	560UL	1			HOT
					NDD			08C	08H	5201P	5			HOT
					NDD			08H	TEC	560UC	65			COLD
1	12				NDD			08H	TEH	560UL	1			HOT
					NDD			08C	08H	5201P	5			HOT
					NDD			08H	TEC	560UC	65			COLD
1	13	4.03	178	1	DNG		01H	08H	TEH	560UL	1			HOT
				3	NDF		01H	01H	01H	560PP	60			HOT
					NDD			07H	TEC	560UC	65			COLD
1	14				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	68			COLD
					RIC			08C	TEC	560UC	65			COLD
1	15				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					RBD			08C	08H	5201P	5			HOT
					NDD			08H	08C	5201P	87			COLD
					NDD			08H	TEC	560UC	65			COLD
1	16				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					RBD			08C	08H	5201P	5			HOT
					NDD			08H	08C	5001P	91			COLD
					RBD			08H	08C	5201P	87			COLD
					NDD			08H	TEC	560UC	65			COLD
1	17				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	65			COLD
1	18				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	65			COLD
1	19				NDD			08H	TEH	560UL	1			HOT
					RBD			08C	08H	5201P	5			HOT
					NDD			08H	08C	5001P	92			COLD
					NDD			08H	TEC	560UC	65			COLD
1	20				NDD			08H	TEH	560UL	1			HOT
					NDD			08C	08H	5201P	5			HOT
					NDD			08H	TEC	560UC	65			COLD
1	21				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	65			COLD
1	22				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	65			COLD
1	23				NDD			08H	TEH	560UL	1			HOT
					NDD			TEH	TSH	560PP	47			HOT
					NDD			08C	08H	5201P	5			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
1	24				NDD			08H	TEC	560UC	65			COLD
					NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					RBD			08C	08H	5201P	5			HOT
					NDD			08H	08C	5001P	92			COLD
					RBD			08H	08C	5201P	87			COLD
					NDD			08H	TEC	560UC	65			COLD
1	25				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	65			COLD
1	26				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	65			COLD
1	27				NDD			08H	TEH	560UL	1			HOT
					RBD			08C	08H	5201P	5			HOT
					RBD			08H	08C	5201P	88			COLD
					NDD			08H	08C	5001P	93			COLD
					NDD			08H	TEC	560UC	65			COLD
1	28				NDD			08H	TEH	560UL	1			HOT
					NDD			08C	08H	5201P	5			HOT
					NDD			08H	TEC	560UC	65			COLD
1	29				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	65			COLD
1	30				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	65			COLD
1	31				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08C	08H	5201P	5			HOT
					NDD			08H	TEC	560UC	65			COLD
1	32				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08C	08H	5201P	5			HOT
					NDD			08H	TEC	560UC	65			COLD
1	33				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	65			COLD
1	34				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			07H	TEC	560UC	65			COLD
1	35				NDD			08H	TEH	560UL	1			HOT
					RBD			08C	08H	5201P	5			HOT
					NDD			08H	08C	5201P	88			COLD
					NDD			07H	TEC	560UC	65			COLD
1	36				NDD			08H	TEH	560UL	1			HOT
					RBD			08C	08H	5201P	6			HOT
					RBD			08H	08C	5201P	88			COLD
					RBD			08H	08C	5001P	92			COLD
					RBD			08H	08C	5001P	92			COLD
					NDD			08H	08C	5001P	93			COLD
					NDD			08H	TEC	560UC	65			COLD
1	37				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	65			COLD
1	38				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	65			COLD
1	39				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					RBD			08C	08H	5201P	6			HOT
					RBD			08H	08C	5201P	88			COLD
					NDD			08H	08C	5001P	92			COLD
					NDD			08H	TEC	560UC	65			COLD
1	40				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					RBD			08C	08H	5201P	6			HOT
					RBD			08H	08C	5201P	88			COLD
					NDD			08H	08C	5001P	92			COLD
					NDD			08H	TEC	560UC	65			COLD
1	41				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	65			COLD
1	42				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			07H	TEC	560UC	65			COLD
1	43				NDD			08H	TEH	560UL	1			HOT
					RBD			08C	08H	5201P	6			HOT
					NDD			08H	08C	5001P	92			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
1	44				NDD			08H	TEC	560UC	65			COLD
					RIC			08C	TEC	560UC	64			COLD
					NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	68			COLD
					RBD			08C	08H	5201P	6			HOT
					NDD			08H	08C	5001P	93			COLD
1	45				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	68			COLD
1	46				NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
1	47				NDD			TSH	TSH	560PP	63			HOT
					NDD			08H	08C	5001P	93			COLD
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
1	48				NDD			TSH	TSH	560PP	63			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	08C	5001P	93			COLD
					NDD			08H	TEC	560UC	100			COLD
1	49				NDD			08H	TEC	560UC	107			COLD
					NDD			TSH	TSH	560PP	63			HOT
					NDD			08H	TEH	560UL	69			HOT
					RIC			08C	TEC	560UC	100			COLD
1	50				NDD			TSH	TSH	560PP	63			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
1	51				NDD			08H	TEH	560UL	69			HOT
					NDD			08H	08C	5001P	93			COLD
					NDD			08H	TEC	560UC	100			COLD
1	52				NDD			08H	TEH	560UL	69			HOT
					NDD			08H	08C	5001P	93			COLD
					NDD			08H	TEC	560UC	100			COLD
1	53				NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
1	54				NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
1	55				NDD			TSH	TSH	560PP	64			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	08C	5001P	93			COLD
					NDD			08H	TEC	560UC	100			COLD
1	56				NDD			08C	08H	5001P	73			HOT
					NDD			TSH	TSH	560PP	64			HOT
					NDD			08H	TEH	560UL	69			HOT
					RBD			08H	08C	5001P	93			COLD
					NDD			08H	TEC	560UC	100			COLD
1	57				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	64			HOT
					NDD			08H	TEH	560UL	69			HOT
1	58				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	66			HOT
					NDD			08H	TEH	560UL	69			HOT
1	59				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	08C	5001P	93			COLD
1	60				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	08C	5001P	93			COLD
					NDD			08H	TEH	560UL	69			HOT
1	61				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	2			HOT
1	62				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	2			HOT
1	63				NDD			08H	TEC	560UC	67			COLD
					NDD			08C	08H	5201P	7			HOT
					NDD			08H	TEH	560UL	2			HOT
					NDD			TSH	TSH	560PP	33			HOT
1	64				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	08C	5201P	85			COLD
					NDD			08H	TEH	560UL	2			HOT
					NDD			TSH	TSH	560PP	32			HOT
1	65				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	2			HOT
					NDD			TSH	TSH	560PP	33			HOT
1	66				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	2			HOT
					NDD			TSH	TSH	560PP	51			HOT
					RBD			TSH	TSH	560PP	32			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
1	67				NDD			07H	TEC	560UC	67			COLD
					RBD			08C	08H	5201P	7			HOT
					RBD			08H	08C	5201P	89			COLD
					NDD			08H	08C	5001P	90			COLD
					NDD			08H	TEH	560UL	2			HOT
1	68				NDD			08H	TEC	560UC	67			COLD
					RBD			08C	08H	5201P	7			HOT
					NDD			08H	TEH	560UL	2			HOT
					NDD			08H	08C	5201P	86			COLD
1	69				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	2			HOT
1	70				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	2			HOT
1	71				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	08C	5201P	89			COLD
					NDD			08H	08C	5001P	90			COLD
					NDD			08H	TEH	560UL	2			HOT
					RBD			08C	08H	5201P	7			HOT
					NDD			TSH	TSH	560PP	33			HOT
1	72				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	2			HOT
					NDD			08C	08H	5201P	7			HOT
					NDD			TSH	TSH	560PP	32			HOT
1	73				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	2			HOT
					NDD			TSH	TSH	560PP	33			HOT
1	74				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	2			HOT
					NDD			TSH	TSH	560PP	32			HOT
1	75				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	2			HOT
					NDD			08C	08H	5201P	7			HOT
1	76				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	2			HOT
					RBD			08C	08H	5201P	7			HOT
					RBD			08H	08C	5201P	86			COLD
					NDD			08H	08C	5201P	87			COLD
1	77				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
1	78				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
1	79				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
					NDD			08C	08H	5201P	7			HOT
1	80				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
					NDD			08C	08H	5201P	7			HOT
1	81				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
1	82				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
1	83				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
					RBD			08C	08H	5201P	7			HOT
					NDD			08C	08H	5201P	8			HOT
1	84				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
					NDD			08C	08H	5201P	8			HOT
1	85				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
1	86				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
1	87				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
					NDD			08C	08H	5201P	8			HOT
1	88				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
					NDD			08C	08H	5201P	8			HOT
1	89				NDD			08H	TEC	560UC	68			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
1	90				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
1	91				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	08C	5201P	86			COLD
					NDD			08H	TEH	560UL	3			HOT
					RBD			08C	08H	5201P	8			HOT
1	92				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
					NDD			08H	08C	5001P	91			COLD
					RBD			08C	08H	5201P	8			HOT
					RBD			08H	08C	5201P	86			COLD
1	93				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
1	94				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
1	95				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
					NDD			08H	08C	5001P	91			COLD
					RBD			08C	08H	5201P	8			HOT
					RBD			08H	08C	5201P	87			COLD
1	96				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
					NDD			08H	08C	5001P	91			COLD
					RBD			08C	08H	5201P	8			HOT
					RBD			08H	08C	5201P	87			COLD
1	97				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
1	98				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
1	99				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
					RBD			08C	08H	5201P	8			HOT
					NDD			08H	08C	5201P	87			COLD
1	100				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
					NDD			08H	08C	5001P	91			COLD
					RBD			08C	08H	5201P	8			HOT
					RBD			08H	08C	5201P	87			COLD
1	101				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
1	102				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
1	103				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
					NDD			08H	08C	5001P	91			COLD
					RBD			08C	08H	5201P	8			HOT
					RBD			08H	08C	5201P	87			COLD
1	104				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
					RBD			08C	08H	5201P	8			HOT
					NDD			08H	08C	5201P	87			COLD
1	105				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
1	106				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
1	107				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
					NDD			08C	08H	5201P	9			HOT
1	108				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
					NDD			08C	08H	5201P	9			HOT
1	109				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
1	110				NDD			08H	TEC	560UC	68			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					NDD			08H	TEH	560UL	3			HOT
					NDD			08H	O8C	5001P	93			COLD
1	111				NDD			08C	O8H	5001P	80			HOT
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
					NDD			08H	TEC	560UC	83			COLD
1	112				NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
					NDD			08H	O8C	5201P	87			COLD
					NDD			07H	TEC	560UC	83			COLD
1	113				NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
					RBD			08H	TEC	560UC	83			COLD
		3.57	186	1	DNG		02C +4.98	08H	TEC	560UC	100			COLD
		7.49	183	1	DNG		01C +5.11	08H	TEC	560UC	100			COLD
		3.55	184	1	DNG		TSC +6.04	08H	TEC	560UC	100			COLD
1	114				NDD			TSH	TSH	560PP	13			HOT
		3.97	179	1	DNG		01H -1.22	08H	TEH	560UL	3			HOT
				3	NDF		01H -1.46	01H	01H	560PP	62			HOT
					RBD			08H	TEC	560UC	83			COLD
		15.95	182	1	DNG		TSC +18.89	08H	TEC	560UC	100			COLD
1	115				NDD			08H	TEH	560UL	3			HOT
					NDD			08H	O8C	5001P	91			COLD
					RBD			08H	O8C	5201P	87			COLD
					RBD			08H	TEC	560UC	83			COLD
		4.75	178	1	DNG		TSC +18.97	08H	TEC	560UC	100			COLD
1	116				NDD			08H	O8C	5201P	87			COLD
					RBD			08C	TEC	560UC	83			COLD
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
1	117				NDD			07H	TEC	560UC	83			COLD
					NDD			08H	TEH	560UL	69			HOT
1	118				NDD			08H	TEC	560UC	83			COLD
					NDD			08H	TEH	560UL	69			HOT
1	119	0.17	88	3	SVI		TSH +13.94	TSH	01H	560PS	88			HOT
		0.43	111	3	NQI		TSH +13.75	08H	TEH	560UL	70			HOT
					NDD			TSH	TSH	560PP	66			HOT
					NDD			08H	O8C	5001P	91			COLD
					RBD			08H	O8C	5201P	87			COLD
		0.17	85	3	PID		TSH +13.94	TSH	01H	560PS	89			HOT
					RBD			08H	TEC	560UC	83			COLD
		0.89	62	P 4	TWD 16		TSC +13.86	TSC	TSC	560PP	89			HOT
		0.35	90	P 4	ARC		TSC +13.83	TSC	TSC	560PP	89			HOT
		0.35	0	P 4	LEN		TSC +13.83	TSC	TSC	560PP	89			HOT
		0.50	88	P 5	TWD 9		TSC +13.83	TSC	TSC	560PP	89			HOT
		0.40	90	P 5	ARC		TSC +13.83	TSC	TSC	560PP	89			HOT
		0.30	0	P 5	LEN		TSC +13.83	TSC	TSC	560PP	89			HOT
					RIC		07H +6.75	07H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
1	120	0.36	0	P 5	TWD 6		TSH +14.15	TSH	TSH	560PP	85			HOT
		0.30	90	P 5	ARC		TSH +14.15	TSH	TSH	560PP	85			HOT
		0.38	0	P 5	LEN		TSH +14.15	TSH	TSH	560PP	85			HOT
		0.30	0	P 4	LEN		TSH +14.12	TSH	TSH	560PP	85			HOT
		0.13	118	3	PID		TSH +14.11	01H	TSH	560PP	85			HOT
		0.17	99	3	SVI		TSH +14.11	TSH	01H	560PP	81			HOT
					NDD			TSH	TSH	560PP	66			HOT
					NDD			08H	O8C	5001P	91			COLD
					RBD			08H	O8C	5201P	87			COLD
					NDD			08H	TEC	560UC	83			COLD
		0.50	0	P 4	TWD 11		TSH +14.12	01H	TSH	560PP	85			HOT
		0.35	90	P 4	ARC		TSH +14.12	TSH	TSH	560PP	85			HOT
		0.60	102	3	NQI		TSH +14.11	08H	TEH	560UL	69			HOT
1	121	0.16	140	3	PID		TSH +14.09	01H	TSH	560PP	86			HOT
		0.18	134	3	SVI		TSH +14.09	TSH	01H	560PP	81			HOT
					NDD			TSH	TSH	560PP	66			HOT
		0.44	0	P 4	TWD 10		TSH +13.97	01H	TSH	560PP	86			HOT
		0.37	90	P 4	ARC		TSH +13.97	01H	TSH	560PP	86			HOT
		0.21	0	P 4	LEN		TSH +13.97	TSH	TSH	560PP	86			HOT
		0.27	0	P 5	TWD 4		TSH +14.00	TSH	TSH	560PP	86			HOT
		0.40	90	P 5	ARC		TSH +14.00	TSH	TSH	560PP	86			HOT
		0.30	0	P 5	LEN		TSH +14.00	TSH	TSH	560PP	86			HOT
		0.46	119	3	NQI		TSH +14.09	08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
2	1				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
2	2				NDD			08H	TEH	560UL	1			HOT
					INF		06C +0.00	07H	TEC	560UC	64	HR		COLD
					NDD			08C	08H	5201P	5			HOT
2	3				NDD			07H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
2	4				NDD			08H	TEH	560UL	1			HOT
		0.78	119	3	INR		06C +20.39	07H	TEC	560UC	64			COLD
		0.92	119	3	INR		06C +14.12	07H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
2	5				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			07H	TEC	560UC	64			COLD
2	6				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			07H	TEC	560UC	64			COLD
2	7				RIC			08H	TSH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			07H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
2	8				NDD			08H	TEH	560UL	4			HOT
					NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			07H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
2	9				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
2	10				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
2	11				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
2	12				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
					RBD			08C	08H	5201P	5			HOT
					NDD			08H	08C	5201P	87			COLD
2	13				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
2	14				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
2	15				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			07H	TEC	560UC	64			COLD
					RBD			08C	08H	5201P	5			HOT
					NDD			08H	08C	5201P	87			COLD
2	16				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			07H	TEC	560UC	64			COLD
					RBD			08C	08H	5201P	5			HOT
					NDD			08H	08C	5201P	87			COLD
2	17				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			07H	TEC	560UC	64			COLD
2	18				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			07H	TEC	560UC	64			COLD
2	19				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
2	20				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
2	21				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
2	22				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
2	23				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
2	24				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
2	25				NDD			08H	TEH	560UL	1			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	64			COLD
2	26				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47	IDOK		HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
2	27				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
2	28	0.22	51	6	INR	02H	+36.00	08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
2	29				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
2	30				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
2	31				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
2	32				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
2	33				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	64			COLD
2	34				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
2	35				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
2	36				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
					NDD			08C	08H	5201P	5			HOT
2	37				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
2	38	1.72	81	6	INR	03H	+4.52	08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
2	39				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	64			COLD
					RBD			08C	08H	5201P	6			HOT
					NDD			08H	08C	5201P	88			COLD
2	40	6.87	180	P 1	DNT	08H	+0.66	08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
		7.23	183	1	DNG	08H	+0.85	08H	TEC	560UC	64			COLD
					RBD			08C	08H	5201P	6			HOT
					RBD			08H	08C	5201P	88			COLD
					NDD			08H	08C	5001P	92			COLD
2	41				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
2	42				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	64			COLD
2	43				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
					RBD			08C	08H	5201P	6			HOT
					NDD			08H	08C	5001P	93			COLD
2	44				NDD			08H	TEC	560UC	64			COLD
					NDD			08H	TEH	560UL	1			HOT
					RBD			08C	08H	5201P	6			HOT
					NDD			08H	08C	5001P	93			COLD
2	45				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
2	46				NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
2	47				NDD			TSH	TSH	560PP	63			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	08C	5001P	93			COLD
					NDD			08H	TEC	560UC	100			COLD
2	48				NDD			TSH	TSH	560PP	63			HOT
					NDD			08H	TEH	560UL	69			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	*TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					NDD			08H	08C	5001P	93			COLD
					NDD			08H	TEC	560UC	100			COLD
2	49				NDD			TSH	TSH	560PP	63			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
2	50				NDD			TSH	TSH	560PP	63			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
2	51				NDD			08H	TEH	560UL	69			HOT
					NDD			08H	08C	5001P	93			COLD
					NDD			08H	TEC	560UC	100			COLD
2	52				NDD			08H	TEH	560UL	69			HOT
					NDD			08H	08C	5001P	93			COLD
					NDD			08H	TEC	560UC	100			COLD
2	53				NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
2	54				NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
2	55				NDD			TSH	TSH	560PP	64			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	08C	5001P	93			COLD
					NDD			08H	TEC	560UC	100			COLD
2	56				NDD			TSH	TSH	560PP	64			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	08C	5001P	93			COLD
					NDD			08H	TEC	560UC	100			COLD
2	57				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	64			HOT
					NDD			08H	TEH	560UL	69			HOT
2	58				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	66			HOT
					NDD			08H	TEH	560UL	69			HOT
2	59				NDD			07H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	08C	5001P	93			COLD
2	60				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	08C	5001P	93			COLD
					NDD			08H	TEH	560UL	69			HOT
2	61	2.44	10	1	INR		03C	+6.40	08H	TEC	560UC	67		COLD
					NDD			08H	TEH	560UL	2			HOT
2	62				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	2			HOT
2	63				NDD			07H	TEC	560UC	67			COLD
					NDD			08C	08H	5201P	7			HOT
					NDD			08H	TEH	560UL	2			HOT
					NDD			TSH	TSH	560PP	33			HOT
2	64				NDD			08H	TEC	560UC	67			COLD
					NDD			08C	08H	5201P	7			HOT
		15.48		8	SLG		TSH	+0.47	08H	TEH	560UL	2		HOT
					NDD			TSH	TSH	560PP	32			HOT
2	65				NDD			08H	TEC	560UC	67			COLD
		25.85		8	SLG		TSH	+0.72	08H	TEH	560UL	2		HOT
					NDD			TSH	TSH	560PP	33			HOT
2	66				NDD			08H	TEC	560UC	67			COLD
		26.91		8	SLG		TSH	+0.88	08H	TEH	560UL	2		HOT
					NDD			TSH	TSH	560PP	32			HOT
2	67				NDD			07H	TEC	560UC	67			COLD
					NDD			08C	08H	5201P	7			HOT
		28.99		8	SLG		TSH	+1.12	08H	TEH	560UL	2		HOT
2	68				NDD			08H	TEC	560UC	67			COLD
					NDD			08C	08H	5201P	7			HOT
		28.54		8	SLG		TSH	+1.20	08H	TEH	560UL	2		HOT
2	69				NDD			08H	TEC	560UC	67			COLD
		27.03		8	SLG		TSH	+1.09	08H	TEH	560UL	2		HOT
2	70				NDD			08H	TEC	560UC	67			COLD
		23.68		8	SLG		TSH	+0.91	08H	TEH	560UL	2		HOT
2	71				NDD			08H	TEC	560UC	67			COLD
		24.15		8	SLG		TSH	+0.86	08H	TEH	560UL	2		HOT
					NDD			08C	08H	5201P	7			HOT
					NDD			TSH	TSH	560PP	33			HOT
2	72				NDD			08H	TEC	560UC	67			COLD
		24.32		8	SLG		TSH	+0.81	08H	TEH	560UL	2		HOT
					NDD			08C	08H	5201P	7			HOT
					NDD			TSH	TSH	560PP	32			HOT
2	73				NDD			08H	TEC	560UC	67			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		23.97		8	SLG		TSH	+0.80	08H	TEH	560UL	2		HOT
					NDD				TSH	TSH	560PP	33		HOT
2	74				NDD				08H	TEC	560UC	67		COLD
		21.64		8	SLG		TSH	+0.64	08H	TEH	560UL	2		HOT
					NDD				TSH	TSH	560PP	32		HOT
2	75				NDD				07H	TEC	560UC	67		COLD
					NDD				08H	TEH	560UL	2		HOT
					NDD				08C	08H	5201P	7		HOT
2	76				NDD				08H	TEC	560UC	67		COLD
					NDD				08H	TEH	560UL	2		HOT
					NDD				08C	08H	5201P	7		HOT
2	77				NDD				08H	TEC	560UC	67		COLD
					NDD				08H	TEH	560UL	3		HOT
2	78				NDD				08H	TEC	560UC	67		COLD
					NDD				08H	TEH	560UL	3		HOT
2	79				NDD				07H	TEC	560UC	67		COLD
					NDD				TSH	TSH	560PP	13		HOT
					NDD				08H	TEH	560UL	3		HOT
					NDD				08C	08H	5201P	7		HOT
2	80				NDD				08H	TEC	560UC	67		COLD
					NDD				08H	08C	5201P	85		COLD
					NDD				TSH	TSH	560PP	12		HOT
					NDD				08H	TEH	560UL	3		HOT
					RBD				08C	08H	5201P	7		HOT
2	81				NDD				08H	TEC	560UC	67		COLD
					NDD				TSH	TSH	560PP	13		HOT
					NDD				08H	TEH	560UL	3		HOT
2	82				NDD				08H	TEC	560UC	67		COLD
					NDD				TSH	TSH	560PP	12		HOT
					NDD				08H	TEH	560UL	3		HOT
2	83				NDD				08H	TEC	560UC	67		COLD
					NDD				08H	TEH	560UL	3		HOT
					NDD				08C	08H	5201P	7		HOT
					NDD				08C	08H	5201P	8	IDOK	HOT
2	84				NDD				08H	TEC	560UC	67		COLD
					NDD				08H	TEH	560UL	3		HOT
					NDD				08C	08H	5201P	8		HOT
2	85				NDD				08H	TEC	560UC	67		COLD
					NDD				08H	TEH	560UL	3		HOT
2	86				NDD				08H	TEC	560UC	67		COLD
					NDD				08H	TEH	560UL	3		HOT
2	87				NDD				08H	TEC	560UC	67		COLD
					NDD				TSH	TSH	560PP	13		HOT
					NDD				08H	TEH	560UL	3		HOT
					NDD				08C	08H	5201P	8		HOT
2	88				NDD				08H	TEC	560UC	67		COLD
					NDD				TSH	TSH	560PP	12		HOT
					NDD				08H	TEH	560UL	3		HOT
					NDD				08C	08H	5201P	8		HOT
2	89				NDD				08H	TEC	560UC	67		COLD
					NDD				TSH	TSH	560PP	13		HOT
					NDD				08H	TEH	560UL	3		HOT
2	90				NDD				08H	TEC	560UC	67		COLD
					NDD				TSH	TSH	560PP	12		HOT
					NDD				08H	TEH	560UL	3		HOT
2	91				NDD				08H	TEC	560UC	67		COLD
					NDD				08H	08C	5201P	84		COLD
					NDD				08H	TEH	560UL	3		HOT
					RBD				08C	08H	5201P	8		HOT
2	92			3	NDF		01C	-0.28	01C	01C	560PP	108		COLD
		0.73		138	P 1	DSS	01C	-0.28	08H	TEC	560UC	67		COLD
					NDD				08H	TEH	560UL	3		HOT
					NDD				08C	08H	5201P	8		HOT
2	93				NDD				08H	TEC	560UC	67		COLD
		0.56		73	3	NQH	05H	+6.16	08H	TEH	560UL	3		HOT
		0.57		68	3	NQH	05H	+5.57	08H	TEH	560UL	3		HOT
		0.16		106	3	NQH	02H	+6.08	08H	TEH	560UL	3		HOT
2	94				NDD				08H	TEC	560UC	67		COLD
					NDD				08H	TEH	560UL	3		HOT
2	95				NDD				08H	TEC	560UC	67		COLD
					NDD				TSH	TSH	560PP	13		HOT
					NDD				08H	TEH	560UL	3		HOT
					NDD				08C	08H	5201P	8		HOT
2	96			61	3	INR	03C	+34.75	08H	TEC	560UC	67		COLD
		0.34				NDD			TSH	TSH	560PP	12		HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		0.57	71	3	NQH		05H +35.49	08H	TEH	560UL	3			HOT
		0.56	104	3	NQH		07H +35.10	08H	TEH	560UL	3			HOT
		0.17	96	3	NQH		07H +33.93	08H	TEH	560UL	3			HOT
2	97				NDD			08C	08H	5201P	8			HOT
					NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	13			HOT
2	98				NDD			08H	TEH	560UL	3			HOT
					NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
2	99				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	3			HOT
					NDD			08C	08H	5201P	8			HOT
2	100				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	3			HOT
					NDD			08C	08H	5201P	8			HOT
2	101				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	3			HOT
2	102				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
2	103				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
		17.37		8	SLG		06H +1.13	08H	TEH	560UL	3			HOT
		3.56	187	1	DNG		05H +21.78	08H	TEH	560UL	3			HOT
		4.44	187	1	DNG		02H +24.72	08H	TEH	560UL	3			HOT
		3.47	187	1	DNG		02H +23.44	08H	TEH	560UL	3			HOT
					NDD			08C	08H	5201P	8			HOT
				3	NDF		02H +23.44	02H	03H	560PP	62			HOT
				3	NDF		02H +24.72	02H	03H	560PP	62			HOT
2	104				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	12			HOT
		19.79		8	SLG		06H +1.14	08H	TEH	560UL	3			HOT
					NDD			08C	08H	5201P	9			HOT
2	105				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
2	106				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
2	107				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	08C	5201P	84			COLD
		22.08		8	SLG		06H +1.47	08H	TEH	560UL	3			HOT
					RBD			08C	08H	5201P	9			HOT
2	108				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	08C	5201P	84			COLD
		4.48	187	1	DNG		02H +16.94	08H	TEH	560UL	3			HOT
		3.32	185	P 1	DNT		01H -0.11	08H	TEH	560UL	3			HOT
					RBD			08C	08H	5201P	9			HOT
				3	NDF		01H -0.11	01H	01H	560PP	62			HOT
2	109				NDD			07H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
2	110				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
2	111				NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	08C	5201P	84			COLD
					NDD			08H	TEH	560UL	3			HOT
					NDD			08H	TEC	560UC	83			COLD
2	112				NDD			08H	08C	5201P	84			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
					NDD			08H	TEC	560UC	83			COLD
2	113				NDD			TSH	TSH	560PP	13			HOT
					NDD			08H	TEH	560UL	3			HOT
					NDD			07H	TEC	560UC	83			COLD
2	114				NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
					NDD			08H	TEC	560UC	83			COLD
2	115				NDD			08H	08C	5201P	84			COLD
					NDD			08H	TEH	560UL	3			HOT
					NDD			08H	TEC	560UC	83			COLD
2	116				NDD			08H	08C	5201P	84			COLD
					NDD			07H	TEC	560UC	83			COLD
					NDD			08H	TEH	560UL	69			HOT
2	117				NDD			07H	TEC	560UC	83			COLD
					NDD			08H	TEH	560UL	69			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
2	118				NDD			08H	TEC	560UC	83			COLD
					NDD			08H	TEH	560UL	69			HOT
2	119				NDD			08H	08C	5201P	84			COLD
					NDD			TSH	TSH	560PP	66			HOT
					NDD			07H	TEC	560UC	83			COLD
					NDD			08H	TEH	560UL	69			HOT
2	120				NDD			08H	08C	5201P	84			COLD
					NDD			TSH	TSH	560PP	66			HOT
					NDD			07H	TEC	560UC	83			COLD
					NDD			08H	TEH	560UL	69			HOT
2	121				NDD			TSH	TSH	560PP	66			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
2	122				NDD			TSH	TSH	560PP	66			HOT
					NDD			08H	TEH	560UL	69			HOT
	0.58		138	3	INR		TSC	+13.46	08H	TEC	560UC	100		COLD
3	1				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	2				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	3				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
3	4				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	5				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	64			COLD
3	6				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	64			COLD
3	7				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	64			COLD
3	8	0.66		100	3		TSH	+1.03	08H	TEH	560UL	1		HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
3	9				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	10				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	11				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
3	12				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	13				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
3	14				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	15				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
3	16	4.12		184	P 1		08H	+0.29	08H	TEH	560UL	1		HOT
					3		NDF	+0.29	08H	08H	560PP	60		HOT
					3		NDF	+0.65	08H	08H	560PP	60		HOT
					NDD			TSH	TSH	560PP	46			HOT
	4.43			184	P 1		08H	+0.65	08H	TEC	560UC	64		COLD
3	17				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			07H	TEC	560UC	64			COLD
3	18				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
3	19				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	20				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
3	21				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	22				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	23				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
3	24				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
3	25				NDD			08H	TEC	560UC	64			COLD
					NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
3	26				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
3	27				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	28				NDD			08H	TEH	560UL	1			HOT
					NDD			07H	TEC	560UC	64			COLD
3	29				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	30				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	31				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
3	32				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
3	33				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
3	34				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
3	35				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	36				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	37				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	38				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	39				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
3	40				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	46			HOT
					NDD			08H	TEC	560UC	64			COLD
3	41				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	64			COLD
3	42				NDD			08H	TEH	560UL	1			HOT
					NDD			TSH	TSH	560PP	47			HOT
					NDD			08H	TEC	560UC	64			COLD
3	43				NDD			08H	TEC	560UC	64			COLD
					NDD			08H	TEH	560UL	1			HOT
3	44				NDD			06H	TEC	560UC	64			COLD
					NDD			08H	TEH	560UL	1			HOT
3	45				NDD			08H	TEH	560UL	1			HOT
					NDD			08H	TEC	560UC	64			COLD
3	46				NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
3	47				NDD			TSH	TSH	560PP	63			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
3	48				NDD			TSH	TSH	560PP	63			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
3	49				NDD			TSH	TSH	560PP	63			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
3	50				NDD			TSH	TSH	560PP	63			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
3	51				NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
3	52				NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
3	53				NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
3	54				NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
3	55				NDD			TSH	TSH	560PP	64			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
3	56				NDD			TSH	TSH	560PP	64			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
3	57				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	64			HOT
					NDD			08H	TEH	560UL	69			HOT
3	58				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	65			HOT
					NDD			08H	TEH	560UL	69			HOT
3	59				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	69			HOT
3	60				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	69			HOT
3	61				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	2			HOT
3	62				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	2			HOT
3	63	17.75		8	NDD			08H	TEC	560UC	67			COLD
					SLG		TSH	08H	TEH	560UL	2			HOT
					NDD			TSH	TSH	560PP	33			HOT
3	64	26.09		8	NDD			07H	TEC	560UC	67			COLD
					SLG		TSH	08H	TEH	560UL	2			HOT
					NDD			TSH	TSH	560PP	32			HOT
3	65	36.60		8	NDD			08H	TEC	560UC	67			COLD
					SLG		TSH	08H	TEH	560UL	2			HOT
					NDD			TSH	TSH	560PP	33			HOT
3	66	34.99		8	NDD			07H	TEC	560UC	67			COLD
					SLG		TSH	08H	TEH	560UL	2			HOT
					NDD			TSH	TSH	560PP	32			HOT
3	67	34.78		8	NDD			08H	TEC	560UC	67			COLD
					SLG		TSH	08H	TEH	560UL	2			HOT
3	68	35.21		8	NDD			08H	TEC	560UC	67			COLD
					SLG		TSH	08H	TEH	560UL	2			HOT
3	69	35.56		8	NDD			08H	TEC	560UC	67			COLD
					SLG		TSH	08H	TEH	560UL	2			HOT
3	70	34.35		8	NDD			08H	TEC	560UC	67			COLD
					SLG		TSH	08H	TEH	560UL	2			HOT
3	71	35.23		8	NDD			08H	TEC	560UC	67			COLD
					SLG		TSH	08H	TEH	560UL	2			HOT
					NDD			TSH	TSH	560PP	33			HOT
3	72	35.27		8	NDD			07H	TEC	560UC	67			COLD
					SLG		TSH	08H	TEH	560UL	2			HOT
					NDD			TSH	TSH	560PP	32			HOT
3	73	33.66		8	NDD			08H	TEC	560UC	67			COLD
					SLG		TSH	08H	TEH	560UL	2			HOT
					NDD			TSH	TSH	560PP	33			HOT
3	74	34.56		8	NDD			08H	TEC	560UC	67			COLD
					SLG		TSH	08H	TEH	560UL	2			HOT
					NDD			TSH	TSH	560PP	32			HOT
3	75	28.48		8	NDD			08H	TEC	560UC	67			COLD
					SLG		TSH	08H	TEH	560UL	2			HOT
3	76				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	2			HOT
3	77	16.24		8	NDD			08H	TEC	560UC	67			COLD
					SLG		06H	08H	TEH	560UL	3			HOT
3	78				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	3			HOT
3	79				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	80				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	81				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	82				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	83				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	3			HOT
3	84				NDD			08H	TEC	560UC	67			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
3	85				NDD			08H	TEH	560UL	3			HOT
					NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	3			HOT
3	86				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	3			HOT
3	87				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	88				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	89				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	90				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	91				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	3			HOT
3	92				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	3			HOT
3	93				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	3			HOT
3	94				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	3			HOT
3	95				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	96				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	97				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	98				NDD			08H	TEC	560UC	67			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	99				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	3			HOT
3	100	15.65		8	NDD			08H	TEC	560UC	67			COLD
					SLG	07H	+1.05	08H	TEH	560UL	3			HOT
3	101				NDD			08H	TEC	560UC	67			COLD
					NDD			08H	TEH	560UL	3			HOT
3	102				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
3	103				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	104				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	12			HOT
		20.54		8	SLG	06H	+1.69	08H	TEH	560UL	3			HOT
3	105				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	106				NDD			08H	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	107				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
3	108				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
3	109				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
3	110				NDD			08H	TEC	560UC	68			COLD
					NDD			08H	TEH	560UL	3			HOT
3	111				NDD			08H	TEC	560UC	83			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	112				NDD			07H	TEC	560UC	83			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	113				NDD			08H	TEC	560UC	83			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	114				NDD			08H	TEC	560UC	83			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					NDD			TSH	TSH	560PP	12			HOT
					NDD			08H	TEH	560UL	3			HOT
3	115				NDD			08H	TEC	560UC	83			COLD
					NDD			08H	TEH	560UL	3			HOT
3	116				NDD			08H	TEC	560UC	83			COLD
					NDD			08H	TEH	560UL	69			HOT
3	117				NDD			08H	TEC	560UC	83			COLD
					NDD			08H	TEH	560UL	69			HOT
3	118				NDD			08H	TEC	560UC	83			COLD
					NDD			08H	TEH	560UL	69			HOT
3	119				NDD			TSH	TSH	560PP	66			HOT
					NDD			08H	TEC	560UC	83			COLD
					NDD			08H	TEH	560UL	69			HOT
3	120				NDD			TSH	TSH	560PP	66			HOT
					NDD			08H	TEC	560UC	83			COLD
					NDD			08H	TEH	560UL	69			HOT
3	121				NDD			TSH	TSH	560PP	66			HOT
					NDD			08H	TEH	560UL	69			HOT
	2.17	68	6		NQH	02C	+18.46	08H	TEC	560UC	100			COLD
3	122				NDD			TSH	TSH	560PP	66			HOT
					NDD			08H	TEH	560UL	69			HOT
					NDD			08H	TEC	560UC	100			COLD
4	1				NDD			TEH	TEC	560UL	56			COLD
4	2				NDD			TEH	TEC	560UL	56			COLD
4	3				NDD			TEH	TEC	560UL	57			COLD
4	4				NDD			TEH	TEC	560UL	57			COLD
4	5				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	57			COLD
4	6				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	57			COLD
4	7				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	57			COLD
4	8				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	57			COLD
4	9				NDD			TEH	TEC	560UL	57			COLD
4	10				NDD			TEH	TEC	560UL	57			COLD
4	11				NDD			TEH	TEC	560UC	69			COLD
4	12	4.29	175	1	RBD			TEH	TEC	560UL	58			COLD
					DNG	07H	+19.09	TEH	TEC	560UC	69			COLD
4	13				NDD			TEH	TEC	560UC	69			COLD
4	14	0.57	64	6	INR	07C	+2.03	TEH	TEC	560UC	69			COLD
					NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UC	69			COLD
4	16				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UC	69			COLD
4	17				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UC	69			COLD
4	18				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UC	69			COLD
4	19				NDD			TEH	TEC	560UC	69			COLD
4	20				NDD			TEH	TSH	560PP	46			HOT
					NDD			TEH	TEC	560UL	63			COLD
4	21				NDD			TEH	TEC	560UL	63			COLD
4	22				NDD			TEH	TEC	560UL	63			COLD
4	23				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	63			COLD
4	24				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	63			COLD
4	25				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	63			COLD
4	26				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	63			COLD
4	27				NDD			TEH	TEC	560UC	69			COLD
4	28				NDD			TEH	TEC	560UL	63			COLD
4	29				NDD			TEH	TEC	560UL	63			COLD
4	30	7.87	185	1	DNG	TSC	+10.60	TEH	TEC	560UL	63			COLD
					NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	63			COLD
4	32				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	63			COLD
4	33				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	63			COLD
4	34				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	63			COLD
4	35				NDD			TEH	TEC	560UL	63			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
4	36				NDD			TEH	TEC	560UL	63			COLD
4	37				NDD			TEH	TEC	560UL	63			COLD
4	38				NDD			TEH	TEC	560UL	63			COLD
4	39				NDD			TSH	TSH	560PP	49			HOT
4	40				NDD			TEH	TEC	560UL	63			COLD
4	41				NDD			TSH	TSH	560PP	49			HOT
4	42				NDD			TEH	TEC	560UL	63			COLD
4	43				NDD			TSH	TSH	560PP	49			HOT
4	44				NDD			TEH	TEC	560UL	63			COLD
4	45	0.68	126	3	INR		TSH +33.40	TEH	TEC	560UL	105			COLD
4	46				NDD			TEH	TEC	560UC	98			COLD
4	47				NDD			TSH	TSH	560PP	63			HOT
4	48				NDD			TEH	TEC	560UC	98			COLD
4	49				NDD			TSH	TSH	560PP	63			HOT
4	50				NDD			TEH	TEC	560UC	98			COLD
4	51				NDD			TSH	TSH	560PP	63			HOT
4	52				NDD			TEH	TEC	560UC	98			COLD
4	53				NDD			TEH	TEC	560UC	98			COLD
4	54				NDD			TEH	TEC	560UC	98			COLD
4	55				NDD			TSH	TSH	560PP	64			HOT
4	56				NDD			TEH	TEC	560UC	98			COLD
4	57				NDD			TSH	TSH	560PP	64			HOT
4	58				NDD			TEH	TEC	560UC	98			COLD
4	59				NDD			TSH	TSH	560PP	66			HOT
4	60				NDD			TEH	TEC	560UC	98			COLD
4	61				NDD			TEH	TEC	560UC	98			COLD
4	62				NDD			TEH	TEC	560UC	98			COLD
4	63				NDD			TEH	TEC	560UC	98			COLD
4	64				NDD			TSH	TSH	560PP	33			HOT
4	65				NDD			TEH	TEC	560UL	53			COLD
4	66				NDD			TSH	TSH	560PP	32			HOT
4	67				NDD			TEH	TEC	560UL	52			COLD
4	68				NDD			TSH	TSH	560PP	33			HOT
4	69				NDD			TEH	TEC	560UL	52			COLD
4	70				NDD			TEH	TEC	560UL	53			COLD
4	71				NDD			TEH	TEC	560UL	52			COLD
4	72				NDD			TSH	TSH	560PP	33			HOT
4	73				NDD			TEH	TEC	560UL	53			COLD
4	74				NDD			TSH	TSH	560PP	33			HOT
4	75				NDD			TEH	TEC	560UL	52			COLD
4	76				NDD			TEH	TEC	560UL	53			COLD
4	77				NDD			TEH	TEC	560UL	57			COLD
4	78				NDD			TEH	TEC	560UL	57			COLD
4	79				NDD			TEH	TEC	560UL	57			COLD
4	80	0.65	123	3	INR		02C +25.30	TSH	TSH	560PP	13			HOT
4	81				NDD			TEH	TEC	560UL	57			COLD
4	82				NDD			TSH	TSH	560PP	13			HOT
4	83				NDD			TEH	TEC	560UL	57			COLD
4	84	3.46	176	1	DNG		07C +20.17	TEH	TEC	560UL	57			COLD
4	85	1.38	172	1	INR		07C +19.11	TEH	TEC	560UL	57			COLD
4	85	0.58	113	3	INR		TSH +19.60	TEH	TEC	560UL	57			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		0.57	125	3	INR		TSH			+23.40				
4	86				NDD			TEH	TEC	560UL	57			COLD
					NDD			TEH	TEC	560UL	57			COLD
4	87				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	13			HOT
4	88				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	13			HOT
4	89				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	13			HOT
4	90				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	13			HOT
4	91				NDD			TEH	TEC	560UL	57			COLD
4	92				NDD			TEH	TEC	560UL	57			COLD
4	93				NDD			TEH	TEC	560UL	57			COLD
4	94				NDD			TEH	TEC	560UL	57			COLD
4	95				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	13			HOT
4	96				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	13			HOT
4	97				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	13			HOT
4	98				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	13			HOT
4	99				NDD			TEH	TEC	560UL	57			COLD
4	100				NDD			TEH	TEC	560UL	57			COLD
4	101				NDD			TEH	TEC	560UL	57			COLD
4	102				NDD			TEH	TEC	560UL	57			COLD
4	103				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	15			HOT
4	104				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560UL	56			COLD
4	105				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560UL	56			COLD
4	106				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560UL	56			COLD
4	107	4.71	181	1	DNG		TSH			+1.66				
					NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	14			HOT
4	108				NDD			TEH	TEC	560UL	56			COLD
4	109				NDD			TEH	TEC	560UL	57			COLD
4	110				NDD			TEH	TEC	560UL	56			COLD
4	111				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	15			HOT
4	112	19.69		8	SLG		06H			+1.49				
					NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	15			HOT
4	113				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	66			HOT
					RBD			TEH	TEC	560UC	75			COLD
4	114				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	66			HOT
					RBD			TEH	TEC	560UC	75			COLD
4	115	3.88	185	1	DNG		02C			+4.03				
					RBD			TEH	TEC	560UL	105			COLD
					RBD			TEH	TEC	560UC	75			COLD
4	116				NDD			TEH	TEC	560UL	105			COLD
4	117				NDD			TEH	TEC	560UL	105			COLD
					RBD			TEH	TEC	560UC	75			COLD
4	118				NDD			TEH	TEC	560UL	105			COLD
4	119				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	66			HOT
					RBD			TEH	TEC	560UC	75			COLD
4	120				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	66			HOT
4	121				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	65			HOT
					RBD			TEH	TEC	560UC	75			COLD
4	122				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	66			HOT
5	1	2.53	155	1	TFH		08H			+3.70				
5	2				NDD			TEH	TEC	560UL	57			COLD
5	3				NDD			TEH	TEC	560UL	57			COLD
5	4				NDD			TEH	TEC	560UL	56			COLD
5	5				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	56			COLD
5	6				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	44			HOT
5	7				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	44			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
5	8				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	44			HOT
5	9				NDD			TEH	TEC	560UL	56			COLD
5	10				NDD			TEH	TEC	560UL	56			COLD
5	11				NDD			TEH	TEC	560UL	58			COLD
5	12				NDD			TEH	TEC	560UL	59			COLD
5	13				NDD			TEH	TEC	560UL	58			COLD
5	14				NDD			TEH	TEC	560UL	58			COLD
5	15	2.15	21	1	INR	04H	+31.80	TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	16				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	17				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	18				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	19				NDD			TEH	TEC	560UL	58			COLD
5	20				NDD			TEH	TEC	560UL	58			COLD
5	21				NDD			TEH	TEC	560UL	59			COLD
5	22				NDD			TEH	TEC	560UL	58			COLD
5	23	0.67	104	3	INR	06C	+8.30	TEH	TEC	560UL	59			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	24				RBD			TEH	TEC	560UL	58			COLD
					NDD			TEH	TEC	560UC	69			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	25				NDD			TEH	TEC	560UL	59			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	26				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	27				NDD			TEH	TEC	560UL	59			COLD
5	28				RBD			TEH	TEC	560UL	58			COLD
					NDD			TEH	TEC	560UC	69			COLD
5	29				NDD			TEH	TEC	560UL	59			COLD
5	30				RBD			TEH	TEC	560UL	58			COLD
					NDD			TEH	TEC	560UC	69			COLD
5	31				NDD			TEH	TEC	560UL	59			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	32				NDD			TEH	TEC	560UL	59			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	33				NDD			TEH	TEC	560UL	59			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	34				RBD			TEH	TEC	560UL	58			COLD
					NDD			TEH	TEC	560UC	69			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	35				NDD			TEH	TEC	560UL	59			COLD
					NDD			TEH	TEC	560UL	59			COLD
5	36				RBD			TEH	TEC	560UL	58			COLD
					NDD			TEH	TEC	560UC	69			COLD
5	37				NDD			TEH	TEC	560UL	59			COLD
5	38				RBD			TEH	TEC	560UL	62			COLD
		4.45	186	1	DNG	03H	+19.44	TEH	TEC	560UC	69			COLD
5	39				NDD			TEH	TEC	560UL	62			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	40				NDD			TEH	TEC	560UL	62			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	41				NDD			TEH	TEC	560UL	62			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	42				NDD			TEH	TEC	560UL	62			COLD
					NDD			TSH	TSH	560PP	48			HOT
5	43				RBD			TEH	TEC	560UL	62			COLD
					NDD			TEH	TEC	560UC	69			COLD
5	44				NDD			TEH	TEC	560UL	105			COLD
5	45				NDD			TEH	TEC	560UL	105			COLD
5	46				NDD			TEH	TEC	560UL	97			COLD
5	47				NDD			TEH	TEC	560UL	99			COLD
					NDD			TSH	TSH	560PP	63			HOT
5	48				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UC	98			COLD
5	49				NDD			TEH	TEC	560UL	99			COLD
					NDD			TSH	TSH	560PP	63			HOT
5	50				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UC	98			COLD
5	51				NDD			TEH	TEC	560UL	99			COLD
5	52				NDD			TEH	TEC	560UC	98			COLD
5	53				NDD			TEH	TEC	560UL	99			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
5	54				NDD			TEH	TEC	560UC	98			COLD
5	55				NDD			TEH	TEC	560UL	99			COLD
					NDD			TSH	TSH	560PP	64			HOT
5	56				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UC	98			COLD
5	57				NDD			TEH	TEC	560UL	99			COLD
					NDD			TSH	TSH	560PP	64			HOT
5	58				NDD			TSH	TSH	560PP	65			HOT
					NDD			TEH	TEC	560UC	98			COLD
5	59				NDD			TEH	TEC	560UL	99			COLD
5	60				NDD			TEH	TEC	560UC	66			COLD
5	61				NDD			TEH	TEC	560UL	52			COLD
5	62	19.94		8	SLG		TSH	TEH	TEC	560UL	52			COLD
5	63				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	33			HOT
5	64				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	32			HOT
5	65				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	32			HOT
5	66				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	32			HOT
5	67				NDD			TEH	TEC	560UL	52			COLD
5	68				NDD			TEH	TEC	560UL	53			COLD
5	69				NDD			TEH	TEC	560UL	52			COLD
5	70				NDD			TEH	TEC	560UL	53			COLD
5	71	1.24		120	3		02C	TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	32			HOT
5	72				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	32			HOT
5	73				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	32			HOT
5	74				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	32			HOT
5	75				NDD			TEH	TEC	560UL	52			COLD
5	76				NDD			TEH	TEC	560UL	53			COLD
5	77	0.94		114	3		03C	TEH	TEC	560UL	56			COLD
					NDD			TEH	TSH	560PP	12			HOT
5	78				NDD			TEH	TEC	560UL	56			COLD
5	79				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	12			HOT
5	80				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	12			HOT
5	81				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	12			HOT
5	82				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	12			HOT
5	83				NDD			TEH	TEC	560UL	56			COLD
5	84				NDD			TEH	TEC	560UL	56			COLD
5	85				NDD			TEH	TEC	560UL	56			COLD
5	86				NDD			TEH	TEC	560UL	56			COLD
5	87				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	12			HOT
5	88				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	12			HOT
5	89				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	12			HOT
5	90	0.61		124	3		02H	TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	12			HOT
5	91				NDD			TEH	TEC	560UL	56			COLD
5	92				NDD			TEH	TEC	560UL	56			COLD
5	93				NDD			TEH	TEC	560UL	56			COLD
5	94				NDD			TEH	TEC	560UL	56			COLD
5	95				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	12			HOT
5	96				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	12			HOT
5	97				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	12			HOT
5	98				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	12			HOT
5	99				NDD			TEH	TEC	560UL	56			COLD
5	100				NDD			TEH	TEC	560UL	56			COLD
5	101				NDD			TEH	TEC	560UL	56			COLD
5	102				NDD			TEH	TEC	560UL	56			COLD
5	103				NDD			TSH	TSH	560PP	14			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
5	104				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560UL	56			COLD
5	105				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	14			HOT
5	106				NDD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560UL	56			COLD
5	107	0.74	113	3	NQH		02H +12.88	TEH	TEC	560UL	57			COLD
					INF		04H +22.90	TEH	TEC	560UL	57	HR		COLD
		0.68	121	3	INR		06H +20.20	TEH	TEC	560UL	57			COLD
5	108				NDD			TEH	TEC	560UL	56			COLD
5	109				NDD			TEH	TEC	560UL	57			COLD
5	110				NDD			TEH	TEC	560UL	56			COLD
5	111				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	14			HOT
5	112				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	14			HOT
5	113				NDD			TEH	TEC	560UL	103			COLD
					NDD			TSH	TSH	560PP	66			HOT
					RBD			TEH	TEC	560UC	75			COLD
5	114				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	66			HOT
5	115	3.74	184	1	DNG		TSC +2.78	TEH	TEC	560UL	103			COLD
					RBD			TEH	TEC	560UC	75			COLD
5	116				NDD			TEH	TEC	560UL	105			COLD
5	117				NDD			TEH	TEC	560UL	103			COLD
					RBD			TEH	TEC	560UC	75			COLD
5	118				NDD			TEH	TEC	560UL	105			COLD
5	119				NDD			TEH	TEC	560UL	103			COLD
					NDD			TSH	TSH	560PP	66			HOT
					RBD			TEH	TEC	560UC	75			COLD
5	120				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	66			HOT
5	121				NDD			TEH	TEC	560UL	103			COLD
					NDD			TSH	TSH	560PP	66			HOT
					RBD			TEH	TEC	560UC	75			COLD
5	122				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	65			HOT
6	1				NDD			TEH	TEC	560UL	56			COLD
6	2				NDD			TEH	TEC	560UL	56			COLD
6	3				NDD			TEH	TEC	560UL	57			COLD
6	4				NDD			TEH	TEC	560UL	57			COLD
6	5				RBD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	50			HOT
6	6				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	57			COLD
6	7				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	57			COLD
6	8				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	57			COLD
6	9				NDD			TEH	TEC	560UL	57			COLD
6	10				NDD			TEH	TEC	560UL	57			COLD
6	11				NDD			TEH	TEC	560UL	58			COLD
6	12				NDD			TEH	TEC	560UL	58			COLD
6	13				NDD			TEH	TEC	560UL	59			COLD
6	14				NDD			TEH	TEC	560UL	59			COLD
6	15				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	59			COLD
6	16				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	59			COLD
6	17				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	59			COLD
6	18				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	59			COLD
6	19				NDD			TEH	TEC	560UL	58			COLD
6	20				NDD			TEH	TEC	560UL	59			COLD
6	21				NDD			TEH	TEC	560UL	58			COLD
6	22				NDD			TEH	TEC	560UL	59			COLD
6	23				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	49			HOT
6	24				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	59			COLD
6	25				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	49			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
6	26				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	59			COLD
6	27				NDD			TEH	TEC	560UL	58			COLD
6	28				NDD			TEH	TEC	560UL	59			COLD
6	29				NDD			TEH	TEC	560UL	58			COLD
6	30				NDD			TEH	TEC	560UL	59			COLD
6	31				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	49			HOT
6	32				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	49			HOT
6	33				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	49			HOT
6	34				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	59			COLD
6	35				NDD			TEH	TEC	560UL	58			COLD
6	36				NDD			TEH	TEC	560UL	59			COLD
6	37				NDD			TEH	TEC	560UL	58			COLD
6	38				NDD			TEH	TEC	560UL	61			COLD
6	39				NDD			TEH	TEC	560UL	61			COLD
					NDD			TSH	TSH	560PP	49			HOT
6	40				NDD			TEH	TEC	560UL	61			COLD
					NDD			TSH	TSH	560PP	49			HOT
6	41				NDD			TEH	TEC	560UL	61			COLD
					NDD			TSH	TSH	560PP	49			HOT
6	42				NDD			TEH	TEC	560UL	61			COLD
					NDD			TSH	TSH	560PP	49			HOT
6	43				NDD			TEH	TEC	560UL	61			COLD
6	44				NDD			TEH	TEC	560UL	105			COLD
6	45				NDD			TEH	TEC	560UL	105			COLD
6	46				NDD			TEH	TEC	560UL	97			COLD
6	47				NDD			TEH	TEC	560UL	99			COLD
					NDD			TSH	TSH	560PP	63			HOT
6	48				NDD			TEH	TEC	560UL	99			COLD
					NDD			TSH	TSH	560PP	63			HOT
6	49				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UC	98			COLD
6	50				NDD			TEH	TEC	560UL	99			COLD
					NDD			TSH	TSH	560PP	63			HOT
6	51				NDD			TEH	TEC	560UC	98			COLD
6	52				NDD			TEH	TEC	560UL	99			COLD
6	53				NDD			TEH	TEC	560UC	98			COLD
6	54				NDD			TEH	TEC	560UL	99			COLD
6	55				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UC	98			COLD
6	56				NDD			TEH	TEC	560UL	99			COLD
					NDD			TSH	TSH	560PP	64			HOT
6	57				NDD			TSH	TSH	560PP	64			HOT
		15.84		8	SLG		TSC	TEH	TEC	560UC	98			COLD
6	58				NDD			TEH	TEC	560UL	99			COLD
					NDD			TSH	TSH	560PP	66			HOT
6	59				SLG		TSC	TEH	TEC	560UC	98			COLD
6	60				NDD			TEH	TEC	560UC	66			COLD
6	61				SLG		TSH	TEH	TEC	560UL	52			COLD
		20.45		8	SLG		TSC	TEH	TEC	560UL	52			COLD
6	62				SLG		TSH	TEH	TEC	560UL	53			COLD
		33.74		8	SLG		TSC	TEH	TEC	560UL	53			COLD
		18.85		8	SLG		TSC	TEH	TEC	560UL	53			COLD
6	63				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	33			HOT
6	64				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	32			HOT
6	65				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	33			HOT
6	66				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	33			HOT
6	67				NDD			TEH	TEC	560UL	52			COLD
6	68				NDD			TEH	TEC	560UL	53			COLD
6	69				NDD			TEH	TEC	560UL	52			COLD
6	70				DNG		TSC	TEH	TEC	560UL	53			COLD
		4.68		187	1			TEH	TEC	560UL	52			COLD
6	71				NDD			TSH	TSH	560PP	33			HOT
					NDD			TEH	TEC	560UL	53			COLD
6	72				NDD			TSH	TSH	560PP	33			HOT
					NDD			TEH	TEC	560UL	52			COLD
6	73				NDD			TSH	TSH	560PP	33			HOT
					NDD			TEH	TEC	560UL	53			COLD
6	74				NDD			TEH	TEC	560UL	53			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
6	75				NDD			TSH	TSH	560PP	33			HOT
					NDD			TEH	TEC	560UL	52			COLD
6	76				NDD			TEH	TEC	560UL	53			COLD
6	77				NDD			TEH	TEC	560UL	54			COLD
6	78				NDD			TEH	TEC	560UL	55			COLD
6	79				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
6	80				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
6	81				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
6	82				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
6	83				NDD			TEH	TEC	560UL	54			COLD
6	84				NDD			TEH	TEC	560UL	55			COLD
6	85				NDD			TEH	TEC	560UL	54			COLD
6	86				NDD			TEH	TEC	560UL	55			COLD
6	87				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
6	88				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
6	89				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
6	90				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
6	91				NDD			TEH	TEC	560UL	56			COLD
6	92				NDD			TEH	TEC	560UL	57			COLD
6	93				NDD			TEH	TEC	560UL	56			COLD
6	94				NDD			TEH	TEC	560UL	57			COLD
6	95				NDD			TSH	TSH	560PP	13			HOT
					NDD			TEH	TEC	560UL	56			COLD
6	96				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	13			HOT
6	97				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	13			HOT
6	98				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	13			HOT
6	99				NDD			TEH	TEC	560UL	56			COLD
6	100				NDD			TEH	TEC	560UL	57			COLD
6	101				NDD			TEH	TEC	560UL	56			COLD
6	102				NDD			TEH	TEC	560UL	57			COLD
6	103				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560UL	56			COLD
6	104				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	15			HOT
6	105				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560UL	56			COLD
6	106				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	15			HOT
6	107				NDD			TEH	TEC	560UL	56			COLD
6	108				NDD			TEH	TEC	560UL	57			COLD
6	109				NDD			TEH	TEC	560UL	56			COLD
6	110				NDD			TEH	TEC	560UL	57			COLD
6	111				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	15			HOT
6	112				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	15			HOT
6	113				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	66			HOT
					RBD			TEH	TEC	560UC	75			COLD
6	114				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	66			HOT
6	115				NDD			TEH	TEC	560UL	105			COLD
					RBD			TEH	TEC	560UC	75			COLD
6	116				NDD			TEH	TEC	560UL	105			COLD
					RBD			TEH	TEC	560UC	75			COLD
6	117				NDD			TEH	TEC	560UL	105			COLD
6	118				NDD			TEH	TEC	560UL	105			COLD
					RBD			TEH	TEC	560UC	75			COLD
6	119	3.80	185	1	DNG		02H +13.32	TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	66			HOT
					RBD			TEH	TEC	560UC	75			COLD
6	120				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	66			HOT
6	121				NDD			TEH	TEC	560UL	105			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		0.81	89	2	VOL		TSH +0.49							
					RBD			TSH	TSH	560PP	65			HOT
					NDD			TEH	TEC	560UC	75			COLD
6	122				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	65			HOT
7	2				NDD			TEH	TEC	560UL	57			COLD
7	3				NDD			TEH	TEC	560UL	56			COLD
7	4				NDD			TEH	TEC	560UL	56			COLD
7	5				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	56			COLD
7	6				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	44			HOT
7	7				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	44			HOT
7	8				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	44			HOT
7	9				NDD			TEH	TEC	560UL	56			COLD
7	10				NDD			TEH	TEC	560UL	56			COLD
7	11				NDD			TEH	TEC	560DT	32			COLD
7	12				NDD			TEH	TEC	560UL	59			COLD
7	13				NDD			TEH	TEC	560UL	58			COLD
7	14				NDD			TEH	TEC	560UL	58			COLD
7	15				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	16				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	17				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	18				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	19				NDD			TEH	TEC	560UL	58			COLD
7	20				NDD			TEH	TEC	560UL	58			COLD
7	21				NDD			TEH	TEC	560UL	58			COLD
7	22				NDD			TEH	TEC	560UL	58			COLD
7	23				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	24				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	25				NDD			TEH	TEC	560UL	59			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	26				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	27				NDD			TEH	TEC	560UL	59			COLD
7	28				NDD			TEH	TSH	560PP	46			HOT
					NDD			TEH	TEC	560UL	58			COLD
7	29				NDD			TEH	TEC	560UL	59			COLD
7	30				NDD			TEH	TEC	560UL	58			COLD
7	31				NDD			TEH	TEC	560UC	69			COLD
					RBD			TEH	TEC	560UL	59			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	32				NDD			TEH	TEC	560UL	59			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	33				NDD			TEH	TEC	560UL	59			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	34				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	35				NDD			TEH	TEC	560UL	58			COLD
7	36				NDD			TEH	TEC	560UL	58			COLD
7	37				NDD			TEH	TEC	560UL	59			COLD
7	38				NDD			TEH	TEC	560UL	62			COLD
7	39				NDD			TEH	TEC	560UL	62			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	40				NDD			TEH	TEC	560UL	62			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	41				NDD			TEH	TEC	560UL	62			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	42				NDD			TEH	TEC	560UL	62			COLD
					NDD			TSH	TSH	560PP	48			HOT
7	43				NDD			TEH	TEC	560UL	61			COLD
7	44				NDD			TEH	TEC	560UL	105			COLD
7	45				NDD			TEH	TEC	560UL	105			COLD
7	46				NDD			TEH	TEC	560UL	97			COLD
7	47				NDD			TEH	TEC	560UL	99	IDOK		COLD
					NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UC	98			COLD
7	48				NDD			TSH	TSH	560PP	63			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
7	49				NDD			TEH	TEC	560UC	98			COLD
					NDD			TEH	TEC	560UL	99			COLD
					NDD			TSH	TSH	560PP	63			HOT
7	50				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UC	98			COLD
7	51				NDD			TEH	TEC	560UL	99			COLD
7	52				NDD			TEH	TEC	560UC	98			COLD
7	53				NDD			TEH	TEC	560UL	99			COLD
7	54	6.62	184	1	DNG	08H	+2.77	TEH	TEC	560UC	98			COLD
7	55				NDD			TEH	TEC	560UL	99			COLD
					NDD			TSH	TSH	560PP	64			HOT
7	56				NDD			TSH	TSH	560PP	64			HOT
		31.40		8	SLG	TSC	+0.67	TEH	TEC	560UC	98			COLD
7	57	22.55		8	SLG	TSC	+0.56	TEH	TEC	560UL	99			COLD
					NDD			TSH	TSH	560PP	64			HOT
7	58				NDD			TSH	TSH	560PP	65			HOT
		18.05		8	SLG	TSC	+0.48	TEH	TEC	560UC	98			COLD
7	59	17.22		8	SLG	TSC	+0.48	TEH	TEC	560UC	98			COLD
7	60	17.93		8	SLG	TSC	+0.68	TEH	TEC	560UC	66			COLD
7	61	19.50		8	SLG	TSH	+0.80	TEH	TEC	560UL	52			COLD
		23.78		8	SLG	TSC	+0.73	TEH	TEC	560UL	52			COLD
7	62				NDD			TEH	TEC	560UL	52			COLD
7	63	16.69		8	SLG	TSH	+0.67	TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	33			HOT
7	64				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	32			HOT
7	65				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	32			HOT
7	66				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	32			HOT
7	67				NDD			TEH	TEC	560UL	52			COLD
7	68				NDD			TEH	TEC	560UL	53			COLD
7	69				NDD			TEH	TEC	560UL	52			COLD
7	70				NDD			TEH	TEC	560UL	53			COLD
7	71				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	32			HOT
7	72				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	32			HOT
7	73				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	32			HOT
7	74				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	32			HOT
7	75				NDD			TEH	TEC	560UL	52			COLD
7	76				NDD			TEH	TEC	560UL	53			COLD
7	77				NDD			TEH	TEC	560UL	54			COLD
7	78				NDD			TEH	TEC	560UL	54			COLD
7	79				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
7	80				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
7	81				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
7	82				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
7	83				NDD			TEH	TEC	560UL	55			COLD
7	84				NDD			TEH	TEC	560UL	54			COLD
7	85				NDD			TEH	TEC	560UL	55			COLD
7	86	0.64	107	3	INR	TSC	+34.17	TEH	TEC	560UL	54			COLD
7	87				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
7	88				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
7	89				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
7	90				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
7	91				NDD			TEH	TEC	560UL	55			COLD
7	92				NDD			TEH	TEC	560UL	54			COLD
7	93				NDD			TEH	TEC	560UL	55			COLD
7	94				NDD			TEH	TEC	560UL	54			COLD
7	95				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
7	96				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
7	97				NDD			TEH	TEC	560UL	55			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
7	98				NDD			TSH	TSH	560PP	12			HOT
					NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
7	99				NDD			TEH	TEC	560UL	55			COLD
7	100				NDD			TEH	TEC	560UL	54			COLD
7	101				NDD			TEH	TEC	560UL	55			COLD
7	102				NDD			TEH	TEC	560UL	54			COLD
7	103				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	14			HOT
7	104				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	14			HOT
7	105				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	14			HOT
7	106				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	14			HOT
7	107				NDD			TEH	TEC	560UL	55			COLD
7	108	0.74		103	3	INR	06C +35.67	TEH	TEC	560UL	54			COLD
7	109				NDD			TEH	TEC	560UL	55			COLD
7	110				NDD			TEH	TEC	560UL	54			COLD
7	111				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	14			HOT
7	112				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	14			HOT
7	113				NDD			TEH	TEC	560UL	103			COLD
					NDD			TSH	TSH	560PP	66			HOT
					RBD			TEH	TEC	560UC	75			COLD
7	114				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	101			COLD
7	115				NDD			TEH	TEC	560UL	103			COLD
					RBD			TEH	TEC	560UC	75			COLD
7	116				NDD			TEH	TEC	560UL	103			COLD
					NDD			TEH	TEC	560UL	102			COLD
7	117				NDD			TEH	TEC	560UL	105			COLD
					RBD			TEH	TEC	560UC	75			COLD
7	118				NDD			TEH	TEC	560UL	105			COLD
7	119				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	66			HOT
					RBD			TEH	TEC	560UC	75			COLD
7	120				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	66			HOT
7	121				NDD			TEH	TEC	560UL	105			COLD
					NDD			TSH	TSH	560PP	66			HOT
8	2				NDD			TEH	TEC	560UL	56			COLD
8	3				NDD			TEH	TEC	560UL	56			COLD
8	4				NDD			TEH	TEC	560UL	57			COLD
8	5				RBD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	50			HOT
8	6				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	57			COLD
8	7				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	57			COLD
8	8				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	57			COLD
8	9				NDD			TEH	TEC	560UL	57			COLD
8	10				NDD			TEH	TEC	560UL	57			COLD
8	11				NDD			TEH	TEC	560DT	32			COLD
8	12				NDD			TEH	TEC	560UL	58			COLD
8	13				NDD			TEH	TEC	560UL	58			COLD
8	14				NDD			TEH	TSH	560PP	46			HOT
					NDD			TEH	TEC	560UL	59			COLD
8	15				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	59			COLD
8	16				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	59			COLD
8	17				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	59			COLD
8	18				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
8	19				NDD			TEH	TEC	560DT	31			COLD
8	20				NDD			TEH	TEC	560DT	31			COLD
8	21				NDD			TEH	TEC	560DT	31			COLD
8	22				NDD			TEH	TEC	560DT	31			COLD
8	23				NDD			TSH	TSH	560PP	49			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
8	24				NDD			TEH	TEC	560DT	31			COLD
					NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
8	25				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	49			HOT
8	26				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	59			COLD
8	27				NDD			TEH	TSH	560PP	46			HOT
					NDD			TEH	TEC	560UL	58			COLD
8	28				NDD			TEH	TEC	560UL	59			COLD
8	29				NDD			TEH	TEC	560UL	58			COLD
8	30				NDD			TEH	TEC	560UL	59			COLD
8	31				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	49			HOT
8	32				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	49			HOT
8	33				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	49			HOT
8	34				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560UL	59			COLD
8	35				NDD			TEH	TEC	560DT	33			COLD
8	36				NDD			TEH	TEC	560DT	33			COLD
8	37				NDD			TEH	TEC	560UL	58			COLD
8	38				NDD			TEH	TEC	560UL	61			COLD
8	39				NDD			TEH	TEC	560UL	61			COLD
					NDD			TSH	TSH	560PP	49			HOT
8	40				NDD			TEH	TEC	560UL	61			COLD
					NDD			TSH	TSH	560PP	49			HOT
8	41				NDD			TEH	TEC	560UL	61			COLD
					NDD			TSH	TSH	560PP	49			HOT
8	42				NDD			TEH	TEC	560UL	61			COLD
					NDD			TSH	TSH	560PP	49			HOT
8	43				NDD			TEH	TEC	560UL	61			COLD
8	44				NDD			TEH	TEC	560UL	105			COLD
8	45				NDD			TEH	TEC	560UL	105			COLD
8	46				NDD			TEH	TEC	560UL	97			COLD
8	47				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
8	48				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
8	49				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UC	98			COLD
8	50				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
8	51				NDD			TEH	TEC	560UC	98			COLD
8	52				NDD			TEH	TEC	560UL	97			COLD
8	53				NDD			TEH	TEC	560UC	98			COLD
8	54	0.72	94	3	INR		TSH	TEH	TEC	560UL	97			COLD
8	55				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UC	98			COLD
8	56				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UL	97			COLD
8	57				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UC	98			COLD
8	58				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UL	97			COLD
8	59				NDD			TEH	TEC	560UC	98			COLD
8	60				NDD			TEH	TEC	560UC	66			COLD
8	61	32.60		8	SLG		TSH	TEH	TEC	560UL	52			COLD
		19.38		8	SLG		TSC	TEH	TEC	560UL	52			COLD
8	62				NDD			TEH	TEC	560UL	53			COLD
8	63	22.05		8	SLG		TSH	TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	33			HOT
8	64				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	32			HOT
8	65				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	33			HOT
8	66				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	33			HOT
8	67				NDD			TEH	TEC	560UL	52			COLD
8	68				NDD			TEH	TEC	560UL	53			COLD
8	69				NDD			TEH	TEC	560UL	52			COLD
8	70				NDD			TEH	TEC	560UL	53			COLD
8	71				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	33			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
8	72				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	33			HOT
8	73				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	33			HOT
8	74				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	33			HOT
8	75				NDD			TEH	TEC	560UL	52			COLD
8	76				NDD			TEH	TEC	560UL	53			COLD
8	77				NDD			TEH	TEC	560UL	54			COLD
8	78				NDD			TEH	TEC	560UL	55			COLD
8	79				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
8	80				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
8	81				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
8	82				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
8	83				NDD			TEH	TEC	560UL	54			COLD
8	84				NDD			TEH	TEC	560UL	55			COLD
8	85				NDD			TEH	TEC	560UL	54			COLD
8	86				NDD			TEH	TEC	560UL	55			COLD
8	87				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
8	88				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
8	89				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
8	90				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
8	91				NDD			TEH	TEC	560UL	54			COLD
8	92				NDD			TEH	TEC	560UL	55			COLD
8	93	0.56	121	3	INR	02H	+13.50	TEH	TEC	560UL	54			COLD
8	94				NDD			TEH	TEC	560UL	55			COLD
8	95				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
8	96				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
8	97				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
8	98				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
8	99				NDD			TEH	TEC	560UL	54			COLD
8	100	16.97		8	SLG	07H	+1.16	TEH	TEC	560UL	55			COLD
8	101				NDD			TEH	TEC	560UL	54			COLD
8	102				NDD			TEH	TEC	560UL	55			COLD
8	103	5.23	179	1	INR	08H	+3.07	TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	15			HOT
8	104	18.75		8	SLG	07H	+1.32	TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	15			HOT
8	105				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	15			HOT
8	106	6.80	178	1	DNG	08H	+3.20	TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	15			HOT
8	107				NDD			TEH	TEC	560UL	54			COLD
8	108				NDD			TEH	TEC	560UL	55			COLD
8	109				NDD			TEH	TEC	560UL	54			COLD
8	110				NDD			TEH	TEC	560UL	55			COLD
8	111				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	15			HOT
8	112				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	15			HOT
8	113				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	75			COLD
8	114				NDD			TSH	TSH	560PP	66			HOT
					RND			TEH	TEC	560UC	75			COLD
					NDD			TEH	TEC	560UL	102			COLD
8	115				NDD			TEH	TEC	560UC	75			COLD
8	116				NDD			TEH	TEC	560UC	75			COLD
8	117				NDD			TEH	TEC	560UC	75			COLD
8	118				NDD			TEH	TEC	560UC	75			COLD
8	119				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	75			COLD
8	120				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	75			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
8	121				NDD			TSH	TSH	560PP	65			HOT
					NDD			TEH	TEC	560UC	75			COLD
9	2				NDD			TEH	TEC	560DT	31			COLD
9	3				NDD			TEH	TEC	560UL	56			COLD
9	4				NDD			TEH	TEC	560UL	56			COLD
9	5				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	56			COLD
9	6				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	44			HOT
9	7				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	44			HOT
9	8				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	44			HOT
9	9	0.60	123	3	INR		02C	TEH	TEC	560UL	56			COLD
9	10				NDD			TEH	TEC	560UL	56			COLD
9	11				NDD			TEH	TEC	560DT	32			COLD
9	12				NDD			TEH	TEC	560DT	32			COLD
9	13				NDD			TEH	TEC	560UL	58			COLD
9	14				NDD			TEH	TEC	560UL	58			COLD
9	15				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
9	16				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
9	17				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
9	18				NDD			TSH	TSH	560PP	48			HOT
		18.10		8	SLG		TSH	TEH	TEC	560DT	30			COLD
		17.40		8	SLG		TSC	TEH	TEC	560DT	30			COLD
9	19	17.15		8	SLG		TSH	TEH	TEC	560DT	30			COLD
		17.35		8	SLG		TSC	TEH	TEC	560DT	30			COLD
9	20	18.29		8	SLG		TSH	TEH	TEC	560DT	30			COLD
		17.17		8	SLG		TSC	TEH	TEC	560DT	30			COLD
9	21	15.48		8	SLG		TSH	TEH	TEC	560DT	30			COLD
		15.90		8	SLG		TSC	TEH	TEC	560DT	30			COLD
9	22	18.50		8	SLG		TSH	TEH	TEC	560DT	30			COLD
9	23				NDD			TSH	TSH	560PP	48			HOT
		17.10		8	SLG		TSH	TEH	TEC	560DT	30			COLD
9	24				NDD			TSH	TSH	560PP	48			HOT
		16.69		8	SLG		TSH	TEH	TEC	560DT	30			COLD
		15.82		8	SLG		TSC	TEH	TEC	560DT	30			COLD
9	25				NDD			TEH	TEC	560DT	32			COLD
					NDD			TSH	TSH	560PP	48			HOT
9	26				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
9	27				NDD			TEH	TEC	560UL	58			COLD
9	28	0.91	121	3	INR		04H	TEH	TEC	560UL	58			COLD
9	29				NDD			TEH	TEC	560UL	58			COLD
9	30				NDD			TEH	TEC	560UL	58			COLD
9	31				NDD			TEH	TEC	560DT	32			COLD
					NDD			TSH	TSH	560PP	48			HOT
9	32				NDD			TEH	TSH	560PP	46			HOT
					NDD			TEH	TEC	560DT	32			COLD
9	33				NDD			TEH	TEC	560UL	58			COLD
					RBD			TEH	TEC	560DT	32			COLD
					NDD			TSH	TSH	560PP	48			HOT
9	34				NDD			TEH	TEC	560UL	58			COLD
					NDD			TSH	TSH	560PP	48			HOT
9	35				NDD			TEH	TEC	560DT	32			COLD
9	36	0.52	9	3	INR		02H	TEH	TEC	560DT	32			COLD
9	37				NDD			TEH	TEC	560DT	32			COLD
9	38				NDD			TEH	TEC	560DT	33			COLD
9	39				NDD			TEH	TEC	560DT	32			COLD
					NDD			TSH	TSH	560PP	48			HOT
9	40				NDD			TEH	TEC	560DT	33			COLD
					NDD			TSH	TSH	560PP	48			HOT
9	41				NDD			TEH	TEC	560DT	32			COLD
					NDD			TSH	TSH	560PP	48			HOT
9	42				NDD			TEH	TEC	560DT	33			COLD
					NDD			TSH	TSH	560PP	48			HOT
9	43				NDD			TEH	TEC	560UL	105			COLD
9	44				NDD			TEH	TEC	560UL	105			COLD
9	45				NDD			TEH	TEC	560UL	105			COLD
9	46				NDD			TEH	TEC	560UL	97			COLD
9	47				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
9	48				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UC	98			COLD
9	49				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
9	50				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UC	98			COLD
9	51				NDD			TEH	TEC	560UL	97			COLD
9	52				NDD			TEH	TEC	560UC	98			COLD
9	53				NDD			TEH	TEC	560UL	97			COLD
9	54				NDD			TEH	TEC	560UC	98			COLD
9	55				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UL	97			COLD
9	56				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UC	98			COLD
9	57				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UL	97			COLD
9	58				NDD			TSH	TSH	560PP	65			HOT
					NDD			TEH	TEC	560UC	98			COLD
9	59				NDD			TEH	TEC	560UC	98			COLD
9	60				NDD			TEH	TEC	560UC	66			COLD
9	61	36.69		8	SLG		TSH	TEH	TEC	560UL	52			COLD
9	62	38.42		8	SLG		TSH	TEH	TEC	560UL	52			COLD
9	63				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	33			HOT
9	64				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	51			HOT
					RBD			TSH	TSH	560PP	32			HOT
9	65				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	32			HOT
9	66				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	32			HOT
9	67	1.12	93	3	NQH		08H	TEH	TEC	560UL	52			COLD
9	68				NDD			TEH	TEC	560UL	53			COLD
9	69				NDD			TEH	TEC	560UL	52			COLD
9	70				NDD			TEH	TEC	560UL	53			COLD
9	71				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	32			HOT
9	72				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	32			HOT
9	73				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	32			HOT
9	74				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	32			HOT
9	75				NDD			TEH	TEC	560UL	52			COLD
9	76				NDD			TEH	TEC	560UL	53			COLD
9	77				NDD			TEH	TEC	560UL	54			COLD
9	78				NDD			TEH	TEC	560UL	54			COLD
9	79				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
9	80				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
9	81				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
9	82				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	12			HOT
9	83				NDD			TEH	TEC	560UL	53			COLD
9	84				NDD			TEH	TEC	560UL	52			COLD
9	85				NDD			TEH	TEC	560UL	53			COLD
9	86				NDD			TEH	TEC	560UL	52			COLD
9	87				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
9	88				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	12			HOT
9	89				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
9	90				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	12			HOT
9	91				NDD			TEH	TEC	560UL	53			COLD
					NDD			TEH	TSH	560PP	12			HOT
9	92				NDD			TEH	TEC	560UL	54			COLD
9	93				NDD			TEH	TEC	560UL	55			COLD
9	94				NDD			TEH	TEC	560UL	54			COLD
9	95				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
9	96				NDD			TEH	TEC	560UL	54			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
9	97				NDD			TSH	TSH	560PP	12			HOT
					NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
9	98				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
9	99				NDD			TEH	TEC	560UL	55			COLD
9	100				NDD			TEH	TEC	560UL	54			COLD
9	101				NDD			TEH	TEC	560UL	55			COLD
9	102				NDD			TEH	TEC	560UL	54			COLD
9	103				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	14			HOT
9	104				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	14			HOT
9	105				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	14			HOT
9	106				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	14			HOT
9	107				NDD			TEH	TEC	560UL	55			COLD
9	108				NDD			TEH	TEC	560UL	54			COLD
9	109				NDD			TEH	TEC	560UL	55			COLD
9	110	6.86	175	1	DNG	08H	+3.36	TEH	TEC	560UL	54			COLD
9	111				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	14			HOT
9	112				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	14			HOT
9	113				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	101			COLD
					RBD			TEH	TEC	560UC	75			COLD
9	114				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	101			COLD
9	115				NDD			TEH	TEC	560UC	101			COLD
					RBD			TEH	TEC	560UC	75			COLD
9	116				NDD			TEH	TEC	560UC	101			COLD
9	117				NDD			TEH	TEC	560UC	101			COLD
					RBD			TEH	TEC	560UC	75			COLD
9	118				NDD			TEH	TEC	560UC	101			COLD
9	119				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	101			COLD
					RBD			TEH	TEC	560UC	75			COLD
9	120				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	101			COLD
9	121				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	75			COLD
10	2				NDD			TEH	TEC	560DT	30			COLD
10	3				NDD			TEH	TEC	560DT	31			COLD
10	4				NDD			TEH	TEC	560DT	31			COLD
10	5				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560DT	31			COLD
10	6				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560DT	31			COLD
10	7				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	56			COLD
					RIC			TSH	TEC	560DT	31			COLD
10	8				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560DT	31			COLD
10	9				NDD			TEH	TEC	560DT	31			COLD
10	10				NDD			TEH	TEC	560DT	31			COLD
10	11				NDD			TEH	TEC	560DT	31			COLD
10	12				NDD			TEH	TEC	560UL	58			COLD
					RIC			TSH	TEC	560DT	31			COLD
10	13				NDD			TEH	TEC	560DT	31			COLD
10	14				NDD			TEH	TEC	560DT	31			COLD
10	15				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
10	16				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
10	17				NDD			TSH	TSH	560PP	49			HOT
		1.00	124	3	INR	02H	+16.66	TEH	TEC	560DT	31			COLD
		19.38		8	SLG	TSH	+0.78	TEH	TEC	560DT	31			COLD
		17.99		8	SLG	TSC	+0.58	TEH	TEC	560DT	31			COLD
10	18				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
10	19				NDD			TEH	TEC	560DT	31			COLD
10	20				NDD			TEH	TEC	560DT	31			COLD
10	21				NDD			TEH	TEC	560DT	31			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
10	22				NDD			TEH	TEC	560DT	31			COLD
10	23				NDD			TSH	TSH	560PP	49			HOT
		2.25	83	6	INR		04C	TEH	TEC	560DT	31			COLD
		17.56		8	SLG		TSH	TEH	TEC	560DT	31			COLD
		16.01		8	SLG		TSC	TEH	TEC	560DT	31			COLD
10	24				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
10	25				NDD			TSH	TSH	560PP	49			HOT
		22.69		8	SLG		TSH	TEH	TEC	560DT	33			COLD
		18.88		8	SLG		TSC	TEH	TEC	560DT	33			COLD
10	26				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	32			COLD
10	27	15.07			SLG		TSH	TEH	TEC	560DT	33			COLD
10	28				NDD			TEH	TEC	560DT	33			COLD
10	29				NDD			TEH	TEC	560DT	33			COLD
10	30				NDD			TEH	TEC	560DT	33			COLD
10	33				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	33			COLD
10	34				NDD			TSH	TSH	560PP	49			HOT
		0.78		104	NQH		04C	TEH	TEC	560DT	32			COLD
		0.71		103	NQH		04C	TEH	TEC	560DT	32			COLD
10	35				NDD			TEH	TEC	560DT	33			COLD
10	36				NDD			TEH	TEC	560DT	33			COLD
10	37				NDD			TEH	TEC	560DT	33			COLD
10	38				NDD			TEH	TEC	560DT	32			COLD
10	39				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	33			COLD
10	40				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	32			COLD
10	41	3.86		177	DNG		02H	TSH	TSH	560PP	49			HOT
10	42				NDD			TEH	TEC	560DT	33			COLD
		0.90		121	INR		03C	TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	32			COLD
10	43				NDD			TEH	TEC	560UL	105			COLD
10	44				NDD			TEH	TEC	560UL	105			COLD
10	45				NDD			TEH	TEC	560UL	105			COLD
10	46				NDD			TEH	TEC	560UL	97			COLD
10	47				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
10	48				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
10	49				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UC	98			COLD
10	50				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
10	51				NDD			TEH	TEC	560UC	98			COLD
10	52				NDD			TEH	TEC	560UL	97			COLD
10	53				NDD			TEH	TEC	560UC	98			COLD
10	54				NDD			TEH	TEC	560UL	97			COLD
10	55				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UC	98			COLD
10	56				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UL	97			COLD
10	57				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UC	98			COLD
10	58				NDD			TSH	TSH	560PP	66			HOT
		5.06		187	DNG		05C	TEH	TEC	560UL	97			COLD
10	59				NDD			TEH	TEC	560UC	98			COLD
10	60				NDD			TEH	TEC	560UC	66			COLD
10	61	40.56		8	SLG		TSH	TEH	TEC	560UL	50			COLD
		20.98		8	SLG		TSC	TEH	TEC	560UL	50			COLD
10	62	42.94		8	SLG		TSH	TEH	TEC	560UL	51			COLD
		16.05		8	SLG		TSC	TEH	TEC	560UL	51			COLD
		0.30		105	INR		TSH	TEH	TEC	560UL	51			COLD
10	63	26.89		8	SLG		TSH	TEH	TEC	560UL	50			COLD
					INF		AV6	TEH	TEC	560UL	50	HR		COLD
					NDD			TSH	TSH	560PP	33			HOT
10	64				NDD			TEH	TEC	560UC	68			COLD
					RBD			TEH	TEC	560UL	51			COLD
					NDD			TSH	TSH	560PP	32			HOT
10	65				NDD			TEH	TEC	560UL	50			COLD
					NDD			TSH	TSH	560PP	33			HOT
10	66				NDD			TEH	TEC	560UC	68			COLD
					RBD			TEH	TEC	560UL	51			COLD
					NDD			TSH	TSH	560PP	33			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
10	67				NDD			TEH	TEC	560UL	50			COLD
10	68				NDD			TEH	TEC	560UC	68			COLD
					RBD			TEH	TEC	560UL	51			COLD
10	69				NDD			TEH	TEC	560UL	50			COLD
10	70				NDD			TEH	TEC	560UC	68			COLD
					RBD			TEH	TEC	560UL	51			COLD
10	71				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	33			HOT
10	72				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	33			HOT
10	73				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	33			HOT
10	74	0.16	200	3	INR		TSH	+0.39	TEH	TEC	560UL	53		COLD
					NDD			TSH	TSH	560PP	33			HOT
10	75				NDD			TEH	TEC	560UL	52			COLD
10	76	0.66	114	3	NQH		05C	+25.18	TEH	TEC	560UL	53		COLD
10	77				NDD			TEH	TEC	560UL	54			COLD
10	78				NDD			TEH	TEC	560UL	55			COLD
10	79				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
10	80				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
10	81				RBD			TEH	TEC	560UL	54			COLD
					NDD			TEH	TEC	560UC	68			COLD
					NDD			TSH	TSH	560PP	13			HOT
10	82				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
10	83				NDD			TEH	TEC	560UL	54			COLD
10	84				NDD			TEH	TEC	560UL	55			COLD
10	85				NDD			TEH	TEC	560UL	54			COLD
10	86				NDD			TEH	TEC	560UL	55			COLD
10	87				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
10	88				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
10	89				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
10	90				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
10	93				NDD			TEH	TEC	560UL	54			COLD
10	94				NDD			TEH	TEC	560UL	55			COLD
10	95				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
10	96				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
10	97				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
10	98	0.44	114	3	NQH		02C	+10.00	TEH	TEC	560UL	55		COLD
					NDD			TSH	TSH	560PP	13			HOT
10	99				NDD			TEH	TEC	560UL	54			COLD
10	100				NDD			TEH	TEC	560UL	55			COLD
10	101				NDD			TEH	TEC	560UL	54			COLD
10	102	3.83	12	1	INR		07C	+3.74	TEH	TEC	560UL	55		COLD
10	103				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	15			HOT
10	104				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	15			HOT
10	105				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	15			HOT
10	106				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	15			HOT
10	107				NDD			TEH	TEC	560UL	54			COLD
10	108				NDD			TEH	TEC	560UL	55			COLD
10	109				NDD			TEH	TEC	560UL	54			COLD
10	110				NDD			TEH	TEC	560UL	55			COLD
10	111				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	15			HOT
10	112				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	15			HOT
10	113				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	75			COLD
10	114				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	75			COLD
10	115				NDD			TEH	TEC	560UC	101			COLD
10	116				NDD			TEH	TEC	560UC	75			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
10	117				NDD			TEH	TEC	560UC	101			COLD
10	118	0.77	115	3	INR		03C +10.10	TEH	TEC	560UC	75			COLD
10	119				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	101			COLD
10	120				NDD			TEH	TEC	560UC	75			COLD
					NDD			TSH	TSH	560PP	66			HOT
10	121				NDD			TSH	TSH	560PP	65			HOT
					NDD			TEH	TEC	560UC	101			COLD
11	2				NDD			TEH	TEC	560DT	31			COLD
11	3				NDD			TEH	TEC	560DT	30			COLD
11	4				NDD			TEH	TEC	560DT	30			COLD
11	5				NDD			TSH	TSH	560PP	45			HOT
	17.35		8		SLG		TSC +0.52	TEH	TEC	560DT	30			COLD
11	6				NDD			TSH	TSH	560PP	44			HOT
	17.19		8		SLG		TSC +0.52	TEH	TEC	560DT	30			COLD
11	7				NDD			TSH	TSH	560PP	44			HOT
	16.19		8		SLG		TSH +0.48	TEH	TEC	560DT	30			COLD
	16.88		8		SLG		TSC +0.52	TEH	TEC	560DT	30			COLD
11	8				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	44			HOT
					RIC			TSH	TEC	560DT	30			COLD
11	9	17.69		8	SLG		TSH +0.57	TEH	TEC	560DT	30			COLD
	16.96		8		SLG		TSC +0.52	TEH	TEC	560DT	30			COLD
11	10	19.62		8	SLG		TSH +0.61	TEH	TEC	560DT	30			COLD
	16.34		8		SLG		TSC +0.50	TEH	TEC	560DT	30			COLD
11	11	18.06		8	SLG		TSH +0.60	TEH	TEC	560DT	30			COLD
	15.48		8		SLG		TSC +0.46	TEH	TEC	560DT	30			COLD
11	12	17.56		8	SLG		TSH +0.57	TEH	TEC	560DT	30			COLD
11	13	18.12		8	SLG		TSH +0.60	TEH	TEC	560DT	30			COLD
11	14	3.04	13	1	INR		08H +2.55	TEH	TEC	560DT	30			COLD
	18.35		8		SLG		TSH +0.90	TEH	TEC	560DT	30			COLD
11	15				NDD			TSH	TSH	560PP	48			HOT
	16.96		8		SLG		TSH +0.55	TEH	TEC	560DT	30			COLD
11	16				NDD			TSH	TSH	560PP	48			HOT
	18.10		8		SLG		TSH +0.63	TEH	TEC	560DT	30			COLD
	15.55		8		SLG		TSC +0.46	TEH	TEC	560DT	30			COLD
11	17				NDD			TSH	TSH	560PP	48			HOT
	16.86		8		SLG		TSH +0.59	TEH	TEC	560DT	30			COLD
	17.08		8		SLG		TSC +0.52	TEH	TEC	560DT	30			COLD
11	18				NDD			TSH	TSH	560PP	48			HOT
	17.02		8		SLG		TSH +0.57	TEH	TEC	560DT	30			COLD
	16.75		8		SLG		TSC +0.52	TEH	TEC	560DT	30			COLD
11	19	18.04		8	SLG		TSH +0.63	TEH	TEC	560DT	30			COLD
	16.92		8		SLG		TSC +0.53	TEH	TEC	560DT	30			COLD
11	20	17.06		8	SLG		TSH +0.60	TEH	TEC	560DT	30			COLD
	16.50		8		SLG		TSC +0.52	TEH	TEC	560DT	30			COLD
11	21	17.06		8	SLG		TSH +0.57	TEH	TEC	560DT	30			COLD
	16.65		8		SLG		TSC +0.52	TEH	TEC	560DT	30			COLD
11	22	18.58		8	SLG		TSH +0.63	TEH	TEC	560DT	30			COLD
	16.98		8		SLG		TSC +0.54	TEH	TEC	560DT	30			COLD
11	23				NDD			TSH	TSH	560PP	48			HOT
	17.33		8		SLG		TSH +0.62	TEH	TEC	560DT	30			COLD
11	24				NDD			TSH	TSH	560PP	48			HOT
	16.69		8		SLG		TSH +0.59	TEH	TEC	560DT	30			COLD
	15.23		8		SLG		TSC +0.45	TEH	TEC	560DT	30			COLD
11	25				NDD			TEH	TEC	560DT	32			COLD
					NDD			TSH	TSH	560PP	48			HOT
11	26	17.18		8	SLG		TSH +0.48	TEH	TEC	560DT	33			COLD
	15.69		8		SLG		TSC +0.46	TEH	TEC	560DT	33			COLD
					NDD			TSH	TSH	560PP	48			HOT
11	27				NDD			TEH	TEC	560DT	32			COLD
11	28				NDD			TEH	TEC	560DT	32			COLD
11	29				NDD			TEH	TEC	560DT	32			COLD
11	30				NDD			TEH	TEC	560DT	32			COLD
11	33	6.69	179	1	DNG		08H +9.22	TEH	TEC	560DT	32			COLD
					NDD			TSH	TSH	560PP	48			HOT
11	34				NDD			TEH	TEC	560DT	33			COLD
					NDD			TSH	TSH	560PP	48			HOT
11	35	8.06	180	1	DNG		08H +9.06	TEH	TEC	560DT	32			COLD
11	36	7.84	179	1	DNG		08H +9.12	TEH	TEC	560DT	32			COLD
11	37	7.75	179	1	DNG		08H +9.20	TEH	TEC	560DT	32			COLD
11	38	6.70	182	1	DNG		08H +9.28	TEH	TEC	560DT	33			COLD
11	39	6.39	180	1	DNG		08H +9.26	TEH	TEC	560DT	32			COLD
					NDD			TSH	TSH	560PP	48			HOT
11	40				NDD			TEH	TEC	560DT	33			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					NDD			TSH	TSH	560PP	48			HOT
11	41	7.27	178	1	DNG		08H	TEH	TEC	560DT	32			COLD
					NDD			TSH	TSH	560PP	48			HOT
11	42				NDD			TEH	TEC	560DT	33			COLD
					NDD			TSH	TSH	560PP	48			HOT
11	43	6.84	181	1	DNG		08H	TEH	TEC	560UL	105			COLD
11	44	7.46	181	1	DNG		08H	TEH	TEC	560UL	105			COLD
11	45	7.63	182	1	DNG		08H	TEH	TEC	560UL	105			COLD
11	46	6.87	186	1	DNG		08H	TEH	TEC	560UL	97			COLD
11	47			3	NDF		TSH	TSH	01H	560PP	81			HOT
					NDD			TSH	TSH	560PP	63			HOT
		4.70	188	1	DNG		TSH	TEH	TEC	560UL	97			COLD
		6.08	187	1	DNG		08H	TEH	TEC	560UL	97			COLD
11	48				NDD			TSH	TSH	560PP	63			HOT
		6.62	184	1	DNG		08H	TEH	TEC	560UC	98			COLD
11	49				NDD			TSH	TSH	560PP	63			HOT
		6.55	186	1	DNG		08H	TEH	TEC	560UL	97			COLD
		0.65	64	3	INR		TSC	TEH	TEC	560UL	97			COLD
11	50				NDD			TSH	TSH	560PP	63			HOT
		0.71	118	3	INR		02H	TEH	TEC	560UC	98			COLD
		7.30	184	1	DNG		08H	TEH	TEC	560UC	98			COLD
11	51	7.45	187	1	DNG		08H	TEH	TEC	560UL	97			COLD
11	52	7.84	183	1	DNG		08H	TEH	TEC	560UC	98			COLD
11	53	8.06	187	1	DNG		08H	TEH	TEC	560UL	97			COLD
		0.25	8	1	INR		08H	TEH	TEC	560UL	97			COLD
		0.25	8	1	INR		08H	TEH	TEC	560UL	97			COLD
11	54	7.21	184	1	DNG		08H	TEH	TEC	560UC	98			COLD
11	55				NDD			TSH	TSH	560PP	64			HOT
		7.62	186	1	DNG		08H	TEH	TEC	560UL	97			COLD
11	56				NDD			TSH	TSH	560PP	64			HOT
		7.47	183	1	DNG		08H	TEH	TEC	560UC	98			COLD
11	57				NDD			TSH	TSH	560PP	66			HOT
		6.66	187	1	DNG		08H	TEH	TEC	560UL	97			COLD
11	58				NDD			TSH	TSH	560PP	65			HOT
					NDD			TEH	TEC	560UC	98			COLD
11	59				NDD			TEH	TEC	560UC	98			COLD
11	60	23.02		8	SLG		TSH	TEH	TEC	560UC	66			COLD
11	61	37.66		8	SLG		TSH	TEH	TEC	560UL	50			COLD
		29.25		8	SLG		TSC	TEH	TEC	560UL	50			COLD
11	62	40.62		8	SLG		TSH	TEH	TEC	560UL	50			COLD
		24.75		8	SLG		TSC	TEH	TEC	560UL	50			COLD
		10.68	182	1	DNG		AV6	TEH	TEC	560UL	50	OK		COLD
					INF		08H	TEH	TEC	560UL	50	HR		COLD
11	63	35.86		8	SLG		TSH	TEH	TEC	560UL	50			COLD
		9.65	183	1	DNG		AV6	TEH	TEC	560UL	50			COLD
					NDD			TSH	TSH	560PP	33			HOT
11	64	7.58	186	1	DNG		AV6	TEH	TEC	560UL	51			COLD
		28.17		8	SLG		TSH	TEH	TEC	560UL	51			COLD
					NDD			TSH	TSH	560PP	32			HOT
11	65	16.01		8	SLG		TSH	TEH	TEC	560UL	50			COLD
		8.84	183	1	DNG		AV6	TEH	TEC	560UL	50	OK		COLD
					INF		08H	TEH	TEC	560UL	50	HR		COLD
					NDD			TSH	TSH	560PP	32			HOT
11	66	6.86	183	1	DNG		AV6	TEH	TEC	560UC	68			COLD
		6.86	183	1	INF		AV2	TEH	TEC	560UC	68	HR/OK		COLD
					RBD			TEH	TEC	560UL	51			COLD
					NDD			TSH	TSH	560PP	32			HOT
11	67	9.91	183	1	DNG		AV6	TEH	TEC	560UL	50	OK		COLD
					INF		08H	TEH	TEC	560UL	50	HR		COLD
11	68	0.75	18	8	SLG		TSH	TEH	TEC	560UC	68			COLD
					RBD			TEH	TEC	560UL	51			COLD
11	69				NDD			TEH	TEC	560UL	50			COLD
11	70				NDD			TEH	TEC	560UL	68			COLD
					RBD			TEH	TEC	560UL	51			COLD
11	71				NDD			TEH	TEC	560UL	50			COLD
					NDD			TSH	TSH	560PP	32			HOT
11	72				NDD			TEH	TEC	560UC	68			COLD
					RBD			TEH	TEC	560UL	51			COLD
					NDD			TSH	TSH	560PP	32			HOT
11	73				NDD			TEH	TEC	560UL	50			COLD
					NDD			TSH	TSH	560PP	32			HOT
11	74				NDD			TEH	TEC	560UC	68			COLD
					RBD			TEH	TEC	560UL	51			COLD
					NDD			TSH	TSH	560PP	32			HOT
11	75				NDD			TEH	TEC	560UL	50			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
11	76				NDD			TEH	TEC	560UC	68			COLD
					RBD			TEH	TEC	560UL	51			COLD
11	77				NDD			TEH	TEC	560UL	54			COLD
11	78				NDD			TEH	TEC	560UL	54			COLD
11	79				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
11	80				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
11	81				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
11	82				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
11	83				NDD			TEH	TEC	560UL	54			COLD
11	84				NDD			TEH	TEC	560UL	55			COLD
11	85				NDD			TEH	TEC	560UL	54			COLD
11	86				NDD			TEH	TEC	560UL	55			COLD
11	87				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
11	88				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
11	89				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
11	90				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
11	93				NDD			TEH	TEC	560UL	54			COLD
11	94				NDD			TEH	TEC	560UL	54			COLD
11	95				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
11	96				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
11	97				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
11	98				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
11	99				NDD			TEH	TEC	560UL	55			COLD
11	100				NDD			TEH	TEC	560UL	54			COLD
11	101				NDD			TEH	TEC	560UL	55			COLD
11	102				NDD			TEH	TEC	560UL	54			COLD
11	103				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	14			HOT
11	104				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	14			HOT
11	105				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	14			HOT
11	106				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	14			HOT
11	107	0.40	86	3	NQH	06C	+29.89	TEH	TEC	560UL	55			COLD
		3.02	185	1	DNG	02C	+13.80	TEH	TEC	560UL	55			COLD
11	108				NDD			TEH	TEC	560UL	54			COLD
11	109				NDD			TEH	TEC	560UL	55			COLD
11	110				NDD			TEH	TEC	560UL	54			COLD
11	111				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	14			HOT
11	112				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	14			HOT
11	113				NDD			TEH	TEC	560UC	75			COLD
					NDD			TSH	TSH	560PP	66			HOT
11	114				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	101			COLD
11	115				NDD			TEH	TEC	560UC	75			COLD
11	116	0.52	112	3	NQH	03C	+38.21	TEH	TEC	560UC	101			COLD
11	117				NDD			TEH	TEC	560UC	75			COLD
11	118				NDD			TEH	TEC	560UC	101			COLD
11	119				NDD			TEH	TEC	560UC	75			COLD
					NDD			TSH	TSH	560PP	66			HOT
11	120				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	101			COLD
11	121				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	101			COLD
12	2				NDD			TEH	TEC	560DT	30			COLD
12	3				NDD			TEH	TEC	560DT	31			COLD
12	4				NDD			TEH	TEC	560DT	31			COLD
12	5				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	56			COLD
					RIC			TSH	TEC	560DT	31			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
12	6				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560DT	31			COLD
12	7				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560DT	31			COLD
12	8				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	56			COLD
					RIC			TSH	TEC	560DT	31			COLD
12	9				NDD			TEH	TEC	560UL	56			COLD
					RIC			TSH	TEC	560DT	31			COLD
12	10				NDD			TEH	TEC	560DT	31			COLD
12	11				NDD			TEH	TEC	560DT	31			COLD
12	12				NDD			TEH	TEC	560DT	31			COLD
12	13				NDD			TEH	TEC	560DT	31			COLD
12	14				NDD			TEH	TEC	560DT	31			COLD
12	15				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
12	16				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
12	17				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
12	18				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
12	19				NDD			TEH	TEC	560DT	31			COLD
12	20				NDD			TEH	TEC	560DT	31			COLD
12	21				NDD			TEH	TEC	560DT	31			COLD
12	22				NDD			TEH	TEC	560DT	31			COLD
12	23				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
12	24				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
12	25				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
12	26				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	32			COLD
12	27	17.22		8	SLG		TSH	TEH	TEC	560DT	33			COLD
		15.57		8	SLG		TSC	TEH	TEC	560DT	33			COLD
12	28	15.41		8	SLG		TSH	TEH	TEC	560DT	33			COLD
12	29				NDD			TEH	TEC	560DT	33			COLD
12	30				NDD			TEH	TEC	560DT	33			COLD
12	31				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	33			COLD
12	32				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	33			COLD
12	33				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	33			COLD
12	34				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	32			COLD
12	35				NDD			TEH	TEC	560DT	33			COLD
12	36				NDD			TEH	TEC	560DT	33			COLD
12	37				NDD			TEH	TEC	560DT	33			COLD
12	38				NDD			TEH	TEC	560DT	32			COLD
12	39				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	33			COLD
12	40				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	32			COLD
12	41				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	33			COLD
12	42				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	32			COLD
12	43				NDD			TEH	TEC	560DT	33			COLD
12	44				NDD			TEH	TEC	560UL	105			COLD
12	45				NDD			TEH	TEC	560UL	105			COLD
12	46				NDD			TEH	TEC	560UL	97			COLD
12	47				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
12	48				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UC	98			COLD
12	49				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
12	50				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UC	98			COLD
12	51				NDD			TEH	TEC	560UL	97			COLD
12	52				NDD			TEH	TEC	560UC	98			COLD
12	53				NDD			TEH	TEC	560UL	97			COLD
12	54				NDD			TEH	TEC	560UC	98			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
12	55				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UL	97			COLD
12	56				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UC	98			COLD
12	57				NDD			TSH	TSH	560PP	65			HOT
					NDD			TEH	TEC	560UL	97			COLD
12	58				NDD			TSH	TSH	560PP	66			HOT
					SLG		TSH	TEH	TEC	560UC	98			COLD
12	59	17.37		8	SLG		TSH	TEH	TEC	560UL	97			COLD
12	60	24.05		8	SLG		TSH	TEH	TEC	560UL	97			COLD
12	61	33.48		8	SLG		TSH	TEH	TEC	560UC	66			COLD
12	62	41.83		8	SLG		TSH	TEH	TEC	560UL	50			COLD
		36.53		8	SLG		TSC	TEH	TEC	560UL	50			COLD
12	62	27.85		8	SLG		TSC	TEH	TEC	560UL	51			COLD
		27.09		8	SLG		TSH	TEH	TEC	560UL	51			COLD
12	63	38.28		8	SLG		TSH	TEH	TEC	560UL	50			COLD
					NDD			TSH	TSH	560PP	33			HOT
12	64	38.49		8	SLG		TSH	TEH	TEC	560UL	51			COLD
					NDD			TSH	TSH	560PP	32			HOT
12	65	22.37		8	SLG		TSH	TEH	TEC	560UL	50			COLD
					NDD			TSH	TSH	560PP	33			HOT
12	66				NDD			TEH	TEC	560UL	51			COLD
					NDD			TSH	TSH	560PP	33			HOT
12	67				NDD			TEH	TEC	560UL	50			COLD
12	68				NDD			TEH	TEC	560UL	51			COLD
12	69				NDD			TEH	TEC	560UL	50			COLD
12	70				NDD			TEH	TEC	560UL	51			COLD
12	71				NDD			TEH	TEC	560UL	50			COLD
					NDD			TSH	TSH	560PP	33			HOT
12	72	6.13		34	8		TSH	TEH	TEC	560UL	51			COLD
					NDD			TSH	TSH	560PP	33			HOT
12	73				NDD			TEH	TEC	560UL	50			COLD
					NDD			TSH	TSH	560PP	33			HOT
12	74				NDD			TEH	TEC	560UC	68			COLD
					RBD			TEH	TEC	560UL	51			COLD
					NDD			TSH	TSH	560PP	33			HOT
12	75				NDD			TEH	TEC	560UL	50			COLD
12	76				NDD			TEH	TEC	560UL	51			COLD
12	77				NDD			TEH	TEC	560UL	54			COLD
12	78				NDD			TEH	TEC	560UL	55			COLD
12	79				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
12	80				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
12	81				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
12	82				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
12	83				NDD			TEH	TEC	560UL	54			COLD
12	84				NDD			TEH	TEC	560UL	55			COLD
12	85				NDD			TEH	TEC	560UL	54			COLD
12	86				NDD			TEH	TEC	560UL	55			COLD
12	87				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
12	88				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
12	89				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
12	90				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
12	91				NDD			TEH	TEC	560UL	54			COLD
12	92				NDD			TEH	TEC	560UL	55			COLD
12	93				NDD			TEH	TEC	560UL	54			COLD
12	94				NDD			TEH	TEC	560UL	55			COLD
12	95				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
12	96				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
12	97				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	13			HOT
12	98				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	13			HOT
12	99				NDD			TEH	TEC	560UL	54			COLD
12	100				NDD			TEH	TEC	560UL	55			COLD
12	101				NDD			TEH	TEC	560UL	54			COLD
12	102				NDD			TEH	TEC	560UL	55			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
12	103				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	15			HOT
12	104				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	15			HOT
12	105				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	15			HOT
12	106				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	15			HOT
12	107				NDD			TEH	TEC	560UL	54			COLD
12	108				NDD			TEH	TEC	560UL	55			COLD
12	109				NDD			TEH	TEC	560UL	54			COLD
12	110				NDD			TEH	TEC	560UL	55			COLD
12	111				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	15			HOT
12	112				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	15			HOT
12	113				NDD			TEH	TEC	560UC	75			COLD
					NDD			TSH	TSH	560PP	66			HOT
12	114				NDD			TEH	TEC	560UC	75			COLD
					NDD			TSH	TSH	560PP	66			HOT
12	115				NDD			TEH	TEC	560UC	101			COLD
12	116				NDD			TEH	TEC	560UC	75			COLD
12	117				NDD			TEH	TEC	560UC	100			COLD
12	118				NDD			TEH	TEC	560UC	75			COLD
12	119				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	100			COLD
12	120				NDD			TEH	TEC	560UC	75			COLD
					NDD			TSH	TSH	560PP	66			HOT
12	121				NDD			TSH	TSH	560PP	65			HOT
					NDD			TEH	TEC	560UC	100			COLD
13	3				NDD			TEH	TEC	560DT	30			COLD
13	4	15.84		8	SLG		TSH	TEH	TEC	560DT	30			COLD
		16.19		8	SLG		TSC	TEH	TEC	560DT	30			COLD
13	5				NDD			TSH	TSH	560PP	45			HOT
		16.05		8	SLG		TSC	TEH	TEC	560DT	30			COLD
13	6				NDD			TSH	TSH	560PP	44			HOT
		16.92		8	SLG		TSC	TEH	TEC	560DT	30			COLD
13	7				NDD			TSH	TSH	560PP	44			HOT
		16.48		8	SLG		TSC	TEH	TEC	560DT	30			COLD
13	8				NDD			TSH	TSH	560PP	44			HOT
		16.52		8	SLG		TSH	TEH	TEC	560DT	30			COLD
		17.62		8	SLG		TSC	TEH	TEC	560DT	30			COLD
13	9				NDD			TSH	TSH	560PP	44			HOT
		17.08		8	SLG		TSH	TEH	TEC	560DT	30			COLD
		16.98		8	SLG		TSC	TEH	TEC	560DT	30			COLD
13	10				NDD			TEH	TEC	560DT	30			COLD
		17.73		8	SLG		TSH	TEH	TEC	560DT	30			COLD
		15.59		8	SLG		TSC	TEH	TEC	560DT	30			COLD
13	11				NDD			TEH	TEC	560DT	30			COLD
		19.93		8	SLG		TSH	TEH	TEC	560DT	30			COLD
13	12				NDD			TEH	TEC	560DT	30			COLD
		17.67		8	SLG		TSH	TEH	TEC	560DT	30			COLD
13	13				NDD			TEH	TEC	560DT	30			COLD
		15.57		8	SLG		TSH	TEH	TEC	560DT	30			COLD
13	14				NDD			TEH	TEC	560DT	30			COLD
		17.38		8	SLG		TSH	TSH	TSH	560PP	48			HOT
13	15				NDD			TEH	TEC	560DT	30			COLD
		17.67		8	SLG		TSH	TSH	TSH	560PP	48			HOT
13	16				NDD			TEH	TEC	560DT	30			COLD
		18.95		8	SLG		TSH	TEH	TEC	560DT	30			COLD
		15.21		8	SLG		TSC	TEH	TEC	560DT	30			COLD
13	17				NDD			TSH	TSH	560PP	48			HOT
		0.70	101	3	INR		01C	TEH	TEC	560DT	30			COLD
		16.02		8	SLG		TSC	TEH	TEC	560DT	30			COLD
		18.14		8	SLG		TSH	TEH	TEC	560DT	30			COLD
13	18				NDD			TSH	TSH	560PP	48			HOT
		18.08		8	SLG		TSC	TEH	TEC	560DT	30			COLD
13	19				NDD			TEH	TEC	560DT	30			COLD
		18.35		8	SLG		TSH	TEH	TEC	560DT	30			COLD
		16.27		8	SLG		TSC	TEH	TEC	560DT	30			COLD
13	20				NDD			TEH	TEC	560DT	30			COLD
		19.14		8	SLG		TSH	TEH	TEC	560DT	30			COLD
		16.29		8	SLG		TSC	TEH	TEC	560DT	30			COLD
13	21				NDD			TEH	TEC	560DT	30			COLD
		17.54		8	SLG		TSH	TEH	TEC	560DT	30			COLD
		16.44		8	SLG		TSC	TEH	TEC	560DT	30			COLD
13	22				NDD			TEH	TEC	560DT	30			COLD
		17.04		8	SLG		TSH	TEH	TEC	560DT	30			COLD
		15.05		8	SLG		TSC	TEH	TEC	560DT	30			COLD
13	23				NDD			TSH	TSH	560PP	48			HOT
		15.77		8	SLG		TSC	TEH	TEC	560DT	30			COLD
13	24				NDD			TSH	TSH	560PP	48			HOT
		20.08		8	SLG		TSH	TEH	TEC	560DT	30			COLD
		16.92		8	SLG		TSC	TEH	TEC	560DT	30			COLD
13	25				NDD			TSH	TSH	560PP	48			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
13	26	18.14		8	SLG		TSH		TEH	TEC	560DT	30		COLD
		0.89		104	3		NQH		TEH	TEC	560DT	33		COLD
		19.84		8	SLG		TSC		TEH	TEC	560DT	33		COLD
					NDD				TSH	TSH	560PP	48		HOT
13	27				NDD				TEH	TEC	560DT	32		COLD
13	28				NDD				TEH	TEC	560DT	32		COLD
13	29				NDD				TEH	TEC	560DT	32		COLD
13	30	3.01		179	P 1		DNT		TEH	TEC	560DT	32		COLD
13	31				NDD		AV1		TEH	TEC	560DT	32		COLD
					NDD				TSH	TSH	560PP	48		HOT
13	32				NDD				TEH	TEC	560DT	32		COLD
					NDD				TSH	TSH	560PP	48		HOT
13	33				NDD				TEH	TEC	560DT	32		COLD
					NDD				TSH	TSH	560PP	48		HOT
13	34				NDD				TEH	TEC	560DT	33		COLD
					NDD				TSH	TSH	560PP	48		HOT
13	35	0.71		83	3		NQH		TEH	TEC	560DT	32		COLD
13	36				NDD		04C		TEH	TEC	560DT	32		COLD
13	37				NDD				TEH	TEC	560DT	32		COLD
13	38				NDD				TEH	TEC	560DT	33		COLD
13	39				NDD				TEH	TEC	560DT	32		COLD
					NDD				TSH	TSH	560PP	48		HOT
13	40				NDD				TEH	TEC	560DT	33		COLD
					NDD				TSH	TSH	560PP	48		HOT
13	41				NDD				TEH	TEC	560DT	32		COLD
					NDD				TSH	TSH	560PP	48		HOT
13	42				NDD				TEH	TEC	560DT	33		COLD
					NDD				TSH	TSH	560PP	48		HOT
13	43				NDD				TEH	TEC	560DT	32		COLD
13	44	0.56		119	3		INR		TEH	TEC	560UL	105		COLD
13	45				NDD		07C		TEH	TEC	560UL	105		COLD
13	46				NDD				TEH	TEC	560UL	97		COLD
13	47				NDD				TSH	TSH	560PP	63		HOT
					NDD				TEH	TEC	560UL	97		COLD
13	48				NDD				TSH	TSH	560PP	63		HOT
					NDD				TEH	TEC	560UC	98		COLD
13	49				NDD				TSH	TSH	560PP	63		HOT
					NDD				TEH	TEC	560UL	97		COLD
13	50				NDD				TSH	TSH	560PP	63		HOT
		3.72		182	1		DNG		TEH	TEC	560UC	98		COLD
13	51				NDD		08H		TEH	TEC	560UL	97		COLD
13	52				NDD				TEH	TEC	560UC	98		COLD
13	53				NDD				TEH	TEC	560UL	97		COLD
13	54				NDD				TEH	TEC	560UC	98		COLD
13	55				NDD				TSH	TSH	560PP	64		HOT
					NDD				TEH	TEC	560UL	97		COLD
13	56				NDD				TSH	TSH	560PP	64		HOT
					NDD				TEH	TEC	560UC	98		COLD
13	57				NDD				TSH	TSH	560PP	66		HOT
					NDD				TEH	TEC	560UL	97		COLD
13	58				NDD				TSH	TSH	560PP	65		HOT
		17.04		8	SLG		TSH		TEH	TEC	560UC	98		COLD
13	59				NDD				TSH	TSH	560PP	65		HOT
		0.54		102	3		NQH		TEH	TEC	560UL	97		COLD
		30.04		8	SLG		TSH		TEH	TEC	560UL	97		COLD
13	60				NDD				TEH	TEC	560UC	66		COLD
					NDD				TSH	TSH	560PP	65		HOT
13	61	36.37		8	SLG		TSH		TEH	TEC	560UL	50		COLD
		17.99		8	SLG		TSC		TEH	TEC	560UL	50		COLD
		1.95		156	8		INR		TEH	TEC	560UL	50		COLD
					NDD				TSH	TSH	560PP	65		HOT
13	62	36.19		8	SLG		TSH		TEH	TEC	560UL	51		COLD
		17.38		8	SLG		TSC		TEH	TEC	560UL	51		COLD
13	63	36.93		8	SLG		TSH		TEH	TEC	560UL	50		COLD
					NDD				TSH	TSH	560PP	33		HOT
13	64	31.70		8	SLG		TSH		TEH	TEC	560UL	51		COLD
					NDD				TSH	TSH	560PP	32		HOT
13	65	21.86		8	SLG		TSH		TEH	TEC	560UL	50		COLD
					NDD				TSH	TSH	560PP	32		HOT
13	66				NDD				TEH	TEC	560UL	51		COLD
					NDD				TSH	TSH	560PP	32		HOT
13	67				NDD				TEH	TEC	560UL	50		COLD
13	68				NDD				TEH	TEC	560UL	51		COLD
13	69				NDD				TEH	TEC	560UL	50		COLD
13	70	0.27		125	3		NQH		TEH	TEC	560UL	51		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
13	71	0.88	101	3	NQH		04C +28.93	TEH	TEC	560UL	50			COLD
		0.34	87	3	NQH		05C +19.25	TEH	TEC	560UL	50			COLD
		18.42		8	SLG		TSH +0.78	TEH	TEC	560UL	50			COLD
					INF		03C +29.20	TEH	TEC	560UL	50	HR		COLD
					NDD			TSH	TSH	560PP	32			HOT
13	72				NDD			TEH	TEC	560UL	51			COLD
					NDD			TSH	TSH	560PP	32			HOT
13	73				NDD			TEH	TEC	560UL	48			COLD
					NDD			TSH	TSH	560PP	32			HOT
13	74				NDD			TEH	TEC	560UL	49			COLD
					NDD			TSH	TSH	560PP	32			HOT
13	75				NDD			TEH	TEC	560UL	48			COLD
13	76				NDD			TEH	TEC	560UL	49			COLD
13	77				NDD			TEH	TEC	560UL	54			COLD
13	78				NDD			TEH	TEC	560UL	54			COLD
13	79				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
13	80				NDD			TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
13	81				NDD			TEH	TEC	560UL	55			COLD
					NDD			TSH	TSH	560PP	12			HOT
13	82	0.55	102	3	INR		02C +20.08	TEH	TEC	560UL	54			COLD
					NDD			TSH	TSH	560PP	12			HOT
13	83				INF		08H +6.22	TEH	TEC	560UL	55	HR		COLD
13	84				NDD			TEH	TEC	560UL	52			COLD
13	85				NDD			TEH	TEC	560UL	53			COLD
13	86				NDD			TEH	TEC	560UL	52			COLD
13	87				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
13	88				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	12			HOT
13	89				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
13	90				NDD			TEH	TEC	560UL	52			COLD
				3	NDF		TSH -19.08	TEH	TSH	560PP	61			HOT
					NDD			TEH	TSH	560PP	12			HOT
13	91				NDD			TEH	TEC	560UL	53			COLD
13	92				NDD			TEH	TEC	560UL	52			COLD
13	93				NDD			TEH	TEC	560UL	53			COLD
13	94				NDD			TEH	TEC	560UL	52			COLD
13	95				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
13	96				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	12			HOT
13	97				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
13	98				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	12			HOT
13	99				NDD			TEH	TEC	560UL	53			COLD
13	100				NDD			TEH	TEC	560UL	52			COLD
13	101				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
					NDD			TEH	TSH	560PP	51			HOT
13	102				NDD			TEH	TEC	560UL	52			COLD
13	103				NDD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560UL	53			COLD
13	104				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	14			HOT
13	105				NDD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560UL	53			COLD
13	106				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	14			HOT
13	107				NDD			TEH	TEC	560UL	53			COLD
13	108				NDD			TEH	TEC	560UL	52			COLD
13	109				NDD			TEH	TEC	560UL	53			COLD
13	110				NDD			TEH	TEC	560UL	52			COLD
13	111				NDD			TSH	TSH	560PP	14			HOT
		0.49	104	3	NQH		02C +8.63	TEH	TEC	560UL	53			COLD
13	112				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	14			HOT
13	113				NDD			TEH	TEC	560UC	75			COLD
					NDD			TSH	TSH	560PP	66			HOT
13	114				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	100			COLD
13	115				NDD			TEH	TEC	560UC	75			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
13	116	0.85	99	3	NQH		06C +37.41	TEH	TEC	560UC	100			COLD
		0.51	84	3	NQH		02C +28.12	TEH	TEC	560UC	100			COLD
13	117				NDD			TEH	TEC	560UC	75			COLD
13	118	0.80	122	3	INR		05C +27.00	TEH	TEC	560UC	100			COLD
13	119				NDD			TEH	TEC	560UC	75			COLD
					NDD			TSH	TSH	560PP	66			HOT
13	120				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	100			COLD
14	3				NDD			TEH	TEC	560DT	31			COLD
14	4				NDD			TEH	TEC	560DT	31			COLD
14	5				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560DT	31			COLD
14	6				NDD			TEH	TEC	560UL	56			COLD
					NDD			TSH	TSH	560PP	44			HOT
					RIC			TSH	TEC	560DT	31			COLD
14	7				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560UL	56			COLD
					RIC			TSH	TEC	560DT	31			COLD
14	8				NDD			TSH	TSH	560PP	44			HOT
					NDD			TEH	TEC	560DT	31			COLD
14	9				NDD			TEH	TEC	560DT	31			COLD
14	10				NDD			TEH	TEC	560DT	31			COLD
14	11				NDD			TEH	TEC	560DT	31			COLD
14	12				NDD			TEH	TEC	560DT	31			COLD
14	13				NDD			TEH	TEC	560DT	31			COLD
14	14				NDD			TEH	TSH	560PP	46			HOT
					NDD			TEH	TEC	560DT	31			COLD
14	15				NDD			TEH	TSH	560PP	46			HOT
					NDD			TEH	TEC	560DT	31			COLD
14	16				NDD			TSH	TSH	560PP	49			HOT
		1.36	126	3	INR		02H +29.12	TEH	TEC	560DT	31			COLD
		16.80		8	SLG		TSH +0.62	TEH	TEC	560DT	31			COLD
		16.59		8	SLG		TSC +0.51	TEH	TEC	560DT	31			COLD
14	17				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
14	18				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
14	19				NDD			TSH	TSH	560PS	79			HOT
					NDD			TEH	TEC	560DT	31			COLD
14	20				NDD			TEH	TEC	560DT	31			COLD
14	21				NDD			TEH	TEC	560DT	31			COLD
14	22				NDD			TEH	TEC	560DT	31			COLD
14	23				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
14	24				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
14	25				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	31			COLD
14	26				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	32			COLD
14	27	18.32		8	SLG		TSH +0.54	TEH	TEC	560DT	33			COLD
		21.04		8	SLG		TSC +0.58	TEH	TEC	560DT	33			COLD
14	28				NDD			TEH	TEC	560DT	33			COLD
14	29				NDD			TEH	TEC	560DT	33			COLD
14	30				NDD			TEH	TEC	560DT	33			COLD
14	31				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	33			COLD
14	32				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	33			COLD
14	33				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	33			COLD
14	34				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	32			COLD
14	35				NDD			TEH	TEC	560DT	33			COLD
14	36				NDD			TEH	TEC	560DT	33			COLD
14	37				NDD			TEH	TEC	560DT	33			COLD
14	38				NDD			TEH	TEC	560DT	32			COLD
14	39				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	33			COLD
14	40				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	32			COLD
14	41				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	33			COLD
14	42				NDD			TSH	TSH	560PP	49			HOT
					NDD			TEH	TEC	560DT	32			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
14	43				NDD			TEH	TEC	560DT	33			COLD
14	44				NDD			TEH	TEC	560DT	33			COLD
14	45				NDD			TEH	TEC	560DT	33			COLD
14	46				NDD			TEH	TEC	560UL	97			COLD
14	47				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
14	48				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
14	49				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UC	98			COLD
14	50				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
14	51				NDD			TEH	TEC	560UC	98			COLD
14	52				NDD			TEH	TEC	560UL	97			COLD
14	53				NDD			TEH	TEC	560UC	98			COLD
14	54				NDD			TEH	TEC	560UL	97			COLD
14	55				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UC	98			COLD
14	56				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UL	97			COLD
14	57				NDD			TSH	TSH	560PP	65			HOT
					NDD			TEH	TEC	560UC	98			COLD
14	58	16.92		8	NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UL	97			COLD
14	59	25.30		8	SLG		TSH	TEH	TEC	560UL	97			COLD
14	60	34.51		8	SLG		TSH	TEH	TEC	560UC	66			COLD
14	61	33.89		8	SLG		TSH	TEH	TEC	560UL	48			COLD
14	62	31.32		8	SLG		TSC	TEH	TEC	560UL	48			COLD
14	63	37.22		8	NDD		TSH	TEH	TEC	560UL	49			COLD
					NDD			TSH	TSH	560PP	33			HOT
14	64				NDD			TEH	TEC	560UL	49			COLD
					NDD			TSH	TSH	560PP	33			HOT
14	65	19.62		8	SLG		TSH	TEH	TEC	560UL	48			COLD
					NDD			TSH	TSH	560PP	33			HOT
14	66	20.51		8	SLG		TSH	TEH	TEC	560UL	49			COLD
					NDD			TSH	TSH	560PP	33			HOT
14	67				NDD			TEH	TEC	560UL	48			COLD
14	68	15.18		8	SLG		TSH	TEH	TEC	560UL	49			COLD
14	69				NDD			TEH	TEC	560UL	48			COLD
14	70				NDD			TEH	TEC	560UL	49			COLD
14	71				NDD			TEH	TEC	560UL	48			COLD
					NDD			TSH	TSH	560PP	33			HOT
14	72	74.83	186	P 1	INR		TSH	TEH	TEC	560UL	49			COLD
					NDD			TSH	TSH	560PP	33			HOT
14	73				NDD			TEH	TEC	560UL	48			COLD
					NDD			TSH	TSH	560PP	33			HOT
14	74				NDD			TEH	TEC	560UL	49			COLD
					NDD			TSH	TSH	560PP	33			HOT
14	75				NDD			TEH	TEC	560UL	48			COLD
14	76				NDD			TEH	TEC	560UL	49			COLD
14	77				NDD			TEH	TEC	560UL	52			COLD
14	78				NDD			TEH	TEC	560UL	53			COLD
14	79				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	13			HOT
14	80				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
14	81				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	13			HOT
14	82				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
14	83				NDD			TEH	TEC	560UL	52			COLD
14	84				NDD			TEH	TEC	560UL	53			COLD
14	85				NDD			TEH	TEC	560UL	52			COLD
14	86				NDD			TEH	TEC	560UL	53			COLD
14	87				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	13			HOT
14	88				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
14	89				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	13			HOT
14	90				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
14	91				NDD			TEH	TEC	560UL	52			COLD
14	92				NDD			TEH	TEC	560UL	53			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
14	93				NDD			TEH	TEC	560UL	52			COLD
14	94				NDD			TEH	TEC	560UL	53			COLD
14	95				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	13			HOT
14	96				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
14	97				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	13			HOT
14	98	3.11	191	1	DNG		TSH	+2.68	TEH	TEC	560UL	53		COLD
					NDD				TSH	TSH	560PP	12		HOT
14	99				NDD			TEH	TEC	560UL	52			COLD
14	100				NDD			TEH	TEC	560UL	53			COLD
14	101				NDD			TEH	TEC	560UL	52			COLD
14	102				NDD			TEH	TEC	560UL	53			COLD
14	103				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	15			HOT
14	104				NDD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560UL	53			COLD
14	105				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	15			HOT
14	106				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560UL	53			COLD
14	107				NDD			TEH	TEC	560UL	52			COLD
14	108				NDD			TEH	TEC	560UL	53			COLD
14	109				NDD			TEH	TEC	560UL	52			COLD
14	110				NDD			TEH	TEC	560UL	53			COLD
14	111				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560UL	53			COLD
14	112				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	15			HOT
14	113				NDD			TEH	TEC	560UC	75			COLD
					NDD			TSH	TSH	560PP	66			HOT
14	114				NDD			TEH	TEC	560UC	75			COLD
					NDD			TSH	TSH	560PP	66			HOT
14	115				NDD			TEH	TEC	560UC	75			COLD
14	116				NDD			TEH	TEC	560UC	100			COLD
14	117				NDD			TEH	TEC	560UC	75			COLD
14	118				NDD			TEH	TEC	560UC	100			COLD
14	119				NDD			TEH	TEC	560UC	75			COLD
					NDD			TSH	TSH	560PP	66			HOT
14	120				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	100			COLD
15	3				NDD			TEH	TEC	560DT	30			COLD
15	4				RBD			TEH	TSH	560PP	45			HOT
		15.05		8	SLG		TSC	+0.45	TEH	TEC	560DT	30		COLD
					NDD				TEH	TSH	560PP	51		HOT
15	5				NDD			TSH	TSH	560PP	45			HOT
		16.02		8	SLG		TSC	+0.48	TEH	TEC	560DT	30		COLD
15	6				NDD			TSH	TSH	560PP	45			HOT
		16.54		8	SLG		TSC	+0.51	TEH	TEC	560DT	30		COLD
15	7				NDD			TSH	TSH	560PP	44			HOT
		15.26		8	SLG		TSH	+0.46	TEH	TEC	560DT	30		COLD
		16.34		8	SLG		TSC	+0.48	TEH	TEC	560DT	30		COLD
15	8				8	SLG	TSH	+0.47	TEH	TEC	560DT	30		COLD
		15.34		8	SLG		TSC	+0.47	TEH	TEC	560DT	30		COLD
		15.77		8	SLG		TSC	+0.47	TEH	TEC	560DT	30		COLD
					NDD			TSH	TSH	560PP	51			HOT
15	9				86	6	INR	03C	+22.58	TEH	TEC	560DT	30	COLD
		15.34		8	SLG		TSH	+0.46	TEH	TEC	560DT	30		COLD
15	10				8	SLG	TSH	+0.48	TEH	TEC	560DT	30		COLD
15	11				8	SLG	TSH	+0.58	TEH	TEC	560DT	30		COLD
15	12				8	SLG	TSH	+0.93	TEH	TEC	560DT	30		COLD
15	13				8	SLG	TSH	+0.60	TEH	TEC	560DT	30		COLD
15	14				8	SLG	TSH	+0.56	TEH	TEC	560DT	30		COLD
15	15				NDD			TSH	TSH	560PP	48			HOT
					NDD			TEH	TEC	560DT	30			COLD
15	16				NDD			TSH	TSH	560PP	48			HOT
		17.60		8	SLG		TSH	+0.58	TEH	TEC	560DT	30		COLD
15	17				NDD			TSH	TSH	560PP	48			HOT
		17.44		8	SLG		TSH	+0.62	TEH	TEC	560DT	30		COLD
		15.30		8	SLG		TSC	+0.46	TEH	TEC	560DT	30		COLD
15	18				76	11	PLP	TSH	+0.27	TSH	TSH	560FS	82	HOT
		0.35		80	11	PLP	TSH	+0.27	TSH	TSH	560PP	48		HOT
		0.45		8	SLG		TSH	+0.65	TEH	TEC	560DT	30		COLD
		17.77		8	SLG		TSH	+0.65	TEH	TEC	560DT	30		COLD
		16.44		8	SLG		TSC	+0.52	TEH	TEC	560DT	30		COLD
15	19				NDD			TSH	TSH	560PS	79			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
15	20	17.21		8	SLG		TSH	+0.62	TEH	TEC	560DT	30		COLD
15	21	18.39		8	SLG		TSH	+0.67	TEH	TEC	560DT	30		COLD
15	22	16.63		8	NDD				TEH	TEC	560DT	30		COLD
15	23	16.63		8	SLG		TSH	+0.59	TEH	TEC	560DT	30		COLD
15	24	18.14		8	NDD				TSH	TSH	560PP	48		HOT
15	25	16.98		8	SLG		TSH	+0.67	TEH	TEC	560DT	30		COLD
15	26	16.63		8	NDD				TSH	TSH	560PP	48		HOT
15	27	16.63		8	SLG		TSH	+0.60	TEH	TEC	560DT	30		COLD
15	28	16.63		8	NDD				TSH	TSH	560PP	48		HOT
15	29	0.68	108	3	SLG		TSH	+0.59	TEH	TEC	560DT	30		COLD
15	30				NDD		07C	+21.82	TEH	TEC	560DT	32		COLD
15	31				NDD				TEH	TEC	560DT	32		COLD
15	32				NDD				TEH	TEC	560DT	32		COLD
15	33				NDD				TSH	TSH	560PP	48		HOT
15	34				NDD				TEH	TEC	560DT	32		COLD
15	35				NDD				TSH	TSH	560PP	48		HOT
15	36				NDD				TEH	TEC	560DT	32		COLD
15	37				NDD				TEH	TEC	560DT	32		COLD
15	38				NDD				TEH	TEC	560DT	32		COLD
15	39				NDD				TEH	TEC	560DT	32		COLD
15	40				NDD				TSH	TSH	560PP	48		HOT
15	41				NDD				TEH	TEC	560DT	32		COLD
15	42				NDD				TSH	TSH	560PP	48		HOT
15	43				NDD				TEH	TEC	560DT	32		COLD
15	44				NDD				TEH	TEC	560DT	32		COLD
15	45				NDD				TEH	TEC	560DT	32		COLD
15	46				NDD				TSH	TSH	560PP	63		HOT
15	47				NDD				TEH	TEC	560UL	97		COLD
15	48				NDD				TSH	TSH	560PP	63		HOT
15	49				NDD				TEH	TEC	560UL	97		COLD
15	50				NDD				TSH	TSH	560PP	63		HOT
15	51				NDD				TEH	TEC	560UL	97		COLD
15	52				NDD				TEH	TEC	560UL	97		COLD
15	53				NDD				TEH	TEC	560UL	97		COLD
15	54				NDD				TEH	TSH	560PP	63		HOT
15	55				NDD				TEH	TEC	560UL	97		COLD
15	56				NDD				TSH	TSH	560PP	64		HOT
15	57				NDD				TEH	TEC	560UL	97		COLD
15	58				NDD				TSH	TSH	560PP	65		HOT
15	59	15.41		8	SLG		TSH	+1.67	TEH	TEC	560UL	97		COLD
15	60	17.27		8	SLG		TSH	+3.09	TEH	TEC	560UL	97		COLD
15	61	30.57		8	SLG		TSH	+3.24	TEH	TEC	560UC	66		COLD
15	62	19.25		8	SLG		TSH	+0.83	TEH	TEC	560UL	48		COLD
15	63	38.18		8	SLG		TSC	+1.61	TEH	TEC	560UL	48		COLD
15	64	41.77		8	SLG		TSH	+5.80	TEH	TEC	560UL	48		COLD
15	65	29.30		8	SLG		TSC	+1.56	TEH	TEC	560UL	48		COLD
15	66	39.69		8	SLG		TSH	+6.67	TEH	TEC	560UL	48		COLD
15	67				NDD				TSH	TSH	560PP	33		HOT
15	68				NDD				TEH	TEC	560UL	49		COLD
15	69				NDD				TSH	TSH	560PP	32		HOT
15	70	18.37		8	SLG		TSH	+0.74	TEH	TEC	560UL	48		COLD
15	71				NDD				TSH	TSH	560PP	32		HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
15	66				NDD			TEH	TEC	560UL	49			COLD
					NDD			TSH	TSH	560PP	32			HOT
15	67	15.58		8	SLG		TSH +1.99	TEH	TEC	560UL	48			COLD
15	68				NDD			TEH	TEC	560UL	49			COLD
15	69				NDD			TEH	TEC	560UL	48			COLD
15	70				NDD			TEH	TEC	560UL	49			COLD
15	71				NDD			TEH	TEC	560UL	48			COLD
					NDD			TSH	TSH	560PP	32			HOT
15	72				NDD			TEH	TEC	560UL	49			COLD
					NDD			TSH	TSH	560PP	32			HOT
15	73				NDD			TEH	TEC	560UL	48			COLD
					NDD			TSH	TSH	560PP	32			HOT
15	74				NDD			TEH	TEC	560UL	49			COLD
					NDD			TSH	TSH	560PP	32			HOT
15	75				NDD			TEH	TEC	560UL	48			COLD
15	76				NDD			TEH	TEC	560UL	49			COLD
15	77				NDD			TEH	TEC	560UL	52			COLD
15	78				NDD			TEH	TEC	560UL	52			COLD
15	79				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	12			HOT
15	80				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
15	81				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	12			HOT
15	82				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
15	83				NDD			TEH	TEC	560UL	52			COLD
15	84				NDD			TEH	TEC	560UL	53			COLD
15	85				NDD			TEH	TEC	560UL	52			COLD
15	86				NDD			TEH	TEC	560UL	53			COLD
15	87				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	12			HOT
15	88				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
15	89				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	12			HOT
15	90				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
15	91				NDD			TEH	TEC	560UL	52			COLD
15	92				NDD			TEH	TEC	560UL	53			COLD
15	93				NDD			TEH	TEC	560UL	52			COLD
15	94				NDD			TEH	TEC	560UL	53			COLD
15	95				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	12			HOT
15	96				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
15	97				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	12			HOT
15	98				NDD			TEH	TEC	560UL	53			COLD
					NDD			TSH	TSH	560PP	12			HOT
15	99				NDD			TEH	TEC	560UL	52			COLD
15	100				NDD			TEH	TEC	560UL	53			COLD
15	101				NDD			TEH	TEC	560UL	52			COLD
15	102				NDD			TEH	TEC	560UL	53			COLD
15	103				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	14			HOT
15	104				NDD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560UL	53			COLD
15	105				NDD			TEH	TEC	560UL	52			COLD
					NDD			TSH	TSH	560PP	14			HOT
15	106				NDD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560UL	53			COLD
15	107				NDD			TEH	TEC	560UL	52			COLD
					NDD			TEH	TSH	560PP	14			HOT
15	108				NDD			TEH	TEC	560UL	53			COLD
15	109				NDD			TEH	TEC	560UL	52			COLD
15	110				NDD			TEH	TEC	560UL	52			COLD
15	111				NDD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560UL	53			COLD
15	112				NDD			TEH	TEC	560UL	57			COLD
					NDD			TSH	TSH	560PP	14			HOT
15	113				NDD			TEH	TEC	560UC	75			COLD
					NDD			TSH	TSH	560PP	66			HOT
15	114				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	100			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
15	115				NDD			TEH	TEC	560UC	75			COLD
15	116				NDD			TEH	TEC	560UC	100			COLD
15	117				NDD			TEH	TEC	560UC	75			COLD
15	118				NDD			TEH	TEC	560UC	100			COLD
15	119				NDD			TEH	TEC	560UC	75			COLD
					NDD			TSH	TSH	560PP	66			HOT
15	120				NDD			TSH	TSH	560PP	66			HOT
					NDD			TEH	TEC	560UC	100			COLD
16	3				NDD			TEH	TEC	560DT	17			COLD
16	4				NDD			TEH	TEC	560DT	16			COLD
16	5				NDD			TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	44			HOT
16	6				NDD			TSH	TSH	560PP	45			HOT
		15.88		8	SLG		TSC	TEH	TEC	560DT	16			COLD
16	7				NDD			TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	44			HOT
16	8				NDD			TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	44			HOT
16	9	15.78		8	SLG		TSH	TEH	TEC	560DT	16			COLD
16	10	16.97		8	SLG		TSH	TEH	TEC	560DT	17			COLD
16	11	17.23		8	SLG		TSH	TEH	TEC	560DT	17			COLD
16	12	16.61		8	SLG		TSH	TEH	TEC	560DT	16			COLD
		0.50	82	3	NQH		O3C	TEH	TEC	560DT	16			COLD
16	13	17.21		8	SLG		TSH	TEH	TEC	560DT	17			COLD
16	14	17.74		8	SLG		TSH	TEH	TEC	560DT	16			COLD
16	15	18.62		8	SLG		TSH	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	44			HOT
16	16				NDD			TSH	TSH	560PP	45			HOT
		18.56		8	SLG		TSH	TEH	TEC	560DT	17			COLD
16	17	17.80		8	SLG		TSH	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	44			HOT
16	18	17.99		8	SLG		TSH	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
16	19	18.44		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		16.69		8	SLG		TSC	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PS	79			HOT
16	20	16.95		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		15.16		8	SLG		TSC	TEH	TEC	560DT	19			COLD
16	21	17.77		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		16.24		8	SLG		TSC	TEH	TEC	560DT	19			COLD
16	22	18.10		8	SLG		TSH	TEH	TEC	560DT	18			COLD
16	23	17.24		8	SLG		TSH	TEH	TEC	560DT	19			COLD
					NDD			TEH	TSH	560PP	42			HOT
16	24	18.38		8	SLG		TSH	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
16	25	18.46		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		15.03		8	SLG		TSC	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
16	26	18.25		8	SLG		TSH	TEH	TEC	560DT	20			COLD
		15.19		8	SLG		TSC	TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	43			HOT
16	27	17.77		8	SLG		TSH	TEH	TEC	560DT	21			COLD
		15.86		8	SLG		TSC	TEH	TEC	560DT	21			COLD
16	28	19.09		8	SLG		TSH	TEH	TEC	560DT	20			COLD
		17.30		8	SLG		TSC	TEH	TEC	560DT	20			COLD
		1.05	119	3	INR		O3H	TEH	TEC	560DT	20			COLD
16	29	18.07		8	SLG		TSH	TEH	TEC	560DT	21			COLD
		15.82		8	SLG		TSC	TEH	TEC	560DT	21			COLD
16	30	18.17		8	SLG		TSH	TEH	TEC	560DT	20			COLD
		16.34		8	SLG		TSC	TEH	TEC	560DT	20			COLD
16	31	16.71		8	SLG		TSH	TEH	TEC	560DT	21			COLD
					NDD			TSH	TSH	560PP	42			HOT
16	32	18.11		8	SLG		TSH	TEH	TEC	560DT	20			COLD
					RBD			TSH	TSH	560PP	41			HOT
					NDD			TSH	TSH	560PP	51			HOT
16	33				NDD			TSH	TSH	560PP	40			HOT
		17.73		8	SLG		TSH	TEH	TEC	560DT	21			COLD
16	34	17.90		8	SLG		TSH	TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	40			HOT
16	35	17.81		8	SLG		TSH	TEH	TEC	560DT	21			COLD
16	36	18.17		8	SLG		TSH	TEH	TEC	560DT	20			COLD
16	37	17.63		8	SLG		TSH	TEH	TEC	560DT	21			COLD
16	38	17.72		8	SLG		TSH	TEH	TEC	560DT	22			COLD
16	39	18.11		8	SLG		TSH	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
16	40	16.98		8	SLG		TSH	+0.52	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
16	41	18.00		8	SLG		TSH	+0.65	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
16	42	16.68		8	SLG		TSH	+0.50	TEH	TEC	560DT	22		COLD
		15.71		8	SLG		TSC	+0.46	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
16	43	18.15		8	SLG		TSC	+0.56	TEH	TEC	560DT	23		COLD
					NDD				TEH	TSH	560PP	40		HOT
16	44	18.93		8	SLG		TSC	+0.56	TEH	TEC	560DT	22		COLD
16	45	18.46		8	SLG		TSH	+0.68	TEH	TEC	560DT	23		COLD
		20.55		8	SLG		TSC	+0.69	TEH	TEC	560DT	23		COLD
16	46				NDD				TEH	TEC	560UL	97		COLD
16	47				NDD				TSH	TSH	560PP	63		HOT
					NDD				TEH	TEC	560UL	97		COLD
16	48				NDD				TSH	TSH	560PP	63		HOT
					NDD				TEH	TEC	560UL	97		COLD
16	49				NDD				TSH	TSH	560PP	63		HOT
					NDD				TEH	TEC	560UL	97		COLD
16	50				NDD				TSH	TSH	560PP	63		HOT
					NDD				TEH	TEC	560UL	97		COLD
16	51				NDD				TEH	TEC	560UL	97		COLD
16	52				NDD				TEH	TEC	560UL	97		COLD
16	53				NDD				TEH	TEC	560UL	97		COLD
16	54				NDD				TEH	TEC	560UL	97		COLD
16	55				NDD				TSH	TSH	560PP	64		HOT
					NDD				TEH	TEC	560UL	97		COLD
16	56				NDD				TSH	TSH	560PP	64		HOT
					NDD				TEH	TEC	560UL	97		COLD
16	57				NDD				TSH	TSH	560PP	65		HOT
					NDD				TEH	TEC	560UL	97		COLD
16	58				NDD				TSH	TSH	560PP	66		HOT
					NDD				TEH	TEC	560UL	97		COLD
16	59				NDD				TEH	TEC	560UL	97		COLD
16	60	26.06		8	SLG		TSH	+2.29	TEH	TEC	560UC	66		COLD
16	61	42.28		8	SLG		TSH	+4.76	TEH	TEC	560UL	48		COLD
		41.42		8	SLG		TSC	+1.35	TEH	TEC	560UL	48		COLD
16	62	40.92		8	SLG		TSC	+1.43	TEH	TEC	560UL	49		COLD
					INF		04H	+6.60	TEH	TEC	560UL	49	HR	COLD
16	63	40.85		8	SLG		TSH	+5.17	TEH	TEC	560UL	48		COLD
		18.13		8	SLG		TSC	+0.99	TEH	TEC	560UL	48		COLD
					NDD				TSH	TSH	560PP	33		HOT
16	64	25.24		8	SLG		TSH	+5.45	TEH	TEC	560UL	49		COLD
					NDD				TSH	TSH	560PP	33		HOT
16	65				NDD				TEH	TEC	560UL	48		COLD
					NDD				TSH	TSH	560PP	33		HOT
16	66				NDD				TEH	TEC	560UL	49		COLD
					NDD				TSH	TSH	560PP	33		HOT
16	67				NDD				TEH	TEC	560UL	48		COLD
16	68				NDD				TEH	TEC	560UL	49		COLD
16	69				NDD				TEH	TEC	560UL	48		COLD
16	70				NDD				TEH	TEC	560UL	49		COLD
16	71				NDD				TEH	TEC	560UL	48		COLD
					NDD				TSH	TSH	560PP	33		HOT
16	72				NDD				TEH	TEC	560UL	49		COLD
					NDD				TSH	TSH	560PP	33		HOT
16	73				NDD				TEH	TEC	560UL	48		COLD
					NDD				TSH	TSH	560PP	33		HOT
16	74				NDD				TEH	TEC	560UL	49		COLD
					NDD				TSH	TSH	560PP	33		HOT
16	75				NDD				TEH	TEC	560UL	48		COLD
16	76				NDD				TEH	TEC	560UL	49		COLD
16	77				NDD				TEH	TEC	560DT	37		COLD
16	78				NDD				TEH	TEC	560DT	37		COLD
16	79				NDD				TSH	TSH	560PP	16		HOT
					NDD				TEH	TEC	560DT	37		COLD
16	80				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	37		COLD
16	81				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	38		COLD
16	82				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	38		COLD
16	83				NDD				TEH	TEC	560DT	40		COLD
16	84				NDD				TEH	TEC	560DT	40		COLD
16	85				NDD				TEH	TEC	560UL	39		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
16	86				NDD			TEH	TEC	560DT	40			COLD
16	87				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560UL	39			COLD
16	88				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
16	89				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
16	90				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
16	91				NDD			TEH	TEC	560UL	39			COLD
16	92				NDD			TEH	TEC	560DT	40			COLD
16	93	15.89		8	SLG		TSC	TEH	TEC	560UL	39			COLD
16	94	19.45		8	SLG		TSC	TEH	TEC	560DT	40			COLD
16	95				NDD			TSH	TSH	560PP	18			HOT
		22.93		8	SLG		TSC	TEH	TEC	560UL	41			COLD
		3.06	182	1	DNG		AV6	TEH	TEC	560UL	41			COLD
16	96				RBD			TEH	TEC	560DT	42			COLD
					NDD			TEH	TEC	560UC	70			COLD
					NDD			TSH	TSH	560PP	19			HOT
16	97				NDD			TSH	TSH	560PP	18			HOT
		18.52		8	SLG		TSC	TEH	TEC	560UL	41			COLD
16	98				RBD			TEH	TEC	560DT	42			COLD
					NDD			TEH	TEC	560UC	70			COLD
					NDD			TSH	TSH	560PP	19			HOT
16	99				NDD			TEH	TEC	560UL	41			COLD
16	100				NDD			TEH	TEC	560DT	42			COLD
16	101				NDD			TEH	TEC	560UL	41			COLD
16	102				NDD			TEH	TEC	560UL	41			COLD
16	103				NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	43			COLD
16	104				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
16	105				NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	43			COLD
16	106				NDD			TEH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
				3	NDF		TSH	TEH	TSH	560PP	62			HOT
16	107				NDD			TEH	TEC	560UL	44			COLD
16	108	3.04		184	1		DNG	TEH	TEC	560UL	45			COLD
16	109				NDD			TEH	TEC	560UL	44			COLD
16	110				NDD			TEH	TEC	560UL	45			COLD
16	111				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
16	112				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UC	72			COLD
16	113				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
16	114				NDD			TSH	TSH	560PP	20			HOT
					RBD			TEH	TEC	560UL	81			COLD
					NDD			TEH	TEC	560UC	72			COLD
16	115				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
16	116				RBD			TEH	TEC	560UL	81			COLD
					NDD			TEH	TEC	560UC	72			COLD
16	117				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
16	118				RBD			TEH	TEC	560UL	81			COLD
					NDD			TEH	TEC	560UC	72			COLD
16	119				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	67			HOT
					NDD			TEH	TEC	560UC	72			COLD
16	120				NDD			TSH	TSH	560PP	67			HOT
					RBD			TEH	TEC	560UL	81			COLD
					NDD			TEH	TEC	560UC	72			COLD
17	4				NDD			TEH	TEC	560DT	16			COLD
17	5				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560DT	17			COLD
17	6				NDD			TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	44			HOT
17	7				NDD			TSH	TSH	560PP	45			HOT
		15.85		8	SLG		TSC	TEH	TEC	560DT	17			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	WTW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
17	8				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560DT	16			COLD
17	9				NDD			TEH	TEC	560DT	16			COLD
17	10	16.02		8	SLG		TSH	TEH	TEC	560DT	16			COLD
17	11	15.94		8	SLG		TSH	TEH	TEC	560DT	16			COLD
17	12				NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560DT	17			COLD
17	13	16.65		8	SLG		TSH	TEH	TEC	560DT	16			COLD
17	14	17.82		8	SLG		TSH	TEH	TEC	560DT	17			COLD
17	15				NDD			TSH	TSH	560PP	45			HOT
		17.80		8	SLG		TSH	TEH	TEC	560DT	16			COLD
17	16	18.63		8	SLG		TSH	TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	44			HOT
17	17				NDD			TSH	TSH	560PP	45			HOT
		17.74		8	SLG		TSH	TEH	TEC	560DT	16			COLD
17	18	18.08		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		16.03		8	SLG		TSC	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
17	19	17.01		8	SLG		TSH	TEH	TEC	560DT	18			COLD
		15.64		8	SLG		TSC	TEH	TEC	560DT	18			COLD
17	20	18.08		8	SLG		TSH	TEH	TEC	560DT	18			COLD
17	21	17.41		8	SLG		TSH	TEH	TEC	560DT	18			COLD
17	22	17.81		8	SLG		TSH	TEH	TEC	560DT	19			COLD
17	23	18.42		8	SLG		TSH	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
17	24	18.16		8	SLG		TSH	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
17	25	18.84		8	SLG		TSH	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
17	26	18.72		8	SLG		TSH	TEH	TEC	560DT	21			COLD
		16.19		8	SLG		TSC	TEH	TEC	560DT	21			COLD
					NDD			TEH	TSH	560PP	42			HOT
17	27	18.87		8	SLG		TSH	TEH	TEC	560DT	20			COLD
		15.15		8	SLG		TSC	TEH	TEC	560DT	20			COLD
17	28	18.39		8	SLG		TSH	TEH	TEC	560DT	21			COLD
		15.42		8	SLG		TSC	TEH	TEC	560DT	21			COLD
17	29				NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560DT	20			COLD
17	30	17.45		8	SLG		TSH	TEH	TEC	560DT	21			COLD
17	31				NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	43			HOT
17	32				NDD			TSH	TSH	560PP	40			HOT
		17.59		8	SLG		TSH	TEH	TEC	560DT	21			COLD
17	33	18.29		8	SLG		TSH	TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	41			HOT
17	34	18.25		8	SLG		TSH	TEH	TEC	560DT	21			COLD
					NDD			TSH	TSH	560PP	41			HOT
17	35				NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560DT	20			COLD
17	36	17.61		8	SLG		TSH	TEH	TEC	560DT	21			COLD
17	37	17.98		8	SLG		TSH	TEH	TEC	560DT	20			COLD
17	38	18.28		8	SLG		TSH	TEH	TEC	560DT	23			COLD
17	39	17.76		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	41			HOT
17	40	17.30		8	SLG		TSH	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
17	41	17.60		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	41			HOT
17	42	17.92		8	SLG		TSH	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
17	43	17.42		8	SLG		TSH	TEH	TEC	560DT	22			COLD
17	44	17.44		8	SLG		TSH	TEH	TEC	560DT	23			COLD
		19.28		8	SLG		TSC	TEH	TEC	560DT	23			COLD
17	45				NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560DT	22			COLD
17	46				NDD			TEH	TEC	560UL	97			COLD
17	47				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
17	48				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
17	49				NDD			TSH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
17	50				NDD			TSH	TSH	560PP	68			HOT
					NDD			TEH	TEC	560UL	97			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
17	51				NDD			TEH	TEC	560UL	97			COLD
17	52				NDD			TEH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
17	53				NDD			TEH	TEC	560UL	97			COLD
17	54				NDD			TEH	TSH	560PP	63			HOT
					NDD			TEH	TEC	560UL	97			COLD
17	55				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UL	97			COLD
17	56				NDD			TSH	TSH	560PP	64			HOT
					NDD			TEH	TEC	560UL	97			COLD
17	57				NDD			TSH	TSH	560PP	65			HOT
					NDD			TEH	TEC	560UL	97			COLD
17	58				NDD			TSH	TSH	560PP	65			HOT
					NDD			TEH	TEC	560UL	97			COLD
17	59				NDD			TEH	TEC	560UL	97			COLD
17	60	25.05		8	SLG		TSH	TEH	TEC	560UC	66			COLD
17	61	41.46		8	SLG		TSH	TEH	TEC	560UL	48			COLD
		39.63		8	SLG		TSC	TEH	TEC	560UL	48			COLD
17	62	41.83		8	SLG		TSH	TEH	TEC	560UL	48			COLD
		40.52		8	SLG		TSC	TEH	TEC	560UL	48			COLD
17	63	42.24		8	SLG		TSH	TEH	TEC	560UL	48			COLD
		19.88		8	SLG		TSC	TEH	TEC	560UL	48			COLD
					NDD			TSH	TSH	560PP	32			HOT
17	64	29.73		8	SLG		TSH	TEH	TEC	560UL	49			COLD
					NDD			TSH	TSH	560PP	32			HOT
17	65				NDD			TEH	TEC	560UL	48			COLD
					NDD			TSH	TSH	560PP	32			HOT
17	66				NDD			TEH	TEC	560UL	49			COLD
					NDD			TSH	TSH	560PP	32			HOT
17	67				NDD			TEH	TEC	560UL	48			COLD
17	68				NDD			TEH	TEC	560UL	49			COLD
17	69				NDD			TEH	TEC	560UL	48			COLD
17	70				NDD			TEH	TEC	560UL	49			COLD
17	71				NDD			TEH	TEC	560UL	48			COLD
					NDD			TSH	TSH	560PP	32			HOT
17	72				NDD			TEH	TEC	560UL	49			COLD
					NDD			TSH	TSH	560PP	32			HOT
17	73				NDD			TEH	TEC	560UL	48			COLD
					NDD			TSH	TSH	560PP	32			HOT
17	74				NDD			TEH	TEC	560UL	49			COLD
					NDD			TSH	TSH	560PP	32			HOT
17	75				NDD			TEH	TEC	560UL	48			COLD
17	76				NDD			TEH	TEC	560UL	49			COLD
17	77				NDD			TEH	TEC	560UL	36			COLD
17	78				NDD			TEH	TEC	560UL	36			COLD
17	79				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560UL	36			COLD
17	80				NDD			TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
17	81				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	38			COLD
17	82				NDD			TEH	TEC	560DT	38			COLD
					NDD			TSH	TSH	560PP	16			HOT
17	83				NDD			TEH	TEC	560UL	39			COLD
17	84	0.69	125	3	INR		03H	TEH	TEC	560UL	39			COLD
17	85				NDD			TEH	TEC	560DT	40			COLD
17	86	0.57	139	1	TFH		08C	TEH	TEC	560UL	39			COLD
17	87				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
17	88				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
17	89				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
17	90				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
17	91				NDD			TEH	TEC	560DT	40			COLD
17	92				NDD			TEH	TEC	560UL	39			COLD
17	93	17.01		8	SLG		TSC	TEH	TEC	560DT	40			COLD
17	94	0.67	116	1	INR		08C	TEH	TEC	560UL	39			COLD
		19.42		8	SLG		TSC	TEH	TEC	560UL	39			COLD
17	95				RBD			TEH	TEC	560DT	42			COLD
					NDD			TEH	TEC	560UC	70			COLD
					NDD			TSH	TSH	560PP	19			HOT
17	96				NDD			TSH	TSH	560PP	18			HOT
		23.52		8	SLG		TSC	TEH	TEC	560UL	41			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
17	97				RBD			TEH	TEC	560DT	42			COLD
					NDD			TEH	TEC	560UC	70			COLD
					NDD			TSH	TSH	560PP	19			HOT
17	98	23.81		8	SLG		TSC	+0.62	TEH	TEC	560UL	41		COLD
					NDD			TEH	TEC	560DT	42			COLD
17	99				NDD			TEH	TEC	560UL	41			COLD
17	100				NDD			TEH	TEC	560UL	41			COLD
17	101				NDD			TEH	TEC	560UL	41			COLD
17	102				NDD			TEH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	41			COLD
17	103				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
17	104				NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	43			COLD
17	105				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
17	106				NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	43			COLD
17	107				NDD			TEH	TEC	560UL	43			COLD
17	108	0.91		3	NDF		07H	+30.90	07H	08H	560PP	62		HOT
			152	1	INR		07C	+37.34	TEH	TEC	560UL	44		COLD
17	109				NDD			TEH	TEC	560UL	45			COLD
17	110				NDD			TEH	TEC	560UL	44			COLD
17	111				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UC	72			COLD
17	112				NDD			TEH	TEC	560UL	106			COLD
					NDD			TSH	TSH	560PP	20			HOT
					RBD			TEH	TEC	560UL	81			COLD
17	113				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
17	114				NDD			TEH	TEC	560UL	106			COLD
					NDD			TSH	TSH	560PP	20			HOT
					RBD			TEH	TEC	560UL	81			COLD
17	115				NDD			TEH	TEC	560UC	80	IDOK		COLD
					NDD			TEH	TEC	560UC	72			COLD
17	116	3.10		179	1		DNG	07H	+28.17	TEH	TEC	560UL	106	COLD
					RBD			TEH	TEC	560UL	81			COLD
17	117				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
17	118				NDD			TEH	TEC	560UL	106			COLD
					RBD			TEH	TEC	560UL	81			COLD
17	119				NDD			TSH	TSH	560PP	67			HOT
					NDD			TEH	TEC	560UL	81			COLD
18	4				NDD			TEH	TEC	560DT	17			COLD
18	5				NDD			TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	44			HOT
18	6	15.78		8	NDD			TSH	TSH	560PP	45			HOT
					SLG		TSC	+0.47	TEH	TEC	560DT	17		COLD
18	7				NDD			TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	44			HOT
18	8	15.62		8	SLG		TSH	+0.47	TEH	TEC	560DT	17		COLD
		15.30		8	SLG		TSC	+0.44	TEH	TEC	560DT	17		COLD
					NDD			TSH	TSH	560PP	44			HOT
18	9				NDD			TEH	TEC	560DT	16			COLD
18	10	16.60		8	SLG		TSH	+0.49	TEH	TEC	560DT	17		COLD
18	11	16.76		8	SLG		TSH	+0.54	TEH	TEC	560DT	17		COLD
18	12	16.20		8	SLG		TSH	+0.49	TEH	TEC	560DT	16		COLD
18	13	15.78		8	SLG		TSH	+0.49	TEH	TEC	560DT	17		COLD
18	14	17.25		8	SLG		TSH	+0.54	TEH	TEC	560DT	16		COLD
18	15	17.60		8	SLG		TSH	+0.54	TEH	TEC	560DT	17		COLD
					NDD			TSH	TSH	560PP	44			HOT
18	16				NDD			TSH	TSH	560PP	45			HOT
		18.66		8	SLG		TSH	+0.67	TEH	TEC	560DT	17		COLD
18	17	18.99		8	SLG		TSH	+0.62	TEH	TEC	560DT	17		COLD
		16.72		8	SLG		TSC	+0.47	TEH	TEC	560DT	17		COLD
					NDD			TSH	TSH	560PP	44			HOT
18	18	18.10		8	SLG		TSH	+0.62	TEH	TEC	560DT	18		COLD
					NDD			TSH	TSH	560PP	43			HOT
18	19	17.53		8	SLG		TSH	+0.59	TEH	TEC	560DT	19		COLD
		15.50		8	SLG		TSC	+0.47	TEH	TEC	560DT	19		COLD
18	20	17.04		8	SLG		TSH	+0.59	TEH	TEC	560DT	19		COLD
18	21	18.32		8	SLG		TSH	+0.62	TEH	TEC	560DT	19		COLD
18	22	17.97		8	SLG		TSH	+0.62	TEH	TEC	560DT	18		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
18	23	18.81		8	SLG		TSH	+0.69	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
18	24	18.44		8	SLG		TSH	+0.65	TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	43		HOT
18	25	18.59		8	SLG		TSH	+0.65	TEH	TEC	560DT	19		COLD
		15.42		8	SLG		TSC	+0.44	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
18	26	18.67		8	SLG		TSH	+0.65	TEH	TEC	560DT	20		COLD
		15.40		8	SLG		TSC	+0.44	TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	43		HOT
18	27	18.63		8	SLG		TSH	+0.64	TEH	TEC	560DT	21		COLD
		15.62		8	SLG		TSC	+0.44	TEH	TEC	560DT	21		COLD
18	28	19.43		8	SLG		TSH	+0.67	TEH	TEC	560DT	20		COLD
18	29	18.31		8	SLG		TSH	+0.64	TEH	TEC	560DT	21		COLD
18	30	18.15		8	SLG		TSH	+0.62	TEH	TEC	560DT	20		COLD
18	31	17.87		8	SLG		TSH	+0.62	TEH	TEC	560DT	21		COLD
					NDD				TSH	TSH	560PP	42		HOT
18	32				NDD				TSH	TSH	560PP	40		HOT
		18.27		8	SLG		TSH	+0.62	TEH	TEC	560DT	20		COLD
18	33				NDD				TSH	TSH	560PP	40		HOT
		18.23		8	SLG		TSH	+0.66	TEH	TEC	560DT	21		COLD
18	34	18.63		8	SLG		TSH	+0.65	TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	40		HOT
18	35	17.53		8	SLG		TSH	+0.61	TEH	TEC	560DT	21		COLD
18	36	18.27		8	SLG		TSH	+0.59	TEH	TEC	560DT	20		COLD
18	37	17.39		8	SLG		TSH	+0.61	TEH	TEC	560DT	21		COLD
18	38	17.86		8	SLG		TSH	+0.57	TEH	TEC	560DT	22		COLD
18	39	17.80		8	SLG		TSH	+0.59	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
18	40	17.70		8	SLG		TSH	+0.57	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
18	41	17.42		8	SLG		TSH	+0.56	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
18	42	17.24		8	SLG		TSH	+0.54	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
18	43	18.65		8	SLG		TSH	+0.66	TEH	TEC	560DT	23		COLD
		16.61		8	SLG		TSC	+0.47	TEH	TEC	560DT	23		COLD
18	44	17.86		8	SLG		TSH	+0.68	TEH	TEC	560DT	22		COLD
		16.98		8	SLG		TSC	+0.51	TEH	TEC	560DT	22		COLD
18	45	18.42		8	SLG		TSH	+0.67	TEH	TEC	560DT	23		COLD
		19.69		8	SLG		TSC	+0.63	TEH	TEC	560DT	23		COLD
18	46	19.71		8	SLG		TSH	+0.69	TEH	TEC	560DT	22		COLD
		17.48		8	SLG		TSC	+0.53	TEH	TEC	560DT	22		COLD
18	47	18.96		8	SLG		TSH	+0.75	TEH	TEC	560DT	23		COLD
		20.17		8	SLG		TSC	+0.59	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
18	48	21.30		8	SLG		TSH	+0.70	TEH	TEC	560DT	25		COLD
		22.16		8	SLG		TSC	+0.62	TEH	TEC	560DT	25		COLD
					NDD				TSH	TSH	560PP	41		HOT
18	49	20.89		8	SLG		TSH	+0.66	TEH	TEC	560DT	25		COLD
		27.85		8	SLG		TSC	+0.89	TEH	TEC	560DT	25		COLD
					NDD				TSH	TSH	560PP	41		HOT
18	50	22.98		8	SLG		TSH	+0.91	TEH	TEC	560DT	25		COLD
		24.02		8	SLG		TSC	+0.75	TEH	TEC	560DT	25		COLD
					NDD				TSH	TSH	560PP	36		HOT
18	51	23.43		8	SLG		TSH	+0.73	TEH	TEC	560DT	25		COLD
		22.07		8	SLG		TSC	+0.74	TEH	TEC	560DT	25		COLD
18	52	19.37		8	SLG		TSC	+0.56	TEH	TEC	560DT	24		COLD
18	53	25.47		8	SLG		TSH	+0.88	TEH	TEC	560DT	25		COLD
		21.75		8	SLG		TSC	+0.62	TEH	TEC	560DT	25		COLD
18	54				NDD				TEH	TEC	560UL	46		COLD
					RBD				TEH	TEC	560DT	26		COLD
18	55				NDD				TEH	TEC	560UL	46		COLD
					RBD				TEH	TEC	560DT	26		COLD
					NDD				TSH	TSH	560PP	34		HOT
18	56				NDD				TEH	TEC	560UL	46		COLD
					NDD				TSH	TSH	560PP	34		HOT
18	57				NDD				TEH	TEC	560UL	47		COLD
					NDD				TSH	TSH	560PP	34		HOT
18	58				NDD				TEH	TEC	560UL	46		COLD
					NDD				TSH	TSH	560PP	34		HOT
18	59				NDD				TEH	TEC	560UL	47		COLD
18	60	25.94		8	SLG		TSH	+1.82	TEH	TEC	560UL	46		COLD
18	61	43.09		8	SLG		TSH	+2.36	TEH	TEC	560DT	34		COLD
		40.83		8	SLG		TSC	+1.68	TEH	TEC	560DT	34		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
18	62	42.74		8	SLG		TSC	+2.10	TEH	TEC	560DT	35		COLD
18	63				NDD				TSH	TSH	560PP	14		HOT
		42.37		8	SLG		TSH	+2.50	TEH	TEC	560DT	34		COLD
		21.48		8	SLG		TSC	+0.95	TEH	TEC	560DT	34		COLD
18	64				NDD				TSH	TSH	560PP	15		HOT
		28.70		8	SLG		TSH	+3.18	TEH	TEC	560DT	35		COLD
18	65				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	34		COLD
18	66				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	35		COLD
18	67				NDD				TEH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	37		COLD
18	68				NDD				TEH	TEC	560DT	37		COLD
18	69				NDD				TEH	TEC	560UL	36		COLD
18	70				NDD				TEH	TEC	560DT	37		COLD
18	71				NDD				TEH	TEC	560UL	36		COLD
					NDD				TSH	TSH	560PP	16		HOT
18	72				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	35		COLD
18	73				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	35		COLD
18	74				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	35		COLD
18	75				NDD				TEH	TEC	560DT	35		COLD
18	76				NDD				TEH	TEC	560DT	35		COLD
18	77				NDD				TEH	TEC	560DT	37		COLD
18	78				NDD				TEH	TEC	560DT	37		COLD
18	79				NDD				TSH	TSH	560PP	16		HOT
					NDD				TEH	TEC	560DT	37		COLD
18	80				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	37		COLD
18	81				NDD				TEH	TEC	560DT	38		COLD
					NDD				TSH	TSH	560PP	16		HOT
18	82				NDD				TSH	TSH	560PP	17		HOT
	0.68	111	3		NQH		02C	+31.51	TEH	TEC	560DT	38		COLD
	4.60	188	1		DNG		03C	-0.82	TEH	TEC	560DT	38		COLD
18	83				NDD				TEH	TEC	560DT	40		COLD
18	84				NDD				TEH	TEC	560DT	40		COLD
18	85				NDD				TEH	TEC	560UL	39		COLD
18	86				NDD				TEH	TEC	560DT	40		COLD
18	87				NDD				TEH	TEC	560UL	39		COLD
					NDD				TSH	TSH	560PP	16		HOT
18	88				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	40		COLD
18	89				NDD				TEH	TEC	560UL	39		COLD
					NDD				TSH	TSH	560PP	16		HOT
18	90				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	40		COLD
18	91				NDD				TEH	TEC	560UL	39		COLD
18	92				NDD				TEH	TEC	560DT	40		COLD
18	93	18.91		8	SLG		TSC	+0.58	TEH	TEC	560UL	39		COLD
18	94	21.62		8	SLG		TSC	+0.59	TEH	TEC	560DT	40		COLD
18	95				NDD				TSH	TSH	560PP	18		HOT
	24.64			8	SLG		TSC	+0.59	TEH	TEC	560UL	41		COLD
18	96				RBD				TEH	TEC	560DT	42		COLD
					NDD				TEH	TEC	560UC	70		COLD
					NDD				TSH	TSH	560PP	19		HOT
18	97				NDD				TSH	TSH	560PP	18		HOT
	23.94			8	SLG		TSC	+0.65	TEH	TEC	560UL	41		COLD
18	98				RBD				TEH	TEC	560DT	42		COLD
					NDD				TEH	TEC	560UC	70		COLD
					NDD				TSH	TSH	560PP	19		HOT
18	99				NDD				TEH	TEC	560UL	41		COLD
18	100				NDD				TEH	TEC	560DT	42		COLD
18	101				NDD				TEH	TEC	560UL	41		COLD
18	102				NDD				TEH	TEC	560UL	41		COLD
18	103				NDD				TSH	TSH	560PP	20		HOT
					NDD				TEH	TEC	560UL	43		COLD
18	104				NDD				TSH	TSH	560PP	21		HOT
					NDD				TEH	TEC	560UL	43		COLD
18	105				NDD				TSH	TSH	560PP	20		HOT
					NDD				TEH	TEC	560UL	43		COLD
18	106				NDD				TSH	TSH	560PP	21		HOT
					NDD				TEH	TEC	560UL	43		COLD
18	107				NDD				TEH	TEC	560UL	43		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
18	108				NDD			TEH	TEC	560UL	45			COLD
18	109				NDD			TEH	TEC	560UL	44			COLD
18	110				NDD			TEH	TEC	560UL	45			COLD
18	111				NDD			TEH	TEC	560UC	80	IDOK		COLD
					NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
18	112				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UC	72			COLD
18	113				NDD			TEH	TEC	560UL	106			COLD
					NDD			TSH	TSH	560PP	20			HOT
					RBD			TEH	TEC	560UL	81			COLD
18	114				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
18	115				NDD			TEH	TEC	560UL	106			COLD
					RBD			TEH	TEC	560UL	81			COLD
18	116				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
18	117				NDD			TEH	TEC	560UL	106			COLD
					RBD			TEH	TEC	560UL	81			COLD
18	118				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
18	119				NDD			TSH	TSH	560PP	67			HOT
					NDD			TEH	TEC	560UL	81			COLD
19	5				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560DT	17			COLD
19	6				NDD			TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	44			HOT
19	7				NDD			TSH	TSH	560PP	45			HOT
	15.42			8	SLG		TSC	TEH	TEC	560DT	17			COLD
19	8				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560DT	16			COLD
19	9	15.40		8	SLG		TSH	TEH	TEC	560DT	17			COLD
	15.40			8	SLG		TSC	TEH	TEC	560DT	17			COLD
19	10	15.64		8	SLG		TSH	TEH	TEC	560DT	16			COLD
19	11	16.65		8	SLG		TSH	TEH	TEC	560DT	16			COLD
19	12	16.85		8	SLG		TSH	TEH	TEC	560DT	17			COLD
	15.25			8	SLG		TSC	TEH	TEC	560DT	17			COLD
19	13	16.97		8	SLG		TSH	TEH	TEC	560DT	16			COLD
19	14	0.59	107	3	NQH		04C	TEH	TEC	560DT	17			COLD
	18.40			8	SLG		TSH	TEH	TEC	560DT	17			COLD
19	15				NDD			TSH	TSH	560PP	45			HOT
	17.13			8	SLG		TSH	TEH	TEC	560DT	16			COLD
19	16	0.88	125	3	INR		AV6	TEH	TEC	560DT	16			COLD
	0.87		122	3	INR		04H	TEH	TEC	560DT	16			COLD
	17.46			8	SLG		TSH	TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	44			HOT
19	17				NDD			TSH	TSH	560PP	45			HOT
	17.68			8	SLG		TSH	TEH	TEC	560DT	16			COLD
	0.51			66	TFH		08H	TEH	TEC	560DT	16			COLD
19	18	16.93		8	SLG		TSH	TEH	TEC	560DT	19			COLD
	15.95			8	SLG		TSC	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
19	19	17.29		8	SLG		TSH	TEH	TEC	560DT	18			COLD
	15.72			8	SLG		TSC	TEH	TEC	560DT	18			COLD
	0.65			127	TFS		08H	TEH	TEC	560DT	18			COLD
				3	NDF		08H	AV1	08H	5201P	75			HOT
					RBD			AV1	08H	5201P	74			HOT
19	20	17.87		8	SLG		TSH	TEH	TEC	560DT	18			COLD
19	21	18.28		8	SLG		TSH	TEH	TEC	560DT	18			COLD
19	22	18.40		8	SLG		TSH	TEH	TEC	560DT	19			COLD
19	23	18.66		8	SLG		TSH	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
19	24	19.02		8	SLG		TSH	TEH	TEC	560DT	19			COLD
	15.16			8	SLG		TSC	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
19	25	18.28		8	SLG		TSH	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
19	26	18.27		8	SLG		TSH	TEH	TEC	560DT	21			COLD
	15.54			8	SLG		TSC	TEH	TEC	560DT	21			COLD
					NDD			TSH	TSH	560PP	42			HOT
19	27	16.54		8	SLG		TSC	TEH	TEC	560DT	20			COLD
19	28	18.80		8	SLG		TSH	TEH	TEC	560DT	21			COLD
19	29	18.57		8	SLG		TSH	TEH	TEC	560DT	20			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
19	30	0.53	118	3	INR		04C	+37.37						
		18.61		8	SLG		TSH	+0.67	TEH	TEC	560DT	21		COLD
19	31	18.93		8	SLG		TSH	+0.64	TEH	TEC	560DT	21		COLD
					NDD				TEH	TEC	560DT	20		COLD
					TSH				TSH	TSH	560PP	43		HOT
19	32	18.92		8	SLG		TSH	+0.67	TSH	TSH	560PP	40		HOT
					NDD				TEH	TEC	560DT	21		COLD
19	33				NDD				TEH	TEC	560DT	20		COLD
					TSH				TSH	TSH	560PP	41		HOT
19	34	18.21		8	SLG		TSH	+0.64	TEH	TEC	560DT	21		COLD
					NDD				TSH	TSH	560PP	41		HOT
19	35	18.87		8	SLG		TSH	+0.62	TEH	TEC	560DT	20		COLD
19	36	18.31		8	SLG		TSH	+0.64	TEH	TEC	560DT	21		COLD
19	37	17.74		8	SLG		TSH	+0.62	TEH	TEC	560DT	20		COLD
19	38	19.30		8	SLG		TSH	+0.64	TEH	TEC	560DT	23		COLD
19	39	18.08		8	SLG		TSH	+0.59	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
19	40	18.21		8	SLG		TSH	+0.59	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
19	41	17.40		8	SLG		TSH	+0.55	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
19	42	18.11		8	SLG		TSH	+0.61	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
19	43	17.34		8	SLG		TSH	+0.57	TEH	TEC	560DT	22		COLD
19	44	17.73		8	SLG		TSH	+0.53	TEH	TEC	560DT	23		COLD
19	45	17.98		8	SLG		TSC	+0.57	TEH	TEC	560DT	22		COLD
19	46	18.67		8	SLG		TSH	+0.60	TEH	TEC	560DT	23		COLD
		17.67		8	SLG		TSC	+0.50	TEH	TEC	560DT	23		COLD
19	47	18.99		8	SLG		TSH	+0.72	TEH	TEC	560DT	22		COLD
		18.89		8	SLG		TSC	+0.59	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
19	48				NDD				TEH	TEC	560UL	46		COLD
					RBD				TEH	TEC	560DT	24		COLD
					NDD				TSH	TSH	560PP	40		HOT
19	49	23.07		8	SLG		TSC	+0.75	TEH	TEC	560DT	24		COLD
					NDD				TSH	TSH	560PP	40		HOT
19	50	19.74		8	SLG		TSH	+1.00	TEH	TEC	560DT	24		COLD
		20.79		8	SLG		TSC	+0.65	TEH	TEC	560DT	24		COLD
					NDD				TSH	TSH	560PP	34		HOT
19	51				NDD				TEH	TEC	560DT	24		COLD
19	52	22.21		8	SLG		TSH	+0.73	TEH	TEC	560DT	25		COLD
		21.82		8	SLG		TSC	+0.64	TEH	TEC	560DT	25		COLD
		0.52	83	1	TFH		08H	+1.89	TEH	TEC	560DT	25		COLD
				2	NDF		08H	+1.89	AV1	08H	5201P	72		HOT
19	53	19.86		8	SLG		TSH	+0.60	TEH	TEC	560DT	24		COLD
		20.90		8	SLG		TSC	+0.59	TEH	TEC	560DT	24		COLD
19	54	19.66		8	SLG		TSH	+0.70	TEH	TEC	560DT	26		COLD
		17.89		8	SLG		TSC	+0.54	TEH	TEC	560DT	26		COLD
19	55	20.27		8	SLG		TSH	+0.69	TEH	TEC	560DT	27		COLD
		17.47		8	SLG		TSC	+0.49	TEH	TEC	560DT	27		COLD
					NDD				TSH	TSH	560PP	34		HOT
19	56				NDD				TEH	TEC	560UL	46		COLD
					NDD				TSH	TSH	560PP	36		HOT
19	57				NDD				TEH	TEC	560UL	46		COLD
					NDD				TSH	TSH	560PP	34		HOT
19	58	0.91	78	3	NQH		AV1	+16.68	TEH	TEC	560UL	47		COLD
					NDD				TSH	TSH	560PP	35		HOT
19	59				NDD				TEH	TEC	560UL	46		COLD
19	60				NDD				TEH	TEC	560UL	47		COLD
19	61	26.72		8	SLG		TSC	+0.74	TEH	TEC	560DT	35		COLD
19	62	40.32		8	SLG		TSH	+1.53	TEH	TEC	560DT	34		COLD
		28.45		8	SLG		TSC	+1.18	TEH	TEC	560DT	34		COLD
19	63				NDD				TSH	TSH	560PP	15		HOT
		41.18		8	SLG		TSH	+1.65	TEH	TEC	560DT	35		COLD
19	64	0.47	142	P 1	SSA		TSH	+0.14	TSH	TSH	560PP	14		HOT
		21.52		8	SLG		TSH	+1.10	TEH	TEC	560DT	34		COLD
19	65				NDD				TSH	TSH	560PP	15		HOT
		0.49	120	3	INR		02C	+4.67	TEH	TEC	560DT	35		COLD
19	66				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	34		COLD
19	67				NDD				TEH	TEC	560DT	37		COLD
19	68				NDD				TEH	TEC	560UL	36		COLD
19	69				NDD				TEH	TEC	560DT	37		COLD
19	70				NDD				TEH	TEC	560UL	36		COLD
19	71				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	37		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
19	72				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
19	73				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
19	74				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
19	75				NDD			TEH	TEC	560DT	35			COLD
19	76				NDD			TEH	TEC	560DT	35			COLD
19	77				NDD			TEH	TEC	560UL	36			COLD
19	78				NDD			TEH	TEC	560UL	36			COLD
19	79				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560UL	36			COLD
19	80				NDD			TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
19	81				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	37			COLD
19	82				NDD			TEH	TEC	560DT	38			COLD
					NDD			TSH	TSH	560PP	16			HOT
19	83				NDD			TEH	TEC	560UL	39			COLD
19	84				NDD			TEH	TEC	560UL	39			COLD
19	85				NDD			TEH	TEC	560DT	40			COLD
19	86				NDD			TEH	TEC	560UL	39			COLD
19	87				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
19	88				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
19	89				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
19	90				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
19	91				NDD			TEH	TEC	560DT	40			COLD
19	92	16.09		8	SLG		TSC	TEH	TEC	560UL	39			COLD
19	93	22.82		8	SLG		TSC	TEH	TEC	560DT	40			COLD
19	94	15.55		8	SLG		TSH	TEH	TEC	560UL	39			COLD
		22.81		8	SLG		TSC	TEH	TEC	560UL	39			COLD
19	95				RBD			TEH	TEC	560DT	42			COLD
					NDD			TEH	TEC	560UC	70			COLD
					NDD			TSH	TSH	560PP	19			HOT
19	96	24.88		8	SLG		TSC	TSH	TSH	560PP	18			HOT
		27.14		8	SLG		TSC	TEH	TEC	560UL	41			COLD
19	97				NDD			TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
19	98	24.53		8	SLG		TSC	TSH	TSH	560PP	18			HOT
					NDD			TEH	TEC	560UL	41			COLD
19	99				NDD			TEH	TEC	560DT	42			COLD
19	100				NDD			TEH	TEC	560UL	41			COLD
19	101				NDD			TEH	TEC	560UL	41			COLD
19	102				NDD			TEH	TEC	560UL	41			COLD
19	103				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
19	104				NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	43			COLD
19	105				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
19	106				NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	43			COLD
19	107				NDD			TEH	TEC	560UL	43			COLD
19	108				NDD			TEH	TEC	560UL	44			COLD
19	109				NDD			TEH	TEC	560UL	45			COLD
19	110				NDD			TEH	TEC	560UL	44			COLD
19	111				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UC	72			COLD
19	112				NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	81			COLD
19	113				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
19	114				NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	81			COLD
19	115				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
19	116				NDD			TEH	TEC	560UL	106			COLD
					RBD			TEH	TEC	560UL	81			COLD
19	117				NDD			TEH	TEC	560UC	80			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
19	118				NDD			TEH	TEC	560UC	72			COLD
					NDD			TEH	TEC	560UL	106			COLD
					RBD			TEH	TEC	560UL	81			COLD
20	5				NDD			TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	44			HOT
20	6				NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560DT	17			COLD
20	7				NDD			TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	44			HOT
20	8	15.99		8	SLG		TSC	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	44			HOT
20	9	15.58		8	SLG		TSC	TEH	TEC	560DT	16			COLD
20	10	15.38		8	SLG		TSH	TEH	TEC	560DT	17			COLD
		16.11		8	SLG		TSC	TEH	TEC	560DT	17			COLD
20	11	16.56		8	SLG		TSC	TEH	TEC	560DT	17			COLD
20	12	16.97		8	SLG		TSH	TEH	TEC	560DT	16			COLD
20	13	16.60		8	SLG		TSH	TEH	TEC	560DT	17			COLD
20	14	16.79		8	SLG		TSH	TEH	TEC	560DT	16			COLD
20	15	18.05		8	SLG		TSH	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	44			HOT
20	16				NDD			TSH	TSH	560PP	45			HOT
		17.23		8	SLG		TSH	TEH	TEC	560DT	17			COLD
20	17	17.78		8	SLG		TSH	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	44			HOT
20	18	17.19		8	SLG		TSH	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
20	19	18.46		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		16.79		8	SLG		TSC	TEH	TEC	560DT	19			COLD
20	20	19.06		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		15.63		8	SLG		TSC	TEH	TEC	560DT	19			COLD
20	21	18.12		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		15.79		8	SLG		TSC	TEH	TEC	560DT	19			COLD
20	22	18.42		8	SLG		TSH	TEH	TEC	560DT	18			COLD
20	23	19.49		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		15.67		8	SLG		TSC	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
20	24	18.78		8	SLG		TSH	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
20	25			3	NDF		07C	07C	07C	560PP	108			COLD
				3	NDF		07C	07C	07C	560PP	108			COLD
		19.26		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		16.01		8	SLG		TSC	TEH	TEC	560DT	19			COLD
		0.34	124	P 1	DSS		07C	TEH	TEC	560DT	19			COLD
		0.27	102	3	NQH		07C	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
20	26	19.21		8	SLG		TSH	TEH	TEC	560DT	20			COLD
		15.52		8	SLG		TSC	TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	43			HOT
20	27	19.80		8	SLG		TSH	TEH	TEC	560DT	21			COLD
		15.64		8	SLG		TSC	TEH	TEC	560DT	21			COLD
20	28	19.09		8	SLG		TSH	TEH	TEC	560DT	20			COLD
20	29	18.59		8	SLG		TSH	TEH	TEC	560DT	21			COLD
20	30	18.45		8	SLG		TSH	TEH	TEC	560DT	20			COLD
20	31	18.13		8	SLG		TSH	TEH	TEC	560DT	21			COLD
					NDD			TSH	TSH	560PP	42			HOT
20	32				NDD			TSH	TSH	560PP	40			HOT
		19.17		8	SLG		TSH	TEH	TEC	560DT	20			COLD
20	33				NDD			TSH	TSH	560PP	40			HOT
		18.21		8	SLG		TSH	TEH	TEC	560DT	21			COLD
20	34	18.93		8	SLG		TSH	TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	40			HOT
20	35	0.53		94	3		05C	TEH	TEC	560DT	21			COLD
20	36	18.91		8	SLG		TSH	TEH	TEC	560DT	20			COLD
20	37	18.37		8	SLG		TSH	TEH	TEC	560DT	21			COLD
20	38	18.97		8	SLG		TSH	TEH	TEC	560DT	22			COLD
20	39	18.21		8	SLG		TSH	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
20	40	18.06		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	41			HOT
20	41	17.75		8	SLG		TSH	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
20	42	18.04		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	41			HOT
20	43	17.52		8	SLG		TSH	TEH	TEC	560DT	23			COLD
20	44	18.24		8	SLG		TSH	TEH	TEC	560DT	22			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
20	45	17.30		8	SLG		TSH	+0.53	TEH	TEC	560DT	23		COLD
20	46	18.70		8	SLG		TSH	+0.63	TEH	TEC	560DT	22		COLD
		15.63		8	SLG		TSC	+0.45	TEH	TEC	560DT	22		COLD
		0.61	39	1	INR		08H	+1.27	TEH	TEC	560DT	22		COLD
20	47	18.19		8	SLG		TSH	+0.56	TEH	TEC	560DT	23		COLD
		16.92		8	SLG		TSC	+0.51	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
20	48	0.54	158	1	INR		08H	+1.06	TEH	TEC	560DT	25		COLD
		20.17		8	SLG		TSH	+0.64	TEH	TEC	560DT	25		COLD
		19.44		8	SLG		TSC	+0.59	TEH	TEC	560DT	25		COLD
					NDD				TSH	TSH	560PP	41		HOT
				2	NDF		08H	+1.06	AV1	08H	5201P	72		HOT
20	49	21.48		8	SLG		TSH	+0.74	TEH	TEC	560DT	25		COLD
		19.83		8	SLG		TSC	+0.57	TEH	TEC	560DT	25		COLD
					NDD				TSH	TSH	560PP	41		HOT
20	50	20.96		8	SLG		TSH	+0.69	TEH	TEC	560DT	25		COLD
		20.17		8	SLG		TSC	+0.60	TEH	TEC	560DT	25		COLD
					NDD				TSH	TSH	560PP	36		HOT
20	51	20.87		8	SLG		TSH	+0.74	TEH	TEC	560DT	25		COLD
		24.54		8	SLG		TSC	+0.74	TEH	TEC	560DT	25		COLD
20	52	19.15		8	SLG		TSH	+0.62	TEH	TEC	560DT	24		COLD
		19.07		8	SLG		TSC	+0.59	TEH	TEC	560DT	24		COLD
20	53	20.55		8	SLG		TSH	+0.77	TEH	TEC	560DT	25		COLD
		18.72		8	SLG		TSC	+0.52	TEH	TEC	560DT	25		COLD
20	54	20.81		8	SLG		TSC	+0.86	TEH	TEC	560DT	27		COLD
20	55	19.22		8	SLG		TSH	+0.72	TEH	TEC	560DT	26		COLD
		16.34		8	SLG		TSC	+0.49	TEH	TEC	560DT	26		COLD
					NDD				TSH	TSH	560PP	36		HOT
20	56	1.84	116	3	INR		02H	+23.57	TEH	TEC	560UL	46		COLD
					NDD				TSH	TSH	560PP	34		HOT
20	57				NDD				TEH	TEC	560UL	47		COLD
					NDD				TSH	TSH	560PP	36		HOT
20	58				NDD				TEH	TEC	560UL	46		COLD
					NDD				TSH	TSH	560PP	34		HOT
20	59				NDD				TEH	TEC	560UL	47		COLD
20	60				NDD				TEH	TEC	560UL	46		COLD
20	61	33.91		8	SLG		TSH	+1.11	TEH	TEC	560DT	34		COLD
20	62	26.72		8	SLG		TSH	+0.87	TEH	TEC	560DT	35		COLD
20	63	0.26	97	P 1	SSA		TSH	+0.10	TSH	TSH	560PP	14		HOT
		21.79		8	SLG		TSH	+0.68	TEH	TEC	560DT	34		COLD
20	64				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	35		COLD
20	65				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	34		COLD
20	66				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	35		COLD
20	67				NDD				TEH	TEC	560DT	37		COLD
20	68				NDD				TEH	TEC	560DT	37		COLD
20	69				NDD				TEH	TEC	560UL	36		COLD
20	70				NDD				TEH	TEC	560DT	37		COLD
20	71				NDD				TEH	TEC	560UL	36		COLD
					NDD				TSH	TSH	560PP	16		HOT
20	72				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	35		COLD
20	73				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	35		COLD
20	74				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	35		COLD
20	75				NDD				TEH	TEC	560UL	36	IDOK	COLD
					NDD				TEH	TEC	560DT	34		COLD
20	76				NDD				TEH	TEC	560DT	35		COLD
20	77				NDD				TEH	TEC	560DT	37		COLD
20	78				NDD				TEH	TEC	560DT	37		COLD
20	79				NDD				TSH	TSH	560PP	16		HOT
					NDD				TEH	TEC	560DT	37		COLD
20	80				NDD				TSH	TSH	560PP	17		HOT
					INF		03C	+28.00	TEH	TEC	560DT	37	HR	COLD
		0.97	104	3	NQH		03C	+25.74	TEH	TEC	560DT	37		COLD
20	81				NDD				TEH	TEC	560UL	36		COLD
					NDD				TSH	TSH	560PP	16		HOT
20	82				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	38		COLD
20	83				NDD				TEH	TEC	560DT	40		COLD
20	84				NDD				TEH	TEC	560DT	40		COLD
20	85				NDD				TEH	TEC	560UL	39		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
20	86				NDD			TEH	TEC	560DT	40			COLD
20	87				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560FP	16			HOT
20	88				NDD			TSH	TSH	560FP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
20	89	4.98	188	1	DNG		03H +23.30	TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560FP	16			HOT
20	90				NDD			TSH	TSH	560FP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
20	91				NDD			TEH	TEC	560UL	39			COLD
20	92				NDD			TEH	TEC	560DT	40			COLD
20	93	0.48	95	3	NQH		05H +3.55	TEH	TEC	560UL	39			COLD
		21.25		8	SLG		TSC +0.63	TEH	TEC	560UL	39			COLD
20	94	25.49		8	SLG		TSC +0.64	TEH	TEC	560DT	40			COLD
20	95				NDD			TSH	TSH	560FP	18			HOT
		25.13		8	SLG		TSC +0.65	TEH	TEC	560UL	41			COLD
20	96	26.98		8	SLG		TSC +0.69	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560FP	19			HOT
20	97				NDD			TSH	TSH	560FP	18			HOT
		28.75		8	SLG		TSC +0.73	TEH	TEC	560UL	41			COLD
20	98	25.51		8	SLG		TSC +0.72	TEH	TEC	560DT	42			COLD
		0.56	95	3	NQH		06C +23.32	TEH	TEC	560DT	42			COLD
		0.46	96	3	NQH		06C +21.57	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560FP	19			HOT
20	99				NDD			TEH	TEC	560UL	41			COLD
20	100				NDD			TEH	TEC	560DT	42			COLD
20	101				NDD			TEH	TEC	560UL	41			COLD
20	102				NDD			TEH	TEC	560UL	41			COLD
20	103				NDD			TSH	TSH	560FP	20			HOT
					NDD			TEH	TEC	560UL	43			COLD
20	104				NDD			TSH	TSH	560FP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
20	105				NDD			TSH	TSH	560FP	20			HOT
					NDD			TEH	TEC	560UL	43			COLD
20	106				NDD			TSH	TSH	560FP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
20	107				NDD			TEH	TEC	560UL	43			COLD
20	108				NDD			TEH	TEC	560UL	45			COLD
20	109				NDD			TEH	TEC	560UL	44			COLD
20	110	0.86	89	3	NQH		07H +27.47	TEH	TEC	560UC	80			COLD
		0.85	89	3	NQH		07H +27.61	TEH	TEC	560UC	72			COLD
20	111	0.62	126	3	INR		03H +38.15	TEH	TEC	560UC	80			COLD
		1.04	68	3	INR		08C +0.66	TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560FP	20			HOT
		0.52	125	3	INR		03H +37.88	TEH	TEC	560UC	72			COLD
		0.42	170	1	INR		08C +0.68	TEH	TEC	560UC	72			COLD
20	112				NDD			TSH	TSH	560FP	21			HOT
					NDD			TEH	TEC	560UL	81			COLD
20	113	1.07	104	3	NQH		06C +36.66	TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560FP	20			HOT
		1.02	99	3	NQH		06C +36.69	TEH	TEC	560UC	72			COLD
20	114				NDD			TSH	TSH	560FP	20			HOT
		1.03	107	3	INR		02H +35.87	TEH	TEC	560UL	81			COLD
20	115	1.00	123	3	INR		07H +26.60	TEH	TEC	560UC	80	IDOK		COLD
		0.92	122	3	INR		07H +26.60	TEH	TEC	560UC	72			COLD
20	116	0.96	116	3	INR		07C +30.50	TEH	TEC	560UL	81			COLD
20	117				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
20	118				NDD			TEH	TEC	560UL	81			COLD
21	5				NDD			TSH	TSH	560FP	45			HOT
					NDD			TEH	TEC	560DT	17			COLD
21	6				NDD			TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560FP	44			HOT
21	7				NDD			TSH	TSH	560FP	45			HOT
					NDD			TEH	TEC	560DT	17			COLD
21	8				NDD			TSH	TSH	560FP	45			HOT
					NDD			TEH	TEC	560DT	16			COLD
21	9	16.68		8	SLG		TSC +0.49	TEH	TEC	560DT	17			COLD
21	10	16.73		8	SLG		TSC +0.52	TEH	TEC	560DT	16			COLD
21	11	16.69		8	SLG		TSC +0.52	TEH	TEC	560DT	16			COLD
21	12	17.25		8	SLG		TSH +0.54	TEH	TEC	560DT	17			COLD
		16.89		8	SLG		TSC +0.49	TEH	TEC	560DT	17			COLD
21	13	16.38		8	SLG		TSH +0.53	TEH	TEC	560DT	16			COLD
21	14	17.72		8	SLG		TSH +0.61	TEH	TEC	560DT	17			COLD
		15.27		8	SLG		TSC +0.44	TEH	TEC	560DT	17			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
21	15	16.99		8	SLG		TSH	+0.52	TEH	TEC	560DT	16		COLD
					NDD				TEH	TSH	560PP	44		HOT
21	16				NDD				TEH	TEC	560DT	16		COLD
					NDD				TSH	TSH	560PP	44		HOT
21	17	17.36		8	SLG		TSH	+0.57	TEH	TEC	560DT	16		COLD
					NDD				TSH	TSH	560PP	43		HOT
21	18	17.59		8	SLG		TSH	+0.59	TEH	TEC	560DT	19		COLD
		16.48		8	SLG		TSC	+0.49	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
21	19	18.84		8	SLG		TSH	+0.62	TEH	TEC	560DT	18		COLD
		16.97		8	SLG		TSC	+0.52	TEH	TEC	560DT	18		COLD
21	20	18.66		8	SLG		TSH	+0.65	TEH	TEC	560DT	18		COLD
		16.85		8	SLG		TSC	+0.49	TEH	TEC	560DT	18		COLD
21	21	18.20		8	SLG		TSH	+0.65	TEH	TEC	560DT	18		COLD
		15.66		8	SLG		TSC	+0.47	TEH	TEC	560DT	18		COLD
21	22	18.51		8	SLG		TSH	+0.67	TEH	TEC	560DT	19		COLD
		15.34		8	SLG		TSC	+0.44	TEH	TEC	560DT	19		COLD
21	23	18.82		8	SLG		TSH	+0.62	TEH	TEC	560DT	18		COLD
		16.45		8	SLG		TSC	+0.49	TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	43		HOT
21	24	18.77		8	SLG		TSH	+0.67	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
21	25	18.40		8	SLG		TSH	+0.62	TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	43		HOT
21	26	0.27	98	3	NQH		02H	+9.61	TEH	TEC	560DT	21		COLD
					NDD				TSH	TSH	560PP	42		HOT
21	27	19.19		8	SLG		TSH	+0.66	TEH	TEC	560DT	20		COLD
21	28	19.62		8	SLG		TSH	+0.72	TEH	TEC	560DT	21		COLD
21	29	18.55		8	SLG		TSH	+0.65	TEH	TEC	560DT	20		COLD
21	30	19.02		8	SLG		TSH	+0.67	TEH	TEC	560DT	21		COLD
21	31	18.59		8	SLG		TSH	+0.65	TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	43		HOT
21	32				NDD				TSH	TSH	560PP	40		HOT
					NDD				TEH	TEC	560DT	21		COLD
21	33	18.29		8	SLG		TSH	+0.62	TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	41		HOT
21	34	18.94		8	SLG		TSH	+0.67	TEH	TEC	560DT	21		COLD
					NDD				TSH	TSH	560PP	41		HOT
21	35	19.15		8	SLG		TSH	+0.62	TEH	TEC	560DT	20		COLD
21	36	18.49		8	SLG		TSH	+0.66	TEH	TEC	560DT	21		COLD
21	37	18.85		8	SLG		TSH	+0.62	TEH	TEC	560DT	20		COLD
21	38	19.46		8	SLG		TSH	+0.66	TEH	TEC	560DT	23		COLD
21	39	18.38		8	SLG		TSH	+0.62	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
21	40	17.98		8	SLG		TSH	+0.59	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
21	41	18.18		8	SLG		TSH	+0.60	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
21	42	20.34		8	SLG		TSH	+0.66	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
21	43	18.22		8	SLG		TSH	+0.60	TEH	TEC	560DT	22		COLD
21	44	19.01		8	SLG		TSH	+0.61	TEH	TEC	560DT	23		COLD
21	45	18.14		8	SLG		TSH	+0.60	TEH	TEC	560DT	22		COLD
21	46	17.67		8	SLG		TSH	+0.54	TEH	TEC	560DT	23		COLD
21	47				NDD				TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
21	48	18.50		8	SLG		TSH	+0.58	TEH	TEC	560DT	24		COLD
		15.99		8	SLG		TSC	+0.46	TEH	TEC	560DT	24		COLD
					NDD				TSH	TSH	560PP	40		HOT
21	49	17.64		8	SLG		TSH	+0.55	TEH	TEC	560DT	24		COLD
		17.54		8	SLG		TSC	+0.56	TEH	TEC	560DT	24		COLD
					NDD				TSH	TSH	560PP	40		HOT
21	50	18.48		8	SLG		TSH	+0.71	TEH	TEC	560DT	24		COLD
		16.70		8	SLG		TSC	+0.50	TEH	TEC	560DT	24		COLD
					NDD				TSH	TSH	560PP	34		HOT
21	51	18.94		8	SLG		TSH	+0.78	TEH	TEC	560DT	24		COLD
		21.43		8	SLG		TSC	+0.64	TEH	TEC	560DT	24		COLD
21	52	22.09		8	SLG		TSH	+1.10	TEH	TEC	560DT	25		COLD
		22.00		8	SLG		TSC	+0.66	TEH	TEC	560DT	25		COLD
21	53	18.96		8	SLG		TSH	+0.66	TEH	TEC	560DT	24		COLD
		18.68		8	SLG		TSC	+0.57	TEH	TEC	560DT	24		COLD
21	54				NDD				TEH	TEC	560UL	46		COLD
					RBD				TEH	TEC	560DT	26		COLD
21	55	19.75		8	SLG		TSH	+0.73	TEH	TEC	560DT	27		COLD
		16.69		8	SLG		TSC	+0.50	TEH	TEC	560DT	27		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
21	56				NDD			TSH	TSH	560PP	34			HOT
					NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560DT	26			COLD
					NDD			TSH	TSH	560PP	36			HOT
21	57				NDD			TEH	TEC	560UL	46			COLD
					NDD			TSH	TSH	560PP	34			HOT
21	58				NDD			TEH	TEC	560UL	47			COLD
					NDD			TSH	TSH	560PP	35			HOT
21	59				NDD			TEH	TEC	560UL	46			COLD
21	60				NDD			TEH	TEC	560UL	47			COLD
21	61	21.54		8	SLG		TSH	TEH	TEC	560DT	34			COLD
21	62				NDD			TEH	TEC	560DT	34			COLD
21	63				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	35			COLD
21	64				NDD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560DT	34			COLD
21	65				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	35			COLD
21	66				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	34			COLD
21	67				NDD			TEH	TEC	560DT	37			COLD
21	68				NDD			TEH	TEC	560UL	36			COLD
21	69				NDD			TEH	TEC	560DT	37			COLD
21	70				NDD			TEH	TEC	560UL	36			COLD
21	71				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	37			COLD
21	72				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
21	73				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
21	74				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
21	75				NDD			TEH	TEC	560DT	35			COLD
21	76				NDD			TEH	TEC	560DT	35			COLD
21	77				NDD			TEH	TEC	560UL	36			COLD
21	78				NDD			TEH	TEC	560UL	36			COLD
21	79				NDD			TSH	TSH	560PP	17			HOT
		0.92		121	3	INR	02H	TEH	TEC	560UL	36			COLD
21	80				NDD			TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
21	81				NDD			TSH	TSH	560PP	17			HOT
		3.64		179	P 1	DNT	08C	TEH	TEC	560DT	37			COLD
21	82				NDD			TEH	TEC	560DT	38			COLD
					NDD			TSH	TSH	560PP	16			HOT
21	83				NDD			TEH	TEC	560UL	39			COLD
21	84				NDD			TEH	TEC	560UL	39			COLD
21	85				NDD			TEH	TEC	560DT	40			COLD
21	86				NDD			TEH	TEC	560UL	39			COLD
21	87				NDD			TSH	TSH	560PP	17			HOT
		0.59		120	3	INR	03H	TEH	TEC	560DT	40			COLD
21	88			90	3	NQH	04C	TEH	TEC	560UL	39			COLD
		0.66				NDD		TSH	TSH	560PP	16			HOT
21	89				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
21	90				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
21	91				NDD			TEH	TEC	560DT	40			COLD
21	92	17.46		8	SLG		TSC	TEH	TEC	560UL	39			COLD
21	93	24.68		8	SLG		TSC	TEH	TEC	560DT	40			COLD
21	94	16.27		8	SLG		TSH	TEH	TEC	560UL	39			COLD
		23.01		8	SLG		TSC	TEH	TEC	560UL	39			COLD
21	95				RBD			TEH	TEC	560DT	42			COLD
					NDD			TEH	TEC	560UC	70			COLD
					NDD			TSH	TSH	560PP	19			HOT
21	96				NDD			TSH	TSH	560PP	18			HOT
		27.56		8	SLG		TSC	TEH	TEC	560UL	41			COLD
21	97	25.15		8	SLG		TSC	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
21	98				NDD			TSH	TSH	560PP	18			HOT
		15.33		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		25.79		8	SLG		TSC	TEH	TEC	560UL	41			COLD
21	99				NDD			TEH	TEC	560DT	42			COLD
21	100				NDD			TEH	TEC	560UL	41			COLD
21	101				NDD			TEH	TEC	560UL	41			COLD
21	102				NDD			TEH	TEC	560UL	41			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
21	103				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
21	104				NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	43			COLD
21	105				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
21	106				NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	43			COLD
21	107				NDD			TEH	TEC	560UL	43			COLD
21	108				NDD			TEH	TEC	560UL	44			COLD
21	109				NDD			TEH	TEC	560UL	45			COLD
21	110				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
21	111				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TSH	560PP	21			HOT
21	112				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
21	113	1.39		122	3	INR	07H	+6.52	TEH	TEC	560UC	80		COLD
					NDD				TSH	TSH	560PP	20		HOT
21	114				NDD				TEH	TEC	560UC	80		COLD
					NDD				TSH	TSH	560PP	20		HOT
					NDD				TEH	TEC	560UC	72		COLD
21	115				NDD				TEH	TEC	560UL	81		COLD
21	116				NDD				TEH	TEC	560UC	80		COLD
					NDD				TEH	TEC	560UC	72		COLD
21	117				NDD				TEH	TEC	560UL	81		COLD
21	118				NDD				TEH	TEC	560UL	81		COLD
22	5				NDD				TEH	TEC	560DT	17		COLD
					NDD				TSH	TSH	560PP	44		HOT
22	6				NDD				TSH	TSH	560PP	45		HOT
					NDD				TEH	TEC	560DT	17		COLD
22	7				NDD				TEH	TEC	560DT	16		COLD
					NDD				TSH	TSH	560PP	44		HOT
22	8	17.25		8	SLG		TSC	+0.52	TEH	TEC	560DT	17		COLD
					NDD				TSH	TSH	560PP	44		HOT
22	9	17.62		8	SLG		TSC	+0.57	TEH	TEC	560DT	16		COLD
22	10	15.15		8	SLG		TSH	+0.46	TEH	TEC	560DT	17		COLD
		18.58		8	SLG		TSC	+0.57	TEH	TEC	560DT	17		COLD
22	11	16.58		8	SLG		TSH	+0.54	TEH	TEC	560DT	17		COLD
		17.82		8	SLG		TSC	+0.54	TEH	TEC	560DT	17		COLD
22	12	15.53		8	SLG		TSH	+0.47	TEH	TEC	560DT	16		COLD
		16.26		8	SLG		TSC	+0.49	TEH	TEC	560DT	16		COLD
22	13	17.33		8	SLG		TSH	+0.54	TEH	TEC	560DT	17		COLD
		16.56		8	SLG		TSC	+0.49	TEH	TEC	560DT	17		COLD
22	14	16.36		8	SLG		TSH	+0.49	TEH	TEC	560DT	16		COLD
		15.64		8	SLG		TSC	+0.47	TEH	TEC	560DT	16		COLD
22	15	17.29		8	SLG		TSH	+0.54	TEH	TEC	560DT	17		COLD
		15.85		8	SLG		TSC	+0.47	TEH	TEC	560DT	17		COLD
					NDD				TSH	TSH	560PP	44		HOT
22	16				NDD				TSH	TSH	560PP	45		HOT
		17.74		8	SLG		TSH	+0.59	TEH	TEC	560DT	17		COLD
		16.27		8	SLG		TSC	+0.47	TEH	TEC	560DT	17		COLD
22	17	18.31		8	SLG		TSH	+0.60	TEH	TEC	560DT	17		COLD
		16.99		8	SLG		TSC	+0.49	TEH	TEC	560DT	17		COLD
					NDD				TSH	TSH	560PP	42		HOT
22	18	18.02		8	SLG		TSH	+0.59	TEH	TEC	560DT	18		COLD
		16.14		8	SLG		TSC	+0.47	TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	43		HOT
22	19	19.40		8	SLG		TSH	+0.67	TEH	TEC	560DT	19		COLD
		16.93		8	SLG		TSC	+0.49	TEH	TEC	560DT	19		COLD
22	20	18.73		8	SLG		TSH	+0.67	TEH	TEC	560DT	19		COLD
		16.75		8	SLG		TSC	+0.49	TEH	TEC	560DT	19		COLD
22	21	18.63		8	SLG		TSH	+0.64	TEH	TEC	560DT	19		COLD
		16.59		8	SLG		TSC	+0.49	TEH	TEC	560DT	19		COLD
22	22	18.66		8	SLG		TSH	+0.67	TEH	TEC	560DT	18		COLD
22	23	19.10		8	SLG		TSH	+0.67	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
22	24				NDD				TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	43		HOT
22	25	19.55		8	SLG		TSH	+0.65	TEH	TEC	560DT	19		COLD
		15.07		8	SLG		TSC	+0.44	TEH	TEC	560DT	19		COLD
		1.44		87	6	INR	06H	+36.20	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
22	26	18.87		8	SLG		TSH	+0.65	TEH	TEC	560DT	20		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
22	27	18.90			NDD			TSH	TSH	560PP	43			HOT
22	28	18.69		8	SLG		TSH	+0.67	TEH	TEC	560DT	21		COLD
22	29	19.26		8	SLG		TSH	+0.65	TEH	TEC	560DT	20		COLD
22	30	19.31		8	SLG		TSH	+0.67	TEH	TEC	560DT	21		COLD
22	31	19.34		8	SLG		TSH	+0.68	TEH	TEC	560DT	20		COLD
					NDD				TEH	TEC	560DT	21		COLD
22	32				NDD				TSH	TSH	560PP	42		HOT
		18.77		8	SLG		TSH	+0.65	TSH	TSH	560PP	40		HOT
22	33				NDD				TEH	TEC	560DT	20		COLD
		19.14		8	SLG		TSH	+0.64	TSH	TSH	560PP	40		HOT
22	34	18.87		8	SLG		TSH	+0.65	TEH	TEC	560DT	21		COLD
					NDD				TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	40		HOT
22	35	19.26		8	SLG		TSH	+0.67	TEH	TEC	560DT	21		COLD
22	36	18.79		8	SLG		TSH	+0.62	TEH	TEC	560DT	20		COLD
22	37	18.74		8	SLG		TSH	+0.66	TEH	TEC	560DT	21		COLD
22	38	18.66		8	SLG		TSH	+0.62	TEH	TEC	560DT	22		COLD
22	39	19.11		8	SLG		TSH	+0.67	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
22	40	18.30		8	SLG		TSH	+0.59	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
22	41	19.07		8	SLG		TSH	+0.64	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
22	42	17.90		8	SLG		TSH	+0.57	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
22	43	18.11		8	SLG		TSH	+0.58	TEH	TEC	560DT	23		COLD
22	44				NDD				TEH	TEC	560UL	46		COLD
					RBD				TEH	TEC	560DT	22		COLD
22	45	19.40		8	SLG		TSH	+0.61	TEH	TEC	560DT	23		COLD
22	46	18.00		8	SLG		TSH	+0.57	TEH	TEC	560DT	22		COLD
22	47	18.76		8	SLG		TSH	+0.66	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
22	48	19.28		8	SLG		TSH	+0.66	TEH	TEC	560DT	25		COLD
		15.11		8	SLG		TSC	+0.45	TEH	TEC	560DT	25		COLD
					NDD				TSH	TSH	560PP	41		HOT
22	49	21.03		8	SLG		TSH	+0.73	TEH	TEC	560DT	25		COLD
		15.27		8	SLG		TSC	+0.46	TEH	TEC	560DT	25		COLD
					NDD				TSH	TSH	560PP	41		HOT
22	50	20.44		8	SLG		TSH	+0.79	TEH	TEC	560DT	25		COLD
		15.54		8	SLG		TSC	+0.46	TEH	TEC	560DT	25		COLD
					NDD				TSH	TSH	560PP	36		HOT
22	51	19.19		8	SLG		TSH	+0.60	TEH	TEC	560DT	25		COLD
		20.39		8	SLG		TSC	+0.59	TEH	TEC	560DT	25		COLD
22	52	17.56		8	SLG		TSH	+0.53	TEH	TEC	560DT	24		COLD
22	53	20.03		8	SLG		TSH	+0.70	TEH	TEC	560DT	25		COLD
		19.80		8	SLG		TSC	+0.56	TEH	TEC	560DT	25		COLD
22	54	18.60		8	SLG		TSH	+0.60	TEH	TEC	560DT	27		COLD
22	55				NDD				TEH	TEC	560UL	46		COLD
					RBD				TEH	TEC	560DT	26		COLD
					NDD				TSH	TSH	560PP	36		HOT
22	56	19.14		8	SLG		TSH	+0.67	TEH	TEC	560DT	27		COLD
					NDD				TSH	TSH	560PP	34		HOT
22	57				NDD				TEH	TEC	560UL	46		COLD
					NDD				TSH	TSH	560PP	36		HOT
22	58				NDD				TEH	TEC	560UL	47		COLD
					NDD				TSH	TSH	560PP	34		HOT
22	59				NDD				TEH	TEC	560UL	46		COLD
22	60				NDD				TEH	TEC	560UL	47		COLD
22	61				NDD				TEH	TEC	560DT	35		COLD
22	62	15.50		8	SLG		TSH	+0.54	TEH	TEC	560DT	35		COLD
22	63				NDD				TSH	TSH	560PP	14		HOT
					NDD				TEH	TEC	560DT	34		COLD
22	64				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	35		COLD
22	65				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	34		COLD
22	66				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	35		COLD
22	67				NDD				TEH	TEC	560DT	37		COLD
22	68				NDD				TEH	TEC	560DT	37		COLD
22	69				NDD				TEH	TEC	560UL	36		COLD
22	70				NDD				TEH	TEC	560DT	37		COLD
22	71				NDD				TEH	TEC	560UL	36		COLD
					NDD				TSH	TSH	560PP	16		HOT
22	72				NDD				TSH	TSH	560PP	17		HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
22	73				NDD			TEH	TEC	560DT	35			COLD
					NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	35			COLD
22	74				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	35			COLD
22	75				NDD			TEH	TEC	560DT	34			COLD
22	76				NDD			TEH	TEC	560DT	37			COLD
22	77				NDD			TEH	TEC	560DT	37			COLD
22	78				NDD			TEH	TEC	560DT	37			COLD
22	79				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	37			COLD
22	80				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	37			COLD
22	81				NDD			TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
22	82				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	38			COLD
22	83				NDD			TEH	TEC	560DT	40			COLD
22	84				NDD			TEH	TEC	560DT	40			COLD
22	85				NDD			TEH	TEC	560UL	39			COLD
22	86				NDD			TEH	TEC	560DT	40			COLD
22	87				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
22	88				NDD			TEH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
22	89				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
22	90				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
22	91				NDD			TEH	TSH	560PP	18			HOT
					NDD			TEH	TEC	560UL	39			COLD
22	92	18.35		8	SLG		TSC	TEH	TEC	560DT	40			COLD
22	93	19.22		8	SLG		TSC	TEH	TEC	560UL	39			COLD
22	94	23.74		8	SLG		TSC	TEH	TEC	560DT	40			COLD
22	95				NDD			TSH	TSH	560PP	18			HOT
		25.93		8	SLG		TSC	TEH	TEC	560UL	41			COLD
22	96	15.44		8	SLG		TSH	TEH	TEC	560DT	42			COLD
		23.90		8	SLG		TSC	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
22	97				NDD			TSH	TSH	560PP	18			HOT
		17.08		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		26.20		8	SLG		TSC	TEH	TEC	560UL	41			COLD
22	98	25.31		8	SLG		TSC	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
22	99				NDD			TEH	TEC	560UL	41			COLD
22	100				NDD			TEH	TEC	560DT	42			COLD
22	101				NDD			TEH	TEC	560UL	41			COLD
22	102				NDD			TEH	TEC	560UL	41			COLD
22	103				NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	43			COLD
22	104				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
22	105				NDD			TSH	TSH	560PP	20			HOT
		0.49	32	3	INR		TSC	TEH	TEC	560UL	43			COLD
22	106				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
22	107				NDD			TEH	TEC	560UL	43			COLD
22	108				NDD			TEH	TEC	560UL	45			COLD
22	109				NDD			TEH	TEC	560UL	44			COLD
22	110				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
22	111				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
22	112				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	21			HOT
22	113				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
22	114				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
22	115				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
22	116				NDD			TEH	TEC	560UC	80			COLD
22	117				NDD			TEH	TEC	560UC	80			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
22	118				NDD			TEH	TEC	560UC	72			COLD
23	6				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560DT	16			COLD
23	7				NDD			TSH	TSH	560PP	44			HOT
					NDD			TSH	TSH	560PP	45			HOT
23	8				NDD			TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	45			HOT
					NDD			TEH	TEC	560DT	16			COLD
23	9	15.60	8	SLG	TSH	+0.44		TEH	TEC	560DT	17			COLD
		18.21	8	SLG	TSC	+0.55		TEH	TEC	560DT	17			COLD
23	10	17.64	8	SLG	TSC	+0.57		TEH	TEC	560DT	17			COLD
23	11	15.33	8	SLG	TSH	+0.45		TEH	TEC	560DT	16			COLD
		17.54	8	SLG	TSC	+0.58		TEH	TEC	560DT	16			COLD
23	12	17.01	8	SLG	TSH	+0.56		TEH	TEC	560DT	17			COLD
		17.76	8	SLG	TSC	+0.55		TEH	TEC	560DT	17			COLD
23	13	16.24	8	SLG	TSH	+0.50		TEH	TEC	560DT	16			COLD
		16.57	8	SLG	TSC	+0.52		TEH	TEC	560DT	16			COLD
23	14	17.42	8	SLG	TSH	+0.59		TEH	TEC	560DT	17			COLD
		16.11	8	SLG	TSC	+0.47		TEH	TEC	560DT	17			COLD
23	15				NDD			TSH	TSH	560PP	45			HOT
		16.75	8	SLG	TSH	+0.52		TEH	TEC	560DT	16			COLD
		16.49	8	SLG	TSC	+0.52		TEH	TEC	560DT	16			COLD
23	16	16.87	8	SLG	TSH	+0.55		TEH	TEC	560DT	16			COLD
		16.24	8	SLG	TSC	+0.49		TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	44			HOT
23	17	17.36	8	SLG	TSH	+0.57		TEH	TEC	560DT	16			COLD
		16.32	8	SLG	TSC	+0.49		TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	43			HOT
23	18	18.24	8	SLG	TSH	+0.62		TEH	TEC	560DT	19			COLD
		16.79	8	SLG	TSC	+0.49		TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
23	19	18.06	8	SLG	TSH	+0.60		TEH	TEC	560DT	18			COLD
		16.53	8	SLG	TSC	+0.49		TEH	TEC	560DT	18			COLD
23	20	18.14	8	SLG	TSH	+0.59		TEH	TEC	560DT	18			COLD
23	21	18.08	8	SLG	TSH	+0.62		TEH	TEC	560DT	18			COLD
23	22	18.85	8	SLG	TSH	+0.64		TEH	TEC	560DT	19			COLD
		16.08	8	SLG	TSC	+0.47		TEH	TEC	560DT	19			COLD
23	23	18.74	8	SLG	TSH	+0.63		TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
23	24	19.00	8	SLG	TSH	+0.62		TEH	TEC	560DT	19			COLD
		15.18	8	SLG	TSC	+0.44		TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
23	25	18.84	8	SLG	TSH	+0.67		TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
23	26	19.18	8	SLG	TSH	+0.64		TEH	TEC	560DT	21			COLD
					NDD			TSH	TSH	560PP	42			HOT
23	27	19.15	8	SLG	TSH	+0.67		TEH	TEC	560DT	20			COLD
23	28	18.47	8	SLG	TSH	+0.64		TEH	TEC	560DT	21			COLD
23	29	18.99	8	SLG	TSH	+0.67		TEH	TEC	560DT	20			COLD
23	30	19.60	8	SLG	TSH	+0.67		TEH	TEC	560DT	21			COLD
23	31	19.81	8	SLG	TSH	+0.67		TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	43			HOT
23	32				NDD			TSH	TSH	560PP	40			HOT
		18.59	8	SLG	TSH	+0.64		TEH	TEC	560DT	21			COLD
23	33	18.81	8	SLG	TSH	+0.65		TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	41			HOT
23	34	18.74	8	SLG	TSH	+0.64		TEH	TEC	560DT	21			COLD
					NDD			TSH	TSH	560PP	41			HOT
23	35	19.05	8	SLG	TSH	+0.64		TEH	TEC	560DT	20			COLD
23	36	18.01	8	SLG	TSH	+0.61		TEH	TEC	560DT	21			COLD
23	37	18.75	8	SLG	TSH	+0.62		TEH	TEC	560DT	20			COLD
23	38	19.19	8	SLG	TSH	+0.61		TEH	TEC	560DT	23			COLD
23	39	19.05	8	SLG	TSH	+0.62		TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	41			HOT
23	40	19.01	8	SLG	TSH	+0.64		TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
23	41	18.52	8	SLG	TSH	+0.62		TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	41			HOT
23	42	19.42	8	SLG	TSH	+0.66		TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
23	43	18.32	8	SLG	TSH	+0.62		TEH	TEC	560DT	22			COLD
23	44	18.38	8	SLG	TSH	+0.61		TEH	TEC	560DT	23			COLD
23	45	20.13	8	SLG	TSH	+0.64		TEH	TEC	560DT	22			COLD
23	46	18.21	8	SLG	TSH	+0.59		TEH	TEC	560DT	23			COLD
23	47	18.16	8	SLG	TSH	+0.57		TEH	TEC	560DT	22			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					NDD			TEH	TSH	560PP	41			HOT
23	48	18.62		8	SLG		TSH	TEH	TEC	560DT	24			COLD
					NDD			TEH	TSH	560PP	40			HOT
23	49	18.48		8	SLG		TSH	TEH	TEC	560DT	24			COLD
					NDD			TSH	TSH	560PP	40			HOT
23	50	18.76		8	SLG		TSH	TEH	TEC	560DT	24			COLD
					NDD			TSH	TSH	560PP	34			HOT
23	51	18.68		8	SLG		TSH	TEH	TEC	560DT	24			COLD
		17.05		8	SLG		TSC	TEH	TEC	560DT	24			COLD
					NDD			TEH	TSH	560PP	34			HOT
23	52	20.42		8	SLG		TSH	TEH	TEC	560DT	25			COLD
		15.30		8	SLG		TSC	TEH	TEC	560DT	25			COLD
23	53	19.43		8	SLG		TSH	TEH	TEC	560DT	24			COLD
		17.68		8	SLG		TSC	TEH	TEC	560DT	24			COLD
23	54	15.95		8	SLG		TSC	TEH	TEC	560DT	26			COLD
23	55	19.71		8	SLG		TSH	TEH	TEC	560DT	27			COLD
					NDD			TSH	TSH	560PP	34			HOT
23	56				NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560DT	26			COLD
					NDD			TSH	TSH	560PP	36			HOT
23	57	0.43	157	1	INR		08H	TEH	TEC	560UL	46			COLD
					NDD			TSH	TSH	560PP	34			HOT
				2	NDF		08H	AV1	08H	5201P	72			HOT
23	58				NDD			TEH	TEC	560UL	47			COLD
					NDD			TSH	TSH	560PP	35			HOT
23	59				NDD			TEH	TEC	560UL	46			COLD
23	60				NDD			TEH	TEC	560UL	47			COLD
23	61				NDD			TEH	TEC	560DT	34			COLD
23	62				NDD			TEH	TEC	560DT	34			COLD
23	63				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	35			COLD
23	64				NDD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560DT	34			COLD
23	65				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	35			COLD
23	66				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	34			COLD
23	67				NDD			TEH	TEC	560DT	37			COLD
23	68				NDD			TEH	TEC	560UL	36			COLD
23	69				NDD			TEH	TEC	560DT	37			COLD
23	70				NDD			TEH	TEC	560UL	36			COLD
23	71				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	37			COLD
23	72				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
23	73				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
23	74				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
23	75				NDD			TEH	TEC	560DT	35			COLD
23	76				NDD			TEH	TEC	560UL	36			COLD
23	77				NDD			TEH	TEC	560UL	36			COLD
23	78				NDD			TEH	TEC	560UL	36			COLD
23	79				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560UL	36			COLD
23	80				NDD			TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
23	81				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	37			COLD
23	82				NDD			TEH	TEC	560DT	38			COLD
					NDD			TSH	TSH	560PP	16			HOT
23	83				NDD			TEH	TEC	560UL	39			COLD
23	84				NDD			TEH	TEC	560UL	39			COLD
23	85				NDD			TEH	TEC	560DT	40			COLD
23	86				NDD			TEH	TEC	560UL	39			COLD
23	87				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
23	88				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
23	89				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
23	90				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
23	91				NDD			TEH	TEC	560DT	40			COLD
23	92	19.24		8	SLG		TSC	TEH	TEC	560UL	39			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
23	93	19.17		8	SLG		TSC	+0.57	TEH	TEC	560DT	40		COLD
23	94				NDD				TEH	TSH	560PP	18		HOT
		15.49		8	SLG		TSH	+0.44	TEH	TEC	560UL	39		COLD
		22.12		8	SLG		TSC	+0.69	TEH	TEC	560UL	39		COLD
23	95				RBD				TEH	TEC	560DT	42		COLD
					NDD				TEH	TEC	560UC	70		COLD
					NDD				TSH	TSH	560PP	19		HOT
23	96				NDD				TSH	TSH	560PP	18		HOT
		24.99		8	SLG		TSC	+0.65	TEH	TEC	560UL	41		COLD
23	97	16.63		8	SLG		TSH	+0.48	TEH	TEC	560DT	42		COLD
		26.24		8	SLG		TSC	+0.75	TEH	TEC	560DT	42		COLD
					NDD				TSH	TSH	560PP	19		HOT
23	98				NDD				TSH	TSH	560PP	18		HOT
		15.68		8	SLG		TSH	+0.46	TEH	TEC	560UL	41		COLD
		25.62		8	SLG		TSC	+0.73	TEH	TEC	560UL	41		COLD
23	99				NDD				TEH	TEC	560DT	42		COLD
23	100				NDD				TEH	TEC	560UL	41		COLD
23	101				NDD				TEH	TEC	560UL	41		COLD
23	102				NDD				TEH	TEC	560UL	41		COLD
23	103				NDD				TSH	TSH	560PP	21		HOT
					NDD				TEH	TEC	560UL	43		COLD
23	104				NDD				TSH	TSH	560PP	20		HOT
					NDD				TEH	TEC	560UL	43		COLD
23	105				NDD				TSH	TSH	560PP	21		HOT
					NDD				TEH	TEC	560UL	43		COLD
23	106				NDD				TSH	TSH	560PP	20		HOT
					NDD				TEH	TEC	560UL	43		COLD
23	107				NDD				TEH	TEC	560UL	43		COLD
23	108				NDD				TEH	TEC	560UL	44		COLD
23	109				NDD				TEH	TEC	560UL	45		COLD
23	110				NDD				TEH	TEC	560UC	80		COLD
					NDD				TEH	TEC	560UC	72		COLD
23	111				NDD				TEH	TEC	560UC	80		COLD
					NDD				TSH	TSH	560PP	21		HOT
23	112				NDD				TEH	TEC	560UC	80		COLD
					NDD				TSH	TSH	560PP	20		HOT
					NDD				TEH	TEC	560UC	72		COLD
23	113	1.31	117	3	INR		02H	+11.99	TEH	TEC	560UC	80		COLD
					NDD				TSH	TSH	560PP	20		HOT
23	114				NDD				TEH	TEC	560UC	80		COLD
					NDD				TSH	TSH	560PP	20		HOT
					NDD				TEH	TEC	560UC	72		COLD
23	115				NDD				TEH	TEC	560UC	80		COLD
23	116				NDD				TEH	TEC	560UC	80		COLD
					NDD				TEH	TEC	560UC	72		COLD
23	117				NDD				TEH	TEC	560UC	80		COLD
24	6				NDD				TEH	TEC	560DT	17		COLD
					NDD				TSH	TSH	560PP	44		HOT
24	7				NDD				TEH	TEC	560DT	16		COLD
					NDD				TSH	TSH	560PP	44		HOT
24	8	17.29		8	SLG		TSC	+0.52	TEH	TEC	560DT	17		COLD
					NDD				TSH	TSH	560PP	44		HOT
24	9	1.38	0	P 5	TWD	21	01H	+0.46	TEH	TEC	560UL	16	FDBW	COLD
		17.56		8	SLG		TSC	+0.60	TEH	TEC	560DT	16		COLD
		0.73	56	P 1	DSS		01H	+0.56	TEH	TEC	560DT	16		COLD
				3	NDF		01H	+0.56	01H	01H	560PP	29		HOT
24	10	18.82		8	SLG		TSC	+0.62	TEH	TEC	560DT	17		COLD
24	11	15.11		8	SLG		TSH	+0.44	TEH	TEC	560DT	17		COLD
		18.70		8	SLG		TSC	+0.62	TEH	TEC	560DT	17		COLD
24	12	17.68		8	SLG		TSC	+0.60	TEH	TEC	560DT	16		COLD
24	13	17.46		8	SLG		TSH	+0.59	TEH	TEC	560DT	17		COLD
		17.82		8	SLG		TSC	+0.55	TEH	TEC	560DT	17		COLD
24	14	0.90	111	3	INR		06C	+15.50	TEH	TEC	560DT	16		COLD
		0.68	123	3	INR		06C	+6.10	TEH	TEC	560DT	16		COLD
		16.57		8	SLG		TSH	+0.52	TEH	TEC	560DT	16		COLD
		17.19		8	SLG		TSC	+0.54	TEH	TEC	560DT	16		COLD
24	15	16.76		8	SLG		TSH	+0.51	TEH	TEC	560DT	17		COLD
		17.25		8	SLG		TSC	+0.52	TEH	TEC	560DT	17		COLD
					NDD				TSH	TSH	560PP	44		HOT
24	16				NDD				TSH	TSH	560PP	45		HOT
		17.56		8	SLG		TSH	+0.57	TEH	TEC	560DT	17		COLD
		17.13		8	SLG		TSC	+0.52	TEH	TEC	560DT	17		COLD
24	17	17.82		8	SLG		TSH	+0.54	TEH	TEC	560DT	17		COLD
		17.17		8	SLG		TSC	+0.52	TEH	TEC	560DT	17		COLD
					NDD				TSH	TSH	560PP	42		HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
24	18	17.89		8	SLG		TSH +0.60	TEH	TEC	560DT	18			COLD
		16.51		8	SLG		TSC +0.52	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
24	19	18.08		8	SLG		TSH +0.59	TEH	TEC	560DT	19			COLD
		16.48		8	SLG		TSC +0.49	TEH	TEC	560DT	19			COLD
24	20	18.89		8	SLG		TSH +0.62	TEH	TEC	560DT	19			COLD
		16.48		8	SLG		TSC +0.47	TEH	TEC	560DT	19			COLD
		0.82	122	3	INR		AV6 +7.18	TEH	TEC	560DT	19			COLD
24	21	18.51		8	SLG		TSH +0.62	TEH	TEC	560DT	19			COLD
		15.85		8	SLG		TSC +0.47	TEH	TEC	560DT	19			COLD
24	22	17.69		8	SLG		TSH +0.60	TEH	TEC	560DT	18			COLD
24	23	19.40		8	SLG		TSH +0.64	TEH	TEC	560DT	19			COLD
		15.42		8	SLG		TSC +0.44	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
24	24	18.52		8	SLG		TSH +0.65	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
24	25	19.32		8	SLG		TSH +0.65	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
24	26	19.07		8	SLG		TSH +0.63	TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	43			HOT
24	27	19.32		8	SLG		TSH +0.67	TEH	TEC	560DT	21			COLD
24	28	18.97		8	SLG		TSH +0.68	TEH	TEC	560DT	20			COLD
24	29	18.98		8	SLG		TSH +0.64	TEH	TEC	560DT	21			COLD
24	30	19.17		8	SLG		TSH +0.65	TEH	TEC	560DT	20			COLD
24	31	18.35		8	SLG		TSH +0.62	TEH	TEC	560DT	21			COLD
					NDD			TSH	TSH	560PP	42			HOT
24	32				NDD			TSH	TSH	560PP	40			HOT
		18.81		8	SLG		TSH +0.65	TEH	TEC	560DT	20			COLD
24	33				NDD			TSH	TSH	560PP	40			HOT
		18.78		8	SLG		TSH +0.64	TEH	TEC	560DT	21			COLD
24	34				NDD			TSH	TSH	560PP	40			HOT
		18.99		8	SLG		TSH +0.65	TEH	TEC	560DT	20			COLD
24	35	18.76		8	SLG		TSH +0.61	TEH	TEC	560DT	21			COLD
24	36	18.61		8	SLG		TSH +0.62	TEH	TEC	560DT	20			COLD
24	37	18.91		8	SLG		TSH +0.62	TEH	TEC	560DT	22			COLD
24	38	17.86		8	SLG		TSH +0.60	TEH	TEC	560DT	22			COLD
24	39	19.36		8	SLG		TSH +0.67	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
24	40	18.89		8	SLG		TSH +0.62	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	41			HOT
24	41	19.46		8	SLG		TSH +0.66	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
24	42	18.54		8	SLG		TSH +0.60	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	41			HOT
24	43	19.11		8	SLG		TSH +0.63	TEH	TEC	560DT	23			COLD
24	44				NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560DT	22			COLD
24	45	18.63		8	SLG		TSH +0.61	TEH	TEC	560DT	23			COLD
24	46	18.20		8	SLG		TSH +0.60	TEH	TEC	560DT	22			COLD
24	47	18.25		8	SLG		TSH +0.61	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
24	48	20.69		8	SLG		TSH +0.66	TEH	TEC	560DT	25			COLD
					NDD			TSH	TSH	560PP	41			HOT
24	49	20.78		8	SLG		TSH +0.66	TEH	TEC	560DT	25			COLD
					NDD			TSH	TSH	560PP	41			HOT
24	50	19.92		8	SLG		TSH +0.64	TEH	TEC	560DT	25			COLD
					NDD			TSH	TSH	560PP	36			HOT
24	51	20.48		8	SLG		TSH +0.65	TEH	TEC	560DT	25			COLD
24	52				NDD			TEH	TEC	560DT	24			COLD
24	53	21.80		8	SLG		TSH +0.74	TEH	TEC	560DT	25			COLD
		15.02		8	SLG		TSC +0.44	TEH	TEC	560DT	25			COLD
24	54				NDD			TEH	TEC	560DT	27			COLD
24	55				NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560DT	26			COLD
					NDD			TSH	TSH	560PP	36			HOT
24	56	19.53		8	SLG		TSH +0.61	TEH	TEC	560DT	27			COLD
					NDD			TSH	TSH	560PP	34			HOT
24	57				NDD			TEH	TEC	560UL	47			COLD
					NDD			TSH	TSH	560PP	36			HOT
24	58				NDD			TEH	TEC	560UL	46			COLD
					NDD			TSH	TSH	560PP	34			HOT
24	59				NDD			TEH	TEC	560UL	46			COLD
24	60				NDD			TEH	TEC	560UL	47			COLD
24	61				NDD			TEH	TEC	560DT	35			COLD
24	62				NDD			TEH	TEC	560DT	35			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
24	63				NDD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560DT	34			COLD
24	64				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	35			COLD
24	65				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	34			COLD
24	66				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	35			COLD
24	67				NDD			TEH	TEC	560DT	37			COLD
24	68				NDD			TEH	TEC	560DT	37			COLD
24	69				NDD			TEH	TEC	560UL	36			COLD
24	70				NDD			TEH	TEC	560DT	37			COLD
24	71				NDD			TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
24	72				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	35			COLD
24	73				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	35			COLD
24	74				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	35			COLD
24	75				NDD			TEH	TEC	560DT	34			COLD
24	76				NDD			TEH	TEC	560DT	37			COLD
24	77				NDD			TEH	TEC	560DT	37			COLD
24	78				NDD			TEH	TEC	560DT	37			COLD
24	79				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	37			COLD
24	80				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	37			COLD
24	81				NDD			TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
24	82				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	38			COLD
24	83				NDD			TEH	TEC	560DT	40			COLD
24	84				NDD			TEH	TEC	560DT	40			COLD
24	85				NDD			TEH	TEC	560UL	39			COLD
24	86	1.34	79	6	INR	05C	+12.20	TEH	TEC	560DT	40			COLD
24	87				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
24	88				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
24	89				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
24	90				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
24	91				NDD			TEH	TEC	560UL	39			COLD
24	92	20.96		8	SLG	TSC	+0.57	TEH	TEC	560DT	40			COLD
24	93	16.76		8	SLG	TSH	+0.50	TEH	TEC	560UL	39			COLD
		23.09		8	SLG	TSC	+0.74	TEH	TEC	560UL	39			COLD
24	94	16.62		8	SLG	TSH	+0.48	TEH	TEC	560DT	40			COLD
		25.84		8	SLG	TSC	+0.67	TEH	TEC	560DT	40			COLD
24	95				NDD			TSH	TSH	560PP	18			HOT
		17.41		8	SLG	TSH	+0.49	TEH	TEC	560UL	41			COLD
		27.19		8	SLG	TSC	+0.68	TEH	TEC	560UL	41			COLD
24	96	17.39		8	SLG	TSH	+0.48	TEH	TEC	560DT	42			COLD
		25.01		8	SLG	TSC	+0.67	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
24	97				NDD			TSH	TSH	560PP	18			HOT
		16.14		8	SLG	TSH	+0.46	TEH	TEC	560UL	41			COLD
		25.64		8	SLG	TSC	+0.75	TEH	TEC	560UL	41			COLD
24	98	16.44		8	SLG	TSH	+0.48	TEH	TEC	560DT	42			COLD
		25.15		8	SLG	TSC	+0.77	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
24	99				NDD			TEH	TEC	560UL	41			COLD
24	100				NDD			TEH	TEC	560DT	42			COLD
24	101				NDD			TEH	TEC	560UL	41			COLD
24	102				NDD			TEH	TEC	560UL	41			COLD
24	103				NDD			TSH	TSH	560PP	20			HOT
		3.99	187	1	DNG	TSC	+4.28	TEH	TEC	560UL	43			COLD
		3.14	186	1	DNG	TSC	+1.60	TEH	TEC	560UL	43			COLD
24	104				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
24	105				NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	43			COLD
24	106				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
24	107				NDD			TEH	TEC	560UL	43			COLD
24	108				NDD			TEH	TEC	560UL	45			COLD
24	109				NDD			TEH	TEC	560UL	44			COLD
24	110				NDD			TEH	TEC	560UC	80			COLD
24	111				NDD			TEH	TEC	560UC	72			COLD
					NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
24	112				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UC	72			COLD
24	113				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
24	114				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
24	115				NDD			TEH	TEC	560UC	80			COLD
24	116				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
24	117	0.64	0	P 2	TWD	17	AV1							
25	7				NDD			TEH	TEC	560UC	80			COLD
		16.13		8	SLG		TSC							
25	8				NDD			TSH	TSH	560PP	45			HOT
		16.43		8	SLG		TSC							
25	9	18.88		8	SLG		TSC							
25	10	18.12		8	SLG		TSC							
25	11	17.78		8	SLG		TSC							
25	12	16.62		8	SLG		TSH							
		19.27		8	SLG		TSC							
		0.67	142	1	TFH		08H							
		0.29	117	1	TFH		08H							
				2	NDF		08H							
				2	NDF		08H							
25	13	15.68		8	SLG		TSH							
		17.92		8	SLG		TSC							
25	14	17.17		8	SLG		TSH							
		17.76		8	SLG		TSC							
		0.79	130	1	TFH		08H							
		0.21	67	1	TFH		AV6							
25	15				NDD			TEH	TEC	560DT	17			COLD
		16.71		8	SLG		TSH							
		17.48		8	SLG		TSC							
25	16	16.75		8	SLG		TSH							
		17.25		8	SLG		TSC							
					NDD			TSH	TSH	560PP	44			HOT
25	17	16.67		8	SLG		TSH							
		16.77		8	SLG		TSC							
					NDD			TSH	TSH	560PP	43			HOT
25	18	17.75		8	SLG		TSH							
		17.12		8	SLG		TSC							
					NDD			TEH	TEC	560DT	19			COLD
25	19	0.76	44	1	INR		08H							
		17.15		8	SLG		TSH							
		16.20		8	SLG		TSC							
				2	NDF		08H							
25	20	17.43		8	SLG		TSH							
25	21	0.94	152	1	INR		08H							
		18.22		8	SLG		TSH							
				2	NDF		08H							
25	22	18.85		8	SLG		TSH							
		16.50		8	SLG		TSC							
25	23	18.44		8	SLG		TSH							
					NDD			TSH	TSH	560PP	43			HOT
25	24	18.89		8	SLG		TSH							
		15.63		8	SLG		TSC							
					NDD			TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
25	25	0.36	72	1	INR		AV6							
		18.22		8	SLG		TSH							
					NDD			TEH	TEC	560DT	18			COLD
					NDD			TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
25	26	19.10		8	SLG		TSH							
					NDD			TEH	TEC	560DT	21			COLD
					NDD			TSH	TSH	560PP	42			HOT
25	27	19.13		8	SLG		TSH							
25	28	0.39	119	1	TFH		08H							
		19.06		8	SLG		TSH							
				2	NDF		08H							

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
25	29	19.21		8	SLG		TSH			560DT	20			COLD
25	30	18.74		8	SLG		TSH			560DT	21			COLD
25	31	18.65		8	SLG		TSH			560DT	20			COLD
					NDD					560PP	43			HOT
25	32				NDD					560PP	40			HOT
		18.39		8	SLG		TSH			560DT	21			COLD
25	33	0.46	82	1	TFH		08H			560DT	20			COLD
		18.09		8	SLG		TSH			560DT	20			COLD
					NDD					560PP	41			HOT
				2	NDF		08H			5201P	72			HOT
25	34	18.88		8	SLG		TSH			560DT	21			COLD
					NDD					560PP	41			HOT
25	35	18.71		8	SLG		TSH			560DT	20			COLD
		0.73	36	1	INR		08H			560DT	20			COLD
				2	NDF		08H			5201P	72			HOT
25	36	18.61		8	SLG		TSH			560DT	21			COLD
25	37	19.84		8	SLG		TSH			560DT	23			COLD
25	38	0.45	139	1	TFH		08H			560DT	23			COLD
		19.03		8	SLG		TSH			560DT	23			COLD
				2	NDF		08H			5201P	72			HOT
25	39	0.75	151	1	TFH		08H			560DT	22			COLD
		1.00	112	3	INR		07C			560DT	22			COLD
		18.32		8	SLG		TSH			560DT	22			COLD
					NDD					560PP	41			HOT
25	40	19.42		8	SLG		TSH			560DT	23			COLD
					NDD					560PP	40			HOT
25	41	18.64		8	SLG		TSH			560DT	22			COLD
					NDD					560PP	41			HOT
25	42	0.39	98	1	TFH		08H			560DT	23			COLD
		19.38		8	SLG		TSH			560DT	23			COLD
					NDD					560PP	40			HOT
25	43	18.91		8	SLG		TSH			560DT	22			COLD
25	44	18.65		8	SLG		TSH			560DT	23			COLD
25	45	19.37		8	SLG		TSH			560DT	22			COLD
25	46	18.59		8	SLG		TSH			560DT	23			COLD
25	47	18.50		8	SLG		TSH			560DT	22			COLD
					NDD					560PP	40			HOT
25	48	19.86		8	SLG		TSH			560DT	24			COLD
					NDD					560PP	40			HOT
25	49	0.61	50	1	TFH		08H			560DT	24			COLD
		19.23		8	SLG		TSH			560DT	24			COLD
					NDD					560PP	40			HOT
25	50	0.65	136	1	TFH		08H			560DT	24			COLD
					NDD					560PP	34			HOT
25	51	18.88		8	SLG		TSH			560DT	24			COLD
25	52	20.76		8	SLG		TSH			560DT	25			COLD
25	53	19.07		8	SLG		TSH			560DT	24			COLD
25	54				NDD					560UL	46			COLD
					RBD					560DT	26			COLD
25	55	20.02		8	SLG		TSH			560DT	27			COLD
					NDD					560PP	34			HOT
25	56	19.44		8	SLG		TSH			560DT	26			COLD
					NDD					560PP	36			HOT
25	57	0.49	145	1	INR		08H			560UL	47			COLD
					NDD					560PP	34			HOT
25	58	1.24	118	3	INR		TSC			560UL	46			COLD
					NDD					560PP	35			HOT
25	59				NDD					560UL	47			COLD
25	60	0.34	157	1	INR		08H			560UL	46			COLD
25	61				NDD					560DT	34			COLD
25	62				NDD					560DT	34			COLD
25	63				NDD					560PP	15			HOT
		3.15	184	1	DNG		06H			560DT	35			COLD
25	64				NDD					560PP	14			HOT
					NDD					560DT	34			COLD
25	65				NDD					560PP	15			HOT
					NDD					560DT	35			COLD
25	66				NDD					560PP	15			HOT
		0.25	83	3	NQH		04H			560DT	34			COLD
25	67	0.43	43	1	TFH		AV6			560DT	37			COLD
25	68	0.68	115	3	INR		05H			560UL	36			COLD
25	69				NDD					560DT	37			COLD
25	70	0.52	137	1	INR		AV6			560UL	36	OK		COLD
25	71				NDD					560PP	17			HOT
		0.54	127	1	TFH		08C			560DT	37			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
25	72				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
25	73				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
25	74				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
25	75				NDD			TEH	TEC	560DT	35			COLD
25	76				NDD			TEH	TEC	560UL	36			COLD
25	77	0.29	92	1	TFH	AV6	+14.82	TEH	TEC	560UL	36			COLD
25	78	0.91	148	1	TFH	AV6	+14.88	TEH	TEC	560UL	36			COLD
25	79				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560UL	36			COLD
25	80	1.36	155	1	INR	AV6	+14.78	TEH	TEC	560UL	36			COLD
		0.57	164	1	TFH	AV6	+15.21	TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
25	81				NDD			TSH	TSH	560PP	17			HOT
		0.70	69	3	NQH	01H	+14.65	TEH	TEC	560DT	37	TO+18.63		COLD
		0.94	86	3	NQH	02H	+2.96	TEH	TEC	560DT	37	TO+5.67		COLD
25	82				NDD			TEH	TEC	560DT	38			COLD
					NDD			TSH	TSH	560PP	16			HOT
25	83	0.62	114	1	TFH	AV6	+15.21	TEH	TEC	560UL	39			COLD
25	84				NDD			TEH	TEC	560UL	39			COLD
25	85				NDD			TEH	TEC	560DT	40			COLD
25	86				NDD			TEH	TEC	560UL	39			COLD
25	87				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
25	88				NDD			TEH	TEC	560UL	39			COLD
					NDD			TEH	TSH	560PP	16			HOT
25	89				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
25	90				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
25	91	0.50	42	1	TFH	08C	+1.99	TEH	TEC	560DT	40			COLD
25	92	15.24		8	SLG	TSH	+0.44	TEH	TEC	560UL	39			COLD
		20.81		8	SLG	TSC	+0.60	TEH	TEC	560UL	39			COLD
25	93	24.72		8	SLG	TSC	+0.67	TEH	TEC	560DT	40			COLD
		0.60	80	1	TFH	08C	+1.93	TEH	TEC	560DT	40			COLD
25	94	18.13		8	SLG	TSH	+0.52	TEH	TEC	560UL	39			COLD
		23.81		8	SLG	TSC	+0.76	TEH	TEC	560UL	39			COLD
25	95				RBD			TEH	TEC	560DT	42			COLD
					NDD			TEH	TEC	560UC	70			COLD
					NDD			TSH	TSH	560PP	19			HOT
25	96				NDD			TSH	TSH	560PP	18			HOT
		21.42		8	SLG	TSH	+0.76	TEH	TEC	560UL	41			COLD
		25.13		8	SLG	TSC	+0.67	TEH	TEC	560UL	41			COLD
25	97	15.42		8	SLG	TSH	+0.46	TEH	TEC	560DT	42			COLD
		27.81		8	SLG	TSC	+0.77	TEH	TEC	560DT	42			COLD
		0.42	83	1	TFH	AV6	+15.54	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
25	98				NDD			TSH	TSH	560PP	18			HOT
		16.03		8	SLG	TSH	+0.46	TEH	TEC	560UL	41			COLD
		26.30		8	SLG	TSC	+0.78	TEH	TEC	560UL	41			COLD
25	99	16.63		8	SLG	TSC	+0.51	TEH	TEC	560DT	42			COLD
25	100	0.44	139	1	INR	AV6	+15.43	TEH	TEC	560UL	41			COLD
25	101	0.43	111	1	TFH	AV6	+15.59	TEH	TEC	560UL	41			COLD
25	102				NDD			TEH	TEC	560UL	41			COLD
25	103				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
25	104				NDD			TSH	TSH	560PP	20			HOT
		0.87	147	1	TFH	AV6	+15.41	TEH	TEC	560UL	43			COLD
25	105				NDD			TSH	TSH	560PP	21			HOT
		0.41	107	1	TFH	08C	+1.96	TEH	TEC	560UL	43			COLD
25	106				NDD			TSH	TSH	560PP	20			HOT
		1.19	155	1	INR	AV6	+15.90	TEH	TEC	560UL	43			COLD
25	107	0.88	120	3	INR	03C	-1.31	TEH	TEC	560UL	43			COLD
25	108	0.80	181	1	INR	08C	+1.83	TEH	TEC	560UL	44			COLD
25	109				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
25	110				NDD			TEH	TEC	560UC	80			COLD
25	111				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UC	72			COLD
25	112				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
25	113				NDD			TEH	TEC	560UC	80			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
25	114				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
25	115				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
25	116				NDD			TEH	TEC	560UC	80			COLD
26	7	15.34		8	SLG		TSC	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	44			HOT
26	8	17.15		8	SLG		TSC	TEH	TEC	560DT	17			COLD
		0.51		P 2	TWD	15	AV6	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	44			HOT
26	9	17.90		8	SLG		TSC	TEH	TEC	560DT	16			COLD
26	10	19.44		8	SLG		TSC	TEH	TEC	560DT	17			COLD
		4.53		184	1		DNG	TEH	TEC	560DT	17			COLD
		0.22		80	3		NQH	TEH	TEC	560DT	17			COLD
		4.05		185	P 1		DNT	TEH	TEC	560DT	17			COLD
					3		NDF	03H	02H	560PP	57			HOT
26	11	19.31		8	SLG		TSC	TEH	TEC	560DT	17			COLD
26	12	18.18		8	SLG		TSC	TEH	TEC	560DT	16			COLD
26	13	15.99		8	SLG		TSH	TEH	TEC	560DT	17			COLD
		18.29		8	SLG		TSC	TEH	TEC	560DT	17			COLD
26	14	15.70		8	SLG		TSH	TEH	TEC	560DT	16			COLD
		17.92		8	SLG		TSC	TEH	TEC	560DT	16			COLD
26	15	16.07		8	SLG		TSH	TEH	TEC	560DT	17			COLD
		18.40		8	SLG		TSC	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	44			HOT
26	16				NDD			TSH	TSH	560PP	45			HOT
		17.09		8	SLG		TSH	TEH	TEC	560DT	17			COLD
		18.21		8	SLG		TSC	TEH	TEC	560DT	17			COLD
26	17	17.52		8	SLG		TSH	TEH	TEC	560DT	17			COLD
		18.46		8	SLG		TSC	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	42			HOT
26	18	16.97		8	SLG		TSH	TEH	TEC	560DT	18			COLD
		16.99		8	SLG		TSC	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
26	19	17.50		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		17.12		8	SLG		TSC	TEH	TEC	560DT	19			COLD
26	20	18.06		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		15.93		8	SLG		TSC	TEH	TEC	560DT	19			COLD
26	21	18.69		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		16.32		8	SLG		TSC	TEH	TEC	560DT	19			COLD
26	22	18.16		8	SLG		TSH	TEH	TEC	560DT	18			COLD
26	23	18.34		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		16.01		8	SLG		TSC	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
26	24	18.96		8	SLG		TSH	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
26	25	19.18		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		15.22		8	SLG		TSC	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
26	26	19.27		8	SLG		TSH	TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	43			HOT
26	27	1.34		89	6		INR	TEH	TEC	560DT	21			COLD
		18.33		8	SLG		TSH	TEH	TEC	560DT	21			COLD
26	28	0.63		107	3		INR	TEH	TEC	560DT	20			COLD
		19.39		8	SLG		TSH	TEH	TEC	560DT	20			COLD
26	29	19.06		8	SLG		TSH	TEH	TEC	560DT	21			COLD
26	30	19.27		8	SLG		TSH	TEH	TEC	560DT	20			COLD
26	31	18.49		8	SLG		TSH	TEH	TEC	560DT	21			COLD
					NDD			TSH	TSH	560PP	42			HOT
26	32				NDD			TSH	TSH	560PP	40			HOT
		18.89		8	SLG		TSH	TEH	TEC	560DT	20			COLD
26	33				NDD			TSH	TSH	560PP	40			HOT
		18.84		8	SLG		TSH	TEH	TEC	560DT	21			COLD
26	34				NDD			TSH	TSH	560PP	40			HOT
		19.19		8	SLG		TSH	TEH	TEC	560DT	20			COLD
26	35	18.94		8	SLG		TSH	TEH	TEC	560DT	21			COLD
26	36	19.81		8	SLG		TSH	TEH	TEC	560DT	20			COLD
26	37	19.47		8	SLG		TSH	TEH	TEC	560DT	22			COLD
26	38				NDD			TEH	TEC	560DT	22			COLD
26	39	19.82		8	SLG		TSH	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
26	40	19.19		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	41			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
26	41	19.92		8	SLG		TSH	+0.67	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
26	42	4.76	184	P 1	DNT		01C	-0.49	TEH	TEC	560DT	22	OK	COLD
		18.93		8	SLG		TSH	+0.65	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
26	43	19.30		8	SLG		TSH	+0.66	TEH	TEC	560DT	23		COLD
26	44	18.24		8	SLG		TSH	+0.65	TEH	TEC	560DT	22		COLD
26	45	18.73		8	SLG		TSH	+0.64	TEH	TEC	560DT	23		COLD
					NDD				TEH	TSH	560PP	40		HOT
26	46	18.88		8	SLG		TSH	+0.67	TEH	TEC	560DT	22		COLD
26	47	19.09		8	SLG		TSH	+0.66	TEH	TEC	560DT	23		COLD
					NDD				TEH	TSH	560PP	41		HOT
26	48	21.21		8	SLG		TSH	+0.69	TEH	TEC	560DT	25		COLD
					NDD				TSH	TSH	560PP	41		HOT
26	49	19.29		8	SLG		TSH	+0.62	TEH	TEC	560DT	24		COLD
					NDD				TSH	TSH	560PP	36		HOT
26	50	21.57		8	SLG		TSH	+0.69	TEH	TEC	560DT	25		COLD
					NDD				TSH	TSH	560PP	36		HOT
26	51	21.23		8	SLG		TSH	+0.69	TEH	TEC	560DT	25		COLD
26	52	19.57		8	SLG		TSH	+0.68	TEH	TEC	560DT	24		COLD
26	53				NDD				TEH	TEC	560DT	25		COLD
26	54	19.98		8	SLG		TSH	+0.72	TEH	TEC	560DT	27		COLD
26	55				NDD				TEH	TEC	560UL	47		COLD
					RBD				TEH	TEC	560DT	26		COLD
					NDD				TSH	TSH	560PP	36		HOT
26	56				NDD				TEH	TEC	560UL	46		COLD
					RBD				TEH	TEC	560DT	27		COLD
					NDD				TSH	TSH	560PP	34		HOT
26	57				NDD				TEH	TEC	560UL	47		COLD
					NDD				TSH	TSH	560PP	36		HOT
26	58				NDD				TEH	TEC	560UL	46		COLD
					NDD				TSH	TSH	560PP	34		HOT
26	59				NDD				TEH	TEC	560UL	47		COLD
26	60				NDD				TEH	TEC	560UL	46		COLD
26	61				NDD				TEH	TEC	560DT	35		COLD
26	62				NDD				TEH	TEC	560DT	35		COLD
26	63				NDD				TSH	TSH	560PP	14		HOT
					NDD				TEH	TEC	560DT	34		COLD
26	64				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	35		COLD
26	65				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	34		COLD
26	66				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	35		COLD
26	67				NDD				TEH	TEC	560DT	37		COLD
26	68				NDD				TEH	TEC	560DT	37		COLD
26	69				NDD				TEH	TEC	560UL	36		COLD
26	70	0.87	63	3	NQH		06C	+11.77	TEH	TEC	560DT	37		COLD
26	71				NDD				TEH	TEC	560UL	36		COLD
					NDD				TSH	TSH	560PP	16		HOT
26	72			3	NDF		08H	+0.00	08H	08H	560PP	61		HOT
					NDD				TSH	TSH	560PP	17		HOT
		7.76	180	P 1	DNT		08H	+0.40	TEH	TEC	560DT	35		COLD
26	73				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	35		COLD
26	74				NDD				TSH	TSH	560PP	17		HOT
		2.09	83	6	INR		01C	+15.29	TEH	TEC	560DT	34		COLD
26	75				NDD				TEH	TEC	560DT	34		COLD
26	76				NDD				TEH	TEC	560DT	37		COLD
26	77				NDD				TEH	TEC	560DT	37		COLD
26	78				NDD				TEH	TEC	560DT	37		COLD
26	79				NDD				TSH	TSH	560PP	16		HOT
					NDD				TEH	TEC	560DT	37		COLD
26	80				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	37		COLD
26	81				NDD				TEH	TEC	560UL	36		COLD
					NDD				TSH	TSH	560PP	16		HOT
26	82				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	38		COLD
26	83				NDD				TEH	TEC	560DT	40		COLD
26	84				NDD				TEH	TEC	560DT	40		COLD
26	85				NDD				TEH	TEC	560UL	39		COLD
26	86				NDD				TEH	TEC	560DT	40		COLD
26	87				NDD				TEH	TEC	560UL	39		COLD
					NDD				TSH	TSH	560PP	16		HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
26	88				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
26	89				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
26	90				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
26	91	18.75		8	SLG		TSC	TEH	TEC	560UL	39			COLD
26	92	22.11		8	SLG		TSC	TEH	TEC	560DT	40			COLD
26	93	21.45		8	SLG		TSC	TEH	TEC	560UL	39			COLD
26	94	17.50		8	SLG		TSH	TEH	TEC	560DT	40			COLD
		25.78		8	SLG		TSC	TEH	TEC	560DT	40			COLD
26	95				NDD			TSH	TSH	560PP	18			HOT
		17.10		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		25.56		8	SLG		TSC	TEH	TEC	560UL	41			COLD
26	96	15.78		8	SLG		TSH	TEH	TEC	560DT	42			COLD
		24.57		8	SLG		TSC	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
26	97				NDD			TSH	TSH	560PP	18			HOT
		15.46		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		25.87		8	SLG		TSC	TEH	TEC	560UL	41			COLD
26	98	19.61		8	SLG		TSH	TEH	TEC	560DT	42			COLD
		25.55		8	SLG		TSC	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
26	99	17.35		8	SLG		TSC	TEH	TEC	560UL	41			COLD
26	100				NDD			TEH	TSH	560PP	18			HOT
					NDD			TEH	TEC	560DT	42			COLD
26	101				NDD			TEH	TEC	560UL	41			COLD
26	102	3.65	180	1	DNG		07H	TEH	TEC	560UL	41			COLD
26	103				NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	43			COLD
26	104				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
26	105				NDD			TSH	TSH	560PP	20			HOT
		17.30		8	SLG		TSC	TEH	TEC	560UL	43			COLD
26	106				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
26	107				NDD			TEH	TEC	560UL	43			COLD
26	108				NDD			TEH	TEC	560UL	45			COLD
26	109				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
26	110				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
26	111				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
26	112				NDD			TEH	TEC	560UC	80			COLD
					RBD			TSH	TSH	560PP	21			HOT
					NDD			TSH	TSH	560PP	50			HOT
26	113				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
26	114				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
26	115	0.40	0	P 2	TWD 11		AV1	TEH	TEC	560UC	80			COLD
		0.44	92	P 2	TWD 12		AV1	TEH	TEC	560UC	72			COLD
26	116				NDD			TEH	TEC	560UC	80			COLD
27	8	17.94		8	SLG		TSC	TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	44			HOT
27	9	18.62		8	SLG		TSC	TEH	TEC	560DT	17			COLD
		0.41	78	3	NQH		08H	TEH	TEC	560DT	17			COLD
27	10	18.27		8	SLG		TSC	TEH	TEC	560DT	16			COLD
27	11	19.32		8	SLG		TSC	TEH	TEC	560DT	16			COLD
27	12	19.35		8	SLG		TSC	TEH	TEC	560DT	17			COLD
27	13	0.31	142	1	INR		08H	TEH	TEC	560DT	16			COLD
		5.67	186	1	DNG		08C	TEH	TEC	560DT	16			COLD
		18.06		8	SLG		TSC	TEH	TEC	560DT	16			COLD
				2	NDF		08H	AV1	08H	5201P	72			HOT
27	14	15.89		8	SLG		TSH	TEH	TEC	560DT	17			COLD
		18.70		8	SLG		TSC	TEH	TEC	560DT	17			COLD
27	15				NDD			TSH	TSH	560PP	45			HOT
		15.84		8	SLG		TSH	TEH	TEC	560DT	16			COLD
		17.60		8	SLG		TSC	TEH	TEC	560DT	16			COLD
27	16	15.98		8	SLG		TSH	TEH	TEC	560DT	16			COLD
		17.05		8	SLG		TSC	TEH	TEC	560DT	16			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	±TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
27	17	16.81		8	NDD		TSH	TSH	560PP	44				HOT
		17.74		8	SLG		TSH	TEC	560DT	16				COLD
							TSC	TEC	560DT	16				COLD
					NDD		TSH	TSH	560PP	43				HOT
27	18	16.85		8	SLG		TSH	TEC	560DT	19				COLD
		17.71		8	SLG		TSC	TEC	560DT	19				COLD
					NDD		TSH	TSH	560PP	42				HOT
27	19	17.03		8	SLG		TSH	TEC	560DT	18				COLD
		16.34		8	SLG		TSC	TEC	560DT	18				COLD
27	20	17.45		8	SLG		TSH	TEC	560DT	18				COLD
		16.34		8	SLG		TSC	TEC	560DT	18				COLD
27	21	17.49		8	SLG		TSH	TEC	560DT	18				COLD
		16.18		8	SLG		TSC	TEC	560DT	18				COLD
27	22	18.20		8	SLG		TSH	TEC	560DT	19				COLD
		15.42		8	SLG		TSC	TEC	560DT	19				COLD
27	23	17.73		8	SLG		TSH	TEC	560DT	18				COLD
					NDD		TSH	TSH	560PP	43				HOT
27	24	18.51		8	SLG		TSH	TEC	560DT	19				COLD
					NDD		TSH	TSH	560PP	42				HOT
27	25	17.97		8	SLG		TSH	TEC	560DT	18				COLD
					NDD		TSH	TSH	560PP	43				HOT
27	26	18.57		8	SLG		TSH	TEC	560DT	21				COLD
					NDD		TSH	TSH	560PP	42				HOT
27	27	19.49		8	SLG		TSH	TEC	560DT	20				COLD
27	28	18.92		8	SLG		TSH	TEC	560DT	21				COLD
27	29	19.21		8	SLG		TSH	TEC	560DT	20				COLD
27	30	18.57		8	SLG		TSH	TEC	560DT	21				COLD
27	31	18.79		8	SLG		TSH	TEC	560DT	20				COLD
					NDD		TSH	TSH	560PP	43				HOT
27	32			8	NDD		TSH	TSH	560PP	40				HOT
		18.86		8	SLG		TSH	TEC	560DT	21				COLD
27	33	19.25		8	SLG		TSH	TEC	560DT	20				COLD
					NDD		TSH	TSH	560PP	41				HOT
27	34	18.72		8	SLG		TSH	TEC	560DT	21				COLD
					NDD		TSH	TSH	560PP	41				HOT
27	35	19.01		8	SLG		TSH	TEC	560DT	20				COLD
27	36	18.88		8	SLG		TSH	TEC	560DT	21				COLD
27	37	20.01		8	SLG		TSH	TEC	560DT	23				COLD
27	38	19.46		8	SLG		TSH	TEC	560DT	23				COLD
27	39	19.11		8	SLG		TSH	TEC	560DT	22				COLD
					NDD		TSH	TSH	560PP	41				HOT
27	40	19.44		8	SLG		TSH	TEC	560DT	23				COLD
					NDD		TSH	TSH	560PP	40				HOT
27	41	19.09		8	SLG		TSH	TEC	560DT	22				COLD
					NDD		TSH	TSH	560PP	41				HOT
27	42	19.69		8	SLG		TSH	TEC	560DT	23				COLD
					NDD		TSH	TSH	560PP	40				HOT
27	43	19.33		8	SLG		TSH	TEC	560DT	22				COLD
27	44	19.51		8	SLG		TSH	TEC	560DT	23				COLD
27	45	18.30		8	SLG		TSH	TEC	560DT	22				COLD
27	46	19.34		8	SLG		TSH	TEC	560DT	23				COLD
27	47	19.31		8	SLG		TSH	TEC	560DT	22				COLD
					NDD		TSH	TSH	560PP	40				HOT
27	48	19.92		8	SLG		TSH	TEC	560DT	24				COLD
					NDD		TSH	TSH	560PP	40				HOT
27	49	20.08		8	SLG		TSH	TEC	560DT	24				COLD
					NDD		TSH	TSH	560PP	34				HOT
27	50	19.61		8	SLG		TSH	TEC	560DT	24				COLD
					NDD		TSH	TSH	560PP	34				HOT
27	51	19.82		8	SLG		TSH	TEC	560DT	24				COLD
27	52	21.19		8	SLG		TSH	TEC	560DT	25				COLD
27	53	19.04		8	SLG		TSH	TEC	560DT	24				COLD
27	54	19.14		8	SLG		TSH	TEC	560DT	26				COLD
27	55	19.69		8	SLG		TSH	TEC	560DT	27				COLD
					NDD		TSH	TSH	560PP	34				HOT
27	56	18.65		8	SLG		TSH	TEC	560DT	26				COLD
					NDD		TSH	TSH	560PP	36				HOT
27	57				NDD		TEH	TEC	560UL	47				COLD
					NDD		TSH	TSH	560PP	34				HOT
27	58				NDD		TEH	TEC	560UL	46				COLD
					NDD		TSH	TSH	560PP	35				HOT
27	59				NDD		TEH	TEC	560UL	47				COLD
27	60				NDD		TEH	TEC	560UL	46				COLD
27	61				NDD		TEH	TEC	560DT	34				COLD
27	62				NDD		TEH	TEC	560DT	34				COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
27	63				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	35			COLD
27	64				RBD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560DT	34			COLD
					NDD			TSH	TSH	560PP	50			HOT
27	65				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	35			COLD
27	66				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	34			COLD
27	67				NDD			TEH	TEC	560DT	37			COLD
27	68				NDD			TEH	TEC	560UL	36			COLD
27	69				NDD			TEH	TEC	560DT	37			COLD
27	70				NDD			TEH	TEC	560UL	36			COLD
27	71				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	37			COLD
27	72			3	NDF	07H	+32.37	07H	08H	560PP	61			HOT
				3	NDF	07H	+39.10	07H	08H	560PP	61			HOT
				3	NDF	08H	-0.58	07H	08H	560PP	61			HOT
				3	NDF	08H	+0.00	07H	08H	560PP	61			HOT
				3	NDF	07H	+31.49	07H	08H	560PP	61			HOT
					NDD			TSH	TSH	560PP	16			HOT
	4.65	175	1	DNG	07H	+32.15		TEH	TEC	560DT	34			COLD
	0.85	137	5	DDH	07H	+32.15		TEH	TEC	560DT	34			COLD
	3.54	165	P 1	DNT	08H	-0.62		TEH	TEC	560DT	34			COLD
	3.54	165	P 1	DDH	08H	-0.62		TEH	TEC	560DT	34			COLD
	15.70	181	P 1	DNT	08H	+0.57		TEH	TEC	560DT	34			COLD
	3.45	179	1	DNG	08H	+3.80		TEH	TEC	560DT	34			COLD
	0.29	114	3	INR	07H	+18.57		TEH	TEC	560DT	34			COLD
	10.51	177	P 1	DNT	08C	-0.37		TEH	TEC	560DT	34			COLD
27	73				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
27	74				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
27	75				NDD			TEH	TEC	560DT	35			COLD
27	76				NDD			TEH	TEC	560UL	36			COLD
27	77				NDD			TEH	TEC	560UL	36			COLD
27	78				NDD			TEH	TEC	560UL	36			COLD
27	79				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560UL	36			COLD
27	80				NDD			TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
27	81				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	37			COLD
27	82				NDD			TEH	TEC	560DT	38			COLD
					NDD			TSH	TSH	560PP	16			HOT
27	83				NDD			TEH	TEC	560UL	39			COLD
27	84				NDD			TEH	TEC	560UL	39			COLD
27	85				RBD			TEH	TEC	560DT	40			COLD
					NDD			TEH	TEC	560UC	70			COLD
27	86				NDD			TEH	TEC	560UL	39			COLD
27	87				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
27	88				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
27	89				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
27	90				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
27	91	20.13		8	SLG	TSC	+0.56	TEH	TEC	560DT	40			COLD
27	92	21.47		8	SLG	TSC	+0.66	TEH	TEC	560UL	39			COLD
27	93			3	NDF	01H	+7.94	01H	02H	560PP	61			HOT
	25.37			8	SLG	TSC	+0.70	TEH	TEC	560DT	40			COLD
	6.78	188	1	DNG	01H	+7.94		TEH	TEC	560DT	40			COLD
27	94	18.71		8	SLG	TSH	+0.57	TEH	TEC	560UL	39			COLD
	23.19			8	SLG	TSC	+0.79	TEH	TEC	560UL	39			COLD
27	95	16.85		8	SLG	TSH	+0.48	TEH	TEC	560DT	42			COLD
	26.02			8	SLG	TSC	+0.72	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
27	96				NDD			TSH	TSH	560PP	18			HOT
	16.94			8	SLG	TSH	+0.49	TEH	TEC	560UL	41			COLD
	23.26			8	SLG	TSC	+0.65	TEH	TEC	560UL	41			COLD
	0.30	98	P 1	INR	08C	-0.73		TEH	TEC	560UL	41			COLD
27	97	17.09		8	SLG	TSH	+0.48	TEH	TEC	560DT	42			COLD
	23.54			8	SLG	TSC	+0.64	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	#TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
27	98				NDD			TSH	TSH	560PP	18			HOT
		21.07		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		25.34		8	SLG		TSC	TEH	TEC	560UL	41			COLD
		0.30	139	1	INR		08C	TEH	TEC	560UL	41			COLD
27	99	17.79		8	SLG		TSC	TEH	TEC	560DT	42			COLD
27	100			3	NDF		01H	01H	02H	560PP	61			HOT
		4.00	188	1	DNG		01H	TEH	TEC	560UL	41			COLD
27	101				NDD			TEH	TEC	560UL	41			COLD
27	102				NDD			TEH	TEC	560UL	41			COLD
27	103				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
27	104	17.54		8	SLG		TSC	TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	43			COLD
27	105	20.51		8	SLG		TSC	TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	43			COLD
27	106	18.32		8	SLG		TSC	TSH	TSH	560PP	20			HOT
		17.26		8	SLG		TSC	TEH	TEC	560UL	43			COLD
27	107	2.46	170	1	INR		08H	TEH	TEC	560UL	43			COLD
		6.64	178	P 1	DNT		08H	TEH	TEC	560UL	43			COLD
				3	NDF		08H	08H	08H	560PP	62			HOT
				3	NDF		08H	08H	08H	560PP	62			HOT
27	108				NDD			TEH	TEC	560UL	44			COLD
27	109				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
27	110				NDD			TEH	TEC	560UC	80			COLD
27	111				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UC	72			COLD
27	112				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
27	113				NDD			TEH	TEC	560UC	80	IDOK		COLD
					NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	72			COLD
27	114				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	67			HOT
27	115	0.40	0	P 2	TWD	11	AV1	TEH	TEC	560UC	80			COLD
		0.36	0	P 2	TWD	10	AV6	TEH	TEC	560UC	80			COLD
28	8	17.19		8	SLG		TSC	TEH	TEC	560DT	17			COLD
		0.39		P 2	TWD	12	AV1	TEH	TEC	560DT	17			COLD
		0.52		P 2	TWD	16	AV6	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	44			HOT
28	9	17.29		8	SLG		TSC	TEH	TEC	560DT	16			COLD
28	10	18.84		8	SLG		TSC	TEH	TEC	560DT	17			COLD
28	11	19.64		8	SLG		TSC	TEH	TEC	560DT	17			COLD
28	12	18.14		8	SLG		TSC	TEH	TEC	560DT	16			COLD
28	13	15.85		8	SLG		TSH	TEH	TEC	560DT	17			COLD
28	13	19.52		8	SLG		TSC	TEH	TEC	560DT	17			COLD
28	14	17.64		8	SLG		TSC	TEH	TEC	560DT	16			COLD
28	15	18.37		8	SLG		TSC	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	44			HOT
28	16				NDD			TSH	TSH	560PP	45			HOT
		16.52		8	SLG		TSH	TEH	TEC	560DT	17			COLD
		18.23		8	SLG		TSC	TEH	TEC	560DT	17			COLD
28	17	1.76	165	3	INR		07C	TEH	TEC	560DT	17			COLD
		15.62		8	SLG		TSH	TEH	TEC	560DT	17			COLD
		17.91		8	SLG		TSC	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	42			HOT
28	18	16.47		8	SLG		TSH	TEH	TEC	560DT	18			COLD
		17.21		8	SLG		TSC	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
28	19	16.83		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		18.28		8	SLG		TSC	TEH	TEC	560DT	19			COLD
28	20	17.12		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		17.10		8	SLG		TSC	TEH	TEC	560DT	19			COLD
28	21	17.22		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		16.26		8	SLG		TSC	TEH	TEC	560DT	19			COLD
28	22	17.83		8	SLG		TSH	TEH	TEC	560DT	18			COLD
28	23	18.44		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		15.63		8	SLG		TSC	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
28	24	18.40		8	SLG		TSH	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
28	25	19.14		8	SLG		TSH	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
28	26	18.13		8	SLG		TSH	+0.60	TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	43		HOT
28	27	19.24		8	SLG		TSH	+0.64	TEH	TEC	560DT	21		COLD
28	28	18.53		8	SLG		TSH	+0.62	TEH	TEC	560DT	20		COLD
28	29	17.91		8	SLG		TSH	+0.62	TEH	TEC	560DT	21		COLD
28	30	18.91		8	SLG		TSH	+0.62	TEH	TEC	560DT	20		COLD
28	31	18.11		8	SLG		TSH	+0.59	TEH	TEC	560DT	21		COLD
					NDD				TSH	TSH	560PP	42		HOT
28	32	19.19		8	SLG		TSH	+0.62	TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	40		HOT
28	33				NDD				TSH	TSH	560PP	40		HOT
		17.55		8	SLG		TSH	+0.56	TEH	TEC	560DT	21		COLD
28	34				NDD				TSH	TSH	560PP	40		HOT
		18.21		8	SLG		TSH	+0.62	TEH	TEC	560DT	20		COLD
28	35	18.29		8	SLG		TSH	+0.61	TEH	TEC	560DT	21		COLD
28	36	11.41	183	1	DNG		07H	+38.16	TEH	TEC	560DT	20		COLD
		4.07	183	1	DNG		07C	+30.98	TEH	TEC	560DT	20		COLD
		4.49	180	P 1	DNT		08C	-0.08	TEH	TEC	560DT	20		COLD
		4.59	176	P 1	DNT		08H	+0.55	TEH	TEC	560DT	20		COLD
		19.17		8	SLG		TSH	+0.65	TEH	TEC	560DT	20		COLD
				3	NDF		08H	+0.55	08H	07H	560PP	57		HOT
				3	NDF		07H	+38.16	08H	07H	560PP	57		HOT
28	37	19.19		8	SLG		TSH	+0.65	TEH	TEC	560DT	22		COLD
28	38	19.35		8	SLG		TSH	+0.67	TEH	TEC	560DT	22		COLD
28	39	19.76		8	SLG		TSH	+0.67	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
28	40	19.55		8	SLG		TSH	+0.67	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
28	41	19.42		8	SLG		TSH	+0.67	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
28	42	4.21	185	1	DNG		AV1	+2.27	TEH	TEC	560DT	22		COLD
		19.39		8	SLG		TSH	+0.67	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
28	43	19.46		8	SLG		TSH	+0.69	TEH	TEC	560DT	23		COLD
28	44	18.91		8	SLG		TSH	+0.67	TEH	TEC	560DT	22		COLD
28	45	19.42		8	SLG		TSH	+0.69	TEH	TEC	560DT	23		COLD
28	46	19.85		8	SLG		TSH	+0.72	TEH	TEC	560DT	22		COLD
28	47	19.74		8	SLG		TSH	+0.71	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	41		HOT
28	48	20.92		8	SLG		TSH	+0.67	TEH	TEC	560DT	24		COLD
					NDD				TSH	TSH	560PP	41		HOT
28	51	22.32		8	SLG		TSH	+0.69	TEH	TEC	560DT	25		COLD
28	52	19.92		8	SLG		TSH	+0.70	TEH	TEC	560DT	24		COLD
28	53	22.39		8	SLG		TSH	+0.79	TEH	TEC	560DT	25		COLD
28	54	20.39		8	SLG		TSH	+0.74	TEH	TEC	560DT	27		COLD
28	55				NDD				TEH	TEC	560UL	46		COLD
					RBD				TEH	TEC	560DT	26		COLD
					NDD				TSH	TSH	560PP	36		HOT
28	56	19.57		8	SLG		TSH	+0.69	TEH	TEC	560DT	27		COLD
					NDD				TSH	TSH	560PP	34		HOT
28	57				NDD				TEH	TEC	560UL	47		COLD
					NDD				TSH	TSH	560PP	36		HOT
28	58				NDD				TEH	TEC	560UL	46		COLD
					NDD				TSH	TSH	560PP	34		HOT
28	59				NDD				TEH	TEC	560UL	46		COLD
28	60				NDD				TEH	TEC	560UL	46		COLD
28	61				NDD				TEH	TEC	560DT	35		COLD
28	62				NDD				TEH	TEC	560DT	35		COLD
28	63				NDD				TSH	TSH	560PP	14		HOT
					NDD				TEH	TEC	560DT	34		COLD
28	64				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	35		COLD
28	65				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	34		COLD
28	66				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	35		COLD
28	67				NDD				TEH	TEC	560DT	37		COLD
28	68				NDD				TEH	TEC	560DT	37		COLD
28	69				NDD				TEH	TEC	560UL	36		COLD
28	70				NDD				TEH	TEC	560DT	37		COLD
28	71	0.59	135	3	INR		01C	+14.39	TEH	TEC	560UL	36		COLD
					NDD				TSH	TSH	560PP	16		HOT
28	72				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	35		COLD
28	75				NDD				TEH	TEC	560DT	34		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
28	76				NDD			TEH	TEC	560DT	37			COLD
28	77				NDD			TEH	TEC	560DT	37			COLD
28	78				NDD			TEH	TEC	560DT	37			COLD
28	79				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	37			COLD
28	80			3	NDF		08H +0.49	08H	08H	560PP	61			HOT
				3	NDF		08H -0.64	08H	08H	560PP	61			HOT
					NDD			TSH	TSH	560PP	17			HOT
		6.10		179	P 1		DNT 08H +0.49	TEH	TEC	560DT	37			COLD
		3.01		167	P 1		DNT 08C +0.28	TEH	TEC	560DT	37			COLD
		0.79		192	P 1		INR 08C -0.66	TEH	TEC	560DT	37			COLD
		1.26		159	P 1		INR 08H -0.65	TEH	TEC	560DT	37			COLD
28	81				NDD			TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
28	82				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	38			COLD
28	83				NDD			TEH	TEC	560DT	40			COLD
28	84				NDD			TEH	TEC	560DT	40			COLD
28	85				NDD			TEH	TEC	560UL	39			COLD
28	86				NDD			TEH	TEC	560DT	40			COLD
28	87				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
28	88				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
28	89				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
28	90				NDD			TSH	TSH	560PP	17			HOT
		15.72		8	SLG		TSC +0.46	TEH	TEC	560DT	40			COLD
		1.26		110	3		NQH 02H +29.49	TEH	TEC	560DT	40			COLD
28	91	16.21		8	SLG		TSH +0.50	TEH	TEC	560UL	39			COLD
		20.53		8	SLG		TSC +0.64	TEH	TEC	560UL	39			COLD
28	92	22.57		8	SLG		TSC +0.62	TEH	TEC	560DT	40			COLD
28	93	16.13		8	SLG		TSH +0.47	TEH	TEC	560UL	39			COLD
		23.31		8	SLG		TSC +0.76	TEH	TEC	560UL	39			COLD
28	94	16.84		8	SLG		TSH +0.48	TEH	TEC	560DT	40			COLD
		25.98		8	SLG		TSC +0.72	TEH	TEC	560DT	40			COLD
28	95				NDD			TSH	TSH	560PP	18			HOT
		18.05		8	SLG		TSH +0.49	TEH	TEC	560UL	41			COLD
		24.78		8	SLG		TSC +0.73	TEH	TEC	560UL	41			COLD
28	96	18.68		8	SLG		TSH +0.51	TEH	TEC	560DT	42			COLD
		24.22		8	SLG		TSC +0.72	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
28	97				NDD			TSH	TSH	560PP	18			HOT
		18.11		8	SLG		TSH +0.51	TEH	TEC	560UL	41			COLD
		24.82		8	SLG		TSC +0.75	TEH	TEC	560UL	41			COLD
28	98	18.58		8	SLG		TSH +0.53	TEH	TEC	560DT	42			COLD
		24.65		8	SLG		TSC +0.80	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
28	99	18.87		8	SLG		TSC +0.60	TEH	TEC	560UL	41			COLD
28	100				RBD			TEH	TEC	560DT	42			COLD
					NDD			TEH	TEC	560UC	70			COLD
28	101				NDD			TEH	TEC	560UL	41			COLD
28	102				NDD			TEH	TEC	560UL	41			COLD
28	103			3	NDF		08H +0.00	07H	08H	560PP	61			HOT
				3	NDF		07H +38.80	07H	08H	560PP	61			HOT
				3	NDF		07H +37.94	07H	08H	560PP	61			HOT
					NDD			TSH	TSH	560PP	20			HOT
		13.26		185	1		DNG 08H -1.56	TEH	TEC	560UL	43			COLD
		8.23		182	1		DNG 07C +36.32	TEH	TEC	560UL	43			COLD
		5.49		183	1		DNG 07C +8.98	TEH	TEC	560UL	43			COLD
		4.34		180	1		DNG 07C +5.92	TEH	TEC	560UL	43			COLD
		14.15		184	P 1		DNT 08C +0.36	TEH	TEC	560UL	43			COLD
28	104				NDD			TSH	TSH	560PP	21			HOT
		19.99		8	SLG		TSC +0.56	TEH	TEC	560UL	43			COLD
28	105				NDD			TSH	TSH	560PP	20			HOT
		23.56		8	SLG		TSC +0.67	TEH	TEC	560UL	43			COLD
28	106				NDD			TSH	TSH	560PP	21			HOT
		0.68		95	3		NQH 02C +37.67	TEH	TEC	560UL	43			COLD
		0.74		114	3		NQH 02C +32.11	TEH	TEC	560UL	43			COLD
		20.81		8	SLG		TSC +0.60	TEH	TEC	560UL	43			COLD
28	107	20.61		8	SLG		TSC +0.57	TEH	TEC	560UL	43			COLD
28	108				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
28	109				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
28	110				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
28	111				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
28	112				NDD			TEH	TEC	560UC	80			COLD
					RBD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UC	72			COLD
					NDD			TSH	TSH	560PP	50			HOT
28	113				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
28	114	1.20	0	P 2	TWD	27	AV2	TEH	TEC	560UC	80			COLD
		0.26	0	P 2	INR		AV5	TEH	TEC	560UC	80	IDOK		COLD
					NDD			TSH	TSH	560PP	67			HOT
		1.27		P 2	TWD	28	AV2	TEH	TEC	560UC	72			COLD
		0.29	138	P 2	INR		AV5	TEH	TEC	560UC	72			COLD
28	115	1.69	0	P 2	TWD	33	AV1	TEH	TEC	560UC	80			COLD
29	9	16.93		8	SLG		TSC	TEH	TEC	560DT	16			COLD
29	10	17.90		8	SLG		TSC	TEH	TEC	560DT	16			COLD
29	11	0.98	125	3	INR		02C	TEH	TEC	560DT	16			COLD
		18.59		8	SLG		TSC	TEH	TEC	560DT	16			COLD
29	12	19.35		8	SLG		TSC	TEH	TEC	560DT	17			COLD
		0.65	124	1	TFH		08H	TEH	TEC	560DT	17			COLD
		0.24	105	1	TFH		08H	TEH	TEC	560DT	17			COLD
29	13	18.51		8	SLG		TSC	TEH	TEC	560DT	16			COLD
29	14	15.34		8	SLG		TSH	TEH	TEC	560DT	17			COLD
		18.97		8	SLG		TSC	TEH	TEC	560DT	17			COLD
29	15				NDD			TSH	TSH	560PP	45			HOT
		0.81	150	1	INR		08H	TEH	TEC	560DT	16			COLD
		17.44		8	SLG		TSC	TEH	TEC	560DT	16			COLD
				2	NDF		08H	AV1	08H	5201P	72			COLD
29	16	17.44		8	SLG		TSC	TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	44			HOT
29	17	0.57	136	1	TFH		08H	TEH	TEC	560DT	16			COLD
		16.95		8	SLG		TSC	TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	43			HOT
29	18	16.81		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		18.59		8	SLG		TSC	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
29	19	15.62		8	SLG		TSH	TEH	TEC	560DT	18			COLD
		16.75		8	SLG		TSC	TEH	TEC	560DT	18			COLD
		0.23	91	3	NQH		08H	TEH	TEC	560DT	18			COLD
29	20	17.27		8	SLG		TSH	TEH	TEC	560DT	18			COLD
		17.51		8	SLG		TSC	TEH	TEC	560DT	18			COLD
29	21	17.21		8	SLG		TSH	TEH	TEC	560DT	18			COLD
		15.98		8	SLG		TSC	TEH	TEC	560DT	18			COLD
		0.87	156	1	INR		08H	TEH	TEC	560DT	18			COLD
29	22	18.08		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		16.67		8	SLG		TSC	TEH	TEC	560DT	19			COLD
29	23	18.24		8	SLG		TSH	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
29	24	18.59		8	SLG		TSH	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
29	25	18.30		8	SLG		TSH	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
29	26	18.74		8	SLG		TSH	TEH	TEC	560DT	21			COLD
					NDD			TSH	TSH	560PP	42			HOT
29	27	18.95		8	SLG		TSH	TEH	TEC	560DT	20			COLD
29	28	0.49	117	1	TFH		08H	TEH	TEC	560DT	21			COLD
		18.84		8	SLG		TSH	TEH	TEC	560DT	21			COLD
29	29	0.79	140	1	TFH		08H	TEH	TEC	560DT	20			COLD
29	30	0.46	103	1	TFH		08H	TEH	TEC	560DT	21			COLD
29	31	18.99		8	SLG		TSH	TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	43			HOT
29	32	18.68		8	SLG		TSH	TEH	TEC	560DT	21			COLD
					NDD			TSH	TSH	560PP	40			HOT
29	33	0.47	139	1	TFH		08H	TEH	TEC	560DT	20			COLD
		19.03		8	SLG		TSH	TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	41			HOT
29	34	18.57		8	SLG		TSH	TEH	TEC	560DT	21			COLD
					NDD			TSH	TSH	560PP	41			HOT
29	35	19.45		8	SLG		TSH	TEH	TEC	560DT	20			COLD
29	36	18.49		8	SLG		TSH	TEH	TEC	560DT	21			COLD
29	37	19.90		8	SLG		TSH	TEH	TEC	560DT	23			COLD
29	38	18.99		8	SLG		TSH	TEH	TEC	560DT	23			COLD
29	39	19.01		8	SLG		TSH	TEH	TEC	560DT	22			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
29	40	19.36			NDD			TSH	TSH	560PP	41			HOT
					SLG		TSH	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
29	41	19.37			SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	41			HOT
29	42	19.30			SLG		TSH	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
29	43	20.03			SLG		TSH	TEH	TEC	560DT	22			COLD
29	44	0.50	142	1	TFH		08H	TEH	TEC	560DT	23			COLD
		20.15			SLG		TSH	TEH	TEC	560DT	23			COLD
					NDF		08H	AV1	08H	5201P	72			HOT
29	45	19.23			SLG		TSH	TEH	TEC	560DT	22			COLD
29	46	0.44	104	3	NQH		01C	TEH	TEC	560DT	23			COLD
		0.59	79	1	INR		08H	TEH	TEC	560DT	23			COLD
		19.78			SLG		TSH	TEH	TEC	560DT	23			COLD
29	47	20.07			SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	40			HOT
29	48	20.13			SLG		TSH	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
29	51	0.53	101	3	INR		02C	TEH	TEC	560DT	24			COLD
		20.71			SLG		TSH	TEH	TEC	560DT	24			COLD
29	52	22.39			SLG		TSH	TEH	TEC	560DT	25			COLD
		0.38	136	1	TFH		08H	TEH	TEC	560DT	25			COLD
29	53	20.39			SLG		TSH	TEH	TEC	560DT	24			COLD
29	54	19.32			SLG		TSH	TEH	TEC	560DT	26			COLD
29	55	20.45			SLG		TSH	TEH	TEC	560DT	27			COLD
					NDD			TSH	TSH	560PP	34			HOT
29	56				NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560DT	26			COLD
					NDD			TSH	TSH	560PP	36			HOT
29	57				NDD			TEH	TEC	560UL	47			COLD
					NDD			TSH	TSH	560PP	34			HOT
29	58	0.97	28	1	INR		08H	TEH	TEC	560UL	46			COLD
					NDD			TSH	TSH	560PP	35			HOT
29	59				NDD			TEH	TEC	560UL	47			COLD
29	60	0.48	173	1	INR		08H	TEH	TEC	560UL	46			COLD
29	61	0.56	141	1	INR		08H	TEH	TEC	560DT	34			COLD
					NDF		08H	AV1	08H	5201P	72			HOT
29	62				NDD			TEH	TEC	560DT	34			COLD
29	63				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	35			COLD
29	64				NDD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560DT	34			COLD
29	65				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	35			COLD
29	66				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	34			COLD
29	67				NDD			TEH	TEC	560DT	37			COLD
29	68				NDD			TEH	TEC	560UL	36			COLD
29	69	0.30	132	1	TFH		08C	TEH	TEC	560DT	37			COLD
29	70				NDD			TEH	TEC	560UL	36			COLD
29	71				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	37			COLD
29	72				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
29	75				NDD			TEH	TEC	560DT	35			COLD
29	76				NDD			TEH	TEC	560UL	36			COLD
29	77				NDD			TEH	TEC	560UL	36			COLD
29	78	0.44	36	1	INR		08C	TEH	TEC	560UL	36			COLD
29	79				NDD			TSH	TSH	560PP	17			HOT
		0.37	120	1	TFH		08C	TEH	TEC	560UL	36			COLD
29	80	0.62	357	1	INR		08C	TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
29	81				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	37			COLD
29	82				NDD			TEH	TEC	560DT	38			COLD
					NDD			TSH	TSH	560PP	16			HOT
29	83				NDD			TEH	TEC	560UL	39			COLD
29	84				NDD			TEH	TEC	560UL	39			COLD
29	85				NDD			TEH	TEC	560DT	40			COLD
29	86				NDD			TEH	TEC	560UL	39			COLD
29	87				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
29	88				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
29	89				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
29	90	18.33		8	SLG		TSC	+0.55	TEH	TEC	560UL	39		COLD
		0.67	118	3	INR		03H	+2.42	TEH	TEC	560UL	39		COLD
					NDD				TSH	TSH	560PP	16		HOT
29	91	15.34		8	SLG		TSH	+0.46	TEH	TEC	560DT	40		COLD
		24.31		8	SLG		TSC	+0.67	TEH	TEC	560DT	40		COLD
29	92	16.15		8	SLG		TSH	+0.49	TEH	TEC	560UL	39		COLD
		21.37		8	SLG		TSC	+0.68	TEH	TEC	560UL	39		COLD
29	93	26.25		8	SLG		TSC	+0.69	TEH	TEC	560DT	40		COLD
29	94	18.43		8	SLG		TSH	+0.62	TEH	TEC	560UL	39		COLD
		23.01		8	SLG		TSC	+0.79	TEH	TEC	560UL	39		COLD
29	95	16.50		8	SLG		TSH	+0.48	TEH	TEC	560DT	42		COLD
		26.58		8	SLG		TSC	+0.77	TEH	TEC	560DT	42		COLD
					NDD				TSH	TSH	560PP	19		HOT
29	96				NDD				TSH	TSH	560PP	18		HOT
		18.34		8	SLG		TSH	+0.51	TEH	TEC	560UL	41		COLD
		24.10		8	SLG		TSC	+0.73	TEH	TEC	560UL	41		COLD
29	97	18.54		8	SLG		TSH	+0.51	TEH	TEC	560DT	42		COLD
		26.32		8	SLG		TSC	+0.77	TEH	TEC	560DT	42		COLD
					NDD				TSH	TSH	560PP	19		HOT
29	98				NDD				TSH	TSH	560PP	18		HOT
		19.61		8	SLG		TSH	+0.56	TEH	TEC	560UL	41		COLD
		25.27		8	SLG		TSC	+0.86	TEH	TEC	560UL	41		COLD
29	99	19.02		8	SLG		TSC	+0.59	TEH	TEC	560DT	42		COLD
29	100				NDD				TEH	TEC	560UL	41		COLD
29	101				NDD				TEH	TEC	560UL	41		COLD
29	102				NDD				TEH	TEC	560UL	41		COLD
29	103				NDD				TSH	TSH	560PP	21		HOT
		16.62		8	SLG		TSC	+0.47	TEH	TEC	560UL	43		COLD
29	104				NDD				TSH	TSH	560PP	20		HOT
		20.59		8	SLG		TSC	+0.60	TEH	TEC	560UL	43		COLD
29	105				NDD				TSH	TSH	560PP	21		HOT
		24.14		8	SLG		TSC	+0.73	TEH	TEC	560UL	43		COLD
29	106				NDD				TSH	TSH	560PP	20		HOT
		22.98		8	SLG		TSC	+0.70	TEH	TEC	560UL	43		COLD
29	107	23.08		8	SLG		TSC	+0.68	TEH	TEC	560UL	43		COLD
		5.67	183	1	DNG		08H	-1.77	TEH	TEC	560UL	43		COLD
		4.00	179	P 1	DNT		08C	+0.31	TEH	TEC	560UL	43		COLD
				3	NDF		07H	+37.44	07H	08H	560PP	62		HOT
				3	NDF		07H	+38.38	07H	08H	560PP	62		HOT
29	108				NDD				TEH	TEC	560UC	80		COLD
					NDD				TEH	TEC	560UC	72		COLD
29	109				NDD				TEH	TEC	560UC	80		COLD
29	110				NDD				TEH	TEC	560UC	80		COLD
					NDD				TEH	TEC	560UC	72		COLD
29	111				NDD				TEH	TEC	560UC	80		COLD
					NDD				TSH	TSH	560PP	21		HOT
29	112				NDD				TEH	TEC	560UC	80		COLD
					NDD				TSH	TSH	560PP	20		HOT
					NDD				TEH	TEC	560UC	72		COLD
29	113	0.50	0	P 2	TWD	13	AV2	-0.10	TEH	TEC	560UC	80		COLD
		0.52	0	P 2	TWD	14	AV5	+0.00	TEH	TEC	560UC	80		COLD
					NDD				TSH	TSH	560PP	20		HOT
29	114				NDD				TEH	TEC	560UC	80		COLD
					NDD				TSH	TSH	560PP	67		HOT
30	9				NDD				TEH	TEC	560DT	16		COLD
30	10	18.62		8	SLG		TSC	+0.60	TEH	TEC	560DT	17		COLD
30	11	20.05		8	SLG		TSC	+0.73	TEH	TEC	560DT	17		COLD
30	12	19.42		8	SLG		TSC	+0.70	TEH	TEC	560DT	16		COLD
30	13	19.48		8	SLG		TSC	+0.65	TEH	TEC	560DT	17		COLD
30	14	18.41		8	SLG		TSC	+0.63	TEH	TEC	560DT	16		COLD
30	15	15.46		8	SLG		TSH	+0.46	TEH	TEC	560DT	17		COLD
		18.58		8	SLG		TSC	+0.57	TEH	TEC	560DT	17		COLD
					NDD				TSH	TSH	560PP	44		HOT
30	16				NDD				TSH	TSH	560PP	45		HOT
		18.88		8	SLG		TSC	+0.60	TEH	TEC	560DT	17		COLD
30	17	16.11		8	SLG		TSH	+0.51	TEH	TEC	560DT	17		COLD
		18.90		8	SLG		TSC	+0.60	TEH	TEC	560DT	17		COLD
					NDD				TSH	TSH	560PP	42		HOT
30	18	17.87		8	SLG		TSC	+0.57	TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	43		HOT
30	19				NDD				TSH	TSH	560PP	54		HOT
		16.50		8	SLG		TSH	+0.49	TEH	TEC	560DT	19		COLD
		17.87		8	SLG		TSC	+0.54	TEH	TEC	560DT	19		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
30	20	10.34	185	1	DNG		07C	+38.96	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	53		HOT
		16.59		8	SLG		TSH	+0.51	TEH	TEC	560DT	19		COLD
		17.57		8	SLG		TSC	+0.54	TEH	TEC	560DT	19		COLD
30	21				NDD				TSH	TSH	560PP	53		HOT
		17.57		8	SLG		TSH	+0.54	TEH	TEC	560DT	19		COLD
		16.46		8	SLG		TSC	+0.49	TEH	TEC	560DT	19		COLD
30	22				NDD				TSH	TSH	560PP	53		HOT
		18.10		8	SLG		TSH	+0.57	TEH	TEC	560DT	18		COLD
30	23	17.71		8	SLG		TSH	+0.54	TEH	TEC	560DT	19		COLD
		15.61		8	SLG		TSC	+0.47	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
30	24				NDD				TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	43		HOT
30	25	18.36		8	SLG		TSH	+0.59	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
30	26	18.91		8	SLG		TSH	+0.60	TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	43		HOT
30	27	17.61		8	SLG		TSH	+0.57	TEH	TEC	560DT	21		COLD
30	28	18.45		8	SLG		TSH	+0.62	TEH	TEC	560DT	20		COLD
30	29	18.37		8	SLG		TSH	+0.59	TEH	TEC	560DT	21		COLD
30	30	8.07	178	P 1	DNT		08C	+0.29	TEH	TEC	560DT	20		COLD
		19.01		8	SLG		TSH	+0.65	TEH	TEC	560DT	20		COLD
30	31	18.53		8	SLG		TSH	+0.64	TEH	TEC	560DT	21		COLD
					NDD				TSH	TSH	560PP	42		HOT
30	32	19.13		8	SLG		TSH	+0.62	TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	40		HOT
30	33				NDD				TSH	TSH	560PP	40		HOT
		0.41	96	3	NQH		06C	+22.11	TEH	TEC	560DT	21		COLD
		18.94		8	SLG		TSH	+0.64	TEH	TEC	560DT	21		COLD
30	34				NDD				TSH	TSH	560PP	40		HOT
		19.15		8	SLG		TSH	+0.65	TEH	TEC	560DT	20		COLD
30	35				NDD				TEH	TEC	560DT	21		COLD
30	36	19.03		8	SLG		TSH	+0.65	TEH	TEC	560DT	20		COLD
30	37	19.15		8	SLG		TSH	+0.66	TEH	TEC	560DT	22		COLD
30	38	18.97		8	SLG		TSH	+0.67	TEH	TEC	560DT	22		COLD
30	39	19.24		8	SLG		TSH	+0.64	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
30	40	19.33		8	SLG		TSH	+0.67	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
30	41	19.97		8	SLG		TSH	+0.69	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
30	42	6.39	183	1	DNG		AV6	+15.16	TEH	TEC	560DT	22		COLD
		20.23		8	SLG		TSH	+0.72	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
30	43	19.82		8	SLG		TSH	+0.69	TEH	TEC	560DT	23		COLD
30	44	19.83		8	SLG		TSH	+0.70	TEH	TEC	560DT	22		COLD
30	45	20.32		8	SLG		TSH	+0.71	TEH	TEC	560DT	23		COLD
30	46	20.03		8	SLG		TSH	+0.75	TEH	TEC	560DT	22		COLD
30	47	20.68		8	SLG		TSH	+0.76	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	41		HOT
30	48	20.31		8	SLG		TSH	+0.70	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	40		HOT
30	49	21.82		8	SLG		TSH	+0.74	TEH	TEC	560DT	25		COLD
					RBD				TSH	TSH	560PP	34		HOT
					NDD				TSH	TSH	560PP	50		HOT
30	50	20.53		8	SLG		TSH	+0.70	TEH	TEC	560DT	24		COLD
					NDD				TSH	TSH	560PP	36		HOT
30	51	22.36		8	SLG		TSH	+0.79	TEH	TEC	560DT	25		COLD
30	52	20.23		8	SLG		TSH	+0.73	TEH	TEC	560DT	24		COLD
30	53	21.87		8	SLG		TSH	+0.79	TEH	TEC	560DT	25		COLD
30	54	20.62		8	SLG		TSH	+0.77	TEH	TEC	560DT	27		COLD
30	55	19.86		8	SLG		TSH	+0.73	TEH	TEC	560DT	26		COLD
					NDD				TSH	TSH	560PP	36		HOT
30	56	18.58		8	SLG		TSH	+0.69	TEH	TEC	560DT	27		COLD
					NDD				TSH	TSH	560PP	34		HOT
30	57				NDD				TEH	TEC	560UL	47		COLD
					NDD				TSH	TSH	560PP	36		HOT
30	58				NDD				TEH	TEC	560UL	46		COLD
					NDD				TSH	TSH	560PP	34		HOT
30	59				NDD				TEH	TEC	560UL	47		COLD
30	60				NDD				TEH	TEC	560UL	46		COLD
30	61				NDD				TEH	TEC	560DT	35		COLD
30	62				NDD				TEH	TEC	560DT	35		COLD
30	63				RBD				TSH	TSH	560PP	14		HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					NDD			TEH	TEC	560DT	34			COLD
					NDD			TSH	TSH	560PP	50			HOT
30	64				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	35			COLD
30	65				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	34			COLD
30	66				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	35			COLD
30	67	0.63	123	3	INR	06C	+30.48	TEH	TEC	560DT	37			COLD
30	68				NDD			TEH	TEC	560DT	37			COLD
30	69				NDD			TEH	TEC	560UL	36			COLD
30	70				NDD			TEH	TEC	560DT	37			COLD
30	71	0.55	126	3	INR	06C	+19.27	TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
30	72				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	35			COLD
30	73				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
30	74				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	35			COLD
30	75				NDD			TEH	TEC	560DT	34			COLD
30	76				NDD			TEH	TEC	560DT	37			COLD
30	77				NDD			TEH	TEC	560DT	37			COLD
30	78				NDD			TEH	TEC	560DT	37			COLD
30	79				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	37			COLD
30	80				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	37			COLD
30	81				NDD			TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
30	82				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	38			COLD
30	83				NDD			TEH	TEC	560DT	40			COLD
30	84				NDD			TEH	TEC	560DT	40			COLD
30	85				NDD			TEH	TEC	560UL	39			COLD
30	86				NDD			TEH	TEC	560DT	40			COLD
30	87				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
30	88				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
30	89				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
30	90				NDD			TSH	TSH	560PP	17			HOT
	22.55			8	SLG	TSC	+0.62	TEH	TEC	560DT	40			COLD
30	91	21.07		8	SLG	TSC	+0.72	TEH	TEC	560UL	39			COLD
30	92	24.43		8	SLG	TSC	+0.69	TEH	TEC	560DT	40			COLD
30	93	16.31		8	SLG	TSH	+0.49	TEH	TEC	560UL	39			COLD
	24.48			8	SLG	TSC	+0.84	TEH	TEC	560UL	39			COLD
30	94	19.57		8	SLG	TSH	+0.57	TEH	TEC	560DT	42			COLD
	26.72			8	SLG	TSC	+0.77	TEH	TEC	560DT	42			COLD
30	95				NDD			TSH	TSH	560PP	18			HOT
	17.64			8	SLG	TSH	+0.51	TEH	TEC	560UL	41			COLD
	26.76			8	SLG	TSC	+0.75	TEH	TEC	560UL	41			COLD
30	96	17.59		8	SLG	TSH	+0.51	TEH	TEC	560DT	42			COLD
	27.12			8	SLG	TSC	+0.82	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
30	97				NDD			TSH	TSH	560PP	18			HOT
	18.19			8	SLG	TSH	+0.51	TEH	TEC	560UL	41			COLD
	24.24			8	SLG	TSC	+0.75	TEH	TEC	560UL	41			COLD
30	98	19.37		8	SLG	TSH	+0.56	TEH	TEC	560DT	42			COLD
	24.36			8	SLG	TSC	+0.90	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
30	99	22.56		8	SLG	TSC	+0.78	TEH	TEC	560UL	41			COLD
30	100				NDD			TEH	TEC	560DT	42			COLD
30	101				NDD			TEH	TEC	560UL	41			COLD
30	102	15.85		8	SLG	TSC	+0.47	TEH	TEC	560UL	41			COLD
30	103				NDD			TSH	TSH	560PP	20			HOT
	16.94			8	SLG	TSC	+0.49	TEH	TEC	560UL	43			COLD
30	104				NDD			TSH	TSH	560PP	21			HOT
	21.51			8	SLG	TSC	+0.62	TEH	TEC	560UL	43			COLD
30	105				NDD			TSH	TSH	560PP	20			HOT
	0.46	98	3		NQH	06C	+9.50	TEH	TEC	560UL	43			COLD
	24.70			8	SLG	TSC	+0.78	TEH	TEC	560UL	43			COLD
30	106				NDD			TSH	TSH	560PP	21			HOT
	25.29			8	SLG	TSC	+0.86	TEH	TEC	560UL	43			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
30	107	24.82		8	SLG		TSC		TEH	TEC	560UL	43		COLD
30	108				NDD				TEH	TEC	560UC	80		COLD
					NDD				TEH	TEC	560UC	72		COLD
30	109				NDD				TEH	TEC	560UC	80		COLD
					NDD				TEH	TEC	560UC	72		COLD
30	110				NDD				TEH	TEC	560UC	80		COLD
30	111	0.49	108	3	INR		02H		TEH	TEC	560UC	80		COLD
		0.69	95	3	INR		02H		TEH	TEC	560UC	80		COLD
					NDD				TSH	TSH	560PP	20		HOT
		0.50	112	3	INR		02H		TEH	TEC	560UC	72		COLD
		0.90	110	3	INR		02H		TEH	TEC	560UC	72		COLD
30	112				NDD				TEH	TEC	560UC	80		COLD
					NDD				TSH	TSH	560PP	20		HOT
30	113	0.15	114	3	INR		07C		TEH	TEC	560UC	80		COLD
					NDD				TSH	TSH	560PP	20		HOT
		0.92	118	3	INR		07C		TEH	TEC	560UC	72		COLD
30	114	0.64	0	P 2	TWD	17	AV6		TEH	TEC	560UC	80		COLD
					NDD				TSH	TSH	560PP	67		HOT
31	10	16.87		8	SLG		TSC		TEH	TEC	560DT	16		COLD
31	11	19.70		8	SLG		TSC		TEH	TEC	560DT	16		COLD
31	12	20.17		8	SLG		TSC		TEH	TEC	560DT	17		COLD
31	13	18.85		8	SLG		TSC		TEH	TEC	560DT	16		COLD
31	14	19.60		8	SLG		TSC		TEH	TEC	560DT	17		COLD
31	15				NDD				TSH	TSH	560PP	45		HOT
		18.59		8	SLG		TSC		TEH	TEC	560DT	16		COLD
31	16	18.93		8	SLG		TSC		TEH	TEC	560DT	16		COLD
					NDD				TSH	TSH	560PP	44		HOT
31	17	17.94		8	SLG		TSC		TEH	TEC	560DT	16		COLD
					NDD				TSH	TSH	560PP	43		HOT
31	18	15.58		8	SLG		TSH		TEH	TEC	560DT	19		COLD
		18.77		8	SLG		TSC		TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
31	19				NDD				TSH	TSH	560PP	54		HOT
		17.65		8	SLG		TSC		TEH	TEC	560DT	18		COLD
31	20	15.94		8	SLG		TSH		TEH	TEC	560DT	18		COLD
		16.75		8	SLG		TSC		TEH	TEC	560DT	18		COLD
		3.13	179	1	DNG		08C		TEH	TEC	560DT	18		COLD
		4.86	176	P 1	DNT		08C		TEH	TEC	560DT	18		COLD
		11.35	180	P 1	DNT		08H		TEH	TEC	560DT	18		COLD
		3.37	168	P 1	DNT		08H		TEH	TEC	560DT	18		COLD
		3.37	168	P 1	DDS		08H		TEH	TEC	560DT	18		COLD
		3.10	177	1	DNG		07C		TEH	TEC	560DT	18		COLD
				3	NDF		08H		08H	08H	560PP	55		HOT
				3	NDF		08H		08H	08H	560PP	57		HOT
				3	NDF		08H		08H	08H	560PP	57		HOT
					NDD				TSH	TSH	560PP	52		HOT
31	21				NDD				TSH	TSH	560PP	53		HOT
		16.10		8	SLG		TSH		TEH	TEC	560DT	18		COLD
		16.10		8	SLG		TSC		TEH	TEC	560DT	18		COLD
31	22	17.61		8	SLG		TSH		TEH	TEC	560DT	19		COLD
		16.08		8	SLG		TSC		TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	52		HOT
31	23	17.19		8	SLG		TSH		TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	43		HOT
31	24	18.28		8	SLG		TSH		TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
31	25	17.39		8	SLG		TSH		TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	43		HOT
31	26	18.03		8	SLG		TSH		TEH	TEC	560DT	21		COLD
					NDD				TSH	TSH	560PP	42		HOT
31	27	18.81		8	SLG		TSH		TEH	TEC	560DT	20		COLD
31	28	18.07		8	SLG		TSH		TEH	TEC	560DT	21		COLD
31	29	18.33		8	SLG		TSH		TEH	TEC	560DT	20		COLD
31	30	18.39		8	SLG		TSH		TEH	TEC	560DT	21		COLD
		3.88	179	1	DNG		07H		TEH	TEC	560DT	21		COLD
		3.73	173	P 1	DNT		08C		TEH	TEC	560DT	21		COLD
					NDD				TEH	TSH	560PP	42		HOT
31	31	18.65		8	SLG		TSH		TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	43		HOT
31	32	18.41		8	SLG		TSH		TEH	TEC	560DT	21		COLD
					NDD				TSH	TSH	560PP	40		HOT
31	33	18.89		8	SLG		TSH		TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	41		HOT
31	34	18.27		8	SLG		TSH		TEH	TEC	560DT	21		COLD
					NDD				TSH	TSH	560PP	41		HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
31	35	18.31	8	SLG	TSH	+0.62		TEH	TEC	560DT	20			COLD
31	36	19.00	8	SLG	TSH	+0.61		TEH	TEC	560DT	21			COLD
31	37	19.92	8	SLG	TSH	+0.69		TEH	TEC	560DT	23			COLD
31	38	20.11	8	SLG	TSH	+0.67		TEH	TEC	560DT	23			COLD
31	39	19.61	8	SLG	TSH	+0.72		TEH	TEC	560DT	22			COLD
				NDD				TSH	TSH	560PP	41			HOT
31	40	19.46	8	SLG	TSH	+0.64		TEH	TEC	560DT	23			COLD
				NDD				TSH	TSH	560PP	40			HOT
31	41	19.79	8	SLG	TSH	+0.67		TEH	TEC	560DT	22			COLD
				NDD				TSH	TSH	560PP	41			HOT
31	42	20.11	8	SLG	TSH	+0.71		TEH	TEC	560DT	23			COLD
				NDD				TSH	TSH	560PP	40			HOT
31	43	20.43	8	SLG	TSH	+0.70		TEH	TEC	560DT	22			COLD
31	44	19.15	8	SLG	TSH	+0.66		TEH	TEC	560DT	23			COLD
31	45	20.05	8	SLG	TSH	+0.75		TEH	TEC	560DT	22			COLD
31	46	21.22	8	SLG	TSH	+0.71		TEH	TEC	560DT	23			COLD
31	47	19.65	8	SLG	TSH	+0.75		TEH	TEC	560DT	22			COLD
				NDD				TSH	TSH	560PP	40			HOT
31	48	20.22	8	SLG	TSH	+0.74		TEH	TEC	560DT	23			COLD
				NDD				TSH	TSH	560PP	41			HOT
31	49	20.41	8	SLG	TSH	+0.77		TEH	TEC	560DT	24			COLD
				NDD				TSH	TSH	560PP	36			HOT
31	50	22.80	8	SLG	TSH	+0.82		TEH	TEC	560DT	25			COLD
				NDD				TSH	TSH	560PP	34			HOT
31	51	20.02	8	SLG	TSH	+0.70		TEH	TEC	560DT	24			COLD
31	52	22.66	8	SLG	TSH	+0.79		TEH	TEC	560DT	25			COLD
31	53	19.78	8	SLG	TSH	+0.73		TEH	TEC	560DT	24			COLD
31	54			NDD				TEH	TEC	560UL	46			COLD
				RBD				TEH	TEC	560DT	26			COLD
31	55	20.08	8	SLG	TSH	+0.77		TEH	TEC	560DT	27			COLD
				NDD				TSH	TSH	560PP	34			HOT
31	56	19.64	8	SLG	TSH	+0.73		TEH	TEC	560DT	26			COLD
				NDD				TSH	TSH	560PP	36			HOT
31	57			NDD				TEH	TEC	560UL	47			COLD
				NDD				TSH	TSH	560PP	34			HOT
31	58			NDD				TEH	TEC	560UL	46			COLD
				NDD				TSH	TSH	560PP	35			HOT
31	59			NDD				TEH	TEC	560UL	47			COLD
31	60			NDD				TEH	TEC	560UL	46			COLD
31	61			NDD				TEH	TEC	560DT	34			COLD
31	62			NDD				TEH	TEC	560DT	34			COLD
31	63			NDD				TSH	TSH	560PP	15			HOT
				NDD				TEH	TEC	560DT	35			COLD
31	64			NDD				TSH	TSH	560PP	14			HOT
				NDD				TEH	TEC	560DT	34			COLD
31	65			NDD				TSH	TSH	560PP	15			HOT
				NDD				TEH	TEC	560DT	35			COLD
31	66			NDD				TSH	TSH	560PP	15			HOT
				NDD				TEH	TEC	560DT	34			COLD
31	67			NDD				TEH	TEC	560DT	37			COLD
31	68			NDD				TEH	TEC	560UL	36			COLD
31	69			NDD				TEH	TEC	560DT	37			COLD
31	70			NDD				TEH	TEC	560UL	36			COLD
31	71			NDD				TSH	TSH	560PP	17			HOT
				NDD				TEH	TEC	560DT	37			COLD
31	72			NDD				TSH	TSH	560PP	16			HOT
				NDD				TEH	TEC	560DT	34			COLD
31	73			NDD				TSH	TSH	560PP	17			HOT
				NDD				TEH	TEC	560DT	35			COLD
31	74			NDD				TSH	TSH	560PP	16			HOT
				NDD				TEH	TEC	560DT	34			COLD
31	75			NDD				TEH	TEC	560DT	35			COLD
31	76			NDD				TEH	TEC	560UL	36			COLD
31	77			NDD				TEH	TEC	560DT	37			COLD
31	78			NDD				TEH	TEC	560UL	36			COLD
31	79			NDD				TSH	TSH	560PP	17			HOT
				NDD				TEH	TEC	560UL	36			COLD
31	80			NDD				TEH	TEC	560UL	36			COLD
				NDD				TSH	TSH	560PP	16			HOT
31	81			NDD				TSH	TSH	560PP	17			HOT
				NDD				TEH	TEC	560DT	37			COLD
31	82			NDD				TEH	TEC	560DT	38			COLD
				NDD				TSH	TSH	560PP	16			HOT
31	83			NDD				TEH	TEC	560UL	39			COLD
31	84			NDD				TEH	TEC	560UL	39			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
31	85				NDD			TEH	TEC	560DT	40			COLD
31	86				NDD			TEH	TEC	560UL	39			COLD
31	87				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
31	88				NDD			TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
31	89				NDD			TSH	TSH	560PP	17			HOT
		19.43		8	SLG		TSC	TEH	TEC	560DT	40			COLD
31	90	23.07		8	SLG		TSC	TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
31	91	23.27		8	SLG		TSC	TEH	TEC	560DT	40			COLD
31	92	21.11		8	SLG		TSC	TEH	TEC	560UL	39			COLD
31	93	26.00		8	SLG		TSC	TEH	TEC	560DT	40			COLD
		0.64	66	3	NQH		AV1	TEH	TEC	560DT	40			COLD
		4.55	184	1	DNG		02C	TEH	TEC	560DT	40			COLD
31	94	19.14		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		27.85		8	SLG		TSC	TEH	TEC	560UL	41			COLD
31	95	18.64		8	SLG		TSH	TEH	TEC	560DT	42			COLD
		25.13		8	SLG		TSC	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
31	96				NDD			TSH	TSH	560PP	18			HOT
		18.13		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		28.07		8	SLG		TSC	TEH	TEC	560UL	41			COLD
31	97	20.01		8	SLG		TSH	TEH	TEC	560DT	42			COLD
		26.74		8	SLG		TSC	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
31	98				NDD			TSH	TSH	560PP	18			HOT
		20.11		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		24.88		8	SLG		TSC	TEH	TEC	560UL	41			COLD
		0.23	104	3	NQH		07C	TEH	TEC	560UL	41			COLD
31	99	24.36		8	SLG		TSC	TEH	TEC	560DT	42			COLD
31	100				NDD			TEH	TEC	560UL	41			COLD
31	101				NDD			TEH	TEC	560UL	41			COLD
31	102	16.88		8	SLG		TSC	TEH	TEC	560UL	41			COLD
31	103				NDD			TSH	TSH	560PP	21			HOT
		19.79		8	SLG		TSC	TEH	TEC	560UL	43			COLD
31	104				NDD			TSH	TSH	560PP	20			HOT
		22.78		8	SLG		TSC	TEH	TEC	560UL	43			COLD
31	105				NDD			TSH	TSH	560PP	21			HOT
		1.18	112	3	NQH		02H	TEH	TEC	560UL	43			COLD
		25.41		8	SLG		TSC	TEH	TEC	560UL	43			COLD
31	106				NDD			TSH	TSH	560PP	20			HOT
		25.89		8	SLG		TSC	TEH	TEC	560UL	43			COLD
31	107				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
31	108				NDD			TEH	TEC	560UC	80			COLD
31	109				NDD			TEH	TEC	560UC	80			COLD
					NDD			TEH	TEC	560UC	72			COLD
31	110				NDD			TEH	TEC	560UC	80			COLD
31	111				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UC	72			COLD
31	112				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	20			HOT
31	113				NDD			TEH	TEC	560UC	80			COLD
					NDD			TSH	TSH	560PP	67			HOT
32	11	18.41		8	SLG		TSC	TEH	TEC	560DT	16			COLD
32	12	18.79		8	SLG		TSC	TEH	TEC	560DT	16			COLD
32	13	20.48		8	SLG		TSC	TEH	TEC	560DT	17			COLD
32	14	19.38		8	SLG		TSC	TEH	TEC	560DT	16			COLD
		0.66	101	3	NQH		AV1	TEH	TEC	560DT	16			COLD
32	15	20.09		8	SLG		TSC	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	44			HOT
32	16				NDD			TSH	TSH	560PP	45			HOT
		19.35		8	SLG		TSC	TEH	TEC	560DT	17			COLD
32	17	19.17		8	SLG		TSC	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	42			HOT
32	18	18.34		8	SLG		TSC	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
32	19				NDD			TSH	TSH	560PP	54			HOT
		18.55		8	SLG		TSC	TEH	TEC	560DT	19			COLD
32	20				NDD			TEH	TEC	560PP	53			HOT
		15.65		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		17.79		8	SLG		TSC	TEH	TEC	560DT	19			COLD
		0.22	124	3	INR		07H	TEH	TEC	560DT	19			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		0.36	120	3	INR		07H		TEH	TEC	560DT	19		COLD
		0.55	145	3	INR		07H		TEH	TEC	560DT	19		COLD
		11.76	183	P 1	DNT		08C		TEH	TEC	560DT	19		COLD
		4.29	174	P 1	DNT		08C		TEH	TEC	560DT	19		COLD
		0.39	127	3	INR		07C		TEH	TEC	560DT	19		COLD
		0.40	143	3	INR		08H		TEH	TEC	560DT	19		COLD
				3	NDF		08H		08H	07H	560PP	57		HOT
				3	NDF		07H		08H	07H	560PP	57		HOT
				3	NDF		07H		08H	07H	560PP	57		HOT
				3	NDF		07H		08H	07H	560PP	57		HOT
32	21				NDD				TSH	TSH	560PP	53		HOT
		15.63		8	SLG		TSH		TEH	TEC	560DT	19		COLD
		16.93		8	SLG		TSC		TEH	TEC	560DT	19		COLD
32	22				NDD				TSH	TSH	560PP	53		HOT
		17.63		8	SLG		TSH		TEH	TEC	560DT	18		COLD
		16.47		8	SLG		TSC		TEH	TEC	560DT	18		COLD
32	23	17.38		8	SLG		TSH		TEH	TEC	560DT	19		COLD
		15.85		8	SLG		TSC		TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
32	24	0.64	125	3	INR		05C		TEH	TEC	560DT	18		COLD
		0.64	107	3	INR		05C		TEH	TEC	560DT	18		COLD
		17.75		8	SLG		TSH		TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	43		HOT
32	25	17.85		8	SLG		TSH		TEH	TEC	560DT	19		COLD
		15.34		8	SLG		TSC		TEH	TEC	560DT	19		COLD
		0.61	113	3	INR		04C		TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
32	26	17.58		8	SLG		TSH		TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	43		HOT
32	27	17.79		8	SLG		TSH		TEH	TEC	560DT	21		COLD
32	28	18.51		8	SLG		TSH		TEH	TEC	560DT	20		COLD
32	29	17.71		8	SLG		TSH		TEH	TEC	560DT	21		COLD
32	30	18.45		8	SLG		TSH		TEH	TEC	560DT	20		COLD
32	31	18.07		8	SLG		TSH		TEH	TEC	560DT	21		COLD
					NDD				TSH	TSH	560PP	42		HOT
32	32	18.81		8	SLG		TSH		TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	40		HOT
32	33				NDD				TSH	TSH	560PP	40		HOT
		18.35		8	SLG		TSH		TEH	TEC	560DT	21		COLD
32	34				NDD				TSH	TSH	560PP	40		HOT
		18.59		8	SLG		TSH		TEH	TEC	560DT	20		COLD
32	35	18.57		8	SLG		TSH		TEH	TEC	560DT	21		COLD
32	36	18.71		8	SLG		TSH		TEH	TEC	560DT	20		COLD
32	37	19.45		8	SLG		TSH		TEH	TEC	560DT	22		COLD
32	38	2.14	0	P 2	PID		AV5		TEH	TEC	560UL	106		COLD
		19.79		8	SLG		TSH		TEH	TEC	560DT	22		COLD
		0.81	0	P 2	TWD	20	AV6		TEH	TEC	560DT	22		COLD
		2.20	0	P 2	TWD	38	AV5		TEH	TEC	560DT	22		COLD
		0.59	0	P 2	TWD	15	AV4		TEH	TEC	560DT	22		COLD
		0.59	0	P 2	TWD	15	AV3		TEH	TEC	560DT	22		COLD
		0.88	0	P 2	TWD	21	AV2		TEH	TEC	560DT	22		COLD
32	39	20.26		8	SLG		TSH		TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
32	40	20.01		8	SLG		TSH		TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
32	41	20.63		8	SLG		TSH		TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
32	42	19.61		8	SLG		TSH		TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
32	43	19.78		8	SLG		TSH		TEH	TEC	560DT	23		COLD
32	44	19.35		8	SLG		TSH		TEH	TEC	560DT	22		COLD
32	45	19.90		8	SLG		TSH		TEH	TEC	560DT	23		COLD
32	46	19.57		8	SLG		TSH		TEH	TEC	560DT	22		COLD
32	47	20.09		8	SLG		TSH		TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	41		HOT
32	48	20.03		8	SLG		TSH		TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	40		HOT
32	49	22.48		8	SLG		TSH		TEH	TEC	560DT	25		COLD
					NDD				TSH	TSH	560PP	34		HOT
32	50	20.63		8	SLG		TSH		TEH	TEC	560DT	24		COLD
					NDD				TSH	TSH	560PP	36		HOT
32	51	22.77		8	SLG		TSH		TEH	TEC	560DT	25		COLD
32	52	0.58	77	3	NQH		AV3		TEH	TEC	560DT	24		COLD
		20.37		8	SLG		TSH		TEH	TEC	560DT	24		COLD
32	53	21.91		8	SLG		TSH		TEH	TEC	560DT	25		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
32	54	20.68		8	SLG		TSH	+0.76	TEH	TEC	560DT	27		COLD
32	55	19.58		8	SLG		TSH	+0.75	TEH	TEC	560DT	26		COLD
					NDD				TSH	TSH	560PP	36		HOT
32	56	19.96		8	SLG		TSH	+0.72	TEH	TEC	560DT	27		COLD
					NDD				TSH	TSH	560PP	34		HOT
32	57				NDD				TEH	TEC	560UL	47		COLD
					NDD				TSH	TSH	560PP	36		HOT
32	58				NDD				TEH	TEC	560UL	46		COLD
					NDD				TSH	TSH	560PP	34		HOT
32	59				NDD				TEH	TEC	560UL	47		COLD
32	60				NDD				TEH	TEC	560UL	46		COLD
32	61				NDD				TEH	TEC	560DT	35		COLD
32	62				NDD				TEH	TEC	560DT	35		COLD
32	63				NDD				TSH	TSH	560PP	14		HOT
					NDD				TEH	TEC	560DT	34		COLD
32	64				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	35		COLD
32	65				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	34		COLD
32	66				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	35		COLD
32	67				NDD				TEH	TEC	560DT	37		COLD
32	68				NDD				TEH	TEC	560DT	37		COLD
32	69	0.25	87	3	NQH		03H	+14.80	TEH	TEC	560UL	36		COLD
32	70				NDD				TEH	TEC	560DT	37		COLD
32	71				NDD				TEH	TEC	560UL	36		COLD
					NDD				TSH	TSH	560PP	16		HOT
32	72				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	35		COLD
32	73				NDD				TSH	TSH	560PP	16		HOT
					NDD				TEH	TEC	560DT	34		COLD
32	74				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	35		COLD
32	75				NDD				TEH	TEC	560DT	34		COLD
32	76				NDD				TEH	TEC	560DT	37		COLD
32	77				NDD				TEH	TEC	560UL	36		COLD
32	78	1.35	170	P 1	INR		07C	+0.03	TEH	TEC	560DT	37		COLD
32	79				NDD				TSH	TSH	560PP	16		HOT
					NDD				TEH	TEC	560DT	37		COLD
32	80				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	37		COLD
32	81				NDD				TEH	TEC	560UL	36		COLD
					NDD				TSH	TSH	560PP	16		HOT
32	82				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	38		COLD
32	83				NDD				TEH	TEC	560DT	40		COLD
32	84				NDD				TEH	TEC	560DT	40		COLD
32	85				NDD				TEH	TEC	560UL	39		COLD
32	86				NDD				TEH	TEC	560DT	40		COLD
32	87				NDD				TEH	TEC	560UL	39		COLD
					NDD				TSH	TSH	560PP	16		HOT
32	88				NDD				TSH	TSH	560PP	17		HOT
		15.13		8	SLG		TSH	+0.45	TEH	TEC	560DT	40		COLD
		0.33	134	1	TFH		08H	+3.37	TEH	TEC	560DT	40		COLD
32	89	20.63		8	SLG		TSC	+0.68	TEH	TEC	560UL	39		COLD
					NDD				TSH	TSH	560PP	16		HOT
32	90				NDD				TSH	TSH	560PP	17		HOT
		23.66		8	SLG		TSC	+0.72	TEH	TEC	560DT	40		COLD
32	91	16.13		8	SLG		TSH	+0.47	TEH	TEC	560UL	39		COLD
		22.72		8	SLG		TSC	+0.87	TEH	TEC	560UL	39		COLD
32	92	24.78		8	SLG		TSC	+0.80	TEH	TEC	560DT	40		COLD
32	93	16.37		8	SLG		TSH	+0.52	TEH	TEC	560UL	39		COLD
		23.33		8	SLG		TSC	+0.90	TEH	TEC	560UL	39		COLD
32	94	19.65		8	SLG		TSH	+0.55	TEH	TEC	560DT	42		COLD
		27.39		8	SLG		TSC	+0.87	TEH	TEC	560DT	42		COLD
32	95				NDD				TSH	TSH	560PP	18		HOT
		20.44		8	SLG		TSH	+0.56	TEH	TEC	560UL	41		COLD
		26.86		8	SLG		TSC	+0.86	TEH	TEC	560UL	41		COLD
32	96	18.46		8	SLG		TSH	+0.53	TEH	TEC	560DT	42		COLD
		26.96		8	SLG		TSC	+0.87	TEH	TEC	560DT	42		COLD
					NDD				TSH	TSH	560PP	19		HOT
32	97				NDD				TSH	TSH	560PP	18		HOT
		16.24		8	SLG		TSH	+0.46	TEH	TEC	560UL	41		COLD
		26.20		8	SLG		TSC	+0.86	TEH	TEC	560UL	41		COLD
32	98	19.89		8	SLG		TSH	+0.56	TEH	TEC	560DT	42		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		24.55		8	SLG		TSC			TEH TEC 560DT	42			COLD
					NDD					TSH TSH 560PP	19			HOT
32	99	24.82		8	SLG		TSC			TEH TEC 560UL	41			COLD
32	100				NDD					TEH TEC 560DT	42			COLD
32	101				NDD					TEH TEC 560UL	41			COLD
32	102	17.93		8	SLG		TSC			TEH TEC 560UL	41			COLD
32	103				NDD					TSH TSH 560PP	20			HOT
		22.46		8	SLG		TSC			TEH TEC 560UL	43			COLD
32	104				NDD					TSH TSH 560PP	21			HOT
		23.76		8	SLG		TSC			TEH TEC 560UL	43			COLD
		0.41	141	P 1	INR		08C			TEH TEC 560UL	43			COLD
32	105				NDD					TSH TSH 560PP	20			HOT
		24.26		8	SLG		TSC			TEH TEC 560UL	43			COLD
32	106				NDD					TSH TSH 560PP	21			HOT
		25.21		8	SLG		TSC			TEH TEC 560UL	43			COLD
32	107				NDD					TEH TEC 560UC	70			COLD
32	108				NDD					TEH TEC 560UC	78			COLD
32	109	3.07	180	1	DNG		03H			TEH TEC 560UC	72			COLD
		3.00	180	1	DNG		03H			TEH TEC 560UC	78			COLD
32	110				NDD					TEH TEC 560UC	70			COLD
32	111				NDD					TSH TSH 560PP	20			HOT
					RBD					TEH TEC 560UL	71			COLD
					NDD					TEH TEC 560UC	78			COLD
32	112				NDD					TSH TSH 560PP	20			HOT
					NDD					TEH TEC 560UC	70			COLD
33	12	19.25		8	SLG		TSC			TEH TEC 560DT	17			COLD
33	13	18.83		8	SLG		TSC			TEH TEC 560DT	16			COLD
33	14	20.54		8	SLG		TSC			TEH TEC 560DT	17			COLD
33	15				NDD					TSH TSH 560PP	45			HOT
		19.54		8	SLG		TSC			TEH TEC 560DT	16			COLD
33	16	19.62		8	SLG		TSC			TEH TEC 560DT	16			COLD
					NDD					TSH TSH 560PP	44			HOT
33	17	18.59		8	SLG		TSC			TEH TEC 560DT	16			COLD
					NDD					TSH TSH 560PP	43			HOT
33	18	19.49		8	SLG		TSC			TEH TEC 560DT	19			COLD
					NDD					TSH TSH 560PP	42			HOT
33	19				NDD					TSH TSH 560PP	54			HOT
		18.04		8	SLG		TSC			TEH TEC 560DT	18			COLD
33	20	17.65		8	SLG		TSC			TEH TEC 560DT	18			COLD
		1.17	105	3	NQH		03C			TEH TEC 560DT	18			COLD
					NDD					TSH TSH 560PP	52			HOT
33	21				NDD					TSH TSH 560PP	53			HOT
		11.65	182	1	DNG		07H			TEH TEC 560DT	18			COLD
		5.65	180	1	DNG		07H			TEH TEC 560DT	18			COLD
		0.75	102	3	INR		07C			TEH TEC 560DT	18			COLD
		0.34	115	3	NQH		07C			TEH TEC 560DT	18			COLD
		0.72	171	1	INR		07C			TEH TEC 560DT	18			COLD
		0.52	158	1	INR		07C			TEH TEC 560DT	18			COLD
		0.52	158	1	INR		07C			TEH TEC 560DT	18			COLD
		0.85	156	1	INR		07C			TEH TEC 560DT	18			COLD
		16.24		8	SLG		TSH			TEH TEC 560DT	18			COLD
		17.03		8	SLG		TSC			TEH TEC 560DT	18			COLD
				3	NDF		07H			08H 07H 560PP	57			HOT
				3	NDF		07H			08H 07H 560PP	57			HOT
33	22	16.79		8	SLG		TSH			TEH TEC 560DT	19			COLD
		16.42		8	SLG		TSC			TEH TEC 560DT	19			COLD
					NDD					TSH TSH 560PP	52			HOT
33	23	16.51		8	SLG		TSH			TEH TEC 560DT	18			COLD
					NDD					TSH TSH 560PP	43			HOT
33	24	17.77		8	SLG		TSH			TEH TEC 560DT	19			COLD
		15.81		8	SLG		TSC			TEH TEC 560DT	19			COLD
					NDD					TSH TSH 560PP	42			HOT
33	25	0.97	96	3	INR		AV6			TEH TEC 560DT	18			COLD
		16.99		8	SLG		TSH			TEH TEC 560DT	18			COLD
					NDD					TSH TSH 560PP	43			HOT
33	26	17.21		8	SLG		TSH			TEH TEC 560DT	21			COLD
					NDD					TSH TSH 560PP	42			HOT
33	27	17.58		8	SLG		TSH			TEH TEC 560DT	20			COLD
33	28	17.35		8	SLG		TSH			TEH TEC 560DT	21			COLD
33	29	17.54		8	SLG		TSH			TEH TEC 560DT	20			COLD
33	30	17.37		8	SLG		TSH			TEH TEC 560DT	21			COLD
33	31	0.43	85	3	NQH		03C			TEH TEC 560DT	20			COLD
		18.65		8	SLG		TSH			TEH TEC 560DT	20			COLD
					NDD					TSH TSH 560PP	43			HOT
33	32	17.41		8	SLG		TSH			TEH TEC 560DT	21			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
33	33	19.05		8	NDD		TSH	+0.62	TSH	TSH	560PP	40		HOT
					SLG		TSH		TEH	TEC	560DT	20		COLD
					NDD		TSH		TSH	TSH	560PP	41		HOT
33	34	18.35		8	SLG		TSH	+0.59	TEH	TEC	560DT	21		COLD
					NDD		TSH		TSH	TSH	560PP	41		HOT
33	35	18.21		8	SLG		TSH	+0.59	TEH	TEC	560DT	20		COLD
33	36	17.97		8	SLG		TSH	+0.56	TEH	TEC	560DT	21		COLD
33	37	20.05		8	SLG		TSH	+0.66	TEH	TEC	560DT	23		COLD
33	38	19.57		8	SLG		TSH	+0.64	TEH	TEC	560DT	23		COLD
33	39	19.67		8	SLG		TSH	+0.67	TEH	TEC	560DT	22		COLD
					NDD		TSH		TSH	TSH	560PP	41		HOT
33	40	18.73		8	SLG		TSH	+0.61	TEH	TEC	560DT	23		COLD
					NDD		TSH		TSH	TSH	560PP	40		HOT
33	41	18.84		8	SLG		TSH	+0.65	TEH	TEC	560DT	22		COLD
		1.39	103	3	NQH		TSH	+7.64	TEH	TEC	560DT	22		COLD
					NDD		TSH		TSH	TSH	560PP	41		HOT
33	42	1.19	112	3	NQH		04H	+12.87	TEH	TEC	560DT	23		COLD
		19.51		8	SLG		TSH	+0.68	TEH	TEC	560DT	23		COLD
					NDD		TSH		TSH	TSH	560PP	40		HOT
33	43	20.07		8	SLG		TSH	+0.70	TEH	TEC	560DT	22		COLD
33	44	20.22		8	SLG		TSH	+0.72	TEH	TEC	560DT	23		COLD
33	45	19.57		8	SLG		TSH	+0.67	TEH	TEC	560DT	22		COLD
33	46	20.07		8	SLG		TSH	+0.71	TEH	TEC	560DT	23		COLD
33	47	19.01		8	SLG		TSH	+0.69	TEH	TEC	560DT	22		COLD
					NDD		TSH		TSH	TSH	560PP	40		HOT
33	48	20.26		8	SLG		TSH	+0.71	TEH	TEC	560DT	23		COLD
					NDD		TSH		TSH	TSH	560PP	41		HOT
33	49	0.54	86	3	NQH		02C	+26.18	TEH	TEC	560DT	24		COLD
		0.49	99	3	NQH		02C	+24.93	TEH	TEC	560DT	24		COLD
		0.66	107	3	INR		01C	+16.53	TEH	TEC	560DT	24		COLD
					NDD		TSH		TSH	TSH	560PP	36		HOT
33	50	22.55		8	SLG		TSH	+0.79	TEH	TEC	560DT	25		COLD
					NDD		TSH		TSH	TSH	560PP	34		HOT
33	51	20.55		8	SLG		TSH	+0.70	TEH	TEC	560DT	24		COLD
33	52	22.50		8	SLG		TSH	+0.82	TEH	TEC	560DT	25		COLD
33	53	20.08		8	SLG		TSH	+0.73	TEH	TEC	560DT	24		COLD
33	54	19.96		8	SLG		TSH	+0.75	TEH	TEC	560DT	26		COLD
33	55	20.76		8	SLG		TSH	+0.76	TEH	TEC	560DT	27		COLD
					NDD		TSH		TSH	TSH	560PP	34		HOT
33	56				NDD		TSH		TEH	TEC	560UL	46		COLD
					RBD		TSH		TEH	TEC	560DT	26		COLD
					NDD		TSH		TSH	TSH	560PP	36		HOT
33	57				NDD		TSH		TEH	TEC	560UL	47		COLD
					NDD		TSH		TSH	TSH	560PP	34		HOT
33	58				NDD		TSH		TEH	TEC	560UL	46		COLD
					NDD		TSH		TSH	TSH	560PP	35		HOT
33	59				NDD		TSH		TEH	TEC	560UL	47		COLD
33	60				NDD		TSH		TEH	TEC	560UL	46		COLD
33	61				NDD		TSH		TEH	TEC	560DT	35		COLD
33	62	15.87		8	SLG		TSH	+0.44	TEH	TEC	560DT	34		COLD
33	63				NDD		TSH		TSH	TSH	560PP	15		HOT
		3.96	188	1	DNG		03C	+11.85	TEH	TEC	560DT	35		COLD
33	64				NDD		TSH		TSH	TSH	560PP	14		HOT
					NDD		TSH		TEH	TEC	560DT	34		COLD
33	65				NDD		TSH		TSH	TSH	560PP	15		HOT
					NDD		TSH		TEH	TEC	560DT	35		COLD
33	66				NDD		TSH		TSH	TSH	560PP	15		HOT
					NDD		TSH		TEH	TEC	560DT	34		COLD
33	67				NDD		TSH		TEH	TEC	560DT	37		COLD
33	68				NDD		TSH		TEH	TEC	560UL	36		COLD
33	69	6.35	189	1	DNG		AV1	+6.12	TEH	TEC	560DT	37		COLD
33	70	0.64	72	3	NQH		AV5	+4.88	TEH	TEC	560UL	36		COLD
33	71				NDD		TSH		TSH	TSH	560PP	17		HOT
					NDD		TSH		TEH	TEC	560DT	37		COLD
33	72				NDD		TSH		TSH	TSH	560PP	16		HOT
					NDD		TSH		TEH	TEC	560DT	34		COLD
33	73				NDD		TSH		TSH	TSH	560PP	17		HOT
					NDD		TSH		TEH	TEC	560DT	35		COLD
33	74				NDD		TSH		TSH	TSH	560PP	16		HOT
					NDD		TSH		TEH	TEC	560DT	34		COLD
33	75				NDD		TSH		TEH	TEC	560DT	35		COLD
33	76				NDD		TSH		TEH	TEC	560UL	36		COLD
33	77				NDD		TSH		TEH	TSH	560PP	16		HOT
					NDD		TSH		TEH	TEC	560DT	37		COLD
33	78				NDD		TSH		TEH	TEC	560UL	36		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
33	79				NDD			TSH	TSH	560PP	17			HOT
		2.25	78	6	NQH		TSC +7.78	TEH	TEC	560UL	36			COLD
33	80				NDD			TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
33	81				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	37			COLD
33	82				NDD			TEH	TEC	560DT	38			COLD
					NDD			TSH	TSH	560PP	16			HOT
33	83				NDD			TEH	TEC	560UL	39			COLD
33	84				NDD			TEH	TEC	560UL	39			COLD
33	85				NDD			TEH	TEC	560DT	40			COLD
33	86				NDD			TEH	TEC	560UL	39			COLD
33	87				NDD			TSH	TSH	560PP	17			HOT
					NDD			TEH	TEC	560DT	40			COLD
33	88	19.14		8	SLG		TSH +0.57	TEH	TEC	560UL	39			COLD
		19.34		8	SLG		TSC +0.61	TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
33	89				NDD			TSH	TSH	560PP	17			HOT
		23.35		8	SLG		TSC +0.70	TEH	TEC	560DT	40			COLD
33	90	20.93		8	SLG		TSC +0.74	TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
33	91	26.06		8	SLG		TSC +0.85	TEH	TEC	560DT	40			COLD
33	92	17.50		8	SLG		TSH +0.57	TEH	TEC	560UL	39			COLD
		23.19		8	SLG		TSC +0.93	TEH	TEC	560UL	39			COLD
33	93	18.27		8	SLG		TSH +0.49	TEH	TEC	560DT	40			COLD
		26.06		8	SLG		TSC +0.93	TEH	TEC	560DT	40			COLD
33	94	18.46		8	SLG		TSH +0.52	TEH	TEC	560UL	41			COLD
		26.49		8	SLG		TSC +0.88	TEH	TEC	560UL	41			COLD
33	95	20.54		8	SLG		TSH +0.55	TEH	TEC	560DT	42			COLD
		25.03		8	SLG		TSC +0.90	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
33	96				NDD			TSH	TSH	560PP	18			HOT
		18.32		8	SLG		TSH +0.51	TEH	TEC	560UL	41			COLD
		28.20		8	SLG		TSC +0.94	TEH	TEC	560UL	41			COLD
33	97	19.65		8	SLG		TSH +0.52	TEH	TEC	560DT	42			COLD
		25.17		8	SLG		TSC +0.88	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
33	98				NDD			TSH	TSH	560PP	18			HOT
		20.81		8	SLG		TSH +0.61	TEH	TEC	560UL	41			COLD
		24.84		8	SLG		TSC +0.99	TEH	TEC	560UL	41			COLD
33	99	25.51		8	SLG		TSC +1.00	TEH	TEC	560DT	42			COLD
33	100				NDD			TEH	TEC	560UL	41			COLD
33	101				NDD			TEH	TEC	560UL	41			COLD
33	102	18.15		8	SLG		TSC +0.52	TEH	TEC	560UL	41			COLD
		0.53	112	3	INR		04C +29.88	TEH	TEC	560UL	41			COLD
33	103				NDD			TSH	TSH	560PP	21			HOT
		0.43		103	3		NQH 07C +24.41	TEH	TEC	560UL	43			COLD
		23.30		8	SLG		TSC +0.70	TEH	TEC	560UL	43			COLD
33	104				NDD			TSH	TSH	560PP	20			HOT
		0.44		83	3		NQH 05C +20.87	TEH	TEC	560UL	43			COLD
		24.64		8	SLG		TSC +0.86	TEH	TEC	560UL	43			COLD
33	105				NDD			TSH	TSH	560PP	21			HOT
		24.97		8	SLG		TSC +0.94	TEH	TEC	560UL	43			COLD
33	106				NDD			TSH	TSH	560PP	20			HOT
		25.07		8	SLG		TSC +0.94	TEH	TEC	560UL	43			COLD
		0.27	109	3	INR		04C +23.40	TEH	TEC	560UL	43			COLD
33	107				RBD			TEH	TEC	560UL	71			COLD
					NDD			TEH	TEC	560UC	78			COLD
33	108				NDD			TEH	TEC	560UC	70			COLD
33	109				RBD			TEH	TEC	560UL	71			COLD
					NDD			TEH	TEC	560UC	78			COLD
33	110				NDD			TEH	TEC	560UC	70			COLD
33	111				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UC	70			COLD
34	12	16.91		8	SLG		TSC +0.65	TEH	TEC	560DT	16			COLD
34	13	20.19		8	SLG		TSC +0.75	TEH	TEC	560DT	17			COLD
34	14	19.70		8	SLG		TSC +0.78	TEH	TEC	560DT	16			COLD
34	15	20.50		8	SLG		TSC +0.73	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	44			HOT
34	16				NDD			TSH	TSH	560PP	45			HOT
		20.58		8	SLG		TSC +0.70	TEH	TEC	560DT	17			COLD
34	17	20.31		8	SLG		TSC +0.68	TEH	TEC	560DT	17			COLD
		2.66		81	6		NQH 05C +19.79	TEH	TEC	560DT	17			COLD
					NDD			TSH	TSH	560PP	42			HOT
34	18	19.28		8	SLG		TSC +0.65	TEH	TEC	560DT	18			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					NDD			TSH	TSH	560PP	43			HOT
34	19				NDD			TSH	TSH	560PP	54			HOT
		19.22		8	SLG		TSC	TEH	TEC	560DT	19			COLD
34	20				NDD			TSH	TSH	560PP	53			HOT
		18.69		8	SLG		TSC	TEH	TEC	560DT	19			COLD
34	21				NDD			TSH	TSH	560PP	53			HOT
		17.73		8	SLG		TSC	TEH	TEC	560DT	19			COLD
34	22				NDD			TSH	TSH	560PP	53			HOT
		16.22		8	SLG		TSC	TEH	TEC	560DT	18			COLD
34	23				SLG		TSH	TEH	TEC	560DT	19			COLD
		15.99		8	SLG		TSC	TEH	TEC	560DT	19			COLD
		16.26		8	SLG		TSC	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
34	24				SLG		TSH	TEH	TEC	560DT	18			COLD
		17.45		8	SLG		TSH	TEH	TEC	560DT	18			COLD
					NDD			TSH	TSH	560PP	43			HOT
34	25				SLG		TSH	TEH	TEC	560DT	19			COLD
		17.85		8	SLG		TSH	TEH	TEC	560DT	19			COLD
		3.40	176	P 1	DNT		08C	TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
34	26				SLG		TSH	TEH	TEC	560DT	20			COLD
		17.38		8	SLG		TSH	TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	43			HOT
34	27				SLG		TSH	TEH	TEC	560DT	21			COLD
		17.01		8	SLG		TSH	TEH	TEC	560DT	21			COLD
34	28				SLG		TSH	TEH	TEC	560DT	20			COLD
		17.96		8	SLG		TSH	TEH	TEC	560DT	20			COLD
34	29				SLG		TSH	TEH	TEC	560DT	21			COLD
		17.41		8	SLG		TSH	TEH	TEC	560DT	21			COLD
34	30				SLG		TSH	TEH	TEC	560DT	20			COLD
		18.07		8	SLG		TSH	TEH	TEC	560DT	20			COLD
34	31				SLG		TSH	TEH	TEC	560DT	21			COLD
		18.74		8	SLG		TSH	TEH	TEC	560DT	21			COLD
					NDD			TSH	TSH	560PP	42			HOT
34	32				SLG		TSH	TEH	TEC	560DT	20			COLD
		18.35		8	SLG		TSH	TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	40			HOT
34	33				NDD			TSH	TSH	560PP	40			HOT
		17.51		8	SLG		TSH	TEH	TEC	560DT	21			COLD
34	34				NDD			TSH	TSH	560PP	40			HOT
		18.33		8	SLG		TSH	TEH	TEC	560DT	20			COLD
34	35				SLG		TSH	TEH	TEC	560DT	21			COLD
		17.49		8	SLG		TSH	TEH	TEC	560DT	21			COLD
34	36				SLG		TSH	TEH	TEC	560DT	20			COLD
		18.17		8	SLG		TSH	TEH	TEC	560DT	20			COLD
34	37				SLG		TSH	TEH	TEC	560DT	22			COLD
		19.05		8	SLG		TSH	TEH	TEC	560DT	22			COLD
34	38				SLG		TSH	TEH	TEC	560DT	22			COLD
		19.39		8	SLG		TSH	TEH	TEC	560DT	22			COLD
34	39				SLG		TSH	TEH	TEC	560DT	23			COLD
		20.17		8	SLG		TSH	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
34	40				SLG		TSH	TEH	TEC	560DT	22			COLD
		19.19		8	SLG		TSH	TEH	TEC	560DT	22			COLD
		1.07	101	3	NQH		03C	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	41			HOT
34	41				DNT		08H	TEH	TEC	560DT	23			COLD
		4.75	175	P 1	DNT		08H	TEH	TEC	560DT	23			COLD
		20.11		8	SLG		08H	TEH	TEC	560DT	23			COLD
				3	NDF		08H	08H	08H	560PP	57			HOT
					NDD			TSH	TSH	560PP	40			HOT
34	42				SLG		TSH	TEH	TEC	560DT	22			COLD
		19.03		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	41			HOT
34	43				SLG		TSH	TEH	TEC	560DT	23			COLD
		20.42		8	SLG		TSH	TEH	TEC	560DT	23			COLD
34	44				SLG		TSH	TEH	TEC	560DT	22			COLD
		19.99		8	SLG		TSH	TEH	TEC	560DT	22			COLD
34	45				NDF		08H	08H	08H	560PP	60			HOT
					SLG		TSH	TEH	TEC	560DT	22			COLD
		19.95		8	SLG		TSH	TEH	TEC	560DT	22			COLD
		3.77	172	P 1	DNT		08H	TEH	TEC	560DT	22			COLD
34	46				SLG		TSH	TEH	TEC	560DT	22			COLD
		20.63		8	SLG		TSH	TEH	TEC	560DT	22			COLD
34	47				SLG		TSH	TEH	TEC	560DT	23			COLD
		20.20		8	SLG		TSH	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	41			HOT
34	48				SLG		TSH	TEH	TEC	560DT	22			COLD
		19.47		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	40			HOT
34	49				INR		05C	TEH	TEC	560DT	25			COLD
		2.00	121	3	INR		05C	TEH	TEC	560DT	25			COLD
		23.32		8	SLG		TSH	TEH	TEC	560DT	25			COLD
					NDD			TSH	TSH	560PP	34			HOT
34	50				NDD			TEH	TEC	560DT	24			COLD
					NDD			TSH	TSH	560PP	36			HOT
34	51				SLG		TSH	TEH	TEC	560DT	25			COLD
		21.93		8	SLG		TSH	TEH	TEC	560DT	25			COLD
34	52				SLG		TSH	TEH	TEC	560DT	24			COLD
		21.02		8	SLG		TSH	TEH	TEC	560DT	24			COLD
34	53				SLG		TSH	TEH	TEC	560DT	25			COLD
		22.30		8	SLG		TSH	TEH	TEC	560DT	25			COLD
34	54				SLG		TSH	TEH	TEC	560DT	27			COLD
		20.10		8	SLG		TSH	TEH	TEC	560DT	27			COLD
34	55				SLG		TSH	TEH	TEC	560DT	26			COLD
		19.98		8	SLG		TSH	TEH	TEC	560DT	26			COLD
					NDD			TSH	TSH	560PP	36			HOT
34	56				SLG		TSH	TEH	TEC	560DT	27			COLD
		20.25		8	SLG		TSH	TEH	TEC	560DT	27			COLD
					NDD			TSH	TSH	560PP	34			HOT
34	57				NDD			TEH	TEC	560UL	47			COLD
					NDD			TSH	TSH	560PP	36			HOT
34	58				NDD			TEH	TEC	560UL	46			COLD
					NDD			TSH	TSH	560PP	34			HOT
34	59				NDD			TEH	TEC	560UL	46			COLD
					NDD			TEH	TEC	560UL	46			COLD
34	60				DNG		06C	TEH	TEC	560UL	46			COLD
		3.05	183	1	DNG		06C	TEH	TEC	560UL	46			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
34	61	0.26	78	3	NQH		07H	+4.45	TEH	TEC	560DT	34		COLD
34	62				NDD				TEH	TEC	560DT	35		COLD
34	63				NDD				TSH	TSH	560PP	14		HOT
					NDD				TEH	TEC	560DT	34		COLD
34	64				NDD				TSH	TSH	560PP	15		HOT
		0.50	105	3	NQH		02C	+6.47	TEH	TEC	560DT	35		COLD
34	65				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	34		COLD
34	66				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	35		COLD
34	67				NDD				TEH	TEC	560DT	37		COLD
34	68	0.41	92	3	NQH		03C	+1.72	TEH	TEC	560DT	37		COLD
34	69				NDD				TEH	TEC	560UL	36		COLD
34	70				NDD				TEH	TEC	560DT	37		COLD
34	71				NDD				TEH	TEC	560UL	36		COLD
					NDD				TSH	TSH	560PP	16		HOT
34	72				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	35		COLD
34	73				NDD				TSH	TSH	560PP	16		HOT
					NDD				TEH	TEC	560DT	34		COLD
34	74				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	35		COLD
34	75				NDD				TEH	TSH	560PP	16		HOT
					NDD				TEH	TEC	560DT	34		COLD
34	76				NDD				TEH	TEC	560DT	37		COLD
34	77				NDD				TEH	TEC	560UL	36		COLD
34	78				NDD				TEH	TEC	560DT	37		COLD
34	79				NDD				TSH	TSH	560PP	16		HOT
					NDD				TEH	TEC	560DT	37		COLD
34	80				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	37		COLD
34	81				NDD				TEH	TEC	560UL	36		COLD
					NDD				TSH	TSH	560PP	16		HOT
34	82				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	38		COLD
34	83				NDD				TEH	TEC	560DT	40		COLD
34	84				NDD				TEH	TEC	560DT	40		COLD
34	85				NDD				TEH	TEC	560UL	39		COLD
34	86				NDD				TEH	TEC	560DT	40		COLD
34	87	16.23		8	SLG		TSC	+0.47	TEH	TEC	560UL	39		COLD
					NDD				TSH	TSH	560PP	16		HOT
34	88				NDD				TSH	TSH	560PP	17		HOT
		18.88		8	SLG		TSH	+0.53	TEH	TEC	560DT	40		COLD
		21.72		8	SLG		TSC	+0.62	TEH	TEC	560DT	40		COLD
34	89	16.37		8	SLG		TSH	+0.47	TEH	TEC	560UL	39		COLD
		21.41		8	SLG		TSC	+0.76	TEH	TEC	560UL	39		COLD
					NDD				TSH	TSH	560PP	16		HOT
34	90				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	40		COLD
34	91	22.78		8	SLG		TSC	+0.77	TEH	TEC	560UL	39		COLD
34	92	16.38		8	SLG		TSH	+0.49	TEH	TEC	560DT	40		COLD
		25.55		8	SLG		TSC	+0.93	TEH	TEC	560DT	40		COLD
34	93	16.57		8	SLG		TSH	+0.50	TEH	TEC	560UL	39		COLD
		23.03		8	SLG		TSC	+0.95	TEH	TEC	560UL	39		COLD
34	94	20.51		8	SLG		TSH	+0.59	TEH	TEC	560DT	42		COLD
		26.02		8	SLG		TSC	+0.93	TEH	TEC	560DT	42		COLD
34	95				NDD				TSH	TSH	560PP	18		HOT
		0.91		107	3	NQH	02C	+16.73	TEH	TEC	560UL	41		COLD
		20.07		8	SLG		TSH	+0.57	TEH	TEC	560UL	41		COLD
		24.59		8	SLG		TSC	+0.91	TEH	TEC	560UL	41		COLD
		4.16		185	P 1	DNT	AV2	-0.28	TEH	TEC	560UL	41		COLD
34	96				NDD				TEH	TEC	560UL	106		COLD
					RBD				TEH	TEC	560DT	42		COLD
					NDD				TSH	TSH	560PP	19		HOT
34	97				NDD				TSH	TSH	560PP	18		HOT
		18.13		8	SLG		TSH	+0.51	TEH	TEC	560UL	41		COLD
		25.25		8	SLG		TSC	+0.91	TEH	TEC	560UL	41		COLD
34	98	20.47		8	SLG		TSH	+0.62	TEH	TEC	560DT	42		COLD
		24.32		8	SLG		TSC	+0.98	TEH	TEC	560DT	42		COLD
					NDD				TSH	TSH	560PP	19		HOT
34	99	24.70		8	SLG		TSC	+1.04	TEH	TEC	560UL	41		COLD
34	100				NDD				TEH	TEC	560UL	41		COLD
34	101				NDD				TEH	TEC	560UL	41		COLD
34	102	16.18		8	SLG		TSC	+0.47	TEH	TEC	560UL	41		COLD
34	103				NDD				TSH	TSH	560PP	20		HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
34	104	22.58		8	SLG		TSC	+0.73	TEH	TEC	560UL	43		COLD
					NDD				TSH	TSH	560PP	21		HOT
		24.89		8	SLG		TSC	+0.86	TEH	TEC	560UL	43		COLD
34	105				NDD				TSH	TSH	560PP	20		HOT
		24.91		8	SLG		TSC	+0.94	TEH	TEC	560UL	43		COLD
34	106				NDD				TSH	TSH	560PP	21		HOT
					NDD				TEH	TEC	560UL	71		COLD
34	107				NDD				TEH	TEC	560UL	71		COLD
34	108				NDD				TEH	TEC	560UL	71		COLD
34	109				NDD				TEH	TEC	560UC	70		COLD
34	110				NDD				TEH	TEC	560UL	71		COLD
34	111				NDD				TSH	TSH	560PP	20		HOT
					NDD				TEH	TEC	560UC	70		COLD
35	13	17.76		8	SLG		TSC	+0.68	TEH	TEC	560DT	16		COLD
35	14	20.64		8	SLG		TSC	+0.75	TEH	TEC	560DT	17		COLD
		0.15	110	3	NQH		07H	+19.46	TEH	TEC	560DT	17		COLD
35	15				NDD				TSH	TSH	560PP	45		HOT
		20.17		8	SLG		TSC	+0.73	TEH	TEC	560DT	16		COLD
35	16	19.64		8	SLG		TSC	+0.68	TEH	TEC	560DT	16		COLD
					NDD				TSH	TSH	560PP	44		HOT
35	17	0.78	118	3	INR		05H	+32.65	TEH	TEC	560DT	16		COLD
		19.56		8	SLG		TSC	+0.68	TEH	TEC	560DT	16		COLD
					NDD				TSH	TSH	560PP	43		HOT
35	18	20.20		8	SLG		TSC	+0.67	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
35	19				NDD				TSH	TSH	560PP	54		HOT
		18.78		8	SLG		TSC	+0.60	TEH	TEC	560DT	18		COLD
35	20	15.10		8	SLG		TSH	+0.46	TEH	TEC	560DT	18		COLD
		17.87		8	SLG		TSC	+0.54	TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	52		HOT
35	21				NDD				TSH	TSH	560PP	53		HOT
		17.05		8	SLG		TSC	+0.52	TEH	TEC	560DT	18		COLD
35	22	16.54		8	SLG		TSH	+0.49	TEH	TEC	560DT	19		COLD
		16.57		8	SLG		TSC	+0.49	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	52		HOT
35	23	1.13	0	P 5	TWD	17	TSH	+0.11	TSH	TSH	560PP	52	SVI	HOT
		0.39	90	P 5	ARC		TSH	+0.11	TSH	TSH	560PP	52		HOT
		0.27	0	P 5	LEN		TSH	+0.11	TSH	TSH	560PP	52		HOT
		1.10	0	P 4	TWD	20	TSH	+0.10	TSH	TSH	560PP	52	SVI	HOT
		0.33	90	P 4	ARC		TSH	+0.10	TSH	TSH	560PP	52		HOT
		0.20	0	P 4	LEN		TSH	+0.10	TSH	TSH	560PP	52		HOT
		17.69		8	SLG		TSH	+0.54	TEH	TEC	560DT	18		COLD
		16.00		8	SLG		TSC	+0.47	TEH	TEC	560DT	18		COLD
		0.37	80	3	PID		TSH	+0.09	TSH	TSH	560PP	52		HOT
		0.38	76	3	SVI		TSH	+0.09	TSH	TSH	560PP	43		HOT
		0.30	88	3	PID		TSH	+0.09	TSH	TSH	560PP	51		HOT
35	24	17.71		8	SLG		TSH	+0.54	TEH	TEC	560DT	19		COLD
		16.10		8	SLG		TSC	+0.47	TEH	TEC	560DT	19		COLD
		1.61	84	6	INR		AV5	+5.00	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
35	25	17.19		8	SLG		TSH	+0.54	TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	43		HOT
35	26	16.41		8	SLG		TSH	+0.51	TEH	TEC	560DT	21		COLD
					NDD				TSH	TSH	560PP	42		HOT
35	27	17.88		8	SLG		TSH	+0.54	TEH	TEC	560DT	20		COLD
		15.01		8	SLG		TSC	+0.44	TEH	TEC	560DT	20		COLD
35	28	17.53		8	SLG		TSH	+0.54	TEH	TEC	560DT	21		COLD
35	29	18.00		8	SLG		TSH	+0.57	TEH	TEC	560DT	20		COLD
35	30	0.91	159	1	INR		AV6	+17.87	TEH	TEC	560DT	21		COLD
		3.11	170	P 1	DNT		08C	+0.44	TEH	TEC	560DT	21		COLD
		19.10		8	SLG		TSH	+0.59	TEH	TEC	560DT	21		COLD
35	31	17.86		8	SLG		TSH	+0.57	TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	43		HOT
35	32	17.69		8	SLG		TSH	+0.56	TEH	TEC	560DT	21		COLD
					NDD				TSH	TSH	560PP	40		HOT
35	33	18.47		8	SLG		TSH	+0.59	TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	41		HOT
35	34	17.79		8	SLG		TSH	+0.56	TEH	TEC	560DT	21		COLD
					NDD				TSH	TSH	560PP	41		HOT
35	35	18.75		8	SLG		TSH	+0.59	TEH	TEC	560DT	20		COLD
35	36	17.91		8	SLG		TSH	+0.56	TEH	TEC	560DT	21		COLD
35	37	19.21		8	SLG		TSH	+0.61	TEH	TEC	560DT	23		COLD
35	38	19.59		8	SLG		TSH	+0.64	TEH	TEC	560DT	23		COLD
35	39	19.13		8	SLG		TSH	+0.67	TEH	TEC	560DT	22		COLD
					NDD				TEH	TSH	560PP	41		HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
35	40	19.53		8	SLG		TSH	+0.64	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
35	41	18.82		8	SLG		TSH	+0.62	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
35	42	19.65		8	SLG		TSH	+0.68	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
35	43	19.29		8	SLG		TSH	+0.67	TEH	TEC	560DT	22		COLD
35	44	19.82		8	SLG		TSH	+0.72	TEH	TEC	560DT	23		COLD
35	45	20.27		8	SLG		TSH	+0.72	TEH	TEC	560DT	22		COLD
35	46	19.90		8	SLG		TSH	+0.71	TEH	TEC	560DT	23		COLD
35	47	20.29		8	SLG		TSH	+0.72	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	40		HOT
35	48	20.13		8	SLG		TSH	+0.69	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	41		HOT
35	49	21.00		8	SLG		TSH	+0.74	TEH	TEC	560DT	24		COLD
					NDD				TSH	TSH	560PP	36		HOT
35	50	22.43		8	SLG		TSH	+0.77	TEH	TEC	560DT	25		COLD
					NDD				TSH	TSH	560PP	34		HOT
35	51	0.87	125	3	INR		05H	+29.10	TEH	TEC	560DT	24		COLD
		20.02		8	SLG		TSH	+0.70	TEH	TEC	560DT	24		COLD
35	52	0.35	109	3	INR		02C	+14.09	TEH	TEC	560DT	25		COLD
		22.25		8	SLG		TSH	+0.77	TEH	TEC	560DT	25		COLD
35	53	20.25		8	SLG		TSH	+0.73	TEH	TEC	560DT	24		COLD
35	54	20.06		8	SLG		TSH	+0.72	TEH	TEC	560DT	26		COLD
35	55	20.39		8	SLG		TSH	+0.71	TEH	TEC	560DT	27		COLD
					NDD				TSH	TSH	560PP	34		HOT
35	56	19.07		8	SLG		TSH	+0.70	TEH	TEC	560DT	26		COLD
					NDD				TSH	TSH	560PP	36		HOT
35	57				NDD				TEH	TEC	560UL	47		COLD
					NDD				TSH	TSH	560PP	34		HOT
35	58				NDD				TEH	TEC	560UL	46		COLD
					NDD				TSH	TSH	560PP	35		HOT
35	59				NDD				TEH	TEC	560UL	47		COLD
35	60				NDD				TEH	TEC	560UL	46		COLD
35	61				NDD				TEH	TEC	560DT	35		COLD
35	62	16.26		8	SLG		TSH	+0.46	TEH	TEC	560DT	34		COLD
35	63				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	35		COLD
35	64				NDD				TSH	TSH	560PP	14		HOT
					NDD				TEH	TEC	560DT	34		COLD
35	65			3	NDF		06H	+1.84	06H	06H	560PP	61		HOT
					NDD				TSH	TSH	560PP	15		HOT
	4.97	188	1		DNG		06H	+1.87	TEH	TEC	560DT	35		COLD
35	66				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	34		COLD
35	67				NDD				TEH	TEC	560DT	37		COLD
35	68				NDD				TEH	TEC	560UL	36		COLD
35	69				NDD				TEH	TEC	560DT	37		COLD
35	70				NDD				TEH	TEC	560UL	36		COLD
35	71				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	37		COLD
35	72				NDD				TSH	TSH	560PP	16		HOT
					NDD				TEH	TEC	560DT	34		COLD
35	73				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	35		COLD
35	74				NDD				TSH	TSH	560PP	16		HOT
	3.96	176	1		DNG		08C	-1.40	TEH	TEC	560DT	34		COLD
35	75				NDD				TEH	TEC	560DT	35		COLD
35	76				NDD				TEH	TEC	560UL	36		COLD
35	77				NDD				TEH	TEC	560DT	37		COLD
35	78				NDD				TEH	TEC	560UL	36		COLD
35	79				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560UL	36		COLD
35	80				NDD				TEH	TEC	560UL	36		COLD
					NDD				TSH	TSH	560PP	16		HOT
35	81				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	37		COLD
35	82				NDD				TEH	TEC	560DT	38		COLD
					NDD				TSH	TSH	560PP	16		HOT
35	83				NDD				TEH	TEC	560UL	39		COLD
35	84	3.20	187	1	DNG		04H	+17.31	TEH	TEC	560UL	39		COLD
35	85				NDD				TEH	TEC	560DT	40		COLD
35	86				NDD				TEH	TEC	560UL	39		COLD
35	87				NDD				TSH	TSH	560PP	17		HOT
	17.58			8	SLG		TSC	+0.54	TEH	TEC	560DT	40		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
35	88	18.79		8	SLG		TSH			TEH TEC 560UL	39			COLD
		20.95		8	SLG		TSC			TEH TEC 560UL	39			COLD
					NDD					TSH TSH 560PP	16			HOT
35	89				NDD					TSH TSH 560PP	17			HOT
		16.23		8	SLG		TSH			TEH TEC 560DT	40			COLD
		23.72		8	SLG		TSC			TEH TEC 560DT	40			COLD
35	90	21.15		8	SLG		TSC			TEH TEC 560UL	39			COLD
					NDD					TSH TSH 560PP	16			HOT
35	91	15.70		8	SLG		TSH			TEH TEC 560DT	40			COLD
		24.35		8	SLG		TSC			TEH TEC 560DT	40			COLD
35	92	18.39		8	SLG		TSH			TEH TEC 560UL	39			COLD
		21.88		8	SLG		TSC			TEH TEC 560UL	39			COLD
35	93	15.03		8	SLG		TSH			TEH TEC 560DT	40			COLD
		23.76		8	SLG		TSC			TEH TEC 560DT	40			COLD
35	94	20.77		8	SLG		TSH			TEH TEC 560UL	41			COLD
		26.41		8	SLG		TSC			TEH TEC 560UL	41			COLD
35	95	18.50		8	SLG		TSH			TEH TEC 560DT	42			COLD
		24.34		8	SLG		TSC			TEH TEC 560DT	42			COLD
					NDD					TSH TSH 560PP	19			HOT
35	96				NDD					TSH TSH 560PP	18			HOT
		18.03		8	SLG		TSH			TEH TEC 560UL	41			COLD
		25.19		8	SLG		TSC			TEH TEC 560UL	41			COLD
35	97	20.43		8	SLG		TSH			TEH TEC 560DT	42			COLD
		24.93		8	SLG		TSC			TEH TEC 560DT	42			COLD
					NDD					TSH TSH 560PP	19			HOT
35	98				NDD					TSH TSH 560PP	18			HOT
		21.20		8	SLG		TSH			TEH TEC 560UL	41			COLD
		24.88		8	SLG		TSC			TEH TEC 560UL	41			COLD
35	99	16.18		8	SLG		TSH			TEH TEC 560DT	42			COLD
		25.29		8	SLG		TSC			TEH TEC 560DT	42			COLD
35	100	0.34	164	1	INR		08H			TEH TEC 560UL	41			COLD
				2	NDF		08H			AV2 08H 5201P	72			HOT
35	101	0.47	156	1	INR		08H			TEH TEC 560UL	41			COLD
35	102	15.52		8	SLG		TSC			TEH TEC 560UL	41			COLD
35	103				NDD					TSH TSH 560PP	21			HOT
		21.23		8	SLG		TSC			TEH TEC 560UL	43			COLD
		0.59	0	P 2	TWD	15	AV5			TEH TEC 560UL	43			COLD
35	104				NDD					TSH TSH 560PP	20			HOT
		24.66		8	SLG		TSC			TEH TEC 560UL	43			COLD
35	105				NDD					TSH TSH 560PP	21			HOT
		25.79		8	SLG		TSC			TEH TEC 560UL	43			COLD
35	106				NDD					TSH TSH 560PP	20			HOT
					NDD					TEH TEC 560UL	71			COLD
35	107				NDD					TEH TEC 560UC	70			COLD
35	108	2.33	72	6	NQH		AV5			TEH TEC 560UL	71			COLD
		0.62	0	P 2	TWD	15	AV3			TEH TEC 560UL	71			COLD
35	109	0.45	0	P 2	TWD	14	AV4			TEH TEC 560UC	70			COLD
35	110				NDD					TEH TEC 560UC	70			COLD
36	13	15.64		8	SLG		TSC			TEH TEC 560DT	16			COLD
		4.68		180	P 1		DNT			TEH TEC 560DT	16	OK		COLD
36	14	18.21		8	SLG		TSC			TEH TEC 560DT	16			COLD
36	15	21.19		8	SLG		TSC			TEH TEC 560DT	17			COLD
		0.27		80	3		NQH			TEH TEC 560DT	17			COLD
					NDD					TSH TSH 560PP	44			HOT
36	16				NDD					TSH TSH 560PP	45			HOT
		20.50		8	SLG		TSC			TEH TEC 560DT	17			COLD
		0.48		139	1		TFH			TEH TEC 560DT	17			COLD
36	17	20.96		8	SLG		TSC			TEH TEC 560DT	17			COLD
					NDD					TSH TSH 560PP	42			HOT
36	18	19.36		8	SLG		TSC			TEH TEC 560DT	18			COLD
					NDD					TSH TSH 560PP	43			HOT
36	19				NDD					TSH TSH 560PP	54			HOT
		19.98		8	SLG		TSC			TEH TEC 560DT	19			COLD
36	20				NDD					TSH TSH 560PP	54	IDOK		HOT
		15.44		8	SLG		TSH			TEH TEC 560DT	19			COLD
		18.96		8	SLG		TSC			TEH TEC 560DT	19			COLD
					NDD					TSH TSH 560PP	52			HOT
36	21				NDD					TSH TSH 560PP	53			HOT
		17.87		8	SLG		TSC			TEH TEC 560DT	19			COLD
36	22				NDD					TSH TSH 560PP	53			HOT
		16.69		8	SLG		TSC			TEH TEC 560DT	18			COLD
36	23	18.12		8	SLG		TSH			TEH TEC 560DT	19			COLD
		17.63		8	SLG		TSC			TEH TEC 560DT	19			COLD
					NDD					TSH TSH 560PP	42			HOT
36	24	16.97		8	SLG		TSH			TEH TEC 560DT	18			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		15.98		8	SLG		TSC							
					NDD			TEH	TEC	560DT	18			COLD
36	25	17.63		8	SLG		TSH	TSH	TSH	560PP	43			HOT
		16.91		8	SLG		TSC	TEH	TEC	560DT	19			COLD
					NDD			TEH	TEC	560DT	19			COLD
					NDD			TSH	TSH	560PP	42			HOT
36	26	17.18		8	SLG		TSH	TEH	TEC	560DT	20			COLD
		16.20		8	SLG		TSC	TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	43			HOT
36	27	17.51		8	SLG		TSH	TEH	TEC	560DT	21			COLD
		15.66		8	SLG		TSC	TEH	TEC	560DT	21			COLD
36	28	17.28		8	SLG		TSH	TEH	TEC	560DT	20			COLD
36	29	17.69		8	SLG		TSH	TEH	TEC	560DT	21			COLD
		15.46		8	SLG		TSC	TEH	TEC	560DT	21			COLD
36	30	18.45		8	SLG		TSH	TEH	TEC	560DT	20			COLD
		15.86		8	SLG		TSC	TEH	TEC	560DT	20			COLD
36	31	16.69		8	SLG		TSH	TEH	TEC	560DT	21			COLD
					NDD			TSH	TSH	560PP	42			HOT
36	32	18.43		8	SLG		TSH	TEH	TEC	560DT	20			COLD
		16.04		8	SLG		TSC	TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	40			HOT
36	33				NDD			TSH	TSH	560PP	40			HOT
		18.31		8	SLG		TSH	TEH	TEC	560DT	21			COLD
		15.20		8	SLG		TSC	TEH	TEC	560DT	21			COLD
36	34				NDD			TSH	TSH	560PP	40			HOT
		18.00		8	SLG		TSH	TEH	TEC	560DT	20			COLD
36	35	18.96		8	SLG		TSH	TEH	TEC	560DT	21			COLD
36	36	18.63		8	SLG		TSH	TEH	TEC	560DT	20			COLD
36	37	17.50		8	SLG		TSH	TEH	TEC	560DT	22			COLD
36	38	18.56		8	SLG		TSH	TEH	TEC	560DT	22			COLD
36	39	18.99		8	SLG		TSH	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
36	40	18.72		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	41			HOT
36	41	19.15		8	SLG		TSH	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	40			HOT
36	42	18.89		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	41			HOT
36	43	22.91		8	SLG		TSH	TEH	TEC	560DT	23			COLD
36	44	19.31		8	SLG		TSH	TEH	TEC	560DT	22			COLD
36	46	19.85		8	SLG		TSH	TEH	TEC	560DT	22			COLD
36	47	20.05		8	SLG		TSH	TEH	TEC	560DT	23			COLD
					NDD			TSH	TSH	560PP	41			HOT
36	48	0.95	107	3	INR		03C	TEH	TEC	560DT	22			COLD
		20.19		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	40			HOT
36	49	22.05		8	SLG		TSH	TEH	TEC	560DT	25			COLD
					NDD			TSH	TSH	560PP	34			HOT
36	50	19.90		8	SLG		TSH	TEH	TEC	560DT	24			COLD
					NDD			TSH	TSH	560PP	36			HOT
36	51	21.96		8	SLG		TSH	TEH	TEC	560DT	25			COLD
36	52	19.37		8	SLG		TSH	TEH	TEC	560DT	24			COLD
36	53	22.77		8	SLG		TSH	TEH	TEC	560DT	25			COLD
		0.82			NDD			TEH	TEC	560DT	25			COLD
36	54	20.66	127	3	INR		AV6	TEH	TEC	560DT	25			COLD
36	55	19.07		8	SLG		TSH	TEH	TEC	560DT	27			COLD
					NDD			TEH	TEC	560DT	26			COLD
36	56				NDD			TSH	TSH	560PP	36			HOT
					NDD			TEH	TEC	560DT	27			COLD
36	57				NDD			TSH	TSH	560PP	34			HOT
					NDD			TEH	TEC	560UL	47			COLD
36	58				NDD			TSH	TSH	560PP	36			HOT
					NDD			TEH	TEC	560UL	46			COLD
36	59				NDD			TSH	TSH	560PP	34			HOT
36	60				NDD			TEH	TEC	560UL	46			COLD
36	61	16.69		8	SLG		TSH	TEH	TEC	560DT	34			COLD
36	62	19.83		8	SLG		TSH	TEH	TEC	560DT	35			COLD
36	63				NDD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560DT	34			COLD
36	64				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	35			COLD
36	65				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	34			COLD
36	66				NDD			TSH	TSH	560PP	15			HOT
		0.88	120	3	INR		07H	TEH	TEC	560DT	35			COLD
36	67				NDD			TEH	TEC	560DT	37			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
36	68	0.44	116	3	NQH		07C							
	69				NDD			TEH	TEC	560DT	37			COLD
	70				NDD			TEH	TEC	560UL	36			COLD
	71				NDD			TEH	TEC	560DT	37			COLD
	72				NDD			TEH	TEC	560UL	36			COLD
	73				NDD			TSH	TSH	560PP	16			HOT
	74				NDD			TSH	TSH	560PP	17			HOT
	75	0.31	80	3	NQH		TSH	TEH	TEC	560DT	35			COLD
	76				NDD			TEH	TEC	560PP	16			HOT
	77				NDD			TEH	TEC	560DT	34			COLD
	78				NDD			TEH	TEC	560UL	36			COLD
	79				NDD			TEH	TEC	560DT	37			COLD
	80				NDD			TSH	TSH	560PP	16			HOT
	81				NDD			TEH	TEC	560DT	37			COLD
	82				NDD			TEH	TEC	560UL	36			COLD
	83				NDD			TSH	TSH	560PP	16			HOT
	84				NDD			TSH	TSH	560PP	17			HOT
	85				NDD			TEH	TEC	560DT	38			COLD
	86				NDD			TEH	TEC	560DT	38			COLD
	87	17.68		8	SLG		TSH	TEH	TEC	560DT	40			COLD
	88	18.65		8	SLG		TSC	TEH	TEC	560UL	39			COLD
	89				NDD			TSH	TSH	560PP	16			HOT
	90				NDD			TSH	TSH	560PP	17			HOT
	91	19.21		8	SLG		TSH	TEH	TEC	560DT	40			COLD
	92	23.53		8	SLG		TSC	TEH	TEC	560DT	40			COLD
	93	18.39		8	SLG		TSH	TEH	TEC	560UL	39			COLD
	94	21.47		8	SLG		TSC	TEH	TEC	560UL	39			COLD
	95				NDD			TSH	TSH	560PP	16			HOT
	96				NDD			TSH	TSH	560PP	17			HOT
	97	25.23		8	SLG		TSC	TEH	TEC	560DT	40			COLD
	98	0.45	133	1	TFH		08H	TEH	TEC	560DT	40			COLD
	99			2	NDF		08H	AV2	08H	5201P	72			HOT
	100	18.05		8	SLG		TSH	TEH	TEC	560UL	39			COLD
	101	22.38		8	SLG		TSC	TEH	TEC	560UL	39			COLD
	102	17.48		8	SLG		TSH	TEH	TEC	560DT	40			COLD
	103	25.04		8	SLG		TSC	TEH	TEC	560DT	40			COLD
	104	17.34		8	SLG		TSH	TEH	TEC	560UL	39			COLD
	105	22.02		8	SLG		TSC	TEH	TEC	560UL	39			COLD
	106	20.64		8	SLG		TSH	TEH	TEC	560DT	42			COLD
	107				NDD			TSH	TSH	560PP	18			HOT
	108	3.25	173	P 1	DNT		08H	TEH	TEC	560UL	41			COLD
	109	17.23		8	SLG		TSH	TEH	TEC	560UL	41			COLD
	110	24.43		8	SLG		TSC	TEH	TEC	560UL	41			COLD
	111			3	NDF		08H	08H	08H	560PP	62			HOT
	112	19.29		8	SLG		TSH	TEH	TEC	560DT	42			COLD
	113	24.97		8	SLG		TSC	TEH	TEC	560DT	42			COLD
	114				NDD			TSH	TSH	560PP	19			HOT
	115				NDD			TSH	TSH	560PP	18			HOT
	116	23.01		8	SLG		TSH	TEH	TEC	560UL	41			COLD
	117	25.48		8	SLG		TSC	TEH	TEC	560UL	41			COLD
	118	0.33	158	1	INR		08H	TEH	TEC	560UL	41			COLD
	119	0.51	0	P 2	TWD	15	AV2	TEH	TEC	560UL	41			COLD
	120	21.36		8	SLG		TSH	TEH	TEC	560DT	42			COLD
	121	24.73		8	SLG		TSC	TEH	TEC	560DT	42			COLD
	122				NDD			TSH	TSH	560PP	19			HOT
	123	1.31	116	3	INR		06C	TEH	TEC	560UL	41			COLD
	124	17.80		8	SLG		TSH	TEH	TEC	560UL	41			COLD
	125	24.86		8	SLG		TSC	TEH	TEC	560UL	41			COLD
	126	16.16		8	SLG		TSH	TEH	TEC	560UL	41			COLD
	127	17.08		8	SLG		TSC	TEH	TEC	560UL	41			COLD
	128				NDD			TEH	TEC	560UL	41			COLD
	129				NDD			TEH	TEC	560UL	41			COLD
	130				NDD			TSH	TSH	560PP	20			HOT
	131	21.09		8	SLG		TSC	TEH	TEC	560UL	43			COLD
	132				NDD			TSH	TSH	560PP	21			HOT
	133	15.47		8	SLG		TSH	TEH	TEC	560UL	43			COLD
	134	25.09		8	SLG		TSC	TEH	TEC	560UL	43			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		14.65	181	P 1	DNT		08H			TEH TEC	560DT	21		COLD
				3	NDF		08H			08H 08H	560PP	57		HOT
				3	NDF		08H			08H 08H	560PP	57		HOT
37	37	18.76		8	SLG		TSH			TEH TEC	560DT	23		COLD
37	38	18.84		8	SLG		TSH			TEH TEC	560DT	23		COLD
37	39	18.56		8	SLG		TSH			TEH TEC	560DT	22		COLD
					NDD					TSH TSH	560PP	41		HOT
37	40	18.48		8	SLG		TSH			TEH TEC	560DT	23		COLD
					NDD					TSH TSH	560PP	40		HOT
37	41	18.66		8	SLG		TSH			TEH TEC	560DT	22		COLD
					NDD					TSH TSH	560PP	41		HOT
37	42	19.86		8	SLG		TSH			TEH TEC	560DT	23		COLD
					NDD					TSH TSH	560PP	40		HOT
37	43	22.62		8	SLG		TSH			TEH TEC	560DT	22		COLD
37	44	21.28		8	SLG		TSH			TEH TEC	560DT	23		COLD
37	45	18.99		8	SLG		TSH			TEH TEC	560DT	23		COLD
		9.00	181	P 1	DNT		08H			TEH TEC	560DT	23		COLD
					RID		08H			08H 08H	560PP	55		HOT
				3	NDF		08H			08H 08H	560PP	57		HOT
37	46	19.55		8	SLG		TSH			TEH TEC	560DT	23		COLD
37	47	18.99		8	SLG		TSH			TEH TEC	560DT	22		COLD
					NDD					TSH TSH	560PP	40		HOT
37	48	20.61		8	SLG		TSH			TEH TEC	560DT	23		COLD
					NDD					TSH TSH	560PP	41		HOT
37	49	18.54		8	SLG		TSH			TEH TEC	560DT	24		COLD
					NDD					TSH TSH	560PP	36		HOT
37	50	22.55		8	SLG		TSH			TEH TEC	560DT	25		COLD
					NDD					TSH TSH	560PP	34		HOT
37	51	19.43		8	SLG		TSH			TEH TEC	560DT	24		COLD
37	52	21.32		8	SLG		TSH			TEH TEC	560DT	25		COLD
37	53	19.51		8	SLG		TSH			TEH TEC	560DT	24		COLD
37	54	18.67		8	SLG		TSH			TEH TEC	560DT	26		COLD
37	55	19.45		8	SLG		TSH			TEH TEC	560DT	27		COLD
					NDD					TSH TSH	560PP	34		HOT
37	56	19.44		8	SLG		TSH			TEH TEC	560DT	26		COLD
					INF		06H			TEH TEC	560DT	26	HR	COLD
					NDD					TSH TSH	560PP	36		HOT
37	57				NDD					TEH TEC	560UL	47		COLD
					NDD					TSH TSH	560PP	34		HOT
37	58				NDD					TEH TEC	560UL	46		COLD
					NDD					TSH TSH	560PP	35		HOT
37	59				NDD					TEH TEC	560UL	47		COLD
37	60				NDD					TEH TEC	560UL	46		COLD
37	61	17.85		8	SLG		TSH			TEH TEC	560DT	35		COLD
37	62	19.74		8	SLG		TSH			TEH TEC	560DT	34		COLD
37	63				NDD					TSH TSH	560PP	15		HOT
					NDD					TEH TEC	560DT	35		COLD
37	64				NDD					TSH TSH	560PP	14		HOT
					NDD					TEH TEC	560DT	34		COLD
37	65				NDD					TSH TSH	560PP	15		HOT
					NDD					TEH TEC	560DT	35		COLD
37	66			3	NDF		08H			08H 08H	560PP	61		HOT
					NDD					TSH TSH	560PP	15		HOT
		0.28	80	3	NQH		08H			TEH TEC	560DT	34		COLD
		1.36	114	3	INR		07C			TEH TEC	560DT	34		COLD
37	67				NDD					TEH TEC	560DT	37		COLD
37	68	0.86	167	1	INR		08C			TEH TEC	560UL	36		COLD
37	69				NDD					TEH TEC	560DT	37		COLD
37	70	3.71	176	1	DNG		07C			TEH TEC	560UL	36		COLD
37	71				NDD					TSH TSH	560PP	17		HOT
					NDD					TEH TEC	560DT	37		COLD
37	72				NDD					TSH TSH	560PP	16		HOT
					NDD					TEH TEC	560DT	34		COLD
37	73				NDD					TSH TSH	560PP	17		HOT
					NDD					TEH TEC	560DT	35		COLD
37	74				NDD					TSH TSH	560PP	16		HOT
					NDD					TEH TEC	560DT	34		COLD
37	75				NDD					TEH TEC	560DT	35		COLD
37	76				NDD					TEH TEC	560UL	36		COLD
37	77				NDD					TEH TEC	560DT	37		COLD
37	78				NDD					TEH TEC	560DT	37		COLD
37	79				NDD					TSH TSH	560PP	17		HOT
		6.04	179	P 1	DNT		08C			TEH TEC	560DT	37		COLD
37	80				NDD					TEH TEC	560UL	36		COLD
					NDD					TSH TSH	560PP	16		HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
37	81				NDD			TSH	TSH	560PP	17			HOT
		3.90	179	P 1	DNT		08C	TEH	TEC	560DT	37			COLD
		0.31	103	3	NQH		07C	TEH	TEC	560DT	37			COLD
37	82				NDD			TEH	TEC	560DT	38			COLD
					NDD			TSH	TSH	560PP	16			HOT
37	83				NDD			TEH	TEC	560DT	38			COLD
37	84				NDD			TEH	TEC	560UL	39			COLD
37	85				NDD			TEH	TEC	560DT	40			COLD
37	86				NDD			TEH	TEC	560UL	39			COLD
37	87				NDD			TSH	TSH	560PP	17			HOT
		21.29		8	SLG		TSH	TEH	TEC	560DT	40			COLD
		22.15		8	SLG		TSC	TEH	TEC	560DT	40			COLD
37	88			8	SLG		TSH	TEH	TEC	560UL	39			COLD
		19.07		8	SLG		TSC	TEH	TEC	560UL	39			COLD
		21.41		8	SLG		TSC	TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
37	89				NDD			TSH	TSH	560PP	17			HOT
		17.70		8	SLG		TSH	TEH	TEC	560DT	40			COLD
		23.64		8	SLG		TSC	TEH	TEC	560DT	40			COLD
37	90			8	SLG		TSC	TEH	TEC	560UL	39			COLD
		23.31		8	SLG		TSC	TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
37	91			8	SLG		TSH	TEH	TEC	560DT	40			COLD
		16.36		8	SLG		TSC	TEH	TEC	560DT	40			COLD
		25.39		8	SLG		TSC	TEH	TEC	560DT	40			COLD
		0.54	164	1	INR		08C	TEH	TEC	560DT	40			COLD
37	92			8	SLG		TSH	TEH	TEC	560UL	39			COLD
		19.28		8	SLG		TSC	TEH	TEC	560UL	39			COLD
		21.78		8	SLG		TSC	TEH	TEC	560UL	39			COLD
37	93			8	SLG		TSH	TEH	TEC	560DT	40			COLD
		19.17		8	SLG		TSC	TEH	TEC	560DT	40			COLD
		25.63		8	SLG		TSC	TEH	TEC	560DT	40			COLD
		0.63	0	P 2	TWD	21	AV3	TEH	TEC	560DT	40			COLD
		0.46	0	P 2	TWD	16	AV4	TEH	TEC	560DT	40			COLD
37	94			3	NDF		08H	08H	08H	560PP	61			HOT
		0.42	149	P 1	INR		08C	TEH	TEC	560UL	41			COLD
		1.16	161	1	INR		08H	TEH	TEC	560UL	41			COLD
		17.97		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		24.24		8	SLG		TSC	TEH	TEC	560UL	41			COLD
37	95			8	SLG		TSH	TEH	TEC	560DT	42			COLD
		17.79		8	SLG		TSC	TEH	TEC	560DT	42			COLD
		23.84		8	SLG		TSC	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
37	96				NDD			TSH	TSH	560PP	18			HOT
		19.18		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		23.85		8	SLG		TSC	TEH	TEC	560UL	41			COLD
37	97			8	SLG		TSH	TEH	TEC	560DT	42			COLD
		21.08		8	SLG		TSC	TEH	TEC	560DT	42			COLD
		24.36		8	SLG		TSC	TEH	TEC	560DT	42			COLD
					NDD			TSH	TSH	560PP	19			HOT
37	98				NDD			TSH	TSH	560PP	18			HOT
		19.96		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		23.98		8	SLG		TSC	TEH	TEC	560UL	41			COLD
37	99			8	SLG		TSH	TEH	TEC	560DT	42			COLD
		20.15		8	SLG		TSC	TEH	TEC	560DT	42			COLD
		25.19		8	SLG		TSC	TEH	TEC	560DT	42			COLD
37	100			8	SLG		TSH	TEH	TEC	560UL	41			COLD
		17.91		8	SLG		TSC	TEH	TEC	560UL	41			COLD
		20.97		8	SLG		TSC	TEH	TEC	560UL	41			COLD
37	101			0	P 2	TWD	14	AV4	TEH	TEC	560UL	41		COLD
		0.46		0	P 2	TWD	15	AV3	TEH	TEC	560UL	41		COLD
		0.48		0	P 2	TWD	19	AV2	TEH	TEC	560UL	41		COLD
		0.69		0	P 2	TWD	19	AV2	TEH	TEC	560UL	41		COLD
37	102				NDD			TEH	TEC	560UL	41			COLD
37	103				NDD			TSH	TSH	560PP	21			HOT
		20.91		8	SLG		TSC	TEH	TEC	560UL	43			COLD
		0.48	0	P 2	TWD	12	AV5	TEH	TEC	560UL	43			COLD
37	104				NDD			TSH	TSH	560PP	20			HOT
		16.10		8	SLG		TSH	TEH	TEC	560UL	43			COLD
		24.66		8	SLG		TSC	TEH	TEC	560UL	43			COLD
37	105				NDD			TSH	TSH	560PP	21			HOT
					NDD			TEH	TEC	560UL	71			COLD
37	106				NDD			01C	01C	560PS	112			COLD
					NDD			TSH	TSH	560PP	20			HOT
		0.64	103	3	NQH		AV2	TEH	TEC	560UC	70			COLD
		0.83	73	3	NQH		AV2	TEH	TEC	560UC	70			COLD
		0.79	0	P 2	TWD	22	AV3	TEH	TEC	560UC	70			COLD
		1.35	0	P 2	TWD	31	AV4	TEH	TEC	560UC	70			COLD
		0.94	0	P 2	TWD	25	AV5	TEH	TEC	560UC	70			COLD
37	107				NDD			01C	01C	560PS	112			COLD
					NDD			TEH	TEC	560UL	71			COLD
37	108				NDD			01C	01C	560PS	112			COLD
					NDD			TEH	TEC	560UC	70			COLD
38	15	19.10		8	SLG		TSC	TEH	TEC	560DT	16			COLD
					NDD			TSH	TSH	560PP	44			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
38	16	21.43		8	SLG		TSC	+0.75	TEH	TEC	560DT	17		COLD
					NDD				TSH	TSH	560PP	44		HOT
38	17	21.25		8	SLG		TSC	+0.73	TEH	TEC	560DT	17		COLD
					NDD				TSH	TSH	560PP	42		HOT
38	18	19.81		8	SLG		TSC	+0.68	TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	43		HOT
38	19				NDD				TSH	TSH	560PP	54		HOT
		20.00		8	SLG		TSC	+0.68	TEH	TEC	560DT	19		COLD
38	20	20.04		8	SLG		TSC	+0.65	TEH	TEC	560DT	19		COLD
		1.03	168	1	INR		05C	+30.27	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	52		HOT
38	21				NDD				TSH	TSH	560PP	53		HOT
		15.44		8	SLG		TSH	+0.44	TEH	TEC	560DT	19		COLD
		19.73		8	SLG		TSC	+0.62	TEH	TEC	560DT	19		COLD
		0.41	0	P 2	TWD	14	AV5	+0.08	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	53		HOT
38	22			8	SLG		TSC	+0.62	TEH	TEC	560DT	18		COLD
		19.20		8	SLG		TSH	+0.49	TEH	TEC	560DT	19		COLD
38	23	15.75		8	SLG		TSC	+0.57	TEH	TEC	560DT	19		COLD
		18.79		8	SLG		TSC	+0.57	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
38	24	17.27		8	SLG		TSH	+0.52	TEH	TEC	560DT	18		COLD
		17.99		8	SLG		TSC	+0.54	TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	43		HOT
38	25	17.46		8	SLG		TSH	+0.51	TEH	TEC	560DT	19		COLD
		18.46		8	SLG		TSC	+0.57	TEH	TEC	560DT	19		COLD
					NDD				TSH	TSH	560PP	42		HOT
38	26	16.72		8	SLG		TSH	+0.50	TEH	TEC	560DT	20		COLD
		17.04		8	SLG		TSC	+0.54	TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	43		HOT
38	27	17.81		8	SLG		TSH	+0.56	TEH	TEC	560DT	21		COLD
		18.07		8	SLG		TSC	+0.57	TEH	TEC	560DT	21		COLD
38	28	18.09		8	SLG		TSH	+0.54	TEH	TEC	560DT	20		COLD
		17.60		8	SLG		TSC	+0.55	TEH	TEC	560DT	20		COLD
38	29	0.34	96	3	NQH		TSH	+6.93	TEH	TEC	560DT	21		COLD
		0.23	114	3	NQH		TSH	+7.52	TEH	TEC	560DT	21		COLD
		17.51		8	SLG		TSH	+0.54	TEH	TEC	560DT	21		COLD
		16.95		8	SLG		TSC	+0.49	TEH	TEC	560DT	21		COLD
38	30	19.13		8	SLG		TSH	+0.60	TEH	TEC	560DT	20		COLD
		17.20		8	SLG		TSC	+0.52	TEH	TEC	560DT	20		COLD
38	31	18.29		8	SLG		TSH	+0.59	TEH	TEC	560DT	21		COLD
		17.31		8	SLG		TSC	+0.52	TEH	TEC	560DT	21		COLD
					NDD				TSH	TSH	560PP	42		HOT
38	32	18.27		8	SLG		TSH	+0.56	TEH	TEC	560DT	20		COLD
		16.66		8	SLG		TSC	+0.51	TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	40		HOT
38	33				NDD				TSH	TSH	560PP	40		HOT
		18.59		8	SLG		TSH	+0.57	TEH	TEC	560DT	21		COLD
		15.26		8	SLG		TSC	+0.44	TEH	TEC	560DT	21		COLD
38	34				NDD				TSH	TSH	560PP	40		HOT
		17.54		8	SLG		TSH	+0.54	TEH	TEC	560DT	20		COLD
38	35	16.99		8	SLG		TSH	+0.54	TEH	TEC	560DT	21		COLD
38	36	5.24	178	P 1	DNT		08C	-0.26	TEH	TEC	560DT	20		COLD
		17.48		8	SLG		TSH	+0.55	TEH	TEC	560DT	20		COLD
38	37	18.48		8	SLG		TSH	+0.59	TEH	TEC	560DT	22		COLD
38	38	18.50		8	SLG		TSH	+0.57	TEH	TEC	560DT	22		COLD
38	39	18.44		8	SLG		TSH	+0.59	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
38	40	18.36		8	SLG		TSH	+0.59	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
38	41	18.67		8	SLG		TSH	+0.61	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	40		HOT
38	42	18.48		8	SLG		TSH	+0.59	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	41		HOT
38	43	19.65		8	SLG		TSH	+0.61	TEH	TEC	560DT	23		COLD
38	44	21.23		8	SLG		TSH	+0.65	TEH	TEC	560DT	22		COLD
38	45	19.57		8	SLG		TSH	+0.67	TEH	TEC	560DT	22		COLD
38	46	19.47		8	SLG		TSH	+0.64	TEH	TEC	560DT	22		COLD
38	47	0.48	101	3	NQH		02H	+8.27	TEH	TEC	560DT	23		COLD
		18.82		8	SLG		TSH	+0.61	TEH	TEC	560DT	23		COLD
					NDD				TSH	TSH	560PP	41		HOT
38	48	20.65		8	SLG		TSH	+0.65	TEH	TEC	560DT	22		COLD
					NDD				TSH	TSH	560PP	40		HOT
38	49	0.67	105	3	NQH		AV2	+4.52	TEH	TEC	560DT	25		COLD
					NDD				TSH	TSH	560PP	34		HOT
38	50			3	NDF		01H	+4.28	01H	01H	560PP	60		HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		3.63	185	1	DNG		01H	+4.28	TEH	TEC	560DT	24		COLD
		18.82		8	SLG		TSH	+0.62	TEH	TEC	560DT	24		COLD
					NDD				TSH	TSH	560PP	36		HOT
38	51	21.98		8	SLG		TSH	+0.74	TEH	TEC	560DT	25		COLD
38	52	19.68		8	SLG		TSH	+0.62	TEH	TEC	560DT	24		COLD
38	53	21.59		8	SLG		TSH	+0.74	TEH	TEC	560DT	25		COLD
38	54	0.18	92	3	NQH		06H	+26.62	TEH	TEC	560DT	27		COLD
38	55	20.83		8	SLG		TSH	+0.72	TEH	TEC	560DT	26		COLD
					NDD				TSH	TSH	560PP	36		HOT
38	56	19.82		8	SLG		TSH	+0.69	TEH	TEC	560DT	27		COLD
					NDD				TSH	TSH	560PP	34		HOT
38	57				NDD				TEH	TEC	560UL	47		COLD
					NDD				TSH	TSH	560PP	35		HOT
38	58				NDD				TEH	TEC	560UL	46		COLD
					NDD				TSH	TSH	560PP	34		HOT
38	59				NDD				TEH	TEC	560UL	46		COLD
38	60				NDD				TEH	TEC	560UL	46		COLD
38	61	3.93	184	1	DNG		06H	+4.72	TEH	TEC	560DT	34		COLD
		0.23	84	3	NQH		07C	+9.05	TEH	TEC	560DT	34		COLD
		3.04	176	P 1	DNT		05C	+0.00	TEH	TEC	560DT	34		COLD
		17.98		8	SLG		TSH	+0.54	TEH	TEC	560DT	34		COLD
38	62	20.09		8	SLG		TSH	+0.52	TEH	TEC	560DT	35		COLD
38	63				NDD				TSH	TSH	560PP	14		HOT
					NDD				TEH	TEC	560DT	34		COLD
38	64				NDD				TSH	TSH	560PP	15		HOT
		3.12	187	1	DNG		01H	+16.56	TEH	TEC	560DT	35		COLD
38	65				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	34		COLD
38	66				NDD				TSH	TSH	560PP	15		HOT
					NDD				TEH	TEC	560DT	35		COLD
38	67				NDD				TEH	TEC	560DT	37		COLD
38	68			3	NDF		08H	+0.56	08H	08H	560PP	61		HOT
				3	NDF		08H	-0.67	08H	08H	560PP	61		HOT
		5.94	174	P 1	DNT		08H	+0.56	TEH	TEC	560DT	37		COLD
				1	INF		08H	-0.67	TEH	TEC	560DT	37	HR	COLD
38	69				NDD				TEH	TEC	560UL	36		COLD
38	70				NDD				TEH	TEC	560DT	37		COLD
38	71			3	NDF		08H	+0.60	08H	08H	560PP	61		HOT
				3	NDF		08H	-0.43	08H	08H	560PP	61		HOT
				3	NDF		08H	+1.87	08H	08H	560PP	61		HOT
		3.88	173	P 1	DNT		08H	-0.52	TEH	TEC	560UL	36		COLD
		20.39	181	P 1	DNT		08H	+0.60	TEH	TEC	560UL	36		COLD
		0.68	69	3	NQS		08H	+1.87	TEH	TEC	560UL	36		COLD
					NDD				TSH	TSH	560PP	16		HOT
38	72				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	35		COLD
38	73				NDD				TSH	TSH	560PP	16		HOT
					NDD				TEH	TEC	560DT	34		COLD
38	74				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	35		COLD
38	75				NDD				TEH	TEC	560DT	34		COLD
38	76				NDD				TEH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	37		COLD
38	77				NDD				TEH	TEC	560UL	36		COLD
					NDD				TSH	TSH	560PP	16		HOT
38	78	0.38	108	3	NQH		03C	+4.41	TEH	TEC	560DT	37		COLD
38	79				NDD				TSH	TSH	560PP	16		HOT
					NDD				TEH	TEC	560DT	37		COLD
38	80				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	37		COLD
38	81				NDD				TEH	TEC	560UL	36		COLD
					NDD				TSH	TSH	560PP	16		HOT
38	82				NDD				TSH	TSH	560PP	17		HOT
					NDD				TEH	TEC	560DT	38		COLD
38	83				NDD				TEH	TEC	560DT	38		COLD
38	84				NDD				TEH	TEC	560DT	40		COLD
38	85				NDD				TEH	TEC	560UL	39		COLD
38	86	17.68		8	SLG		TSC	+0.54	TEH	TEC	560DT	40		COLD
38	87	3.35	175	P 1	DNT		08H	+0.57	TEH	TEC	560UL	39		COLD
		20.47		8	SLG		TSH	+0.61	TEH	TEC	560UL	39		COLD
		20.81		8	SLG		TSC	+0.76	TEH	TEC	560UL	39		COLD
				3	NDF		08H	+0.57	08H	08H	560PP	62		HOT
					NDD				TEH	TSH	560PP	16		HOT
38	88				NDD				TEH	TSH	560PP	17		HOT
		19.60		8	SLG		TSH	+0.56	TEH	TEC	560DT	40		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	#TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		23.70		8	SLG		TSC			560DT	40			COLD
38	89	17.10		8	SLG		TSH			560UL	39			COLD
		21.66		8	SLG		TSC			560UL	39			COLD
					NDD					560PP	16			HOT
38	90				NDD					560PP	17			HOT
		24.63		8	SLG		TSC			560DT	40			COLD
38	91	16.01		8	SLG		TSH			560UL	39			COLD
		22.44		8	SLG		TSC			560UL	39			COLD
38	92	15.05		8	SLG		TSH			560DT	40			COLD
		24.96		8	SLG		TSC			560DT	40			COLD
38	93	16.57		8	SLG		TSH			560UL	39			COLD
		23.79		8	SLG		TSC			560UL	39			COLD
38	94	21.89		8	SLG		TSH			560DT	42			COLD
38	95				NDD					560PP	18			HOT
		19.37		8	SLG		TSH			560UL	41			COLD
		23.81		8	SLG		TSC			560UL	41			COLD
		1.29	87	3	NQH		TSC			560UL	41			COLD
38	96	19.97		8	SLG		TSH			560DT	42			COLD
		25.35		8	SLG		TSC			560DT	42			COLD
					NDD					560PP	19			HOT
38	97				NDD					560PP	18			HOT
		21.71		8	SLG		TSH			560UL	41			COLD
		24.55		8	SLG		TSC			560UL	41			COLD
38	98	22.07		8	SLG		TSH			560DT	42			COLD
		25.13		8	SLG		TSC			560DT	42			COLD
		0.52	0	P 2	TWD	16	AV4			560DT	42			COLD
					NDD					560PP	19			HOT
38	99	20.03		8	SLG		TSH			560UL	41			COLD
		24.76		8	SLG		TSC			560UL	41			COLD
38	100	19.53		8	SLG		TSH			560UL	41			COLD
		22.19		8	SLG		TSC			560UL	41			COLD
38	101	15.29		8	SLG		TSH			560UL	41			COLD
38	102	16.90		8	SLG		TSC			560UL	41			COLD
38	103				NDD					560PP	20			HOT
		21.75		8	SLG		TSC			560UL	43			COLD
38	104				NDD					560PP	21			HOT
		0.64	116	3	INR		02C			560UL	71			COLD
		0.31	113	3	INR		05H			560UL	71			COLD
38	105				NDD					560PP	20			HOT
					NDD					560UL	71			COLD
38	106				RIC					560PP	108			COLD
					NDD					560PS	112			COLD
					NDD					560PP	21			HOT
				3	NDF		07H			560PP	62			HOT
				3	NDF		07H			560PP	62			HOT
		0.28	107	3	NQH		02C			560UC	70			COLD
		6.61	184	1	DNG		07H			560UC	70			COLD
38	107	0.56	83	11	PLP		01C			560PP	108			COLD
		0.41	118	3	SVI		01C			560PP	108			COLD
		0.40	103	3	PID		01C			560PS	112			COLD
		0.32	121	P 4	TWD	5	01C			560PP	108			COLD
		0.25	90	P 4	ARC		01C			560PP	108			COLD
		0.26	0	P 4	LEN		01C			560PP	108			COLD
		0.87	88	P 5	TWD	14	01C			560PP	108			COLD
		0.44	90	P 5	ARC		01C			560PP	108			COLD
		0.31	0	P 5	LEN		01C			560PP	108			COLD
					NDD					560UL	71			COLD
38	108				NDD					560PP	108			COLD
					NDD					560UC	70			COLD
39	16	3.06	180	P 1	DNT		AV2			560DT	16			COLD
		19.01		8	SLG		TSC			560DT	16			COLD
					NDD					560PP	44			HOT
39	17	19.30		8	SLG		TSC			560DT	16			COLD
					NDD					560PP	43			HOT
39	18	20.06		8	SLG		TSC			560DT	19			COLD
					NDD					560PP	42			HOT
39	19				NDD					560PP	54			HOT
		19.67		8	SLG		TSC			560DT	18			COLD
39	20	18.92		8	SLG		TSC			560DT	18			COLD
					NDD					560PP	52			HOT
39	21	18.78		8	SLG		TSC			560DT	18			COLD
					NDD					560PP	52			HOT
39	22			3	NDF		08C			560PP	108			COLD
		19.04		8	SLG		TSC			560DT	19			COLD
		7.77	176	P 1	DNT		08H			560DT	19			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		0.59	136	P 1	DSS		08C			TEH TEC	560DT	19		COLD
				3	NDF		08H			08H 08H	560PP	57		HOT
					NDD					TSH TSH	560PP	52		HOT
39	23	15.68		8	SLG		TSH			TEH TEC	560DT	18		COLD
		18.38		8	SLG		TSC			TEH TEC	560DT	18		COLD
					NDD					TSH TSH	560PP	43		HOT
39	24	16.61		8	SLG		TSH			TEH TEC	560DT	19		COLD
		18.75		8	SLG		TSC			TEH TEC	560DT	19		COLD
					NDD					TSH TSH	560PP	42		HOT
39	25	16.38		8	SLG		TSH			TEH TEC	560DT	18		COLD
		18.46		8	SLG		TSC			TEH TEC	560DT	18		COLD
					NDD					TSH TSH	560PP	43		HOT
39	26	15.34		8	SLG		TSH			TEH TEC	560DT	21		COLD
		18.43		8	SLG		TSC			TEH TEC	560DT	21		COLD
					NDD					TSH TSH	560PP	42		HOT
39	27	17.44		8	SLG		TSH			TEH TEC	560DT	20		COLD
		18.27		8	SLG		TSC			TEH TEC	560DT	20		COLD
39	28	17.25		8	SLG		TSH			TEH TEC	560DT	21		COLD
		17.77		8	SLG		TSC			TEH TEC	560DT	21		COLD
39	29	17.06		8	SLG		TSH			TEH TEC	560DT	20		COLD
		17.94		8	SLG		TSC			TEH TEC	560DT	20		COLD
39	30	16.95		8	SLG		TSH			TEH TEC	560DT	21		COLD
		18.01		8	SLG		TSC			TEH TEC	560DT	21		COLD
39	31	0.40	84	3	NQH		05H			TEH TEC	560DT	20		COLD
		17.88		8	SLG		TSH			TEH TEC	560DT	20		COLD
		17.82		8	SLG		TSC			TEH TEC	560DT	20		COLD
					RBD					TSH TSH	560PP	40		HOT
					NDD					TSH TSH	560PP	51		HOT
39	32	16.75		8	SLG		TSH			TEH TEC	560DT	21		COLD
		16.95		8	SLG		TSC			TEH TEC	560DT	21		COLD
					NDD					TSH TSH	560PP	40		HOT
39	33	17.66		8	SLG		TSH			TEH TEC	560DT	20		COLD
		15.15		8	SLG		TSC			TEH TEC	560DT	20		COLD
					NDD					TSH TSH	560PP	41		HOT
39	34				NDD					TSH TSH	560PP	40		HOT
		16.87		8	SLG		TSH			TEH TEC	560DT	21		COLD
39	35	17.80		8	SLG		TSH			TEH TEC	560DT	20		COLD
		0.53	88	3	INR		TSH			TEH TEC	560DT	20		COLD
39	36	17.83		8	SLG		TSH			TEH TEC	560DT	21		COLD
39	37	18.93		8	SLG		TSH			TEH TEC	560DT	22		COLD
39	38	18.53		8	SLG		TSH			TEH TEC	560DT	23		COLD
39	39	18.14		8	SLG		TSH			TEH TEC	560DT	22		COLD
					NDD					TSH TSH	560PP	41		HOT
39	40	5.78	180	P 1	DNT		08C			TEH TEC	560DT	23		COLD
		1.62	171	P 1	INR		08C			TEH TEC	560DT	23		COLD
		0.50	84	3	NQH		02C			TEH TEC	560DT	23		COLD
		0.55	84	3	NQH		02C			TEH TEC	560DT	23		COLD
		0.63	85	3	NQH		01C			TEH TEC	560DT	23		COLD
		18.73		8	SLG		TSH			TEH TEC	560DT	23		COLD
		0.33	74	3	INR		01C			TEH TEC	560DT	23		COLD
					NDD					TSH TSH	560PP	40		HOT
39	41	18.86		8	SLG		TSH			TEH TEC	560DT	22		COLD
		0.65	85	3	NQH		03C			TEH TEC	560DT	22		COLD
					NDD					TSH TSH	560PP	41		HOT
39	42	0.72	93	3	NQH		06H			TEH TEC	560DT	23		COLD
		0.46	72	3	NQH		03C			TEH TEC	560DT	23		COLD
		18.78		8	SLG		TSH			TEH TEC	560DT	23		COLD
					NDD					TSH TSH	560PP	40		HOT
39	43	0.68	93	3	NQH		07C			TEH TEC	560DT	22		COLD
		19.41		8	SLG		TSH			TEH TEC	560DT	22		COLD
39	44	19.44		8	SLG		TSH			TEH TEC	560DT	23		COLD
39	45	19.28		8	SLG		TSH			TEH TEC	560DT	23		COLD
39	46	19.11		8	SLG		TSH			TEH TEC	560DT	23		COLD
39	47	19.25		8	SLG		TSH			TEH TEC	560DT	22		COLD
					NDD					TSH TSH	560PP	40		HOT
39	48	19.74		8	SLG		TSH			TEH TEC	560DT	23		COLD
					NDD					TSH TSH	560PP	41		HOT
39	49	21.55		8	SLG		TSH			TEH TEC	560DT	24		COLD
					NDD					TSH TSH	560PP	36		HOT
39	50	21.28		8	SLG		TSH			TEH TEC	560DT	25		COLD
					NDD					TSH TSH	560PP	34		HOT
39	51	19.70		8	SLG		TSH			TEH TEC	560DT	24		COLD
39	52	20.91		8	SLG		TSH			TEH TEC	560DT	25		COLD
39	53	19.27		8	SLG		TSH			TEH TEC	560DT	24		COLD
39	54				NDD					TEH TEC	560UL	46		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
39	95	18.64		8	SLG		TSH	+0.53	TEH	TEC	560DT	42		COLD
		24.59		8	SLG		TSC	+0.95	TEH	TEC	560DT	42		COLD
					NDD				TSH	TSH	560PP	19		HOT
39	96				NDD				TSH	TSH	560PP	18		HOT
		16.36		8	SLG		TSH	+0.49	TEH	TEC	560UL	41		COLD
		24.92		8	SLG		TSC	+0.96	TEH	TEC	560UL	41		COLD
39	97	20.72		8	SLG		TSH	+0.56	TEH	TEC	560DT	42		COLD
		24.32		8	SLG		TSC	+0.90	TEH	TEC	560DT	42		COLD
					NDD				TSH	TSH	560PP	19		HOT
39	98				NDD				TSH	TSH	560PP	18		HOT
		22.12		8	SLG		TSH	+0.64	TEH	TEC	560UL	41		COLD
		25.25		8	SLG		TSC	+1.09	TEH	TEC	560UL	41		COLD
39	99	20.92		8	SLG		TSH	+0.99	TEH	TEC	560DT	42		COLD
		24.61		8	SLG		TSC	+1.06	TEH	TEC	560DT	42		COLD
		1.28	116	3	INR		07H	-1.45	TEH	TEC	560DT	42		COLD
39	100	21.22		8	SLG		TSH	+0.64	TEH	TEC	560UL	41		COLD
		23.59		8	SLG		TSC	+0.86	TEH	TEC	560UL	41		COLD
39	101	16.77		8	SLG		TSH	+0.51	TEH	TEC	560UL	41		COLD
		18.69		8	SLG		TSC	+0.52	TEH	TEC	560UL	41		COLD
		0.54	89	3	NQH		06C	+17.32	TEH	TEC	560UL	41		COLD
		0.35	79	3	NQH		06C	+16.72	TEH	TEC	560UL	41		COLD
39	102	17.10		8	SLG		TSH	+0.49	TEH	TEC	560UL	41		COLD
		21.01		8	SLG		TSC	+0.57	TEH	TEC	560UL	41		COLD
					NDD				TSH	TSH	560PP	21		HOT
39	103	17.30		8	SLG		TSH	+0.51	TEH	TEC	560UL	43		COLD
		23.78		8	SLG		TSC	+0.80	TEH	TEC	560UL	43		COLD
					NDD				TSH	TSH	560PP	20		HOT
					NDD				TEH	TEC	560UL	71		COLD
39	105				NDD				TSH	TSH	560PP	21		HOT
					NDD				TEH	TEC	560UC	70		COLD
39	106				NDD				01C	01C	560PP	108		COLD
					NDD				TSH	TSH	560PP	20		HOT
					NDD				TEH	TEC	560UL	71		COLD
39	107	0.89	32	3	PID		01C	+1.53	01C	01C	560PS	115		COLD
		0.55	82	11	PLP		01C	+1.36	01C	01C	560PP	108		COLD
		0.40	79	11	PLP		01C	+1.52	01C	01C	560PP	108		COLD
		0.55	58	3	SVI		01C	+1.25	01C	01C	560PP	108		COLD
		0.34	44	3	SVI		01C	+1.53	01C	01C	560PP	108		COLD
		0.65	124	P 1	LPI		01C	+0.58	TEH	TEC	560UC	70		COLD
		0.85	78	7	PLP		01C	+0.71	TEH	TEC	560UC	70		COLD
		1.06	43	P 4	TWD	17	TEH	+1.19	01C	TEH	560PP	108		COLD
		0.36	90	P 4	ARC		TEH	+1.19	01C	TEH	560PP	108		COLD
		0.33	0	P 4	LEN		TEH	+1.19	01C	TEH	560PP	108		COLD
		1.09	86	P 5	TWD	17	TEH	+1.19	01C	TEH	560PP	108		COLD
		0.41	90	P 5	ARC		01C	+1.19	01C	01C	560PP	108		COLD
		0.36	0	P 5	LEN		01C	+1.19	01C	01C	560PP	108		COLD
					NDD		01C	+1.42	01C	01C	560PP	108	#2	COLD
		0.58	80	P 5	TWD	9	01C	+1.42	01C	01C	560PP	108	#2	COLD
		0.36	90	P 5	ARC		01C	+1.42	01C	01C	560PP	108	#2	COLD
		0.24	0	P 5	LEN		01C	+1.42	01C	01C	560PP	108	#2	COLD
40	17	17.31		8	SLG		TSC	+0.52	TEH	TEC	560DT	16		COLD
					NDD				TSH	TSH	560PP	42		HOT
40	18	19.04		8	SLG		TSC	+0.62	TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	42		HOT
40	19				NDD				TSH	TSH	560PP	54		HOT
		18.96		8	SLG		TSC	+0.62	TEH	TEC	560DT	18		COLD
40	20				NDD				TEH	TEC	560UC	66		COLD
					NDD				TSH	TSH	560PP	52		HOT
40	21				NDD				TSH	TSH	560PP	53		HOT
		19.04		8	SLG		TSC	+0.62	TEH	TEC	560DT	18		COLD
40	22				NDD				TSH	TSH	560PP	53		HOT
		18.62		8	SLG		TSC	+0.62	TEH	TEC	560DT	18		COLD
40	23	19.12		8	SLG		TSC	+0.65	TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	42		HOT
40	24	18.92		8	SLG		TSC	+0.62	TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	42		HOT
40	25	15.80		8	SLG		TSH	+0.46	TEH	TEC	560DT	18		COLD
		19.18		8	SLG		TSC	+0.67	TEH	TEC	560DT	18		COLD
					NDD				TSH	TSH	560PP	42		HOT
40	26	17.80		8	SLG		TSH	+0.89	TEH	TEC	560DT	20		COLD
		19.37		8	SLG		TSC	+0.70	TEH	TEC	560DT	20		COLD
					NDD				TSH	TSH	560PP	42		HOT
40	27	5.08	174	P 1	DNT		08H	-0.49	TEH	TEC	560DT	20		COLD
		17.60		8	SLG		TSH	+0.54	TEH	TEC	560DT	20		COLD
		19.21		8	SLG		TSC	+0.65	TEH	TEC	560DT	20		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
				3	NDF		08H							HOT
40	28	17.54		8	SLG		TSH	08H	08H	560PP	57			COLD
		18.37		8	SLG		TSC	TEH	TEC	560DT	20			COLD
40	29	17.88		8	SLG		TSH	TEH	TEC	560DT	20			COLD
		18.89		8	SLG		TSC	TEH	TEC	560DT	20			COLD
40	30	18.61		8	SLG		TSH	TEH	TEC	560DT	20			COLD
		18.73		8	SLG		TSC	TEH	TEC	560DT	20			COLD
40	31				NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560DT	20			COLD
					RBD			TSH	TSH	560PP	40			HOT
					NDD			TSH	TSH	560PP	50			HOT
40	32	18.53		8	SLG		TSH	TEH	TEC	560DT	20			COLD
		18.29		8	SLG		TSC	TEH	TEC	560DT	20			COLD
					NDD			TSH	TSH	560PP	40			HOT
40	33				NDD			TSH	TSH	560PP	40			HOT
		18.00		8	SLG		TSH	TEH	TEC	560DT	20			COLD
		17.48		8	SLG		TSC	TEH	TEC	560DT	20			COLD
40	34				NDD			TSH	TSH	560PP	40			HOT
		18.11		8	SLG		TSH	TEH	TEC	560DT	20			COLD
40	35	18.00		8	SLG		TSH	TEH	TEC	560DT	20			COLD
40	36	18.21		8	SLG		TSH	TEH	TEC	560DT	20			COLD
40	37	18.64		8	SLG		TSH	TEH	TEC	560DT	22			COLD
40	38	18.04		8	SLG		TSH	TEH	TEC	560DT	22			COLD
40	39	18.78		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	40			HOT
40	40	18.66		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	40			HOT
40	41	19.17		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	40			HOT
40	42	19.25		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	40			HOT
40	43	19.31		8	SLG		TSH	TEH	TEC	560DT	22			COLD
40	44	19.15		8	SLG		TSH	TEH	TEC	560DT	22			COLD
40	45	20.51		8	SLG		TSH	TEH	TEC	560DT	22			COLD
40	46	19.17		8	SLG		TSH	TEH	TEC	560DT	22			COLD
40	47	0.42	103	3	NQH		03C	TEH	TEC	560DT	22			COLD
		20.11		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	41			HOT
40	48	3.61	187	1	DNG		02C	TEH	TEC	560DT	22			COLD
		19.11		8	SLG		TSH	TEH	TEC	560DT	22			COLD
					NDD			TSH	TSH	560PP	40			HOT
40	49	19.23		8	SLG		TSH	TEH	TEC	560DT	24			COLD
					NDD			TSH	TSH	560PP	34			HOT
40	50	18.76		8	SLG		TSH	TEH	TEC	560DT	24			COLD
					NDD			TSH	TSH	560PP	34			HOT
40	51	19.15		8	SLG		TSH	TEH	TEC	560DT	24			COLD
40	52	19.78		8	SLG		TSH	TEH	TEC	560DT	24			COLD
40	53	18.65		8	SLG		TSH	TEH	TEC	560DT	26			COLD
40	54	18.93		8	SLG		TSH	TEH	TEC	560DT	27			COLD
40	55	18.67		8	SLG		TSH	TEH	TEC	560DT	26			COLD
					INF		AV6	TEH	TEC	560DT	26	HR		COLD
		0.37	152	1	TFH		AV6	TEH	TEC	560DT	26			COLD
					NDD			TSH	TSH	560PP	36			HOT
40	56	19.07		8	SLG		TSH	TEH	TEC	560DT	27			COLD
					NDD			TSH	TSH	560PP	34			HOT
40	57				NDD			TEH	TEC	560UL	46			COLD
					NDD			TSH	TSH	560PP	35			HOT
40	58				NDD			TEH	TEC	560UL	47			COLD
					NDD			TSH	TSH	560PP	35			HOT
40	59				NDD			TEH	TEC	560UL	46			COLD
40	60				NDD			TEH	TEC	560UL	46			COLD
40	61	0.33	78	3	NQH		04C	TEH	TEC	560DT	34			COLD
		19.19		8	SLG		TSH	TEH	TEC	560DT	34			COLD
40	62	17.88		8	SLG		TSH	TEH	TEC	560DT	34			COLD
40	63				NDD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560DT	34			COLD
40	64				RBD			TSH	TSH	560PP	14			HOT
					NDD			TEH	TEC	560DT	34			COLD
					NDD			TSH	TSH	560PP	51			HOT
40	65				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	34			COLD
40	66				NDD			TSH	TSH	560PP	15			HOT
					NDD			TEH	TEC	560DT	34			COLD
40	67				NDD			TEH	TEC	560DT	34			COLD
40	68				NDD			TEH	TEC	560UL	36			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
40	69				NDD			TEH	TEC	560UL	36			COLD
40	70	5.43	187	1	DNG		04C	TEH	TEC	560UL	36			COLD
40	71				NDD			TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
40	72				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
40	73				NDD			TSH	TSH	560PP	16			HOT
		1.66	0	P 2	INR		AV6	TEH	TEC	560DT	34			COLD
40	74				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	34			COLD
40	75				NDD			TEH	TEC	560DT	34			COLD
40	76				NDD			TEH	TEC	560UL	36			COLD
40	77	0.22	76	3	NQH		05C	TEH	TEC	560UL	36			COLD
40	78				NDD			TEH	TEC	560DT	37			COLD
40	79				NDD			TSH	TSH	560PP	16			HOT
					NDD			TEH	TEC	560DT	37			COLD
40	80				NDD			TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
40	81				NDD			TEH	TEC	560UL	36			COLD
					NDD			TSH	TSH	560PP	16			HOT
40	82				NDD			TEH	TEC	560DT	38			COLD
					NDD			TSH	TSH	560PP	16			HOT
40	83				NDD			TEH	TEC	560DT	38			COLD
40	84	3.80	169	P 1	DNT		08C	TEH	TEC	560UL	39			COLD
40	85				NDD			TEH	TEC	560UL	39			COLD
40	86	18.95		8	SLG		TSH	TEH	TEC	560UL	39			COLD
		21.74		8	SLG		TSC	TEH	TEC	560UL	39			COLD
40	87	18.93		8	SLG		TSH	TEH	TEC	560UL	39			COLD
		22.74		8	SLG		TSC	TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
40	88	19.66		8	SLG		TSH	TEH	TEC	560UL	39			COLD
		22.48		8	SLG		TSC	TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
40	89	17.24		8	SLG		TSH	TEH	TEC	560UL	39			COLD
		22.04		8	SLG		TSC	TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
40	90	24.02		8	SLG		TSC	TEH	TEC	560UL	39			COLD
					NDD			TSH	TSH	560PP	16			HOT
40	91	19.32		8	SLG		TSH	TEH	TEC	560UL	39			COLD
		22.97		8	SLG		TSC	TEH	TEC	560UL	39			COLD
40	92	16.80		8	SLG		TSH	TEH	TEC	560UL	39			COLD
		24.06		8	SLG		TSC	TEH	TEC	560UL	39			COLD
40	93	15.06		8	SLG		TSH	TEH	TEC	560UL	39			COLD
		23.25		8	SLG		TSC	TEH	TEC	560UL	39			COLD
40	94				NDD			TSH	TSH	560PP	18			HOT
		16.77		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		24.94		8	SLG		TSC	TEH	TEC	560UL	41			COLD
40	95				NDD			TSH	TSH	560PP	18			HOT
		18.54		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		26.43		8	SLG		TSC	TEH	TEC	560UL	41			COLD
40	96				NDD			TSH	TSH	560PP	18			HOT
		17.08		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		24.64		8	SLG		TSC	TEH	TEC	560UL	41			COLD
		3.65	171	P 1	DNT		08C	TEH	TEC	560UL	41			COLD
40	97				NDD			TSH	TSH	560PP	18			HOT
		20.44		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		24.10		8	SLG		TSC	TEH	TEC	560UL	41			COLD
40	98				NDD			TSH	TSH	560PP	18			HOT
		20.73		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		25.79		8	SLG		TSC	TEH	TEC	560UL	41			COLD
40	99	0.99		P 2	TWD 24		AV4	TEH	TEC	560UL	41			COLD
		1.34		P 2	TWD 29		AV5	TEH	TEC	560UL	41			COLD
		20.66		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		25.89		8	SLG		TSC	TEH	TEC	560UL	41			COLD
40	100	25.21		8	SLG		TSC	TEH	TEC	560UL	41			COLD
		0.49	0	P 2	TWD 15		AV6	TEH	TEC	560UL	41			COLD
		0.55	0	P 2	TWD 16		AV5	TEH	TEC	560UL	41			COLD
		0.49	0	P 2	TWD 15		AV4	TEH	TEC	560UL	41			COLD
		22.37		8	SLG		TSH	TEH	TEC	560UL	41			COLD
40	101	19.94		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		23.77		8	SLG		TSC	TEH	TEC	560UL	41			COLD
40	102	18.40		8	SLG		TSH	TEH	TEC	560UL	41			COLD
		24.43		8	SLG		TSC	TEH	TEC	560UL	41			COLD
		0.79	0	P 2	TWD 21		AV4	TEH	TEC	560UL	41			COLD
		0.61	0	P 2	TWD 18		AV5	TEH	TEC	560UL	41			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
40	103				NDD			TSH	TSH	560PP	20			HOT
		1.04	0	P 2	TWD 23		AV2	-0.03	TEH	TEC	560UL	71		COLD
		1.18	0	P 2	TWD 26		AV3	+0.00	TEH	TEC	560UL	71		COLD
		1.66	0	P 2	TWD 32		AV4	+0.10	TEH	TEC	560UL	71		COLD
		1.36	0	P 2	TWD 28		AV5	+0.05	TEH	TEC	560UL	71		COLD
		0.68	0	P 2	TWD 16		AV6	-0.03	TEH	TEC	560UL	71		COLD
		0.40	0	P 2	INR		AV1	+0.00	TEH	TEC	560UL	71		COLD
40	104				NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	71			COLD
40	105				NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UL	71			COLD
40	106				NDD			01C	01C	560PP	108			COLD
					NDD			TSH	TSH	560PP	20			HOT
					NDD			TEH	TEC	560UC	70			COLD
41	18				NDD			TEH	TEC	560DT	3			COLD
					NDD			TSH	TSH	560PP	26			HOT
41	19				NDD			TSH	TSH	560PP	54	IDOK		HOT
					NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560UL	4			COLD
					NDD			TSH	TSH	560PP	52			HOT
41	20	15.29		8	SLG		TSC	+0.44	TSH	TSH	560PP	61		HOT
					RBD			TEH	TEC	560DT	3			COLD
					NDD			TSH	TSH	560PP	52			HOT
41	21				NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560UL	4			COLD
					NDD			TSH	TSH	560PP	52			HOT
41	22	17.46		8	SLG		TSC	+0.53	TEH	TEC	560DT	3		COLD
					NDD			TSH	TSH	560PP	52			HOT
41	23				NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560UL	4			COLD
					NDD			TSH	TSH	560PP	26			HOT
41	24	19.46		8	SLG		TSC	+0.63	TEH	TEC	560DT	3		COLD
					NDD			TSH	TSH	560PP	26			HOT
41	25				NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560UL	4			COLD
					NDD			TSH	TSH	560PP	26			HOT
41	26	19.86		8	SLG		TSC	+0.67	TEH	TEC	560UL	4		COLD
		1.60	0	P 2	TWD 32		AV6	-0.27	TEH	TEC	560UL	4		COLD
		1.61	0	P 2	TWD 32		AV5	-0.16	TEH	TEC	560UL	4		COLD
		0.46	0	P 2	TWD 13		AV2	+0.03	TEH	TEC	560UL	4		COLD
					NDD			TSH	TSH	560PP	26			HOT
41	27	18.17		8	SLG		TSC	+0.59	TEH	TEC	560UL	4		COLD
41	28	16.94		8	SLG		TSC	+0.53	TEH	TEC	560UL	4		COLD
41	29	17.18		8	SLG		TSC	+0.50	TEH	TEC	560UL	4		COLD
41	30	16.89		8	SLG		TSC	+0.53	TEH	TEC	560DT	6		COLD
		0.61	0	P 2	TWD 16		AV5	+0.00	TEH	TEC	560DT	6		COLD
		0.69	0	P 2	TWD 18		AV4	+0.08	TEH	TEC	560DT	6		COLD
41	31	16.41		8	SLG		TSC	+0.50	TEH	TEC	560DT	6		COLD
		1.54	115	3	INR		07C	+22.29	TEH	TEC	560DT	6		COLD
		0.56	0	P 2	TWD 15		AV2	+0.16	TEH	TEC	560DT	6		COLD
					NDD			TSH	TSH	560PP	28			HOT
41	32	15.37		8	SLG		TSC	+0.44	TEH	TEC	560DT	6		COLD
					NDD			TSH	TSH	560PP	28			HOT
41	33				NDD			TEH	TEC	560DT	6			COLD
					NDD			TSH	TSH	560PP	28			HOT
41	34				NDD			TEH	TEC	560DT	5			COLD
					NDD			TEH	TEC	560DT	6			COLD
41	35				NDD			TEH	TEC	560DT	6			COLD
41	36				NDD			TEH	TEC	560DT	6			COLD
41	37				NDD			TEH	TEC	560DT	6			COLD
41	38				NDD			TEH	TEC	560DT	5			COLD
41	39				NDD			TSH	TSH	560PP	28			HOT
		0.44		P 2	TWD 13		AV2	+0.08	TEH	TEC	560DT	5		COLD
		0.82		P 2	TWD 22		AV3	+0.28	TEH	TEC	560DT	5		COLD
		0.92		P 2	TWD 23		AV4	+0.19	TEH	TEC	560DT	5		COLD
		1.25		P 2	TWD 29		AV5	-0.03	TEH	TEC	560DT	5		COLD
41	40				NDD			TSH	TSH	560PP	28			HOT
					NDD			TEH	TEC	560DT	5			COLD
41	41				NDD			TSH	TSH	560PP	28			HOT
					NDD			TEH	TEC	560DT	5			COLD
41	42				NDD			TSH	TSH	560PP	28			HOT
					NDD			TEH	TEC	560DT	7			COLD
41	43				NDD			TEH	TEC	560DT	7			COLD
41	44				NDD			TEH	TEC	560DT	7			COLD
41	45				NDD			TEH	TEC	560DT	7			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
41	46				NDD			TEH	TEC	560DT	7			COLD
41	47				NDD			TSH	TSH	560PP	30			HOT
					NDD			TEH	TEC	560DT	7			COLD
41	48				NDD			TSH	TSH	560PP	30			HOT
					NDD			TEH	TEC	560DT	7			COLD
41	49				NDD			TSH	TSH	560PP	30			HOT
					NDD			TEH	TEC	560DT	7			COLD
41	50				NDD			TSH	TSH	560PP	30			HOT
					NDD			TEH	TEC	560DT	7			COLD
41	52				NDD			TEH	TEC	560DT	7			COLD
41	53				NDD			TEH	TEC	560DT	7			COLD
41	54				NDD			TEH	TEC	560DT	7			COLD
41	55				NDD			TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	30			HOT
41	56				NDD			TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	30			HOT
41	57	1.47	105	2	VOL		AV3	AV3	AV5	5201P	111			COLD
		0.84	121	2	VOL		AV4	AV3	AV5	5201P	111			COLD
		0.44	90	2	VOL		AV4	AV3	AV5	5201P	111			COLD
		1.17	106	2	VOL		AV5	AV3	AV5	5201P	111			COLD
		0.30	76	2	VOL		AV5	AV3	AV5	5201P	111			COLD
		0.56	0	P 2	TWD	16	AV6	TEH	TEC	560DT	7			COLD
		2.42	0	P 2	TWD	40	AV5	TEH	TEC	560DT	7			COLD
		1.46	0	P 2	TWD	31	AV4	TEH	TEC	560DT	7			COLD
		3.19	0	P 2	TWD	45	AV3	TEH	TEC	560DT	7			COLD
		1.33	0	P 2	TWD	29	AV2	TEH	TEC	560DT	7			COLD
		0.56	0	P 2	TWD	16	AV1	TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	30			HOT
		2.72	0	P 2	PID		AV5	TEH	TEC	560UL	46			COLD
41	58				NDD			TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	30			HOT
41	59				NDD			TEH	TEC	560DT	7			COLD
41	60				NDD			TEH	TEC	560DT	7			COLD
41	61				NDD			TEH	TEC	560DT	9			COLD
41	62				NDD			TEH	TEC	560DT	9			COLD
41	63				NDD			TSH	TSH	560PP	50			HOT
					NDD			TEH	TEC	560DT	9			COLD
41	64				NDD			TEH	TEC	560DT	9			COLD
					NDD			TSH	TSH	560PP	50			HOT
41	65				NDD			TSH	TSH	560PP	23			HOT
					NDD			TEH	TEC	560DT	9			COLD
41	66				NDD			TSH	TSH	560PP	23			HOT
					NDD			TEH	TEC	560DT	9			COLD
41	67				NDD			TEH	TEC	560DT	9			COLD
41	68	1.53	171	1	INR		08H	TEH	TEC	560DT	9			COLD
				2	NDF		08H	AV1	08H	5201P	72			HOT
41	69				NDD			TEH	TEC	560DT	9			COLD
41	70				NDD			TEH	TEC	560DT	9			COLD
41	71				NDD			TSH	TSH	560PP	23			HOT
				3	NDF		08H	08H	08H	560PP	60			HOT
				3	NDF		08H	08H	08H	560PP	60			HOT
		6.84	181	P 1	DNT		08H	TEH	TEC	560DT	9			COLD
		0.36	116	3	NQH		08H	TEH	TEC	560DT	9			COLD
		0.36	113	3	INR		05H	TEH	TEC	560DT	9			COLD
41	72				NDD			TSH	TSH	560PP	23			HOT
					NDD			TEH	TEC	560DT	9			COLD
41	73				NDD			TSH	TSH	560PP	23			HOT
					NDD			TEH	TEC	560DT	9			COLD
41	74				NDD			TSH	TSH	560PP	23			HOT
		16.28		8	SLG		TSH	TEH	TEC	560DT	11			COLD
		15.27		8	SLG		TSC	TEH	TEC	560DT	11			COLD
41	75	16.68		8	SLG		TSH	TEH	TEC	560DT	11			COLD
		16.30		8	SLG		TSC	TEH	TEC	560DT	11			COLD
41	76	17.89		8	SLG		TSH	TEH	TEC	560DT	11			COLD
		16.12		8	SLG		TSC	TEH	TEC	560DT	11			COLD
41	77	3.86	175	P 1	DNT		08H	TEH	TEC	560DT	11			COLD
		12.21	185	P 1	DNT		08H	TEH	TEC	560DT	11			COLD
		17.52		8	SLG		TSH	TEH	TEC	560DT	11			COLD
		17.18		8	SLG		TSC	TEH	TEC	560DT	11			COLD
				3	NDF		08H	08H	08H	560PP	58			HOT
				3	NDF		08H	08H	08H	560PP	58			HOT
41	78	0.60		P 2	TWD	12	AV3	TEH	TEC	560DT	11			COLD
		17.66		8	SLG		TSH	TEH	TEC	560DT	11			COLD
		18.01		8	SLG		TSC	TEH	TEC	560DT	11			COLD
		0.56		P 2	TWD	11	AV5	TEH	TEC	560DT	11			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
41	79	0.75	0	P 2	TWD	18	AV4							
					RBD			TEH	TEC	560DT	11			COLD
					NDD			TSH	TSH	560PP	23			HOT
					NDD			TSH	TSH	560PS	90			HOT
		17.22		8	SLG		TSH	TEH	TEC	560DT	11			COLD
		17.79		8	SLG		TSC	TEH	TEC	560DT	11			COLD
		0.34	104	1	TFH		08H	TEH	TEC	560DT	11			COLD
				2	NDF		08H	AV1	08H	5201P	72			HOT
41	80				RBD			TSH	TSH	560PP	23			HOT
					NDD			TSH	TSH	560PS	90			HOT
		16.80		8	SLG		TSH	TEH	TEC	560DT	11			COLD
		18.41		8	SLG		TSC	TEH	TEC	560DT	11			COLD
41	81				NDD			TSH	TSH	560PP	26			HOT
		16.36		8	SLG		TSH	TEH	TEC	560DT	11			COLD
		18.83		8	SLG		TSC	TEH	TEC	560DT	11			COLD
41	82				NDD			TSH	TSH	560PP	26			HOT
		17.23		8	SLG		TSH	TEH	TEC	560DT	14			COLD
		18.96		8	SLG		TSC	TEH	TEC	560DT	14			COLD
41	83	16.25		8	SLG		TSH	TEH	TEC	560DT	14			COLD
		19.40		8	SLG		TSC	TEH	TEC	560DT	14			COLD
41	84	15.69		8	SLG		TSH	TEH	TEC	560DT	14			COLD
		19.10		8	SLG		TSC	TEH	TEC	560DT	14			COLD
41	85	15.49		8	SLG		TSH	TEH	TEC	560DT	14			COLD
		19.66		8	SLG		TSC	TEH	TEC	560DT	14			COLD
41	86	20.16		8	SLG		TSC	TEH	TEC	560DT	14			COLD
41	87	15.63		8	SLG		TSH	TEH	TEC	560DT	14			COLD
		21.02		8	SLG		TSC	TEH	TEC	560DT	14			COLD
					NDD			TSH	TSH	560PP	26			HOT
41	88	20.76		8	SLG		TSC	TEH	TEC	560DT	14			COLD
		3.12	174	P 1	DNT		08H	TEH	TEC	560DT	14			COLD
				3	NDF		08H	08H	08H	560PP	68			HOT
					NDD			TSH	TSH	560PP	26			HOT
41	89	21.20		8	SLG		TSC	TEH	TEC	560DT	14			COLD
					NDD			TSH	TSH	560PP	26			HOT
41	90	0.50		P 2	TWD	15	AV1	TEH	TEC	560DT	14			COLD
		22.18		8	SLG		TSC	TEH	TEC	560DT	14			COLD
					NDD			TSH	TSH	560PP	26			HOT
41	91	21.40		8	SLG		TSC	TEH	TEC	560DT	14			COLD
41	92				NDD			TEH	TEC	560DT	14			COLD
41	93	22.08		8	SLG		TSC	TEH	TEC	560DT	14			COLD
41	94	21.40		8	SLG		TSC	TEH	TEC	560DT	14			COLD
41	95	21.46		8	SLG		TSC	TEH	TEC	560DT	14			COLD
					NDD			TSH	TSH	560PP	26			HOT
41	96	21.44		8	SLG		TSC	TEH	TEC	560DT	14			COLD
		0.77	161	1	TFH		08H	TEH	TEC	560DT	14			COLD
					NDD			TSH	TSH	560PP	26			HOT
				2	NDF		08H	AV1	08H	5201P	72			HOT
41	97	21.16		8	SLG		TSC	TEH	TEC	560DT	14			COLD
					NDD			TEH	TSH	560PP	26			HOT
41	98	20.74		8	SLG		TSC	TEH	TEC	560DT	14			COLD
		0.89	159	1	TFH		08H	TEH	TEC	560DT	14			COLD
					NDD			TSH	TSH	560PP	26			HOT
				2	NDF		08H	AV1	08H	5201P	72			HOT
41	99	20.14		8	SLG		TSC	TEH	TEC	560DT	14			COLD
41	100	20.83		8	SLG		TSH	TEH	TEC	560UL	46			COLD
		24.53		8	SLG		TSC	TEH	TEC	560UL	46			COLD
41	101	1.04	163	1	INR		08H	TEH	TEC	560UL	46			COLD
		19.37		8	SLG		TSH	TEH	TEC	560UL	46			COLD
		24.99		8	SLG		TSC	TEH	TEC	560UL	46			COLD
41	102				NDD			TEH	TEC	560UL	71			COLD
41	103				NDD			TEH	TEC	560UC	70			COLD
					NDD			TSH	TSH	560PP	26			HOT
41	104				NDD			TEH	TEC	560UL	71			COLD
					NDD			TSH	TSH	560PP	26			HOT
41	105				NDD			TSH	TSH	560PP	27			HOT
					NDD			TEH	TEC	560UC	70			COLD
42	19				NDD			TEH	TEC	560DT	3			COLD
					NDD			TSH	TSH	560PP	52			HOT
42	20				NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560UL	4			COLD
					NDD			TSH	TSH	560PP	52			HOT
42	21				NDD			TSH	TSH	560PP	53			HOT
		0.65	111	3	INR		03C	TEH	TEC	560DT	3			COLD
		16.32		8	SLG		TSC	TEH	TEC	560DT	3			COLD
42	22				NDD			TSH	TSH	560PP	53			HOT
					NDD			TEH	TEC	560UL	46			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					RBD			TEH	TEC	560UL	4			COLD
42	23	0.90	0	P 5	TWD	14	TSH	+0.13						HOT
		0.39	90	P 5	ARC		TSH	+0.13			52	SVI		HOT
		0.32	0	P 5	LEN		TSH	+0.13			52			HOT
		0.78	0	P 4	TWD	15	TSH	+0.10			52	SVI		HOT
		0.29	90	P 4	ARC		TSH	+0.10			52			HOT
		0.29	0	P 4	LEN		TSH	+0.10			52			HOT
		19.78			SLG		TSC	+0.64			3			COLD
		0.28	75	3	PID		TSH	+0.16			52			HOT
		0.34	73	3	SVI		TSH	+0.16			26			HOT
		0.32	71	3	PID		TSH	+0.16			50			HOT
42	24				NDD						46			COLD
					RBD						4			COLD
					NDD						26			HOT
42	25	20.55		8	SLG		TSC	+0.72			3			COLD
					NDD						26			HOT
42	26	20.49		8	SLG		TSC	+0.66			3			COLD
					NDD						26			HOT
42	27	20.03		8	SLG		TSC	+0.66			3			COLD
42	28	1.24	76	6	INR		04C	+24.63			3			COLD
		19.22		8	SLG		TSC	+0.61			3			COLD
42	29	19.08		8	SLG		TSC	+0.61			3			COLD
42	30	19.16		8	SLG		TSC	+0.61			5			COLD
42	31				NDD						28			HOT
		18.14		8	SLG		TSC	+0.55			5			COLD
42	32				NDD						28			HOT
		16.32		8	SLG		TSC	+0.50			5			COLD
42	33				NDD						28			HOT
					NDD						5			COLD
42	34				NDD						6			COLD
					NDD						28			HOT
42	35				NDD						5			COLD
42	36				NDD						5			COLD
42	37				NDD						5			COLD
42	38				NDD						5			COLD
42	39				NDD						6			COLD
					NDD						28			HOT
42	40				NDD						28			HOT
					NDD						5			COLD
42	41	3.22	169	P 1	DDH		08H	-0.58			6			COLD
		9.14	181	P 1	DNT		08H	+0.49			6			COLD
					NDD						28			HOT
				3	NDF		08H	+0.49			57			HOT
				3	NDF		08H	-0.58			57			HOT
42	42				NDD						28			HOT
					NDD						7			COLD
42	43				NDD						8			COLD
42	44				NDD						7			COLD
42	45				NDD						8			COLD
42	46				NDD						7			COLD
42	47				NDD						31			HOT
					NDD						8			COLD
42	48				NDD						31			HOT
					NDD						7			COLD
42	49				NDD						31			HOT
					NDD						8			COLD
42	50				NDD						31			HOT
					NDD						7			COLD
42	51				NDD						7			COLD
42	52				NDD						7			COLD
42	53				NDD						8			COLD
42	54				NDD						7			COLD
42	55				NDD						30			HOT
		0.78	97	3	NQH		02C	+13.26			8			COLD
42	56				NDD						7			COLD
					NDD						31			HOT
42	57				NDD						30			HOT
					NDD						8			COLD
42	58				NDD						7			COLD
					NDD						31			HOT
42	59				NDD						8			COLD
42	60				NDD						7			COLD
42	61				NDD						10			COLD
42	62				NDD						9			COLD
42	63				NDD						23			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
42	64				NDD			TEH	TEC	560DT	10			COLD
					NDD			TEH	TEC	560DT	9			COLD
					NDD			TSH	TSH	560PP	51			HOT
42	65				NDD			TSH	TSH	560PP	23			HOT
					NDD			TEH	TEC	560DT	10			COLD
42	66				NDD			TSH	TSH	560PP	24			HOT
					NDD			TEH	TEC	560DT	9			COLD
42	67				NDD			TEH	TEC	560DT	10			COLD
42	68				NDD			TEH	TEC	560DT	9			COLD
42	69				NDD			TEH	TEC	560DT	10			COLD
42	70				NDD			TEH	TEC	560DT	9			COLD
42	71				NDD			TSH	TSH	560PP	23			HOT
					NDD			TEH	TEC	560DT	10			COLD
42	72				NDD			TSH	TSH	560PP	24			HOT
					NDD			TEH	TEC	560DT	9			COLD
42	73				NDD			TSH	TSH	560PP	23			HOT
	15.47			8	SLG		TSC	TEH	TEC	560DT	10			COLD
42	74				NDD			TSH	TSH	560PP	24			HOT
	16.48			8	SLG		TSH	TEH	TEC	560DT	11			COLD
	17.22			8	SLG		TSC	TEH	TEC	560DT	11			COLD
42	75				8	SLG	TSH	TEH	TEC	560DT	12			COLD
	15.53			8	SLG		TSC	TEH	TEC	560DT	12			COLD
	17.87			8	SLG		TSC	TEH	TEC	560DT	12			COLD
42	76				8	SLG	TSH	TEH	TEC	560DT	11			COLD
	18.11			8	SLG		TSC	TEH	TEC	560DT	11			COLD
	18.41			8	SLG		TSC	TEH	TEC	560DT	11			COLD
42	77				8	SLG	TSH	TEH	TEC	560DT	12			COLD
	18.06			8	SLG		TSC	TEH	TEC	560DT	12			COLD
	19.59			8	SLG		TSC	TEH	TEC	560DT	12			COLD
42	78				8	SLG	TSH	TEH	TEC	560DT	11			COLD
	17.93			8	SLG		TSC	TEH	TEC	560DT	11			COLD
	18.77			8	SLG		TSC	TEH	TEC	560DT	11			COLD
42	79				RBD			TSH	TSH	560PP	23			HOT
					NDD			TSH	TSH	560PS	90			HOT
	18.38			8	SLG		TSH	TEH	TEC	560DT	12			COLD
	20.07			8	SLG		TSC	TEH	TEC	560DT	12			COLD
42	80				NDD			TSH	TSH	560PP	24			HOT
	17.83			8	SLG		TSH	TEH	TEC	560DT	11			COLD
	20.16			8	SLG		TSC	TEH	TEC	560DT	11			COLD
42	81				NDD			TSH	TSH	560PP	26			HOT
	18.54			8	SLG		TSH	TEH	TEC	560DT	12			COLD
	20.78			8	SLG		TSC	TEH	TEC	560DT	12			COLD
42	82				NDD			TSH	TSH	560PP	27			HOT
	17.40			8	SLG		TSH	TEH	TEC	560DT	11			COLD
	20.14			8	SLG		TSC	TEH	TEC	560DT	11			COLD
42	83				8	SLG	TSH	TEH	TEC	560DT	15			COLD
	18.13			8	SLG		TSC	TEH	TEC	560DT	15			COLD
	20.99			8	SLG		TSC	TEH	TEC	560DT	15			COLD
42	84				8	SLG	TSH	TEH	TEC	560DT	14			COLD
	17.11			8	SLG		TSC	TEH	TEC	560DT	14			COLD
	20.38			8	SLG		TSC	TEH	TEC	560DT	14			COLD
42	85				8	SLG	TSH	TEH	TEC	560DT	15			COLD
	16.88			8	SLG		TSC	TEH	TEC	560DT	15			COLD
	21.19			8	SLG		TSC	TEH	TEC	560DT	15			COLD
	0.77			96	6	INR	03H	TEH	TEC	560DT	15			COLD
42	86				8	SLG	TSH	TEH	TEC	560DT	14			COLD
	16.27			8	SLG		TSC	TEH	TEC	560DT	14			COLD
	21.08			8	SLG		TSC	TEH	TEC	560DT	14			COLD
42	87				NDD			TSH	TSH	560PP	26			HOT
	16.56			8	SLG		TSH	TEH	TEC	560DT	15			COLD
	22.13			8	SLG		TSC	TEH	TEC	560DT	15			COLD
42	88				NDD			TSH	TSH	560PP	27			HOT
	16.29			8	SLG		TSH	TEH	TEC	560DT	14			COLD
	21.82			8	SLG		TSC	TEH	TEC	560DT	14			COLD
42	89				8	SLG	TSH	TEH	TEC	560DT	15			COLD
	15.73			8	SLG		TSC	TEH	TEC	560DT	15			COLD
	22.80			8	SLG		TSC	TEH	TEC	560DT	15			COLD
	0.50			107	P 1	DSS	08C	TEH	TEC	560DT	15			COLD
				3	NDF		08C	08C	08C	560PS	112			COLD
					NDD			TSH	TSH	560PP	26			HOT
42	90				NDD			TSH	TSH	560PP	27			HOT
	22.28			8	SLG		TSC	TEH	TEC	560DT	14			COLD
42	91				8	SLG	TSC	TEH	TEC	560DT	15			COLD
	23.34			8	SLG		TSC	TEH	TEC	560DT	15			COLD
42	92				8	SLG	TSC	TEH	TEC	560DT	14			COLD
	22.78			8	SLG		TSC	TEH	TEC	560DT	14			COLD
42	93				8	SLG	TSC	TEH	TEC	560DT	15			COLD
	23.02			8	SLG		TSC	TEH	TEC	560DT	15			COLD
42	94				8	SLG	TSC	TEH	TEC	560DT	14			COLD
	22.88			8	SLG		TSC	TEH	TEC	560DT	14			COLD
42	95				8	SLG	TSC	TEH	TEC	560DT	15			COLD
	23.73			8	SLG		TSC	TEH	TEC	560DT	15			COLD
42	96				0	P 2	PID	TEH	TEC	560UL	106			COLD
					NDD			TSH	TSH	560PP	27			HOT
	2.04				P 2	TWD	38	TEH	TEC	560DT	14			COLD
	22.32			8	SLG		TSC	TEH	TEC	560DT	14			COLD
	0.57				P 2	TWD	16	TEH	TEC	560DT	14			COLD
42	97				8	SLG	TSC	TEH	TEC	560DT	15			COLD
	22.94			8	SLG		TSC	TEH	TEC	560DT	15			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					NDD			TSH	TSH	560PP	26			HOT
42	98				NDD			TSH	TSH	560PP	27			HOT
		21.88		8	SLG		TSC	TEH	TEC	560DT	14			COLD
42	99	21.53		8	SLG		TSC	TEH	TEC	560DT	15			COLD
42	101	1.68		103	2		AV5	AV5	AV6	5201P	111			COLD
		0.60		134	2		VOL	AV5	AV6	5201P	111			COLD
		1.26		105	2		VOL	AV2	AV2	5201P	75			HOT
		2.48		0	P 2		TWD 40	TEH	TEC	560UL	47			COLD
		0.38		0	P 2		TWD 12	TEH	TEC	560UL	47			COLD
		1.41		0	P 2		TWD 31	TEH	TEC	560UL	47			COLD
		3.85		0	P 2		TWD 47	TEH	TEC	560UL	47			COLD
		0.56		0	P 2		TWD 17	TEH	TEC	560UL	47			COLD
		21.11		8	SLG		TSH	TEH	TEC	560UL	47			COLD
		27.27		8	SLG		TSC	TEH	TEC	560UL	47			COLD
		3.66		0	P 2		PID	TEH	TEC	560UL	71			COLD
42	102	1.14		104	2		VOL	AV4	AV5	5201P	111			COLD
		0.87		110	2		VOL	AV4	AV5	5201P	111			COLD
		0.96			P 2		TWD 20	TEH	TEC	560UL	71			COLD
		0.98			P 2		TWD 20	TEH	TEC	560UL	71			COLD
		2.85			P 2		TWD 42	TEH	TEC	560UL	71			COLD
		1.43			P 2		TWD 28	TEH	TEC	560UL	71			COLD
		0.82			P 2		TWD 17	TEH	TEC	560UL	71			COLD
		2.68		0	P 2		PID	TEH	TEC	560UC	82			COLD
42	103						RID	TEH	TEH	4701C	83			HOT
							NDD	TEH	TEC	560UL	71			COLD
42	104	6.61		185	1		DNG	TEH	TEC	560UC	70	OK		COLD
43	20						NDD	TSH	TSH	560PP	61			HOT
							NDD	TEH	TEC	560DT	3			COLD
							RBD	TSH	TSH	560PP	52			HOT
43	21	15.68		8	SLG		TSC	TEH	TEC	560DT	3			COLD
							NDD	TSH	TSH	560PP	52			HOT
43	22	16.57		8	SLG		TSC	TEH	TEC	560DT	3			COLD
							NDD	TSH	TSH	560PP	52			HOT
43	23	0.38		0	P 5		TWD 7	TSH	TSH	560PP	53	SVI		HOT
		0.35		90	P 5		ARC	TSH	TSH	560PP	53			HOT
		0.19		0	P 5		LEN	TSH	TSH	560PP	53			HOT
		0.67		0	P 4		TWD 12	TSH	TSH	560PP	53	SVI		HOT
		0.35		90	P 4		ARC	TSH	TSH	560PP	53			HOT
		0.28		0	P 4		LEN	TSH	TSH	560PP	53			HOT
		0.10		83	3		PID	TSH	TSH	560PP	53			HOT
		1.66		105	2		VOL	AV5	AV6	5201P	111			COLD
		0.55		130	2		VOL	AV5	AV6	5201P	111			COLD
		0.38		0	P 2		TWD 10	TEH	TEC	560UL	46			COLD
		2.93		0	P 2		TWD 43	TEH	TEC	560UL	46			COLD
		0.66		0	P 2		TWD 17	TEH	TEC	560UL	46			COLD
		1.84		0	P 2		TWD 34	TEH	TEC	560UL	46			COLD
		3.14		0	P 2		PID	TEH	TEC	560UC	66			COLD
							RBD	TEH	TEC	560UL	4			COLD
		0.15		92	3		SVI	TSH	TSH	560PP	26			HOT
		0.12		95	3		PID	TSH	TSH	560PP	51			HOT
43	24	0.55		0	P 5		TWD 9	TSH	TSH	560PP	52	SVI		HOT
		0.36		90	P 5		ARC	TSH	TSH	560PP	52			HOT
		0.24		0	P 5		LEN	TSH	TSH	560PP	52			HOT
					P 4		NDD	TSH	TSH	560PP	52			HOT
		19.44		8	SLG		TSC	TEH	TEC	560DT	3			COLD
		0.18		75	3		PID	TSH	TSH	560PP	52			HOT
		0.19		70	3		SVI	TSH	TSH	560PP	26			HOT
		0.17		77	3		PID	TSH	TSH	560PP	50			HOT
43	25						NDD	TEH	TEC	560UL	46			COLD
							RBD	TEH	TEC	560UL	4			COLD
							NDD	TSH	TSH	560PP	26			HOT
43	26	5.97		180	P 1		DNT	TEH	TEC	560UL	4			COLD
		20.74		8	SLG		TSC	TEH	TEC	560UL	4			COLD
							NDD	TSH	TSH	560PP	26			HOT
43	27	21.14		8	SLG		TSC	TEH	TEC	560UL	4			COLD
43	28	21.37		8	SLG		TSC	TEH	TEC	560UL	4			COLD
43	29	20.78		8	SLG		TSC	TEH	TEC	560UL	4			COLD
43	30	20.28		8	SLG		TSC	TEH	TEC	560DT	6			COLD
43	31	20.54		8	SLG		TSC	TEH	TEC	560DT	6			COLD
							NDD	TSH	TSH	560PP	28			HOT
43	32			3	NDF		O8C	O8C	O8C	560PP	108			COLD
		18.89		8	SLG		TSC	TEH	TEC	560DT	6			COLD
		0.27		113	P 1		DSS	TEH	TEC	560DT	6			COLD
							NDD	TSH	TSH	560PP	28			HOT
43	33	16.43		8	SLG		TSC	TEH	TEC	560DT	6			COLD

Master Report

QUERY: QueryMi

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					NDD			TSH	TSH	560PP	28			HOT
43	34				NDD			TSH	TSH	560PP	28			HOT
					NDD			TEH	TEC	560DT	5			COLD
43	35	13.30	182	P 1	DNT		08H	+0.52	TEH	TEC	560DT	6		COLD
		4.48	161	P 1	DDH		08H	-0.42	TEH	TEC	560DT	6		COLD
				3	NDF		08H	+0.52	08H	08H	560PP	57		HOT
				3	NDF		08H	-0.42	08H	08H	560PP	57		HOT
43	36				NDD			TEH	TEC	560DT	6			COLD
43	37				NDD			TEH	TEC	560DT	6			COLD
43	38				NDD			TEH	TEC	560DT	5			COLD
43	39				NDD			TSH	TSH	560PP	28			HOT
					NDD			TEH	TEC	560DT	5			COLD
43	40				NDD			TEH	TEC	560DT	6			COLD
					NDD			TSH	TSH	560PP	28			HOT
43	41				NDD			TSH	TSH	560PP	28			HOT
		12.37	182	P 1	DNT		08H	+0.66	TEH	TEC	560DT	5		COLD
		4.84	171	P 1	DNT		08H	-0.56	TEH	TEC	560DT	5		COLD
				3	NDF		08H	+0.66	08H	08H	560PP	57		HOT
				3	NDF		08H	-0.56	08H	08H	560PP	57		HOT
43	43				NDD			TEH	TEC	560DT	7			COLD
43	44				NDD			TEH	TEC	560DT	8			COLD
43	45				NDD			TEH	TEC	560DT	7			COLD
43	46				NDD			TEH	TEC	560DT	7			COLD
43	47				NDD			TSH	TSH	560PP	30			HOT
					NDD			TEH	TEC	560DT	7			COLD
43	48				NDD			TSH	TSH	560PP	30			HOT
					NDD			TEH	TEC	560DT	7			COLD
43	49				NDD			TSH	TSH	560PP	30			HOT
					NDD			TEH	TEC	560DT	7			COLD
43	50				NDD			TSH	TSH	560PP	30			HOT
					NDD			TEH	TEC	560DT	7			COLD
43	51				NDD			TEH	TEC	560DT	8			COLD
43	52				NDD			TEH	TEC	560DT	7			COLD
43	53				NDD			TEH	TEC	560DT	7			COLD
43	54				NDD			TEH	TEC	560DT	7			COLD
43	55				NDD			TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	31			HOT
43	56				NDD			TSH	TSH	560PP	30			HOT
					NDD			TEH	TEC	560DT	8			COLD
43	57				NDD			TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	31			HOT
43	58				NDD			TSH	TSH	560PP	30			HOT
		0.57	0	P 2	TWD	15	AV5	+0.15	TEH	TEC	560DT	8		COLD
		0.85	0	P 2	TWD	21	AV6	-0.31	TEH	TEC	560DT	8		COLD
		1.87	0	P 2	TWD	34	AV4	-0.03	TEH	TEC	560DT	8		COLD
		0.48	0	P 2	TWD	14	AV3	+0.03	TEH	TEC	560DT	8		COLD
		0.42		P 2	TWD	11	AV2	+0.28	TEH	TEC	560DT	8		COLD
43	59				NDD			TEH	TEC	560DT	7			COLD
43	60	4.39	183	1	DNG		08H	+4.30	TEH	TEC	560DT	8		COLD
		0.43	99	3	NQH		TSC	+11.90	TEH	TEC	560DT	8		COLD
43	61	4.05	190	1	DNG		08H	+11.77	TEH	TEC	560DT	9		COLD
43	62				NDD			TEH	TEC	560DT	10			COLD
43	63				NDD			TSH	TSH	560PP	23			HOT
					NDD			TEH	TEC	560DT	9			COLD
43	64				NDD			TEH	TEC	560DT	10			COLD
					NDD			TSH	TSH	560PP	51			HOT
43	65				NDD			TSH	TSH	560PP	24			HOT
					NDD			TEH	TEC	560DT	9			COLD
43	66				NDD			TSH	TSH	560PP	23			HOT
					NDD			TEH	TEC	560DT	10			COLD
43	67	15.41		8	SLG		TSC	+0.44	TEH	TEC	560DT	9		COLD
43	68	17.50		8	SLG		TSC	+0.54	TEH	TEC	560DT	10		COLD
43	69	1.22	109	2	VOL		AV4	+0.01	AV4	AV5	5201P	111		COLD
		0.88	114	2	VOL		AV5	+0.04	AV4	AV5	5201P	111		COLD
		1.84	77	2	VOL		AV3	+0.01	AV3	AV3	5201P	75		HOT
		2.14	0	P 2	PID		AV4	+0.10	TEH	TEC	560UL	46		COLD
		0.82	0	P 2	TWD	24	AV2	+0.00	TEH	TEC	560DT	9		COLD
		2.93	0	P 2	TWD	45	AV3	+0.00	TEH	TEC	560DT	9		COLD
		2.04	0	P 2	TWD	40	AV4	+0.10	TEH	TEC	560DT	9		COLD
		1.22	0	P 2	TWD	31	AV5	+0.00	TEH	TEC	560DT	9		COLD
		17.56		8	SLG		TSC	+0.52	TEH	TEC	560DT	9		COLD
43	70	17.52		8	SLG		TSC	+0.52	TEH	TEC	560DT	9		COLD
43	71				NDD			TSH	TSH	560PP	23			HOT
				3	NDF		TSH	+3.60	TSH	TSH	560PP	60		HOT
		17.84		8	SLG		TSC	+0.55	TEH	TEC	560DT	9		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
43	72				NDD			TSH	TSH	560PP	23			HOT
		17.00		8	SLG	TSC	+0.49	TEH	TEC	560DT	9			COLD
43	73				NDD			TSH	TSH	560PP	23			HOT
		16.88		8	SLG	TSC	+0.50	TEH	TEC	560DT	9			COLD
43	74				NDD			TSH	TSH	560PP	23			HOT
		16.98		8	SLG	TSH	+0.50	TEH	TEC	560DT	11			COLD
		21.31		8	SLG	TSC	+0.74	TEH	TEC	560DT	11			COLD
43	75				NDD			TSH	TSH	560PP	23			HOT
		0.62		P 2	TWD 15	AV6	-0.05	TEH	TEC	560DT	11			COLD
		0.64		P 2	TWD 14	AV2	+0.00	TEH	TEC	560DT	11			COLD
		0.84		P 2	TWD 21	AV3	+0.26	TEH	TEC	560DT	11			COLD
		1.37		P 2	TWD 32	AV4	+0.03	TEH	TEC	560DT	11			COLD
		1.54		P 2	TWD 34	AV5	+0.13	TEH	TEC	560DT	11			COLD
		16.54		8	SLG	TSH	+0.48	TEH	TEC	560DT	11			COLD
		19.74		8	SLG	TSC	+0.68	TEH	TEC	560DT	11			COLD
43	76				NDD			TSH	TSH	560PP	23			HOT
		17.34		8	SLG	TSH	+0.50	TEH	TEC	560DT	11			COLD
		20.20		8	SLG	TSC	+0.65	TEH	TEC	560DT	11			COLD
43	77				SLG	TSH	+0.51	TEH	TEC	560DT	11			COLD
		16.84		8	SLG	TSC	+0.76	TEH	TEC	560DT	11			COLD
		20.42		8	SLG	TSC	+0.76	TEH	TEC	560DT	11			COLD
43	78		84	3	NQH	07C	+26.71	TEH	TEC	560DT	12			COLD
		0.45		8	SLG	TSH	+0.60	TEH	TEC	560DT	12			COLD
		18.30		8	SLG	TSC	+0.82	TEH	TEC	560DT	12			COLD
43	79				NDD			TSH	TSH	560PP	24			HOT
		17.26		8	SLG	TSH	+0.53	TEH	TEC	560DT	11			COLD
		20.52		8	SLG	TSC	+0.70	TEH	TEC	560DT	11			COLD
43	80				RBD			TSH	TSH	560PP	23			HOT
					NDD			TSH	TSH	560PS	90			HOT
		15.99		8	SLG	TSH	+0.49	TEH	TEC	560DT	11			COLD
		20.98		8	SLG	TSC	+0.75	TEH	TEC	560DT	11			COLD
43	81				NDD			TSH	TSH	560PP	26			HOT
		18.35		8	SLG	TSH	+0.54	TEH	TEC	560DT	11			COLD
		21.35		8	SLG	TSC	+0.83	TEH	TEC	560DT	11			COLD
43	82				NDD			TSH	TSH	560PP	26			HOT
		16.80		8	SLG	TSH	+0.51	TEH	TEC	560DT	11			COLD
		20.98		8	SLG	TSC	+0.81	TEH	TEC	560DT	11			COLD
				3	NDF	TSH	+15.07	01H	TSH	560PP	58			HOT
43	83				SLG	TSH	+0.51	TEH	TEC	560DT	14			COLD
		16.71		8	SLG	TSC	+0.79	TEH	TEC	560DT	14			COLD
		21.12		8	SLG	TSC	+0.79	TEH	TEC	560DT	14			COLD
43	84				SLG	TSH	+0.53	TEH	TEC	560DT	15			COLD
		17.18		8	SLG	TSC	+0.77	TEH	TEC	560DT	15			COLD
		21.69		8	SLG	TSC	+0.84	TEH	TEC	560DT	14			COLD
43	85				SLG	TSC	+0.84	TEH	TEC	560DT	14			COLD
43	86				SLG	TSC	+0.86	TEH	TEC	560DT	14			COLD
43	87				NDD			TSH	TSH	560PP	26			HOT
		22.16		8	SLG	TSC	+0.89	TEH	TEC	560DT	14			COLD
43	88				SLG	TSC	+0.96	TEH	TEC	560DT	14			COLD
		22.24		8	SLG	TSC	+0.96	TEH	TEC	560DT	14			COLD
					NDD			TSH	TSH	560PP	26			HOT
43	89				NDD			TSH	TSH	560PP	27			HOT
		22.40		8	SLG	TSC	+0.97	TEH	TEC	560DT	14			COLD
43	90				SLG	TSC	+0.95	TEH	TEC	560DT	15			COLD
		24.07		8	SLG	TSC	+0.95	TEH	TEC	560DT	15			COLD
					NDD			TSH	TSH	560PP	26			HOT
43	91			99	2	VOL	AV4	AV4	AV5	5201P	111			COLD
		0.98		131	2	VOL	AV5	AV4	AV5	5201P	111			COLD
		0.55		76	2	VOL	AV2	AV2	AV2	5201P	75			HOT
		1.67		0	P 2	PID	AV4	TEH	TEC	560UL	46			COLD
		2.35		P 2	TWD 43	AV2	+0.13	TEH	TEC	560DT	14			COLD
		2.83		P 2	TWD 31	AV3	+0.57	TEH	TEC	560DT	14			COLD
		1.39		P 2	TWD 40	AV4	+0.26	TEH	TEC	560DT	14			COLD
		2.40		P 2	TWD 10	AV5	-0.16	TEH	TEC	560DT	14			COLD
		0.34		8	SLG	TSC	+1.04	TEH	TEC	560DT	14			COLD
		23.28		171	1	INR	08C	TEH	TEC	560DT	14			COLD
		1.92		8	SLG	TSC	+0.90	TEH	TEC	560DT	15			COLD
43	92				SLG	TSC	+0.90	TEH	TEC	560DT	15			COLD
		23.04		8	SLG	TSH	+0.46	TEH	TEC	560DT	14			COLD
43	93				SLG	TSC	+0.94	TEH	TEC	560DT	14			COLD
		15.21		8	SLG	TSC	+0.94	TEH	TEC	560DT	14			COLD
		22.92		8	SLG	TSC	+0.89	TEH	TEC	560DT	14			COLD
43	94				SLG	TSC	+0.89	TEH	TEC	560DT	14			COLD
		22.66		8	SLG	TSC	+0.89	TEH	TEC	560DT	14			COLD
43	95				NDD			TSH	TSH	560PP	27			HOT
		0.57		P 2	TWD 16	AV5	+0.10	TEH	TEC	560DT	14			COLD
		22.62		8	SLG	TSC	+0.86	TEH	TEC	560DT	14			COLD
43	96				SLG	TSC	+0.83	TEH	TEC	560DT	15			COLD
		22.76		8	SLG	TSC	+0.83	TEH	TEC	560DT	15			COLD
					NDD			TSH	TSH	560PP	26			HOT
43	97				SLG	TSC	+0.78	TEH	TEC	560DT	14			COLD
		21.52		8	SLG	TSC	+0.78	TEH	TEC	560DT	14			COLD
					NDD			TSH	TSH	560PP	26			HOT
43	98				SLG	TSC	+0.70	TEH	TEC	560DT	15			COLD
		21.43		8	SLG	TSC	+0.70	TEH	TEC	560DT	15			COLD
		0.69		41	3	NQH	03C	TEH	TEC	560DT	15			COLD
					NDD		+4.09	TSH	TSH	560PP	26			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
43	99	19.66		8	SLG		TSC			560DT	14			COLD
43	100	0.71	0	P 2	TWD	18	AV4			560UL	46			COLD
		17.96		8	SLG		TSH			560UL	46			COLD
		25.52		8	SLG		TSC			560UL	46			COLD
43	101				INF		AV5			560UL	71	HR		COLD
		0.15	76	3	INR		AV6			560UL	71			COLD
43	102	0.40	0	P 2	TWD	13	AV6			560UC	70			COLD
44	21				NDD					560PP	53			HOT
		0.44	0	P 2	TWD	13	AV1			560DT	3			COLD
		0.32	0	P 2	TWD	10	AV6			560DT	3			COLD
44	22				NDD					560UL	46			COLD
					RBD					560UL	4			COLD
					NDD					560PP	52			HOT
44	23	0.76	0	P 5	TWD	12	TSH			560PP	52	SVI		HOT
		0.36	90	P 5	ARC		TSH			560PP	52			HOT
		0.32	0	P 5	LEN		TSH			560PP	52			HOT
		0.91	0	P 4	TWD	17	TSH			560PP	52	SVI		HOT
		0.29	90	P 4	ARC		TSH			560PP	52			HOT
		0.24	0	P 4	LEN		TSH			560PP	52			HOT
		15.11		8	SLG		TSC			560DT	3			COLD
		0.23	87	3	PID		TSH			560PP	52			HOT
		0.27	79	3	SVI		TSH			560PP	26			HOT
		0.24	91	3	PID		TSH			560PP	50			HOT
44	24	0.62	0	P 5	TWD	11	TSH			560PP	53	SVI		HOT
		0.38	90	P 5	ARC		TSH			560PP	53			HOT
		0.25	0	P 5	LEN		TSH			560PP	53			HOT
		0.48	0	P 4	TWD	9	TSH			560PP	53	SVI		HOT
		0.30	90	P 4	ARC		TSH			560PP	53			HOT
		0.23	0	P 4	LEN		TSH			560PP	53			HOT
		0.22	85	3	PID		TSH			560PP	53			HOT
					NDD					560UL	46			COLD
					RBD					560UL	4			COLD
		0.27	85	3	SVI		TSH			560PP	26			HOT
		0.22	84	3	PID		TSH			560PP	51			HOT
44	25				NDD					560DT	3			COLD
					NDD					560PP	26			HOT
44	26	20.98		8	SLG		TSC			560DT	3			COLD
					NDD					560PP	26			HOT
44	27	20.53		8	SLG		TSC			560DT	3			COLD
44	28	20.45		8	SLG		TSC			560DT	3			COLD
44	29	20.61		8	SLG		TSC			560DT	3			COLD
44	30	20.06		8	SLG		TSC			560DT	5			COLD
44	31				NDD					560PP	28			HOT
		19.85		8	SLG		TSC			560DT	5			COLD
44	32				NDD					560PP	28			HOT
		18.85		8	SLG		TSC			560DT	5			COLD
44	33				NDD					560PP	28			HOT
		17.52		8	SLG		TSC			560DT	5			COLD
44	34	16.31		8	SLG		TSC			560DT	6			COLD
					NDD					560PP	28			HOT
44	35				NDD					560DT	5			COLD
44	36				NDD					560DT	5			COLD
44	37				NDD					560DT	5			COLD
44	38				NDD					560DT	6			COLD
44	39				NDD					560DT	6			COLD
					NDD					560PP	28			HOT
44	40				NDD					560PP	28			HOT
					NDD					560DT	5			COLD
44	41				NDD					560DT	6			COLD
					NDD					560PP	28			HOT
44	42				NDD					560PP	28			HOT
					NDD					560DT	7			COLD
44	43				NDD					560DT	8			COLD
44	44				NDD					560DT	7			COLD
44	45				NDD					560DT	8			COLD
44	46	0.93	81	3	NQH		AV3			560DT	8			COLD
44	47				NDD					560PP	31			HOT
					NDD					560DT	8			COLD
44	48				NDD					560PP	31			HOT
					NDD					560DT	8			COLD
44	49				NDD					560DT	8			COLD
					NDD					560PP	31			HOT
44	50				NDD					560PP	31			HOT
					NDD					560DT	8			COLD
44	51				NDD					560DT	7			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAI#	COMMENT1	COMMENT2	LEG
44	52				NDD			TEH	TEC	560DT	8			COLD
44	53				NDD			TEH	TEC	560DT	8			COLD
44	54				NDD			TEH	TEC	560DT	8			COLD
44	55				NDD			TSH	TSH	560PP	30			HOT
					NDD			TEH	TEC	560DT	8			COLD
44	56				NDD			TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	31			HOT
44	57				NDD			TSH	TSH	560PP	30			HOT
					NDD			TEH	TEC	560DT	8			COLD
44	58				NDD			TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	31			HOT
44	59				NDD			TEH	TEC	560DT	8			COLD
44	60				NDD			TEH	TEC	560DT	7			COLD
44	61	4.24	186	1	DNG		AV6	+4.83	TEH	TEC	560DT	10		COLD
44	62				NDD			TEH	TEC	560DT	9			COLD
44	63			3	NDF		08H	+0.52	08H	08H	560PP	60		HOT
					NDD			TSH	TSH	560PP	50			HOT
	4.81		179	P 1	DNT		08H	+0.52	TEH	TEC	560DT	10		COLD
44	64				NDD			TSH	TSH	560PP	24			HOT
					NDD			TEH	TEC	560DT	9			COLD
44	65				NDD			TSH	TSH	560PP	24			HOT
					NDD			TEH	TEC	560DT	10			COLD
44	66				NDD			TSH	TSH	560PP	24			HOT
	17.44		8		SLG		TSC	+0.52	TEH	TEC	560DT	9		COLD
44	67	19.83		8	SLG		TSC	+0.62	TEH	TEC	560DT	10		COLD
44	68	19.01		8	SLG		TSC	+0.60	TEH	TEC	560DT	9		COLD
44	69	19.67		8	SLG		TSC	+0.67	TEH	TEC	560DT	10		COLD
44	70				NDD			TSH	TSH	560PP	23			HOT
	19.39		8		SLG		TSC	+0.64	TEH	TEC	560DT	10		COLD
44	71				NDD			TSH	TSH	560PP	24			HOT
	21.14		8		SLG		TSC	+0.72	TEH	TEC	560DT	10		COLD
44	72				NDD			TSH	TSH	560PP	24			HOT
	19.97		8		SLG		TSC	+0.69	TEH	TEC	560DT	10		COLD
44	73				NDD			TSH	TSH	560PP	24			HOT
	19.63		8		SLG		TSC	+0.72	TEH	TEC	560DT	10		COLD
44	74				NDD			TSH	TSH	560PP	24			HOT
	6.47		179	P 1	DNT		08C	+0.36	TEH	TEC	560DT	12		COLD
	15.25		8		SLG		TSH	+0.45	TEH	TEC	560DT	12		COLD
	20.60		8		SLG		TSC	+0.77	TEH	TEC	560DT	12		COLD
44	75	1.58	98	6	INR		AV2	+2.57	TEH	TEC	560DT	12		COLD
	15.29		8		SLG		TSH	+0.46	TEH	TEC	560DT	12		COLD
	20.35		8		SLG		TSC	+0.75	TEH	TEC	560DT	12		COLD
44	76	16.22		8	SLG		TSH	+0.47	TEH	TEC	560DT	12		COLD
	21.08		8		SLG		TSC	+0.80	TEH	TEC	560DT	12		COLD
44	77	15.80		8	SLG		TSH	+0.48	TEH	TEC	560DT	12		COLD
	21.14		8		SLG		TSC	+0.82	TEH	TEC	560DT	12		COLD
44	78	15.85		8	SLG		TSH	+0.48	TEH	TEC	560DT	11		COLD
	20.32		8		SLG		TSC	+0.78	TEH	TEC	560DT	11		COLD
44	79				RBD			TSH	TSH	560PP	23			HOT
					NDD			TSH	TSH	560PS	90			HOT
	17.93		8		SLG		TSH	+0.60	TEH	TEC	560DT	12		COLD
	20.86		8		SLG		TSC	+0.97	TEH	TEC	560DT	12		COLD
44	80				NDD			TSH	TSH	560PP	24			HOT
	1.24		124	3	INR		02C	+32.70	TEH	TEC	560DT	12		COLD
	17.05		8		SLG		TSH	+0.55	TEH	TEC	560DT	12		COLD
	21.65		8		SLG		TSC	+0.97	TEH	TEC	560DT	12		COLD
44	81				NDD			TSH	TSH	560PP	27			HOT
	19.10		8		SLG		TSH	+0.60	TEH	TEC	560DT	12		COLD
	21.22		8		SLG		TSC	+0.92	TEH	TEC	560DT	12		COLD
44	82				NDD			TSH	TSH	560PP	27			HOT
	16.12		8		SLG		TSH	+0.49	TEH	TEC	560DT	11		COLD
	22.31		8		SLG		TSC	+0.89	TEH	TEC	560DT	11		COLD
44	83	16.82		8	SLG		TSH	+0.52	TEH	TEC	560DT	15		COLD
	21.81		8		SLG		TSC	+0.84	TEH	TEC	560DT	15		COLD
44	84	15.13		8	SLG		TSH	+0.46	TEH	TEC	560DT	14		COLD
	21.68		8		SLG		TSC	+0.91	TEH	TEC	560DT	14		COLD
44	85	15.53		8	SLG		TSH	+0.45	TEH	TEC	560DT	15		COLD
	21.61		8		SLG		TSC	+0.77	TEH	TEC	560DT	15		COLD
44	86	15.63		8	SLG		TSH	+0.48	TEH	TEC	560DT	15		COLD
	22.15		8		SLG		TSC	+0.82	TEH	TEC	560DT	15		COLD
44	87	21.11		8	SLG		TSC	+0.80	TEH	TEC	560DT	15		COLD
					NDD			TSH	TSH	560PP	27			HOT
44	88	15.35		8	SLG		TSH	+0.45	TEH	TEC	560DT	15		COLD
	22.76		8		SLG		TSC	+0.85	TEH	TEC	560DT	15		COLD
					NDD			TSH	TSH	560PP	27			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
44	89	22.52		8	SLG		TSC		TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	26		HOT
					NDD				TSH	TSH	560PP	27		HOT
		22.92		8	SLG		TSC		TEH	TEC	560DT	14		COLD
44	91	21.87		8	SLG		TSC		TEH	TEC	560DT	15		COLD
44	92	22.40		8	SLG		TSC		TEH	TEC	560DT	14		COLD
		0.63	97	3	NQH		03H		TEH	TEC	560DT	14		COLD
44	93	21.95		8	SLG		TSC		TEH	TEC	560DT	15		COLD
44	94	22.01		8	SLG		TSC		TEH	TEC	560DT	15		COLD
44	95	21.89		8	SLG		TSC		TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	26		HOT
					NDD				TSH	TSH	560PP	27		HOT
44	96	20.74		8	SLG		TSC		TEH	TEC	560DT	14		COLD
44	97	20.38		8	SLG		TSC		TEH	TEC	560DT	15		COLD
		7.11	183	1	DNG		AV6		TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	27		HOT
					NDD				TSH	TSH	560PP	27		HOT
44	98	18.72		8	SLG		TSC		TEH	TEC	560DT	14		COLD
		7.58	184	1	DNG		AV6		TEH	TEC	560DT	14		COLD
					INF		AV6		TEH	TEC	560DT	14		COLD
					INF		AV6		TEH	TEC	560DT	14	HR	COLD
44	99	0.49	66	P 1	INR		08H		TEH	TEC	560DT	15		COLD
		17.18		8	SLG		TSC		TEH	TEC	560DT	15		COLD
				2	NDF		08H		AV1	08H	5201P	72		HOT
44	100	3.41	179	1	DNG		03C		TEH	TEC	560UL	71		COLD
44	101				NDD				TEH	TEC	560UL	71		COLD
44	102				NDD				TEH	TEC	560UC	70		COLD
45	22				NDD				TSH	TSH	560PP	53		HOT
					NDD				TEH	TEC	560DT	3		COLD
45	23	0.67	0	P 5	TWD	12	TSH		TSH	TSH	560PP	53	SVI	HOT
		0.38	90	P 5	ARC		TSH		TSH	TSH	560PP	53		HOT
		0.25	0	P 5	LEN		TSH		TSH	TSH	560PP	53		HOT
		0.87	0	P 4	TWD	16	TSH		TSH	TSH	560PP	53	SVI	HOT
		0.30	90	P 4	ARC		TSH		TSH	TSH	560PP	53		HOT
		0.21	0	P 4	LEN		TSH		TSH	TSH	560PP	53		HOT
		0.24	91	3	PID		TSH		TSH	TSH	560PP	53		HOT
					NDD				TEH	TEC	560DT	3		COLD
		0.30	85	3	SVI		TSH		TSH	TSH	560PP	26		HOT
		0.25	89	3	PID		TSH		TSH	TSH	560PP	51		HOT
45	24	0.91	0	P 5	TWD	14	TSH		TSH	TSH	560PP	52	SVI	HOT
		0.39	90	P 5	ARC		TSH		TSH	TSH	560PP	52		HOT
		0.37	0	P 5	LEN		TSH		TSH	TSH	560PP	52		HOT
		0.63	0	P 4	TWD	13	TSH		TSH	TSH	560PP	52	SVI	HOT
		0.31	90	P 4	ARC		TSH		TSH	TSH	560PP	52		HOT
		0.24	0	P 4	LEN		TSH		TSH	TSH	560PP	52		HOT
		15.98		8	SLG		TSC		TEH	TEC	560DT	3		COLD
		0.30	87	3	PID		TSH		TSH	TSH	560PP	52		HOT
		0.33	85	3	SVI		TSH		TSH	TSH	560PP	26		HOT
		0.26	86	3	PID		TSH		TSH	TSH	560PP	51		HOT
45	25				NDD				TEH	TEC	560UL	46		COLD
					RBD				TEH	TEC	560UL	4		COLD
					NDD				TSH	TSH	560PP	26		HOT
45	26				NDD				TEH	TEC	560UL	46		COLD
					RBD				TEH	TEC	560UL	4		COLD
					NDD				TSH	TSH	560PP	26		HOT
45	27	21.12		8	SLG		TSC		TEH	TEC	560UL	4		COLD
45	28	21.26		8	SLG		TSC		TEH	TEC	560UL	4		COLD
45	29	21.79		8	SLG		TSC		TEH	TEC	560UL	4		COLD
45	30	20.60		8	SLG		TSC		TEH	TEC	560DT	6		COLD
45	31	22.30		8	SLG		TSC		TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
45	32	18.91		8	SLG		TSC		TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
45	33	19.21		8	SLG		TSC		TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
45	34	16.93		8	SLG		TSC		TSH	TSH	560PP	28		HOT
					NDD				TEH	TEC	560DT	5		COLD
45	35				NDD				TEH	TEC	560DT	6		COLD
45	36				NDD				TEH	TEC	560DT	6		COLD
45	37				NDD				TEH	TEC	560DT	6		COLD
45	38				NDD				TEH	TEC	560DT	5		COLD
45	39				NDD				TSH	TSH	560PP	28		HOT
					NDD				TEH	TEC	560DT	5		COLD
45	40				NDD				TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
45	41				NDD				TSH	TSH	560PP	28		HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
45	42	0.45	0	P 2	TWD	14	AV3	-0.11	TEH	TEC	560DT	5		COLD
					NDD				TSH	TSH	560PP	28		HOT
					NDD				TEH	TEC	560DT	7		COLD
45	43				NDD				TEH	TEC	560DT	7		COLD
45	44				NDD				TEH	TEC	560DT	8		COLD
45	45				NDD				TEH	TEC	560DT	7		COLD
45	46				NDD				TEH	TEC	560DT	7		COLD
45	47				NDD				TSH	TSH	560PP	30		HOT
					NDD				TEH	TEC	560DT	7		COLD
45	48				NDD				TSH	TSH	560PP	30		HOT
					NDD				TEH	TEC	560DT	7		COLD
45	49				NDD				TSH	TSH	560PP	30		HOT
					NDD				TEH	TEC	560DT	7		COLD
45	50				NDD				TSH	TSH	560PP	30		HOT
					NDD				TEH	TEC	560DT	7		COLD
45	51				NDD				TEH	TEC	560DT	8		COLD
45	52				NDD				TEH	TEC	560DT	7		COLD
45	53				NDD				TEH	TEC	560DT	7		COLD
45	54	0.40	164	P 1	INR		08H	+3.81	TEH	TEC	560DT	7		COLD
				2	NDF		08H	+3.81	AV1	08H	5201P	72		HOT
45	55				NDD				TEH	TEC	560DT	7		COLD
					NDD				TSH	TSH	560PP	31		HOT
45	56				NDD				TSH	TSH	560PP	30		HOT
					NDD				TEH	TEC	560DT	8		COLD
45	57				NDD				TEH	TEC	560DT	7		COLD
					NDD				TSH	TSH	560PP	31		HOT
45	58				NDD				TSH	TSH	560PP	30		HOT
					NDD				TEH	TEC	560DT	8		COLD
45	59				NDD				TEH	TEC	560DT	7		COLD
45	60				NDD				TEH	TEC	560DT	8		COLD
45	61				NDD				TEH	TEC	560DT	9		COLD
45	62				NDD				TEH	TEC	560DT	10		COLD
45	63				NDD				TSH	TSH	560PP	23		HOT
		0.45	161	1	TFH		AV6	+22.50	TEH	TEC	560DT	9		COLD
45	64				NDD				TSH	TSH	560PP	24		HOT
		16.70		8	SLG		TSC	+0.49	TEH	TEC	560DT	10		COLD
45	65				NDD				TSH	TSH	560PP	24		HOT
		18.75		8	SLG		TSC	+0.60	TEH	TEC	560DT	9		COLD
45	66				NDD				TSH	TSH	560PP	23		HOT
		19.81		8	SLG		TSC	+0.62	TEH	TEC	560DT	10		COLD
45	67	20.60		8	SLG		TSC	+0.70	TEH	TEC	560DT	9		COLD
45	68	21.88		8	SLG		TSC	+0.80	TEH	TEC	560DT	10		COLD
45	69	21.41		8	SLG		TSC	+0.84	TEH	TEC	560DT	9		COLD
45	70	21.55		8	SLG		TSC	+0.78	TEH	TEC	560DT	9		COLD
45	71				NDD				TSH	TSH	560PP	23		HOT
		21.45		8	SLG		TSC	+0.84	TEH	TEC	560DT	9		COLD
45	72				NDD				TSH	TSH	560PP	23		HOT
		21.83		8	SLG		TSC	+0.83	TEH	TEC	560DT	9		COLD
45	73				NDD				TSH	TSH	560PP	23		HOT
		21.47		8	SLG		TSC	+0.78	TEH	TEC	560DT	9		COLD
45	74				NDD				TSH	TSH	560PP	23		HOT
		21.91		8	SLG		TSC	+0.86	TEH	TEC	560DT	9		COLD
45	75	15.37		8	SLG		TSH	+0.44	TEH	TEC	560DT	11		COLD
		21.69		8	SLG		TSC	+0.99	TEH	TEC	560DT	11		COLD
45	76	16.44		8	SLG		TSH	+0.50	TEH	TEC	560DT	11		COLD
		21.83		8	SLG		TSC	+0.88	TEH	TEC	560DT	11		COLD
45	77	16.76		8	SLG		TSH	+0.51	TEH	TEC	560DT	11		COLD
		21.73		8	SLG		TSC	+0.94	TEH	TEC	560DT	11		COLD
45	78	17.55		8	SLG		TSH	+0.62	TEH	TEC	560DT	12		COLD
		22.39		8	SLG		TSC	+0.97	TEH	TEC	560DT	12		COLD
45	79				NDD				TSH	TSH	560PP	24		HOT
		15.95		8	SLG		TSH	+0.48	TEH	TEC	560DT	11		COLD
		22.31		8	SLG		TSC	+0.93	TEH	TEC	560DT	11		COLD
45	80				RBD				TSH	TSH	560PP	23		HOT
					NDD				TSH	TSH	560PS	90		HOT
		15.39		8	SLG		TSH	+0.46	TEH	TEC	560DT	11		COLD
		22.23		8	SLG		TSC	+0.99	TEH	TEC	560DT	11		COLD
45	81				NDD				TSH	TSH	560PP	26		HOT
		21.93		8	SLG		TSC	+0.91	TEH	TEC	560DT	11		COLD
45	82				NDD				TSH	TSH	560PP	26		HOT
		15.27		8	SLG		TSH	+0.46	TEH	TEC	560DT	11		COLD
		21.93		8	SLG		TSC	+0.94	TEH	TEC	560DT	11		COLD
45	83	21.74		8	SLG		TSC	+0.94	TEH	TEC	560DT	14		COLD
45	84	15.53		8	SLG		TSH	+0.45	TEH	TEC	560DT	15		COLD
		21.61		8	SLG		TSC	+0.87	TEH	TEC	560DT	15		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
45	85	21.86		8	SLG		TSC		TEH	TEC	560DT	14		COLD
45	86	21.50		8	SLG		TSC		TEH	TEC	560DT	14		COLD
45	87				NDD				TSH	TSH	560PP	26		HOT
		21.36		8	SLG		TSC		TEH	TEC	560DT	14		COLD
		6.47	184	P 1	DNT		08H		TEH	TEC	560DT	14		COLD
				3	NDF		08H		08H	08H	560PP	58		HOT
45	88	21.72		8	SLG		TSC		TEH	TEC	560DT	14		COLD
					NDD				TSH	TSH	560PP	26		HOT
45	89				NDD				TSH	TSH	560PP	27		HOT
		21.80		8	SLG		TSC		TEH	TEC	560DT	14		COLD
45	90	22.22		8	SLG		TSC		TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	26		HOT
45	91	21.46		8	SLG		TSC		TEH	TEC	560DT	14		COLD
45	92	21.81		8	SLG		TSC		TEH	TEC	560DT	15		COLD
		0.33	79	3	NQH		02C		TEH	TEC	560DT	15		COLD
		0.26	96	3	NQH		TSC		TEH	TEC	560DT	15		COLD
45	93	21.30		8	SLG		TSC		TEH	TEC	560DT	14		COLD
45	94	21.28		8	SLG		TSC		TEH	TEC	560DT	14		COLD
45	95				NDD				TSH	TSH	560PP	27		HOT
		20.52		8	SLG		TSC		TEH	TEC	560DT	14		COLD
45	96	20.28		8	SLG		TSC		TEH	TEC	560DT	15		COLD
		3.45	175	P 1	DNT		08C		TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	26		HOT
45	97	19.32		8	SLG		TSC		TEH	TEC	560DT	14		COLD
					NDD				TSH	TSH	560PP	26		HOT
45	98	16.41		8	SLG		TSC		TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	26		HOT
45	99				NDD				TEH	TEC	560DT	14		COLD
45	100	5.41	180	P 1	DNT		AV5		TEH	TEC	560UL	71		COLD
45	101	1.27	104	2	VOL		AV4		AV4	AV5	5201P	111		COLD
		3.32	0	P 2	TWD	45	AV4		TEH	TEC	560UC	70		COLD
		0.53	0	P 2	TWD	16	AV6		TEH	TEC	560UC	70		COLD
		3.17		P 2	PID		AV4		TEH	TEC	560UC	82		COLD
46	24				NDD				TEH	TEC	560UL	46		COLD
					RBD				TEH	TEC	560UL	4		COLD
					NDD				TSH	TSH	560PP	26		HOT
46	25	17.74		8	SLG		TSC		TEH	TEC	560DT	3		COLD
					NDD				TSH	TSH	560PP	26		HOT
46	26	19.01		8	SLG		TSC		TEH	TEC	560DT	3		COLD
					NDD				TSH	TSH	560PP	26		HOT
46	27	19.84		8	SLG		TSC		TEH	TEC	560DT	3		COLD
46	28	3.03	187	1	DNG		06H		TEH	TEC	560DT	3		COLD
		20.19		8	SLG		TSC		TEH	TEC	560DT	3		COLD
46	29	22.66		8	SLG		TSC		TEH	TEC	560DT	3		COLD
46	30	20.41		8	SLG		TSC		TEH	TEC	560DT	5		COLD
46	31				NDD				TSH	TSH	560PP	28		HOT
		21.98		8	SLG		TSC		TEH	TEC	560DT	5		COLD
46	32				NDD				TSH	TSH	560PP	28		HOT
		20.14		8	SLG		TSC		TEH	TEC	560DT	5		COLD
		5.57	185	1	DNG		02C		TEH	TEC	560DT	5		COLD
46	33				NDD				TSH	TSH	560PP	28		HOT
		19.91		8	SLG		TSC		TEH	TEC	560DT	5		COLD
46	34	18.85		8	SLG		TSC		TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
46	35	17.44		8	SLG		TSC		TEH	TEC	560DT	5		COLD
46	36	16.32		8	SLG		TSC		TEH	TEC	560DT	5		COLD
46	37	16.40		8	SLG		TSC		TEH	TEC	560DT	5		COLD
46	38	17.49		8	SLG		TSC		TEH	TEC	560DT	6		COLD
		2.11	85	6	NQH		TSH		TEH	TEC	560DT	6		COLD
46	39	17.85		8	SLG		TSC		TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
46	40				NDD				TSH	TSH	560PP	28		HOT
					NDD				TEH	TEC	560DT	5		COLD
46	41	17.71		8	SLG		TSC		TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
46	42				NDD				TSH	TSH	560PP	28		HOT
		15.37		8	SLG		TSC		TEH	TEC	560DT	8		COLD
46	43	16.29		8	SLG		TSC		TEH	TEC	560DT	8		COLD
46	44				NDD				TEH	TEC	560DT	7		COLD
46	45	16.19		8	SLG		TSC		TEH	TEC	560DT	8		COLD
46	46	17.05		8	SLG		TSC		TEH	TEC	560DT	8		COLD
46	47				NDD				TSH	TSH	560PP	31		HOT
		17.95		8	SLG		TSC		TEH	TEC	560DT	8		COLD
46	48				NDD				TSH	TSH	560PP	31		HOT
		18.01		8	SLG		TSC		TEH	TEC	560DT	8		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
46	49				NDD			TSH	TSH	560PP	31			HOT
		18.35		8	SLG		TSC	TEH	TEC	560DT	8			COLD
46	50				NDD			TSH	TSH	560PP	31			HOT
		18.13		8	SLG		TSC	TEH	TEC	560DT	8			COLD
46	51	16.62		8	SLG		TSC	TEH	TEC	560DT	7			COLD
46	52	17.27		8	SLG		TSC	TEH	TEC	560DT	8			COLD
46	53			3	NDF		03H	03H	04H	560PP	60			HOT
				3	NDF		02H	03H	02H	560PP	57			HOT
		5.02	185	1	DNG		03H	TEH	TEC	560DT	8			COLD
		16.27		8	SLG		TSC	TEH	TEC	560DT	8			COLD
46	54	16.50		8	SLG		TSC	TEH	TEC	560DT	8			COLD
46	55				NDD			TSH	TSH	560PP	30			HOT
		16.09		8	SLG		TSC	TEH	TEC	560DT	8			COLD
46	56	15.09		8	SLG		TSC	TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	31			HOT
46	57				NDD			TSH	TSH	560PP	30			HOT
		15.78		8	SLG		TSC	TEH	TEC	560DT	8			COLD
46	58				NDD			TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	31			HOT
46	59	15.25		8	SLG		TSC	TEH	TEC	560DT	8			COLD
46	60	15.16		8	SLG		TSC	TEH	TEC	560DT	7			COLD
46	61				NDD			TEH	TEC	560DT	10			COLD
46	62	17.12		8	SLG		TSC	TEH	TEC	560DT	9			COLD
46	63				NDD			TSH	TSH	560PP	50			HOT
		18.24		8	SLG		TSC	TEH	TEC	560DT	10			COLD
46	64				NDD			TSH	TSH	560PP	24			HOT
		19.50		8	SLG		TSC	TEH	TEC	560DT	9			COLD
		3.74	188	1	DNG		06C	TEH	TEC	560DT	9			COLD
46	65				NDD			TSH	TSH	560PP	24			HOT
		0.56	89	3	INR		04C	TEH	TEC	560DT	10			COLD
		21.22		8	SLG		TSC	TEH	TEC	560DT	10			COLD
46	66				NDD			TSH	TSH	560PP	24			HOT
		20.68		8	SLG		TSC	TEH	TEC	560DT	9			COLD
46	67	4.23	186	1	DNG		04C	TEH	TEC	560DT	10			COLD
		22.91		8	SLG		TSC	TEH	TEC	560DT	10			COLD
46	68	22.21		8	SLG		TSC	TEH	TEC	560DT	9			COLD
46	69	0.42	98	3	INR		03H	TEH	TEC	560DT	10			COLD
		23.23		8	SLG		TSC	TEH	TEC	560DT	10			COLD
46	70	23.73		8	SLG		TSC	TEH	TEC	560DT	10			COLD
46	71				NDD			TSH	TSH	560PP	24			HOT
		23.71		8	SLG		TSC	TEH	TEC	560DT	10			COLD
46	72				NDD			TSH	TSH	560PP	24			HOT
		22.34		8	SLG		TSC	TEH	TEC	560DT	10			COLD
46	73				NDD			TSH	TSH	560PP	24			HOT
		23.01		8	SLG		TSC	TEH	TEC	560DT	10			COLD
46	74				NDD			TSH	TSH	560PP	24			HOT
		23.11		8	SLG		TSC	TEH	TEC	560DT	10			COLD
46	75	22.74		8	SLG		TSC	TEH	TEC	560DT	12			COLD
46	76	22.15		8	SLG		TSC	TEH	TEC	560DT	12			COLD
46	77	22.61		8	SLG		TSC	TEH	TEC	560DT	12			COLD
46	78	15.31		8	SLG		TSH	TEH	TEC	560DT	11			COLD
		21.87		8	SLG		TSC	TEH	TEC	560DT	11			COLD
46	79				RBD			TSH	TSH	560PP	23			HOT
					NDD			TSH	TSH	560PS	90			HOT
		16.70		8	SLG		TSH	TEH	TEC	560DT	12			COLD
		22.92		8	SLG		TSC	TEH	TEC	560DT	12			COLD
46	80				NDD			TSH	TSH	560PP	24			HOT
		17.13		8	SLG		TSH	TEH	TEC	560DT	12			COLD
		23.04		8	SLG		TSC	TEH	TEC	560DT	12			COLD
46	81				NDD			TSH	TSH	560PP	27			HOT
		15.57		8	SLG		TSH	TEH	TEC	560DT	12			COLD
		22.37		8	SLG		TSC	TEH	TEC	560DT	12			COLD
46	82				NDD			TSH	TSH	560PP	27			HOT
		22.25		8	SLG		TSC	TEH	TEC	560DT	11			COLD
46	83	15.41		8	SLG		TSH	TEH	TEC	560DT	15			COLD
46	84	21.80		8	SLG		TSC	TEH	TEC	560DT	14			COLD
46	85	22.05		8	SLG		TSC	TEH	TEC	560DT	15			COLD
		0.26	99	3	NQH		08H	TEH	TEC	560DT	15			COLD
46	86	22.58		8	SLG		TSC	TEH	TEC	560DT	15			COLD
46	87	22.54		8	SLG		TSC	TEH	TEC	560DT	15			COLD
		0.25	103	3	NQH		08H	TEH	TEC	560DT	15			COLD
					NDD			TSH	TSH	560PP	27			HOT
46	88	22.09		8	SLG		TSC	TEH	TEC	560DT	15			COLD
					NDD			TSH	TSH	560PP	27			HOT
46	89	21.89		8	SLG		TSC	TEH	TEC	560DT	15			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					NDD			TSH	TSH	560PP	26			HOT
46	90				NDD			TSH	TSH	560PP	27			HOT
		20.74		8	SLG		TSC	TEH	TEC	560DT	14			COLD
46	91	22.17		8	SLG		TSC	TEH	TEC	560DT	15			COLD
46	92	21.16		8	SLG		TSC	TEH	TEC	560DT	14			COLD
46	93	21.43		8	SLG		TSC	TEH	TEC	560DT	15			COLD
46	94	20.64		8	SLG		TSC	TEH	TEC	560DT	15			COLD
46	95	20.40		8	SLG		TSC	TEH	TEC	560DT	15			COLD
					NDD			TSH	TSH	560PP	26			HOT
46	96				NDD			TSH	TSH	560PP	27			HOT
		17.75		8	SLG		TSC	TEH	TEC	560DT	14			COLD
46	97	16.52		8	SLG		TSC	TEH	TEC	560DT	15			COLD
					NDD			TSH	TSH	560PP	27			HOT
46	98				NDD			TSH	TSH	560PP	27			HOT
					NDD			TEH	TEC	560DT	14			COLD
46	99				NDD			TEH	TEC	560DT	15			COLD
47	24				NDD			TEH	TEC	560DT	3			COLD
					NDD			TSH	TSH	560PP	26			HOT
47	25				NDD			TEH	TEC	560DT	3			COLD
					NDD			TSH	TSH	560PP	26			HOT
47	26				NDD			TEH	TEC	560UL	46			COLD
					RBD			TEH	TEC	560UL	4			COLD
					NDD			TSH	TSH	560PP	26			HOT
47	27	19.80		8	SLG		TSC	TEH	TEC	560UL	4			COLD
47	28	21.04		8	SLG		TSC	TEH	TEC	560UL	4			COLD
47	29	21.38		8	SLG		TSC	TEH	TEC	560DT	6			COLD
47	30	23.62		8	SLG		TSC	TEH	TEC	560DT	6			COLD
47	31	21.94		8	SLG		TSC	TEH	TEC	560DT	6			COLD
					NDD			TSH	TSH	560PP	28			HOT
47	32	22.22		8	SLG		TSC	TEH	TEC	560DT	6			COLD
					NDD			TSH	TSH	560PP	28			HOT
47	33	20.10		8	SLG		TSC	TEH	TEC	560DT	6			COLD
					NDD			TSH	TSH	560PP	28			HOT
47	34				NDD			TSH	TSH	560PP	28			HOT
		19.44		8	SLG		TSC	TEH	TEC	560DT	5			COLD
47	35	17.25		8	SLG		TSC	TEH	TEC	560DT	6			COLD
		0.80	114	3	INR		05H	TEH	TEC	560DT	6			COLD
		0.55	112	3	NQH		01C	TEH	TEC	560DT	6			COLD
47	36	18.31		8	SLG		TSC	TEH	TEC	560DT	6			COLD
		0.69	107	3	NQH		04C	TEH	TEC	560DT	6			COLD
47	37	18.27		8	SLG		TSC	TEH	TEC	560DT	6			COLD
47	38	19.04		8	SLG		TSC	TEH	TEC	560DT	5			COLD
47	39				NDD			TSH	TSH	560PP	28			HOT
		3.73	178	P 1	DNT		08C	TEH	TEC	560DT	5			COLD
		18.93		8	SLG		TSC	TEH	TEC	560DT	5			COLD
47	40	19.49		8	SLG		TSC	TEH	TEC	560DT	6			COLD
					NDD			TSH	TSH	560PP	28			HOT
47	41				NDD			TSH	TSH	560PP	28			HOT
		18.71		8	SLG		TSC	TEH	TEC	560DT	5			COLD
47	42	0.52	62	2	VOL		TSH	TSH	TSH	560PP	28			HOT
		19.69		8	SLG		TSC	TEH	TEC	560DT	7			COLD
47	43	20.01		8	SLG		TSC	TEH	TEC	560DT	7			COLD
47	44	0.64	108	3	NQH		AV6	TEH	TEC	560DT	8			COLD
		20.37		8	SLG		TSC	TEH	TEC	560DT	8			COLD
47	45	19.28		8	SLG		TSC	TEH	TEC	560DT	7			COLD
47	46	20.01		8	SLG		TSC	TEH	TEC	560DT	7			COLD
47	47				NDD			TSH	TSH	560PP	30			HOT
		20.25		8	SLG		TSC	TEH	TEC	560DT	7			COLD
47	48				NDD			TSH	TSH	560PP	30			HOT
		20.36		8	SLG		TSC	TEH	TEC	560DT	7			COLD
47	49				NDD			TSH	TSH	560PP	30			HOT
		20.42		8	SLG		TSC	TEH	TEC	560DT	7			COLD
47	50				NDD			TSH	TSH	560PP	30			HOT
		21.56		8	SLG		TSC	TEH	TEC	560DT	7			COLD
47	51	20.95		8	SLG		TSC	TEH	TEC	560DT	8			COLD
47	52	19.65		8	SLG		TSC	TEH	TEC	560DT	7			COLD
47	53	0.73	106	3	NQH		06C	TEH	TEC	560DT	7			COLD
		20.03		8	SLG		TSC	TEH	TEC	560DT	7			COLD
47	54	20.25		8	SLG		TSC	TEH	TEC	560DT	7			COLD
47	55	19.77		8	SLG		TSC	TEH	TEC	560DT	7			COLD
		2.06	83	6	INR		02C	TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	31			HOT
47	56				NDD			TSH	TSH	560PP	30			HOT
		19.86		8	SLG		TSC	TEH	TEC	560DT	8			COLD
47	57	19.46		8	SLG		TSC	TEH	TEC	560DT	7			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					NDD			TSH	TSH	560PP	31			HOT
47	58				NDD			TSH	TSH	560PP	30			HOT
		19.50		8	SLG	TSC	+0.60	TEH	TEC	560DT	8			COLD
47	59	19.08		8	SLG	TSC	+0.57	TEH	TEC	560DT	7			COLD
47	60	19.48		8	SLG	TSC	+0.59	TEH	TEC	560DT	8			COLD
47	61	20.26		8	SLG	TSC	+0.63	TEH	TEC	560DT	9			COLD
47	62	18.77		8	SLG	TSC	+0.54	TEH	TEC	560DT	10			COLD
47	63				NDD			TSH	TSH	560PP	23			HOT
		20.89		8	SLG	TSC	+0.65	TEH	TEC	560DT	9			COLD
47	64			3	NDF	TSH	+3.24	TSH	TSH	560PP	60			HOT
					NDD			TSH	TSH	560PP	24			HOT
		21.54		8	SLG	TSC	+0.70	TEH	TEC	560DT	10			COLD
47	65				NDD			TSH	TSH	560PP	24			HOT
		22.32		8	SLG	TSC	+0.78	TEH	TEC	560DT	9			COLD
47	66				NDD			TSH	TSH	560PP	23			HOT
		22.38		8	SLG	TSC	+0.80	TEH	TEC	560DT	10			COLD
47	67	23.20		8	SLG	TSC	+0.88	TEH	TEC	560DT	9			COLD
47	68	3.17	177	P 1	DNT	08H	+0.59	TEH	TEC	560DT	10			COLD
		24.29		8	SLG	TSC	+0.98	TEH	TEC	560DT	10			COLD
				3	NDF	08H	+0.59	08H	08H	560PP	68			HOT
47	69	23.87		8	SLG	TSC	+0.99	TEH	TEC	560DT	9			COLD
47	70	23.77		8	SLG	TSC	+1.02	TEH	TEC	560DT	9			COLD
47	71				NDD			TSH	TSH	560PP	23			HOT
		24.53		8	SLG	TSC	+1.04	TEH	TEC	560DT	9			COLD
47	72				NDD			TSH	TSH	560PP	23			HOT
		23.36		8	SLG	TSC	+0.98	TEH	TEC	560DT	9			COLD
47	73				NDD			TSH	TSH	560PP	23			HOT
		23.58		8	SLG	TSC	+1.01	TEH	TEC	560DT	9			COLD
47	74				NDD			TSH	TSH	560PP	23			HOT
		24.93		8	SLG	TSC	+1.05	TEH	TEC	560DT	9			COLD
47	75	22.94		8	SLG	TSC	+1.07	TEH	TEC	560DT	11			COLD
				3	NDF	TSH	+14.78	01H	TSH	560PP	58			HOT
47	76	22.47		8	SLG	TSC	+1.08	TEH	TEC	560DT	11			COLD
47	77	23.04		8	SLG	TSC	+1.14	TEH	TEC	560DT	11			COLD
47	78	16.80		8	SLG	TSH	+0.52	TEH	TEC	560DT	12			COLD
		23.76		8	SLG	TSC	+1.18	TEH	TEC	560DT	12			COLD
47	79				NDD			TSH	TSH	560PP	24			HOT
		7.53	180	P 1	DNT	08C	+0.25	TEH	TEC	560DT	11			COLD
		3.34	173	P 1	DNT	08C	-0.55	TEH	TEC	560DT	11			COLD
		22.73		8	SLG	TSC	+1.01	TEH	TEC	560DT	11			COLD
				3	NDF	08H	+0.00	08H	08H	560PP	58			HOT
47	80				RBD			TSH	TSH	560PP	23			HOT
					NDD			TSH	TSH	560PP	24			HOT
		23.22		8	SLG	TSC	+1.04	TEH	TEC	560DT	11			COLD
47	81				NDD			TSH	TSH	560PP	26			HOT
		22.75		8	SLG	TSC	+0.99	TEH	TEC	560DT	11			COLD
47	82				NDD			TSH	TSH	560PP	26			HOT
		22.57		8	SLG	TSC	+1.05	TEH	TEC	560DT	11			COLD
47	83				NDD			TEH	TEC	560DT	14			COLD
47	84	15.13		8	SLG	TSH	+0.45	TEH	TEC	560DT	15			COLD
		23.28		8	SLG	TSC	+0.82	TEH	TEC	560DT	15			COLD
47	85	21.50		8	SLG	TSC	+0.86	TEH	TEC	560DT	14			COLD
47	86	21.44		8	SLG	TSC	+0.83	TEH	TEC	560DT	14			COLD
47	87				NDD			TSH	TSH	560PP	26			HOT
		21.48		8	SLG	TSC	+0.81	TEH	TEC	560DT	14			COLD
47	88	20.72		8	SLG	TSC	+0.78	TEH	TEC	560DT	14			COLD
					NDD			TSH	TSH	560PP	26			HOT
47	89				NDD			TSH	TSH	560PP	27			HOT
		21.42		8	SLG	TSC	+0.80	TEH	TEC	560DT	14			COLD
47	90	20.85		8	SLG	TSC	+0.69	TEH	TEC	560DT	15			COLD
					NDD			TSH	TSH	560PP	26			HOT
47	91	20.64		8	SLG	TSC	+0.68	TEH	TEC	560DT	14			COLD
					NDD			TSH	TSH	560PP	26			HOT
47	92	20.44		8	SLG	TSC	+0.64	TEH	TEC	560DT	15			COLD
47	93	18.64		8	SLG	TSC	+0.57	TEH	TEC	560DT	14			COLD
47	94	18.48		8	SLG	TSC	+0.54	TEH	TEC	560DT	14			COLD
47	95				NDD			TSH	TSH	560PP	27			HOT
		17.31		8	SLG	TSC	+0.52	TEH	TEC	560DT	14			COLD
47	96	16.84		8	SLG	TSC	+0.49	TEH	TEC	560DT	15			COLD
					NDD			TSH	TSH	560PP	26			HOT
47	97				NDD			TEH	TEC	560DT	14			COLD
					NDD			TSH	TSH	560PP	26			HOT
47	98				NDD			TEH	TEC	560DT	15			COLD
					NDD			TSH	TSH	560PP	26			HOT
47	99	2.06	0	P 2	PID	AV5	+0.05	TEH	TEC	560UL	106			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		1.41	0	P 2	TWD	32	AV6	-0.03	TEH	TEC	560UC	70		COLD
		1.90	0	P 2	TWD	37	AV5	+0.05	TEH	TEC	560UC	70		COLD
		0.81	0	P 2	TWD	22	AV4	-0.08	TEH	TEC	560UC	70		COLD
48	25	3.25	182	1	DNG		08H	+4.36	TEH	TEC	560DT	3		COLD
					NDD				TSH	TSH	560PP	26		HOT
48	26			3	NDF		08H	+0.45	08H	08H	560PP	57		HOT
		4.56	182	P 1	DNT		AV1	-0.06	TEH	TEC	560DT	3		COLD
		3.30	184	1	DNG		08H	+4.86	TEH	TEC	560DT	3		COLD
		0.25	146	P 1	INR		08H	+0.45	TEH	TEC	560DT	3		COLD
		16.12		8	SLG		TSC	+0.47	TEH	TEC	560DT	3		COLD
					NDD				TSH	TSH	560PP	26		HOT
48	27			3	NDF		TSH	+3.69	01H	TEH	560PP	57		HOT
		20.17		8	SLG		TSC	+0.66	TEH	TEC	560DT	3		COLD
48	28			3	NDF		02H	+0.55	02H	02H	560PP	61		HOT
		0.45	55	P 1	DSS		02H	+0.55	TEH	TEC	560DT	3		COLD
		4.09	185	1	DNG		08H	+4.21	TEH	TEC	560DT	3		COLD
		21.81		8	SLG		TSC	+0.80	TEH	TEC	560DT	3		COLD
48	29	21.94		8	SLG		TSC	+0.89	TEH	TEC	560DT	5		COLD
48	30	22.90		8	SLG		TSC	+0.89	TEH	TEC	560DT	5		COLD
48	31				NDD				TSH	TSH	560PP	28		HOT
		20.18		8	SLG		TSC	+0.72	TEH	TEC	560DT	5		COLD
48	32				NDD				TSH	TSH	560PP	28		HOT
		21.00		8	SLG		TSC	+0.69	TEH	TEC	560DT	5		COLD
48	33				NDD				TSH	TSH	560PP	28		HOT
		19.63		8	SLG		TSC	+0.63	TEH	TEC	560DT	5		COLD
48	34	19.23		8	SLG		TSC	+0.62	TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
48	35	17.58		8	SLG		TSC	+0.55	TEH	TEC	560DT	5		COLD
48	36	18.16		8	SLG		TSC	+0.58	TEH	TEC	560DT	5		COLD
48	37	19.59		8	SLG		TSC	+0.71	TEH	TEC	560DT	5		COLD
48	38	20.86		8	SLG		TSC	+0.80	TEH	TEC	560DT	6		COLD
48	39	20.98		8	SLG		TSC	+0.78	TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
48	40				NDD				TSH	TSH	560PP	28		HOT
		20.59		8	SLG		TSC	+0.66	TEH	TEC	560DT	5		COLD
48	41	21.54		8	SLG		TSC	+0.77	TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
48	42				NDD				TSH	TSH	560PP	28		HOT
		21.36		8	SLG		TSC	+0.68	TEH	TEC	560DT	8		COLD
48	43	0.29	88	3	NQH		05C	+34.20	TEH	TEC	560DT	8		COLD
		20.89		8	SLG		TSC	+0.74	TEH	TEC	560DT	8		COLD
48	44	21.70		8	SLG		TSC	+0.73	TEH	TEC	560DT	7		COLD
48	45	21.80		8	SLG		TSC	+0.75	TEH	TEC	560DT	8		COLD
48	46	22.01		8	SLG		TSC	+0.73	TEH	TEC	560DT	8		COLD
48	47				NDD				TSH	TSH	560PP	31		HOT
		22.34		8	SLG		TSC	+0.76	TEH	TEC	560DT	8		COLD
48	48				NDD				TSH	TSH	560PP	31		HOT
		23.05		8	SLG		TSC	+0.81	TEH	TEC	560DT	8		COLD
48	49				NDD				TSH	TSH	560PP	31		HOT
		24.81		8	SLG		TSC	+0.86	TEH	TEC	560DT	8		COLD
48	50				NDD				TEH	TEC	560DT	8		COLD
		23.46		8	SLG		TSC	+0.88	TEH	TEC	560DT	8		COLD
48	51	23.04		8	SLG		TSC	+0.81	TEH	TEC	560DT	7		COLD
48	52	23.13		8	SLG		TSC	+0.81	TEH	TEC	560DT	8		COLD
48	53	22.78		8	SLG		TSC	+0.80	TEH	TEC	560DT	8		COLD
48	54	22.48		8	SLG		TSC	+0.75	TEH	TEC	560DT	8		COLD
48	55				NDD				TSH	TSH	560PP	30		HOT
		22.33		8	SLG		TSC	+0.75	TEH	TEC	560DT	8		COLD
48	56	22.12		8	SLG		TSC	+0.70	TEH	TEC	560DT	7		COLD
					NDD				TSH	TSH	560PP	31		HOT
48	57				NDD				TSH	TSH	560PP	30		HOT
		22.17		8	SLG		TSC	+0.72	TEH	TEC	560DT	8		COLD
48	58	21.78		8	SLG		TSC	+0.68	TEH	TEC	560DT	7		COLD
					NDD				TSH	TSH	560PP	31		HOT
48	59	22.89		8	SLG		TSC	+0.72	TEH	TEC	560DT	8		COLD
48	60	22.31		8	SLG		TSC	+0.73	TEH	TEC	560DT	7		COLD
48	61	23.07		8	SLG		TSC	+0.75	TEH	TEC	560DT	10		COLD
48	62	22.17		8	SLG		TSC	+0.75	TEH	TEC	560DT	9		COLD
48	63				NDD				TSH	TSH	560PP	50		HOT
		22.80		8	SLG		TSC	+0.75	TEH	TEC	560DT	10		COLD
48	64				NDD				TSH	TSH	560PP	24		HOT
		22.76		8	SLG		TSC	+0.80	TEH	TEC	560DT	9		COLD
48	65				NDD				TSH	TSH	560PP	24		HOT
		23.35		8	SLG		TSC	+0.83	TEH	TEC	560DT	10		COLD
48	66				NDD				TSH	TSH	560PP	24		HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
48	67	23.18		8	SLG		TSC	+0.88	TEH	TEC	560DT	9		COLD
48	67	24.91		8	SLG		TSC	+0.98	TEH	TEC	560DT	10		COLD
48	68	24.73		8	SLG		TSC	+1.01	TEH	TEC	560DT	9		COLD
48	69	25.18		8	SLG		TSC	+1.13	TEH	TEC	560DT	10		COLD
48	70	25.52		8	SLG		TSC	+1.13	TEH	TEC	560DT	10		COLD
48	71				NDD				TSH	TSH	560PP	24		HOT
		25.44		8	SLG		TSC	+1.20	TEH	TEC	560DT	10		COLD
48	72				NDD				TSH	TSH	560PP	24		HOT
		24.33		8	SLG		TSC	+1.13	TEH	TEC	560DT	10		COLD
48	73				NDD				TSH	TSH	560PP	24		HOT
		24.51		8	SLG		TSC	+1.18	TEH	TEC	560DT	10		COLD
48	74				NDD				TSH	TSH	560PP	24		HOT
		24.71		8	SLG		TSC	+1.09	TEH	TEC	560DT	10		COLD
48	75	23.52		8	SLG		TSC	+1.12	TEH	TEC	560DT	12		COLD
48	76	23.66		8	SLG		TSC	+1.09	TEH	TEC	560DT	12		COLD
48	77	23.32		8	SLG		TSC	+1.07	TEH	TEC	560DT	12		COLD
48	78	22.94		8	SLG		TSC	+1.01	TEH	TEC	560DT	11		COLD
48	79				RBD				TSH	TSH	560PP	23		HOT
					NDD				TSH	TSH	560PS	90		HOT
		15.65		8	SLG		TSH	+0.47	TEH	TEC	560DT	12		COLD
		23.16		8	SLG		TSC	+1.06	TEH	TEC	560DT	12		COLD
48	80				NDD				TSH	TSH	560PP	24		HOT
		24.13		8	SLG		TSC	+1.14	TEH	TEC	560DT	12		COLD
48	81				NDD				TSH	TSH	560PP	27		HOT
		15.35		8	SLG		TSH	+0.45	TEH	TEC	560DT	12		COLD
		23.40		8	SLG		TSC	+1.13	TEH	TEC	560DT	12		COLD
		0.45	117	3	INR		04H	+35.12	TEH	TEC	560DT	12		COLD
48	82				NDD				TSH	TSH	560PP	27		HOT
		22.49		8	SLG		TSC	+0.91	TEH	TEC	560DT	11		COLD
48	83	20.76		8	SLG		TSC	+0.69	TEH	TEC	560DT	15		COLD
48	84	20.72		8	SLG		TSC	+0.70	TEH	TEC	560DT	14		COLD
48	85	19.50		8	SLG		TSC	+0.56	TEH	TEC	560DT	15		COLD
				3	NDF		TSH	+9.37	01H	TEH	560PP	58		HOT
				3	NDF		TSH	+15.75	01H	TEH	560PP	58		HOT
48	86	19.31		8	SLG		TSC	+0.59	TEH	TEC	560DT	15		COLD
48	87	21.39		8	SLG		TSC	+0.67	TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	27		HOT
48	88	21.55		8	SLG		TSC	+0.67	TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	27		HOT
48	89	20.89		8	SLG		TSC	+0.64	TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	26		HOT
48	90				NDD				TSH	TSH	560PP	27		HOT
		21.20		8	SLG		TSC	+0.70	TEH	TEC	560DT	14		COLD
48	91	19.48		8	SLG		TSC	+0.59	TEH	TEC	560DT	15		COLD
48	92	18.78		8	SLG		TSC	+0.55	TEH	TEC	560DT	14		COLD
48	93	17.38		8	SLG		TSC	+0.52	TEH	TEC	560DT	15		COLD
48	94	16.29		8	SLG		TSC	+0.46	TEH	TEC	560DT	15		COLD
48	96				NDD				TSH	TSH	560PP	27		HOT
		0.59	0	P 2	TWD	15	AV5	+0.05	TEH	TEC	560DT	14		COLD
48	97	0.56	44	1	INR		08H	+4.31	TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	27		HOT
49	27			3	NDF		TSH	+3.88	01H	TEH	560PP	57		HOT
		19.70		8	SLG		TSC	+0.64	TEH	TEC	560DT	3		COLD
49	28	21.12		8	SLG		TSC	+0.78	TEH	TEC	560UL	4		COLD
49	29	21.47		8	SLG		TSC	+0.80	TEH	TEC	560DT	5		COLD
49	30	21.00		8	SLG		TSC	+0.74	TEH	TEC	560DT	6		COLD
49	31	21.02		8	SLG		TSC	+0.69	TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
				3	NDF		TSH	+13.75	01H	TEH	560PP	57		HOT
				3	NDF		TSH	+12.24	01H	TEH	560PP	57		HOT
49	32	19.47		8	SLG		TSC	+0.61	TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
49	33	18.89		8	SLG		TSC	+0.60	TEH	TEC	560DT	6		COLD
		0.63	145	P 1	INR		08C	-0.60	TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
49	34				NDD				TSH	TSH	560PP	28		HOT
		18.28		8	SLG		TSC	+0.55	TEH	TEC	560DT	5		COLD
49	35	17.93		8	SLG		TSC	+0.54	TEH	TEC	560DT	6		COLD
49	36	18.79		8	SLG		TSC	+0.60	TEH	TEC	560DT	6		COLD
		4.05	180	1	DNG		08C	+0.85	TEH	TEC	560DT	6		COLD
49	37	19.84		8	SLG		TSC	+0.63	TEH	TEC	560DT	6		COLD
49	38	3.24	175	P 1	DNT		08C	+0.35	TEH	TEC	560DT	5		COLD
		20.61		8	SLG		TSC	+0.74	TEH	TEC	560DT	5		COLD
49	39				NDD				TSH	TSH	560PP	28		HOT
		21.37		8	SLG		TSC	+0.74	TEH	TEC	560DT	5		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
49	40	21.82		8	SLG		TSC		TEH	TEC	560DT	6		COLD
		6.16	184	1	DNG		08H		TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
49	41				NDD				TSH	TSH	560PP	28		HOT
		7.10	182	1	DNG		08H		TEH	TEC	560DT	5		COLD
		21.49		8	SLG		TSC		TEH	TEC	560DT	5		COLD
49	42				NDD				TSH	TSH	560PP	28		HOT
		5.60	183	1	DNG		08H		TEH	TEC	560DT	7		COLD
		21.58		8	SLG		TSC		TEH	TEC	560DT	7		COLD
49	43	21.51		8	SLG		TSC		TEH	TEC	560DT	7		COLD
		8.86	185	1	DNG		08H		TEH	TEC	560DT	7		COLD
49	44	23.74		8	SLG		TSC		TEH	TEC	560DT	8		COLD
		0.37	105	3	INR		03H		TEH	TEC	560DT	8		COLD
49	45	23.91		8	SLG		TSC		TEH	TEC	560DT	7		COLD
49	46			3	NDF		TSH		TSH	TEH	560PP	57		HOT
		24.01		8	SLG		TSC		TEH	TEC	560DT	7		COLD
49	47				NDD				TSH	TSH	560PP	30		HOT
		24.48		8	SLG		TSC		TEH	TEC	560DT	7		COLD
49	48				RBD				TSH	TSH	560PP	30		HOT
		24.60		8	SLG		TSC		TEH	TEC	560DT	7		COLD
		1.93	167	1	INR		AV6		TEH	TEC	560DT	7		COLD
					NDD				TSH	TSH	560PP	51		HOT
49	49				NDD				TSH	TSH	560PP	30		HOT
		24.87		8	SLG		TSC		TEH	TEC	560DT	7		COLD
49	50				NDD				TSH	TSH	560PP	30		HOT
		24.20		8	SLG		TSC		TEH	TEC	560DT	7		COLD
49	51	0.56	107	3	INR		TSC		TEH	TEC	560DT	8		COLD
49	52	24.05		8	SLG		TSC		TEH	TEC	560DT	7		COLD
49	53	25.07		8	SLG		TSC		TEH	TEC	560DT	7		COLD
49	54	24.74		8	SLG		TSC		TEH	TEC	560DT	7		COLD
49	55	25.25		8	SLG		TSC		TEH	TEC	560DT	7		COLD
		4.76	10	1	IDC		TSC		TEH	TEC	560DT	7		COLD
					NDD				TSH	TSH	560PP	31		HOT
49	56				NDD				TSH	TSH	560PP	30		HOT
		24.70		8	SLG		TSC		TEH	TEC	560DT	8		COLD
49	57	24.28		8	SLG		TSC		TEH	TEC	560DT	7		COLD
					NDD				TSH	TSH	560PP	31		HOT
49	58				NDD				TSH	TSH	560PP	30		HOT
		23.97		8	SLG		TSC		TEH	TEC	560DT	8		COLD
49	59	23.48		8	SLG		TSC		TEH	TEC	560DT	7		COLD
49	60	24.38		8	SLG		TSC		TEH	TEC	560DT	8		COLD
49	61	24.67		8	SLG		TSC		TEH	TEC	560DT	9		COLD
49	62	25.90		8	SLG		TSC		TEH	TEC	560DT	10		COLD
		0.66	0	P 2	TWD	18	AV1		TEH	TEC	560DT	10		COLD
		1.04	0	P 2	TWD	25	AV2		TEH	TEC	560DT	10		COLD
		1.34	0	P 2	TWD	29	AV3		TEH	TEC	560DT	10		COLD
		0.86	0	P 2	TWD	22	AV4		TEH	TEC	560DT	10		COLD
49	63				NDD				TSH	TSH	560PP	23		HOT
		25.64		8	SLG		TSC		TEH	TEC	560DT	9		COLD
49	64				NDD				TSH	TSH	560PP	24		HOT
		1.86	164	1	INR		06H		TEH	TEC	560DT	10		COLD
		25.26		8	SLG		TSC		TEH	TEC	560DT	10		COLD
49	65				NDD				TSH	TSH	560PP	24		HOT
		25.38		8	SLG		TSC		TEH	TEC	560DT	9		COLD
49	66				NDD				TSH	TSH	560PP	23		HOT
		0.66	0	P 2	TWD	18	AV3		TEH	TEC	560DT	10		COLD
		1.75	0	P 2	TWD	34	AV2		TEH	TEC	560DT	10		COLD
		25.96		8	SLG		TSC		TEH	TEC	560DT	10		COLD
49	67	0.69	0	P 2	TWD	22	AV2		TEH	TEC	560DT	9		COLD
		0.68	0	P 2	TWD	21	AV3		TEH	TEC	560DT	9		COLD
		25.96		8	SLG		TSC		TEH	TEC	560DT	9		COLD
49	68	26.96		8	SLG		TSC		TEH	TEC	560DT	10		COLD
49	69	3.27	184	1	DNG		AV6		TEH	TEC	560DT	9		COLD
		0.45	0	P 2	TWD	16	AV2		TEH	TEC	560DT	9		COLD
		26.73		8	SLG		TSC		TEH	TEC	560DT	9		COLD
49	70	26.46		8	SLG		TSC		TEH	TEC	560DT	9		COLD
		0.52	0	P 2	TWD	17	AV2		TEH	TEC	560DT	9		COLD
49	71				NDD				TSH	TSH	560PP	23		HOT
		26.04		8	SLG		TSC		TEH	TEC	560DT	9		COLD
49	72				NDD				TSH	TSH	560PP	23		HOT
		25.28		8	SLG		TSC		TEH	TEC	560DT	9		COLD
49	73				NDD				TSH	TSH	560PP	23		HOT
		25.05		8	SLG		TSC		TEH	TEC	560DT	9		COLD
49	74				NDD				TSH	TSH	560PP	23		HOT
		24.05		8	SLG		TSC		TEH	TEC	560DT	9		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
49	75	23.34		8	SLG		TSC	+1.12	TEH	TEC	560DT	11		COLD
49	76	23.74		8	SLG		TSC	+1.08	TEH	TEC	560DT	11		COLD
49	77	23.22		8	SLG		TSC	+1.16	TEH	TEC	560DT	11		COLD
49	78	15.69		8	SLG		TSH	+0.47	TEH	TEC	560DT	12		COLD
		23.38		8	SLG		TSC	+1.08	TEH	TEC	560DT	12		COLD
49	79				NDD				TSH	TSH	560PP	24		HOT
		3.67	187	1	DNG		AV1	+17.00	TEH	TEC	560DT	11		COLD
		23.60		8	SLG		TSC	+0.99	TEH	TEC	560DT	11		COLD
49	80				NDD				TSH	TSH	560PP	24		HOT
		22.67		8	SLG		TSC	+0.96	TEH	TEC	560DT	11		COLD
49	81				NDD				TSH	TSH	560PP	26		HOT
		22.33		8	SLG		TSC	+0.85	TEH	TEC	560DT	11		COLD
49	82				NDD				TSH	TSH	560PP	26		HOT
		20.20		8	SLG		TSC	+0.65	TEH	TEC	560DT	11		COLD
49	83				NDD				TEH	TEC	560DT	14		COLD
49	84				NDD				TEH	TEC	560DT	15		COLD
49	85				NDD				TEH	TEC	560DT	14		COLD
49	86				NDD				TEH	TEC	560DT	14		COLD
49	87				NDD				TSH	TSH	560PP	26		HOT
					NDD				TEH	TEC	560DT	14		COLD
49	88				NDD				TEH	TEC	560DT	14		COLD
					NDD				TSH	TSH	560PP	26		HOT
49	89				NDD				TSH	TSH	560PP	27		HOT
		16.63		8	SLG		TSC	+0.49	TEH	TEC	560DT	14		COLD
		5.91	187	1	DNG		05H	+22.61	TEH	TEC	560DT	14		COLD
				3	NDF		05H	+22.61	06H	05H	560PP	58		HOT
49	90	17.93		8	SLG		TSC	+0.52	TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	26		HOT
49	91				NDD				TEH	TEC	560DT	14		COLD
49	92				NDD				TEH	TEC	560DT	15		COLD
49	93				NDD				TEH	TEC	560DT	14		COLD
49	94				NDD				TEH	TEC	560DT	14		COLD
49	95	0.75		P 2	TWD	20	AV2	+0.16	TEH	TEC	560DT	14		COLD
		0.69		P 2	TWD	19	AV3	+0.00	TEH	TEC	560DT	14		COLD
		0.34		P 2	TWD	10	AV4	+0.03	TEH	TEC	560DT	14		COLD
					NDD				TSH	TSH	560PP	26		HOT
49	96				NDD				TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	27		HOT
50	28	16.47		8	SLG		TSC	+0.47	TEH	TEC	560DT	3		COLD
50	29	20.12		8	SLG		TSC	+0.66	TEH	TEC	560DT	5		COLD
50	30	3.07	181	P 1	DNT		AV5	+0.14	TEH	TEC	560DT	5		COLD
		20.24		8	SLG		TSC	+0.67	TEH	TEC	560DT	5		COLD
50	31				NDD				TSH	TSH	560PP	28		HOT
		18.87		8	SLG		TSC	+0.58	TEH	TEC	560DT	5		COLD
50	32			3	NDF		TSH	+2.95	01H	TEH	560PP	57		HOT
					NDD				TSH	TSH	560PP	28		HOT
		17.30		8	SLG		TSC	+0.50	TEH	TEC	560DT	5		COLD
				3	NDF		TSH	+4.63	01H	TEH	560PP	57		HOT
				3	NDF		TSH	+3.96	01H	TEH	560PP	57		HOT
50	33				NDD				TSH	TSH	560PP	28		HOT
		17.32		8	SLG		TSC	+0.50	TEH	TEC	560DT	5		COLD
50	34	16.51		8	SLG		TSC	+0.49	TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
50	35	17.11		8	SLG		TSC	+0.49	TEH	TEC	560DT	5		COLD
50	36	16.91		8	SLG		TSC	+0.49	TEH	TEC	560DT	5		COLD
50	37	20.02		8	SLG		TSC	+0.66	TEH	TEC	560DT	5		COLD
50	38	21.14		8	SLG		TSC	+0.74	TEH	TEC	560DT	6		COLD
50	39	22.34		8	SLG		TSC	+0.83	TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
50	40				NDD				TSH	TSH	560PP	28		HOT
		22.23		8	SLG		TSC	+0.77	TEH	TEC	560DT	5		COLD
50	41	24.22		8	SLG		TSC	+0.90	TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
50	42				RBD				TSH	TSH	560PP	28		HOT
		22.25		8	SLG		TSC	+0.81	TEH	TEC	560DT	8		COLD
					NDD				TSH	TSH	560PP	50		HOT
50	43	23.31		8	SLG		TSC	+0.84	TEH	TEC	560DT	8		COLD
50	44	22.79		8	SLG		TSC	+0.83	TEH	TEC	560DT	7		COLD
50	45	23.74		8	SLG		TSC	+0.94	TEH	TEC	560DT	8		COLD
50	46	24.17		8	SLG		TSC	+0.97	TEH	TEC	560DT	8		COLD
50	47				NDD				TSH	TSH	560PP	31		HOT
		25.03		8	SLG		TSC	+1.02	TEH	TEC	560DT	8		COLD
50	48				NDD				TSH	TSH	560PP	31		HOT
		25.70		8	SLG		TSC	+1.04	TEH	TEC	560DT	8		COLD
50	49				NDD				TSH	TSH	560PP	31		HOT

Master Report

QUERY: QueryMI

ROW	COL	VOLTS	DEG	CHN	IND	§TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		26.13		8	SLG		TSC	+1.06	TEH	TEC	560DT	8		COLD
50	50				NDD				TSH	TSH	560PP	31		HOT
		25.97		8	SLG		TSC	+1.06	TEH	TEC	560DT	8		COLD
50	51	3.58	188	1	DNG		05C	+26.18	TEH	TEC	560DT	7		COLD
50	52	26.15		8	SLG		TSC	+1.06	TEH	TEC	560DT	8		COLD
50	53	26.01		8	SLG		TSC	+1.04	TEH	TEC	560DT	8		COLD
50	54	26.13		8	SLG		TSC	+1.01	TEH	TEC	560DT	8		COLD
50	55				NDD				TSH	TSH	560PP	30		HOT
		25.52		8	SLG		TSC	+0.98	TEH	TEC	560DT	8		COLD
50	56	25.05		8	SLG		TSC	+0.95	TEH	TEC	560DT	7		COLD
					NDD				TSH	TSH	560PP	31		HOT
50	57				NDD				TSH	TSH	560PP	30		HOT
		25.09		8	SLG		TSC	+0.93	TEH	TEC	560DT	8		COLD
50	58	25.96		8	SLG		TSC	+0.93	TEH	TEC	560DT	7		COLD
					NDD				TSH	TSH	560PP	31		HOT
50	59	26.19		8	SLG		TSC	+1.01	TEH	TEC	560DT	8		COLD
50	60	0.91	75	6	INR		TSH	+13.15	TEH	TEC	560DT	7		COLD
50	61	26.60		8	SLG		TSC	+1.04	TEH	TEC	560DT	10		COLD
50	62	26.04		8	SLG		TSC	+1.04	TEH	TEC	560DT	9		COLD
50	63				NDD				TSH	TSH	560PP	50		HOT
		0.79	90	3	NQH		01C	+1.65	TEH	TEC	560DT	10		COLD
		26.66		8	SLG		TSC	+0.98	TEH	TEC	560DT	10		COLD
50	64				NDD				TSH	TSH	560PP	24		HOT
		26.38		8	SLG		TSC	+1.03	TEH	TEC	560DT	9		COLD
50	65				NDD				TSH	TSH	560PP	24		HOT
		26.66		8	SLG		TSC	+1.03	TEH	TEC	560DT	10		COLD
50	66				NDD				TSH	TSH	560PP	24		HOT
		26.38		8	SLG		TSC	+1.00	TEH	TEC	560DT	9		COLD
50	67	27.20		8	SLG		TSC	+1.14	TEH	TEC	560DT	10		COLD
50	68	26.91		8	SLG		TSC	+1.12	TEH	TEC	560DT	9		COLD
50	69	1.25	82	6	INR		03C	+23.57	TEH	TEC	560DT	10		COLD
		27.08		8	SLG		TSC	+1.18	TEH	TEC	560DT	10		COLD
50	70	27.12		8	SLG		TSC	+1.24	TEH	TEC	560DT	10		COLD
50	71				NDD				TSH	TSH	560PP	24		HOT
		27.33		8	SLG		TSC	+1.28	TEH	TEC	560DT	10		COLD
50	72				NDD				TSH	TSH	560PP	24		HOT
		25.40		8	SLG		TSC	+1.12	TEH	TEC	560DT	10		COLD
50	73				NDD				TSH	TSH	560PP	24		HOT
		25.78		8	SLG		TSC	+1.17	TEH	TEC	560DT	10		COLD
50	74				NDD				TSH	TSH	560PP	24		HOT
		0.66	109	3	INR		04H	+9.01	TEH	TEC	560DT	10		COLD
		24.97		8	SLG		TSC	+1.09	TEH	TEC	560DT	10		COLD
50	75				NDD				TEH	TEC	560UL	46		COLD
					RBD				TEH	TEC	560DT	12		COLD
50	76	23.89		8	SLG		TSC	+1.06	TEH	TEC	560DT	12		COLD
50	77	23.50		8	SLG		TSC	+1.00	TEH	TEC	560DT	12		COLD
50	78	23.50		8	SLG		TSC	+0.93	TEH	TEC	560DT	11		COLD
50	79				RBD				TSH	TSH	560PP	23		HOT
					NDD				TSH	TSH	560PS	90		HOT
		22.92		8	SLG		TSC	+0.99	TEH	TEC	560DT	12		COLD
50	80				NDD				TSH	TSH	560PP	24		HOT
		24.03		8	SLG		TSC	+0.86	TEH	TEC	560DT	12		COLD
50	81				NDD				TSH	TSH	560PP	27		HOT
		3.16	172	P 1	DNT		08C	-0.38	TEH	TEC	560DT	12		COLD
		19.81		8	SLG		TSC	+0.62	TEH	TEC	560DT	12		COLD
50	82				NDD				TSH	TSH	560PP	27		HOT
					NDD				TEH	TEC	560DT	11		COLD
50	83				NDD				TEH	TEC	560DT	15		COLD
50	84				NDD				TEH	TEC	560DT	14		COLD
50	85				NDD				TEH	TEC	560DT	15		COLD
50	86				NDD				TEH	TEC	560DT	15		COLD
					NDD				TEH	TSH	560PP	26		HOT
50	87				NDD				TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	27		HOT
50	88	0.45	111	3	NQH		03C	+1.70	TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	27		HOT
50	89	1.31	112	3	INR		05H	+10.30	TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	26		HOT
50	90				NDD				TSH	TSH	560PP	27		HOT
					NDD				TEH	TEC	560DT	14		COLD
50	91	4.23	185	1	DNG		07H	+25.13	TEH	TEC	560DT	15		COLD
				3	NDF		07H	+25.13	08H	07H	560PP	58		HOT
50	92				NDD				TEH	TEC	560DT	14		COLD
50	93	10.55	184	P 1	DNT		AV4	-0.08	TEH	TEC	560DT	15		COLD
				P 2	INF		AV6	+0.00	TEH	TEC	560DT	15	HR	COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
50	94				NDD			TEH	TEC	560DT	15			COLD
50	95				NDD			TEH	TEC	560DT	15			COLD
					NDD			TSH	TSH	560PP	27			HOT
51	31				NDD			TSH	TSH	560PP	28			HOT
		16.62		8	SLG		TSC	TEH	TEC	560DT	5			COLD
		3.40		183	P 1	DNT	AV5	TEH	TEC	560DT	5			COLD
51	32				NDD			TEH	TEC	560DT	6			COLD
					NDD			TSH	TSH	560PP	28			HOT
51	33	15.29		8	SLG		TSC	TEH	TEC	560DT	6			COLD
					NDD			TSH	TSH	560PP	28			HOT
51	34				NDD			TEH	TEC	560DT	5			COLD
					NDD			TEH	TEC	560DT	6			COLD
51	35	15.49		8	SLG		TSC	TEH	TEC	560DT	6			COLD
51	36	16.89		8	SLG		TSC	TEH	TEC	560DT	6			COLD
51	37	18.85		8	SLG		TSC	TEH	TEC	560DT	6			COLD
51	38	21.06		8	SLG		TSC	TEH	TEC	560DT	5			COLD
51	39				NDD			TSH	TSH	560PP	28			HOT
		22.06		8	SLG		TSC	TEH	TEC	560DT	5			COLD
51	40	22.72		8	SLG		TSC	TEH	TEC	560DT	6			COLD
					NDD			TSH	TSH	560PP	28			HOT
51	41				NDD			TSH	TSH	560PP	28			HOT
		23.88		8	SLG		TSC	TEH	TEC	560DT	5			COLD
51	42				RBD			TSH	TSH	560PP	28			HOT
		5.30		191	P 1	INR	08H	TEH	TEC	560DT	7			COLD
		24.42		8	SLG		TSC	TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	51			HOT
51	43	23.49		8	SLG		TSC	TEH	TEC	560DT	7			COLD
51	44	24.76		8	SLG		TSC	TEH	TEC	560DT	8			COLD
51	47				NDD			TSH	TSH	560PP	30			HOT
		25.62		8	SLG		TSC	TEH	TEC	560DT	7			COLD
51	48				NDD			TSH	TSH	560PP	30			HOT
		24.72		8	SLG		TSC	TEH	TEC	560DT	7			COLD
51	49				NDD			TSH	TSH	560PP	30			HOT
		25.25		8	SLG		TSC	TEH	TEC	560DT	7			COLD
51	50				NDD			TSH	TSH	560PP	30			HOT
					NDD			TEH	TEC	560DT	7			COLD
51	51	26.46		8	SLG		TSC	TEH	TEC	560DT	8			COLD
51	52				NDD			TSC	TSC	560PS	113			COLD
					NDD			TEH	TEC	560DT	7			COLD
51	53				NDD			TSC	TSC	560PS	113			COLD
					NDD			TEH	TEC	560DT	7			COLD
51	54				NDD			TSC	TSC	560PS	113			COLD
					NDD			TEH	TEC	560DT	7			COLD
51	55				NDD			TSC	TSC	560PS	113			COLD
		26.23		8	SLG		TSC	TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	31			HOT
51	56				RBD			TSH	TSH	560PP	30			HOT
		26.09		8	SLG		TSC	TEH	TEC	560DT	8			COLD
					NDD			TSH	TSH	560PP	50			HOT
51	57				NDD			TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	31			HOT
51	58				NDD			TSH	TSH	560PP	30			HOT
		25.78		8	SLG		TSC	TEH	TEC	560DT	8			COLD
51	59	25.80		8	SLG		TSC	TEH	TEC	560DT	7			COLD
51	60	26.52		8	SLG		TSC	TEH	TEC	560DT	8			COLD
51	61	3.48		177	1	DNG	06C	TEH	TEC	560DT	9			COLD
		27.73		8	SLG		TSC	TEH	TEC	560DT	9			COLD
51	62	27.18		8	SLG		TSC	TEH	TEC	560DT	10			COLD
51	63				NDD			TSH	TSH	560PP	23			HOT
		26.81		8	SLG		TSC	TEH	TEC	560DT	9			COLD
51	64				NDD			TSH	TSH	560PP	24			HOT
		27.61		8	SLG		TSC	TEH	TEC	560DT	10			COLD
51	65				NDD			TSH	TSH	560PP	24			HOT
		26.91		8	SLG		TSC	TEH	TEC	560DT	9			COLD
51	66				NDD			TSH	TSH	560PP	23			HOT
		26.44		8	SLG		TSC	TEH	TEC	560DT	10			COLD
51	67	26.40		8	SLG		TSC	TEH	TEC	560DT	9			COLD
51	68	0.71		95	2	VOL	AV4	AV4	AV6	5201P	111			COLD
		0.93		103	2	VOL	AV4	AV4	AV6	5201P	111			COLD
		0.51		96	2	VOL	AV5	AV4	AV6	5201P	111			COLD
		1.07		108	2	VOL	AV5	AV4	AV6	5201P	111			COLD
		0.73		102	2	VOL	AV6	AV4	AV6	5201P	111			COLD
		2.33		0	P 2	PID	AV5	TEH	TEC	560UL	46			COLD
		0.56		0	P 2	TWD	16 AV1	TEH	TEC	560DT	10			COLD
		2.05		0	P 2	TWD	37 AV2	TEH	TEC	560DT	10			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	#TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		1.26	0	P 2	TWD	28	AV3		TEH	TEC	560DT	10		COLD
		3.34	0	P 2	TWD	44	AV4		TEH	TEC	560DT	10		COLD
		2.46	0	P 2	TWD	40	AV5		TEH	TEC	560DT	10		COLD
		2.22	0	P 2	TWD	38	AV6		TEH	TEC	560DT	10		COLD
		27.31		8	SLG		TSC		TEH	TEC	560DT	10		COLD
51	69	27.47		8	SLG		TSC		TEH	TEC	560DT	9		COLD
51	70	27.17		8	SLG		TSC		TEH	TEC	560DT	9		COLD
51	71				NDD				TSH	TSH	560PP	23		HOT
		26.99		8	SLG		TSC		TEH	TEC	560DT	9		COLD
51	72				NDD				TSH	TSH	560PP	23		HOT
		26.52		8	SLG		TSC		TEH	TEC	560DT	9		COLD
51	73				NDD				TSH	TSH	560PP	23		HOT
		25.38		8	SLG		TSC		TEH	TEC	560DT	9		COLD
51	74				NDD				TSH	TSH	560PP	23		HOT
		24.23		8	SLG		TSC		TEH	TEC	560DT	9		COLD
51	75	4.85	183	1	DNG		TSH		TEH	TEC	560DT	11		COLD
		23.60		8	SLG		TSC		TEH	TEC	560DT	11		COLD
				3	NDF		TSH		01H	TSH	560PP	58		HOT
51	76	24.04		8	SLG		TSC		TEH	TEC	560DT	11		COLD
51	77	23.28		8	SLG		TSC		TEH	TEC	560DT	11		COLD
51	78	24.41		8	SLG		TSC		TEH	TEC	560DT	12		COLD
51	79				NDD				TSH	TSH	560PP	24		HOT
		22.63		8	SLG		TSC		TEH	TEC	560DT	11		COLD
51	80				NDD				TSH	TSH	560PP	24		HOT
		19.54		8	SLG		TSC		TEH	TEC	560DT	11		COLD
51	82				NDD				TSH	TSH	560PP	26		HOT
					NDD				TEH	TEC	560DT	11		COLD
51	83	0.42	51	1	TFH		08H		TEH	TEC	560DT	14		COLD
51	84				NDD				TEH	TEC	560DT	15		COLD
51	85	0.33	108	3	NQH		02C		TEH	TEC	560DT	14		COLD
51	86				NDD				TEH	TEC	560DT	14		COLD
51	87				NDD				TSH	TSH	560PP	26		HOT
					NDD				TEH	TEC	560DT	14		COLD
51	88				NDD				TEH	TEC	560DT	14		COLD
					NDD				TSH	TSH	560PP	26		HOT
51	89				NDD				TSH	TSH	560PP	27		HOT
		0.59		P 2	TWD	17	AV6		TEH	TEC	560DT	14		COLD
51	90	5.03	187	1	DNG		TSH		TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	26		HOT
51	91				NDD				TEH	TEC	560DT	14		COLD
51	92	3.50	182	P 1	DNT		AV4		TEH	TEC	560DT	15		COLD
		0.64	64	3	INR		08H		TEH	TEC	560DT	15		COLD
				2	NDF		08H		AV1	08H	5201P	72		HOT
52	32				NDD				TSH	TSH	560PP	28		HOT
					NDD				TEH	TEC	560DT	5		COLD
52	33				NDD				TSH	TSH	560PP	28		HOT
					NDD				TEH	TEC	560DT	5		COLD
52	34				NDD				TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
52	35	0.71	114	3	INR		06C		TEH	TEC	560DT	5		COLD
52	36	17.42		8	SLG		TSC		TEH	TEC	560DT	5		COLD
52	37	19.44		8	SLG		TSC		TEH	TEC	560DT	5		COLD
52	38	20.90		8	SLG		TSC		TEH	TEC	560DT	6		COLD
52	39	22.14		8	SLG		TSC		TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
52	40				NDD				TSH	TSH	560PP	28		HOT
		22.16		8	SLG		TSC		TEH	TEC	560DT	5		COLD
		0.64	120	3	INR		07C		TEH	TEC	560DT	5		COLD
		0.98	124	3	INR		06C		TEH	TEC	560DT	5		COLD
52	41	23.74		8	SLG		TSC		TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
52	42				RBD				TSH	TSH	560PP	30		HOT
		25.23		8	SLG		TSC		TEH	TEC	560DT	8		COLD
					NDD				TSH	TSH	560PP	50		HOT
52	43	24.01		8	SLG		TSC		TEH	TEC	560DT	8		COLD
52	44	24.36		8	SLG		TSC		TEH	TEC	560DT	7		COLD
52	45	24.60		8	SLG		TSC		TEH	TEC	560DT	7		COLD
52	46	25.23		8	SLG		TSC		TEH	TEC	560DT	7		COLD
52	47				NDD				TSH	TSH	560PP	31		HOT
		25.89		8	SLG		TSC		TEH	TEC	560DT	8		COLD
52	48				NDD				TSH	TSH	560PP	31		HOT
		25.25		8	SLG		TSC		TEH	TEC	560DT	8		COLD
52	49				NDD				TSH	TSH	560PP	31		HOT
		26.09		8	SLG		TSC		TEH	TEC	560DT	8		COLD
52	50				NDD				TSH	TSH	560PP	31		HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	&TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		0.48	121	1	INR		AV6			TEH TEC 560DT	8			COLD
		25.91		8	SLG		TSC			TEH TEC 560DT	8			COLD
52	51				NDD					TEH TEC 560DT	7			COLD
52	52				NDD					TSC TSC 560PS	113			COLD
		25.87		8	SLG		TSC			TEH TEC 560DT	8			COLD
52	53	0.22	86	3	PID		TSC			TSC TSC 560PS	113			COLD
		0.21	85	3	SVI		TSC			TEC TSC 560PP	108			COLD
		0.41	98	P 4	TWD 7		TSC			TSC TSC 560PP	108			COLD
		0.30	90	P 4	ARC		TSC			TSC TSC 560PP	108			COLD
		0.24	0	P 4	LEN		TSC			TSC TSC 560PP	108			COLD
		0.51	81	P 5	TWD 8		TSC			TSC TSC 560PP	108			COLD
		0.35	90	P 5	ARC		TSC			TSC TSC 560PP	108			COLD
		0.24	0	P 5	LEN		TSC			TSC TSC 560PP	108			COLD
		26.15		8	SLG		TSC			TEH TEC 560DT	8			COLD
		0.41	109	3	NQH		TSC			TEH TEC 560DT	8			COLD
		6.52	200	8	INR		TSC			TEH TEC 560DT	8			COLD
52	54	0.59	78	3	PID		TSC			TSC TSC 560PS	113			COLD
		0.54	86	3	SVI		TSC			TEC TSC 560PP	108			COLD
		1.76	52	P 4	TWD 25		TSC			TSC TSC 560PP	108			COLD
		0.38	90	P 4	ARC		TSC			TSC TSC 560PP	108			COLD
		0.34	0	P 4	LEN		TSC			TSC TSC 560PP	108			COLD
		1.65	70	P 5	TWD 23		TSC			TSC TSC 560PP	108			COLD
		0.43	90	P 5	ARC		TSC			TSC TSC 560PP	108			COLD
		0.34	0	P 5	LEN		TSC			TSC TSC 560PP	108			COLD
		26.64		8	SLG		TSC			TEH TEC 560DT	8			COLD
		1.41	129	3	NQH		TSC			TEH TEC 560DT	8			COLD
52	55				NDD					TSC TSC 560PS	113			COLD
					NDD					TSH TSH 560PP	30			HOT
		26.15		8	SLG		TSC			TEH TEC 560DT	8			COLD
52	56				NDD					TEH TEC 560DT	7			COLD
					NDD					TSH TSH 560PP	31			HOT
52	57				NDD					TSH TSH 560PP	30			HOT
		25.95		8	SLG		TSC			TEH TEC 560DT	8			COLD
52	58				NDD					TEH TEC 560DT	7			COLD
					NDD					TSH TSH 560PP	31			HOT
52	59	28.07		8	SLG		TSC			TEH TEC 560DT	8			COLD
52	60				NDD					TEH TEC 560DT	7			COLD
52	61	27.53		8	SLG		TSC			TEH TEC 560DT	10			COLD
52	62	27.37		8	SLG		TSC			TEH TEC 560DT	9			COLD
52	63				NDD					TSH TSH 560PP	50			HOT
		27.43		8	SLG		TSC			TEH TEC 560DT	10			COLD
52	64				NDD					TSH TSH 560PP	24			HOT
		26.22		8	SLG		TSC			TEH TEC 560DT	9			COLD
52	65				NDD					TSH TSH 560PP	24			HOT
		2.24	81	6	INR		03H			TEH TEC 560DT	10			COLD
		27.53		8	SLG		TSC			TEH TEC 560DT	10			COLD
52	66				NDD					TSH TSH 560PP	24			HOT
		26.32		8	SLG		TSC			TEH TEC 560DT	9			COLD
52	67	26.80		8	SLG		TSC			TEH TEC 560DT	10			COLD
52	68	26.67		8	SLG		TSC			TEH TEC 560DT	9			COLD
52	69	27.29		8	SLG		TSC			TEH TEC 560DT	10			COLD
52	70	1.95	0	P 2	PID		AV3			TEH TEC 560UL	106			COLD
		27.71		8	SLG		TSC			TEH TEC 560DT	10			COLD
		1.05	0	P 2	TWD 25		AV2			TEH TEC 560DT	10			COLD
		2.18	0	P 2	TWD 38		AV3			TEH TEC 560DT	10			COLD
		2.09	0	P 2	TWD 37		AV4			TEH TEC 560DT	10			COLD
		0.97	0	P 2	TWD 24		AV5			TEH TEC 560DT	10			COLD
		0.52	0	P 2	TWD 15		AV6			TEH TEC 560DT	10			COLD
52	71				NDD					TSH TSH 560PP	24			HOT
		26.72		8	SLG		TSC			TEH TEC 560DT	10			COLD
52	72				NDD					TSH TSH 560PP	24			HOT
		26.04		8	SLG		TSC			TEH TEC 560DT	10			COLD
52	73				NDD					TSH TSH 560PP	24			HOT
		3.08	186	1	DNG		07H			TEH TEC 560DT	10			COLD
		25.68		8	SLG		TSC			TEH TEC 560DT	10			COLD
52	74				NDD					TSH TSH 560PP	24			HOT
		24.43		8	SLG		TSC			TEH TEC 560DT	10			COLD
52	75	23.74		8	SLG		TSC			TEH TEC 560DT	12			COLD
52	76	23.44		8	SLG		TSC			TEH TEC 560DT	12			COLD
52	77	3.26	176	P 1	DNT		08C			TEH TEC 560DT	12			COLD
		23.72		8	SLG		TSC			TEH TEC 560DT	12			COLD
52	78				NDD					01C 01C 560PS	112			COLD
		22.67		8	SLG		TSC			TEH TEC 560DT	11			COLD
52	79				RBD					TSH TSH 560PP	23			HOT
					NDD					TSH TSH 560PS	90			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		19.47		8	NDD		TSC	+0.59	01C	01C	560PS	112		COLD
52	80				SLG				TEH	TEC	560DT	12		COLD
					NDD				01C	01C	560PS	112		COLD
					NDD				TSH	TSH	560PP	24		HOT
					NDD				TEH	TEC	560DT	12		COLD
52	81				NDD				TSH	TSH	560PP	26		HOT
					NDD				TEH	TEC	560DT	11		COLD
52	82				NDD				TSH	TSH	560PP	27		HOT
					NDD				TEH	TEC	560DT	12		COLD
52	83				NDD				TEH	TEC	560DT	15		COLD
52	84				NDD				TEH	TEC	560DT	14		COLD
52	85				NDD				TEH	TEC	560DT	15		COLD
52	86				NDD				TEH	TEC	560DT	15		COLD
52	87	0.59	0	P 2	TWD	16	AV5	+0.05	TEH	TEC	560DT	15		COLD
		0.25	87	3	NQH		TSH	+18.35	TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	27		HOT
52	88	0.76	0	P 2	TWD	20	AV4	+0.00	TEH	TEC	560DT	15		COLD
		0.65	0	P 2	TWD	18	AV2	+0.05	TEH	TEC	560DT	15		COLD
					NDD				TSH	TSH	560PP	27		HOT
52	91	0.37	98	3	NQH		01H	+2.53	TEH	TEC	560DT	15		COLD
53	33				NDD				TSH	TSH	560PP	28		HOT
					NDD				TEH	TEC	560DT	5		COLD
53	34				NDD				TSH	TSH	560PP	28		HOT
					NDD				TEH	TEC	560DT	5		COLD
53	35	0.38	0	P 2	TWD	12	AV4	+0.03	TEH	TEC	560DT	5		COLD
		0.50	0	P 2	TWD	15	AV5	+0.03	TEH	TEC	560DT	5		COLD
		0.41	0	P 2	TWD	12	AV6	-0.11	TEH	TEC	560DT	5		COLD
53	36				NDD				TEH	TEC	560DT	6		COLD
53	37	19.73		8	SLG		TSC	+0.58	TEH	TEC	560DT	5		COLD
53	38				NDD				TEH	TEC	560DT	5		COLD
53	39				NDD				TSH	TSH	560PP	28		HOT
		22.08		8	SLG		TSC	+0.74	TEH	TEC	560DT	5		COLD
53	40	22.88		8	SLG		TSC	+0.74	TEH	TEC	560DT	6		COLD
					NDD				TSH	TSH	560PP	28		HOT
53	41				NDD				TSH	TSH	560PP	28		HOT
		22.78		8	SLG		TSC	+0.79	TEH	TEC	560DT	5		COLD
		1.23	119	3	INR		03C	+13.77	TEH	TEC	560DT	5		COLD
53	42				NDD				TSH	TSH	560PP	31		HOT
		0.93	118	3	INR		07H	+1.61	TEH	TEC	560DT	7		COLD
		23.48		8	SLG		TSC	+0.81	TEH	TEC	560DT	7		COLD
53	43	24.12		8	SLG		TSC	+0.88	TEH	TEC	560DT	7		COLD
53	44				NDD				01C	01C	560PP	108		COLD
		24.80		8	SLG		TSC	+0.97	TEH	TEC	560DT	8		COLD
53	45				NDD				01C	01C	560PP	108		COLD
		26.11		8	SLG		TSC	+0.99	TEH	TEC	560DT	8		COLD
53	46				NDD				01C	01C	560PP	108		COLD
		24.99		8	SLG		TSC	+0.94	TEH	TEC	560DT	7		COLD
53	47				NDD				TSH	TSH	560PP	30		HOT
		25.44		8	SLG		TSC	+0.99	TEH	TEC	560DT	7		COLD
53	48				NDD				TSH	TSH	560PP	30		HOT
		26.23		8	SLG		TSC	+0.94	TEH	TEC	560DT	7		COLD
53	49				NDD				TSH	TSH	560PP	30		HOT
		25.78		8	SLG		TSC	+0.91	TEH	TEC	560DT	7		COLD
53	50				NDD				TSH	TSH	560PP	30		HOT
		27.24		8	SLG		TSC	+1.02	TEH	TEC	560DT	7		COLD
53	51	25.21		8	SLG		TSC	+0.96	TEH	TEC	560DT	8		COLD
53	52				NDD				TSC	TSC	560PS	113		COLD
					NDD				TEH	TEC	560DT	7		COLD
53	53				NDD				TSC	TSC	560PS	113		COLD
		27.00		8	SLG		TSC	+1.01	TEH	TEC	560DT	7		COLD
53	54	0.18	75	3	SVI		TSC	+0.01	TSC	TSC	560PS	113		COLD
					NDD				TEH	TEC	560DT	7		COLD
		0.64	0	P 4	TWD	13	TSC	-0.02	TSC	TSC	560PS	114		COLD
		0.33	90	P 4	ARC		TSC	-0.02	TSC	TSC	560PS	114		COLD
		0.27	0	P 4	LEN		TSC	-0.02	TSC	TSC	560PS	114		COLD
		0.46	0	P 5	TWD	9	TSC	-0.02	TSC	TSC	560PS	114		COLD
		0.33	90	P 5	ARC		TSC	-0.02	TSC	TSC	560PS	114		COLD
		0.27	0	P 5	LEN		TSC	-0.02	TSC	TSC	560PS	114		COLD
		0.14	87	3	PID		TSC	+0.01	TSC	TSC	560PS	114		COLD
53	55				NDD				TSC	TSC	560PS	113		COLD
					NDD				TEH	TEC	560DT	7		COLD
					NDD				TSH	TSH	560PP	31		HOT
53	56				NDD				TSH	TSH	560PP	30		HOT
		26.87		8	SLG		TSC	+1.12	TEH	TEC	560DT	8		COLD
53	57				NDD				TEH	TEC	560DT	7		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
53	58	26.60			NDD			TSH	TSH	560PP	31			HOT
					RBD			TSH	TSH	560PP	30			HOT
				8	SLG		TSC	TEH	TEC	560DT	8			COLD
					NDD			TSH	TSH	560PP	50			HOT
53	59				NDD			TEH	TEC	560DT	7			COLD
53	60	0.28	91	3	NQH		07C	TEH	TEC	560DT	8			COLD
		27.91		8	SLG		TSC	TEH	TEC	560DT	8			COLD
53	61	0.30	68	3	INR		07C	TEH	TEC	560DT	9			COLD
		27.73		8	SLG		TSC	TEH	TEC	560DT	9			COLD
53	62	27.39		8	SLG		TSC	TEH	TEC	560DT	10			COLD
53	63				NDD			TSH	TSH	560PP	23			HOT
		27.01		8	SLG		TSC	TEH	TEC	560DT	9			COLD
		3.16	91	6	INR		08H	TEH	TEC	560DT	9			COLD
53	64				NDD			TSH	TSH	560PP	24			HOT
		27.61		8	SLG		TSC	TEH	TEC	560DT	10			COLD
53	65				NDD			TSH	TSH	560PP	24			HOT
		1.19	110	3	INR		02H	TEH	TEC	560DT	9			COLD
		25.82		8	SLG		TSC	TEH	TEC	560DT	9			COLD
53	66				NDD			TSH	TSH	560PP	23			HOT
		26.40		8	SLG		TSC	TEH	TEC	560DT	10			COLD
53	67	26.65		8	SLG		TSC	TEH	TEC	560DT	9			COLD
53	68	26.98		8	SLG		TSC	TEH	TEC	560DT	10			COLD
53	69	26.28		8	SLG		TSC	TEH	TEC	560DT	9			COLD
53	70	26.44		8	SLG		TSC	TEH	TEC	560DT	9			COLD
53	71				NDD			TSH	TSH	560PP	23			HOT
		25.62		8	SLG		TSC	TEH	TEC	560DT	9			COLD
53	72				NDD			TSH	TSH	560PP	23			HOT
		3.95	177	P 1	DNT		08H	TEH	TEC	560DT	9			COLD
		24.55		8	SLG		TSC	TEH	TEC	560DT	9			COLD
				3	NDF		08H	08H	08H	560PP	58			HOT
53	73				NDD			TSH	TSH	560PP	23			HOT
		24.95		8	SLG		TSC	TEH	TEC	560DT	9			COLD
53	74				NDD			TSH	TSH	560PP	23			HOT
		23.91		8	SLG		TSC	TEH	TEC	560DT	9			COLD
		0.58	136	1	INR		08H	TEH	TEC	560DT	9			COLD
53	75	24.06		8	SLG		TSC	TEH	TEC	560DT	11			COLD
53	76	5.75	182	P 1	DNT		08H	TEH	TEC	560DT	11			COLD
		22.49		8	SLG		TSC	TEH	TEC	560DT	11			COLD
				3	NDF		08H	08H	08H	560PP	58			HOT
53	77	21.79		8	SLG		TSC	TEH	TEC	560DT	11			COLD
53	78				NDD			01C	01C	560PS	112			COLD
		20.86		8	SLG		TSC	TEH	TEC	560DT	12			COLD
53	79	0.20	89	3	SVI		01C	01C	01C	560PP	108			COLD
		0.18	86	11	PLP		01C	01C	01C	560PP	108			COLD
		0.18	91	3	PID		01C	01C	01C	560PS	112			COLD
		0.71	60	P 4	TWD	12	01C	01C	01C	560PP	108			COLD
		0.41	90	P 4	ARC		01C	01C	01C	560PP	108			COLD
		0.33	0	P 4	LEN		01C	01C	01C	560PP	108			COLD
		0.57	70	P 5	TWD	9	01C	01C	01C	560PP	108			COLD
		0.27	90	P 5	ARC		01C	01C	01C	560PP	108			COLD
					NDD			TSH	TSH	560PP	24			HOT
					NDD			TEH	TEC	560DT	11			COLD
53	80	0.31	0	P 5	LEN		01C	01C	01C	560PP	108			COLD
					NDD			01C	01C	560PP	108			COLD
					NDD			TSH	TSH	560PP	24			HOT
					NDD			TEH	TEC	560DT	11			COLD
53	81				NDD			01C	01C	560PP	108			COLD
					NDD			TSH	TSH	560PP	27			HOT
					NDD			TEH	TEC	560DT	12			COLD
53	82				NDD			TSH	TSH	560PP	26			HOT
					NDD			01C	01C	560PS	112			COLD
					NDD			TEH	TEC	560DT	11			COLD
53	83				NDD			TEH	TEC	560DT	14			COLD
53	84	0.66	127	3	INR		08H	TEH	TEC	560DT	15			COLD
53	85				NDD			TEH	TEC	560DT	14			COLD
53	87				NDD			TSH	TSH	560PP	26			HOT
		1.08	130	3	INR		06H	TEH	TEC	560DT	14			COLD
53	89				NDD			TEH	TEC	560DT	15			COLD
					NDD			TSH	TSH	560PP	27			HOT
54	35	6.72	185	P 1	DNT		AV5	TEH	TEC	560DT	5			COLD
54	36	15.80		8	SLG		TSC	TEH	TEC	560DT	5			COLD
54	37	0.24	0	P 2	INR		AV5	TEH	TEC	560DT	5			COLD
54	38	20.98		8	SLG		TSC	TEH	TEC	560DT	6			COLD
54	39	20.84		8	SLG		TSC	TEH	TEC	560DT	6			COLD
					NDD			TSH	TSH	560PP	28			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
54	40				NDD			TSH	TSH	560PP	28			HOT
		21.45		8	SLG		TSC	TEH	TEC	560DT	5			COLD
54	41	22.74		8	SLG		TSC	TEH	TEC	560DT	6			COLD
					NDD			TSH	TSH	560PP	28			HOT
54	42				NDD			TSH	TSH	560PP	30			HOT
		23.38		8	SLG		TSC	TEH	TEC	560DT	8			COLD
54	43	23.70		8	SLG		TSC	TEH	TEC	560DT	8			COLD
54	44				NDD			01C	01C	560PP	108			COLD
		24.70		8	SLG		TSC	TEH	TEC	560DT	7			COLD
54	45	0.29	91	3	SVI		01C	01C	01C	560PP	60			COLD
		0.30	102	3	PID		01C	01C	01C	560PP	108			COLD
		0.61	64	P 4	TWD 10		01C	01C	01C	560PP	108			COLD
		0.36	90	P 4	ARC		01C	01C	01C	560PP	108			COLD
		0.24	0	P 4	LEN		01C	01C	01C	560PP	108			COLD
		0.73	68	P 5	TWD 12		01C	01C	01C	560PP	108			COLD
		0.30	90	P 5	ARC		01C	01C	01C	560PP	108			COLD
		0.28	0	P 5	LEN		01C	01C	01C	560PP	108			COLD
		1.43	0	P 4	TWD 23		01C	01C	01C	560PP	60	LPW		COLD
		0.39	90	P 4	ARC		01C	01C	01C	560PP	60			COLD
		0.21	0	P 4	LEN		01C	01C	01C	560PP	60			COLD
		0.92	0	P 5	TWD 18		01C	01C	01C	560PP	60	LPW		COLD
		0.39	90	P 5	ARC		01C	01C	01C	560PP	60			COLD
		0.26	0	P 5	LEN		01C	01C	01C	560PP	60			COLD
		0.48	121	P 1	DSI		01C	TEH	TEC	560DT	7			COLD
		25.21		8	SLG		TSC	TEH	TEC	560DT	7			COLD
54	46				RIC			01C	01C	560PP	108			COLD
		1.62	105	2	VOL		AV4	AV4	AV5	5201P	111			COLD
		0.88	118	2	VOL		AV5	AV4	AV5	5201P	111			COLD
		1.66	103	2	VOL		AV4	AV4	AV5	5201P	111			COLD
		0.91	120	2	VOL		AV5	AV4	AV5	5201P	111			COLD
					NDD			01C	01C	560PS	112			COLD
		1.89	86	2	VOL		AV3	AV3	AV3	5201P	75			HOT
		3.41	0	P 2	PID		AV4	TEH	TEC	560UL	46			COLD
		26.27		8	SLG		TSC	TEH	TEC	560DT	7			COLD
		0.48	0	P 2	TWD 14		AV2	TEH	TEC	560DT	7			COLD
		2.85	0	P 2	TWD 43		AV3	TEH	TEC	560DT	7			COLD
		3.10	0	P 2	TWD 45		AV4	TEH	TEC	560DT	7			COLD
		1.13	0	P 2	TWD 27		AV5	TEH	TEC	560DT	7			COLD
54	47				NDD			01C	01C	560PS	112			COLD
					NDD			TSH	TSH	560PP	31			HOT
		26.01		8	SLG		TSC	TEH	TEC	560DT	8			COLD
54	48				NDD			TSH	TSH	560PP	31			HOT
		25.19		8	SLG		TSC	TEH	TEC	560DT	8			COLD
54	49				NDD			TSH	TSH	560PP	31			HOT
		0.37	0	P 2	TWD 11		AV4	TEH	TEC	560DT	8			COLD
		0.89	0	P 2	TWD 22		AV3	TEH	TEC	560DT	8			COLD
		0.52	0	P 2	TWD 14		AV2	TEH	TEC	560DT	8			COLD
		25.27		8	SLG		TSC	TEH	TEC	560DT	8			COLD
54	50				NDD			TSH	TSH	560PP	31			HOT
		25.76		8	SLG		TSC	TEH	TEC	560DT	8			COLD
54	51	26.04		8	SLG		TSC	TEH	TEC	560DT	7			COLD
54	52	26.34		8	SLG		TSC	TEH	TEC	560DT	8			COLD
54	53				NDD			TSC	TSC	560PS	116			COLD
		25.38		8	SLG		TSC	TEH	TEC	560DT	8			COLD
54	54				NDD			TSC	TSC	560PS	116			COLD
		25.54		8	SLG		TSC	TEH	TEC	560DT	8			COLD
54	55				NDD			TSC	TSC	560PS	116			COLD
					NDD			TSH	TSH	560PP	30			HOT
		26.76		8	SLG		TSC	TEH	TEC	560DT	8			COLD
54	56				NDD			TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	31			HOT
54	57				NDD			TSH	TSH	560PP	30			HOT
		27.09		8	SLG		TSC	TEH	TEC	560DT	8			COLD
54	58				NDD			TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	31			HOT
54	59	27.44		8	SLG		TSC	TEH	TEC	560DT	8			COLD
54	60	28.12		8	SLG		TSC	TEH	TEC	560DT	7			COLD
54	61	28.03		8	SLG		TSC	TEH	TEC	560DT	10			COLD
54	62	29.10		8	SLG		TSC	TEH	TEC	560DT	9			COLD
54	63				NDD			TSH	TSH	560PP	50			HOT
		28.17		8	SLG		TSC	TEH	TEC	560DT	10			COLD
54	64				NDD			TSH	TSH	560PP	24			HOT
		27.25		8	SLG		TSC	TEH	TEC	560DT	9			COLD
54	65				NDD			TSH	TSH	560PP	24			HOT
		27.20		8	SLG		TSC	TEH	TEC	560DT	10			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
54	66				NDD			TSH	TSH	560PP	24			HOT
		26.79		8	SLG		TSC	TEH	TEC	560DT	9			COLD
54	67	26.68		8	SLG		TSC	TEH	TEC	560DT	10			COLD
54	68	25.03		8	SLG		TSC	TEH	TEC	560DT	9			COLD
54	69	26.56		8	SLG		TSC	TEH	TEC	560DT	10			COLD
54	70	26.72		8	SLG		TSC	TEH	TEC	560DT	10			COLD
54	71				NDD			TSH	TSH	560PP	24			HOT
		26.56		8	SLG		TSC	TEH	TEC	560DT	10			COLD
54	72				NDD			TSH	TSH	560PP	24			HOT
		24.93		8	SLG		TSC	TEH	TEC	560DT	10			COLD
54	73				NDD			TSH	TSH	560PP	24			HOT
		24.53		8	SLG		TSC	TEH	TEC	560DT	10			COLD
54	74				NDD			TSH	TSH	560PP	24			HOT
		24.19		8	SLG		TSC	TEH	TEC	560DT	10			COLD
54	75	23.36		8	SLG		TSC	TEH	TEC	560DT	12			COLD
54	76	22.31		8	SLG		TSC	TEH	TEC	560DT	12			COLD
54	77	0.30	267	3	INR		08H	TEH	TEC	560DT	12			COLD
		20.17		8	SLG		TSC	TEH	TEC	560DT	12			COLD
54	78				NDD			01C	01C	560PS	112			COLD
					NDD			TEH	TEC	560DT	11			COLD
54	79	0.30	84	11	PLP		01C	01C	01C	560PP	108			COLD
					RBD			TSH	TSH	560PP	23			HOT
		0.22	92	11	PID		01C	01C	01C	560PS	117			COLD
					NDD			TSH	TSH	560PS	90			HOT
					NDD			TEH	TEC	560DT	12			COLD
54	80	1.02	66	3	SVI		01C	01C	01C	560PP	60			COLD
		0.70	75	11	PLP		01C	01C	01C	560PP	60			COLD
		0.24	82	11	PLP		01C	01C	01C	560PP	60			COLD
		0.91	56	3	PID		01C	01C	01C	560PP	108			COLD
					NDD			TSH	TSH	560PP	24			HOT
		1.35	108	P 1	DSI		01C	TEH	TEC	560DT	12			COLD
		1.56	75	P 4	TWD	23	01C	01C	01C	560PP	108			COLD
		0.38	90	P 4	ARC		01C	01C	01C	560PP	108			COLD
		0.31	0	P 4	LEN		01C	01C	01C	560PP	108			COLD
		1.96	68	P 5	TWD	27	01C	01C	01C	560PP	108			COLD
		0.38	90	P 5	ARC		01C	01C	01C	560PP	108			COLD
		0.33	0	P 5	LEN		01C	01C	01C	560PP	108			COLD
		2.23	0	P 4	TWD	32	01C	01C	01C	560PP	60	LPW	W/LP	COLD
		0.38	90	P 4	ARC		01C	01C	01C	560PP	60			COLD
		0.18	0	P 4	LEN		01C	01C	01C	560PP	60			COLD
		2.79	0	P 5	TWD	38	01C	01C	01C	560PP	60	LPW	W/LP	COLD
		0.43	90	P 5	ARC		01C	01C	01C	560PP	60			COLD
		0.26	0	P 5	LEN		01C	01C	01C	560PP	60			COLD
54	81				NDD			TSH	TSH	560PP	26			HOT
		0.37	84	11	PLP		01C	01C	01C	560PP	108			COLD
		0.30	91	11	PID		01C	01C	01C	560PS	117			COLD
					NDD			TEH	TEC	560DT	11			COLD
54	82				NDD			01C	01C	560PS	112			COLD
					NDD			TSH	TSH	560PP	27			HOT
					NDD			TEH	TEC	560DT	12			COLD
54	83				NDD			TEH	TEC	560DT	15			COLD
54	84				NDD			TEH	TEC	560DT	14			COLD
54	85	0.46	112	3	NQH		03C	TEH	TEC	560DT	15			COLD
54	86				NDD			TEH	TEC	560DT	15			COLD
54	87				NDD			TEH	TEC	560DT	15			COLD
					NDD			TSH	TSH	560PP	27			HOT
54	88	1.38	86	2	VOL		AV6	AV6	08C	5201P	111			COLD
		0.50	0	P 2	TWD	14	AV1	TEH	TEC	560DT	15			COLD
		0.76	0	P 2	TWD	20	AV4	TEH	TEC	560DT	15			COLD
		1.42	0	P 2	TWD	31	AV5	TEH	TEC	560DT	15			COLD
		2.85	0	P 2	TWD	42	AV6	TEH	TEC	560DT	15			COLD
					NDD			TSH	TSH	560PP	27			HOT
		2.77	0	P 2	PID		AV6	TEH	TEC	560UL	46			COLD
55	39	15.71		8	SLG		TSC	TEH	TEC	560DT	6			COLD
					NDD			TSH	TSH	560PP	28			HOT
55	40	20.18		8	SLG		TSC	TEH	TEC	560DT	6			COLD
		0.74	0	P 2	TWD	19	AV6	TEH	TEC	560DT	6			COLD
					NDD			TSH	TSH	560PP	28			HOT
					NDD			TSH	TSH	560PP	28			HOT
		18.44		8	SLG		TSC	TEH	TEC	560DT	5			COLD
		0.32	0	P 2	INR		AV5	TEH	TEC	560DT	5			COLD
55	42				NDD			TSH	TSH	560PP	31			HOT
		22.12		8	SLG		TSC	TEH	TEC	560DT	5			COLD
55	43	21.90		8	SLG		TSC	TEH	TEC	560DT	7			COLD
55	44				NDD			01C	01C	560PP	108			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
55	45	23.56		8	SLG		TSC		TEH	TEC	560DT	8		COLD
		0.17	89	3	SVI		01C	01C	01C	01C	560PP	108		COLD
		0.37	72	P 4	TWD	6	01C	01C	01C	01C	560PP	108		COLD
		0.30	90	P 4	ARC		01C	01C	01C	01C	560PP	108		COLD
		0.40	0	P 4	LEN		01C	01C	01C	01C	560PP	108		COLD
		0.42	79	P 5	TWD	7	01C	01C	01C	01C	560PP	108		COLD
		0.38	90	P 5	ARC		01C	01C	01C	01C	560PP	108		COLD
		0.26	0	P 5	LEN		01C	01C	01C	01C	560PP	108		COLD
		0.22	77	3	PID		01C	01C	01C	01C	560PS	112		COLD
		24.17		8	SLG		TSC		TEH	TEC	560DT	8		COLD
55	46	0.18	87	3	SVI		01C	01C	01C	01C	560PP	108		COLD
		0.74	61	P 4	TWD	12	01C	01C	01C	01C	560PP	108		COLD
		0.36	90	P 4	ARC		01C	01C	01C	01C	560PP	108		COLD
		0.33	0	P 4	LEN		01C	01C	01C	01C	560PP	108		COLD
		0.41	78	P 5	TWD	7	01C	01C	01C	01C	560PP	108		COLD
		0.36	90	P 5	ARC		01C	01C	01C	01C	560PP	108		COLD
		0.33	0	P 5	LEN		01C	01C	01C	01C	560PP	108		COLD
		0.15	92	3	PID		01C	01C	01C	01C	560PS	112		COLD
		24.17		8	SLG		TSC		TEH	TEC	560DT	8		COLD
55	47				NDD			01C	01C	01C	560PS	112		COLD
					NDD			TSH	TSH	TSH	560PP	30		HOT
		24.54		8	SLG		TSC		TEH	TEC	560DT	7		COLD
55	48				NDD			TSH	TSH	TSH	560PP	30		HOT
		25.46		8	SLG		TSC		TEH	TEC	560DT	7		COLD
55	49				NDD			TSH	TSH	TSH	560PP	30		HOT
		24.32		8	SLG		TSC		TEH	TEC	560DT	7		COLD
55	50				RBD			TSH	TSH	TSH	560PP	30		HOT
		25.31		8	SLG		TSC		TEH	TEC	560DT	7		COLD
					NDD			TSH	TSH	TSH	560PP	50		HOT
55	51	24.46		8	SLG		TSC		TEH	TEC	560DT	8		COLD
55	52	25.09		8	SLG		TSC		TEH	TEC	560DT	7		COLD
55	53	25.21		8	SLG		TSC		TEH	TEC	560DT	7		COLD
55	54				NDD			TEH	TEC	TEH	560DT	7		COLD
55	55				NDD			TEH	TEC	TEH	560DT	7		COLD
					NDD			TEH	TSH	TEH	560PP	31		HOT
55	56				NDD			TSH	TSH	TSH	560PP	30		HOT
		26.68		8	SLG		TSC		TEH	TEC	560DT	8		COLD
55	57				NDD			TEH	TEC	TEH	560DT	7		COLD
					NDD			TSH	TSH	TSH	560PP	31		HOT
55	58				RBD			TSH	TSH	TSH	560PP	30		HOT
		26.62		8	SLG		TSC		TEH	TEC	560DT	8		COLD
					NDD			TSH	TSH	TSH	560PP	50		HOT
55	59				NDD			TEH	TEC	TEH	560DT	7		COLD
55	60	26.99		8	SLG		TSC		TEH	TEC	560DT	8		COLD
55	61	27.09		8	SLG		TSC		TEH	TEC	560DT	9		COLD
55	62	27.53		8	SLG		TSC		TEH	TEC	560DT	10		COLD
55	64				NDD			TSH	TSH	TSH	560PP	24		HOT
		25.30		8	SLG		TSC		TEH	TEC	560DT	10		COLD
55	65				NDD			TSH	TSH	TSH	560PP	24		HOT
		24.53		8	SLG		TSC		TEH	TEC	560DT	9		COLD
55	66				NDD			TSH	TSH	TSH	560PP	23		HOT
		25.88		8	SLG		TSC		TEH	TEC	560DT	10		COLD
55	67	26.81		8	SLG		TSC		TEH	TEC	560DT	9		COLD
55	68	25.74		8	SLG		TSC		TEH	TEC	560DT	10		COLD
55	69	25.03		8	SLG		TSC		TEH	TEC	560DT	9		COLD
55	70	2.31	0	P 2	PID		AV5		TEH	TEC	560UL	106		COLD
		0.50	0	P 2	TWD	17	AV3		TEH	TEC	560DT	9		COLD
		0.73	0	P 2	TWD	23	AV4		TEH	TEC	560DT	9		COLD
		1.92	0	P 2	TWD	39	AV5		TEH	TEC	560DT	9		COLD
		1.34	0	P 2	TWD	33	AV6		TEH	TEC	560DT	9		COLD
		27.05		8	SLG		TSC		TEH	TEC	560DT	9		COLD
55	71				NDD			TSH	TSH	TSH	560PP	23		HOT
		23.02		8	SLG		TSC		TEH	TEC	560DT	9		COLD
55	72				NDD			TSH	TSH	TSH	560PP	23		HOT
		22.52		8	SLG		TSC		TEH	TEC	560DT	9		COLD
55	73				NDD			TSH	TSH	TSH	560PP	23		HOT
		22.09		8	SLG		TSC		TEH	TEC	560DT	9		COLD
55	74				NDD			TSH	TSH	TSH	560PP	23		HOT
		21.95		8	SLG		TSC		TEH	TEC	560DT	9		COLD
55	75	20.98		8	SLG		TSC		TEH	TEC	560DT	11		COLD
55	76	17.89		8	SLG		TSC		TEH	TEC	560DT	11		COLD
55	77				NDD			TEH	TEC	TEH	560DT	11		COLD
55	78				NDD			01C	01C	01C	560PS	112		COLD
					NDD			TEH	TEC	TEH	560DT	12		COLD
55	79				NDD			01C	01C	01C	560PP	108		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
					NDD			TSH	TSH	560PP	24			HOT
					NDD			TEH	TEC	560DT	11			COLD
55	80				NDD			01C	01C	560PP	108			COLD
					NDD			TSH	TSH	560PP	24			HOT
					NDD			TEH	TEC	560DT	11			COLD
55	81				NDD			01C	01C	560PP	108			COLD
					NDD			TSH	TSH	560PP	27			HOT
					NDD			TEH	TEC	560DT	12			COLD
55	82				NDD			TSH	TSH	560PP	26			HOT
					NDD			01C	01C	560PS	112			COLD
					NDD			TEH	TEC	560DT	11			COLD
55	83	4.23	185	P 1	DNT		AV5	TEH	TEC	560DT	15			COLD
55	84	6.92	183	P 1	DNT		AV1	TEH	TEC	560DT	15			COLD
		1.12	0	P 2	TWD	27	AV5	TEH	TEC	560DT	15			COLD
56	41	15.13		8	SLG		TSC	TEH	TEC	560DT	6			COLD
					NDD			TSH	TSH	560PP	28			HOT
56	42	5.39	183	P 1	DNT		AV5	TEH	TEC	560DT	6			COLD
		18.47		8	SLG		TSC	TEH	TEC	560DT	6			COLD
					NDD			TSH	TSH	560PP	31			HOT
56	43	0.68	0	P 2	TWD	18	AV1	TEH	TEC	560DT	8			COLD
		19.54		8	SLG		TSC	TEH	TEC	560DT	8			COLD
56	44				NDD			01C	01C	560PP	108			COLD
		21.21		2	NDF		05C	05C	05C	560PS	112			COLD
		1.03	25	P 1	DDS		05C	TEH	TEC	560DT	7			COLD
56	45				NDD			01C	01C	560PS	112			COLD
		3.10	173	P 1	DNT		08C	TEH	TEC	560DT	7			COLD
		23.04		8	SLG		TSC	TEH	TEC	560DT	7			COLD
56	46				NDD			01C	01C	560PS	112			COLD
		23.48		8	SLG		TSC	TEH	TEC	560DT	7			COLD
56	47				NDD			01C	01C	560PS	112			COLD
					NDD			TSH	TSH	560PP	31			HOT
		24.70		8	SLG		TSC	TEH	TEC	560DT	8			COLD
56	48				NDD			TSH	TSH	560PP	31			HOT
		23.91		8	SLG		TSC	TEH	TEC	560DT	8			COLD
56	49				NDD			TSH	TSH	560PP	31			HOT
		23.05		8	SLG		TSC	TEH	TEC	560DT	8			COLD
56	50				NDD			TSH	TSH	560PP	31			HOT
		24.42		8	SLG		TSC	TEH	TEC	560DT	8			COLD
56	51	23.44		8	SLG		TSC	TEH	TEC	560DT	7			COLD
56	52	24.11		8	SLG		TSC	TEH	TEC	560DT	8			COLD
56	53	23.87		8	SLG		TSC	TEH	TEC	560DT	8			COLD
56	54	23.97		8	SLG		TSC	TEH	TEC	560DT	8			COLD
56	55				RBD			TSH	TSH	560PP	30			HOT
		25.07		8	SLG		TSC	TEH	TEC	560DT	8			COLD
					NDD			TSH	TSH	560PP	50			HOT
56	56	25.80		8	SLG		TSC	TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	31			HOT
56	57				NDD			TSH	TSH	560PP	30			HOT
		24.60		8	SLG		TSC	TEH	TEC	560DT	8			COLD
56	58	25.03		8	SLG		TSC	TEH	TEC	560DT	7			COLD
					NDD			TSH	TSH	560PP	31			HOT
56	59	25.21		8	SLG		TSC	TEH	TEC	560DT	8			COLD
56	60	24.99		8	SLG		TSC	TEH	TEC	560DT	7			COLD
56	61	25.54		8	SLG		TSC	TEH	TEC	560DT	10			COLD
56	62	25.72		8	SLG		TSC	TEH	TEC	560DT	9			COLD
56	63				NDD			TSH	TSH	560PP	23			HOT
		24.85		8	SLG		TSC	TEH	TEC	560DT	9			COLD
56	64				NDD			TSH	TSH	560PP	24			HOT
		25.40		8	SLG		TSC	TEH	TEC	560DT	9			COLD
		3.09	185	1	DNG		TSC	TEH	TEC	560DT	9			COLD
56	65				NDD			TSH	TSH	560PP	24			HOT
		26.72		8	SLG		TSC	TEH	TEC	560DT	10			COLD
56	66				NDD			TSH	TSH	560PP	24			HOT
		23.16		8	SLG		TSC	TEH	TEC	560DT	9			COLD
56	67	24.17		8	SLG		TSC	TEH	TEC	560DT	10			COLD
56	68	3.29	175	P 1	DNT		06H	TEH	TEC	560DT	9			COLD
		23.48		8	SLG		TSC	TEH	TEC	560DT	9			COLD
		0.31	51	1	INR		AV6	TEH	TEC	560DT	9			COLD
				3	NDF		06H	06H	06H	560PP	68			HOT
56	69	4.39	179	P 1	DNT		06H	TEH	TEC	560DT	10			COLD
		23.27		8	SLG		TSC	TEH	TEC	560DT	10			COLD
				3	NDF		06H	06H	06H	560PP	68			HOT
56	70	23.65		8	SLG		TSC	TEH	TEC	560DT	10			COLD
56	71				NDD			TSH	TSH	560PP	24			HOT

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		22.32		8	SLG		TSC			TEH TEC 560DT	10			COLD
56	72				NDD					TSH TSH 560PP	24			HOT
		20.98		8	SLG		TSC			TEH TEC 560DT	10			COLD
56	73				NDD					01C 01C 560PP	108			COLD
		20.21		8	SLG		TSC			TSH TSH 560PP	24			HOT
56	74				NDD					TEH TEC 560DT	10			COLD
		17.86		8	SLG		TSC			01C 01C 560PP	108			COLD
56	75				NDD					TSH TSH 560PP	24			HOT
		3.59	179	P 1	DNT		06H			TEH TEC 560DT	12			COLD
		4.62	182	P 1	DNT		08H			TEH TEC 560DT	12			COLD
		18.03		8	SLG		TSC			TEH TEC 560DT	12			COLD
56	76				NDF		08H			08H 08H 560PP	58			HOT
		3.29	180	P 1	DNT		08H			01C 01C 560PS	112			COLD
56	77				NDD					TEH TEC 560DT	12			COLD
56	78				NDD					01H 01H 560PP	61			HOT
56	79				NDD					TEH TEC 560DT	11			COLD
					NDD					01H 01H 560PP	61			HOT
					NDD					TSH TSH 560PP	23			HOT
					NDD					TSH TSH 560PS	90	IDOK		HOT
					NDD					TEH TEC 560DT	12			COLD
56	80				NDD					01H 01H 560PP	61			HOT
		5.72	184	P 1	DNT		AV6			TSH TSH 560PP	24			HOT
		3.93	183	P 1	DNT		AV4			TEH TEC 560DT	12			COLD
56	81				NDD					TSH TSH 560PP	24			HOT
		0.52	89	3	INR		05C			TEH TEC 560DT	12			COLD
56	82				NDD					TSH TSH 560PP	27			HOT
					NDD					TEH TEC 560DT	12			COLD
57	44	15.94		8	SLG		TSC			TEH TEC 560DT	8			COLD
57	45	21.23		8	SLG		TSC			TEH TEC 560DT	8			COLD
57	46	21.48		8	SLG		TSC			TEH TEC 560DT	8			COLD
57	47				NDD					TSH TSH 560PP	30			HOT
		21.21		8	SLG		TSC			TEH TEC 560DT	7			COLD
57	48				RBD					TSH TSH 560PP	30			HOT
		22.69		8	SLG		TSC			TEH TEC 560DT	7			COLD
					NDD					TSH TSH 560PP	51			HOT
57	49				RBD					TSH TSH 560PP	30			HOT
		22.35		8	SLG		TSC			TEH TEC 560DT	7			COLD
		0.55	121	3	INR		06C			TEH TEC 560DT	7			COLD
57	50				NDD					TSH TSH 560PP	50			HOT
		22.47		8	SLG		TSC			TSH TSH 560PP	30			HOT
					NDD					TEH TEC 560DT	7			COLD
57	51	22.97		8	SLG		TSC			TSH TSH 560PP	50			HOT
57	52	22.23		8	SLG		TSC			TEH TEC 560DT	8			COLD
57	53				NDD					TEH TEC 560DT	7			COLD
		22.12		8	SLG		TSC			01C 01C 560PP	108			COLD
57	54				NDD					TEH TEC 560DT	7			COLD
		22.84		8	SLG		TSC			01C 01C 560PP	108			COLD
57	55				NDD					TEH TEC 560DT	7			COLD
		23.12		8	SLG		TSC			01C 01C 560PP	108			COLD
57	56				NDD					TEH TEC 560DT	7			COLD
					NDD					TSH TSH 560PP	31			HOT
		23.32		8	SLG		TSC			TEH TEC 560DT	8			COLD
					NDD					TSH TSH 560PP	51			HOT
57	57				RIC					01C 01C 560PP	108			COLD
		23.97		8	SLG		TSC			TEH TEC 560DT	7			COLD
					NDD					01C 01C 560PS	112			COLD
					NDD					TSH TSH 560PP	31			HOT
57	58				NDD					TSH TSH 560PP	30			HOT
		22.91		8	SLG		TSC			TEH TEC 560DT	8			COLD
57	59	22.25		8	SLG		TSC			TEH TEC 560DT	7			COLD
57	60				NDF		06H			06H 06H 560PP	57			HOT
		3.08	177	P 1	DNT		06H			TEH TEC 560DT	8			COLD
		21.82		8	SLG		TSC			TEH TEC 560DT	8			COLD
57	61				NDF		06H			06H 06H 560PP	60			HOT
		23.00		8	SLG		TSC			TEH TEC 560DT	9			COLD
57	62				NDF		06H			06H 06H 560PP	60			HOT
		23.39		8	SLG		TSC			TEH TEC 560DT	10			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG	
57	63	22.40		8	SLG		TSC	+0.67	TEH	TEC	560DT	10		COLD	
					NDD				TSH	TSH	560PP	51		HOT	
57	64			3	NDF		06H	+0.75	06H	06H	560PP	60		HOT	
				3	NDF		07H	+21.70	07H	08H	560PP	60		HOT	
					NDD				TSH	TSH	560PP	24		HOT	
		4.72		179	P 1		DNT	06H	TEH	TEC	560DT	10		COLD	
		21.84		8	SLG		TSC	+0.65	TEH	TEC	560DT	10		COLD	
57	65			3	NDF		06H	+0.73	06H	06H	560PP	60		HOT	
				3	NDF		06H	-0.34	06H	06H	560PP	60		HOT	
					NDD				TSH	TSH	560PP	24		HOT	
		3.02		178	P 1		DNT	06H	TEH	TEC	560DT	9		COLD	
		4.27		177	P 1		DNT	06H	TEH	TEC	560DT	9		COLD	
		21.09		8	SLG		TSC	+0.62	TEH	TEC	560DT	9		COLD	
57	66				NDD				TSH	TSH	560PP	23		HOT	
				3	NDF		06H	+0.67	06H	06H	560PP	60		HOT	
				3	NDF		06H	-0.32	06H	06H	560PP	60		HOT	
		19.99		8	SLG		TSC	+0.57	TEH	TEC	560DT	10		COLD	
		5.02		178	P 1		DNT	06H	TEH	TEC	560DT	10		COLD	
		2.63		182	P 1		INR	06H	TEH	TEC	560DT	10		COLD	
57	67			3	NDF		06H	+0.80	06H	06H	560PP	60		HOT	
				3	NDF		06H	-0.23	06H	06H	560PP	60		HOT	
		20.16		8	SLG		TSC	+0.59	TEH	TEC	560DT	9		COLD	
		3.90		180	P 1		DNT	06H	TEH	TEC	560DT	9		COLD	
		5.10		179	P 1		DNT	06H	TEH	TEC	560DT	9	OK	COLD	
57	68			3	NDF		06H	+0.67	06H	06H	560PP	60		HOT	
				3	NDF		06H	-0.23	06H	06H	560PP	60		HOT	
		19.03		8	SLG		TSC	+0.56	TEH	TEC	560DT	10		COLD	
		3.44		187	P 1		DNT	06H	TEH	TEC	560DT	10		COLD	
		7.76		181	P 1		DNT	06H	TEH	TEC	560DT	10		COLD	
57	69			3	NDF		06H	+0.75	06H	06H	560PP	60		HOT	
				3	NDF		06H	-0.28	06H	06H	560PP	60		HOT	
		4.77		180	P 1		DNT	06H	TEH	TEC	560DT	9		COLD	
		6.58		180	P 1		DNT	06H	TEH	TEC	560DT	9		COLD	
		19.11		8	SLG		TSC	+0.60	TEH	TEC	560DT	9		COLD	
57	70			3	NDF		06H	+0.75	06H	06H	560PP	60		HOT	
				3	NDF		06H	-0.28	06H	06H	560PP	60		HOT	
		19.03		8	SLG		TSC	+0.54	TEH	TEC	560DT	9		COLD	
		3.78		178	P 1		DNT	06H	TEH	TEC	560DT	9		COLD	
		5.79		178	P 1		DNT	06H	TEH	TEC	560DT	9		COLD	
57	71				NDD				TSH	TSH	560PP	23		HOT	
				3	NDF		06H	+0.78	06H	06H	560PP	60		HOT	
		17.16		8	SLG		TSC	+0.51	TEH	TEC	560DT	9		COLD	
		5.60		178	P 1		DNT	+0.78	TEH	TEC	560DT	9		COLD	
57	72				NDD				TSH	TSH	560PP	23		HOT	
		3.59		179	P 1		DNT	06H	TEH	TEC	560DT	9		COLD	
		4.53		178	P 1		DNT	06H	TEH	TEC	560DT	9		COLD	
		16.05		8	SLG		TSC	+0.46	TEH	TEC	560DT	9		COLD	
				3	NDF		06H	+0.75	06H	06H	560PP	58		HOT	
				3	NDF		06H	-0.23	06H	06H	560PP	58		HOT	
57	73				NDD				TSH	TSH	560PP	23		HOT	
					NDD				01C	01C	560PP	108		COLD	
		5.31		179	P 1		DNT	06H	TEH	TEC	560DT	9	OK	COLD	
				3	NDF		06H	+0.83	06H	06H	560PP	58		HOT	
57	74	0.85		73	3		SVI	01C	01C	01C	560PP	60		COLD	
		0.73		76	11		PLP	01C	01C	01C	560PP	60		COLD	
		0.86		68	3		PID	01C	01C	01C	560PP	108		COLD	
					NDD				TSH	TSH	560PP	23		HOT	
		1.22		46	P 4	19	TWD	01C	01C	01C	560PP	108		COLD	
		0.36		90	P 4		ARC	01C	01C	01C	560PP	108		COLD	
		0.36		0	P 4		LEN	01C	01C	01C	560PP	108		COLD	
		1.92		75	P 5	26	TWD	01C	01C	01C	560PP	108		COLD	
		0.41		90	P 5		ARC	01C	01C	01C	560PP	108		COLD	
		0.36		0	P 5		LEN	01C	01C	01C	560PP	108		COLD	
		3.65		187	P 1		DNT	AV2	TEH	TEC	560DT	9		COLD	
		1.25		164	8		PLP	01C	TEH	TEC	560DT	9		COLD	
		0.90		96	P 1		LPI	01C	TEH	TEC	560DT	9		COLD	
		4.40		177	P 1		DNT	06H	TEH	TEC	560DT	9	OK	COLD	
				3	NDF		06H	+0.83	06H	06H	560PP	68		HOT	
		1.51		0	P 4	24	TWD	01C	01C	01C	560PP	60	LPW	W/LP	COLD
		0.31		90	P 4		ARC	01C	01C	01C	560PP	60		COLD	
		0.31		0	P 4		LEN	01C	01C	01C	560PP	60		COLD	
		2.53		0	P 5	36	TWD	01C	01C	01C	560PP	60	LPW	W/LP	COLD
		0.41		90	P 5		ARC	01C	01C	01C	560PP	60		COLD	
		0.34		0	P 5		LEN	01C	01C	01C	560PP	60		COLD	
57	75	0.58		81	11		PLP	01C	01C	01C	560PP	108		COLD	

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		0.49	87	11	PID		01C			560PS	117			COLD
					NDD			01C	01C	560DT	11			COLD
57	76				NDD			01C	01C	560PS	112			COLD
					NDD			TEH	TEC	560DT	11			COLD
57	77			3	NDF		08H	08H	08H	560PP	81			HOT
		8.44	180	P 1	DNT		06H	TEH	TEC	560DT	12			COLD
		1.77	163	1	INR		08H	TEH	TEC	560DT	12			COLD
				3	NDF		06H	06H	06H	560PP	58			HOT
57	78				NDD			01H	01H	560PP	61			HOT
		1.30	111	2	VOL		AV5	AV5	AV6	5201P	111			COLD
		1.53	81	2	VOL		AV2	AV3	AV2	5201P	75			HOT
		1.23	85	2	VOL		AV3	AV3	AV2	5201P	75			HOT
		0.49	95	2	VOL		AV3	AV3	AV2	5201P	75			HOT
		2.19	0	P 2	PID		AV5	TEH	TEC	560UL	46			COLD
		3.87	0	P 2	TWD	47	AV2	TEH	TEC	560DT	12			COLD
		2.93	0	P 2	TWD	43	AV3	TEH	TEC	560DT	12			COLD
		1.84	0	P 2	TWD	35	AV4	TEH	TEC	560DT	12			COLD
		2.47	0	P 2	TWD	40	AV5	TEH	TEC	560DT	12			COLD
57	79	1.72	0	P 4	TWD	28	01H	01H	01H	560PP	82			HOT
		0.33	90	P 4	ARC		01H	01H	01H	560PP	82			HOT
		0.28	0	P 4	LEN		01H	01H	01H	560PP	82			HOT
		1.40	0	P 5	TWD	21	01H	01H	01H	560PP	82			HOT
		0.36	90	P 5	ARC		01H	01H	01H	560PP	82			HOT
		0.33	0	P 5	LEN		01H	01H	01H	560PP	82			HOT
		1.81	0	P 4	TWD	27	01H	01H	01H	560PP	29	LPW		HOT
		0.32	90	P 4	ARC		01H	01H	01H	560PP	29			HOT
		0.29	0	P 4	LEN		01H	01H	01H	560PP	29			HOT
		1.45	0	P 5	TWD	23	01H	01H	01H	560PP	29	LPW		HOT
		0.37	90	P 5	ARC		01H	01H	01H	560PP	29			HOT
		0.31	0	P 5	LEN		01H	01H	01H	560PP	29			HOT
		0.56	75	3	PID		01H	01H	01H	560PP	61			HOT
		0.50	74	3	PID		01H	01H	01H	560PS	82			HOT
					NDD			TSH	TSH	560PP	24			HOT
		0.53	73	3	SVI		01H	01H	01H	560PP	29			HOT
		3.25	182	1	DNG		08H	TEH	TEC	560DT	12	OK		COLD
		0.67	53	8	PLP		01H	TEH	TEC	560DT	12			COLD
		1.02	123	P 1	LPI		01H	TEH	TEC	560DT	12			COLD
58	47				NDD			TSH	TSH	560PP	31			HOT
		16.48		8	SLG		TSC	TEH	TEC	560DT	8			COLD
58	48				NDD			TSH	TSH	560PP	31			HOT
		19.05		8	SLG		TSC	TEH	TEC	560DT	8			COLD
58	49				NDD			TSH	TSH	560PP	31			HOT
		19.74		8	SLG		TSC	TEH	TEC	560DT	8			COLD
58	50				NDD			TSH	TSH	560PP	31			HOT
		18.60		8	SLG		TSC	TEH	TEC	560DT	8			COLD
58	51	18.60		8	SLG		TSC	TEH	TEC	560DT	8			COLD
58	52	3.43	185	P 1	DNT		AV5	TEH	TEC	560DT	8			COLD
		18.70		8	SLG		TSC	TEH	TEC	560DT	8			COLD
58	53				NDD			01C	01C	560PP	108			COLD
		3.42	185	P 1	DNT		AV5	TEH	TEC	560DT	8			COLD
		5.03	182	P 1	DNT		AV2	TEH	TEC	560DT	8			COLD
		17.46		8	SLG		TSC	TEH	TEC	560DT	8			COLD
58	54	0.28	71	3	SVI		01C	01C	01C	560PP	60			COLD
		0.21	73	P 4	PID		01C	01C	01C	560PP	108			COLD
		0.59	74	P 4	TWD	10	01C	01C	01C	560PP	108			COLD
		0.33	90	P 4	ARC		01C	01C	01C	560PP	108			COLD
		0.21	0	P 4	LEN		01C	01C	01C	560PP	108			COLD
		0.65	72	P 5	TWD	10	01C	01C	01C	560PP	108			COLD
		0.36	90	P 5	ARC		01C	01C	01C	560PP	108			COLD
		0.28	0	P 5	LEN		01C	01C	01C	560PP	108			COLD
		3.00	184	P 1	DNT		AV6	TEH	TEC	560DT	8			COLD
		17.37		8	SLG		TSC	TEH	TEC	560DT	8			COLD
		0.48	116	P 1	DSI		01C	TEH	TEC	560DT	8			COLD
		0.81	0	P 4	TWD	14	01C	01C	01C	560PP	60	LPW		COLD
		0.35	90	P 4	ARC		01C	01C	01C	560PP	60			COLD
		0.26	0	P 4	LEN		01C	01C	01C	560PP	60			COLD
		0.94	0	P 5	TWD	18	01C	01C	01C	560PP	60	LPW		COLD
		0.43	90	P 5	ARC		01C	01C	01C	560PP	60			COLD
		0.27	0	P 5	LEN		01C	01C	01C	560PP	60			COLD
58	55	0.35	85	11	PLP		01C	01C	01C	560PP	108			COLD
		0.15	60	3	SVI		01C	01C	01C	560PP	108			COLD
		0.13	84	3	PID		01C	01C	01C	560PS	112			COLD
					NDD			TSH	TSH	560PP	30			HOT
		0.37	89	P 4	TWD	6	01C	01C	01C	560PP	108			COLD
		0.30	90	P 4	ARC		01C	01C	01C	560PP	108			COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		0.28	0	P 4	LEN		01C		01C	560PP	108			COLD
		0.35	76	P 5	TWD	6	01C		01C	560PP	108			COLD
		0.36	90	P 5	ARC		01C		01C	560PP	108			COLD
		0.31	0	P 5	LEN		01C		01C	560PP	108			COLD
58	56	18.78		8	SLG		TSC		TEH	TEC	560DT	8		COLD
		0.22	76	3	SVI		01C		01C	560PP	60			COLD
		0.43	71	3	SVI		01C		01C	560PP	60			COLD
		0.43	71	3	PID		01C		01C	560PP	108			COLD
		1.03	130	P 1	DST		01C		TEH	TEC	560DT	7		COLD
		18.77		8	SLG		TSC		TEH	TEC	560DT	7		COLD
					NDD				TSH	TSH	560PP	31		HOT
		1.37	64	P 4	TWD	21	01C		01C	560PP	108			COLD
		0.41	90	P 4	ARC		01C		01C	560PP	108			COLD
		0.36	0	P 4	LEN		01C		01C	560PP	108			COLD
		0.87	76	P 5	TWD	13	TEH		01C	TEH	560PP	108		COLD
		0.38	90	P 5	ARC		TEH		01C	TEH	560PP	108		COLD
		0.19	0	P 5	LEN		TEH		01C	TEH	560PP	108		COLD
		1.07	74	P 5	TWD	16	TEH		01C	TEH	560PP	108	#2	COLD
		0.44	90	P 5	ARC		TEH		01C	TEH	560PP	108	#2	COLD
		0.21	0	P 5	LEN		TEH		01C	TEH	560PP	108	#2	COLD
		1.91	0	P 4	TWD	28	01C		01C	01C	560PP	60	LPW	COLD
		0.41	90	P 4	ARC		01C		01C	01C	560PP	60		COLD
		0.32	0	P 4	LEN		01C		01C	01C	560PP	60		COLD
		1.39	0	P 5	TWD	24	01C		01C	01C	560PP	60	LPW	COLD
		0.48	90	P 5	ARC		01C		01C	01C	560PP	60		COLD
		0.35	0	P 5	LEN		01C		01C	01C	560PP	60		COLD
58	57				NDD				01C	01C	560PP	108		COLD
					NDD				TSH	TSH	560PP	30		HOT
		19.05		8	SLG		TSC		TEH	TEC	560DT	8		COLD
58	58	17.88		8	SLG		TSC		TEH	TEC	560DT	7		COLD
		3.24	176	P 1	DNT		06H		TEH	TEC	560DT	7		COLD
		8.45	185	1	DNG		AV5		TEH	TEC	560DT	7		COLD
				3	NDF		06H		06H	06H	560PP	60		HOT
					NDD				TSH	TSH	560PP	31		HOT
58	59			3	NDF		06H		06H	06H	560PP	57		HOT
		16.95		8	SLG		TSC		TEH	TEC	560DT	8		COLD
58	60	15.70		8	SLG		TSC		TEH	TEC	560DT	7		COLD
				3	NDF		06H		06H	06H	560PP	57		HOT
58	61			3	NDF		06H		06H	06H	560PP	60		HOT
				3	NDF		07H		07H	08H	560PP	60		HOT
				3	NDF		08H		07H	08H	560PP	60		HOT
		3.76	177	1	DNG		08H		TEH	TEC	560DT	10	OK	COLD
		1.55	165	1	INR		07H		TEH	TEC	560DT	10		COLD
		2.28	175	P 1	INR		06H		TEH	TEC	560DT	10		COLD
		2.39	185	P 1	INR		08H		TEH	TEC	560DT	10		COLD
		17.66		8	SLG		TSC		TEH	TEC	560DT	10		COLD
58	62			3	NDF		06H		06H	06H	560PP	60		HOT
		3.77	176	P 1	DNT		06H		TEH	TEC	560DT	9		COLD
		17.99		8	SLG		TSC		TEH	TEC	560DT	9		COLD
58	63				NDD				TSH	TSH	560PP	23		HOT
				3	NDF		06H		06H	06H	560PP	60		HOT
				3	NDF		06H		06H	06H	560PP	60		HOT
		4.13	179	P 1	DNT		06H		TEH	TEC	560DT	9		COLD
		6.92	178	P 1	DNT		06H		TEH	TEC	560DT	9		COLD
		16.82		8	SLG		TSC		TEH	TEC	560DT	9		COLD
58	64			3	NDF		06H		06H	06H	560PP	60		HOT
				3	NDF		06H		06H	06H	560PP	60		HOT
					NDD				TSH	TSH	560PP	24		HOT
		5.48	181	P 1	DNT		06H		TEH	TEC	560DT	9		COLD
		7.09	180	P 1	DNT		06H		TEH	TEC	560DT	9		COLD
		15.65		8	SLG		TSC		TEH	TEC	560DT	9		COLD
58	65			3	NDF		06H		06H	06H	560PP	60		HOT
				3	NDF		06H		06H	06H	560PP	60		HOT
					NDD				TSH	TSH	560PP	24		HOT
		15.99		8	SLG		TSC		TEH	TEC	560DT	10		COLD
		4.31	181	P 1	DNT		06H		TEH	TEC	560DT	10		COLD
		7.45	180	P 1	DNT		06H		TEH	TEC	560DT	10		COLD
58	66			3	NDF		06H		06H	06H	560PP	60		HOT
				3	NDF		06H		06H	06H	560PP	60		HOT
					NDD				TSH	TSH	560PP	24		HOT
		6.81	182	P 1	DNT		06H		TEH	TEC	560DT	9		COLD
		9.26	180	P 1	DNT		06H		TEH	TEC	560DT	9		COLD
58	67			3	NDF		06H		06H	06H	560PP	60		HOT
				3	NDF		06H		06H	06H	560PP	60		HOT
		4.97	185	P 1	DNT		06H		TEH	TEC	560DT	10		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
58	68	6.59	179	P 1	DNT		06H		TEH	TEC	560DT	10		COLD
					NDD				TEH	TSH	560PP	23		HOT
				3	NDF		06H		06H	06H	560PP	60		HOT
				3	NDF		06H		06H	06H	560PP	60		HOT
		4.21	179	P 1	DNT		06H		TEH	TEC	560DT	9		COLD
		7.00	178	P 1	DNT		06H		TEH	TEC	560DT	9		COLD
58	69			3	NDF		06H		06H	06H	560PP	60		HOT
				3	NDF		06H		06H	06H	560PP	60		HOT
		4.96	186	P 1	DNT		06H		TEH	TEC	560DT	10		COLD
		8.11	181	P 1	DNT		06H		TEH	TEC	560DT	10		COLD
		11.65	181	P 1	DNT		AV1		TEH	TEC	560DT	10		COLD
		7.33	185	P 1	DNT		AV6		TEH	TEC	560DT	10		COLD
58	70			3	NDF		06H		06H	06H	560PP	60		HOT
		6.55	180	P 1	DNT		06H		TEH	TEC	560DT	10		COLD
		4.74	180	P 1	DNT		AV1		TEH	TEC	560DT	10		COLD
		5.13	183	P 1	DNT		AV5		TEH	TEC	560DT	10		COLD
58	71			3	NDF		06H		06H	06H	560PP	81		HOT
					NDD				TSH	TSH	560PP	24		HOT
		5.62	180	P 1	DNT		06H		TEH	TEC	560DT	10		COLD
58	72				NDD				TSH	TSH	560PP	24		HOT
		7.17	180	P 1	DNT		06H		TEH	TEC	560DT	10		COLD
				3	NDF		06H		06H	06H	560PP	58		HOT
58	73				NDD				01C	01C	560PP	108		COLD
					NDD				TSH	TSH	560PP	24		HOT
		3.28	184	P 1	DNT		06H		TEH	TEC	560DT	10		COLD
		5.65	180	P 1	DNT		06H		TEH	TEC	560DT	10		COLD
		5.16	183	P 1	DNT		08H		TEH	TEC	560DT	10		COLD
				3	NDF		08H		08H	06H	560PP	58		HOT
				3	NDF		06H		08H	06H	560PP	58		HOT
				3	NDF		06H		08H	06H	560PP	58		HOT
58	74	0.12	84	11	PID		01C		01C	01C	560PP	108		COLD
					NDD				TSH	TSH	560PP	24		HOT
		5.73	181	P 1	DNT		06H		TEH	TEC	560DT	10		COLD
		4.54	184	1	DNG		AV1		TEH	TEC	560DT	10		COLD
		3.90	183	P 1	DNT		AV1		TEH	TEC	560DT	10		COLD
				3	NDF		06H		06H	06H	560PP	58		HOT
58	75	0.64	74	3	SVI		01C		01C	01C	560PP	108		COLD
		0.63	83	11	PLP		01C		01C	01C	560PP	108		COLD
		0.64	59	3	PID		01C		01C	01C	560PS	112		COLD
		0.46	41	P 4	TWD	7	01C		01C	01C	560PP	108		COLD
		0.33	90	P 4	ARC		01C		01C	01C	560PP	108		COLD
		0.31	0	P 4	LEN		01C		01C	01C	560PP	108		COLD
		1.32	80	P 5	TWD	20	01C		01C	01C	560PP	108		COLD
		0.36	90	P 5	ARC		01C		01C	01C	560PP	108		COLD
		0.28	0	P 5	LEN		01C		01C	01C	560PP	108		COLD
		5.46	180	P 1	DNT		06H		TEH	TEC	560DT	12		COLD
				3	NDF		06H		06H	06H	560PP	58		HOT
58	76			3	NDF		06H		06H	06H	560PP	81		HOT
					NDD				01C	01C	560PS	112		COLD
		4.83	179	P 1	DNT		06H		TEH	TEC	560DT	12		COLD
		3.85	182	P 1	DNT		AV1		TEH	TEC	560DT	12		COLD
		8.70	184	P 1	DNT		AV6		TEH	TEC	560DT	12		COLD
59	55	0.46	83	11	PLP		01C		01C	01C	560PP	108		COLD
		0.42	89	11	PID		01C		01C	01C	560PS	117		COLD
					NDD				TSH	TSH	560PP	31		HOT
				3	NDF		06H		06H	06H	560PP	57		HOT
		3.78	180	P 1	DNT		06H		TEH	TEC	560DT	8		COLD
59	56	0.35	83	11	PLP		01C		01C	01C	560PP	108		COLD
		0.34	90	11	PID		01C		01C	01C	560PS	117		COLD
				3	NDF		06H		06H	06H	560PP	60		HOT
				3	NDF		06H		06H	06H	560PP	60		HOT
					NDD				TSH	TSH	560PP	31		HOT
				3	NDF		05H		05H	05H	560PP	57		HOT
		3.64	181	P 1	DNT		AV5		TEH	TEC	560DT	8		COLD
		3.28	175	P 1	DNT		06H		TEH	TEC	560DT	8		COLD
		3.27	183	P 1	DNT		06H		TEH	TEC	560DT	8		COLD
59	57				NDD				01C	01C	560PP	108		COLD
				3	NDF		06H		06H	06H	560PP	60		HOT
					NDD				TSH	TSH	560PP	31		HOT
		3.03	179	P 1	DNT		AV1		TEH	TEC	560DT	8		COLD
		3.66	177	P 1	DNT		06H		TEH	TEC	560DT	8		COLD
59	58				NDD				TSH	TSH	560PP	31		HOT
		3.23	178	P 1	DNT		AV6		TEH	TEC	560DT	8		COLD
59	59			3	NDF		06H		06H	06H	560PP	57		HOT
		0.97	114	3	INR		02C		TEH	TEC	560DT	8		COLD

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
		5.41	182	P	1	DNT	AV5		TEH	TEC	560DT	8		COLD
		3.70	182	P	1	DNT	AV2		TEH	TEC	560DT	8		COLD
		3.41	179	P	1	DNT	AV1		TEH	TEC	560DT	8		COLD
		5.18	179	P	1	DNT	06H		TEH	TEC	560DT	8		COLD
59	60			3		NDF	06H		06H	06H	560PP	57		HOT
		4.37	183	P	1	DNT	AV5		TEH	TEC	560DT	8	OK	COLD
		6.54	183	P	1	DNT	AV2		TEH	TEC	560DT	8		COLD
		3.72	179	P	1	DNT	AV1		TEH	TEC	560DT	8		COLD
		4.82	178	P	1	DNT	06H		TEH	TEC	560DT	8		COLD
59	61			3		NDF	06H		06H	06H	560PP	60		HOT
				3		NDF	06H		06H	06H	560PP	60		HOT
		3.75	181	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
		6.54	179	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
		5.69	184	P	1	DNT	AV2		TEH	TEC	560DT	10		COLD
		8.20	183	P	1	DNT	AV5		TEH	TEC	560DT	10		COLD
59	62			3		NDF	06H		06H	06H	560PP	60		HOT
				3		NDF	06H		06H	06H	560PP	60		HOT
		3.35	186	1		DNG	05C		TEH	TEC	560DT	10		COLD
		6.37	179	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
		3.34	180	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
59	63			3		NDF	06H		06H	06H	560PP	60		HOT
				3		NDF	06H		06H	06H	560PP	60		HOT
		3.83	180	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
		10.22	180	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
						NDD			TSH	TSH	560PP	51		HOT
59	64			3		NDF	05H		05H	06H	560PP	60		HOT
				3		NDF	06H		05H	06H	560PP	60		HOT
				3		NDF	06H		05H	06H	560PP	60		HOT
						NDD			TSH	TSH	560PP	24		HOT
		4.47	182	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
		7.99	179	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
		7.24	184	P	1	DNT	AV5		TEH	TEC	560DT	10		COLD
59	65			3		NDF	06H		06H	06H	560PP	60		HOT
				3		NDF	06H		06H	06H	560PP	60		HOT
						NDD			TSH	TSH	560PP	24		HOT
		6.03	185	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
		10.11	181	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
		7.42	183	P	1	DNT	AV5		TEH	TEC	560DT	10		COLD
59	66			3		NDF	06H		06H	06H	560PP	60		HOT
				3		NDF	06H		06H	06H	560PP	60		HOT
						NDD			TSH	TSH	560PP	24		HOT
		6.70	184	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
		9.11	181	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
59	67			3		NDF	06H		06H	06H	560PP	60		HOT
				3		NDF	06H		06H	06H	560PP	60		HOT
		10.28	183	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
		6.86	186	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
59	68			3		NDF	06H		06H	06H	560PP	60		HOT
				3		NDF	06H		06H	06H	560PP	60		HOT
		4.19	181	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
		7.06	180	P	1	DNT	06H		TEH	TEC	560DT	10		COLD
		18.47	182	P	1	DNT	AV1		TEH	TEC	560DT	10		COLD
		6.16	184	1		DNG	AV1		TEH	TEC	560DT	10		COLD
		4.79	185	1		DNG	AV1		TEH	TEC	560DT	10		COLD
		3.26	183	1		DNG	AV1		TEH	TEC	560DT	10		COLD

Total Tubes : 5609
 Total Records: 11080

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
===	==	=====	==	==	==	==	=====	==	==	=====	==	=====	=====	=====

Master Report

QUERY: QueryM1

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	PROBE	CAL#	COMMENT1	COMMENT2	LEG
===	==	=====	==	==	==	==	=====	==	==	=====	==	=====	=====	=====

Docket No. 50-423
Enclosure 1 to B18572

Appendix 4

Millstone Nuclear Power Station, Unit No. 3

Information Related to Telephone Conference of February 13, 2001, on
Refueling Outage 7 Steam Generator Tube Inspections

Information Related to Telephone Conference of February 13, 2001, on
Refueling Outage 7 Steam Generator Tube Inspections

On February 13, 2001, a telephone conference between Millstone Unit 3 and members of the NRC staff discussed the results of steam generator (SG) tube inspections completed during refueling outage (RFO) 7. The telephone conference established an expectation that significant results, or relevant trends related to the discussion, would be included in this special report. Consistent with that expectation, Millstone Unit 3 has provided in the balance of this appendix a summary of information pertinent to the thirteen (13) items addressed during the February 13 telephone conference.

1. Discuss whether any primary to secondary leakage existed in this unit prior to shutdown.

The identified leakage was low and relatively constant during cycle 7. Leakage was determined to be approximately 0.2 gallons per day, by tritium analysis.

2. Discuss the results of secondary side hydrostatic test.

No secondary side hydrostatic tests were scheduled or performed during RFO7.

3. For each steam generator, provide a general description of areas examined, including the expansion criteria utilized and type of probe used in each area.

A description of the inspection scope is provided in the body of this report and in Table 1. The scope expansion criteria is provided in Table 6.

4. For analyzed eddy current results, describe bobbin indications (those not examined with rotating pancake coil (RPC)) and RPC/Plus Point/Cecco indications. Include the following information in the discussion: location, number, degradation mode, disposition, and voltage/depths/lengths of significant indications.

This information is provided in the body of this report.

5. Describe repair/plugging plans for the steam generator tubes that meet the plugging/repair criteria.

This information is provided in the body of this report.

6. Discuss the previous history of SG tube inspection results, including any 'look backs' performed.

Look backs are performed continuously during our examinations to address indications of interest, such as bobbin I-codes and to address calls made during prior outages. The Single Volumetric Indications (SVIs) identified during this inspection were of particular interest. Look backs indicate that 12 of the 29 tubes with SVIs contained a precursor bobbin indication during the most recent prior examination (1995, RFO5). Increased emphasis placed on the detection of foreign objects during examinations since refueling outage 5 may explain the increased reporting of SVIs and potential loose parts during RFO7.

7. Discuss, in general, the new inspection findings.

The body of this report provides a summary of the results.

8. Describe In-situ pressure test plans and results, if applicable and available, including tube selection criteria.

No in-situ pressure tests were performed during RFO7. However, in-situ testing was a contingency, in the event eddy current testing identified defects which, after consideration of nondestructive examination sizing uncertainty, exceeded the structural limit. No such defects were identified.

9. Describe tube pull plans and preliminary results, if applicable and available, including tube selection criteria.

No tubes were pulled during RFO7.

10. Discuss the assessment of the tube integrity for the previous operating cycle.

The body of this report provides the Condition Monitoring Assessment conclusions.

11. Discuss the assessment of the tube integrity for the next operating cycle.

The body of this report provides Operational Assessment conclusions.

12. Provide the schedule for SG related activities during the remainder of the current outage.

SG primary side inspection and repair activities were completed on February 18, 2001.

13. Discuss what steps have been taken, or will be taken, in response to lessons learned from the Indian Point Unit 2 tube failure. In addition, please be prepared to discuss the following:
- a) Discuss the actions taken in response to identifying a new degradation mechanism, and
 - b) Discuss the actions taken to ensure the data noise levels are acceptable, and
 - c) Address data quality issues and the need for criteria to address data quality.

Several changes were made to the Millstone SG inspection program in response to lessons learned from the Indian Point 2 event:

- 1) Both the Millstone Unit 3 eddy current analyst guidelines and the site specific performance demonstration program were modified to emphasize analyst responsibilities for the rejection of poor quality data or data in which degradation indications may be masked by interfering signals.
- 2) The Millstone Unit 3 eddy current analyst guidelines were modified to include a quantitative acceptance criteria for signal to noise ratio for rotating probe data, (the guidelines already contained similar criteria for bobbin probe data). The site validation of eddy current techniques in use at Millstone Unit 3 included comparisons of noise levels present in acquired plant data with those present in the EPRI ETSS data to ensure that the EPRI qualifications were bounding with respect to noise.
- 3) A 50 percent sample of row one and two U-bends was performed in SGs B and D using mid-range plus point probes. In order to determine if the improved signal to noise (s/n) ratio observed at Indian Point 2 with the use of high frequency plus point probes would also occur at Millstone Unit 3, a 20 tube sample of the Unit 3 u-bends was retested using the high frequency probe. A comparison of the mid-range and high frequency data revealed no advantage in the use of high frequency plus point probes for the inspection of Millstone Unit 3 u-bends.

- 13.a) Discuss the actions taken in response to identifying a new degradation mechanism.

While foreign object related wear is not a new mechanism at Millstone Unit 3, it provides some insight to the unit's response to unusual findings. The identification of foreign object-related degradation (e.g. SVIs) prompted an extensive foreign object search and retrieval effort in which areas of the bundle

typically considered to be inaccessible were examined visually with some success (e.g. FDB 90° from handhole). All foreign objects which could be retrieved were removed from the bundle. Those remaining and those hypothesized to remain were evaluated and the evaluation was incorporated into the Operational Assessment. All tubes surrounding those with foreign object and/or related damage indications were examined with both bobbin coil probes and rotating probes. All tubes affected by foreign objects were removed from service by plugging.

In general, the minimum steps which would be taken to address a new degradation mechanism include:

- i) confirm that the indications are consistent with the EPRI ETSS credited for detection and sizing;
- ii) expand the inspection scope in accordance with the attached table;
- iii) perform in-situ pressure testing if necessary to determine whether NEI-97-06 performance criteria were exceeded.

13.b) Discuss the actions taken to ensure the data noise levels are acceptable.

Refer to 1, 2 and 3 above.

13.c) Address data quality issues and the need for criteria to address data quality.

The proper interpretation of eddy current signals, and the determination that interfering signals may be masking degradation, are dependent upon human judgement and experience. The element of judgement can not be removed from the analysis process. However, there is a need to develop fundamental quantitative criteria (such as the s/n criteria incorporated in the Millstone Unit 3 guidelines) to aid the analyst in making data quality decisions. The criteria should be based on the level of interfering signal present in the data, used to qualify an NDE technique. The industry's vision for addressing the data quality issue leans towards incorporating quantitative criteria into data acquisition software. Poor quality data would be rejected, and the tube rerun prior to being analyzed by a human being. The analysts could then concentrate on the qualitative aspects of data quality - those requiring judgement and experience to evaluate.