Peter E. Katz
Plant General Manager

1650 Calvert Cliffs Parkway
Lusby, Maryland 20657
410 495-4101

Constellation
Nuclear

Calvert Cliffs
Nuclear Power Plant

A Member of the
Constellation Energy Group

February 26, 2002

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
2001 Steam Generator Tube Inspection Results Report

REFERENCE: (a) Calvert Cliffs Nuclear Power Plant Units 1 and 2 Technical Specification 5.6.9.b

Reference (a) requires that we report, on an annual basis, the results of the steam generator tube inservice inspection conducted in the past year. This letter provides the steam generator tube examinations conducted on the Unit 2 steam generators during the spring of 2001. No similar inspections were conducted on the Unit 1 steam generators in 2001. This report includes the number and extent of tubes examined, imperfections noted, and the identity of tubes plugged and sleeved. The Unit 2 steam generator tube inspection results required 51 tubes to be plugged and 210 tubes to be sleeved in No. 21 Steam Generator and 138 tubes to be plugged and 155 tubes to be sleeved in No. 22 Steam Generator. The number of circumferential flaws detected were 8 in No. 21 Steam Generator and 55 in No. 22 Steam Generator.

A001

INSPECTION SCOPE

The examination of Calvert Cliffs Unit 2 Steam Generators (Nos. 21 and 22) consisted of bobbin coil and motorized rotating plus point inspection technologies. All distorted bobbin coil indications were dispositioned with the plus point probe. The table below identifies the number and extent of tubes inspected.

Inspection Zones	Number of Tubes Inspected (SG21/SG22)	Tube Extent Examined
100% Full Length Bobbin Coil	7562/7775	tube end to tube end
100% Plus Point on top of hot leg tube sheet	7562/7775	TSH minus 3" to TSH plus 3"
100% Plus Point of the Steam Blanket Region	602/590	05H to 06C
100% Plus Point on top of cold leg tube sheet	7562/7775	TSC minus 3" to TSC plus 3"
100% Plus Point of Rows 1 and 2 U-bends	111/110	05H Egg Crate to 06C Egg Crate
20% Plus Point Dents at 09H Solid Support Plate	43/117	NA

SG = Steam Generator TSH = Tubesheet Hot TSC = Tubesheet Cold

EDDY CURRENT INSPECTION RESULTS

Attachment (1) contains the results of the motorized rotating plus point and bobbin coil exams for Nos. 21 and 22 Steam Generators. All steam generator tubes with crack-like indications, both circumferential and axial, and all tubes with volumetric indications were removed from service or repaired with sleeves.

Should you have questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

Peter Katz

PEK/GT/bjd

Attachment: (1) Results of Bobbin Coil and Motorized Rotating Plus Point Exams for Unit 2 Nos. 21 and 22 Steam Generators

cc: H. J. Miller, NRC

(Without Attachment)
R. S. Fleishman, Esquire
J. E. Silberg, Esquire
Director, Project Directorate I-1, NRC
D. M. Skay, NRC
Resident Inspector, NRC
R. I. McLean, DNR

ATTACHMENT (1)

RESULTS OF BOBBIN COIL AND MOTORIZED ROTATING PLUS POINT EXAMS FOR UNIT 2 NOs. 21 AND 22 STEAM GENERATORS

Calvert Cliffs Nuclear Power Plant, Inc.
February 26, 2002

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final

****
* INSPECTION SUMMARY QUERY REPORT *
****

* All Test Plans in the database are included in summary: 19 *

Test Plan Name:	Probe Type:	Probe Code:	Leg:
1. F/L Rows >5	BOBBIN	600UL	HL
2. 100% TSH	MRPC	600PP	HL
3. 100% Steam Blanket Region	MRPC	5602C	HL
4. H/L Special Interest Straights	MRPC	600PP	HL
5. H/L Special Interest Ubend	MRPC	5602C	HL
6. Either Leg Ubend Rows <90	MRPC	5602C	HL
7. H/L SI DNT's =>5v 20% Sample	MRPC	5602C	HL
8. H/L SI DNT's =>50v Ubends	MRPC	5602C	HL
9. Either DNT's =>50v Ubend Row<90	MRPC	5602C	HL
10. Rows 1-5 H/L Straight	BOBBIN	600UL	HL
11. EC on New Sleeves	MRPC	500PP	HL
12. Rows 3-5 Candy Cane	BOBBIN	560SF	CL
13. Rows 1-2 Straight	BOBBIN	600UL	CL
14. 100% TSC	MRPC	600PP	CL
15. 100% Rows 1-2 Ubends	MRPC	560FH	CL
16. C/L Special Interest Straights	MRPC	600PP	CL
17. C/L Special Interest Ubend	MRPC	5602C	CL
18. C/L SI DNT's =>50v Straights	MRPC	600PP	CL
19. C/L SI DNT's =>50v Ubends	MRPC	5602C	CL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL
COL	ALL
VOLTS	ALL
DEGREES	ALL
PERCENT	0 to 100
LOCATION	ALL
ELEVATION	ALL
EXTENT	ALL
UTILITY1	ALL
UTILITY2	ALL
NAME	ALL
EVAL TYPE	ALL
CAL GROUP	ALL
PROBE CODE(s)	ALL
IND. CODES	ADR BLG CUD DEP DIS
	DNG DNI DNT DRI DSI
	DTI ETL EXP GEO IDC
	IDM INF INR LDE LPI
	MAI MBM MCI MMI MSI
	MVI NDF NQI NRC NRH
	NSY OBS PBC PID PLP
	PPS PRC PSP PTS PVN

SAI SCI SVI TBP TBS
UDE VOL WAR

CHANNELS ALL

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38
PLANT: CCNPP
UNIT: 2
SG: 22
DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 1

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1	3	1	6.22	183	DNG	P 1	01C	+18.83	06HTEC			M2655	seco	22C00058	C	600CS	341219
2	5	1	8.91	175	DNG	P 1	06H	+6.80	06HTEC			C5542	reso	22C00058	C	600CS	341219
3			21.60	172	DNG	P 1	06H	+9.38	06HTEC			C5542	reso	22C00058	C	600CS	341219
4			17.54	174	DNG	P 1	06C	+3.84	06HTEC			C5542	reso	22C00058	C	600CS	341219
5			7.76	5	INR	P 1	06C	+6.12	06HTEC			C5542	reso	22C00058	C	600CS	341219
6					INF		06C	+14.34	06HTEC	HR		S4373	reso	22C00058	C	600CS	341219
7	7	1	0.24	102	WAR	4	01H	-1.02	TSH01H			A9608	reso	22H00167	H	600PP	345290
8			0.40	79	17	P 2	01H	-1.02	TECTEH			A9608	reso	22H00028	H	600UL	340972
9	15	1	0.15	67	WAR	2	06H	-0.25	05H06C			T6956	prim	22H00220	H	5602C	340987
10			0.19	23	8	P 2	06H	-0.20	TECTEH			C3340	reso	22H00001	H	600UL	340972
11			0.16	27	7	P 2	06H	+0.77	TECTEH			C3340	reso	22H00001	H	600UL	340972
12			0.20	33	WAR	2	06H	+0.79	05H06C			T6956	prim	22H00220	H	5602C	340987
13	8	2	2.58	179	DNG	P 1	06C	+1.36	TECTEH			D3858	reso	22H00001	H	600UL	340972
14	24	2	2.90	179	DNT	P 1	06H	+1.18	TECTEH			M2655	seco	22H00001	H	600UL	340972
15	5	3	17.73	180	DNG	P 1	06H	+5.28	06HTEC			M2655	seco	22C00058	C	600CS	341219
16	9	3	0.04	103	INR	P 1	06H	+6.67	TECTEH			C3340	reso	22H00001	H	600UL	340972
17	15	3	0.51	80	MBM	5	01C	+3.93	TECTEH			L2157	reso	22H00002	H	600UL	331893
			0.49	51	MBM	5	01C	+12.20	TECTEH			L2157	reso	22H00002	H	600UL	331893
-			0.87	78	MBM	5	TSC	+11.83	TECTEH			L2157	reso	22H00002	H	600UL	331893
20	2	4	2.37	176	DNG	P 1	02H	+22.24	06HTEH			A6997	seco	22H00083	H	600UL	340943
21	12	4	10.24	180	DNG	P 1	06H	+7.46	TECTEH			O8795	seco	22H00002	H	600UL	331893
22	24	4	0.59	71	MBM	5	05H	+29.40	TECTEH			L2157	reso	22H00002	H	600UL	331893
23	1	5			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
24			2.30	13	GEO	2	06H	+7.78	06C06H			C3340	reso	22C00099	C	560FH	345358
25			2.14	12	PID	2	06H	+7.78	06C06H			M7007	prim	22C00100	C	560FH	345358
26	33	5	4.57	181	DNT	P 1	VM	-1.40	TECTEH			M2655	seco	22H00001	H	600UL	340972
27			9.91	178	DNT	P 1	VM	-0.40	TECTEH			M2655	seco	22H00001	H	600UL	340972
28	12	6	10.18	178	DNG	P 1	06C	+7.66	TECTEH			L2157	reso	22H00002	H	600UL	331893
29	16	6			INF	9	TSH	+0.17	TSHTSH	HR		C5542	reso	22H00103	H	600PP	345338
30	22	6	0.20	79	PLP	10	TSH	-0.55	TSHTSH			G2927	prim	22H00101	H	600PP	345291
31	30	6	0.78	89	MBM	5	04C	+13.93	TECTEH			M7006	reso	22H00001	H	600UL	340972
32			1.04	79	MBM	5	03C	+6.56	TECTEH			M7006	reso	22H00001	H	600UL	340972
33			0.40	59	MBM	5	03C	+18.73	TECTEH			M7006	reso	22H00001	H	600UL	340972
34			0.51	75	MBM	6	03C	+20.88	TECTEH			M7006	reso	22H00001	H	600UL	340972
35			0.23	81	MBM	5	03C	+22.64	TECTEH			M7006	reso	22H00001	H	600UL	340972
36			0.48	77	MBM	5	03C	+26.45	TECTEH			M7006	reso	22H00001	H	600UL	340972
37			0.28	79	MBM	5	03C	+31.28	TECTEH			M7006	reso	22H00001	H	600UL	340972
38			0.52	65	MBM	5	02C	+35.32	TECTEH			M7006	reso	22H00001	H	600UL	340972
39	40	6	3.62	181	DNG	P 1	VM	+9.89	TECTEH			L2157	reso	22H00002	H	600UL	331893
40			2.28	180	DNG	P 1	06C	+13.93	TECTEH			L2157	reso	22H00002	H	600UL	331893
41	42	6	0.70	66	MBM	6	06H	+9.16	TECTEH			C3340	reso	22H00001	H	600UL	340972
42			6.68	7	PVN	P 1	02C	+8.51	TECTEH			M7006	reso	22H00001	H	600UL	340972
	1	7			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
			2.58	13	PID	2	06H	+7.68	06C06H			M7007	prim	22C00100	C	560FH	345358
45			2.97	14	GEO	2	06H	+7.68	06C06H			C3340	reso	22C00099	C	560FH	345358
46	5	7	9.66	182	DNG	P 1	02H	+4.24	06HTEH			T7451	seco	22H00082	H	600UL	340912
47			4.95	184	DNG	P 1	02H	+31.32	06HTEH			T7451	seco	22H00082	H	600UL	340912
48			5.31	180	DNG	P 1	03H	+19.53	06HTEH			T7451	seco	22H00082	H	600UL	340912

49				1.07	79	MBM	5	05H	+13.50		06HTEH				A9608	reso	22H00082	H	600UL	340912

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 2

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
50	9	7	14.78	179	DNG	P 1	VM		+9.87		TECTEH				M2655	seco	22H00001	H	600UL	340972
51	11	7	3.38	182	DNG	P 1	01C		+17.80		TECTEH				O8795	seco	22H00002	H	600UL	331893
52	25	7	0.77	86	MBM	5	01C		+8.51		TECTEH				M7006	reso	22H00001	H	600UL	340972
53	29	7	6.55	178	DNG	P 1	DH		+10.54		TECTEH				M2655	seco	22H00001	H	600UL	340972
54	39	7	0.19	55	MBM	5	01H		+7.84		TECTEH				L2157	reso	22H00002	H	600UL	331893
55			0.50	98	INR	5	DH		+8.08		TECTEH				L2157	reso	22H00002	H	600UL	331893
56	8	8	5.56	177	DNG	P 1	05H		+14.07		TECTEH				M2655	seco	22H00001	H	600UL	340972
57	10	8	3.22	175	DNG	P 1	03C		+2.93		TECTEH				O8795	seco	22H00002	H	600UL	331893
58	12	8			INF	P 1	VM		+8.11		TECTEH	HR			M7006	reso	22H00001	H	600UL	340972
59			13.07	181	DNG	P 1	DC		+8.08		TECTEH				M2655	seco	22H00001	H	600UL	340972
60	28	8	8.11	181	DNG	P 1	DH		+9.24		TECTEH				M2655	seco	22H00001	H	600UL	340972
61	48	8	2.69	180	DNG	P 1	04H		+21.15		TECTEH				M2655	seco	22H00001	H	600UL	340972
62			3.07	179	DNG	P 1	04H		+21.79		TECTEH				M2655	seco	22H00001	H	600UL	340972
63	5	9	20.25	182	DNG	P 1	06C		+4.46		06HTEC				M2655	seco	22C00058	C	600CS	341219
64	9	9	16.26	179	DNG	P 1	VM		+10.01		TECTEH				M2655	seco	22H00001	H	600UL	340972
65	27	9	0.42	91	MBM	5	05H		+23.80		TECTEH				M7006	reso	22H00001	H	600UL	340972
66	29	9	4.42	175	DNT	P 1	VM		-2.25		TECTEH				N5432	reso	22H00028	H	600UL	340972
	37	9	6.50	178	DNT	P 1	VM		-1.57		TECTEH				N5877	seco	22H00028	H	600UL	340972
	39	9	0.83	61	MBM	5	03H		+23.36		TECTEH				M7006	reso	22H00001	H	600UL	340972
69			0.72	92	MBM	6	05C		+7.54		TECTEH				M7006	reso	22H00001	H	600UL	340972
70			0.60	68	MBM	6	05C		+9.06		TECTEH				M7006	reso	22H00001	H	600UL	340972
71			1.20	85	MBM	6	05C		+36.73		TECTEH				M7006	reso	22H00001	H	600UL	340972
72	2	10	3.12	354	INR	P 1	06C		+3.84		06CTEC				D3858	reso	22C00059	C	600CS	341611
73	4	10	3.35	183	DNG	P 1	TSC		+34.95		06HTEC				M2655	seco	22C00058	C	600CS	341219
74	10	10			NDF		DH		+2.17	TO+3.48	05H06C				K5380	prim	22H00224	H	5602C	340987
75			1.00	55	ADR	6	DH		+2.17	TO+3.48	TECTEH				M7006	reso	22H00001	H	600UL	340972
76	14	10	0.35	56	INR	P 1	01H		-1.06		TECTEH				M7006	reso	22H00001	H	600UL	340972
77	38	10			INF		TSH		+1.44		TSHTSH	HR			L2157	reso	22H00107	H	600PP	345291
78					INF	8	TSH		+1.64		TECTEH	HR			M7006	reso	22H00001	H	600UL	340972
79	42	10	0.89	76	MBM	6	TSC		+30.91		TECTEH				M7006	reso	22H00001	H	600UL	340972
80	48	10	3.32	178	DNT	P 1	03H		+0.71		TECTEH				L2157	reso	22H00002	H	600UL	331893
81	7	11	2.21	183	DNT	P 1	04H		-0.96		TECTEH				M2655	seco	22H00007	H	600UL	340972
82			0.65	87	MBM	5	04H		+18.47		TECTEH				M7006	reso	22H00007	H	600UL	340972
83			6.15	178	DNG	P 1	VM		+4.25		TECTEH				M7006	reso	22H00007	H	600UL	340972
84	9	11	10.27	180	DNG	P 1	VM		+9.80		TECTEH				A6997	seco	22H00083	H	600UL	340943
85	33	11	4.34	180	DNG	P 1	02H		+18.03		TECTEH				A6997	seco	22H00083	H	600UL	340943
86			4.48	182	DNG	P 1	03H		+5.52		TECTEH				A6997	seco	22H00083	H	600UL	340943
87	39	11			INF		TSH		+1.20		TSHTSH	HR			L2157	reso	22H00107	H	600PP	345291
88			3.45	180	DNT	P 1	VM		-1.86		TECTEH				M2655	seco	22H00007	H	600UL	340972
89	43	11	0.57	89	MBM	6	02C		+15.16		TECTEH				M7006	reso	22H00007	H	600UL	340972
90	4	12	6.47	5	INR	P 1	06H		+4.38		06HTEC				C5542	reso	22C00058	C	600CS	341219
91			2.35	169	INR	P 1	06H		+5.83		06HTEC				M2655	seco	22C00058	C	600CS	341219
92			15.19	181	INR	P 1	06H		+6.08		06HTEC				M2655	seco	22C00058	C	600CS	341219
			6.94	177	INR	P 1	06H		+6.87		06HTEC				M2655	seco	22C00058	C	600CS	341219
94			6.21	175	INR	P 1	06H		+7.49		06HTEC				M2655	seco	22C00058	C	600CS	341219
95	28	12	2.90	179	DNT	P 1	VM		+2.01		TECTEH				A6997	seco	22H00083	H	600UL	340943
96	52	12	0.65	85	MBM	5	04H		+9.61		TECTEH				M7006	reso	22H00083	H	600UL	340943
97			0.69	77	MBM	6	06H		+16.06		TECTEH				M7006	reso	22H00083	H	600UL	340943

98	56	12	0.53	69	PLP	9	TSH	+0.27	TSHTSH				L2157	reso	22H00108	H	600PP	345338

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 3

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
99			2.14	182	DNG	P 1	01C	+35.68	TECTEH			A6997	seco	22H00083	H	600UL	340943
100	60	12	2.68	175	DNG	P 1	DH	+3.72	TECTEH			A6997	seco	22H00083	H	600UL	340943
101			5.42	178	DNG	P 1	DH	+11.33	TECTEH			A6997	seco	22H00083	H	600UL	340943
102			2.19	179	DNT	P 1	VM	-1.76	TECTEH			A6997	seco	22H00083	H	600UL	340943
103			3.01	181	DNT	P 1	VM	+1.72	TECTEH			A6997	seco	22H00083	H	600UL	340943
104	66	12	0.25	63	10	P 2	02C	+0.93	TECTEH			A9608	reso	22H00007	H	600UL	340972
105	1	13	0.31	86	PLP	9	TSC	+0.48	TSCTSC			F3453	reso	22C00086	C	600PP	345298
106	5	13	19.97	182	DNG	P 1	06H	+5.25	06HTEC			M2655	seco	22C00058	C	600CS	341219
107	9	13	13.62	180	DNG	P 1	VM	+9.73	TECTEH			M2655	seco	22H00007	H	600UL	340972
108	25	13	0.46	82	MBM	5	04C	+32.25	TECTEH			M7006	reso	22H00007	H	600UL	340972
109	39	13	0.83	88	MBM	5	VM	+6.70	TECTEH			M7006	reso	22H00083	H	600UL	340943
110			0.42	73	MBM	5	TSC	+28.18	TECTEH			M7006	reso	22H00083	H	600UL	340943
111	67	13	9.48	177	DNG	P 1	TSH	+8.62	TECTEH			M2655	seco	22H00007	H	600UL	340972
112	2	14	1.07	78	MBM	6	05H	+27.05	06HTEH			M7006	reso	22H00083	H	600UL	340943
113					INF		06C	+3.70	06CTEC	HR		S4373	reso	22C00059	C	600CS	341611
114			0.56	75	MBM	5	03C	+35.30	06CTEC			C5542	reso	22C00059	C	600CS	341611
115	24	14	4.60	185	DNT	P 1	06H	-0.04	TECTEH			M2655	seco	22H00007	H	600UL	340972
			0.97	85	MBM	5	TSC	+11.90	TECTEH			M7006	reso	22H00007	H	600UL	340972
	26	14	0.82	82	MBM	5	03H	+27.41	TECTEH			L2157	reso	22H00008	H	600UL	331893
118	30	14	0.54	54	MBM	5	05C	+20.33	TECTEH			L2157	reso	22H00008	H	600UL	331893
119	32	14	7.59	180	DNT	P 1	VM	+1.93	TECTEH			M2655	seco	22H00007	H	600UL	340972
120	60	14	2.86	181	DNG	P 1	VM	+19.89	TECTEH			M2655	seco	22H00007	H	600UL	340972
121	5	15	4.79	180	DNT	P 1	VM	+0.13	06HTEC			M2655	seco	22C00058	C	600CS	341219
122	9	15	3.83	182	DNG	P 1	01C	+6.95	TECTEH			M2655	seco	22H00007	H	600UL	340972
123	15	15	0.23	129	INR	2	VM	+0.00	05H06C			L2157	reso	22H00208	H	5602C	326248
124	27	15	1.24	78	MBM	6	04H	+24.93	TECTEH			L2157	reso	22H00008	H	600UL	331893
125	33	15	3.16	177	DNG	P 1	TSH	+32.77	TECTEH			M2655	seco	22H00007	H	600UL	340972
126	37	15	2.07	176	DNG	P 1	05H	+35.89	TECTEH			M2655	seco	22H00007	H	600UL	340972
127	51	15	22.49	178	DNG	P 1	02H	+34.94	TECTEH			I3805	seco	22H00008	H	600UL	331893
128	57	15	4.33	182	DNG	P 1	07C	+5.90	TECTEH			M7006	reso	22H00007	H	600UL	340972
129			0.89	83	MBM	5	04C	+9.53	TECTEH			M7006	reso	22H00007	H	600UL	340972
130	61	15	3.20	179	DNG	P 1	DH	+10.32	TECTEH			M2655	seco	22H00007	H	600UL	340972
131			6.98	179	DNG	P 1	DH	+16.72	TECTEH			M2655	seco	22H00007	H	600UL	340972
132	8	16	3.31	177	DNG	P 1	04C	+13.25	TECTEH			M2655	seco	22H00009	H	600UL	340972
133	12	16	3.59	190	DNG	P 1	05C	+1.88	TECTEH			M2655	seco	22H00007	H	600UL	340972
134	42	16	0.84	68	MBM	5	06C	+11.89	TECTEH			L2157	reso	22H00008	H	600UL	331893
135	44	16	2.53	182	DNG	P 1	VM	+11.62	TECTEH			M2655	seco	22H00007	H	600UL	340972
136	70	16	0.89	85	MBM	5	03C	+31.18	TECTEH			L2157	reso	22H00008	H	600UL	331893
137	27	17	5.69	176	DNT	P 1	VM	-0.45	TECTEH			N5877	seco	22H00028	H	600UL	340972
138	31	17	3.33	177	DNT	P 1	03H	-0.72	TECTEH			I3805	seco	22H00010	H	600UL	331893
139	35	17	4.40	176	DNG	P 1	04C	+1.65	TECTEH			I3805	seco	22H00010	H	600UL	331893
140	65	17	0.49	83	MBM	5	04C	+8.56	TECTEH			M7006	reso	22H00009	H	600UL	340972
[illegible]			0.89	75	MBM	5	03C	+17.50	TECTEH			M7006	reso	22H00009	H	600UL	340972
			1.13	69	MBM	5	03C	+29.47	TECTEH			M7006	reso	22H00009	H	600UL	340972
143	69	17	0.32	80	MBM	6	02C	+27.06	TECTEH			M7006	reso	22H00009	H	600UL	340972
144	6	18	0.38	81	MBM	5	TSC	+11.03	TECTEH			M7006	reso	22H00009	H	600UL	340972
145	12	18	10.63	183	DNG	P 1	06H	+7.38	TECTEH			T7451	seco	22H00010	H	600UL	331893
146	20	18	3.64	181	DNG	P 1	06H	+2.24	TECTEH			T7451	seco	22H00010	H	600UL	331893

147				2.52	179	DNG	P 1	01C	+34.79	TECTEH			T7451	seco	22H00010	H	600UL	331893

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 4

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
148	38	18	3.60	181	DNG	P 1	06H	+21.78	TECTEH			M2655	seco	22H00009	H	600UL	340972
149			13.11	178	DNT	P 1	VM	-0.76	TECTEH			M2655	seco	22H00009	H	600UL	340972
150			4.65	179	DNT	P 1	VM	+0.90	TECTEH			M2655	seco	22H00009	H	600UL	340972
151			12.21	179	DNG	P 1	07C	+2.03	TECTEH			M7006	reso	22H00009	H	600UL	340972
152			2.89	177	DNG	P 1	TSC	+4.10	TECTEH			M2655	seco	22H00009	H	600UL	340972
153			8.64	182	DNG	P 1	TSC	+13.18	TECTEH			M2655	seco	22H00009	H	600UL	340972
154			5.90	177	DNG	P 1	TSC	+30.63	TECTEH			M2655	seco	22H00009	H	600UL	340972
155			7.06	178	DNG	P 1	TSC	+37.06	TECTEH			M2655	seco	22H00009	H	600UL	340972
156	46	18	0.89	84	MBM	5	03H	+16.77	TECTEH			M7006	reso	22H00009	H	600UL	340972
157	50	18	3.22	184	DNG	P 1	06H	+9.03	TECTEH			M2655	seco	22H00009	H	600UL	340972
158			2.57	179	DNG	P 1	06C	+2.30	TECTEH			M2655	seco	22H00009	H	600UL	340972
159			8.04	177	DNG	P 1	06C	+12.40	TECTEH			M2655	seco	22H00009	H	600UL	340972
160	54	18			OBS		TSC	-20.96	TSCTEH			W2096	prim	22H00028	H	600UL	340972
161					OBS		TSC	-20.29	TSCTEH			W2096	prim	22H00078	H	600UL	331969
162					OBS		TEC	+0.00	TECTEC			A9608	reso	22C00077	C	600PP	345298
163					OBS		TEC	+0.00	TECTEC			C4373	reso	22C00060	C	600CS	341219
164	60	18	3.14	182	DNG	P 1	VM	+19.47	TECTEH			I3805	seco	22H00010	H	600UL	331893
	68	18	0.67	94	MBM	5	05H	+7.59	TECTEH			C5542	reso	22H00010	H	600UL	331893
			2.50	178	DNG	P 1	03C	+24.97	TECTEH			I3805	seco	22H00010	H	600UL	331893
167			0.92	107	MBM	5	01C	+26.55	TECTEH			C5542	reso	22H00010	H	600UL	331893
168			0.56	87	MBM	5	01C	+31.80	TECTEH			C5542	reso	22H00010	H	600UL	331893
169	72	18	3.18	176	DNG	P 1	02C	+22.41	TECTEH			I3805	seco	22H00010	H	600UL	331893
170	76	18	15.92	181	DNT	P 1	DH	-0.40	TECTEH			I3805	seco	22H00010	H	600UL	331893
171	78	18	3.02	183	DNG	P 1	03C	+8.83	TECTEH			M2655	seco	22H00009	H	600UL	340972
172	3	19	0.47	69	MBM	5	04C	+29.89	06HTEC			C5542	reso	22C00058	C	600CS	341219
173	5	19	20.15	181	DNG	P 1	06H	+5.11	06HTEC			M2655	seco	22C00058	C	600CS	341219
174	15	19	2.94	184	DNG	P 1	05H	+2.20	TECTEH			M0945	seco	22H00009	H	600UL	340972
175	19	19	11.90	179	DNG	P 1	TSC	+36.94	TECTEH			M0945	seco	22H00009	H	600UL	340972
176	25	19	0.68	70	MBM	5	02C	+27.49	TECTEH			C5542	reso	22H00010	H	600UL	331893
177	45	19	2.57	181	DNG	P 1	04H	+6.79	TECTEH			T7451	seco	22H00010	H	600UL	331893
178	67	19	2.26	177	DNG	P 1	TSH	+11.79	TECTEH			M0945	seco	22H00009	H	600UL	340972
179			3.52	180	DNG	P 1	TSH	+22.24	TECTEH			M0945	seco	22H00009	H	600UL	340972
180	69	19	2.56	183	DNG	P 1	05C	+18.98	TECTEH			T7451	seco	22H00010	H	600UL	331893
181			2.15	182	DNG	P 1	05C	+20.96	TECTEH			T7451	seco	22H00010	H	600UL	331893
182			2.44	182	DNG	P 1	03C	+21.24	TECTEH			T7451	seco	22H00010	H	600UL	331893
183	81	19	2.00	182	DNG	P 1	08H	+13.23	TECTEH			M0945	seco	22H00009	H	600UL	340972
184	12	20	8.91	180	DNG	P 1	06H	+7.98	TECTEH			T7451	seco	22H00010	H	600UL	331893
185	14	20	2.76	180	DNG	P 1	01H	+3.43	TECTEH			M0945	seco	22H00009	H	600UL	340972
186			12.55	179	DNG	P 1	01H	+3.74	TECTEH			M0945	seco	22H00009	H	600UL	340972
187			2.58	177	DNG	P 1	04H	+32.60	TECTEH			M0945	seco	22H00009	H	600UL	340972
188			13.28	180	DNG	P 1	TSC	+35.96	TECTEH			M0945	seco	22H00009	H	600UL	340972
189			2.68	172	DNG	P 1	TSC	+36.64	TECTEH			M0945	seco	22H00009	H	600UL	340972
	22	20	2.70	183	DNG	P 1	01H	+26.62	TECTEH			M0945	seco	22H00009	H	600UL	340972
	26	20	2.47	178	DNG	P 1	06H	+14.28	TECTEH			M0945	seco	22H00009	H	600UL	340972
192	38	20	2.81	182	DNG	P 1	06H	+21.64	TECTEH			M0945	seco	22H00009	H	600UL	340972
193			3.15	181	DNG	P 1	06H	+24.15	TECTEH	LOCOK		D3858	reso	22H00009	H	600UL	340972
194			2.31	181	DNG	P 1	06C	+19.46	TECTEH			M0945	seco	22H00009	H	600UL	340972
195	58	20	2.43	180	DNG	P 1	VM	+18.46	TECTEH			M0945	seco	22H00009	H	600UL	340972

196	62	20	3.52	182	DNG	P 1	VM	+20.27	TECTEH			M0945	seco	22H00009	H	600UL		340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 5

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
197	64	20	3.55	179	DNT	P 1	VM	-1.83	TECTEH			T7451	seco	22H00010	H	600UL	331893
198	78	20	2.67	180	DNG	P 1	08C	+10.87	TECTEH			M7006	reso	22H00009	H	600UL	340972
199	21	21			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
200			0.32	93	SCI	P 1	TSH	+0.06	TSHTSH	1.03		D3858	reso	22H00112	H	600PP	345338
201			0.24	125	PID	P 1	TSH	+0.06	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
202			0	0	SCI	1	TSH	+0.06	TSHTSH	0		D3858	reso	22H00112	H	600PP	345338
203	31	21	2.73	185	DNG	P 1	04H	+36.27	TECTEH			M0945	seco	22H00009	H	600UL	340972
204	37	21	5.02	181	DNT	P 1	VM	-1.65	TECTEH			C5542	reso	22H00010	H	600UL	331893
205	41	21	2.26	179	DNT	P 1	VM	-1.75	TECTEH			T7451	seco	22H00010	H	600UL	331893
206	63	21	2.20	183	DNG	P 1	01C	+31.03	TECTEH			M0945	seco	22H00009	H	600UL	340972
207	67	21	2.02	182	DNG	P 1	VM	+23.33	TECTEH			M0945	seco	22H00009	H	600UL	340972
208	2	22	0.30	94	MBM	5	04C	+15.71	06CTEC			C5542	reso	22C00059	C	600CS	341611
209			0.59	95	MBM	5	04C	+22.31	06CTEC			C5542	reso	22C00059	C	600CS	341611
210			0.44	84	MBM	5	04C	+28.74	06CTEC			C5542	reso	22C00059	C	600CS	341611
211	4	22	0.66	104	MBM	5	02C	+24.16	06HTEC			C5542	reso	22C00058	C	600CS	341219
212	12	22	9.27	181	DNG	P 1	06H	+7.71	TECTEH			H4599	seco	22H00015	H	600UL	331895
213	20	22	0.49	64	MBM	5	02C	+6.06	TECTEH			L2157	reso	22H00014	H	600UL	340972
	42	22	2.97	179	DNG	P 1	VM	+10.79	TECTEH			H4599	seco	22H00015	H	600UL	331895
	44	22	2.05	13	INR	P 1	VM	+12.51	TECTEH			D3858	reso	22H00014	H	600UL	340972
216	60	22	2.61	186	DNG	P 1	VM	+17.67	TECTEH			M0945	seco	22H00009	H	600UL	340972
217			5.13	182	DNG	P 1	VM	+19.96	TECTEH			M0945	seco	22H00009	H	600UL	340972
218			2.45	13	INR	P 1	03C	+4.61	TECTEH			M0945	seco	22H00009	H	600UL	340972
219	82	22	3.04	181	DNG	P 1	07C	+19.53	TECTEH			T7451	seco	22H00010	H	600UL	331893
220	29	23			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
221			0.18	96	PID	4	TSH	+0.15	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
222			0.21	102	SAI	2	TSH	+0.15	TSHTSH	0.3		F6623	reso	22H00117	H	600PP	345291
223			0.09	43	SAI	1	TSH	+0.15	TSHTSH	0.3		F6623	reso	22H00117	H	600PP	345291
224	33	23	5.76	184	DNG	P 1	VM	-2.04	TECTEH	LOCOK		D3858	reso	22H00014	H	600UL	340972
225	35	23			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
226			0.00	0	SCI	1	TSH	+0.10	TSHTSH	0.0		N5432	reso	22H00116	H	600PP	326414
227			0.10	110	SCI	P 1	TSH	+0.10	TSHTSH	0.3		N5432	reso	22H00116	H	600PP	326414
228			0.05	101	PID	P 1	TSH	+0.10	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
229	37	23	4.14	181	DNG	P 1	01C	+26.53	TECTEH			T7451	seco	22H00014	H	600UL	340972
230	75	23			INF		DC	-0.53	TECTEH	HR		M1680	reso	22H00015	H	600UL	331895
231			0.91	118	30	P 2	DC	+0.52	TECTEH	LOCOK		D3858	reso	22H00015	H	600UL	331895
232	6	24	5.28	178	DNT	P 1	VM	-0.36	TECTEH			L2157	reso	22H00014	H	600UL	340972
233	8	24	0.65	83	MBM	5	TSH	+24.19	TECTEH			L2157	reso	22H00015	H	600UL	331895
234	12	24	9.28	178	DNG	P 1	06C	+8.07	TECTEH			H4599	seco	22H00015	H	600UL	331895
235	26	24	1.96	78	MBM	5	VM	+2.61	TECTEH			L2157	reso	22H00014	H	600UL	340972
236	28	24			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
237			0.14	119	SAI	1	TSH	+0.22	TSHTSH	0.2		N5432	reso	22H00116	H	600PP	326414
238			0.30	87	PID	4	TSH	+0.22	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
			0.29	80	SAI	2	TSH	+0.22	TSHTSH	0.2		N5432	reso	22H00116	H	600PP	326414
	32	24	8.61	184	DNG	P 1	04H	+5.04	TECTEH			H4599	seco	22H00015	H	600UL	331895
241	38	24	3.90	177	DNG	P 1	TSC	+28.40	TECTEH			T7451	seco	22H00014	H	600UL	340972
242	40	24	2.48	182	DNG	P 1	05H	+16.24	TECTEH			H4599	seco	22H00015	H	600UL	331895
243	60	24	3.73	181	DNG	P 1	VM	+19.25	TECTEH			H4599	seco	22H00015	H	600UL	331895
244	84	24	3.70	76	MBM	6	VH	+21.29	TECTEH			L2157	reso	22H00015	H	600UL	331895

245	5	25	19.75	182	DNG	P 1	06C	+4.58	06HTEC			M2655	seco	22C00058	C	600CS	341219

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 6

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
246	9	25	11.00	182	DNG	P 1	06H	+6.56	TECTEH			T7451	seco	22H00014	H	600UL	340972
247	13	25	0.38	76	INR	P 1	03H	-0.83	TECTEH			T7451	seco	22H00014	H	600UL	340972
248	27	25	4.06	179	DNG	P 1	02H	+14.74	TECTEH			H4599	seco	22H00015	H	600UL	331895
249			0.85	86	MBM	6	05C	+14.92	TECTEH			L2157	reso	22H00015	H	600UL	331895
250	29	25			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
251			0.17	89	PID	4	TSH	+0.23	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
252			0.23	66	SAI	2	TSH	+0.23	TSHTSH	0.4		F6623	reso	22H00117	H	600PP	345291
253			0.12	40	SAI	1	TSH	+0.23	TSHTSH	0.3		F6623	reso	22H00117	H	600PP	345291
254	37	25			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
255			0.16	78	SCI	P 1	TSH	+0.10	TSHTSH	0.3		F6623	reso	22H00117	H	600PP	345291
256			0.07	35	SCI	1	TSH	+0.10	TSHTSH	0.3		F6623	reso	22H00117	H	600PP	345291
257			0.14	87	PID	P 1	TSH	+0.10	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
258	39	25	4.20	176	DNT	P 1	VM	-1.82	TECTEH			H4599	seco	22H00015	H	600UL	331895
259	41	25			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
260			0.17	84	PID	P 1	TSH	+0.06	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
261			0.27	50	SCI	P 1	TSH	+0.06	TSHTSH	0.6		F6623	reso	22H00117	H	600PP	345291
262			0.39	26	SCI	1	TSH	+0.06	TSHTSH	0.3		F6623	reso	22H00117	H	600PP	345291
			1.22	85	MBM	5	04C	+37.31	TECTEH			L2157	reso	22H00014	H	600UL	340972
	53	25			OBS		01H	+0.00	01H01H			D9573	prim	22H00167	H	600PP	345290
265			0.77	27	DSI	P 1	01H	+0.66	TECTEH			B4165	prim	22H00014	H	600UL	340972
266					NDF		01H	+0.66	01H01H			P5436	prim	22H00196	H	500DP	290406
267	59	25	2.60	178	DNG	P 1	TSH	+24.02	TECTEH			H4599	seco	22H00015	H	600UL	331895
268	69	25	0.99	74	MBM	5	06H	+20.96	TECTEH			L2157	reso	22H00014	H	600UL	340972
269	83	25	0.77	83	MBM	5	03H	+10.13	TECTEH			L2157	reso	22H00015	H	600UL	331895
270	91	25	2.16	178	DNG	P 1	07H	+20.77	TECTEH			M9715	seco	22H00029	H	600UL	331895
271			2.73	180	DNG	P 1	08H	+14.28	TECTEH			M9715	seco	22H00029	H	600UL	331895
272			2.63	180	DNT	P 1	08C	+1.01	TECTEH			M9715	seco	22H00029	H	600UL	331895
273			3.02	181	DNG	P 1	08C	+5.44	TECTEH			M9715	seco	22H00029	H	600UL	331895
274			5.82	179	DNG	P 1	08C	+7.21	TECTEH			M9715	seco	22H00029	H	600UL	331895
275			2.42	178	DNG	P 1	08C	+8.81	TECTEH			M9715	seco	22H00029	H	600UL	331895
276			2.23	180	DNG	P 1	07C	+15.82	TECTEH			M9715	seco	22H00029	H	600UL	331895
277	95	25	3.12	177	DNG	P 1	03H	+13.85	TECTEH			N5877	seco	22H00028	H	600UL	340972
278			4.58	177	DNT	P 1	09C	-0.41	TECTEH			N5877	seco	22H00028	H	600UL	340972
279			5.95	177	DNT	P 1	09C	+0.50	TECTEH			N5877	seco	22H00028	H	600UL	340972
280	4	26	20.79	178	DNG	P 1	06H	+6.14	06HTEC			M2655	seco	22C00058	C	600CS	341219
281			23.78	178	DNG	P 1	06H	+6.55	06HTEC			M2655	seco	22C00058	C	600CS	341219
282			9.40	178	DNG	P 1	06H	+6.93	06HTEC			M2655	seco	22C00058	C	600CS	341219
283			8.29	177	DNG	P 1	06H	+7.39	06HTEC			M2655	seco	22C00058	C	600CS	341219
284			18.24	178	DNG	P 1	06H	+7.99	06HTEC			M2655	seco	22C00058	C	600CS	341219
285	8	26	2.38	180	DNG	P 1	05H	+3.57	TECTEH			H4599	seco	22H00015	H	600UL	331895
286			2.43	184	DNG	P 1	01C	+36.49	TECTEH			H4599	seco	22H00015	H	600UL	331895
287	40	26			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
[illegible]			0.46	77	SAI	2	TSH	+0.22	TSHTSH	0.3		N5432	reso	22H00116	H	600PP	326414
			0.45	45	SAI	1	TSH	+0.22	TSHTSH	0.4		N5432	reso	22H00116	H	600PP	326414
290			0.39	86	PID	4	TSH	+0.22	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
291			6.65	182	DNT	P 1	DH	-0.67	TECTEH			H4599	seco	22H00015	H	600UL	331895
292	42	26			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
293			0.10	96	SCI	P 1	TSH	+0.14	TSHTSH	0.2		F6623	reso	22H00117	H	600PP	345291

294				0.04	70	SCI	1	TSH	+0.14	TSHTSH	0.2			F6623	reso	22H00117	H	600PP	345291

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 7

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
295			0.10	79	PID	P 1	TSH	+0.14	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
296	54	26	4.38	183	DNT	P 1	07H	+0.07	TECTEH			L2157	reso	22H00014	H	600UL	340972
297			4.44	184	DNG	P 1	VM	+15.05	TECTEH			T7451	seco	22H00014	H	600UL	340972
298			5.33	185	DNG	P 1	VM	+15.97	TECTEH			T7451	seco	22H00014	H	600UL	340972
299			3.41	182	DNT	P 1	07C	+0.25	TECTEH			T7451	seco	22H00014	H	600UL	340972
300			4.54	183	DNG	P 1	06C	+8.67	TECTEH			T7451	seco	22H00014	H	600UL	340972
301			1.89	185	INR	P 1	06C	+21.19	TECTEH			A9608	reso	22H00014	H	600UL	340972
302			4.68	181	DNG	P 1	04C	+27.90	TECTEH			T7451	seco	22H00014	H	600UL	340972
303	60	26	3.25	182	DNG	P 1	02H	+37.27	TECTEH			L2157	reso	22H00015	H	600UL	331895
304			3.30	176	DNG	P 1	04H	+23.46	TECTEH			H4599	seco	22H00015	H	600UL	331895
305			3.46	180	DNG	P 1	VM	+19.21	TECTEH			H4599	seco	22H00015	H	600UL	331895
306	62	26	3.16	183	DNG	P 1	VM	+20.61	TECTEH			T7451	seco	22H00014	H	600UL	340972
307	64	26	2.33	178	DNG	P 1	07C	+24.39	TECTEH			H4599	seco	22H00015	H	600UL	331895
308	66	26	0.56	82	MBM	5	04H	+8.64	TECTEH			L2157	reso	22H00014	H	600UL	340972
309			0.76	67	MBM	5	04H	+11.00	TECTEH			L2157	reso	22H00014	H	600UL	340972
310	74	26	2.61	184	DNG	P 1	VM	+11.65	TECTEH			L2157	reso	22H00014	H	600UL	340972
311	80	26	30.81	175	DNG	P 1	02C	+22.51	TECTEH			H4599	seco	22H00015	H	600UL	331895
	84	26	2.33	182	DNG	P 1	08H	+15.50	TECTEH			H4599	seco	22H00015	H	600UL	331895
	92	26	0.49	95	18	P 2	VH	+1.43	TECTEH			W2096	prim	22H00028	H	600UL	340972
314	96	26	2.12	183	DNT	P 1	09C	-0.52	TECTEH			M9715	seco	22H00029	H	600UL	331895
315			1.54	84	MBM	5	02C	+7.86	TECTEH			N5432	reso	22H00029	H	600UL	331895
316	98	26	3.54	178	DNT	P 1	09C	-0.46	TECTEH			N5877	seco	22H00028	H	600UL	340972
317			2.80	172	DNT	P 1	09C	+0.39	TECTEH			N5877	seco	22H00028	H	600UL	340972
318	5	27	18.65	181	DNG	P 1	06C	+4.65	06HTEC			M2655	seco	22C00058	C	600CS	341219
319	7	27	4.23	179	DNT	P 1	VM	-1.50	TECTEH			H4599	seco	22H00015	H	600UL	331895
320	27	27	0.62	82	MBM	5	05H	+12.62	TECTEH			L2157	reso	22H00014	H	600UL	340972
321	35	27			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
322			0.15	82	MAI	2	TSH	+0.20	TSHTSH	0.3		F6623	reso	22H00117	H	600PP	345291
323			0.19	46	MAI	1	TSH	+0.20	TSHTSH	0.2		F6623	reso	22H00117	H	600PP	345291
324			0.14	94	PID	4	TSH	+0.20	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
325	37	27			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
326			0.23	77	MAI	2	TSH	+0.40	TSHTSH	0.4		F6623	reso	22H00117	H	600PP	345291
327			0.11	71	MAI	1	TSH	+0.40	TSHTSH	0.3		F6623	reso	22H00117	H	600PP	345291
328			0.21	81	PID	4	TSH	+0.40	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
329	39	27	1.44	80	MBM	5	04C	+37.20	TECTEH			L2157	reso	22H00014	H	600UL	340972
330	43	27	2.53	176	DNG	P 1	VM	+9.71	TECTEH			M0945	seco	22H00019	H	600UL	331895
331	65	27	2.23	185	DNG	P 1	05H	+24.62	TECTEH			T7451	seco	22H00018	H	600UL	340972
332	77	27	0.57	86	MBM	5	01H	+20.48	TECTEH			N5432	reso	22H00018	H	600UL	340972
333			0.70	53	MBM	6	01H	+25.76	TECTEH			N5432	reso	22H00018	H	600UL	340972
334	44	28	2.30	182	DNG	P 1	VM	+11.33	TECTEH			M0945	seco	22H00019	H	600UL	331895
335	60	28	4.85	175	DNG	P 1	DH	+11.15	TECTEH			M0945	seco	22H00019	H	600UL	331895
336			8.56	177	DNG	P 1	DH	+12.33	TECTEH			M0945	seco	22H00019	H	600UL	331895
[illegible]			3.86	180	DNG	P 1	DH	+14.62	TECTEH			M0945	seco	22H00019	H	600UL	331895
			3.59	177	DNG	P 1	DH	+16.52	TECTEH			M0945	seco	22H00019	H	600UL	331895
339			3.50	177	DNT	P 1	VM	+1.98	TECTEH			M0945	seco	22H00019	H	600UL	331895
340			3.23	175	DNG	P 1	VM	+15.91	TECTEH			M0945	seco	22H00019	H	600UL	331895
341			3.32	175	DNG	P 1	VM	+18.28	TECTEH			M0945	seco	22H00019	H	600UL	331895
342			10.48	178	DNG	P 1	VM	+18.61	TECTEH			M0945	seco	22H00019	H	600UL	331895

343				3.28	182	DNG	P 1	VM	+20.23	TECTEH			M0945	seco	22H00019	H	600UL	331895

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 8

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
344	104	28	2.65	175	DNT	P 1	09H	-0.24	TECTEH			N5877	seco	22H00028	H	600UL	340972
345			4.52	174	DNT	P 1	09H	+0.53	TECTEH			N5877	seco	22H00028	H	600UL	340972
346			10.43	173	DNG	P 1	09H	+1.49	TECTEH			N5877	seco	22H00028	H	600UL	340972
347	5	29	24.27	180	DNG	P 1	06H	+5.16	06HTEC			C5542	reso	22C00058	C	600CS	341219
348	7	29	6.33	181	DNG	P 1	04C	+18.84	TECTEH			M0945	seco	22H00019	H	600UL	331895
349	9	29	16.00	180	DNG	P 1	VM	+6.18	TECTEH			T7451	seco	22H00018	H	600UL	340972
350					INF		06C	+6.16	TECTEH	HR		N5432	reso	22H00018	H	600UL	340972
351	15	29	1.20	84	MBM	6	02C	+30.90	TECTEH			N5432	reso	22H00018	H	600UL	340972
352	25	29			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
353			0.12	108	MCI	P 1	TSH	+0.17	TSHTSH	0.2		F6623	reso	22H00117	H	600PP	345291
354			0.16	57	MCI	1	TSH	+0.17	TSHTSH	0.3		F6623	reso	22H00117	H	600PP	345291
355			0.11	106	PID	P 1	TSH	+0.17	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
356	37	29			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
357			0.21	138	MAI	1	TSH	+0.35	TSHTSH	0.2		F6623	reso	22H00117	H	600PP	345291
358			0.20	64	MAI	2	TSH	+0.35	TSHTSH	0.3		F6623	reso	22H00117	H	600PP	345291
~~359~~			~~0.17~~	~~97~~	~~MAI~~	~~2~~	~~TSH~~	~~+0.62~~	~~TSHTSH~~	~~0.5~~		~~F6623~~	~~reso~~	~~22H00117~~	~~H~~	~~600PP~~	~~345291~~
360			0.18	110	PID	4	TSH	+0.62	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
			0.20	71	MAI	1	TSH	+0.62	TSHTSH	0.4		F6623	reso	22H00117	H	600PP	345291
	45	29			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
363			0.08	120	PID	4	TSH	+0.19	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
364			0.00	0	SAI	1	TSH	+0.19	TSHTSH	0.0		F6623	reso	22H00117	H	600PP	345291
365			0.09	121	SAI	2	TSH	+0.19	TSHTSH	0.2		F6623	reso	22H00117	H	600PP	345291
366	51	29	3.60	177	DNG	P 1	02H	+24.38	TECTEH			M0945	seco	22H00019	H	600UL	331895
367	91	29	7.82	186	DNT	P 1	09H	+0.29	TECTEH			M9715	seco	22H00029	H	600UL	331895
368			0.43	88	20	P 2	VH	-0.66	TECTEH			M7007	prim	22H00029	H	600UL	331895
369	93	29	7.53	171	DNT	P 1	09H	+0.20	TECTEH			N5877	seco	22H00028	H	600UL	340972
370			5.30	174	DNG	P 1	09H	+1.00	TECTEH			N5877	seco	22H00028	H	600UL	340972
371	22	30			TBP				TECTEH	FAILSLV	ADDTBP	D3858	reso	22H00044	H	600UL	331892
372			0.00	0	MCI	1	TSH	+0.04	TSHTSH	0.0		F3453	reso	22H00119	H	600PP	326414
373			0.21	86	MCI	P 1	TSH	+0.04	TSHTSH	0.5		F3453	reso	22H00119	H	600PP	326414
374			0.15	92	PID	P 1	TSH	+0.04	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
375			0.09	86	MAI	2	TSH	+1.11	TSHTSH	0.2		F3453	reso	22H00119	H	600PP	326414
376			0.00	0	MAI	1	TSH	+1.11	TSHTSH	0.0		F3453	reso	22H00119	H	600PP	326414
377	24	30			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
378			0.00	0	SAI	1	TSH	+0.91	TSHTSH	0.0		M1680	reso	22H00118	H	600PP	345291
379			0.09	110	SAI	2	TSH	+0.91	TSHTSH	0.1		N5432	reso	22H00118	H	600PP	345291
380			0.19	99	SAI	1	TSH	+1.16	TSHTSH	0.2		N5432	reso	22H00118	H	600PP	345291
381			0.20	114	PID	4	TSH	+1.16	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
382			0.17	98	SAI	2	TSH	+1.16	TSHTSH	0.2		N5432	reso	22H00118	H	600PP	345291
383	26	30	2.63	180	DNG	P 1	01H	+29.96	TECTEH			M0945	seco	22H00019	H	600UL	331895
384	28	30			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
385			0.24	107	MCI	P 1	TSH	+0.14	TSHTSH	0.8		N5432	reso	22H00118	H	600PP	345291
[illegible]			0.15	125	MCI	1	TSH	+0.14	TSHTSH	0.5		N5432	reso	22H00118	H	600PP	345291
			0.35	119	PID	P 1	TSH	+0.14	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
388	44	30	2.26	179	DNG	P 1	VM	+11.37	TECTEH			M0945	seco	22H00019	H	600UL	331895
389	46	30			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
390			0.15	111	PID	4	TSH	+0.22	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
391			0.17	25	SAI	1	TSH	+0.22	TSHTSH	0.3		N5432	reso	22H00118	H	600PP	345291

392				0.16	81	SAI	2	TSH	+0.22		TSHTSH	0.2			N5432	reso	22H00118	H	600PP	345291

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 9

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
393	50	30				TBP			TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
394			0.16	111	PID	4	TSH	+0.59	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
395			0.15	115	SAI	2	TSH	+0.59	TSHTSH	0.2		N5432	reso	22H00118	H	600PP	345291
396			0.00	0	SAI	1	TSH	+0.59	TSHTSH	0.0		M1680	reso	22H00118	H	600PP	345291
397			0.00	0	SAI	1	TSH	+0.87	TSHTSH	0.0		M1680	reso	22H00118	H	600PP	345291
398			0.14	113	SAI	2	TSH	+0.87	TSHTSH	0.2		N5432	reso	22H00118	H	600PP	345291
399	52	30	0.71	84	MBM	5	07C	+9.38	TECTEH			F6623	reso	22H00019	H	600UL	331895
400			0.46	87	INR	5	04C	+7.89	TECTEH			F6623	reso	22H00019	H	600UL	331895
401			0.66	73	MBM	5	02C	+18.78	TECTEH			F6623	reso	22H00019	H	600UL	331895
402	56	30	2.00	177	DNG	P 1	TSH	+16.03	TECTEH			M0945	seco	22H00019	H	600UL	331895
403	58	30	1.97	46	MBM	6	07H	+27.74	TECTEH			N5432	reso	22H00018	H	600UL	340972
404			2.06	185	DNG	P 1	VM	+18.16	TECTEH			T7451	seco	22H00018	H	600UL	340972
405	60	30	3.82	179	DNG	P 1	02H	+35.46	TECTEH			M0945	seco	22H00019	H	600UL	331895
406			4.20	183	DNG	P 1	VM	+19.41	TECTEH			F6623	reso	22H00019	H	600UL	331895
407	62	30	0.69	80	MBM	6	TSH	+33.79	TECTEH			N5432	reso	22H00018	H	600UL	340972
408	64	30	2.18	182	DNG	P 1	VM	+21.60	TECTEH			M0945	seco	22H00019	H	600UL	331895
409	68	30	2.47	182	DNG	P 1	VM	+24.01	TECTEH			M0945	seco	22H00019	H	600UL	331895
	84	30	2.32	180	DNG	P 1	01C	+7.37	TECTEH			M0945	seco	22H00019	H	600UL	331895
	86	30	6.38	181	DNG	P 1	VM	+2.36	TECTEH			N5432	reso	22H00018	H	600UL	340972
412	92	30	4.04	180	DNT	P 1	09H	+0.27	TECTEH			M9715	seco	22H00029	H	600UL	331895
413	94	30	12.82	172	DNT	P 1	09H	+0.29	TECTEH			N5877	seco	22H00028	H	600UL	340972
414	100	30	1.22	82	MBM	6	04H	+36.73	TECTEH			N5432	reso	22H00029	H	600UL	331895
415			0.81	80	MBM	5	TSC	+12.99	TECTEH			N5432	reso	22H00029	H	600UL	331895
416	102	30	0.79	79	MBM	5	06H	+5.08	TECTEH			N5432	reso	22H00028	H	600UL	340972
417	104	30	0.29	100	WAR	2	02C	+0.89	02C02C			F6623	reso	22C00087	C	600PP	345298
418			0.49	53	21	P 2	02C	+0.99	TECTEH			A9608	reso	22H00029	H	600UL	331895
419			0.70	74	MBM	5	02C	+34.20	TECTEH			N5432	reso	22H00029	H	600UL	331895
420	1	31	0.14	71	INR	9	TSH	+0.20	TSHTSH			F3453	reso	22H00119	H	600PP	326414
421	5	31	21.90	182	DNG	P 1	06C	+4.61	06HTEC			M2655	seco	22C00058	C	600CS	341219
422	13	31	2.42	182	DNG	P 1	TSH	+2.68	TECTEH			T7451	seco	22H00018	H	600UL	340972
423			2.40	84	MBM	6	05C	+4.60	TECTEH			N5432	reso	22H00018	H	600UL	340972
424	45	31			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
425			0.24	119	SCI	P 1	TSH	+0.12	TSHTSH	0.3		F3453	reso	22H00119	H	600PP	326414
426			0.26	84	SCI	1	TSH	+0.12	TSHTSH	0.3		F3453	reso	22H00119	H	600PP	326414
427			0.32	120	PID	P 1	TSH	+0.12	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
428	47	31			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
429			0.00	0	SAI	1	TSH	+0.26	TSHTSH	0.0		M1680	reso	22H00118	H	600PP	345291
430			0.11	79	SAI	2	TSH	+0.26	TSHTSH	0.2		N5432	reso	22H00118	H	600PP	345291
431			0.11	65	PID	4	TSH	+0.26	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
432	57	31	0.58	70	MBM	5	04C	+14.65	TECTEH			F6623	reso	22H00019	H	600UL	331895
433	59	31	3.20	183	DNG	P 1	06H	+20.70	TECTEH			T7451	seco	22H00018	H	600UL	340972
434					INF		DH	+9.72	TECTEH	HR		N5432	reso	22H00018	H	600UL	340972
					INF		DH	+10.27	TECTEH	HR		N5432	reso	22H00018	H	600UL	340972
			17.96	181	DNG	P 1	DH	+11.75	TECTEH			T7451	seco	22H00018	H	600UL	340972
437			18.88	182	DNG	P 1	DH	+12.50	TECTEH			T7451	seco	22H00018	H	600UL	340972
438			2.11	185	DNT	P 1	VM	+1.58	TECTEH			T7451	seco	22H00018	H	600UL	340972
439			2.98	178	DNG	P 1	VM	+15.35	TECTEH			T7451	seco	22H00018	H	600UL	340972
440			2.74	179	DNG	P 1	VM	+15.63	TECTEH			T7451	seco	22H00018	H	600UL	340972

441				3.26	182	DNG	P 1	VM	+18.44	TECTEH			T7451	seco	22H00018	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 10

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
442			3.28	182	DNG	P 1	VM	+18.79	TECTEH			T7451	seco	22H00018	H	600UL	340972
443			9.36	183	DNG	P 1	06C	+15.53	TECTEH			T7451	seco	22H00018	H	600UL	340972
444			8.97	181	DNG	P 1	06C	+17.16	TECTEH			T7451	seco	22H00018	H	600UL	340972
445	63	31			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
446			0.12	93	SAI	2	TSH	+0.24	TSHTSH	0.2		N5432	reso	22H00118	H	600PP	345291
447			0.11	95	PID	4	TSH	+0.24	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
448			0.00	0	SAI	1	TSH	+0.24	TSHTSH	0.0		M1680	reso	22H00118	H	600PP	345291
449	69	31	9.19	178	DNG	P 1	03C	+9.97	TECTEH			M0945	seco	22H00019	H	600UL	331895
450	83	31	2.15	74	MBM	6	01H	+18.82	TECTEH			N5432	reso	22H00018	H	600UL	340972
451			0.78	68	MBM	6	03H	+16.85	TECTEH			N5432	reso	22H00018	H	600UL	340972
452	93	31	5.18	176	DNT	P 1	09H	+0.34	TECTEH			N5877	seco	22H00028	H	600UL	340972
453	95	31	0.42	52	MBM	5	05H	+2.59	TECTEH			N5432	reso	22H00029	H	600UL	331895
454			2.71	179	DNT	P 1	09H	+0.31	TECTEH			M9715	seco	22H00029	H	600UL	331895
455	97	31	4.95	172	DNT	P 1	09H	+0.45	TECTEH			N5877	seco	22H00028	H	600UL	340972
456	99	31	5.22	183	DNG	P 1	DH	+6.55	TECTEH			M9715	seco	22H00029	H	600UL	331895
457	6	32			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
458			0.35	39	PID	2	06H	+13.63	05H06C			F7467	seco	22H00231	H	5602C	340987
			0.26	52	SAI	2	06H	+13.63	05H06C	0.5		M7006	reso	22H00215	H	5602C	340987
			1.02	108	SAI	1	06H	+13.63	05H06C	0.6		M7006	reso	22H00215	H	5602C	340987
461	12	32	10.44	180	DNG	P 1	06H	+8.08	TECTEH			M0945	seco	22H00019	H	600UL	331895
462	22	32			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
463			0.09	121	SAI	2	TSH	+0.99	TSHTSH	0.2		F3453	reso	22H00119	H	600PP	326414
464			0.11	105	PID	4	TSH	+0.99	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
465			0.00	0	SAI	1	TSH	+0.99	TSHTSH	0.0		F3453	reso	22H00119	H	600PP	326414
466	26	32	2.11	177	DNG	P 1	01H	+1.57	TECTEH			F6623	reso	22H00019	H	600UL	331895
467	30	32	1.36	99	MBM	6	01C	+13.20	TECTEH			F6623	reso	22H00019	H	600UL	331895
468	32	32	4.75	188	DNT	P 1	VM	+0.88	TECTEH			T7451	seco	22H00018	H	600UL	340972
469	36	32	2.71	183	DNT	P 1	VM	+0.92	TECTEH			T7451	seco	22H00018	H	600UL	340972
470	40	32			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
471			0.14	85	SAI	2	TSH	+0.59	TSHTSH	0.2		N5432	reso	22H00118	H	600PP	345291
472			0.00	0	SAI	1	TSH	+0.59	TSHTSH	0.0		M1680	reso	22H00118	H	600PP	345291
473			0.07	96	PID	4	TSH	+0.59	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
474			0.08	110	SAI	2	TSH	+0.73	TSHTSH	0.1		N5432	reso	22H00118	H	600PP	345291
475			0.00	0	SAI	1	TSH	+0.73	TSHTSH	0.0		M1680	reso	22H00118	H	600PP	345291
476			6.89	183	DNG	P 1	05H	+37.18	TECTEH			T7451	seco	22H00018	H	600UL	340972
477	50	32	2.27	184	DNG	P 1	03H	+11.31	TECTEH			T7451	seco	22H00018	H	600UL	340972
478	52	32			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
479			0.12	57	SAI	1	TSH	+3.31	TSHTSH	0.3		N5432	reso	22H00118	H	600PP	345291
480			0.19	116	PID	4	TSH	+3.31	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
481			0.18	93	SAI	2	TSH	+3.31	TSHTSH	0.2		N5432	reso	22H00118	H	600PP	345291
482			0.54	68	MBM	5	03H	+15.64	TECTEH			F6623	reso	22H00019	H	600UL	331895
483			0.73	74	MBM	5	02C	+14.25	TECTEH			F6623	reso	22H00019	H	600UL	331895
			1.28	91	MBM	5	01C	+34.04	TECTEH			F6623	reso	22H00019	H	600UL	331895
			0.87	100	MBM	5	TSC	+26.20	TECTEH			F6623	reso	22H00019	H	600UL	331895
486	60	32	4.02	180	DNT	P 1	07H	+0.18	TECTEH			M0945	seco	22H00019	H	600UL	331895
487			2.16	181	DNG	P 1	VM	+19.56	TECTEH			M0945	seco	22H00019	H	600UL	331895
488			3.69	181	DNG	P 1	06C	+23.75	TECTEH			M0945	seco	22H00019	H	600UL	331895
489	80	32	0.55	90	MBM	5	02C	+33.16	TECTEH			F6623	reso	22H00019	H	600UL	331895

490	86	32	0.41	73	MBM	5	06H	+8.40	TECTEH				N5432	reso	22H00018	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 11

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
491	92	32	0.29	102	12	P 2	VH	+0.27	TECTEH			W2096	prim	22H00028	H	600UL	340972
492	96	32	3.12	179	DNT	P 1	09H	+0.38	TECTEH			N5877	seco	22H00028	H	600UL	340972
493	98	32	6.93	181	DNT	P 1	09H	+0.38	TECTEH			M9715	seco	22H00029	H	600UL	331895
494	108	32	2.68	177	DNG	P 1	VC	+3.60	TECTEH			N5877	seco	22H00028	H	600UL	340972
495			2.58	173	DNT	P 1	09C	-0.72	TECTEH			N5877	seco	22H00028	H	600UL	340972
496			5.40	176	DNG	P 1	08C	+14.62	TECTEH			N5877	seco	22H00028	H	600UL	340972
497	1	33	1.20	78	MBM	5	TSH	+34.01	06HTEH			A9608	reso	22H00082	H	600UL	340912
498	5	33	22.43	182	DNG	P 1	06H	+5.24	06HTEC			M2655	seco	22C00058	C	600CS	341219
499			18.81	0	INR	P 1	06H	+7.55	06HTEC			C5542	reso	22C00058	C	600CS	341219
500	13	33	3.34	176	DNG	P 1	01C	+15.67	TECTEH			A6997	seco	22H00022	H	600UL	340972
501	33	33	3.43	183	DNT	P 1	VM	-0.67	TECTEH			A6997	seco	22H00022	H	600UL	340972
502	39	33	12.92	179	DNG	P 1	TSH	+3.25	TECTEH			A6997	seco	22H00022	H	600UL	340972
503			0.65	77	MBM	5	02C	+18.28	TECTEH			N5432	reso	22H00022	H	600UL	340972
504	47	33			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
505			0.32	108	SCI	P 1	TSH	+0.13	TSHTSH	0.3		N5432	reso	22H00118	H	600PP	345291
~~506~~			~~0.34~~	~~107~~	~~PID~~	~~P 1~~	~~TSH~~	~~+0.13~~	~~TSHTSH~~	~~080~~		~~F6623~~	~~reso~~	~~22H00155~~	~~H~~	~~600PP~~	~~345291~~
507			0.36	63	SCI	1	TSH	+0.13	TSHTSH	0.3		N5432	reso	22H00118	H	600PP	345291
			0.18	92	SVI	2	TSH	+0.32	TSHTSH	0.2		N5432	reso	22H00118	H	600PP	345291
			0.23	37	SVI	1	TSH	+0.32	TSHTSH	0.2		N5432	reso	22H00118	H	600PP	345291
510			4.54	179	DNT	P 1	07C	+0.98	TECTEH			A6997	seco	22H00022	H	600UL	340972
511	69	33			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
512			0.00	0	SCI	1	TSH	+0.09	TSHTSH	0.0		M1680	reso	22H00118	H	600PP	345291
513			0.17	116	SCI	P 1	TSH	+0.09	TSHTSH	0.2		N5432	reso	22H00118	H	600PP	345291
514			0.20	120	PID	P 1	TSH	+0.09	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
515	73	33	0.41	92	MBM	5	02C	+7.29	TECTEH			N5432	reso	22H00022	H	600UL	340972
516	97	33	2.87	82	MBM	6	04H	+6.13	TECTEH			M7006	reso	22H00033	H	600UL	331895
517	99	33	3.82	182	DNT	P 1	09H	+0.40	TECTEH			A9574	seco	22H00032	H	600UL	340972
518	101	33	2.89	179	DNT	P 1	09H	+0.38	TECTEH			N5877	seco	22H00033	H	600UL	331895
519			0.30	50	15	P 2	VH	+1.04	TECTEH			G2927	prim	22H00033	H	600UL	331895
520	103	33	0.85	88	MBM	6	03H	+28.83	TECTEH			M7006	reso	22H00032	H	600UL	340972
521			6.97	176	DNT	P 1	09H	+0.40	TECTEH			A9574	seco	22H00032	H	600UL	340972
522	105	33	2.70	177	DNT	P 1	09H	+0.40	TECTEH			N5877	seco	22H00033	H	600UL	331895
523	18	34			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
524			0.00	0	SAI	1	TSH	+0.79	TSHTSH	0.0		M1680	reso	22H00118	H	600PP	345291
525			0.14	130	PID	4	TSH	+0.79	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
526			0.10	122	SAI	2	TSH	+0.79	TSHTSH	0.4		N5432	reso	22H00118	H	600PP	345291
527	26	34	3.33	183	DNG	P 1	04H	+25.39	TECTEH			A6997	seco	22H00022	H	600UL	340972
528	30	34	2.66	178	DNG	P 1	05H	+29.78	TECTEH			A6997	seco	22H00022	H	600UL	340972
529	38	34	2.68	185	DNT	P 1	06H	-0.98	TEHTEC			D8661	reso	22C00060	H	600CS	341219
530			2.72	183	DNT	P 1	06H	-0.98	07CTEH			D8661	reso	22H00079	H	600UL	340943
531			2.62	182	DNT	P 1	06H	-0.98	DC TEH			T7451	seco	22H00023	H	600UL	331895
532					OBS		DC	-6.41	DC TEH			N5432	reso	22H00023	H	600UL	331895
[illegible]					OBS		07C	-4.16	07CTEH			I3805	seco	22H00079	H	600UL	340943
			15.83	179	DNT	P 1	07C	-0.55	TEHTEC			D8661	reso	22C00060	H	600CS	341219
535			14.47	177	DNT	P 1	07C	-0.55	07CTEH			I3805	seco	22H00079	H	600UL	340943
536			22.00	179	DNG	P 1	06C	+8.84	TEHTEC			M1637	seco	22C00060	H	600CS	341219
537	40	34	5.12	183	DNG	P 1	07H	+2.32	TECTEH			A6997	seco	22H00022	H	600UL	340972
538			4.02	182	DNG	P 1	VM	+9.74	TECTEH			A6997	seco	22H00022	H	600UL	340972

539	44	34	0.83	96	INR	6	05H	+33.28	TECTEH				S4373	reso	22H00022	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 12

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
540			2.59	179	DNG	P 1	VM	+11.66	TECTEH			A6997	seco	22H00022	H	600UL	340972
541	52	34			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
542			0.16	104	MAI	2	TSH	+0.18	TSHTSH	0.3		F3453	reso	22H00119	H	600PP	326414
543			0.15	86	PID	4	TSH	+0.18	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
544			0.20	35	MAI	1	TSH	+0.18	TSHTSH	0.3		F3453	reso	22H00119	H	600PP	326414
545			0.61	66	MBM	5	03H	+27.00	TECTEH			N5432	reso	22H00023	H	600UL	331895
546			0.62	79	MBM	5	04H	+7.15	TECTEH			N5432	reso	22H00023	H	600UL	331895
547			0.59	84	MBM	5	03C	+30.79	TECTEH			N5432	reso	22H00023	H	600UL	331895
548			1.14	69	MBM	5	02C	+31.58	TECTEH			N5432	reso	22H00023	H	600UL	331895
549	54	34			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
550			0.09	80	SAI	2	TSH	+0.25	TSHTSH	0.2		N5432	reso	22H00118	H	600PP	345291
551			0.00	0	SAI	1	TSH	+0.25	TSHTSH	0.0		M1680	reso	22H00118	H	600PP	345291
552			0.09	87	PID	4	TSH	+0.25	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
553			2.28	184	DNG	P 1	04C	+24.33	TECTEH			A6997	seco	22H00022	H	600UL	340972
554	56	34	2.37	181	DNG	P 1	VM	+17.73	TECTEH			T7451	seco	22H00023	H	600UL	331895
555	59	34	2.09	182	DNG	P 1	VM	+19.99	TECTEH			A6997	seco	22H00022	H	600UL	340972
556	60	34	3.21	182	DNG	P 1	VM	+20.20	TECTEH			T7451	seco	22H00023	H	600UL	331895
	70	34			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
			0.09	75	SAI	2	TSH	+1.47	TSHTSH	0.4		N5432	reso	22H00118	H	600PP	345291
559			0.00	0	SAI	1	TSH	+1.47	TSHTSH	0.0		M1680	reso	22H00118	H	600PP	345291
560			0.09	116	PID	4	TSH	+1.47	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
561	72	34			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
562			0.10	133	PID	4	TSH	+1.78	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
563			0.11	105	SAI	2	TSH	+1.78	TSHTSH	0.5		F3453	reso	22H00119	H	600PP	326414
564			0.00	0	SAI	1	TSH	+1.78	TSHTSH	0.0		F3453	reso	22H00119	H	600PP	326414
565			2.66	183	DNG	P 1	04C	+18.26	TECTEH			T7451	seco	22H00023	H	600UL	331895
566			2.31	177	DNT	P 1	01C	+0.68	TECTEH			T7451	seco	22H00023	H	600UL	331895
567	82	34	0.78	73	MBM	5	02C	+3.05	TECTEH			N5432	reso	22H00022	H	600UL	340972
568	90	34	0.59	87	MBM	5	04H	+17.72	TECTEH			N5432	reso	22H00022	H	600UL	340972
569			1.32	84	MBM	5	05H	+34.95	TECTEH			N5432	reso	22H00022	H	600UL	340972
570	92	34	0.33	53	17	P 2	VC	-0.84	TECTEH			A9574	seco	22H00032	H	600UL	340972
571	100	34	0.24	78	12	P 2	VH	-0.11	TECTEH			A9574	seco	22H00032	H	600UL	340972
572			2.95	179	DNG	P 1	09C	+7.29	TECTEH			A9574	seco	22H00032	H	600UL	340972
573	104	34	5.18	173	DNT	P 1	09H	+0.40	TECTEH			A9574	seco	22H00032	H	600UL	340972
574	106	34	3.32	184	DNT	P 1	09H	+0.42	TECTEH			N5877	seco	22H00033	H	600UL	331895
575	112	34	0.76	65	MBM	5	03H	+27.99	TECTEH			M7006	reso	22H00032	H	600UL	340972
576	1	35	3.41	177	DNG	P 1	03C	+25.26	06CTEC			I3805	seco	22C00059	C	600CS	341611
577	7	35	4.07	178	DNT	P 1	01H	+0.86	TECTEH			A6997	seco	22H00022	H	600UL	340972
578			2.86	187	DNG	P 1	01H	+1.43	TECTEH			A6997	seco	22H00022	H	600UL	340972
579	39	35	0.40	87	MBM	5	02H	+5.31	TECTEH			N5432	reso	22H00022	H	600UL	340972
580	43	35			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
581			0.34	61	MAI	1	TSH	+0.58	TSHTSH	0.4		F3453	reso	22H00119	H	600PP	326414
582			0.22	100	MAI	2	TSH	+0.58	TSHTSH	0.5		F3453	reso	22H00119	H	600PP	326414
			0.25	92	PID	4	TSH	+0.58	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
584	55	35			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
585			0.19	111	MAI	2	TSH	+0.21	TSHTSH	0.3		F3453	reso	22H00119	H	600PP	326414
586			0.19	88	PID	4	TSH	+0.21	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
587			0.18	79	MAI	1	TSH	+0.21	TSHTSH	0.4		F3453	reso	22H00119	H	600PP	326414

588	69	35	0.99	86	MBM	6	01C	+17.60	TECTEH				N5432	reso	22H00023	H	600UL	331895

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 13

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
589	71	35	0.51	91	MBM	5	03H	+6.06	TECTEH			N5432	reso	22H00022	H	600UL	340972
590			0.52	96	MBM	5	06H	+12.80	TECTEH			N5432	reso	22H00022	H	600UL	340972
591			0.76	87	MBM	5	07C	+16.62	TECTEH			N5432	reso	22H00022	H	600UL	340972
592	81	35	1.87	176	INR	P 1	03H	+8.91	TECTEH			T7451	seco	22H00023	H	600UL	331895
593	87	35	1.57	80	MBM	5	07H	+6.64	TECTEH			N5432	reso	22H00022	H	600UL	340972
594	93	35	2.87	181	DNT	P 1	09H	+0.78	TECTEH			A9574	seco	22H00032	H	600UL	340972
595			4.44	179	DNT	P 1	09C	+0.18	TECTEH			A9574	seco	22H00032	H	600UL	340972
596	105	35	4.46	183	DNT	P 1	09H	+0.42	TECTEH			A9574	seco	22H00032	H	600UL	340972
597	107	35	1.11	59	MBM	6	08H	+16.85	TECTEH			M7006	reso	22H00033	H	600UL	331895
598	113	35	9.92	174	DNG	P 1	09H	+20.54	TECTEH			A9574	seco	22H00032	H	600UL	340972
599					INF		09H	+22.19	TECTEH	HR		M7006	reso	22H00032	H	600UL	340972
600	6	36	2.05	173	DNG	P 1	TSH	+28.58	TECTEH			A6997	seco	22H00022	H	600UL	340972
601			6.68	173	DNG	P 1	TSH	+29.04	TECTEH			A6997	seco	22H00022	H	600UL	340972
602			3.86	179	DNT	P 1	01H	+0.74	TECTEH			A6997	seco	22H00022	H	600UL	340972
603	12	36	9.77	179	DNG	P 1	06H	+7.62	TECTEH			T7451	seco	22H00023	H	600UL	331895
604	14	36	2.29	173	DNG	P 1	01C	+14.14	TECTEH			A6997	seco	22H00022	H	600UL	340972
605			3.33	174	DNG	P 1	01C	+28.38	TECTEH			A6997	seco	22H00022	H	600UL	340972
	18	36	4.81	189	DNG	P 1	04H	+16.00	TECTEH			T7451	seco	22H00023	H	600UL	331895
	24	36			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
608			0.14	111	PID	4	TSH	+1.17	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
609			0.15	106	SAI	2	TSH	+1.17	TSHTSH	0.4		N5432	reso	22H00118	H	600PP	345291
610			0.00	0	SAI	1	TSH	+1.17	TSHTSH	0.0		M1680	reso	22H00118	H	600PP	345291
611			0.28	130	12	P 2	DH	+1.27	TECTEH	LOCOK		S4373	reso	22H00022	H	600UL	340972
612	30	36	0.67	57	MBM	6	05C	+5.26	TECTEH			N5432	reso	22H00023	H	600UL	331895
613			0.74	61	MBM	5	04C	+27.61	TECTEH			N5432	reso	22H00023	H	600UL	331895
614			1.83	79	MBM	6	04C	+34.93	TECTEH			N5432	reso	22H00023	H	600UL	331895
615	32	36	4.56	182	DNT	P 1	VM	+1.75	TECTEH			A6997	seco	22H00022	H	600UL	340972
616	38	36	7.22	179	DNT	P 1	VM	+1.89	TECTEH			T7451	seco	22H00023	H	600UL	331895
617			3.95	183	DNG	P 1	VM	+2.44	TECTEH			T7451	seco	22H00023	H	600UL	331895
618			5.49	181	DNG	P 1	VM	+8.58	TECTEH			T7451	seco	22H00023	H	600UL	331895
619			10.67	181	DNG	P 1	VM	+9.52	TECTEH			T7451	seco	22H00023	H	600UL	331895
620			3.58	184	DNG	P 1	VM	+10.94	TECTEH			T7451	seco	22H00023	H	600UL	331895
621	40	36	3.67	179	DNG	P 1	VM	+9.69	TECTEH			A6997	seco	22H00022	H	600UL	340972
622	44	36	2.18	178	DNG	P 1	VM	+11.69	TECTEH			A6997	seco	22H00022	H	600UL	340972
623	46	36			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
624			0.25	124	PID	4	TSH	+0.51	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
625			0.60	15	MAI	1	TSH	+0.51	TSHTSH	0.4		F3453	reso	22H00119	H	600PP	326414
626			0.26	118	MAI	2	TSH	+0.51	TSHTSH	0.5		F3453	reso	22H00119	H	600PP	326414
627	56	36			TBP				TECTEH	FAILSLV	ADDTBP	D3858	reso	22H00044	H	600UL	331892
628			0.11	96	PID	4	TSH	+0.17	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
629			0.13	118	SAI	2	TSH	+0.17	TSHTSH	0.2		F3453	reso	22H00119	H	600PP	326414
630			0.12	65	SAI	1	TSH	+0.17	TSHTSH	0.1		F3453	reso	22H00119	H	600PP	326414
[illegible]	60	36	3.02	181	DNG	P 1	DH	+8.15	TECTEH			T7451	seco	22H00023	H	600UL	331895
	64	36			OBS		DC	-4.05	DC TEH			T5565	prim	22H00023	H	600UL	331895
633					OBS		DC	+10.76	DC TEH			I3805	seco	22H00079	H	600UL	340943
634					OBS		07C	+14.37	07CTEC			T6956	prim	22C00060	H	600CS	341219
635			74.91	177	DNG	P 1	07C	+21.99	TEHTEC			S8982	seco	22C00062	H	560SF	270908
636					OBS		07C	+22.58	07CTEC			B4052	prim	22C00061	H	580UL	287821

637	72	36	0.48	80	MBM	5	01H	+35.13	TECTEH			N5432	reso	22H00023	H	600UL	331895

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 14

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
638			0.41	66	MBM	5	01H	+36.29	TECTEH			N5432	reso	22H00023	H	600UL	331895
639	84	36	1.93	180	INR	P 1	03H	+12.53	TECTEH			T7451	seco	22H00023	H	600UL	331895
640	92	36	6.84	181	DNG	P 1	08H	+8.45	TECTEH			N5877	seco	22H00033	H	600UL	331895
641			3.38	181	DNG	P 1	08H	+8.96	TECTEH			N5877	seco	22H00033	H	600UL	331895
642			3.81	182	DNG	P 1	08H	+9.96	TECTEH			N5877	seco	22H00033	H	600UL	331895
643			2.52	180	DNG	P 1	08H	+10.96	TECTEH			N5877	seco	22H00033	H	600UL	331895
644			1.94	177	INR	P 1	08H	+12.42	TECTEH			N5877	seco	22H00033	H	600UL	331895
645			4.68	178	DNG	P 1	08H	+13.50	TECTEH			N5877	seco	22H00033	H	600UL	331895
646			3.84	190	DNT	P 1	09H	+0.31	TECTEH			M7006	reso	22H00033	H	600UL	331895
647			15.70	181	DNG	P 1	09H	+1.29	TECTEH			N5877	seco	22H00033	H	600UL	331895
648			4.17	178	DNG	P 1	09C	-1.24	TECTEH			N5877	seco	22H00033	H	600UL	331895
649			14.73	179	DNT	P 1	09C	+0.62	TECTEH			N5877	seco	22H00033	H	600UL	331895
650			2.78	179	DNG	P 1	08C	+21.00	TECTEH			N5877	seco	22H00033	H	600UL	331895
651			2.85	179	DNG	P 1	07C	+22.66	TECTEH			N5877	seco	22H00033	H	600UL	331895
652	94	36	2.57	176	DNT	P 1	09C	+0.37	TECTEH			A9574	seco	22H00032	H	600UL	340972
653	99	36	0.22	93	16	P 2	VC	+0.09	TECTEH			A9574	seco	22H00032	H	600UL	340972
654	108	36	0.41	72	MBM	5	TSH	+18.02	TECTEH			M7006	reso	22H00033	H	600UL	331895
	110	36	15.42	176	DNT	P 1	VH	+1.68	TECTEH			A9574	seco	22H00032	H	600UL	340972
			0.60	92	MBM	5	03C	+24.43	TECTEH			M7006	reso	22H00032	H	600UL	340972
657	112	36	0.36	71	MBM	5	02H	+2.81	TECTEH			M7006	reso	22H00033	H	600UL	331895
658	5	37	2.59	181	DNG	P 1	05H	+2.81	06HTEH			T7451	seco	22H00082	H	600UL	340912
659			23.46	182	DNG	P 1	06C	+4.26	06HTEC			M2655	seco	22C00058	C	600CS	341219
660	15	37	0.87	76	MBM	5	01C	+0.66	TECTEH			N5432	reso	22H00023	H	600UL	331895
661	27	37	2.31	180	DNG	P 1	VM	+2.60	TECTEH			A6997	seco	22H00022	H	600UL	340972
662	45	37	4.67	176	DNG	P 1	TSC	+32.63	TECTEH			T7451	seco	22H00023	H	600UL	331895
663	47	37			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
664			0.10	113	SAI	2	TSH	+0.90	TSHTSH	0.2		N5432	reso	22H00118	H	600PP	345291
665			0.09	76	PID	4	TSH	+0.90	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
666			0.00	0	SAI	1	TSH	+0.90	TSHTSH	0.0		M1680	reso	22H00118	H	600PP	345291
667			0.43	78	MBM	5	VM	+5.95	TECTEH			N5432	reso	22H00022	H	600UL	340972
668			0.59	72	MBM	5	VM	+8.19	TECTEH			N5432	reso	22H00022	H	600UL	340972
669	53	37			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
670			0.12	89	SAI	2	TSH	+0.46	TSHTSH	0.4		F3453	reso	22H00119	H	600PP	326414
671			0.20	50	SAI	1	TSH	+0.46	TSHTSH	0.3		F3453	reso	22H00119	H	600PP	326414
672			0.13	100	PID	4	TSH	+0.46	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
673	55	37			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
674			0.15	115	PID	4	TSH	+0.29	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
675			0.16	99	SAI	2	TSH	+0.29	TSHTSH	0.4		N5432	reso	22H00118	H	600PP	345291
676			0.24	93	SAI	1	TSH	+0.29	TSHTSH	0.3		N5432	reso	22H00118	H	600PP	345291
677			8.30	13	PVN	P 1	02H	+34.18	TECTEH			A6997	seco	22H00022	H	600UL	340972
678			2.05	177	DNG	P 1	03H	+13.07	TECTEH			A6997	seco	22H00022	H	600UL	340972
679	63	37			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
			0.16	67	SAI	2	TSH	+0.23	TSHTSH	0.2		N5432	reso	22H00118	H	600PP	345291
			0.15	66	PID	4	TSH	+0.23	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
682			0.00	0	SAI	1	TSH	+0.23	TSHTSH	0.0		M1680	reso	22H00118	H	600PP	345291
683	65	37			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
684			0.12	34	SAI	3	TSH	+0.24	TSHTSH	0.3		F6623	reso	22H00155	H	600PP	345291
685			0.18	100	SAI	4	TSH	+0.24	TSHTSH	0.3		F6623	reso	22H00155	H	600PP	345291

686				0.18	91	PID	4	TSH	+0.24	TSHTSH	080			L2157	reso	22H00167	H	600PP	345290

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 15

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
687	67	37			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
688			0.18	81	SCI	P 1	TSH	+0.07	TSHTSH	0.4		F6623	reso	22H00155	H	600PP	345291
689			0.12	129	SCI	3	TSH	+0.07	TSHTSH	0.5		F6623	reso	22H00155	H	600PP	345291
690			0.83	94	PID	P 1	TSH	+0.07	TSHTSH	080		L2157	reso	22H00167	H	600PP	345290
691	69	37	3.91	181	DNG	P 1	07H	+14.77	TECTEH			N5432	reso	22H00023	H	600UL	331895
692			5.99	181	DNT	P 1	08C	-0.41	TECTEH			T7451	seco	22H00023	H	600UL	331895
693			2.40	181	DNG	P 1	07C	+20.88	TECTEH			T7451	seco	22H00023	H	600UL	331895
694			0.72	79	MBM	5	02C	+23.06	TECTEH			N5432	reso	22H00023	H	600UL	331895
695	71	37	3.01	182	DNG	P 1	07H	+5.87	TECTEH			A6997	seco	22H00022	H	600UL	340972
696			3.90	180	DNG	P 1	07C	+23.14	TECTEH			A6997	seco	22H00022	H	600UL	340972
697	89	37	0.76	69	MBM	6	04H	+23.34	TECTEH			N5432	reso	22H00022	H	600UL	340972
698			0.44	80	MBM	5	06H	+6.71	TECTEH			N5432	reso	22H00022	H	600UL	340972
699	91	37	6.82	180	DNT	P 1	08H	+1.01	TECTEH			N5877	seco	22H00033	H	600UL	331895
700			5.18	178	DNG	P 1	08H	+17.37	TECTEH			N5877	seco	22H00033	H	600UL	331895
701			5.92	179	DNG	P 1	08C	+3.15	TECTEH			N5877	seco	22H00033	H	600UL	331895
702			6.50	179	DNG	P 1	08C	+1.49	TECTEH			N5877	seco	22H00033	H	600UL	331895
703			11.26	179	DNG	P 1	08C	+12.58	TECTEH			N5877	seco	22H00033	H	600UL	331895
			11.25	181	DNG	P 1	08C	+13.48	TECTEH			N5877	seco	22H00033	H	600UL	331895
			0.62	1	INR	P 1	08C	+15.17	TECTEH			N5877	seco	22H00033	H	600UL	331895
706	95	37	2.16	75	MBM	6	VH	+20.20	TECTEH			M7006	reso	22H00033	H	600UL	331895
707			3.32	179	DNT	P 1	09C	+0.07	TECTEH			N5877	seco	22H00033	H	600UL	331895
708	97	37	0.18	75	9	P 2	VH	-1.21	TECTEH			A9574	seco	22H00032	H	600UL	340972
709	101	37	0.18	23	10	P 2	VH	+0.07	TECTEH			A9574	seco	22H00032	H	600UL	340972
710	103	37	1.39	91	MBM	6	07H	+14.42	TECTEH			M7006	reso	22H00033	H	600UL	331895
711					NDF		09H	-0.18	09H09H			K5380	prim	22H00184	H	600PP	345332
712			0.46	62	DSI	P 1	09H	-0.18	TECTEH			G2927	prim	22H00033	H	600UL	331895
713					NDF		09C	+0.00	09C09C			F6623	reso	22C00087	C	600PP	345298
714			1.06	116	DSI	P 1	09C	+0.00	TECTEH			G2927	prim	22H00033	H	600UL	331895
715			1.10	82	MBM	5	08C	+11.07	TECTEH			M7006	reso	22H00033	H	600UL	331895
716	109	37	1.22	65	MBM	6	TSH	+32.59	TECTEH			M7006	reso	22H00032	H	600UL	340972
717	12	38			INF		06C	+6.15	TECTEH	HR		N5432	reso	22H00023	H	600UL	331895
718	14	38	4.58	185	DNG	P 1	06H	+9.47	TECTEH			A6997	seco	22H00022	H	600UL	340972
719	22	38			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
720			0.00	0	MAI	1	TSH	+0.55	TSHTSH	0.0		F3453	reso	22H00122	H	600PP	345291
721			0.10	101	PID	4	TSH	+0.55	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
722			0.17	113	MAI	2	TSH	+0.55	TSHTSH	0.3		F3453	reso	22H00122	H	600PP	345291
723			0.00	0	SAI	1	TSH	+0.83	TSHTSH	0.0		F3453	reso	22H00122	H	600PP	345291
724			0.10	115	SAI	2	TSH	+0.83	TSHTSH	0.2		F3453	reso	22H00122	H	600PP	345291
725	32	38	4.94	181	DNT	P 1	VM	+1.46	TECTEH			A6997	seco	22H00022	H	600UL	340972
726	38	38	2.97	184	DNG	P 1	05H	+36.29	TECTEH			A6997	seco	22H00022	H	600UL	340972
727			3.00	189	DNG	P 1	06H	+7.09	TECTEH			A6997	seco	22H00022	H	600UL	340972
728			5.21	177	DNG	P 1	06C	+13.29	TECTEH			A6997	seco	22H00022	H	600UL	340972
-			10.90	179	DNG	P 1	06C	+14.13	TECTEH			A6997	seco	22H00022	H	600UL	340972
			3.70	185	DNG	P 1	06C	+18.91	TECTEH			A6997	seco	22H00022	H	600UL	340972
731			8.30	177	DNG	P 1	06C	+21.93	TECTEH			A6997	seco	22H00022	H	600UL	340972
732			4.83	175	DNG	P 1	06C	+22.35	TECTEH			A6997	seco	22H00022	H	600UL	340972
733	40	38	4.06	182	DNG	P 1	VM	+10.09	TECTEH			T7451	seco	22H00023	H	600UL	331895
734	42	38	2.63	179	DNG	P 1	VM	+11.14	TECTEH			A6997	seco	22H00022	H	600UL	340972

735	48	38			TBS				TECTEH				D3858	reso	22H00044	H	600UL	331892

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 16

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
736			0.00	0	MAI	1	TSH	+0.65	TSHTSH	0.0		F3453	reso	22H00122	H	600PP	345291
737			0.10	86	PID	4	TSH	+0.65	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
738			0.12	126	MAI	2	TSH	+0.65	TSHTSH	0.4		F3453	reso	22H00122	H	600PP	345291
739	56	38	0.51	81	MBM	5	05H	+23.59	TECTEH			N5432	reso	22H00022	H	600UL	340972
740	60	38	3.41	180	DNG	P 1	VM	+19.73	TECTEH			T7451	seco	22H00023	H	600UL	331895
741	62	38			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
742			0.10	115	PID	4	TSH	+0.19	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
743			0.00	0	MAI	1	TSH	+0.19	TSHTSH	0.0		F3453	reso	22H00122	H	600PP	345291
744			0.14	70	MAI	2	TSH	+0.19	TSHTSH	0.3		F3453	reso	22H00122	H	600PP	345291
745	74	38	3.95	177	DNG	P 1	03C	+33.68	TECTEH			A6997	seco	22H00022	H	600UL	340972
746	78	38			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
747			0.22	81	SCI	P 1	TSH	+0.08	TSHTSH	0.4		F3453	reso	22H00122	H	600PP	345291
748			0.00	0	SCI	1	TSH	+0.08	TSHTSH	0.0		F3453	reso	22H00122	H	600PP	345291
749			0.20	86	PID	P 1	TSH	+0.08	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
750	94	38			NDF		VM	+6.44	VM VC			L2157	reso	22C00090	C	5602C	326272
751			0.39	82	NOI	5	VM	+6.44	TECTEH			M7006	reso	22H00033	H	600UL	331895
752			5.79	179	DNT	P 1	09C	+0.18	TECTEH			N5877	seco	22H00033	H	600UL	331895
	96	38	4.12	187	DNG	P 1	02H	+33.96	TECTEH			A9574	seco	22H00032	H	600UL	340972
	98	38	0.83	70	DSI	P 1	09C	-0.05	TECTEH			G2927	prim	22H00033	H	600UL	331895
755					NDF		09C	-0.05	09C09C			F6623	reso	22C00087	C	600PP	345298
756	104	38	0.79	93	MBM	5	06H	+12.78	TECTEH			M7006	reso	22H00032	H	600UL	340972
757			2.51	175	INR	P 1	09H	+0.23	TECTEH			M7006	reso	22H00032	H	600UL	340972
758			1.38	65	MBM	5	VH	+24.72	TECTEH			M7006	reso	22H00032	H	600UL	340972
759	106	38	1.99	168	INR	P 1	09H	-0.33	TECTEH			M7006	reso	22H00033	H	600UL	331895
760	110	38	2.17	81	MBM	6	03C	+13.29	TECTEH			M7006	reso	22H00033	H	600UL	331895
761			1.69	76	MBM	6	03C	+19.85	TECTEH			M7006	reso	22H00033	H	600UL	331895
762			3.40	76	MBM	6	03C	+37.42	TECTEH			M7006	reso	22H00033	H	600UL	331895
763	15	39	0.45	81	MBM	5	01H	+8.38	TECTEH			N5432	reso	22H00024	H	600UL	340972
764	33	39	2.74	175	DNT	P 1	01H	+0.99	TECTEH			S4373	reso	22H00024	H	600UL	340972
765	37	39			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
766			0.15	68	MAI	2	TSH	+0.15	TSHTSH	0.3		F3453	reso	22H00122	H	600PP	345291
767			0.00	0	MAI	1	TSH	+0.15	TSHTSH	0.0		F3453	reso	22H00122	H	600PP	345291
768			0.13	73	PID	4	TSH	+0.15	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
769			0.00	0	SAI	1	TSH	+0.53	TSHTSH	0.0		F3453	reso	22H00122	H	600PP	345291
770			0.08	109	SAI	2	TSH	+0.53	TSHTSH	0.2		F3453	reso	22H00122	H	600PP	345291
771			0.37	120	INR	P 1	TSH	+6.62	TECTEH			N5432	reso	22H00024	H	600UL	340972
772			2.39	180	DNG	P 1	07H	+8.76	TECTEH			A6997	seco	22H00024	H	600UL	340972
773			3.54	178	DNT	P 1	VM	-2.00	TECTEH			S4373	reso	22H00024	H	600UL	340972
774	39	39	2.00	181	DNG	P 1	04C	+26.25	TECTEH			A6997	seco	22H00024	H	600UL	340972
775	65	39			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
776			0.00	0	SCI	1	TSH	+0.06	TSHTSH	0.0		F3453	reso	22H00122	H	600PP	345291
777			0.15	122	PID	P 1	TSH	+0.06	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
778			0.12	109	SCI	P 1	TSH	+0.06	TSHTSH	0.3		F3453	reso	22H00122	H	600PP	345291
			0.00	0	MAI	1	TSH	+0.20	TSHTSH	0.0		F3453	reso	22H00122	H	600PP	345291
780			0.27	90	MAI	2	TSH	+0.20	TSHTSH	0.3		F3453	reso	22H00122	H	600PP	345291
781	69	39			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
782			0.35	75	SCI	P 1	TSH	+0.08	TSHTSH	1.12		F3453	reso	22H00122	H	600PP	345291
783			0.00	0	SCI	1	TSH	+0.08	TSHTSH	0.0		F3453	reso	22H00122	H	600PP	345291

784				0.17	129	PID	4	TSH	+0.19	TSHTSH	080			F6623	reso	22H00155	H	600PP	345291

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 17

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
785			0.22	81	SAI	2	TSH	+0.19	TSHTSH	0.2		M1680	reso	22H00122	H	600PP	345291
786			0.26	55	SAI	1	TSH	+0.19	TSHTSH	0.2		M1680	reso	22H00122	H	600PP	345291
787	75	39			INF		VH	+15.87	TECTEH	HR		A9608	reso	22H00025	H	600UL	331895
788			5.50	187	DNG	P 1	VH	+17.28	TECTEH			F6623	reso	22H00025	H	600UL	331895
789	83	39			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
790			0.00	0	SAI	1	TSH	+2.24	TSHTSH	0.0		N5432	reso	22H00123	H	600PP	326414
791			0.16	135	PID	4	TSH	+2.24	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
792			0.12	133	SAI	2	TSH	+2.24	TSHTSH	0.3		N5432	reso	22H00123	H	600PP	326414
793	85	39	1.01	76	MBM	5	01H	+11.13	TECTEH			N5432	reso	22H00024	H	600UL	340972
794	91	39	8.27	177	DNG	P 1	09C	+1.40	TECTEH			N5877	seco	22H00033	H	600UL	331895
795	93	39	19.86	182	DNT	P 1	09H	-0.07	TECTEH			A9574	seco	22H00032	H	600UL	340972
796	101	39			INF		VC	+9.96	TECTEH	HR		M7006	reso	22H00032	H	600UL	340972
797	109	39	0.38	94	MBM	5	08H	+4.81	TECTEH			M7006	reso	22H00032	H	600UL	340972
798	115	39	1.21	55	MBM	6	05H	+7.04	TECTEH			M7006	reso	22H00032	H	600UL	340972
799	117	39	2.35	179	DNG	P 1	09H	+1.57	TECTEH			A9574	seco	22H00032	H	600UL	340972
800					INF		09H	+4.70	TECTEH	HR		M7006	reso	22H00032	H	600UL	340972
801			17.43	179	DNG	P 1	09H	+6.67	TECTEH			A9574	seco	22H00032	H	600UL	340972
			3.33	177	DNG	P 1	06C	+12.49	TECTEH			A9574	seco	22H00032	H	600UL	340972
	4	40	7.54	8	PVN	P 1	TSH	+8.81	06HTEH			D6502	prim	22H00082	H	600UL	340912
804	8	40	2.69	191	DNG	P 1	04H	+13.87	TECTEH			M0945	seco	22H00025	H	600UL	331895
805	16	40	5.49	187	DNG	P 1	04H	+15.23	TECTEH			M0945	seco	22H00025	H	600UL	331895
806	20	40			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
807			0.19	83	SAI	2	TSH	+0.27	TSHTSH	0.2		N5432	reso	22H00123	H	600PP	326414
808			0.22	83	PID	4	TSH	+0.27	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
809			0.00	0	SAI	1	TSH	+0.27	TSHTSH	0.0		N5432	reso	22H00123	H	600PP	326414
810	32	40	2.74	183	DNT	P 1	VM	+1.61	TECTEH			A6997	seco	22H00024	H	600UL	340972
811	34	40	5.34	176	DNG	P 1	02H	+10.86	TECTEH			M0945	seco	22H00025	H	600UL	331895
812			3.56	178	DNT	P 1	06C	+0.04	TECTEH			M0945	seco	22H00025	H	600UL	331895
813	36	40	2.52	180	DNG	P 1	06H	+14.54	TECTEH			A6997	seco	22H00024	H	600UL	340972
814	38	40	0.69	74	MBM	5	02H	+20.18	TECTEH			F6623	reso	22H00025	H	600UL	331895
815			0.52	63	MBM	5	02H	+26.77	TECTEH			F6623	reso	22H00025	H	600UL	331895
816			0.54	71	MBM	5	02H	+36.69	TECTEH			F6623	reso	22H00025	H	600UL	331895
817	42	40	3.09	180	DNG	P 1	VM	+10.98	TECTEH			M0945	seco	22H00025	H	600UL	331895
818	44	40	5.05	176	DNG	P 1	06H	+21.95	TECTEH			S4373	reso	22H00024	H	600UL	340972
819			2.30	186	DNG	P 1	06H	+22.11	TECTEH			A6997	seco	22H00024	H	600UL	340972
820			4.69	181	DNG	P 1	06H	+23.27	TECTEH			A6997	seco	22H00024	H	600UL	340972
821	60	40	3.33	181	DNG	P 1	VM	+19.97	TECTEH			A6997	seco	22H00024	H	600UL	340972
822	62	40			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
823			0.17	92	SCI	P 1	TSH	+0.09	TSHTSH	0.4		N5432	reso	22H00123	H	600PP	326414
824			0.14	76	PID	P 1	TSH	+0.09	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
825			0.00	0	SCI	1	TSH	+0.09	TSHTSH	0.0		N5432	reso	22H00123	H	600PP	326414
826	64	40	1.72	180	INR	P 1	05C	-0.47	TECTEH			A6997	seco	22H00024	H	600UL	340972
827	70	40	2.36	170	INR	P 1	DH	+28.94	TECTEH			F6623	reso	22H00025	H	600UL	331895
			1.08	100	MBM	5	TSC	+0.75	TECTEH			F6623	reso	22H00025	H	600UL	331895
829	72	40	0.62	69	MBM	5	04H	+24.03	TECTEH			N5432	reso	22H00024	H	600UL	340972
830			0.52	94	MBM	5	01C	+18.09	TECTEH			N5432	reso	22H00024	H	600UL	340972
831			0.43	89	MBM	5	TSC	+18.80	TECTEH			N5432	reso	22H00024	H	600UL	340972
832	74	40			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892

833				0.18	90	SCI	P	1	TSH	+0.12	TSHTSH	0.3			N5432	reso	22H00123	H	600PP	326414

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 18

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
834			0.00	0	SCI	P	1	TSH +0.12	TSHTSH	0.0		N5432	reso	22H00123	H	600PP	326414
835			0.16	79	PID	P	1	TSH +0.12	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
836	76	40	3.15	185	DNG	P	1	04H +23.34	TECTEH			A6997	seco	22H00024	H	600UL	340972
837			2.92	186	DNG	P	1	04H +28.66	TECTEH			A6997	seco	22H00024	H	600UL	340972
838	84	40	4.47	182	DNG	P	1	07H +18.42	TECTEH			A6997	seco	22H00024	H	600UL	340972
839	96	40	0.22	89	11	P	2	VC -0.59	TECTEH			G2927	prim	22H00033	H	600UL	331895
840	104	40	0.44	82	MBM		5	03H +30.11	TECTEH			M7006	reso	22H00033	H	600UL	331895
841			3.80	180	DNT	P	1	09H +0.00	TECTEH			N5877	seco	22H00033	H	600UL	331895
842	106	40	1.17	92	MBM		5	05H +28.46	TECTEH			M7006	reso	22H00032	H	600UL	340972
843	108	40			NDF			09H -0.20	09H09H			K5380	prim	22H00184	H	600PP	345332
844			9.06	183	DNT	P	1	09H -0.20	TECTEH			N5877	seco	22H00033	H	600UL	331895
845	7	41	6.70	178	DNG	P	1	VM +4.22	TECTEH			F6623	reso	22H00025	H	600UL	331895
846	15	41	2.19	181	DNT	P	1	02H -0.81	TECTEH			A6997	seco	22H00024	H	600UL	340972
847	23	41			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
848			0.21	44	SAI		1	TSH +0.20	TSHTSH	0.3		F3453	reso	22H00122	H	600PP	345291
849			0.24	112	PID		4	TSH +0.20	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
850			0.25	111	SAI		2	TSH +0.20	TSHTSH	0.3		F3453	reso	22H00122	H	600PP	345291
	31	41	2.19	175	DNG	P	1	05H +13.71	TECTEH			M0945	seco	22H00025	H	600UL	331895
			3.87	177	DNG	P	1	05H +19.18	TECTEH			M0945	seco	22H00025	H	600UL	331895
853	33	41	3.80	176	DNG	P	1	DH +13.02	TECTEH			A6997	seco	22H00024	H	600UL	340972
854	37	41	1.00	75	MBM		5	02H +31.53	TECTEH			N5432	reso	22H00024	H	600UL	340972
855	43	41			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
856			0.16	113	PID		4	TSH +0.74	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
857			0.00	0	SAI		1	TSH +0.74	TSHTSH	0.0		N5432	reso	22H00123	H	600PP	326414
858			0.16	101	SAI		2	TSH +0.74	TSHTSH	0.3		N5432	reso	22H00123	H	600PP	326414
859	65	41			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
860			0.12	114	PID		4	TSH +0.19	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
861			0.00	0	MAI		1	TSH +0.19	TSHTSH	0.0		F3453	reso	22H00122	H	600PP	345291
862			0.13	101	MAI		2	TSH +0.19	TSHTSH	0.3		F3453	reso	22H00122	H	600PP	345291
863	71	41	0.45	80	MBM		5	TSC +35.79	TECTEH			N5432	reso	22H00024	H	600UL	340972
864	79	41	2.03	179	DNG	P	1	02C +37.71	TECTEH			M0945	seco	22H00025	H	600UL	331895
865	83	41	0.74	95	MBM		5	08H +11.64	TECTEH			F6623	reso	22H00025	H	600UL	331895
866			0.72	109	MBM		5	07C +16.81	TECTEH			F6623	reso	22H00025	H	600UL	331895
867	85	41	0.52	82	MBM		5	04H +10.54	TECTEH			N5432	reso	22H00024	H	600UL	340972
868	87	41	2.70	177	DNT	P	1	01C +0.99	TECTEH			S4373	reso	22H00024	H	600UL	340972
869	91	41	0.62	50	MBM		6	01H +15.70	TECTEH			M7006	reso	22H00033	H	600UL	331895
870			0.86	102	MBM		6	03C +29.52	TECTEH			M7006	reso	22H00033	H	600UL	331895
871	93	41	2.56	180	DNG	P	1	07H +24.16	TECTEH			A9574	seco	22H00032	H	600UL	340972
872			2.14	181	DNT	P	1	08H +0.82	TECTEH			A9574	seco	22H00032	H	600UL	340972
873			4.77	180	DNG	P	1	08H +11.00	TECTEH			A9574	seco	22H00032	H	600UL	340972
874			3.73	179	DNG	P	1	08H +13.03	TECTEH			A9574	seco	22H00032	H	600UL	340972
875			3.29	179	DNG	P	1	08H +14.31	TECTEH			M7006	reso	22H00032	H	600UL	340972
876			10.73	179	DNG	P	1	08H +15.02	TECTEH			A9574	seco	22H00032	H	600UL	340972
			4.60	177	DNG	P	1	08H +18.52	TECTEH			A9574	seco	22H00032	H	600UL	340972
878			4.58	177	DNG	P	1	08H +18.63	TECTEH			M7006	reso	22H00032	H	600UL	340972
879			2.83	182	DNT	P	1	09C +0.71	TECTEH			A9574	seco	22H00032	H	600UL	340972
880			2.21	176	DNT	P	1	08C -0.34	TECTEH			A9574	seco	22H00032	H	600UL	340972
881			1.21	358	INR	P	1	08C +4.11	TECTEH			A9574	seco	22H00032	H	600UL	340972

882				0.84	188	INR	P 1	08C	+5.02	TECTEH			A9574	seco	22H00032	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 19

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
883			1.12	353	INR	P 1	08C	+6.73	TECTEH			A9574	seco	22H00032	H	600UL	340972
884			26.48	180	DNG	P 1	08C	+8.80	TECTEH			A9574	seco	22H00032	H	600UL	340972
885			47.15	179	DNG	P 1	08C	+9.59	TECTEH			A9574	seco	22H00032	H	600UL	340972
886			4.40	177	DNG	P 1	08C	+12.73	TECTEH			A9574	seco	22H00032	H	600UL	340972
887			4.47	179	DNG	P 1	08C	+14.54	TECTEH			A9574	seco	22H00032	H	600UL	340972
888			2.28	175	DNG	P 1	07C	+21.33	TECTEH			A9574	seco	22H00032	H	600UL	340972
889	95	41	52.53	180	DNT	P 1	09H	+0.13	TECTEH			N5877	seco	22H00033	H	600UL	331895
890					NDF		09H	+0.13	09H09H			F6623	reso	22H00184	H	600PP	345332
891	107	41	17.13	182	DNT	P 1	09H	-0.15	TECTEH			N5877	seco	22H00033	H	600UL	331895
892	111	41	2.67	181	DNG	P 1	08H	+6.51	TECTEH			N5877	seco	22H00033	H	600UL	331895
893			3.70	182	DNG	P 1	08H	+10.81	TECTEH			N5877	seco	22H00033	H	600UL	331895
894			1.91	179	INR	P 1	08C	+3.71	TECTEH			N5877	seco	22H00033	H	600UL	331895
895	115	41	3.12	180	DNT	P 1	09H	-0.02	TECTEH			N5877	seco	22H00033	H	600UL	331895
896			0.44	88	MBM	6	VM	+26.29	TECTEH			M7006	reso	22H00033	H	600UL	331895
897	117	41	3.76	185	DNT	P 1	10H	-0.41	TECTEH			A9574	seco	22H00032	H	600UL	340972
898					NDF		10H	+0.35	10H10H			K5300	prim	22H00184	H	600PP	345332
899			10.11	182	DNT	P 1	10H	+0.35	TECTEH			A9574	seco	22H00032	H	600UL	340972
	2	42			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
			1.28	15	GEO	P 1	VM	-0.12	06C06H			D3858	reso	22C00098	C	560FH	345358
902			1.77	25	PID	P 2	VM	-0.12	06C06H			M9715	seco	22C00100	C	560FH	345358
903	14	42			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
904			3.76	175	DNT	P 1	02H	+0.93	05HTEH			I3805	seco	22H00079	H	600UL	340943
905			3.33	176	DNT	P 1	02H	+0.93	TEHTEC			C5542	reso	22C00062	H	560SF	270908
906			3.17	177	DNT	P 1	02H	+0.99	05HTEH			M0945	seco	22H00025	H	600UL	331895
907					OBS		05H	+29.08	05HTEH			M0945	seco	22H00025	H	600UL	331895
908					OBS		05H	+32.65	05HTEH			I3805	seco	22H00079	H	600UL	340943
909			29.31	174	DNG	P 1	05H	+36.26	TEHTEC			S8982	seco	22C00062	H	560SF	270908
910			11.57	181	DNG	P 1	05H	+37.91	TEHTEC			C5542	reso	22C00062	H	560SF	270908
911					OBS		DH	-15.54	DH TEC			B4052	prim	22C00061	H	580UL	287821
912					OBS		DH	-13.51	DH TEC			L2157	reso	22C00060	H	600CS	341219
913			1.18	149	SVI	2	DC	+0.69	05H06C	0.9		N5432	reso	22H00216	H	5602C	340987
914			0.00	0	SVI	1	DC	+0.69	05H06C	0.0		M1680	reso	22H00216	H	5602C	340987
915			0.26	142	PID	2	DC	+0.69	05H06C			P5436	prim	22H00231	H	5602C	340987
916	22	42	4.23	181	DNG	P 1	06H	+2.16	TECTEH			A6997	seco	22H00024	H	600UL	340972
917	32	42	4.80	180	DNT	P 1	VM	+2.03	TECTEH			A6997	seco	22H00024	H	600UL	340972
918	40	42	3.29	183	DNG	P 1	07H	+10.69	TECTEH			A6997	seco	22H00024	H	600UL	340972
919	42	42	2.39	181	DNG	P 1	06H	+9.09	TECTEH			M0945	seco	22H00025	H	600UL	331895
920			2.22	184	DNG	P 1	06H	+9.54	TECTEH			M0945	seco	22H00025	H	600UL	331895
921			5.63	180	DNG	P 1	06H	+10.32	TECTEH			M0945	seco	22H00025	H	600UL	331895
922			2.17	178	DNG	P 1	VM	+11.16	TECTEH			M0945	seco	22H00025	H	600UL	331895
923	46	42			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
924			0.00	0	MAI	1	TSH	+0.68	TSHTSH	0.0		N5432	reso	22H00123	H	600PP	326414
			0.14	91	PID	4	TSH	+0.68	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
			0.17	89	MAI	2	TSH	+0.68	TSHTSH	0.5		N5432	reso	22H00123	H	600PP	326414
927	48	42	2.16	183	DNG	P 1	VM	+14.15	TECTEH			A6997	seco	22H00024	H	600UL	340972
928	58	42	3.06	180	DNG	P 1	06H	+9.07	TECTEH			M0945	seco	22H00025	H	600UL	331895
929			2.17	180	DNG	P 1	06H	+13.09	TECTEH			M0945	seco	22H00025	H	600UL	331895
930			2.59	181	DNG	P 1	06H	+16.72	TECTEH			M0945	seco	22H00025	H	600UL	331895

931	60	42	3.61	181	DNG	P 1	VM	+19.90	TECTEH			A6997	seco	22H00024	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 20

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
932	62	42	2.27	180	DNG	P 1	VM	+21.02	TECTEH			M0945	seco	22H00025	H	600UL	331895
933	68	42			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
934			0.19	98	PID	4	TSH	+0.24	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
935			0.26	131	SAI	1	TSH	+0.24	TSHTSH	0.4		F3453	reso	22H00122	H	600PP	345291
936			0.21	84	SAI	2	TSH	+0.24	TSHTSH	0.4		F3453	reso	22H00122	H	600PP	345291
937			4.17	182	DNG	P 1	07H	+18.39	TECTEH			A6997	seco	22H00024	H	600UL	340972
938			2.20	181	DNG	P 1	07C	+8.23	TECTEH			A6997	seco	22H00024	H	600UL	340972
939	70	42	2.44	180	DNG	P 1	07C	+2.17	TECTEH			M0945	seco	22H00025	H	600UL	331895
940	72	42	2.47	176	DNG	P 1	08C	+5.77	TECTEH			A6997	seco	22H00024	H	600UL	340972
941	76	42			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
942			0.00	0	SCI	1	TSH	+0.10	TSHTSH	0.0		N5432	reso	22H00123	H	600PP	326414
943			0.08	75	PID	P 1	TSH	+0.10	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
944			0.12	97	SCI	P 1	TSH	+0.10	TSHTSH	0.2		N5432	reso	22H00123	H	600PP	326414
945	78	42			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
946			1.05	90	PID	4	TSH	+0.18	TSHTSH	080		N5432	reso	22H00156	H	600PP	345329
947			0.19	182	MAI	2	TSH	+0.18	TSHTSH	0.3		F3453	reso	22H00122	H	600PP	345291
948			0.00	0	MAI	1	TSH	+0.18	TSHTSH	0.0		F3453	reso	22H00122	H	600PP	345291
	80	42	1.90	182	INR	P 1	TSH	+17.78	TECTEH			M0945	seco	22H00025	H	600UL	331895
.	92	42	5.79	188	DNT	P 1	09H	-0.11	TECTEH			A9574	seco	22H00032	H	600UL	340972
951	94	42	40.47	181	DNT	P 1	09H	+0.02	TECTEH			N5877	seco	22H00033	H	600UL	331895
952	96	42			NDF		09H	-0.11	09H09H			T2170	seco	22H00197	H	600PP	345329
953			76.13	180	DNT	P 1	09H	-0.11	TECTEH			A9574	seco	22H00032	H	600UL	340972
954	102	42	0.12	88	INR	9	TSC	+0.20	TSCTSC			S4373	reso	22C00052	C	600PP	345295
955	106	42			NDF		09H	-0.04	09H09H			K5380	prim	22H00184	H	600PP	345332
956			55.11	181	DNT	P 1	09H	-0.04	TECTEH			N5877	seco	22H00033	H	600UL	331895
957	108	42	22.11	182	DNT	P 1	09H	-0.04	TECTEH			A9574	seco	22H00032	H	600UL	340972
958	112	42	0.97	93	MBM	6	02H	+24.53	TECTEH			M7006	reso	22H00032	H	600UL	340972
959			0.56	93	MBM	6	02H	+29.98	TECTEH			M7006	reso	22H00032	H	600UL	340972
960			0.50	86	MBM	5	02H	+35.44	TECTEH			M7006	reso	22H00032	H	600UL	340972
961			0.76	70	MBM	6	03H	+1.88	TECTEH			M7006	reso	22H00032	H	600UL	340972
962			0.71	80	MBM	5	03H	+13.07	TECTEH			M7006	reso	22H00032	H	600UL	340972
963			0.70	53	MBM	6	03H	+24.07	TECTEH			M7006	reso	22H00032	H	600UL	340972
964			1.11	79	MBM	6	03H	+29.63	TECTEH			M7006	reso	22H00032	H	600UL	340972
965			0.64	85	MBM	6	04H	+1.70	TECTEH			M7006	reso	22H00032	H	600UL	340972
966			0.58	87	MBM	6	04H	+7.21	TECTEH			M7006	reso	22H00032	H	600UL	340972
967			1.64	183	INR	P 1	09H	+2.21	TECTEH			A9574	seco	22H00032	H	600UL	340972
968	118	42	9.79	180	DNG	P 1	09H	+14.89	TECTEH			N5877	seco	22H00033	H	600UL	331895
969			4.03	178	DNG	P 1	09H	+18.75	TECTEH			N5877	seco	22H00033	H	600UL	331895
970			2.21	177	DNG	P 1	09H	+20.98	TECTEH			N5877	seco	22H00033	H	600UL	331895
971			10.47	178	DNT	P 1	10H	-0.64	TECTEH			N5877	seco	22H00033	H	600UL	331895
972			8.73	180	DNT	P 1	10H	-0.37	TECTEH			N5877	seco	22H00033	H	600UL	331895
973			18.63	182	DNT	P 1	10H	+0.42	TECTEH			N5877	seco	22H00033	H	600UL	331895
[illegible]			3.39	180	DNG	P 1	07C	+20.85	TECTEH			N5877	seco	22H00033	H	600UL	331895
	33	43	3.89	182	DNT	P 1	VM	-1.75	TECTEH			M0945	seco	22H00025	H	600UL	331895
976			2.61	178	DNT	P 1	VM	-1.18	TECTEH			M0945	seco	22H00025	H	600UL	331895
977	39	43	0.67	82	MBM	5	01H	+33.07	TECTEH			F6623	reso	22H00025	H	600UL	331895
978	45	43			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
979			0.00	0	MAI	1	TSH	+0.70	TSHTSH	0.0		F3453	reso	22H00122	H	600PP	345291

980			0.20	88	MAI	2	TSH	+0.70	TSHTSH	0.2			F3453	reso	22H00122	H	600PP	345291

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 21

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
981			0.15	113	PID	4	TSH	+0.70	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
982	51	43	2.26	183	DNG	P 1	TSH	+21.07	TECTEH			M0945	seco	22H00025	H	600UL	331895
983			2.35	181	DNG	P 1	TSH	+37.40	TECTEH			M0945	seco	22H00025	H	600UL	331895
984			2.45	182	DNT	P 1	01H	-1.28	TECTEH			M0945	seco	22H00025	H	600UL	331895
985			2.80	181	DNT	P 1	01H	-0.89	TECTEH			M0945	seco	22H00025	H	600UL	331895
986	61	43	0.64	61	MBM	5	02H	+15.89	TECTEH			N5432	reso	22H00024	H	600UL	340972
987			0.56	83	MBM	5	06H	+20.78	TECTEH			N5432	reso	22H00024	H	600UL	340972
988			2.88	174	DNG	P 1	07C	+24.91	TECTEH	LOCOK		S4373	reso	22H00024	H	600UL	340972
989			2.47	172	DNG	P 1	07C	+26.36	TECTEH	LOCOK		S4373	reso	22H00024	H	600UL	340972
990			11.24	177	DNG	P 1	07C	+27.15	TECTEH	LOCOK		S4373	reso	22H00024	H	600UL	340972
991	65	43			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
992			0.15	29	SAI	3	TSH	+0.62	TSHTSH	0.2		F6623	reso	22H00155	H	600PP	345291
993			0.14	81	PID	4	TSH	+0.62	TSHTSH	080		L2157	reso	22H00167	H	600PP	345290
994			0.16	85	SAI	4	TSH	+0.62	TSHTSH	0.2		F6623	reso	22H00155	H	600PP	345291
995			1.79	178	INR	P 1	02H	+14.51	TECTEH			A6997	seco	22H00024	H	600UL	340972
996			1.99	0	INR	P 1	07H	0.48	TECTEH			A6997	seco	22H00024	H	600UL	340972
997			2.88	178	DNG	P 1	07C	+1.58	TECTEH			A6997	seco	22H00024	H	600UL	340972
	85	43	2.02	181	DNG	P 1	03H	+13.65	TECTEH			F4645	seco	22H00029	H	600UL	331895
			0.60	76	MBM	5	03C	+34.60	TECTEH			N5432	reso	22H00029	H	600UL	331895
1000	91	43	0.62	71	MBM	6	01H	+7.78	TECTEH			M7006	reso	22H00033	H	600UL	331895
1001	93	43	5.40	182	DNT	P 1	08H	+0.68	TECTEH			A9574	seco	22H00032	H	600UL	340972
1002			3.47	182	DNG	P 1	08H	+6.89	TECTEH			A9574	seco	22H00032	H	600UL	340972
1003			4.51	182	DNG	P 1	08H	+11.99	TECTEH			A9574	seco	22H00032	H	600UL	340972
1004			2.59	180	DNG	P 1	08H	+16.07	TECTEH			A9574	seco	22H00032	H	600UL	340972
1005			3.74	177	DNT	P 1	09C	+0.87	TECTEH			A9574	seco	22H00032	H	600UL	340972
1006	97	43	37.88	181	DNT	P 1	09H	-0.02	TECTEH			A9574	seco	22H00032	H	600UL	340972
1007					NDF		09H	-0.02	09H09H			K5380	prim	22H00184	H	600PP	345332
1008	103	43	0.39	74	MBM	5	VM	+12.15	TECTEH			M7006	reso	22H00033	H	600UL	331895
1009	105	43			INF		VH	+22.44	TECTEH	HR		M7006	reso	22H00032	H	600UL	340972
1010			0.78	70	MBM	5	VH	+25.76	TECTEH			M7006	reso	22H00032	H	600UL	340972
1011	107	43	37.80	179	DNT	P 1	09H	-0.04	TECTEH			N5877	seco	22H00033	H	600UL	331895
1012					NDF		09H	-0.04	09H09H			K5380	prim	22H00184	H	600PP	345332
1013			3.12	180	DNG	P 1	08C	+6.28	TECTEH			N5877	seco	22H00033	H	600UL	331895
1014	113	43	0.48	83	MBM	5	06H	+7.96	TECTEH			M7006	reso	22H00032	H	600UL	340972
1015	115	43	4.41	182	DNT	P 1	09H	-0.02	TECTEH			N5877	seco	22H00033	H	600UL	331895
1016					NDF		VH	+10.07	VH VM			H4599	seco	22H00199	H	5602C	326272
1017			0.46	64	NQI	5	VH	+10.07	TECTEH			M7006	reso	22H00033	H	600UL	331895
1018	117	43	1.78	171	INR	P 1	09H	+0.32	TECTEH			A9574	seco	22H00032	H	600UL	340972
1019			2.63	177	DNG	P 1	09H	+8.76	TECTEH			A9574	seco	22H00032	H	600UL	340972
1020			5.46	182	DNG	P 1	09H	+9.86	TECTEH			A9574	seco	22H00032	H	600UL	340972
1021			2.18	179	DNG	P 1	09H	+12.76	TECTEH			A9574	seco	22H00032	H	600UL	340972
1022			2.12	182	DNG	P 1	09H	+13.90	TECTEH			A9574	seco	22H00032	H	600UL	340972
1023			2.13	181	DNG	P 1	09H	+17.37	TECTEH			A9574	seco	22H00032	H	600UL	340972
			6.03	184	DNG	P 1	09H	+21.03	TECTEH			A9574	seco	22H00032	H	600UL	340972
1025			13.89	181	DNT	P 1	10H	-0.39	TECTEH			A9574	seco	22H00032	H	600UL	340972
1026			22.07	182	DNT	P 1	10H	+0.40	TECTEH			A9574	seco	22H00032	H	600UL	340972
1027			5.31	180	DNT	P 1	10C	-0.57	TECTEH			A9574	seco	22H00032	H	600UL	340972
1028	119	43	4.49	179	DNT	P 1	10H	-0.36	TECTEH			N5877	seco	22H00033	H	600UL	331895

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 22

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1029			3.27	176	DNT	P 1	10H	+0.44	TECTEH			N5877	seco	22H00033	H	600UL	331895
1030	121	43	4.27	212	NRC	2	TSC	+0.00	TECTEH			W2096	prim	22H00032	H	600UL	340972
1031	6	44	0.56	77	MBM	5	TSC	+21.43	TECTEH			N5432	reso	22H00028	H	600UL	340972
1032	30	44	0.52	28	INR	P 1	TSH	+1.95	TECTEH			N5432	reso	22H00029	H	600UL	331895
1033	40	44	2.70	175	DNG	P 1	07H	+2.36	TECTEH			A6997	seco	22H00028	H	600UL	340972
1034			5.89	174	DNT	P 1	VM	+2.00	TECTEH			S4373	reso	22H00028	H	600UL	340972
1035			4.66	176	DNG	P 1	VM	+10.17	TECTEH			A6997	seco	22H00028	H	600UL	340972
1036	42	44	4.16	175	DNG	P 1	03H	-1.55	TECTEH			S4373	reso	22H00029	H	600UL	331895
1037	48	44	2.20	175	DNG	P 1	07H	+9.83	TECTEH			A6997	seco	22H00028	H	600UL	340972
1038			2.49	175	DNG	P 1	VM	+14.06	TECTEH			A6997	seco	22H00028	H	600UL	340972
1039	54	44	0.45	70	MBM	5	07H	+3.72	TECTEH			N5432	reso	22H00029	H	600UL	331895
1040			2.84	183	DNG	P 1	TSC	+7.35	TECTEH			F4645	seco	22H00029	H	600UL	331895
1041	56	44			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1042			0.18	119	SAI	2	TSH	+0.68	TSHTSH	0.5		F3453	reso	22H00122	H	600PP	345291
1043			0.19	118	PID	4	TSH	+0.68	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
1044			0.18	60	SAI	1	TSH	+0.68	TSHTSH	0.3		F3453	reso	22H00122	H	600PP	345291
1045	60	44	3.36	177	DNG	P 1	VM	+17.42	TECTEH			A6997	seco	22H00028	H	600UL	340972
1046			6.33	177	DNG	P 1	VM	+20.05	TECTEH			A6997	seco	22H00028	H	600UL	340972
	74	44	2.50	174	DNG	P 1	TSC	+12.20	TECTEH			F4645	seco	22H00029	H	600UL	331895
	86	44	0.28	75	MBM	5	05H	+17.81	TECTEH			N5432	reso	22H00028	H	600UL	340972
1049	88	44	0.42	96	INR	5	03H	+7.53	TECTEH			T5565	prim	22H00029	H	600UL	331895
1050			0.68	100	INR	5	03H	+8.72	TECTEH			T5565	prim	22H00029	H	600UL	331895
1051			1.88	62	MBM	6	04H	+24.28	TECTEH			N5432	reso	22H00029	H	600UL	331895
1052	96	44	4.34	181	DNT	P 1	09H	-0.02	TECTEH			N5877	seco	22H00033	H	600UL	331895
1053			4.03	176	DNG	P 1	04C	+2.08	TECTEH			N5877	seco	22H00033	H	600UL	331895
1054	98	44	2.78	173	DNG	P 1	03H	+25.93	TECTEH			A9574	seco	22H00032	H	600UL	340972
1055			0.60	85	MBM	5	07H	+21.31	TECTEH			M7006	reso	22H00032	H	600UL	340972
1056	100	44	0.49	109	MBM	5	06C	+15.98	TECTEH			M7006	reso	22H00033	H	600UL	331895
1057	104	44	0.68	85	MBM	5	03C	+18.28	TECTEH			M7006	reso	22H00033	H	600UL	331895
1058	116	44	0.76	82	MBM	5	03C	+15.75	TECTEH			M7006	reso	22H00033	H	600UL	331895
1059	118	44	0.49	74	MBM	5	TSH	+8.04	TECTEH			M7006	reso	22H00032	H	600UL	340972
1060			9.88	178	DNT	P 1	10H	-0.38	TECTEH			A9574	seco	22H00032	H	600UL	340972
1061			7.55	182	DNT	P 1	10H	+0.41	TECTEH			M7006	reso	22H00032	H	600UL	340972
1062	120	44	6.18	181	DNT	P 1	10H	-0.33	TECTEH			N5877	seco	22H00033	H	600UL	331895
1063			9.99	179	DNT	P 1	10H	+0.44	TECTEH			N5877	seco	22H00033	H	600UL	331895
1064	15	45	2.99	182	DNT	P 1	DH	+2.21	TECTEH			M9715	seco	22H00029	H	600UL	331895
1065			3.94	180	DNT	P 1	DC	+1.56	TECTEH			M9715	seco	22H00029	H	600UL	331895
1066	19	45	0.63	88	MBM	6	02H	+36.31	TECTEH			N5432	reso	22H00028	H	600UL	340972
1067	23	45			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1068			0.00	0	SAI	1	TSH	+0.50	TSHTSH	0.0		N5432	reso	22H00123	H	600PP	326414
1069			0.24	108	SAI	2	TSH	+0.50	TSHTSH	0.3		N5432	reso	22H00123	H	600PP	326414
1070			0.21	113	PID	4	TSH	+0.50	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
1071	31	45	3.84	181	DNT	P 1	VM	-2.00	TECTEH			M9715	seco	22H00029	H	600UL	331895
1072	39	45	4.28	180	DNT	P 1	VM	-1.89	TECTEH			M9715	seco	22H00029	H	600UL	331895
	69	45	0.26	7	IDM	2	TSC	+0.83	TSCTSC			F3453	reso	22C00084	C	600PP	345343
1074	79	45	0.59	76	MBM	5	03H	+7.87	TECTEH			N5432	reso	22H00028	H	600UL	340972
1075	85	45	0.26	84	MBM	5	03H	+13.66	TECTEH			N5432	reso	22H00029	H	600UL	331895
1076	89	45	0.56	110	22	P 2	VH	+1.82	TECTEH			N5877	seco	22H00028	H	600UL	340972
1077	91	45			INF		08H	+9.60	TECTEH	HR		M7006	reso	22H00033	H	600UL	331895

1078			9.27	180	DNG	P 1	08H	+14.35	TECTEH			N5877	seco	22H00033	H	600UL	331895

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 23

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1079		13.64	177	DNG	P 1	09C	+1.71	TECTEH			N5877	seco	22H00033	H	600UL	331895
1080	93	45	6.42	181	DNG	P 1	08C	+16.11	TECTEH			A9574	seco	22H00032	H	600UL	340972
1081					INF		08C	+18.26	TECTEH	HR		M7006	reso	22H00032	H	600UL	340972
1082			3.62	178	DNG	P 1	07C	+21.99	TECTEH			A9574	seco	22H00032	H	600UL	340972
1083	95	45			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
1084			0.27	92	SAI	2	TSH	+1.01	TSHTSH	0.4		C5542	reso	22H00132	H	600PP	345291
1085			0.30	106	PID	4	TSH	+1.01	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
1086			0.41	85	SAI	1	TSH	+1.01	TSHTSH	0.4		C5542	reso	22H00132	H	600PP	345291
1087			0.12	117	SAI	2	TSH	+1.58	TSHTSH	0.2		D8661	reso	22H00132	H	600PP	345291
1088			0.11	62	SAI	1	TSH	+1.58	TSHTSH	0.2		D8661	reso	22H00132	H	600PP	345291
1089					NDF		09C	+0.02	09C09C			F6623	reso	22C00087	C	600PP	345298
1090			0.48	71	DSI	P 1	09C	+0.02	TECTEH			G2927	prim	22H00033	H	600UL	331895
1091	101	45	5.48	173	DNG	P 1	02H	+36.71	TECTEH			A9574	seco	22H00032	H	600UL	340972
1092	107	45	8.04	177	DNT	P 1	09H	-0.02	TECTEH			N5877	seco	22H00033	H	600UL	331895
1093					NDF		09H	-0.02	09H09H			K5380	prim	22H00184	H	600PP	345332
1094	117	45	4.21	181	DNG	P 1	09H	+5.48	TECTEH			A9574	seco	22H00032	H	600UL	340972
1095			6.48	176	DNT	P 1	10H	-0.38	TECTEH			A9574	seco	22H00032	H	600UL	340972
			15.97	179	DNT	P 1	10H	+0.35	TECTEH			A9574	seco	22H00032	H	600UL	340972
					NDF		10H	+0.35	10H10H			K5380	prim	22H00184	H	600PP	345332
1098			3.16	176	DNT	P 1	10C	-0.81	TECTEH			A9574	seco	22H00032	H	600UL	340972
1099			12.24	180	DNT	P 1	10C	-0.42	TECTEH			A9574	seco	22H00032	H	600UL	340972
1100			6.51	179	DNT	P 1	10C	-0.04	TECTEH			A9574	seco	22H00032	H	600UL	340972
1101	119	45	4.91	181	DNT	P 1	10H	+0.47	TECTEH			N5877	seco	22H00033	H	600UL	331895
1102	121	45	4.79	180	DNT	P 1	09H	+0.07	TECTEH			A9574	seco	22H00032	H	600UL	340972
1103			10.30	174	DNT	P 1	10H	-0.40	TECTEH			A9574	seco	22H00032	H	600UL	340972
1104			11.22	177	DNT	P 1	10H	+0.67	TECTEH			A9574	seco	22H00032	H	600UL	340972
1105			4.54	213	NRC	2	TSC	+0.00	TECTEH			W2096	prim	22H00032	H	600UL	340972
1106	123	45	2.65	182	DNG	P 1	08H	+15.46	TECTEH			A9574	seco	22H00032	H	600UL	340972
1107			2.81	178	DNG	P 1	08H	+18.97	TECTEH			A9574	seco	22H00032	H	600UL	340972
1108			7.80	180	DNG	P 1	08H	+20.03	TECTEH			A9574	seco	22H00032	H	600UL	340972
1109			3.54	178	DNG	P 1	09H	+3.82	TECTEH			A9574	seco	22H00032	H	600UL	340972
1110			6.10	181	DNG	P 1	09H	+4.84	TECTEH			A9574	seco	22H00032	H	600UL	340972
1111			3.96	176	DNG	P 1	09H	+10.64	TECTEH			A9574	seco	22H00032	H	600UL	340972
1112			19.86	181	DNG	P 1	09H	+11.59	TECTEH			A9574	seco	22H00032	H	600UL	340972
1113			3.54	179	DNG	P 1	09H	+13.21	TECTEH			A9574	seco	22H00032	H	600UL	340972
1114			4.05	180	DNG	P 1	09H	+14.04	TECTEH			A9574	seco	22H00032	H	600UL	340972
1115			3.04	177	DNG	P 1	09H	+18.63	TECTEH			A9574	seco	22H00032	H	600UL	340972
1116			18.02	181	DNG	P 1	09H	+19.73	TECTEH			A9574	seco	22H00032	H	600UL	340972
1117			16.77	177	DNT	P 1	10H	-0.52	TECTEH			A9574	seco	22H00032	H	600UL	340972
1118			7.07	181	DNT	P 1	10H	+0.40	TECTEH			A9574	seco	22H00032	H	600UL	340972
1119					NDF		10H	+0.40	10H10H			K5380	prim	22H00184	H	600PP	345332
1120			5.40	181	DNG	P 1	10H	+0.99	TECTEH			A9574	seco	22H00032	H	600UL	340972
[illegible]			14.18	181	DNT	P 1	10C	-0.46	TECTEH			A9574	seco	22H00032	H	600UL	340972
			13.98	178	DNT	P 1	10C	+0.63	TECTEH			A9574	seco	22H00032	H	600UL	340972
1123			4.77	179	DNG	P 1	09C	+3.63	TECTEH			A9574	seco	22H00032	H	600UL	340972
1124			6.50	182	DNG	P 1	09C	+11.53	TECTEH			A9574	seco	22H00032	H	600UL	340972
1125			4.51	174	DNT	P 1	03C	-0.55	TECTEH			A9574	seco	22H00032	H	600UL	340972
1126	12	46	3.37	180	DNG	P 1	DH	-1.16	TECTEH			F4645	seco	22H00062	H	600UL	340914

1127	16	46	4.08	181	DNG	P 1	TSC	+17.26		TECTEH				F4645	seco	22H00062	H	600UL	340914

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 24

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1128	24	46			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1129			0.19	111	SAI	1	TSH	+0.21	TSHTSH	0.3		F6623	reso	22H00148	H	600PP	345329
1130			0.28	75	SAI	2	TSH	+0.21	TSHTSH	0.3		F6623	reso	22H00148	H	600PP	345329
1131			0.24	96	PID	4	TSH	+0.21	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1132	30	46	2.12	182	DNG	P 1	TSH	+31.78	TECTEH			D4576	seco	22H00061	H	600UL	340945
1133			3.79	181	DNG	P 1	DH	+9.75	TECTEH			D4576	seco	22H00061	H	600UL	340945
1134	40	46	9.64	178	DNG	P 1	TSH	+15.96	TECTEH			F4645	seco	22H00062	H	600UL	340914
1135			5.89	178	DNG	P 1	01H	+12.36	TECTEH			F4645	seco	22H00062	H	600UL	340914
1136			15.98	181	DNG	P 1	06H	+4.50	TECTEH			F4645	seco	22H00062	H	600UL	340914
1137			4.20	183	DNG	P 1	06H	+7.09	TECTEH			F4645	seco	22H00062	H	600UL	340914
1138			5.80	182	DNG	P 1	06H	+10.37	TECTEH			F4645	seco	22H00062	H	600UL	340914
1139			3.94	180	DNG	P 1	06H	+11.20	TECTEH			F4645	seco	22H00062	H	600UL	340914
1140			3.86	179	DNG	P 1	06C	+5.05	TECTEH			F4645	seco	22H00062	H	600UL	340914
1141			3.88	179	DNG	P 1	06C	+5.65	TECTEH			F4645	seco	22H00062	H	600UL	340914
1142			2.69	182	DNG	P 1	05C	+19.53	TECTEH			F4645	seco	22H00062	H	600UL	340914
1143			2.66	180	DNG	P 1	05C	+35.79	TECTEH			F4645	seco	22H00062	H	600UL	340914
1144	42	46	6.27	179	DNG	P 1	06H	+11.29	TECTEH			D4576	seco	22H00061	H	600UL	340945
			2.56	181	DNG	P 1	VM	+10.95	TECTEH			D4576	seco	22H00061	H	600UL	340945
	46	46			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1147			0.11	142	PID	4	TSH	+0.93	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
1148			0.09	49	MAI	1	TSH	+0.93	TSHTSH	0.3		F6623	reso	22H00147	H	600PP	345291
1149			0.11	90	MAI	2	TSH	+0.93	TSHTSH	0.5		F6623	reso	22H00147	H	600PP	345291
1150	52	46	3.12	180	DNG	P 1	VM	+5.07	TECTEH			F4645	seco	22H00062	H	600UL	340914
1151	54	46			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1152			0.18	94	PID	4	TSH	+0.57	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
1153			0.21	93	MAI	2	TSH	+0.57	TSHTSH	0.6		F6623	reso	22H00147	H	600PP	345291
1154			0.22	95	MAI	1	TSH	+0.57	TSHTSH	0.5		F6623	reso	22H00147	H	600PP	345291
1155	60	46	3.19	181	DNG	P 1	VM	+19.86	TECTEH			F4645	seco	22H00062	H	600UL	340914
1156	66	46	2.41	176	DNG	P 1	TSC	+7.40	TECTEH			D4576	seco	22H00061	H	600UL	340945
1157	80	46	3.53	179	DNG	P 1	TSH	+17.39	TECTEH			F4645	seco	22H00062	H	600UL	340914
1158			9.74	183	DNG	P 1	TSH	+17.70	TECTEH			F4645	seco	22H00062	H	600UL	340914
1159	82	46			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
1160			0.44	116	MCI	1	TSH	+0.11	TSHTSH	1.0		F6623	reso	22H00147	H	600PP	345291
1161			0.33	117	PID	P 1	TSH	+0.11	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1162			0.36	121	MCI	P 1	TSH	+0.11	TSHTSH	1.1		F6623	reso	22H00147	H	600PP	345291
1163	96	46			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
1164			0.12	99	SCI	P 1	TSH	+0.10	TSHTSH	0.3		L2157	reso	22H00133	H	600PP	345329
1165			0.0	0	SCI	1	TSH	+0.10	TSHTSH	0.0		L2157	reso	22H00133	H	600PP	345329
1166			0.11	96	PID	P 1	TSH	+0.10	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
1167	98	46	3.61	183	DNT	P 1	09H	-0.07	TECTEH			N5877	seco	22H00033	H	600UL	331895
1168	100	46	2.17	180	DNG	P 1	03H	+3.66	TECTEH			A9574	seco	22H00032	H	600UL	340972
1169	104	46			NDF		09H	-0.26	09H09H			K5380	prim	22H00184	H	600PP	345332
[illegible]			7.26	181	DNT	P 1	09H	-0.26	TECTEH			A9574	seco	22H00032	H	600UL	340972
	112	46	0.58	75	MBM	5	08H	+3.56	TECTEH			M7006	reso	22H00032	H	600UL	340972
1172	118	46	3.48	176	DNT	P 1	10H	-0.36	TECTEH			N5877	seco	22H00033	H	600UL	331895
1173					NDF		10H	+0.38	10H10H			K5380	prim	22H00184	H	600PP	345332
1174			12.44	181	DNT	P 1	10H	+0.38	TECTEH			N5877	seco	22H00033	H	600UL	331895
1175	120	46	7.69	183	DNG	P 1	09H	+15.13	TECTEH			A9574	seco	22H00032	H	600UL	340972

1176			7.44	176	DNT	P 1	10H	-0.45	TECTEH			A9574	seco	22H00032	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 25

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1177		8.33	181	DNT	P 1	10H	+0.44	TECTEH			A9574	seco	22H00032	H	600UL	340972
1178				NDF		10H	+0.44	10H10H			K5380	prim	22H00184	H	600PP	345332
1179	122 46	2.07	71	MBM	6	03H	+29.48	TECTEH			M7006	reso	22H00033	H	600UL	331895
1180		13.81	181	DNT	P 1	10H	-0.44	TECTEH			N5877	seco	22H00033	H	600UL	331895
1181		13.07	186	DNT	P 1	10H	+0.51	TECTEH			N5877	seco	22H00033	H	600UL	331895
1182	124 46	5.67	174	DNT	P 1	10H	-0.51	TECTEH			A9574	seco	22H00032	H	600UL	340972
1183		2.92	182	DNT	P 1	10H	+0.46	TECTEH			A9574	seco	22H00032	H	600UL	340972
1184	9 47	11.41	182	DNG	P 1	06H	+6.84	TECTEH			D4576	seco	22H00061	H	600UL	340945
1185	21 47	0.79	78	MBM	5	01H	+18.61	TECTEH			N5432	reso	22H00061	H	600UL	340945
1186	33 47	6.88	177	DNG	P 1	01H	+6.85	TECTEH			D4576	seco	22H00061	H	600UL	340945
1187	37 47	1.04	88	MBM	5	01C	+19.19	TECTEH			N5432	reso	22H00061	H	600UL	340945
1188	69 47			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
1189		0.28	37	SAI	1	TSH	+0.63	TSHTSH	0.3		F6623	reso	22H00151	H	600PP	345291
1190		0.15	99	SAI	2	TSH	+0.63	TSHTSH	0.3		F6623	reso	22H00151	H	600PP	345291
1191		0.14	93	PID	4	TSH	+0.63	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
1192	75 47	2.95	183	DNG	P 1	VH	+21.45	TECTEH			F4645	seco	22H00062	H	600UL	340914
1193		1.22	97	MBM	5	TSC	+1.18	TECTEH			C5542	reso	22H00062	H	600UL	340914
	79 47	2.20	182	DNG	P 1	02H	+9.23	TECTEH			F4645	seco	22H00062	H	600UL	340914
[illegible]	97 47			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
1196		0.00	0	MCI	1	TSH	+0.03	TSHTSH	0.0		D8661	reso	22H00132	H	600PP	345291
1197		0.22	83	MCI	P 1	TSH	+0.03	TSHTSH	0.1		C5542	reso	22H00132	H	600PP	345291
1198		0.22	82	PID	P 1	TSH	+0.03	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
1199	99 47	1.13	80	MBM	5	07C	+2.42	TECTEH			M7006	reso	22H00032	H	600UL	340972
1200		1.15	69	MBM	5	07C	+3.44	TECTEH			M7006	reso	22H00032	H	600UL	340972
1201	103 47			NDF		09H	-0.22	09H09H			K5380	prim	22H00184	H	600PP	345332
1202		16.81	187	DNT	P 1	09H	-0.22	TECTEH			C3340	reso	22H00036	H	600UL	340972
1203	105 47			NDF		09H	-0.28	09H09H			S4373	reso	22H00184	H	600PP	345332
1204		14.89	182	DNT	P 1	09H	-0.28	TECTEH			F3453	reso	22H00037	H	600UL	331895
1205		0.35	83	MBM	5	04C	+3.00	TECTEH			F3453	reso	22H00037	H	600UL	331895
1206	109 47	21.32	180	DNT	P 1	09H	-0.11	TECTEH			O8795	seco	22H00037	H	600UL	331895
1207	111 47			NDF		09H	-0.26	09H09H			K5380	prim	22H00184	H	600PP	345332
1208		8.07	186	DNT	P 1	09H	-0.26	TECTEH			C3340	reso	22H00036	H	600UL	340972
1209		2.48	179	DNG	P 1	VH	+2.90	TECTEH			A9574	seco	22H00036	H	600UL	340972
1210	115 47	0.56	85	MBM	5	03H	+37.26	TECTEH			C3340	reso	22H00036	H	600UL	340972
1211		15.46	181	DNT	P 1	09H	-0.26	TECTEH			A9574	seco	22H00036	H	600UL	340972
1212	119 47	4.17	178	DNT	P 1	10H	+0.48	TECTEH			O8795	seco	22H00037	H	600UL	331895
1213	121 47	5.08	171	DNT	P 1	10H	-0.41	TECTEH			A9574	seco	22H00036	H	600UL	340972
1214		7.41	180	DNT	P 1	10H	+0.44	TECTEH			A9574	seco	22H00036	H	600UL	340972
1215		3.83	214	NRC	2	TSC	+0.00	TECTEH			W2096	prim	22H00036	H	600UL	340972
1216	123 47	12.29	174	DNT	P 1	10H	-0.45	TECTEH			A9574	seco	22H00036	H	600UL	340972
1217		15.13	178	DNT	P 1	10H	+0.47	TECTEH			A9574	seco	22H00036	H	600UL	340972
1218		2.69	186	DNT	P 1	10C	-0.48	TECTEH			C3340	reso	22H00036	H	600UL	340972
[illegible]		2.75	177	DNG	P 1	10C	+5.93	TECTEH			A9574	seco	22H00036	H	600UL	340972
	125 47	10.92	177	DNT	P 1	10H	-0.45	TECTEH			A9574	seco	22H00036	H	600UL	340972
1221		9.68	181	DNT	P 1	10H	+0.42	TECTEH			A9574	seco	22H00036	H	600UL	340972
1222	8 48	4.05	177	DNG	P 1	05C	+16.88	TECTEH			F4645	seco	22H00062	H	600UL	340914
1223	32 48	0.57	191	INR	P 1	VM	-2.10	TECTEH			F4645	seco	22H00062	H	600UL	340914
1224		6.19	182	DNT	P 1	VM	+2.04	TECTEH			F4645	seco	22H00062	H	600UL	340914

1225	36	48	2.59	182	DNG	P 1	06H	+15.18	TECTEH			F4645	seco	22H00062	H	600UL		340914

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 26

ROW	COL		VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1226			4.11	183	DNG	P 1	06H	+16.85	TECTEH			F4645	seco	22H00062	H	600UL	340914
1227			6.08	183	DNG	P 1	06H	+18.01	TECTEH			F4645	seco	22H00062	H	600UL	340914
1228			9.56	183	DNG	P 1	06H	+21.18	TECTEH			F4645	seco	22H00062	H	600UL	340914
1229			1.71	178	INR	P 1	VM	-1.48	TECTEH			F4645	seco	22H00062	H	600UL	340914
1230			5.05	181	DNT	P 1	VM	+1.59	TECTEH			F4645	seco	22H00062	H	600UL	340914
1231	40	48	2.96	182	DNG	P 1	VM	+9.81	TECTEH			F4645	seco	22H00062	H	600UL	340914
1232	44	48	2.11	182	DNG	P 1	VM	+12.17	TECTEH			F4645	seco	22H00062	H	600UL	340914
1233	60	48	2.96	181	DNG	P 1	VM	+19.80	TECTEH			F4645	seco	22H00062	H	600UL	340914
1234	72	48	2.78	180	DNG	P 1	07H	+19.64	TECTEH			F4645	seco	22H00062	H	600UL	340914
1235			4.61	180	DNG	P 1	07H	+20.58	TECTEH			F4645	seco	22H00062	H	600UL	340914
1236			4.06	181	DNT	P 1	08C	+1.29	TECTEH			F4645	seco	22H00062	H	600UL	340914
1237			5.96	181	DNG	P 1	07C	+21.31	TECTEH			F4645	seco	22H00062	H	600UL	340914
1238			3.23	180	DNG	P 1	07C	+23.17	TECTEH			F4645	seco	22H00062	H	600UL	340914
1239	96	48			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
1240			0.23	82	PID	P 1	TSH	+0.01	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
1241			0.08	76	SCI	P 1	TSH	+0.01	TSHTSH	0.1		C5542	reso	22H00132	H	600PP	345291
1242			0.00	0	SCI	1	TSH	+0.01	TSHTSH	0.0		D8661	reso	22H00132	H	600PP	345291
	98	48	4.51	175	DNT	P 1	09H	-0.20	TECTEH			A9574	seco	22H00036	H	600UL	340972
	100	48			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
1245			0.11	95	SCI	P 1	TSH	+0.03	TSHTSH	0.1		C5542	reso	22H00132	H	600PP	345291
1246			0.00	0	SCI	1	TSH	+0.03	TSHTSH	0.0		D8661	reso	22H00132	H	600PP	345291
1247			0.12	76	PID	P 1	TSH	+0.03	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
1248	102	48	0.92	80	MBM	5	03C	+27.90	TECTEH			C3340	reso	22H00036	H	600UL	340972
1249	104	48	14.25	180	DNT	P 1	09H	+0.04	TECTEH			O8795	seco	22H00037	H	600UL	331895
1250			2.42	181	DNG	P 1	06C	+9.42	TECTEH			O8795	seco	22H00037	H	600UL	331895
1251	106	48	11.31	181	DNT	P 1	09H	-0.26	TECTEH			A9574	seco	22H00036	H	600UL	340972
1252	114	48	0.72	79	MBM	5	03H	+24.15	TECTEH			C3340	reso	22H00036	H	600UL	340972
1253			16.24	181	DNT	P 1	09H	-0.09	TECTEH			A9574	seco	22H00036	H	600UL	340972
1254	116	48	2.56	175	DNT	P 1	09H	-0.35	TECTEH			F3453	reso	22H00037	H	600UL	331895
1255			0.95	83	MBM	5	05C	+34.99	TECTEH			F3453	reso	22H00037	H	600UL	331895
1256	120	48	1.00	86	MBM	5	04C	+25.16	TECTEH			F3453	reso	22H00037	H	600UL	331895
1257			0.81	73	MBM	6	01C	+7.20	TECTEH			F3453	reso	22H00037	H	600UL	331895
1258			0.57	86	MBM	5	TSC	+8.00	TECTEH			F3453	reso	22H00037	H	600UL	331895
1259	122	48	1.05	231	INR	P 1	10H	-0.36	TECTEH			A9574	seco	22H00036	H	600UL	340972
1260			3.28	187	DNT	P 1	10H	+0.54	TECTEH			A9574	seco	22H00036	H	600UL	340972
1261	124	48	7.00	181	DNT	P 1	10H	-0.52	TECTEH			O8795	seco	22H00037	H	600UL	331895
1262			13.87	181	DNT	P 1	10H	+0.38	TECTEH			O8795	seco	22H00037	H	600UL	331895
1263	126	48	3.12	185	DNT	P 1	10H	-0.40	TECTEH			A9574	seco	22H00036	H	600UL	340972
1264			8.32	180	DNT	P 1	10H	+0.36	TECTEH			A9574	seco	22H00036	H	600UL	340972
1265	9	49	12.20	183	DNG	P 1	06H	+6.78	TECTEH			D4576	seco	22H00061	H	600UL	340945
1266	21	49			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1267			0.18	100	PID	4	TSH	+0.23	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1268			0.22	94	MAI	2	TSH	+0.23	TSHTSH	0.3		F6623	reso	22H00151	H	600PP	345291
			0.24	52	MAI	1	TSH	+0.23	TSHTSH	0.3		F6623	reso	22H00151	H	600PP	345291
1270	33	49	4.96	179	DNG	P 1	DH	+12.62	TECTEH			N5432	reso	22H00061	H	600UL	340945
1271	39	49	5.07	180	DNG	P 1	02H	+15.46	TECTEH			F0075	seco	22H00062	H	600UL	340914
1272			2.38	181	DNG	P 1	02H	+18.39	TECTEH			F0075	seco	22H00062	H	600UL	340914
1273			3.08	181	DNT	P 1	DH	+0.53	TECTEH			F0075	seco	22H00062	H	600UL	340914

1274	61	49	4.91	177	DNG	P 1	07C	+8.15	TECTEH			D4576	seco	22H00061	H	600UL	340945

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 27

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1275	63	49	4.73	181	DNG	P 1	TSH	+5.21	TECTEH			F4645	seco	22H00062	H	600UL	340914
1276			3.54	184	DNG	P 1	TSH	+14.99	TECTEH			F4645	seco	22H00062	H	600UL	340914
1277			3.54	185	DNG	P 1	01H	+4.39	TECTEH			F4645	seco	22H00062	H	600UL	340914
1278			2.02	182	DNG	P 1	03H	+23.26	TECTEH			F4645	seco	22H00062	H	600UL	340914
1279	67	49	30.24	177	DNT	P 1	08C	+1.80	TECTEH			F4645	seco	22H00062	H	600UL	340914
1280	81	49	4.08	187	DNT	P 1	DC	-0.52	TECTEH			F4645	seco	22H00062	H	600UL	340914
1281	83	49			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
1282			0.26	76	MAI	2	TSH	+0.20	TSHTSH	0.3		F6623	reso	22H00151	H	600PP	345291
1283			0.23	75	PID	4	TSH	+0.20	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1284			0.29	31	MAI	1	TSH	+0.20	TSHTSH	0.3		F6623	reso	22H00151	H	600PP	345291
1285	95	49			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
1286			0.26	117	MCI	P 1	TSH	-0.01	TSHTSH	0.2		C5542	reso	22H00132	H	600PP	345291
1287			0.29	107	PID	P 1	TSH	-0.01	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
1288			0.00	0	MCI	1	TSH	-0.01	TSHTSH	0.0		D8661	reso	22H00132	H	600PP	345291
1289	97	49			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
1290			0.44	79	MCI	P 1	TSH	+0.13	TSHTSH	1.15		L2157	reso	22H00133	H	600PP	345329
1291			0.42	78	PID	P 1	TSH	+0.13	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
			0.48	125	MCI	1	TSH	+0.13	TSHTSH	0.8		L2157	reso	22H00133	H	600PP	345329
	101	49	7.15	178	DNT	P 1	09H	+0.02	TECTEH			A9574	seco	22H00036	H	600UL	340972
1294	107	49	21.77	182	DNT	P 1	09H	-0.18	TECTEH			O8795	seco	22H00037	H	600UL	331895
1295	109	49	4.61	184	DNT	P 1	09H	-0.28	TECTEH			C3340	reso	22H00036	H	600UL	340972
1296	113	49	7.41	179	DNT	P 1	09H	-0.17	TECTEH			A9574	seco	22H00036	H	600UL	340972
1297	117	49	8.56	178	DNT	P 1	09H	-0.20	TECTEH			A9574	seco	22H00036	H	600UL	340972
1298			4.07	175	DNG	P 1	VH	+2.72	TECTEH			A9574	seco	22H00036	H	600UL	340972
1299			4.51	172	DNG	P 1	02C	+13.42	TECTEH			A9574	seco	22H00036	H	600UL	340972
1300	119	49	6.75	183	DNT	P 1	10H	+0.07	TECTEH			O8795	seco	22H00037	H	600UL	331895
1301					NDF		10H	+0.07	10H10H			K5380	prim	22H00184	H	600PP	345332
1302	121	49	4.67	176	DNT	P 1	10H	-0.11	TECTEH			A9574	seco	22H00036	H	600UL	340972
1303			3.01	189	DNT	P 1	10H	+0.46	TECTEH			A9574	seco	22H00036	H	600UL	340972
1304			4.61	216	NRC	2	TSC	+0.00	TECTEH			W2096	prim	22H00036	H	600UL	340972
1305	123	49	2.17	184	DNT	P 1	10H	-0.54	TECTEH			F3453	reso	22H00037	H	600UL	331895
1306			5.39	179	DNT	P 1	10H	+0.49	TECTEH			O8795	seco	22H00037	H	600UL	331895
1307					NDF		10H	+0.49	10H10H			K5380	prim	22H00184	H	600PP	345332
1308	125	49	2.32	178	DNG	P 1	TSH	+15.95	TECTEH			A9574	seco	22H00036	H	600UL	340972
1309			2.42	192	DNT	P 1	10H	-0.54	TECTEH			A9574	seco	22H00036	H	600UL	340972
1310			10.29	179	DNT	P 1	10H	+0.49	TECTEH			A9574	seco	22H00036	H	600UL	340972
1311	127	49	5.74	182	DNT	P 1	10H	-0.51	TECTEH			A9574	seco	22H00036	H	600UL	340972
1312			21.25	178	DNT	P 1	10H	+0.40	TECTEH			A9574	seco	22H00036	H	600UL	340972
1313					NDF		10H	+0.41	10H10H			K5380	prim	22H00184	H	600PP	345332
1314	12	50	1.52	93	MBM	5	04H	+9.43	TECTEH			N5432	reso	22H00061	H	600UL	340945
1315	16	50	0.59	58	MBM	5	02C	+11.09	TECTEH			N5432	reso	22H00061	H	600UL	340945
1316			3.71	184	DNG	P 1	TSC	+16.45	TECTEH			D4576	seco	22H00061	H	600UL	340945
1317	20	50	5.02	177	DNG	P 1	TSH	+5.93	TECTEH			D4576	seco	22H00061	H	600UL	340945
	62	50	2.33	175	DNG	P 1	TSH	+32.10	TECTEH			F0075	seco	22H00062	H	600UL	340914
1319			1.02	96	MBM	6	02C	+7.43	TECTEH			C5542	reso	22H00062	H	600UL	340914
1320	64	50	9.39	181	DNG	P 1	07C	+13.05	TECTEH			D4576	seco	22H00061	H	600UL	340945
1321			2.24	184	DNG	P 1	07C	+24.85	TECTEH			D4576	seco	22H00061	H	600UL	340945
1322	68	50	2.13	180	DNT	P 1	DH	+0.64	TECTEH			D4576	seco	22H00061	H	600UL	340945

1323			1.13	67	MBM	5	DH	+10.22		TECTEH				N5432	reso	22H00061	H	600UL	340945

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 28

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1324	70	50	5.21	179	DNG	P 1	07H	+8.95		TECTEH			F0075	seco	22H00062	H	600UL	340914
1325	74	50	2.63	179	DNG	P 1	08H	+1.79		TECTEH			F0075	seco	22H00062	H	600UL	340914
1326	100	50	14.74	179	DNT	P 1	09H	-0.02		TECTEH			A9574	seco	22H00036	H	600UL	340972
1327			0.26	126	11	P 2	VH	-1.61		TECTEH			A9574	seco	22H00036	H	600UL	340972
1328	106	50	2.68	181	DNG	P 1	08H	+18.74		TECTEH			O8795	seco	22H00037	H	600UL	331895
1329			3.18	179	DNT	P 1	09H	-0.41		TECTEH			O8795	seco	22H00037	H	600UL	331895
1330	108	50	4.65	177	DNT	P 1	09H	-0.33		TECTEH			A9574	seco	22H00036	H	600UL	340972
1331	110	50	8.70	184	DNT	P 1	09H	+0.00		TECTEH			O8795	seco	22H00037	H	600UL	331895
1332	112	50	27.36	179	DNT	P 1	09H	-0.17		TECTEH			A9574	seco	22H00036	H	600UL	340972
1333	116	50	10.99	357	INR	P 1	08H	+22.08		TECTEH			A9574	seco	22H00036	H	600UL	340972
1334			18.12	178	DNT	P 1	09H	-0.02		TECTEH			A9574	seco	22H00036	H	600UL	340972
1335	118	50	1.06	79	MBM	5	04H	+5.41		TECTEH			F3453	reso	22H00037	H	600UL	331895
1336			2.62	175	DNT	P 1	09H	+0.25		TECTEH			F3453	reso	22H00037	H	600UL	331895
1337	120	50	1.44	74	MBM	6	05H	+13.07		TECTEH			C3340	reso	22H00036	H	600UL	340972
1338			6.64	177	DNT	P 1	10H	-0.07		TECTEH			A9574	seco	22H00036	H	600UL	340972
1339	122	50	6.62	186	DNT	P 1	10H	+0.00		TECTEH			O8795	seco	22H00037	H	600UL	331895
1340	124	50	3.03	173	DNT	P 1	10H	-0.29		TECTEH			A9574	seco	22H00036	H	600UL	340972
			3.23	183	DNT	P 1	10H	+0.55		TECTEH			A9574	seco	22H00036	H	600UL	340972
	126	50	3.70	180	DNG	P 1	07H	+1.60		TECTEH			O8795	seco	22H00037	H	600UL	331895
1343			2.38	185	DNT	P 1	10H	+0.00		TECTEH			O8795	seco	22H00037	H	600UL	331895
1344			3.79	184	DNT	P 1	10H	+0.50		TECTEH			O8795	seco	22H00037	H	600UL	331895
1345	128	50	13.04	176	DNT	P 1	10H	+0.40		TECTEH			A9574	seco	22H00036	H	600UL	340972
1346			2.70	177	DNG	P 1	DH	+16.97		TECTEH			A9574	seco	22H00036	H	600UL	340972
1347	5	51	1.76	88	MBM	6	04H	-0.67		06HTEH			A9608	reso	22H00082	H	600UL	340912
1348	9	51	9.78	182	DNG	P 1	06H	+6.94		TECTEH			N2574	seco	22H00061	H	600UL	340945
1349			0.79	49	DSI	P 1	VM	-1.72		TECTEH			N5432	reso	22H00061	H	600UL	340945
1350			0.27	77	VOL	2	VM	-1.32		06H06C			C3340	reso	22H00219	H	5602C	340987
1351	19	51	2.31	222	PVN	2	TSC	-5.23	TO+4.29	TSCTSC			B4052	prim	22C00051	C	600PP	345352
1352	23	51	0.97	90	MBM	5	05H	+12.53		TECTEH			N5432	reso	22H00061	H	600UL	340945
1353	27	51	0.62	71	MBM	6	05C	+5.02		TECTEH			C5542	reso	22H00062	H	600UL	340914
1354	33	51	5.20	182	DNG	P 1	DH	+12.32		TECTEH			N2574	seco	22H00061	H	600UL	340945
1355			17.79	177	DNT	P 1	VM	-1.47		TECTEH			N2574	seco	22H00061	H	600UL	340945
1356			42.44	179	DNT	P 1	VM	+0.69		TECTEH			N2574	seco	22H00061	H	600UL	340945
1357			3.59	176	DNG	P 1	06C	+22.25		TECTEH			N2574	seco	22H00061	H	600UL	340945
1358	37	51	2.68	179	DNT	P 1	VM	-2.01		TECTEH			N2574	seco	22H00061	H	600UL	340945
1359	39	51	0.42	82	MBM	5	06H	+13.94		TECTEH			C5542	reso	22H00062	H	600UL	340914
1360	61	51	0.30	34	11	P 2	DH	+1.47		TECTEH	LOCOK		S4373	reso	22H00061	H	600UL	340945
1361			0.48	116	17	P 2	DH	+1.79		TECTEH			N5432	reso	22H00061	H	600UL	340945
1362			2.47	179	DNG	P 1	DH	+4.17		TECTEH			D4576	seco	22H00061	H	600UL	340945
1363	73	51	0.41	92	MBM	5	VM	+8.51		TECTEH			N5432	reso	22H00061	H	600UL	340945
1364	85	51			TBS					TECTEH			D3858	reso	22H00044	H	600UL	331892
1365			0.29	107	PID	P 1	TSH	+0.19		TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1366			0.36	54	SCI	1	TSH	+0.19		TSHTSH	0.3		N5432	reso	22H00152	H	600PP	345329
			0.32	102	SCI	P 1	TSH	+0.19		TSHTSH	0.5		N5432	reso	22H00152	H	600PP	345329
1368			0.12	32	SAI	1	TSH	+0.58		TSHTSH	0.2		N5432	reso	22H00152	H	600PP	345329
1369			0.21	114	SAI	2	TSH	+0.58		TSHTSH	0.4		N5432	reso	22H00152	H	600PP	345329
1370			0.53	91	MBM	5	02C	+16.08		TECTEH			N5432	reso	22H00061	H	600UL	340945
1371	97	51			TBS					TECTEH			D3858	reso	22H00044	H	600UL	331892

1372				0.13	127	SAI	2	TSH	+0.29	TSHTSH	0.4			D8661	reso	22H00132	H	600PP	345291

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 29

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1373		0.12	138	PID	4	TSH	+0.29	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
1374		0.00	0	SAI	1	TSH	+0.29	TSHTSH	0.0		D8661	reso	22H00132	H	600PP	345291
1375		10.13	184	DNG	P 1	08H	+19.83	TECTEH			O8795	seco	22H00037	H	600UL	331895
1376		3.65	183	DNG	P 1	08H	+21.40	TECTEH			O8795	seco	22H00037	H	600UL	331895
1377		2.45	194	DNT	P 1	09H	+0.54	TECTEH			F3453	reso	22H00037	H	600UL	331895
1378		2.87	185	DNT	P 1	09C	+0.50	TECTEH			O8795	seco	22H00037	H	600UL	331895
1379		2.41	183	DNG	P 1	08C	+2.20	TECTEH			O8795	seco	22H00037	H	600UL	331895
1380		3.51	183	DNG	P 1	08C	+11.40	TECTEH			O8795	seco	22H00037	H	600UL	331895
1381		6.32	183	DNG	P 1	08C	+12.39	TECTEH			O8795	seco	22H00037	H	600UL	331895
1382		3.04	183	DNG	P 1	08C	+19.26	TECTEH			O8795	seco	22H00037	H	600UL	331895
1383		2.73	185	DNG	P 1	08C	+19.89	TECTEH			O8795	seco	22H00037	H	600UL	331895
1384	99	51	15.50	182	DNT	P 1	09H	+0.00	TECTEH			A9574	seco	22H00036	H	600UL	340972
1385	101	51	1.66	76	MBM	5	08H	+6.83	TECTEH			F3453	reso	22H00037	H	600UL	331895
1386			26.78	185	DNT	P 1	09H	+0.00	TECTEH			O8795	seco	22H00037	H	600UL	331895
1387			1.10	69	MBM	5	03C	+27.59	TECTEH			F3453	reso	22H00037	H	600UL	331895
1388			1.45	91	MBM	5	03C	+32.69	TECTEH			F3453	reso	22H00037	H	600UL	331895
1389	105	51	2.07	181	DNT	P 1	09H	-0.30	TECTEH			F3453	reso	22H00037	H	600UL	331895
	109	51	10.35	183	DNT	P 1	09H	-0.20	TECTEH			F3453	reso	22H00037	H	600UL	331895
					NDF		09H	-0.20	09H09H			K5380	prim	22H00184	H	600PP	345332
1392	111	51	19.16	180	DNT	P 1	09H	-0.24	TECTEH			A9574	seco	22H00036	H	600UL	340972
1393	113	51	20.55	185	DNT	P 1	09H	-0.04	TECTEH			O8795	seco	22H00037	H	600UL	331895
1394	119	51	5.30	177	DNT	P 1	09H	+0.05	TECTEH			A9574	seco	22H00036	H	600UL	340972
1395	121	51	5.86	183	DNT	P 1	10H	+0.17	TECTEH			O8795	seco	22H00037	H	600UL	331895
1396			2.03	184	DNG	P 1	01C	+35.31	TECTEH			O8795	seco	22H00037	H	600UL	331895
1397			5.88	21	NRC	2	TSC	+0.00	TECTEH			F3453	reso	22H00037	H	600UL	331895
1398	123	51	3.50	178	DNT	P 1	10H	-0.22	TECTEH			A9574	seco	22H00036	H	600UL	340972
1399			2.51	179	DNG	P 1	10C	+1.44	TECTEH			A9574	seco	22H00036	H	600UL	340972
1400			3.88	180	DNG	P 1	09C	+7.51	TECTEH			A9574	seco	22H00036	H	600UL	340972
1401	125	51	2.29	184	DNT	P 1	10H	+0.50	TECTEH			F3453	reso	22H00037	H	600UL	331895
1402			2.64	182	DNT	P 1	10C	+0.30	TECTEH			O8795	seco	22H00037	H	600UL	331895
1403	129	51	6.41	182	DNT	P 1	10H	+0.42	TECTEH			A9574	seco	22H00036	H	600UL	340972
1404	2	52	0.65	66	MBM	5	TSH	+14.02	06HTEH			M7006	reso	22H00083	H	600UL	340943
1405			20.11	352	INR	P 1	06C	+1.51	06CTEC			D3858	reso	22C00059	C	600CS	341611
1406	4	52	1.01	79	MBM	5	04C	+12.15	06HTEC			C5542	reso	22C00058	C	600CS	341219
1407	10	52			NDF		DH	+0.09	05H06C			T6956	prim	22H00220	H	5602C	340987
1408			0.66	137	DSI	P 1	DH	+0.09	TECTEH			I3805	seco	22H00098	H	600UL	340929
1409	12	52	3.25	180	DNG	P 1	03H	+33.13	TECTEH			N2574	seco	22H00061	H	600UL	340945
1410			11.45	182	DNG	P 1	06H	+7.93	TECTEH			N2574	seco	22H00061	H	600UL	340945
1411	14	52	1.73	80	MBM	5	05C	+4.11	TECTEH			N5432	reso	22H00061	H	600UL	340945
1412			0.77	85	MBM	5	05C	+16.62	TECTEH			N5432	reso	22H00061	H	600UL	340945
1413			0.97	79	MBM	5	05C	+20.20	TECTEH			N5432	reso	22H00061	H	600UL	340945
1414			1.44	83	MBM	5	05C	+22.99	TECTEH			N5432	reso	22H00061	H	600UL	340945
[illegible]			1.17	75	MBM	5	05C	+24.50	TECTEH			N5432	reso	22H00061	H	600UL	340945
			1.89	93	MBM	5	04C	+10.23	TECTEH			N5432	reso	22H00061	H	600UL	340945
1417			1.52	87	MBM	5	04C	+14.74	TECTEH			N5432	reso	22H00061	H	600UL	340945
1418			0.79	94	MBM	5	04C	+19.49	TECTEH			N5432	reso	22H00061	H	600UL	340945
1419			1.17	95	MBM	5	04C	+23.61	TECTEH			N5432	reso	22H00061	H	600UL	340945
1420			1.33	91	MBM	5	03C	+35.26	TECTEH			N5432	reso	22H00061	H	600UL	340945

1421	20	52			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 30

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1422		0.12	99	SCI	P 1	TSH	+0.09	TSHTSH	0.3		N5432	reso	22H00152	H	600PP	345329
1423		0.11	121	PID	P 1	TSH	+0.09	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1424		0.00	0	SCI	1	TSH	+0.09	TSHTSH	0.0		N5432	reso	22H00152	H	600PP	345329
1425	22	52		TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1426		0.12	113	SAI	2	TSH	+0.19	TSHTSH	0.2		F6623	reso	22H00151	H	600PP	345291
1427		0.09	58	SAI	1	TSH	+0.19	TSHTSH	0.2		F6623	reso	22H00151	H	600PP	345291
1428		0.11	110	PID	4	TSH	+0.19	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1429	24	52		TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
1430		0.10	97	SCI	P 1	TSH	+0.07	TSHTSH	0.2		F6623	reso	22H00151	H	600PP	345291
1431		0.11	37	SCI	1	TSH	+0.07	TSHTSH	0.2		F6623	reso	22H00151	H	600PP	345291
1432		0.13	95	SAI	1	TSH	+0.22	TSHTSH	0.2		F6623	reso	22H00151	H	600PP	345291
1433		0.19	95	SAI	2	TSH	+0.22	TSHTSH	0.3		F6623	reso	22H00151	H	600PP	345291
1434		0.13	75	PID	4	TSH	+0.22	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1435	28	52		TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1436		0.14	99	PID	4	TSH	+0.19	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1437		0.00	0	SAI	1	TSH	+0.19	TSHTSH	0.0		C5542	reso	22H00166	H	600PP	345329
1438		0.15	107	SAI	2	TSH	+0.19	TSHTSH	0.2		C5542	reso	22H00166	H	600PP	345329
	32	52	5.29	182	DNT	P 1	VM	+2.06	TECTEH			F0075	seco	22H00062	H	600UL	340914
	34	52	2.51	178	DNG	P 1	TSC	+21.45	TECTEH			N2574	seco	22H00061	H	600UL	340945
1441	46	52		TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
1442		0.38	60	MCI	1	TSH	-0.19	TSHTSH	0.6	PWSCC	L2157	reso	22H00165	H	600PP	345290
1443		0.73	19	PID	P 1	TSH	-0.19	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1444		0.28	24	MCI	P 1	TSH	-0.19	TSHTSH	0.4	PWSCC	L2157	reso	22H00165	H	600PP	345290
1445	48	52	3.33	179	DNG	P 1	04H	+18.85	TECTEH			I3805	seco	22H00079	H	600UL	340943
1446	56	52	0.44	40	18	P 2	DC	-1.72	TECTEH	LOCOK		S4373	reso	22H00062	H	600UL	340914
1447	60	52	3.62	182	DNG	P 1	VM	+20.04	TECTEH			F0075	seco	22H00062	H	600UL	340914
1448	66	52	1.65	183	INR	P 1	TSC	+21.08	TECTEH			I3805	seco	22H00098	H	600UL	340929
1449	72	52	1.59	183	INR	P 1	08C	+3.56	TECTEH			F0075	seco	22H00062	H	600UL	340914
1450			3.23	180	DNG	P 1	08C	+10.75	TECTEH			F0075	seco	22H00062	H	600UL	340914
1451	82	52	2.38	182	DNG	P 1	07H	+10.73	TECTEH			N2574	seco	22H00061	H	600UL	340945
1452	86	52		TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
1453			0.27	79	SCI	1	TSH	+0.16	TSHTSH	0.2		N5432	reso	22H00152	H	600PP	345329
1454			0.41	99	PID	P 1	TSH	+0.16	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1455			0.41	101	SCI	P 1	TSH	+0.16	TSHTSH	0.7		N5432	reso	22H00152	H	600PP	345329
1456			0.17	126	MAI	2	TSH	+0.53	TSHTSH	0.6		N5432	reso	22H00152	H	600PP	345329
1457			0.00	0	MAI	1	TSH	+0.53	TSHTSH	0.0		N5432	reso	22H00152	H	600PP	345329
1458			0.64	82	MBM	5	01H	+30.42	TECTEH			N5432	reso	22H00061	H	600UL	340945
1459	94	52	7.61	179	DNT	P 1	09H	+0.04	TECTEH			A9574	seco	22H00036	H	600UL	340972
1460	96	52	2.52	181	DNT	P 1	08H	+0.74	TECTEH			A9574	seco	22H00036	H	600UL	340972
1461			3.75	179	DNG	P 1	08H	+6.18	TECTEH			A9574	seco	22H00036	H	600UL	340972
1462			1.99	182	INR	P 1	08H	+13.69	TECTEH			A9574	seco	22H00036	H	600UL	340972
1463			15.52	177	DNT	P 1	09H	-0.02	TECTEH			A9574	seco	22H00036	H	600UL	340972
[illegible]	98	52		TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
			0.14	114	SAI	1	TSH	+0.17	TSHTSH	0.2		C5542	reso	22H00132	H	600PP	345291
1466			0.16	94	PID	4	TSH	+0.17	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
1467			0.16	106	SAI	2	TSH	+0.17	TSHTSH	0.2		C5542	reso	22H00132	H	600PP	345291
1468	104	52	31.15	184	DNT	P 1	09H	+0.07	TECTEH			O8795	seco	22H00037	H	600UL	331895
1469	106	52	1.36	179	INR	P 1	09H	-0.33	TECTEH			A9574	seco	22H00036	H	600UL	340972

1470	112	52	6.51	185	DNT	P 1	09H	-0.11	TECTEH				O8795	seco	22H00037	H	600UL	331895

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 31

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1471					INF		09C	+16.29	TECTEH	HR		F3453	reso	22H00037	H	600UL	331895
1472					INF		09C	+17.00	TECTEH	HR		F3453	reso	22H00037	H	600UL	331895
1473			3.55	185	DNG	P 1	09C	+18.01	TECTEH			F3453	reso	22H00037	H	600UL	331895
1474	114	52	1.55	70	MBM	6	07H	+25.08	TECTEH			C3340	reso	22H00036	H	600UL	340972
1475			4.55	186	DNT	P 1	09H	-0.22	TECTEH			C3340	reso	22H00036	H	600UL	340972
1476	116	52	6.65	182	DNT	P 1	09H	-0.24	TECTEH			O8795	seco	22H00037	H	600UL	331895
1477	120	52	3.94	178	INR	P 1	10C	+2.59	TECTEH			A9574	seco	22H00036	H	600UL	340972
1478	122	52	0.72	67	MBM	5	06H	+5.91	TECTEH			C3340	reso	22H00036	H	600UL	340972
1479			11.27	178	DNT	P 1	09H	+0.02	TECTEH			A9574	seco	22H00036	H	600UL	340972
1480			2.15	171	DNT	P 1	10H	+0.09	TECTEH			A9574	seco	22H00036	H	600UL	340972
1481			0.78	176	INR	P 1	10C	+0.27	TECTEH			A9574	seco	22H00036	H	600UL	340972
1482	126	52	1.73	182	INR	P 1	09H	+0.35	TECTEH			F3453	reso	22H00037	H	600UL	331895
1483	128	52	3.97	172	DNT	P 1	10H	+0.07	TECTEH			A9574	seco	22H00036	H	600UL	340972
1484	19	53			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
1485			0.10	114	PID	P 1	TSH	+0.12	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1486			0.00	0	MCI	1	TSH	+0.12	TSHTSH	0.0		C5542	reso	22H00162	H	600PP	345329
1487			0.10	95	MCI	P 1	TSH	+0.12	TSHTSH	0.1		C5542	reso	22H00162	H	600PP	345329
	21	53			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
			0.18	91	SCI	P 1	TSH	+0.05	TSHTSH	0.5		L2157	reso	22H00161	H	600PP	345291
1490			0.09	134	SCI	1	TSH	+0.05	TSHTSH	0.3		L2157	reso	22H00161	H	600PP	345291
1491			0.13	125	PID	P 1	TSH	+0.05	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1492	23	53	1.18	89	MBM	6	03H	+14.61	TECTEH			F3453	reso	22H00068	H	600UL	340927
1493			1.25	69	MBM	6	03H	+16.40	TECTEH			F3453	reso	22H00068	H	600UL	340927
1494			0.63	85	MBM	5	03H	+17.85	TECTEH			F3453	reso	22H00068	H	600UL	340927
1495	25	53	0.36	151	14	P 2	02C	+1.05	TECTEH			N2574	seco	22H00067	H	600UL	340945
1496	35	53			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1497			0.00	0	SAI	1	TSH	+1.12	TSHTSH	0.0		D8661	reso	22H00162	H	600PP	345329
1498			0.14	122	PID	4	TSH	+1.12	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1499			0.09	120	SAI	2	TSH	+1.12	TSHTSH	0.2		D8661	reso	22H00162	H	600PP	345329
1500	37	53	4.05	180	DNT	P 1	VM	-1.28	TECTEH			N2574	seco	22H00067	H	600UL	340945
1501	39	53	0.65	77	MBM	5	TSH	+20.94	TECTEH			C5542	reso	22H00079	H	600UL	340943
1502			0.63	77	MBM	5	04H	+19.47	TECTEH			C5542	reso	22H00079	H	600UL	340943
1503	43	53	1.10	79	MBM	5	03C	+11.15	TECTEH			C5542	reso	22H00079	H	600UL	340943
1504	45	53	3.29	175	DNG	P 1	TSC	+10.10	TECTEH			N5877	seco	22H00078	H	600UL	331969
1505	51	53	2.40	180	DNT	P 1	VM	-1.50	TECTEH			I3805	seco	22H00079	H	600UL	340943
1506	57	53	5.58	179	DNG	P 1	04H	+10.07	TECTEH			N2574	seco	22H00067	H	600UL	340945
1507			3.01	178	DNG	P 1	07C	+5.69	TECTEH			N2574	seco	22H00067	H	600UL	340945
1508	67	53	4.49	182	DNG	P 1	07C	+11.94	TECTEH			I3805	seco	22H00068	H	600UL	340927
1509			2.75	189	DNG	P 1	07C	+12.47	TECTEH			I3805	seco	22H00068	H	600UL	340927
1510	75	53	3.38	182	DNG	P 1	07H	+24.68	TECTEH			I3805	seco	22H00068	H	600UL	340927
1511	79	53	3.35	184	DNG	P 1	06H	+2.71	TECTEH			I3805	seco	22H00068	H	600UL	340927
1512	83	53	3.94	179	DNG	P 1	07H	+13.80	TECTEH			I3805	seco	22H00068	H	600UL	340927
1513	95	53			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
			0.40	97	PID	P 1	TSH	+0.08	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
1515			0.42	96	MCI	P 1	TSH	+0.08	TSHTSH	0.2		C5542	reso	22H00132	H	600PP	345291
1516			0.00	0	MCI	1	TSH	+0.08	TSHTSH	0.0		D8661	reso	22H00132	H	600PP	345291
1517			2.23	174	DNG	P 1	03H	+13.76	TECTEH			A9574	seco	22H00036	H	600UL	340972
1518			10.53	177	DNT	P 1	09H	+0.18	TECTEH			A9574	seco	22H00036	H	600UL	340972

1519			4.85	179	DNG	P 1	TSC	+9.57	TECTEH			A9574	seco	22H00036	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 32

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1520	97	53			TBS			TECTEH			D3858	reso	22H00044	H	600UL	331892
1521			0.09	141	SCI	1	TSH +0.08	TSHTSH	0.5		L2157	reso	22H00133	H	600PP	345329
1522			0.13	120	SCI	P 1	TSH +0.08	TSHTSH	0.3		L2157	reso	22H00133	H	600PP	345329
1523			0.17	114	PID	P 1	TSH +0.08	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
1524	99	53	51.85	179	DNT	P 1	09H +0.00	TECTEH			A9574	seco	22H00036	H	600UL	340972
1525					NDF	P 1	09H +-0.00	09H09H			K5380	prim	22H00184	H	600PP	345332
1526			1.20	181	INR	P 1	09C +3.31	TECTEH			A9574	seco	22H00036	H	600UL	340972
1527	101	53	93.98	182	DNT	P 1	09H -0.18	TECTEH			O8795	seco	22H00037	H	600UL	331895
1528					NDF		09H -0.18	09H09H			T2170	seco	22H00197	H	600PP	345329
1529			0.33	121	16	P 2	DC +1.10	TECTEH	LOCOK		D3858	reso	22H00037	H	600UL	331895
1530	103	53			NDF		09H -0.02	09H09H			K5380	prim	22H00184	H	600PP	345332
1531			108.8	177	DNT	P 1	09H -0.02	TECTEH			A9574	seco	22H00036	H	600UL	340972
1532	105	53	1.82	184	INR	P 1	01H +31.63	TECTEH			O8795	seco	22H00037	H	600UL	331895
1533					NDF		09H +0.02	09H09H			K5380	prim	22H00184	H	600PP	345332
1534			82.57	182	DNT	P 1	09H +0.02	TECTEH			O8795	seco	22H00037	H	600UL	331895
1535	111	53			NDF		09H -0.17	09H09H			K5380	prim	22H00184	H	600PP	345332
1536			6.15	180	DNT	P 1	09H -0.17	TECTEH			A9574	seco	22H00036	H	600UL	340972
			3.04	172	DNG	P 1	02C +23.61	TECTEH			A9574	seco	22H00036	H	600UL	340972
	117	53	3.30	184	DNT	P 1	10H -0.14	TECTEH			O8795	seco	22H00037	H	600UL	331895
1539	119	53	3.31	172	DNG	P 1	03H +10.68	TECTEH			A9574	seco	22H00036	H	600UL	340972
1540			9.65	176	DNT	P 1	09H -0.24	TECTEH			A9574	seco	22H00036	H	600UL	340972
1541	121	53	7.19	185	DNT	P 1	09H +0.13	TECTEH			O8795	seco	22H00037	H	600UL	331895
1542			4.39	184	DNT	P 1	10H +0.13	TECTEH			O8795	seco	22H00037	H	600UL	331895
1543			0.43	4	IDM	4	TSC -1.80	TECTSC			M2655	seco	22C00071	C	600PP	345298
1544			5.08	22	NRC	2	TSC +0.00	TECTEH			F3453	reso	22H00037	H	600UL	331895
1545	125	53	0.66	77	MBM	5	05H +13.87	TECTEH			F3453	reso	22H00037	H	600UL	331895
1546	127	53	2.60	182	DNT	P 1	09H +0.47	TECTEH			A9574	seco	22H00036	H	600UL	340972
1547			2.02	179	DNT	P 1	10H +0.55	TECTEH			A9574	seco	22H00036	H	600UL	340972
1548	129	53	0.88	63	MBM	5	TSH +5.41	TECTEH			F3453	reso	22H00037	H	600UL	331895
1549			3.02	185	DNT	P 1	10H +0.00	TECTEH			O8795	seco	22H00037	H	600UL	331895
1550	2	54	2.15	352	INR	P 1	06C +2.48	06CTEC			D3858	reso	22C00059	C	600CS	341611
1551	8	54	2.83	176	DNG	P 1	TSH +9.24	TECTEH			I3805	seco	22H00068	H	600UL	340927
1552			1.17	57	MBM	6	01H +14.16	TECTEH			F3453	reso	22H00068	H	600UL	340927
1553	16	54	4.07	182	DNT	P 1	06H -0.33	TECTEH			I3805	seco	22H00068	H	600UL	340927
1554			0.39	78	MBM	5	06H +7.90	TECTEH			F3453	reso	22H00068	H	600UL	340927
1555	30	54	3.10	180	DNT	P 1	06H -0.39	TECTEH			N2574	seco	22H00067	H	600UL	340945
1556			8.94	180	DNG	P 1	VM +2.63	TECTEH			N2574	seco	22H00067	H	600UL	340945
1557	32	54			TBP			TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1558			0.0	0	MAI	1	TSH +0.18	TSHTSH	0.0		L2157	reso	22H00161	H	600PP	345291
1559			0.11	110	MAI	2	TSH +0.18	TSHTSH	0.4		L2157	reso	22H00161	H	600PP	345291
1560			0.27	95	SAI	2	TSH +0.64	TSHTSH	0.2		L2157	reso	22H00161	H	600PP	345291
1561			0.29	79	SAI	1	TSH +0.64	TSHTSH	0.3		L2157	reso	22H00161	H	600PP	345291
[illegible]			0.20	113	PID	4	TSH +0.64	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
	40	54	3.40	183	DNG	P 1	VM +9.70	TECTEH			I3805	seco	22H00079	H	600UL	340943
1564	92	54	0.44	74	MBM	5	04H +25.67	TECTEH			F3453	reso	22H00037	H	600UL	331895
1565			2.29	183	DNT	P 1	09H -0.13	TECTEH			F3453	reso	22H00037	H	600UL	331895
1566			2.31	175	DNT	P 1	09C +0.20	TECTEH			F3453	reso	22H00037	H	600UL	331895
1567	94	54	6.99	180	DNT	P 1	09H -0.02	TECTEH			A9574	seco	22H00036	H	600UL	340972

1568			3.26	178	DNG	P 1	07C	+8.35		TECTEH			A9574	seco	22H00036	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 33

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT		UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1569	98	54	1.73	82	MBM	5	02C	+21.00		TECTEH			F3453	reso	22H00037	H	600UL	331895
1570	100	54			NDF		09H	-0.02		09H09H			M9715	seco	22H00187	H	600PP	345332
1571			80.61	178	DNT	P 1	09H	-0.02		TECTEH			A9574	seco	22H00036	H	600UL	340972
1572	102	54	130.4	182	DNT	P 1	09H	+0.02		TECTEH			O8795	seco	22H00037	H	600UL	331895
1573					NDF		09H	+0.02		09H09H			M9715	seco	22H00187	H	600PP	345332
1574			0.61	94	MBM	5	04C	+18.45		TECTEH			F3453	reso	22H00037	H	600UL	331895
1575	104	54	71.77	178	DNT	P 1	09H	+0.02		TECTEH			A9574	seco	22H00036	H	600UL	340972
1576					NDF		09H	+0.02		09H09H			B6768	prim	22H00187	H	600PP	345332
1577	110	54			NDF		09H	+0.29		09H09H			K5380	prim	22H00184	H	600PP	345332
1578			68.95	183	DNT	P 1	09H	+0.29		TECTEH			O8795	seco	22H00037	H	600UL	331895
1579	112	54	20.87	177	DNT	P 1	09H	-0.11		TECTEH			A9574	seco	22H00036	H	600UL	340972
1580	114	54	41.72	184	DNT	P 1	09H	-0.11		TECTEH			O8795	seco	22H00037	H	600UL	331895
1581	118	54	0.43	77	MBM	5	06H	+10.33		TECTEH			F3453	reso	22H00037	H	600UL	331895
1582			0.38	64	MBM	5	06H	+17.91		TECTEH			F3453	reso	22H00037	H	600UL	331895
1583	120	54	10.75	182	DNT	P 1	09H	-0.24		TECTEH			A9574	seco	22H00036	H	600UL	340972
~~1584~~	~~122~~	~~54~~	~~8.99~~	~~183~~	~~DNT~~	~~P 1~~	~~09H~~	~~+0.09~~		~~TECTEH~~			~~O8795~~	~~seco~~	~~22H00037~~	~~H~~	~~600UL~~	~~331895~~
1585					NDF		09H	+0.09		09H09H			F6623	reso	22H00184	H	600PP	345332
	124	54	2.96	179	DNT	P 1	09H	-0.02		TECTEH			A9574	seco	22H00036	H	600UL	340972
.	126	54	4.97	176	DNT	P 1	09H	+0.49		TECTEH			O8795	seco	22H00037	H	600UL	331895
1588	130	54	4.27	184	DNT	P 1	10H	+0.07		TECTEH			O8795	seco	22H00037	H	600UL	331895
1589	7	55	2.38	86	MBM	5	01H	+20.23		TECTEH			M1680	reso	22H00098	H	600UL	340929
1590			1.27	85	MBM	5	01H	+22.07		TECTEH			M1680	reso	22H00098	H	600UL	340929
1591	29	55			TBP					TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1592			0.28	43	MAI	1	TSH	+0.49		TSHTSH	0.4		L2157	reso	22H00161	H	600PP	345291
1593			0.23	77	PID	4	TSH	+0.49		TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1594			0.25	83	MAI	2	TSH	+0.49		TSHTSH	0.6		L2157	reso	22H00161	H	600PP	345291
1595	33	55			TBP					TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1596			0.16	118	SAI	2	TSH	+0.61		TSHTSH	0.3		L2157	reso	22H00161	H	600PP	345291
1597			0.17	62	SAI	1	TSH	+0.61		TSHTSH	0.3		L2157	reso	22H00161	H	600PP	345291
1598			0.18	112	PID	4	TSH	+0.61		TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1599	41	55			NDF		06C	+17.73		06C07C			T6956	prim	22C00091	C	600PP	345343
1600			0.55	40	NQI	5	06C	+17.73		TECTEH			C5542	reso	22H00076	H	600UL	340945
1601	57	55	3.57	182	DNT	P 1	03H	+0.34		TECTEH			N5877	seco	22H00076	H	600UL	340945
1602	67	55	0.60	80	MBM	5	01H	+7.35		TECTEH			M1680	reso	22H00098	H	600UL	340929
1603	75	55	5.15	180	DNG	P 1	07H	+12.93		TECTEH			N5877	seco	22H00066	H	600UL	340914
1604			4.66	185	INR	P 1	VH	+2.33		TECTEH			N5877	seco	22H00066	H	600UL	340914
1605	79	55	5.68	178	INR	P 1	05C	-1.53	TO+8.40	TECTEH			F3453	reso	22H00066	H	600UL	340914
1606			5.36	181	INR	P 1	04C	-1.36		TECTEH			F3453	reso	22H00066	H	600UL	340914
1607			3.28	180	INR	P 1	04C	-0.82		TECTEH			F3453	reso	22H00066	H	600UL	340914
1608			6.31	178	INR	P 1	03C	+24.92	TO+37.01	TECTEH			S4373	reso	22H00066	H	600UL	340914
1609			3.07	183	INR	P 1	02C	+0.69	TO+35.38	TECTEH			F3453	reso	22H00066	H	600UL	340914
1610			4.32	180	INR	P 1	01C	-0.37	TO+35.97	TECTEH			F3453	reso	22H00066	H	600UL	340914
[illegible]	85	55	1.41	78	MBM	6	03H	+19.89		TECTEH			F3453	reso	22H00065	H	600UL	340945
	89	55	1.12	86	MBM	5	05C	+11.02		TECTEH			F3453	reso	22H00065	H	600UL	340945
1613	93	55	8.55	185	DNT	P 1	09H	-0.02		TECTEH			O8795	seco	22H00037	H	600UL	331895
1614	95	55	10.83	181	DNT	P 1	09H	+0.04		TECTEH			A9574	seco	22H00036	H	600UL	340972
1615	97	55	2.34	183	DNG	P 1	06H	+13.60		TECTEH			F3453	reso	22H00037	H	600UL	331895
1616			3.12	182	DNG	P 1	06H	+21.95		TECTEH			F3453	reso	22H00037	H	600UL	331895

1617			3.99	183	DNG	P 1	07H	+24.09	TECTEH			F3453	reso	22H00037	H	600UL	331895

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 34

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1618			4.21	185	DNT	P 1	08H	-0.22	TECTEH			F3453	reso	22H00037	H	600UL	331895
1619			3.42	185	DNG	P 1	08H	+3.09	TECTEH			F3453	reso	22H00037	H	600UL	331895
1620			5.83	183	DNG	P 1	08H	+4.80	TECTEH			F3453	reso	22H00037	H	600UL	331895
1621			5.40	185	DNG	P 1	08H	+7.40	TECTEH			F3453	reso	22H00037	H	600UL	331895
1622			3.83	185	DNG	P 1	08H	+8.37	TECTEH			F3453	reso	22H00037	H	600UL	331895
1623			2.41	188	DNG	P 1	08H	+8.76	TECTEH			F3453	reso	22H00037	H	600UL	331895
1624			24.19	184	DNT	P 1	09H	-0.11	TECTEH			F3453	reso	22H00037	H	600UL	331895
1625			6.06	182	DNT	P 1	09C	+0.04	TECTEH			F3453	reso	22H00037	H	600UL	331895
1626			4.64	182	DNG	P 1	09C	+0.87	TECTEH			F3453	reso	22H00037	H	600UL	331895
1627			2.41	185	DNG	P 1	09C	+1.93	TECTEH			F3453	reso	22H00037	H	600UL	331895
1628			3.33	185	DNG	P 1	08C	+5.01	TECTEH			F3453	reso	22H00037	H	600UL	331895
1629			4.69	184	DNG	P 1	08C	+10.58	TECTEH			F3453	reso	22H00037	H	600UL	331895
1630			6.74	183	DNG	P 1	08C	+11.03	TECTEH			F3453	reso	22H00037	H	600UL	331895
1631			1.91	183	INR	P 1	08C	+14.15	TECTEH			F3453	reso	22H00037	H	600UL	331895
1632			3.99	182	DNG	P 1	08C	+14.52	TECTEH			F3453	reso	22H00037	H	600UL	331895
1633			2.03	183	DNG	P 1	08C	+15.91	TECTEH			F3453	reso	22H00037	H	600UL	331895
1634			2.49	184	DNG	P 1	08C	+17.49	TECTEH			F3453	reso	22H00037	H	600UL	331895
			2.63	185	DNG	P 1	07C	+24.44	TECTEH			F3453	reso	22H00037	H	600UL	331895
	101	55	32.93	184	DNT	P 1	09H	-0.04	TECTEH			O8795	seco	22H00037	H	600UL	331895
1637	105	55	7.11	185	DNT	P 1	09H	-0.17	TECTEH			O8795	seco	22H00037	H	600UL	331895
1638	109	55	44.18	184	DNT	P 1	09H	+0.02	TECTEH			O8795	seco	22H00037	H	600UL	331895
1639	111	55	0.38	69	MBM	5	02H	+1.77	TECTEH			C3340	reso	22H00036	H	600UL	340972
1640					NDF		09H	-0.20	09H09H			T2170	seco	22H00197	H	600PP	345329
1641			125.0	177	DNT	P 1	09H	-0.20	TECTEH			A9574	seco	22H00036	H	600UL	340972
1642			9.49	177	DNG	P 1	VM	+28.21	TECTEH			A9574	seco	22H00036	H	600UL	340972
1643	113	55	120.6	181	DNT	P 1	09H	+0.29	TECTEH			O8795	seco	22H00037	H	600UL	331895
1644					NDF		09H	+0.29	09H09H			T2170	seco	22H00197	H	600PP	345329
1645	115	55			OBS		08H	+18.31	08HTEH			W2096	prim	22H00036	H	600UL	340972
1646					OBS		08H	+19.16	08HTEH			M7006	reso	22H00086	H	600UL	340912
1647					OBS		09H	+0.00	08H08H			M1680	reso	22H00204	H	600PP	345329
1648					NDF		09H	+0.10	09H09H			D9424	prim	22H00205	H	500DP	290406
1649			70.29	180	DNT	P 1	09H	+0.10	TEHTEC			O8795	seco	22C00061	H	580UL	287821
1650					OBS		DH	-27.00	DH TEC			L2157	reso	22C00060	H	600CS	341219
1651			0.60	38	DSI	P 1	09C	+0.00	TEHTEC			B4052	prim	22C00061	H	580UL	287821
1652			0.69	49	DSI	P 1	09C	+0.00	DH TEC			L2157	reso	22C00060	H	600CS	341219
1653					NDF		09C	+0.00	09C09C			M7007	prim	22C00087	C	600PP	345298
1654	119	55	2.69	180	DNG	P 1	VH	+2.91	TECTEH			A9574	seco	22H00036	H	600UL	340972
1655	121	55	19.45	185	DNT	P 1	09H	+0.09	TECTEH			O8795	seco	22H00037	H	600UL	331895
1656					NDF		09H	+0.09	09H09H			T2170	seco	22H00197	H	600PP	345329
1657			3.31	182	DNG	P 1	10H	+2.88	TECTEH			O8795	seco	22H00037	H	600UL	331895
1658			3.23	185	DNG	P 1	06C	+9.17	TECTEH			O8795	seco	22H00037	H	600UL	331895
1659			1.27	63	MBM	5	06C	+9.49	TECTEH			F3453	reso	22H00037	H	600UL	331895
[illegible]			4.79	23	NRC	2	TSC	+0.00	TECTEH			T6956	prim	22H00037	H	600UL	331895
	123	55	18.90	179	DNT	P 1	09H	+0.00	TECTEH			A9574	seco	22H00036	H	600UL	340972
1662	125	55	2.63	184	DNT	P 1	09H	-0.06	TECTEH			O8795	seco	22H00037	H	600UL	331895
1663	127	55	1.85	180	INR	P 1	09H	+0.39	TECTEH			A9574	seco	22H00036	H	600UL	340972
1664			2.42	174	DNT	P 1	10H	+0.16	TECTEH			A9574	seco	22H00036	H	600UL	340972
1665			4.38	176	DNT	P 1	10C	-0.11	TECTEH			A9574	seco	22H00036	H	600UL	340972

1666	129	55	3.11	178	DNG	P 1	VH	+3.85	TECTEH				O8795	seco	22H00037	H	600UL	331895

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 35

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1667	131	55	0.85	68	MBM	5	TSH	+22.56	TECTEH			F3453	reso	22H00037	H	600UL	331895
1668			3.56	179	DNG	P 1	05H	+10.56	TECTEH			O8795	seco	22H00037	H	600UL	331895
1669	2	56			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
1670			0.19	146	SCI	P 1	TSC	+0.01	TSCTSC	0.4		M7006	reso	22C00052	C	600PP	345295
1671			0.26	142	PID	P 1	TSC	+0.01	TSCTSC	080		N5432	reso	22C00071	C	600PP	345298
1672			0.00	0	SCI	1	TSC	+0.01	TSCTSC	0.0		M7006	reso	22C00052	C	600PP	345295
1673	6	56			NDF		05H	+34.04	05H06C			S4373	reso	22H00227	H	5602C	340987
1674			0.41	70	NQI	5	05H	+34.04	TECTEH			D3858	reso	22H00077	H	600UL	340943
1675	12	56	9.83	181	DNG	P 1	06H	+8.01	TECTEH			N2574	seco	22H00061	H	600UL	340945
1676	32	56	5.17	180	DNT	P 1	VM	+2.22	TECTEH			N2574	seco	22H00061	H	600UL	340945
1677	38	56	3.12	181	DNG	P 1	VM	+8.63	TECTEH			I3805	seco	22H00077	H	600UL	340943
1678	42	56			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1679			0.00	0	SAI	1	TSH	+1.41	TSHTSH	0.0		C5542	reso	22H00162	H	600PP	345329
1680			0.14	99	SAI	2	TSH	+1.41	TSHTSH	0.2		C5542	reso	22H00162	H	600PP	345329
1681			0.16	116	PID	4	TSH	+1.41	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
~~1682~~	~~[illegible]~~	~~[illegible]~~	~~0.54~~	~~85~~	~~MBM~~	~~5~~	~~02H~~	~~+12.21~~	~~TECTEH~~			~~C5542~~	~~reso~~	~~22H00077~~	~~H~~	~~600UL~~	~~340943~~
1683			2.20	181	DNG	P 1	VM	+10.47	TECTEH			I3805	seco	22H00077	H	600UL	340943
			3.64	176	DNT	P 1	03C	+0.26	TECTEH			I3805	seco	22H00077	H	600UL	340943
[illegible]	56	56			NDF		07C	+5.59	DC 07C			F0075	seco	22C00090	H	5602C	326272
1686			0.51	59	NQI	5	07C	+5.59	TECTEH			C5542	reso	22H00076	H	600UL	340945
1687	80	56	0.54	87	MBM	5	04H	+7.91	TECTEH			F3453	reso	22H00065	H	600UL	340945
1688	84	56			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
1689			0.13	33	SAI	1	TSH	+0.37	TSHTSH	0.2		F6623	reso	22H00148	H	600PP	345329
1690			0.11	109	PID	4	TSH	+0.37	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1691			0.11	108	SAI	2	TSH	+0.37	TSHTSH	0.2		F6623	reso	22H00148	H	600PP	345329
1692			0.53	62	MBM	5	03H	+16.18	TECTEH			F3453	reso	22H00065	H	600UL	340945
1693	88	56	2.15	180	DNG	P 1	01H	+5.03	TECTEH			N2574	seco	22H00065	H	600UL	340945
1694	92	56	2.92	179	DNG	P 1	08H	+15.22	TECTEH			A9574	seco	22H00036	H	600UL	340972
1695			3.53	179	DNG	P 1	08H	+16.06	TECTEH			A9574	seco	22H00036	H	600UL	340972
1696			4.11	178	DNG	P 1	08H	+17.44	TECTEH			A9574	seco	22H00036	H	600UL	340972
1697			3.09	177	DNT	P 1	09H	+0.16	TECTEH			A9574	seco	22H00036	H	600UL	340972
1698	94	56	3.29	179	DNT	P 1	09H	+0.14	TECTEH			A9574	seco	22H00036	H	600UL	340972
1699			3.51	174	DNG	P 1	08C	+12.84	TECTEH			A9574	seco	22H00036	H	600UL	340972
1700			2.44	177	DNG	P 1	07C	+2.88	TECTEH			A9574	seco	22H00036	H	600UL	340972
1701	96	56	2.44	185	DNG	P 1	03H	+5.23	TECTEH			O8795	seco	22H00037	H	600UL	331895
1702			0.79	79	MBM	5	07H	+21.23	TECTEH			F3453	reso	22H00037	H	600UL	331895
1703	98	56	0.43	86	MBM	5	01H	+2.42	TECTEH			C3340	reso	22H00036	H	600UL	340972
1704			2.36	178	DNT	P 1	09H	+0.11	TECTEH			A9574	seco	22H00036	H	600UL	340972
1705	108	56	0.57	82	MBM	5	03C	+28.39	TECTEH			C3340	reso	22H00036	H	600UL	340972
1706	110	56	0.55	82	MBM	5	01H	+24.31	TECTEH			C3340	reso	22H00036	H	600UL	340972
1707			0.63	78	MBM	5	04C	+10.66	TECTEH			C3340	reso	22H00036	H	600UL	340972
1708	116	56	1.58	177	INR	P 1	02H	+35.65	TECTEH			A9574	seco	22H00036	H	600UL	340972
[illegible]	118	56	8.59	184	DNT	P 1	10H	-0.02	TECTEH			O8795	seco	22H00037	H	600UL	331895
	120	56	0.56	92	MBM	5	05H	+15.01	TECTEH			C3340	reso	22H00036	H	600UL	340972
1711			1.50	175	INR	P 1	DH	+23.72	TECTEH			A9574	seco	22H00036	H	600UL	340972
1712			0.57	73	MBM	5	04C	+21.97	TECTEH			C3340	reso	22H00036	H	600UL	340972
1713	122	56	7.19	185	DNT	P 1	09H	-0.17	TECTEH			O8795	seco	22H00037	H	600UL	331895
1714	124	56			NDF		09H	-0.35	09H09H			T2170	seco	22H00197	H	600PP	345329

1715			10.17	179	DNT	P 1	09H	-0.35		TECTEH				A9574	seco	22H00036	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 36

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1716			6.42	178	DNG	P 1	09H	+16.44	TECTEH			A9574	seco	22H00036	H	600UL	340972
1717			7.53	180	DNG	P 1	09H	+17.38	TECTEH			A9574	seco	22H00036	H	600UL	340972
1718			4.27	179	DNG	P 1	09H	+18.03	TECTEH			A9574	seco	22H00036	H	600UL	340972
1719			2.34	182	DNT	P 1	10C	+0.58	TECTEH			A9574	seco	22H00036	H	600UL	340972
1720	126	56	3.55	182	DNT	P 1	09H	+0.42	TECTEH			O8795	seco	22H00037	H	600UL	331895
1721	128	56	2.62	175	DNT	P 1	10H	-0.14	TECTEH			A9574	seco	22H00036	H	600UL	340972
1722	7	57	5.55	177	DNG	P 1	TSH	+20.88	TECTEH			I3805	seco	22H00077	H	600UL	340943
1723	25	57	0.24	111	INR	P 1	TSH	+1.02	TECTEH			N2574	seco	22H00067	H	600UL	340945
1724	27	57	8.36	179	DNG	P 1	05H	+23.48	TECTEH			N2574	seco	22H00067	H	600UL	340945
1725	35	57			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1726			0.17	91	SAI	2	TSH	+0.30	TSHTSH	0.2		L2157	reso	22H00161	H	600PP	345291
1727			0.14	92	PID	4	TSH	+0.30	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1728			0.0	0	SAI	1	TSH	+0.30	TSHTSH	0.0		L2157	reso	22H00161	H	600PP	345291
1729	43	57			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1730			0.39	85	SAI	1	TSH	+0.90	TSHTSH	0.3		L2157	reso	22H00161	H	600PP	345291
~~1731~~	~~|~~	~~|~~	~~0.30~~	~~87~~	~~PID~~	~~4~~	~~TSH~~	~~+0.90~~	~~TSHTSH~~	~~080~~		~~F3453~~	~~reso~~	~~22H00181~~	~~H~~	~~600PP~~	~~345332~~
1732			0.29	98	SAI	2	TSH	+0.90	TSHTSH	0.3		L2157	reso	22H00161	H	600PP	345291
	47	57			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
			0.38	20	PID	P 1	TSH	-0.16	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1735			0.22	22	SCI	P 1	TSH	-0.16	TSHTSH	0.2	PWSCC	L2157	reso	22H00161	H	600PP	345291
1736			0.20	46	SCI	1	TSH	-0.16	TSHTSH	0.2	PWSCC	L2157	reso	22H00161	H	600PP	345291
1737	55	57			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
1738			0.57	121	DSI	P 1	03H	+0.35	TECTEH			T6956	prim	22H00077	H	600UL	340943
1739			0.45	95	PID	4	03H	+0.37	03H03H	080		F3453	reso	22H00181	H	600PP	345332
1740			0.74	96	SAI	3	03H	+0.37	03H03H	0.6		L2157	reso	22H00167	H	600PP	345290
1741			0.50	101	SAI	4	03H	+0.37	03H03H	0.4		L2157	reso	22H00167	H	600PP	345290
1742	57	57	6.22	185	DNG	P 1	07C	+6.53	TECTEH			N5877	seco	22H00076	H	600UL	340945
1743	67	57	1.16	79	MBM	5	01H	+23.93	TECTEH			F3453	reso	22H00068	H	600UL	340927
1744			3.43	185	DNG	P 1	02H	+12.50	TECTEH			I3805	seco	22H00068	H	600UL	340927
1745	77	57	1.32	85	MBM	6	03C	+15.74	TECTEH			F3453	reso	22H00065	H	600UL	340945
1746	79	57	3.25	183	DNG	P 1	05C	+3.17	TECTEH			I3805	seco	22H00098	H	600UL	340929
1747			2.91	182	DNG	P 1	05C	+6.44	TECTEH			I3805	seco	22H00098	H	600UL	340929
1748			3.00	179	DNG	P 1	05C	+16.12	TECTEH			I3805	seco	22H00098	H	600UL	340929
1749			2.31	180	DNG	P 1	04C	+23.54	TECTEH			I3805	seco	22H00098	H	600UL	340929
1750			2.58	184	DNG	P 1	04C	+25.30	TECTEH			I3805	seco	22H00098	H	600UL	340929
1751			2.92	181	DNG	P 1	04C	+32.28	TECTEH			I3805	seco	22H00098	H	600UL	340929
1752			1.98	188	INR	P 1	04C	+35.06	TECTEH			I3805	seco	22H00098	H	600UL	340929
1753			2.07	184	DNG	P 1	03C	+1.29	TECTEH			I3805	seco	22H00098	H	600UL	340929
1754			3.97	181	DNG	P 1	03C	+1.87	TECTEH			I3805	seco	22H00098	H	600UL	340929
1755			4.05	183	DNG	P 1	03C	+2.48	TECTEH			I3805	seco	22H00098	H	600UL	340929
1756			2.22	181	DNG	P 1	03C	+31.01	TECTEH			I3805	seco	22H00098	H	600UL	340929
1757			2.72	180	DNG	P 1	03C	+32.92	TECTEH			I3805	seco	22H00098	H	600UL	340929
1758			2.38	183	DNG	P 1	03C	+33.51	TECTEH			I3805	seco	22H00098	H	600UL	340929
			2.07	189	DNG	P 1	03C	+34.69	TECTEH			I3805	seco	22H00098	H	600UL	340929
1760			2.29	183	DNG	P 1	03C	+35.83	TECTEH			I3805	seco	22H00098	H	600UL	340929
1761			3.86	181	DNG	P 1	02C	+11.40	TECTEH			I3805	seco	22H00098	H	600UL	340929
1762			4.76	182	DNG	P 1	02C	+11.92	TECTEH			I3805	seco	22H00098	H	600UL	340929
1763			4.16	182	DNG	P 1	02C	+12.52	TECTEH			I3805	seco	22H00098	H	600UL	340929

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38
PLANT: CCNPP
UNIT: 2
SG: 22
DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 37

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1764			2.75	182	DNG	P 1	02C	+13.03	TECTEH			I3805	seco	22H00098	H	600UL	340929
1765			2.64	178	DNG	P 1	02C	+13.58	TECTEH			I3805	seco	22H00098	H	600UL	340929
1766			2.52	177	DNG	P 1	02C	+14.12	TECTEH			I3805	seco	22H00098	H	600UL	340929
1767			2.53	175	DNG	P 1	02C	+14.68	TECTEH			I3805	seco	22H00098	H	600UL	340929
1768			3.19	180	DNG	P 1	02C	+16.11	TECTEH			I3805	seco	22H00098	H	600UL	340929
1769			3.25	182	DNG	P 1	02C	+17.22	TECTEH			I3805	seco	22H00098	H	600UL	340929
1770			3.89	180	DNG	P 1	02C	+19.21	TECTEH			I3805	seco	22H00098	H	600UL	340929
1771			2.69	179	DNG	P 1	02C	+21.46	TECTEH			I3805	seco	22H00098	H	600UL	340929
1772			3.71	183	DNG	P 1	02C	+22.01	TECTEH			I3805	seco	22H00098	H	600UL	340929
1773			2.66	177	DNG	P 1	02C	+22.40	TECTEH			I3805	seco	22H00098	H	600UL	340929
1774			2.22	178	DNG	P 1	02C	+22.63	TECTEH			I3805	seco	22H00098	H	600UL	340929
1775			2.39	181	DNG	P 1	02C	+22.96	TECTEH			I3805	seco	22H00098	H	600UL	340929
1776			2.91	184	DNG	P 1	02C	+23.21	TECTEH			I3805	seco	22H00098	H	600UL	340929
1777			4.07	181	DNG	P 1	02C	+23.60	TECTEH			I3805	seco	22H00098	H	600UL	340929
1778			2.61	181	DNG	P 1	02C	+25.27	TECTEH			I3805	seco	22H00098	H	600UL	340929
1779			2.52	182	DNG	P 1	02C	+28.92	TECTEH			I3805	seco	22H00098	H	600UL	340929
1780			3.18	180	DNG	P 1	02C	+30.59	TECTEH			I3805	seco	22H00098	H	600UL	340929
1781			2.92	181	DNG	P 1	02C	+33.25	TECTEH			I3805	seco	22H00098	H	600UL	340929
			2.22	181	DNG	P 1	02C	+33.80	TECTEH			I3805	seco	22H00098	H	600UL	340929
			2.47	178	DNG	P 1	02C	+34.64	TECTEH			I3805	seco	22H00098	H	600UL	340929
1784			4.34	181	DNG	P 1	02C	+35.00	TECTEH			I3805	seco	22H00098	H	600UL	340929
1785			2.94	182	DNG	P 1	02C	+35.51	TECTEH			I3805	seco	22H00098	H	600UL	340929
1786			2.64	182	DNG	P 1	02C	+36.03	TECTEH			I3805	seco	22H00098	H	600UL	340929
1787			2.18	179	DNG	P 1	02C	+37.14	TECTEH			I3805	seco	22H00098	H	600UL	340929
1788	81	57			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
1789			0.62	98	NQI	P 1	TSC	+1.92	TECTEH			G2927	prim	22H00065	H	600UL	340945
1790			0.12	145	PID	4	TSC	+2.30	TSCTSC	080		M1680	reso	22C00085	C	600PP	345298
1791			0.11	98	SAI	4	TSC	+2.30	TSCTSC	0.2		N5432	reso	22C00070	C	600PP	345324
1792			0.00	0	SAI	3	TSC	+2.30	TSCTSC	0.0		N5432	reso	22C00070	C	600PP	345324
1793	87	57	0.76	92	MBM	5	TSC	+18.70	TECTEH			M1680	reso	22H00098	H	600UL	340929
1794	89	57	0.55	63	MBM	5	03C	+2.99	TECTEH			F3453	reso	22H00065	H	600UL	340945
1795	91	57	5.60	169	INR	P 1	09C	+1.66	TECTEH			A9574	seco	22H00036	H	600UL	340972
1796	93	57	2.71	185	DNG	P 1	08H	+5.69	TECTEH			O8795	seco	22H00037	H	600UL	331895
1797			5.18	184	DNG	P 1	08H	+8.82	TECTEH			O8795	seco	22H00037	H	600UL	331895
1798			4.46	185	DNG	P 1	08H	+10.18	TECTEH			O8795	seco	22H00037	H	600UL	331895
1799			2.37	183	DNT	P 1	09H	+0.11	TECTEH			O8795	seco	22H00037	H	600UL	331895
1800			3.90	186	DNG	P 1	09C	+0.98	TECTEH			F3453	reso	22H00037	H	600UL	331895
1801			2.08	182	DNT	P 1	08C	+0.32	TECTEH			O8795	seco	22H00037	H	600UL	331895
1802			2.73	188	DNG	P 1	08C	+3.73	TECTEH			O8795	seco	22H00037	H	600UL	331895
1803			2.50	183	DNG	P 1	08C	+7.49	TECTEH			O8795	seco	22H00037	H	600UL	331895
1804			0.34	184	INR	P 1	08C	+8.53	TECTEH			O8795	seco	22H00037	H	600UL	331895
1805			3.03	185	DNG	P 1	08C	+9.92	TECTEH			O8795	seco	22H00037	H	600UL	331895
1806			2.75	182	DNG	P 1	08C	+12.25	TECTEH			O8795	seco	22H00037	H	600UL	331895
1807	97	57	7.99	185	DNT	P 1	09H	-0.11	TECTEH			O8795	seco	22H00037	H	600UL	331895
	101	57			NDF		09H	-0.09	09H09H			M9715	seco	22H00187	H	600PP	345332
1809			5.73	185	DNT	P 1	09H	-0.09	TECTEH			O8795	seco	22H00037	H	600UL	331895
1810	103	57	42.30	178	DNT	P 1	09H	+0.04	TECTEH			A9574	seco	22H00036	H	600UL	340972
1811	107	57	15.10	180	DNT	P 1	09H	-0.15	TECTEH			A9574	seco	22H00036	H	600UL	340972
1812	111	57	2.87	177	DNG	P 1	VM	+29.08	TECTEH			A9574	seco	22H00036	H	600UL	340972

1813			5.97	178	DNG	P 1	08C	+12.84	TECTEH			A9574	seco	22H00036	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 38

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1814			9.37	177	DNG	P 1	08C	+14.45	TECTEH			A9574	seco	22H00036	H	600UL	340972
1815	117	57	10.91	184	DNT	P 1	09H	-0.17	TECTEH			O8795	seco	22H00037	H	600UL	331895
1816			2.54	182	DNT	P 1	10H	-0.04	TECTEH			O8795	seco	22H00037	H	600UL	331895
1817	121	57	0.55	65	MBM	5	04C	+32.96	TECTEH			F3453	reso	22H00037	H	600UL	331895
1818			4.90	22	NRC	2	TSC	+0.00	TECTEH			F3453	reso	22H00037	H	600UL	331895
1819	123	57	6.34	177	DNT	P 1	09H	+0.07	TECTEH			A9574	seco	22H00036	H	600UL	340972
1820	127	57	3.68	183	DNT	P 1	09H	+0.43	TECTEH			A9574	seco	22H00036	H	600UL	340972
1821	129	57	2.43	183	DNT	P 1	VH	-1.70	TECTEH			O8795	seco	22H00037	H	600UL	331895
1822			0.53	74	MBM	5	03C	+4.76	TECTEH			F3453	reso	22H00037	H	600UL	331895
1823	131	57	0.70	78	MBM	5	04H	+7.69	TECTEH			C3340	reso	22H00036	H	600UL	340972
1824			4.04	180	DNG	P 1	VH	+4.36	TECTEH			A9574	seco	22H00036	H	600UL	340972
1825	26	58	1.11	82	MBM	5	03H	+23.15	TECTEH			C3340	reso	22H00067	H	600UL	340945
1826	34	58	2.02	181	DNT	P 1	03C	+0.35	TECTEH			I3805	seco	22H00079	H	600UL	340943
1827	40	58	3.05	177	DNT	P 1	VM	+1.80	TECTEH			N5877	seco	22H00078	H	600UL	331969
1828			3.21	181	DNG	P 1	VM	+9.30	TECTEH			N5877	seco	22H00078	H	600UL	331969
~~1829~~	~~62~~	~~58~~	~~0.93~~	~~68~~	~~MBM~~	~~5~~	~~07H~~	~~+21.01~~	~~TECTEH~~			~~F3453~~	~~reso~~	~~22H00068~~	~~H~~	~~600UL~~	~~340927~~
1830	64	58	8.45	175	DNG	P 1	07C	+10.04	TECTEH			N2574	seco	22H00067	H	600UL	340945
	66	58	2.73	181	DNG	P 1	07H	+7.42	TECTEH			I3805	seco	22H00068	H	600UL	340927
			6.30	182	DNG	P 1	07C	+14.73	TECTEH			I3805	seco	22H00068	H	600UL	340927
1833	90	58	0.94	61	MBM	5	02C	+22.54	TECTEH			F3453	reso	22H00065	H	600UL	340945
1834	96	58	2.53	179	DNG	P 1	07H	+22.58	TECTEH			M1637	seco	22H00038	H	600UL	340972
1835			3.17	183	DNG	P 1	08H	+6.96	TECTEH			M1637	seco	22H00038	H	600UL	340972
1836			9.90	183	DNG	P 1	08H	+8.49	TECTEH			M1637	seco	22H00038	H	600UL	340972
1837			2.99	185	DNG	P 1	08H	+9.43	TECTEH			M1637	seco	22H00038	H	600UL	340972
1838			7.15	181	DNG	P 1	08H	+10.50	TECTEH			M1637	seco	22H00038	H	600UL	340972
1839			9.99	182	DNG	P 1	08H	+16.72	TECTEH			N5432	reso	22H00038	H	600UL	340972
1840			6.61	182	DNT	P 1	09H	+0.74	TECTEH			N5432	reso	22H00038	H	600UL	340972
1841			4.74	183	DNT	P 1	09C	-0.64	TECTEH			M1637	seco	22H00038	H	600UL	340972
1842			26.16	183	DNT	P 1	09C	+0.24	TECTEH			M1637	seco	22H00038	H	600UL	340972
1843			7.16	180	DNG	P 1	08C	+1.14	TECTEH			M1637	seco	22H00038	H	600UL	340972
1844			7.05	182	DNG	P 1	08C	+18.77	TECTEH			M1637	seco	22H00038	H	600UL	340972
1845			3.75	179	DNG	P 1	08C	+20.24	TECTEH			M1637	seco	22H00038	H	600UL	340972
1846			20.70	183	DNG	P 1	08C	+21.28	TECTEH			M1637	seco	22H00038	H	600UL	340972
1847			8.56	183	DNG	P 1	07C	+12.78	TECTEH			M1637	seco	22H00038	H	600UL	340972
1848			4.83	182	DNG	P 1	07C	+14.39	TECTEH			M1637	seco	22H00038	H	600UL	340972
1849			2.50	178	DNG	P 1	07C	+18.98	TECTEH			M1637	seco	22H00038	H	600UL	340972
1850			8.28	180	DNG	P 1	07C	+19.99	TECTEH			M1637	seco	22H00038	H	600UL	340972
1851	102	58			OBS	P 1	08H	+20.31	08HTEH			I3805	seco	22H00039	H	600UL	331895
1852					OBS		09H	+0.00	09H09H			M7006	reso	22H00187	H	600PP	345332
1853					NDF		09H	+0.06	09H09H			D9424	prim	22H00205	H	500DP	290406
1854			161.5	180	DNT	P 1	09H	+0.06	TECTEH			D3858	reso	22H00086	H	600UL	340912
1855	104	58	0.41	80	MBM	5	04H	+5.23	TECTEH			N5432	reso	22H00038	H	600UL	340972
[illegible]					NDF		09H	+0.00	09H09H			M9715	seco	22H00187	H	600PP	345332
			69.99	181	DNT	P 1	09H	+0.00	TECTEH			M1637	seco	22H00038	H	600UL	340972
1858	106	58	31.49	180	DNT	P 1	09H	+0.04	TECTEH			I3805	seco	22H00039	H	600UL	331895
1859					NDF		09H	+0.04	09H09H			T2170	seco	22H00197	H	600PP	345329
1860	108	58	3.88	173	DNG	P 1	01H	+23.26	TECTEH			M1637	seco	22H00038	H	600UL	340972
1861	114	58	0.74	84	MBM	6	06H	+7.50	TECTEH			C3340	reso	22H00036	H	600UL	340972

1862	118	58	35.75	180	DNT	P 1	10H	-0.02	TECTEH				A9574	seco	22H00036	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 39

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1863	120	58	2.57	185	DNT	P 1	10C	+0.00	TECTEH			O8795	seco	22H00037	H	600UL	331895
1864			7.41	186	DNG	P 1	10C	+2.92	TECTEH			O8795	seco	22H00037	H	600UL	331895
1865	126	58	5.86	177	DNT	P 1	10H	+0.11	TECTEH			A9574	seco	22H00036	H	600UL	340972
1866	11	59	0.89	62	MBM	6	03C	+8.57	TECTEH			C5542	reso	22H00078	H	600UL	331969
1867	13	59	0.84	80	MBM	5	02C	+6.81	TECTEH			C5542	reso	22H00079	H	600UL	340943
1868	29	59			NDF		TSC	+2.18	TSCTSC			S4373	reso	22C00042	C	600PP	345295
1869			0.45	121	NQI	P 1	TSC	+2.18	TECTEH			K5380	prim	22H00068	H	600UL	340927
1870	45	59			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1871			0.0	0	SAI	1	TSH	+0.71	TSHTSH	0.0		L2157	reso	22H00165	H	600PP	345290
1872			0.12	91	PID	4	TSH	+0.71	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1873			0.16	96	SAI	2	TSH	+0.71	TSHTSH	0.2		L2157	reso	22H00165	H	600PP	345290
1874	67	59	3.36	188	DNG	P 1	04C	+35.42	TECTEH			N2574	seco	22H00065	H	600UL	340945
1875	77	59	0.69	68	MBM	5	07C	+19.86	TECTEH			F3453	reso	22H00065	H	600UL	340945
1876	93	59	0.42	39	MBM	5	TSH	+15.98	TECTEH			F3453	reso	22H00039	H	600UL	331895
1877			0.32	81	MBM	5	01H	+4.04	TECTEH			F3453	reso	22H00039	H	600UL	331895
1878			0.41	70	MBM	5	01H	+15.22	TECTEH			F3453	reso	22H00039	H	600UL	331895
1879			2.74	181	DNT	P 1	08H	+0.44	TECTEH			I3805	seco	22H00039	H	600UL	331895
			5.06	182	DNG	P 1	08H	+2.43	TECTEH			I3805	seco	22H00039	H	600UL	331895
			2.74	184	DNG	P 1	08H	+4.22	TECTEH			I3805	seco	22H00039	H	600UL	331895
1882			7.55	182	DNG	P 1	08H	+6.24	TECTEH			I3805	seco	22H00039	H	600UL	331895
1883			5.23	183	DNT	P 1	09H	+0.02	TECTEH			I3805	seco	22H00039	H	600UL	331895
1884					NDF		09H	+0.02	09H09H			J9815	prim	22H00197	H	600PP	345329
1885			6.28	181	DNG	P 1	08C	+2.84	TECTEH			I3805	seco	22H00039	H	600UL	331895
1886			2.90	181	DNG	P 1	08C	+3.77	TECTEH			I3805	seco	22H00039	H	600UL	331895
1887			7.14	182	DNG	P 1	08C	+7.70	TECTEH			I3805	seco	22H00039	H	600UL	331895
1888			3.00	179	DNG	P 1	07C	+15.35	TECTEH			I3805	seco	22H00039	H	600UL	331895
1889			4.51	182	DNG	P 1	07C	+17.90	TECTEH			I3805	seco	22H00039	H	600UL	331895
1890			5.71	183	DNG	P 1	07C	+24.74	TECTEH			I3805	seco	22H00039	H	600UL	331895
1891			0.29	66	MBM	5	TSC	+12.62	TECTEH			F3453	reso	22H00039	H	600UL	331895
1892			0.50	77	MBM	5	TSC	+33.80	TECTEH			F3453	reso	22H00039	H	600UL	331895
1893			0.56	91	MBM	5	TSC	+34.69	TECTEH			F3453	reso	22H00039	H	600UL	331895
1894	97	59	3.47	180	DNG	P 1	07C	+2.82	TECTEH			I3805	seco	22H00039	H	600UL	331895
1895			2.02	181	DNG	P 1	07C	+10.66	TECTEH			I3805	seco	22H00039	H	600UL	331895
1896			2.22	180	DNG	P 1	07C	+20.55	TECTEH			I3805	seco	22H00039	H	600UL	331895
1897	101	59	14.05	181	DNT	P 1	09H	+0.07	TECTEH			I3805	seco	22H00039	H	600UL	331895
1898	103	59	156.2	174	DNT	P 1	09H	+0.02	TECTEH			M1637	seco	22H00038	H	600UL	340972
1899					NDF		09H	+0.02	09H09H			M9715	seco	22H00187	H	600PP	345332
1900	105	59			NDF		09H	+0.00	09H09H			T2170	seco	22H00197	H	600PP	345329
1901			116.1	179	DNT	P 1	09H	+0.00	TECTEH			I3805	seco	22H00039	H	600UL	331895
1902	107	59	36.85	181	DNT	P 1	09H	-0.09	TECTEH			M1637	seco	22H00038	H	600UL	340972
1903	111	59	21.45	183	DNT	P 1	09H	-0.11	TECTEH			M1637	seco	22H00038	H	600UL	340972
1904	113	59	18.91	182	DNT	P 1	09H	-0.04	TECTEH			I3805	seco	22H00039	H	600UL	331895
	115	59	6.56	184	DNT	P 1	09H	-0.28	TECTEH			M1637	seco	22H00038	H	600UL	340972
	117	59	3.96	179	DNT	P 1	09H	-0.23	TECTEH			I3805	seco	22H00039	H	600UL	331895
1907			5.81	180	DNT	P 1	10C	+0.19	TECTEH			I3805	seco	22H00039	H	600UL	331895
1908			0.51	71	MBM	5	05C	+5.76	TECTEH			F3453	reso	22H00039	H	600UL	331895
1909			0.50	72	MBM	5	04C	+10.95	TECTEH			F3453	reso	22H00039	H	600UL	331895
1910			0.40	72	MBM	5	03C	+7.90	TECTEH			F3453	reso	22H00039	H	600UL	331895

1911			0.46	64	MBM	5	03C	+29.41	TECTEH			F3453	reso	22H00039	H	600UL		331895

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 40

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1912		0.48	80	MBM	5	03C	+37.24	TECTEH			F3453	reso	22H00039	H	600UL	331895
1913		1.11	76	MBM	5	02C	+19.32	TECTEH			F3453	reso	22H00039	H	600UL	331895
1914		0.45	74	MBM	5	02C	+24.84	TECTEH			F3453	reso	22H00039	H	600UL	331895
1915		0.63	81	MBM	5	TSC	+14.32	TECTEH			F3453	reso	22H00039	H	600UL	331895
1916		0.68	83	MBM	5	TSC	+25.41	TECTEH			F3453	reso	22H00039	H	600UL	331895
1917	121	4.52	27	NRC	2	TSC	+0.00	TECTEH			F3453	reso	22H00039	H	600UL	331895
1918	123	3.61	176	DNG	P 1	03H	+8.52	TECTEH			M1637	seco	22H00038	H	600UL	340972
1919	125	2.97	184	DNT	P 1	09C	+0.55	TECTEH			I3805	seco	22H00039	H	600UL	331895
1920	127	2.51	181	DNG	P 1	08H	+12.19	TECTEH			M1637	seco	22H00038	H	600UL	340972
1921		1.45	176	INR	P 1	09H	+0.41	TECTEH			N5432	reso	22H00038	H	600UL	340972
1922		4.19	181	DNG	P 1	10H	+1.64	TECTEH			M1637	seco	22H00038	H	600UL	340972
1923	131	3.18	184	DNG	P 1	09H	+5.78	TECTEH			M1637	seco	22H00038	H	600UL	340972
1924		9.10	181	DNT	P 1	10H	+0.00	TECTEH			M1637	seco	22H00038	H	600UL	340972
1925	2	21.17	174	INR	P 1	06C	+1.48	06CTEC			D3858	reso	22C00059	C	600CS	341611
1926		21.32	174	INR	P 1	06C	+2.62	06CTEC			D3858	reso	22C00059	C	600CS	341611
1927	60	3.03	183	DNG	P 1	DH	+8.22	TECTEH			N5077	seco	22H00070	H	600UL	340945
1928	62	0.23	75	MBM	5	05H	+16.43	TECTEH			F3453	reso	22H00068	H	600UL	340927
		0.49	67	MBM	5	05H	+17.65	TECTEH			F3453	reso	22H00068	H	600UL	340927
[illegible]		3.19	183	DNG	P 1	VM	+21.76	TECTEH			I3805	seco	22H00068	H	600UL	340927
1931	70	5.13	177	DNG	P 1	07H	+8.03	TECTEH			I3805	seco	22H00068	H	600UL	340927
1932		4.14	178	DNG	P 1	07H	+13.22	TECTEH			I3805	seco	22H00068	H	600UL	340927
1933	84	0.39	119	WAR	2	06C	+1.01	06C06C			F6623	reso	22C00087	C	600PP	345298
1934		0.33	134	14	P 2	06C	+1.06	TECTEH			D3858	reso	22H00068	H	600UL	340927
1935	90	3.14	176	DNG	P 1	03H	+24.30	TECTEH			N2574	seco	22H00067	H	600UL	340945
1936	92	3.95	180	DNT	P 1	08C	+0.56	TECTEH			M1637	seco	22H00038	H	600UL	340972
1937	96	6.10	179	DNG	P 1	08C	+1.47	TECTEH			M1637	seco	22H00038	H	600UL	340972
1938		2.40	182	DNG	P 1	07C	+15.14	TECTEH			M1637	seco	22H00038	H	600UL	340972
1939		4.03	180	DNG	P 1	07C	+20.94	TECTEH			M1637	seco	22H00038	H	600UL	340972
1940	98	3.51	179	DNT	P 1	09H	-0.02	TECTEH			I3805	seco	22H00039	H	600UL	331895
1941	100	3.47	182	DNG	P 1	VH	+25.96	TECTEH			M1637	seco	22H00038	H	600UL	340972
1942	104	23.38	181	DNT	P 1	09H	+0.13	TECTEH			M1637	seco	22H00038	H	600UL	340972
1943	106	1.95	184	INR	P 1	02H	+31.15	TECTEH			I3805	seco	22H00039	H	600UL	331895
1944	108	27.02	183	DNT	P 1	09H	-0.09	TECTEH			M1637	seco	22H00038	H	600UL	340972
1945		15.09	181	DNG	P 1	TSC	+22.55	TECTEH			M1637	seco	22H00038	H	600UL	340972
1946	110	0.48	64	MBM	5	02H	+3.82	TECTEH			F3453	reso	22H00039	H	600UL	331895
1947				INF		08H	+22.15	TECTEH	HR		F3453	reso	22H00039	H	600UL	331895
1948		9.03	181	DNT	P 1	09H	-0.43	TECTEH			I3805	seco	22H00039	H	600UL	331895
1949				NDF		01C	-0.21	01C01C			F6623	reso	22C00087	C	600PP	345298
1950		0.43	60	DSI	P 1	01C	-0.21	TECTEH			M7007	prim	22H00039	H	600UL	331895
1951	114	7.11	180	DNT	P 1	09H	-0.34	TECTEH			I3805	seco	22H00039	H	600UL	331895
1952				NDF		09H	-0.34	09H09H			M9715	seco	22H00187	H	600PP	345332
1953	116	5.36	180	DNT	P 1	09H	-0.17	TECTEH			M1637	seco	22H00038	H	600UL	340972
[illegible]	118	0.23	77	NQI	P 1	TSH	+1.95	TECTEH			M7007	prim	22H00039	H	600UL	331895
				NDF		TSH	+1.95	TSHTSH			S4373	reso	22H00135	H	600PP	345329
1956	120	9.44	184	DNT	P 1	10H	-0.09	TECTEH			M1637	seco	22H00038	H	600UL	340972
1957	122	6.88	175	DNT	P 1	09H	-0.15	TECTEH			I3805	seco	22H00039	H	600UL	331895
1958	124	3.73	179	DNG	P 1	03H	+24.27	TECTEH			M1637	seco	22H00038	H	600UL	340972
1959		2.00	182	DNG	P 1	09H	+5.05	TECTEH			M1637	seco	22H00038	H	600UL	340972

1960			2.80	179	DNG	P 1	09H	+7.68	TECTEH			M1637	seco	22H00038	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 41

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1961			17.21	182	DNG	P 1	09H	+8.63	TECTEH			M1637	seco	22H00038	H	600UL	340972
1962			5.30	180	DNG	P 1	09H	+9.84	TECTEH			M1637	seco	22H00038	H	600UL	340972
1963			7.16	186	DNT	P 1	10H	-0.34	TECTEH			M1637	seco	22H00038	H	600UL	340972
1964			12.64	183	DNT	P 1	10H	+0.69	TECTEH			M1637	seco	22H00038	H	600UL	340972
1965			3.73	181	DNT	P 1	10C	-0.59	TECTEH			M1637	seco	22H00038	H	600UL	340972
1966			13.14	180	DNT	P 1	10C	+0.52	TECTEH			M1637	seco	22H00038	H	600UL	340972
1967			2.47	185	DNT	P 1	09C	+0.48	TECTEH			M1637	seco	22H00038	H	600UL	340972
1968			3.69	182	DNG	P 1	09C	+16.88	TECTEH			M1637	seco	22H00038	H	600UL	340972
1969			7.10	182	DNG	P 1	08C	+17.95	TECTEH			M1637	seco	22H00038	H	600UL	340972
1970			4.24	182	DNG	P 1	08C	+19.21	TECTEH			M1637	seco	22H00038	H	600UL	340972
1971	126	60	3.13	179	DNT	P 1	09H	-0.28	TECTEH			I3805	seco	22H00039	H	600UL	331895
1972			2.72	185	DNT	P 1	09H	+0.29	TECTEH			I3805	seco	22H00039	H	600UL	331895
1973			6.85	179	DNT	P 1	09C	+0.38	TECTEH			I3805	seco	22H00039	H	600UL	331895
1974	128	60	4.82	173	DNT	P 1	09H	+0.36	TECTEH			M1637	seco	22H00038	H	600UL	340972
1975			2.02	182	DNG	P 1	10H	-1.62	TECTEH			M1637	seco	22H00038	H	600UL	340972
1976	130	60	8.27	182	DNT	P 1	09H	+0.42	TECTEH			I3805	seco	22H00039	H	600UL	331895
1977	7	61	0.69	93	MBM	6	TSC	+35.55	TECTEH			C5542	reso	22H00077	H	600UL	340943
	9	61			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
			0.14	16	SAI	2	TSH	-0.69	TSHTSH	0.3	PWSCC	L2157	reso	22H00165	H	600PP	345290
1980			0.54	15	PID	4	TSH	-0.69	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1981			0.11	12	SAI	1	TSH	-0.69	TSHTSH	0.3	PWSCC	L2157	reso	22H00165	H	600PP	345290
1982	19	61			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
1983			0.41	17	PID	4	TSH	-0.85	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
1984			0.16	20	SAI	2	TSH	-0.85	TSHTSH	0.2	PWSCC	C5542	reso	22H00166	H	600PP	345329
1985			0.18	11	SAI	1	TSH	-0.85	TSHTSH	0.2	PWSCC	C5542	reso	22H00166	H	600PP	345329
1986	27	61	0.56	82	MBM	5	05H	+14.02	TECTEH			C5542	reso	22H00077	H	600UL	340943
1987	51	61	2.91	176	DNG	P 1	03H	+15.52	TECTEH			I3805	seco	22H00077	H	600UL	340943
1988			2.48	185	DNG	P 1	TSC	+17.03	TECTEH			I3805	seco	22H00077	H	600UL	340943
1989	57	61	0.39	67	NQI	5	07C	+6.77	TECTEH			C5542	reso	22H00076	H	600UL	340945
1990					NDF		07C	+6.77	DC 07C			F0075	seco	22C00090	H	5602C	326272
1991	61	61	3.82	182	DNG	P 1	TSH	+8.66	TECTEH			N5877	seco	22H00076	H	600UL	340945
1992	67	61	6.24	181	DNG	P 1	DH	+17.75	TECTEH			I3805	seco	22H00068	H	600UL	340927
1993	79	61	0.49	65	MBM	5	04C	+21.67	TECTEH			F3453	reso	22H00068	H	600UL	340927
1994	81	61	0.55	79	MBM	5	06C	+7.05	TECTEH			C3340	reso	22H00067	H	600UL	340945
1995			1.22	61	MBM	6	06C	+15.20	TECTEH			C3340	reso	22H00067	H	600UL	340945
1996	83	61	0.67	81	INR	5	TSH	+7.31	TECTEH			F3453	reso	22H00068	H	600UL	340927
1997	85	61	0.35	88	MBM	5	04H	+13.83	TECTEH			C3340	reso	22H00067	H	600UL	340945
1998			0.82	88	MBM	5	05H	+4.38	TECTEH			C3340	reso	22H00067	H	600UL	340945
1999			0.55	81	MBM	5	06C	+10.71	TECTEH			C3340	reso	22H00067	H	600UL	340945
2000	87	61	1.24	78	MBM	6	03H	+22.01	TECTEH			F3453	reso	22H00068	H	600UL	340927
2001			1.20	71	MBM	6	02C	+24.37	TECTEH			F3453	reso	22H00068	H	600UL	340927
2002	89	61	0.67	68	MBM	6	07H	+11.54	TECTEH			C3340	reso	22H00067	H	600UL	340945
2003			1.12	71	MBM	6	08H	+6.03	TECTEH			C3340	reso	22H00067	H	600UL	340945
			0.64	41	MBM	5	VH	+20.16	TECTEH			C3340	reso	22H00067	H	600UL	340945
2005	107	61	15.04	179	DNT	P 1	09H	-0.17	TECTEH			M1637	seco	22H00038	H	600UL	340972
2006	109	61	3.68	182	DNT	P 1	09H	-0.22	TECTEH			I3805	seco	22H00039	H	600UL	331895
2007	111	61	2.66	175	DNG	P 1	06H	+6.03	TECTEH			M1637	seco	22H00038	H	600UL	340972
2008			3.05	178	DNG	P 1	06H	+15.11	TECTEH			M1637	seco	22H00038	H	600UL	340972

2009					INF	08H	+22.15	TECTEH	HR			N5432	reso	22H00038	H	600UL		340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 42

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2010			21.02	182	DNT	P 1	09H	-0.37	TECTEH			N5432	reso	22H00038	H	600UL	340972
2011	113	61	53.37	181	DNT	P 1	09H	-0.28	TECTEH			I3805	seco	22H00039	H	600UL	331895
2012					NDF		09H	-0.28	09H09H			T2170	seco	22H00197	H	600PP	345329
2013	115	61	3.16	177	DNG	P 1	03H	+7.16	TECTEH			M1637	seco	22H00038	H	600UL	340972
2014	117	61	2.14	175	DNT	P 1	10C	+0.09	TECTEH			I3805	seco	22H00039	H	600UL	331895
2015			4.52	182	DNT	P 1	10C	+0.50	TECTEH			I3805	seco	22H00039	H	600UL	331895
2016	119	61	4.08	190	DNG	P 1	01C	+3.13	TECTEH			M1637	seco	22H00038	H	600UL	340972
2017	121	61	6.37	183	DNT	P 1	09H	-0.30	TECTEH			I3805	seco	22H00039	H	600UL	331895
2018			5.36	21	NRC	2	TSC	+0.00	TECTEH			F3453	reso	22H00039	H	600UL	331895
2019	123	61	4.25	177	DNT	P 1	09H	-0.11	TECTEH			M1637	seco	22H00038	H	600UL	340972
2020	125	61	7.56	181	DNT	P 1	10H	-0.02	TECTEH			I3805	seco	22H00039	H	600UL	331895
2021	127	61	1.16	169	INR	P 1	09H	+0.47	TECTEH			N5432	reso	22H00038	H	600UL	340972
2022			4.26	189	DNT	P 1	09C	+0.46	TECTEH			M1637	seco	22H00038	H	600UL	340972
2023	129	61	0.47	75	MBM	5	07H	+21.71	TECTEH			F3453	reso	22H00039	H	600UL	331895
2024			2.25	180	DNT	P 1	09H	-0.49	TECTEH			F3453	reso	22H00039	H	600UL	331895
2025			31.08	179	DNT	P 1	09H	-0.34	TECTEH			I3805	seco	22H00039	H	600UL	331895
2026			4.01	178	DNG	P 1	09H	+13.43	TECTEH			I3805	seco	22H00039	H	600UL	331895
			8.48	182	DNG	P 1	09H	+14.44	TECTEH			I3805	seco	22H00039	H	600UL	331895
			2.66	180	DNG	P 1	DH	+29.73	TECTEH			I3805	seco	22H00039	H	600UL	331895
2029			2.45	179	DNG	P 1	VM	+29.66	TECTEH			I3805	seco	22H00039	H	600UL	331895
2030			2.90	184	DNG	P 1	10C	-1.31	TECTEH			I3805	seco	22H00039	H	600UL	331895
2031			2.92	176	DNT	P 1	10C	-0.04	TECTEH			I3805	seco	22H00039	H	600UL	331895
2032			15.98	180	DNT	P 1	10C	+1.01	TECTEH			I3805	seco	22H00039	H	600UL	331895
2033	131	61	1.98	181	INR	P 1	06H	+8.09	TECTEH			N5432	reso	22H00038	H	600UL	340972
2034	133	61	3.23	179	DNT	P 1	09H	+0.63	TECTEH			I3805	seco	22H00072	H	600UL	340945
2035	26	62	0.64	97	MBM	5	03C	+12.61	TECTEH			C5542	reso	22H00076	H	600UL	340945
2036	46	62	0.86	60	MBM	5	05H	+5.40	TECTEH			C5542	reso	22H00076	H	600UL	340945
2037	82	62	0.63	73	MBM	5	01H	+35.25	TECTEH			C3340	reso	22H00067	H	600UL	340945
2038			0.60	66	MBM	5	01H	+36.09	TECTEH			C3340	reso	22H00067	H	600UL	340945
2039			1.62	77	MBM	6	04H	+6.83	TECTEH			C3340	reso	22H00067	H	600UL	340945
2040			0.73	79	MBM	6	05H	+9.92	TECTEH			C3340	reso	22H00067	H	600UL	340945
2041			0.42	79	MBM	5	05H	+33.00	TECTEH			C3340	reso	22H00067	H	600UL	340945
2042			0.37	85	MBM	5	05H	+34.08	TECTEH			C3340	reso	22H00067	H	600UL	340945
2043			0.46	61	MBM	5	05H	+37.20	TECTEH			C3340	reso	22H00067	H	600UL	340945
2044			0.85	78	MBM	5	07H	+14.71	TECTEH			C3340	reso	22H00067	H	600UL	340945
2045			1.93	82	MBM	6	VH	+13.75	TECTEH			C3340	reso	22H00067	H	600UL	340945
2046			0.45	73	MBM	5	VH	+19.33	TECTEH			C3340	reso	22H00067	H	600UL	340945
2047			1.08	59	MBM	6	07C	+5.33	TECTEH			C3340	reso	22H00067	H	600UL	340945
2048			1.49	83	MBM	6	03C	+10.31	TECTEH			C3340	reso	22H00067	H	600UL	340945
2049			1.49	83	MBM	6	03C	+30.79	TECTEH			C3340	reso	22H00067	H	600UL	340945
2050			1.08	79	MBM	6	TSC	+18.53	TECTEH			C3340	reso	22H00067	H	600UL	340945
2051	90	62	3.13	176	DNG	P 1	VH	+9.85	TECTEH			N2574	seco	22H00067	H	600UL	340945
2052	92	62	3.98	176	DNT	P 1	03H	+1.24	TECTEH			M1637	seco	22H00038	H	600UL	340972
			13.62	183	DNT	P 1	09H	+0.02	TECTEH			M1637	seco	22H00038	H	600UL	340972
2054	96	62	6.58	180	DNT	P 1	08C	-0.58	TECTEH			M1637	seco	22H00038	H	600UL	340972
2055			2.00	182	DNG	P 1	08C	+1.93	TECTEH			M1637	seco	22H00038	H	600UL	340972
2056			6.13	182	DNG	P 1	08C	+2.97	TECTEH			M1637	seco	22H00038	H	600UL	340972
2057			4.29	183	DNG	P 1	08C	+6.56	TECTEH			M1637	seco	22H00038	H	600UL	340972

2058			4.45	182	DNG	P 1	07C	+17.14	TECTEH			M1637	seco	22H00038	H	600UL		340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 43

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2059		5.00	179	DNG	P 1	07C	+22.89	TECTEH			M1637	seco	22H00038	H	600UL	340972
2060		2.53	178	DNG	P 1	07C	+24.93	TECTEH			M1637	seco	22H00038	H	600UL	340972
2061		6.58	183	DNG	P 1	07C	+25.90	TECTEH			M1637	seco	22H00038	H	600UL	340972
2062		0.66	85	MBM	6	01C	+20.77	TECTEH			N5432	reso	22H00038	H	600UL	340972
2063		0.36	69	MBM	5	01C	+24.92	TECTEH			N5432	reso	22H00038	H	600UL	340972
2064	102	2.07	186	DNG	P 1	07H	+10.52	TECTEH			I3805	seco	22H00039	H	600UL	331895
2065	104	36.63	181	DNT	P 1	09H	-0.11	TECTEH			N5432	reso	22H00038	H	600UL	340972
2066	106	15.70	181	DNT	P 1	09H	+0.07	TECTEH			I3805	seco	22H00039	H	600UL	331895
2067	108	1.58	174	INR	P 1	06H	+1.55	TECTEH			N5432	reso	22H00038	H	600UL	340972
2068		4.69	174	DNG	P 1	09H	+14.66	TECTEH			M1637	seco	22H00038	H	600UL	340972
2069		1.04	88	MBM	6	06C	+2.09	TECTEH			N5432	reso	22H00038	H	600UL	340972
2070		0.44	85	MBM	5	05C	+36.68	TECTEH			N5432	reso	22H00038	H	600UL	340972
2071	110	0.96	87	MBM	5	04H	+20.34	TECTEH			F3453	reso	22H00039	H	600UL	331895
2072		0.65	88	MBM	5	04H	+21.77	TECTEH			F3453	reso	22H00039	H	600UL	331895
2073		1.22	80	MBM	5	05C	+15.09	TECTEH			F3453	reso	22H00039	H	600UL	331895
2074		0.53	85	MBM	5	05C	+31.77	TECTEH			F3453	reso	22H00039	H	600UL	331895
2075	112	146.3	177	DNT	P 1	09H	-0.15	TECTEH			M1637	seco	22H00038	H	600UL	340972
				NDF		09H	-0.15	09H09H			T2170	seco	22H00197	H	600PP	345329
		5.04	181	DNT	P 1	09C	+1.32	TECTEH			M1637	seco	22H00038	H	600UL	340972
2078	114			NDF		09H	+0.09	09H09H			T2170	seco	22H00197	H	600PP	345329
2079		50.25	180	DNT	P 1	09H	+0.09	TECTEH			I3805	seco	22H00039	H	600UL	331895
2080	116	3.44	183	DNT	P 1	09H	-0.28	TECTEH			M1637	seco	22H00038	H	600UL	340972
2081	118	2.14	182	DNG	P 1	VH	+33.97	TECTEH			I3805	seco	22H00039	H	600UL	331895
2082		4.41	183	DNT	P 1	10C	-0.39	TECTEH			F3453	reso	22H00039	H	600UL	331895
2083		4.83	180	DNT	P 1	10C	+0.09	TECTEH			I3805	seco	22H00039	H	600UL	331895
2084		5.12	178	DNT	P 1	10C	+0.97	TECTEH			I3805	seco	22H00039	H	600UL	331895
2085		2.45	182	DNG	P 1	09C	+19.59	TECTEH			F3453	reso	22H00039	H	600UL	331895
2086	120	3.89	181	DNT	P 1	10H	+0.02	TECTEH			M1637	seco	22H00038	H	600UL	340972
2087	122	2.24	179	DNG	P 1	08H	+18.10	TECTEH			I3805	seco	22H00039	H	600UL	331895
2088		15.01	182	DNT	P 1	10H	-0.05	TECTEH			I3805	seco	22H00039	H	600UL	331895
2089	126	0.24	70	MBM	5	04H	+23.75	TECTEH			F3453	reso	22H00039	H	600UL	331895
2090		5.59	181	DNT	P 1	09C	+0.40	TECTEH			I3805	seco	22H00039	H	600UL	331895
2091		0.25	116	INR	6	02C	+3.82	TECTEH			M7007	prim	22H00039	H	600UL	331895
2092	128			INF		09H	+0.47	TECTEH	HR		N5432	reso	22H00038	H	600UL	340972
2093		2.80	189	DNT	P 1	09C	+0.48	TECTEH			M1637	seco	22H00038	H	600UL	340972
2094	130	2.20	178	DNG	P 1	08H	+19.81	TECTEH			I3805	seco	22H00039	H	600UL	331895
2095		4.44	181	DNT	P 1	09H	+0.31	TECTEH			I3805	seco	22H00039	H	600UL	331895
2096		2.57	178	DNG	P 1	09H	+18.17	TECTEH			I3805	seco	22H00039	H	600UL	331895
2097		6.17	181	DNG	P 1	09H	+19.17	TECTEH			I3805	seco	22H00039	H	600UL	331895
2098		3.21	180	DNG	P 1	09H	+19.95	TECTEH			I3805	seco	22H00039	H	600UL	331895
2099		6.32	181	DNG	P 1	09H	+20.35	TECTEH			I3805	seco	22H00039	H	600UL	331895
2100		3.31	184	DNG	P 1	09H	+20.92	TECTEH			I3805	seco	22H00039	H	600UL	331895
[illegible]		3.31	180	DNG	P 1	09H	+21.77	TECTEH			I3805	seco	22H00039	H	600UL	331895
		2.74	177	DNT	P 1	10H	-0.71	TECTEH			I3805	seco	22H00039	H	600UL	331895
2103		3.84	174	DNT	P 1	10H	-0.18	TECTEH			I3805	seco	22H00039	H	600UL	331895
2104		9.18	182	DNT	P 1	10H	+0.44	TECTEH			I3805	seco	22H00039	H	600UL	331895
2105		16.28	181	DNT	P 1	10H	+0.92	TECTEH			I3805	seco	22H00039	H	600UL	331895
2106		3.47	180	DNT	P 1	VC	-0.38	TECTEH			I3805	seco	22H00039	H	600UL	331895

2107			6.71	182	DNG	P 1	10C	-1.21	TECTEH			I3805	seco	22H00039	H	600UL	331895

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 44

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2108			3.20	182	DNT	P 1	10C	-0.22	TECTEH			I3805	seco	22H00039	H	600UL	331895
2109			4.39	180	DNG	P 1	09C	+13.92	TECTEH			I3805	seco	22H00039	H	600UL	331895
2110			1.95	183	INR	P 1	09C	+14.18	TECTEH			I3805	seco	22H00039	H	600UL	331895
2111			2.64	180	DNG	P 1	09C	+16.65	TECTEH			I3805	seco	22H00039	H	600UL	331895
2112			2.81	177	DNG	P 1	09C	+18.04	TECTEH			I3805	seco	22H00039	H	600UL	331895
2113			3.48	178	DNG	P 1	09C	+19.75	TECTEH			I3805	seco	22H00039	H	600UL	331895
2114			7.82	181	DNG	P 1	09C	+20.72	TECTEH			I3805	seco	22H00039	H	600UL	331895
2115	132	62	3.18	181	DNT	P 1	09H	+0.54	TECTEH			I3805	seco	22H00072	H	600UL	340945
2116	136	62	0.19	133	VOL	2	08C	+1.89	08C08C	ENCODE		M7006	reso	22C00087	C	600PP	345298
2117			0.42	48	NQI	P 1	08C	+1.97	TECTEH			M7006	reso	22H00073	H	600UL	340927
2118	19	63	4.18	178	DNG	P 1	01C	+20.59	TECTEH			I3805	seco	22H00072	H	600UL	340945
2119	29	63	1.80	181	INR	P 1	VM	-1.12	TECTEH			I3805	seco	22H00072	H	600UL	340945
2120	31	63	0.48	81	MBM	5	04H	+20.78	TECTEH			M7006	reso	22H00073	H	600UL	340927
2121	33	63	2.80	178	DNT	P 1	VM	-1.84	TECTEH			I3805	seco	22H00072	H	600UL	340945
2122	41	63	0.74	85	MBM	5	05C	+6.07	TECTEH			C3340	reso	22H00072	H	600UL	340945
2123	53	63	0.65	58	MBM	5	VM	+0.00	TECTEH			C3340	reso	22H00072	H	600UL	340945
2124	69	63	2.94	176	DNG	P 1	04C	+14.82	TECTEH			N2574	seco	22H00067	H	600UL	340945
	77	63	0.58	81	MBM	5	05H	+20.49	TECTEH			C3340	reso	22H00067	H	600UL	340945
[illegible]			0.49	70	MBM	5	07H	+22.82	TECTEH			C3340	reso	22H00067	H	600UL	340945
2127			0.49	55	MBM	5	06C	+8.58	TECTEH			C3340	reso	22H00067	H	600UL	340945
2128	79	63	1.53	75	MBM	6	07H	+23.24	TECTEH			F3453	reso	22H00068	H	600UL	340927
2129			1.67	67	MBM	6	05C	+1.96	TECTEH			F3453	reso	22H00068	H	600UL	340927
2130	83	63	0.67	76	MBM	5	04C	+2.68	TECTEH			F3453	reso	22H00068	H	600UL	340927
2131	85	63	0.65	88	MBM	5	04C	+31.95	TECTEH			C3340	reso	22H00067	H	600UL	340945
2132	91	63	4.37	177	DNT	P 1	09H	-0.20	TECTEH			D4576	seco	22H00038	H	600UL	340972
2133	95	63	4.55	182	DNG	P 1	07C	+12.47	TECTEH			M1637	seco	22H00038	H	600UL	340972
2134	97	63	0.25	79	MBM	5	02H	+33.50	TECTEH			F3453	reso	22H00039	H	600UL	331895
2135	101	63	1.53	81	MBM	6	05H	+9.96	TECTEH			F3453	reso	22H00039	H	600UL	331895
2136	103	63	35.23	181	DNT	P 1	09H	+0.02	TECTEH			M1637	seco	22H00038	H	600UL	340972
2137	107	63	2.18	183	DNG	P 1	08H	+13.07	TECTEH			M1637	seco	22H00038	H	600UL	340972
2138			4.84	183	DNG	P 1	08H	+18.87	TECTEH			M1637	seco	22H00038	H	600UL	340972
2139	109	63			NDF		09H	-0.35	09H09H			J9815	prim	22H00197	H	600PP	345329
2140			6.17	181	DNT	P 1	09H	-0.35	TECTEH			I3805	seco	22H00039	H	600UL	331895
2141			0.49	72	21	P 2	VM	-1.82	TECTEH			M7007	prim	22H00039	H	600UL	331895
2142	111	63			NDF		09H	-0.17	09H09H			M9715	seco	22H00187	H	600PP	345332
2143			13.78	183	DNT	P 1	09H	-0.17	TECTEH			N5432	reso	22H00038	H	600UL	340972
2144			4.65	179	DNG	P 1	VM	+28.23	TECTEH			M1637	seco	22H00038	H	600UL	340972
2145	115	63	11.22	184	DNT	P 1	09H	-0.51	TECTEH			T7451	seco	22H00086	H	600UL	340912
2146					NDF		09H	-0.51	09H09H			T2170	seco	22H00197	H	600PP	345329
2147			10.58	182	DNT	P 1	09H	-0.11	TSCTEH			N5432	reso	22H00038	H	600UL	340972
2148	117	63	6.20	180	DNT	P 1	10C	-0.04	TECTEH			I3805	seco	22H00039	H	600UL	331895
2149			8.86	184	DNT	P 1	10C	+0.36	TECTEH			I3805	seco	22H00039	H	600UL	331895
[illegible]	119	63	41.54	181	DNT	P 1	10H	+0.11	TECTEH			M1637	seco	22H00038	H	600UL	340972
	121	63	4.39	181	DNG	P 1	09H	+17.48	TECTEH			I3805	seco	22H00039	H	600UL	331895
2152			11.82	181	DNG	P 1	09H	+18.45	TECTEH			I3805	seco	22H00039	H	600UL	331895
2153			8.42	180	DNG	P 1	10C	+3.26	TECTEH			I3805	seco	22H00039	H	600UL	331895
2154			1.82	39	NRC	2	TSC	+0.00	TECTEH			B4165	prim	22H00039	H	600UL	331895
2155	123	63	2.75	175	DNT	P 1	09H	-0.17	TECTEH			M1637	seco	22H00038	H	600UL	340972

2156			9.51	179	DNT	P 1	10H	-0.02	TECTEH			M1637	seco	22H00038	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 45

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2157					INF		DH	+20.00	TECTEH	HR		N5432	reso	22H00038	H	600UL	340972
2158			0.78	72	MBM	6	DH	+21.69	TECTEH			N5432	reso	22H00038	H	600UL	340972
2159	125	63	0.82	79	MBM	5	02H	+15.62	TECTEH			F3453	reso	22H00039	H	600UL	331895
2160	129	63	4.07	181	DNT	P 1	09H	+0.34	TECTEH			I3805	seco	22H00039	H	600UL	331895
2161	131	63			INF		09H	+0.45	TECTEH	HR		N5432	reso	22H00038	H	600UL	340972
2162	133	63	3.90	180	DNT	P 1	09H	+0.49	TECTEH			I3805	seco	22H00072	H	600UL	340945
2163			15.80	183	DNT	P 1	10H	-0.07	TECTEH			I3805	seco	22H00072	H	600UL	340945
2164			4.65	184	DNG	P 1	VM	+18.72	TECTEH			I3805	seco	22H00072	H	600UL	340945
2165	135	63	0.33	83	PLP	9	TSH	+0.49	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2166			2.09	180	DNG	P 1	03H	+31.05	TECTEH			M1637	seco	22H00073	H	600UL	340927
2167			3.11	180	DNG	P 1	DH	+11.44	TECTEH			M1637	seco	22H00073	H	600UL	340927
2168			2.00	181	DNG	P 1	04C	+24.68	TECTEH			M1637	seco	22H00073	H	600UL	340927
2169	24	64			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
2170			0.21	48	SAI	1	TSH	+1.19	TSHTSH	0.5		L2157	reso	22H00165	H	600PP	345290
2171			0.17	108	PID	4	TSH	+1.19	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
2172			0.17	119	SAI	2	TSH	+1.19	TSHTSH	0.4		L2157	reso	22H00165	H	600PP	345290
2173	36	64	4.17	176	DNG	P 1	01H	+15.48	TECTEH			I3805	seco	22H00072	H	600UL	340945
	38	64	3.70	184	DNG	P 1	VM	+8.71	TECTEH			M1637	seco	22H00073	H	600UL	340927
[illegible]	40	64	3.73	187	DNG	P 1	VM	+10.13	TECTEH			I3805	seco	22H00072	H	600UL	340945
2176			3.14	183	DNG	P 1	06C	+4.40	TECTEH			I3805	seco	22H00072	H	600UL	340945
2177	58	64	2.63	182	DNG	P 1	03C	+16.57	TECTEH			I3805	seco	22H00072	H	600UL	340945
2178	60	64	2.34	181	DNG	P 1	DH	+8.10	TECTEH			M0945	seco	22H00058	H	600UL	340944
2179	64	64	5.65	179	DNG	P 1	07C	+9.91	TECTEH			D4576	seco	22H00057	H	600UL	340945
2180	70	64	7.06	183	DNG	P 1	02H	+24.15	TECTEH			D4576	seco	22H00057	H	600UL	340945
2181			3.77	182	DNG	P 1	DH	+6.05	TECTEH			D4576	seco	22H00057	H	600UL	340945
2182			10.41	177	DNG	P 1	DH	+8.66	TECTEH			D4576	seco	22H00057	H	600UL	340945
2183	72	64	0.58	69	MBM	5	02H	+20.80	TECTEH			F6623	reso	22H00058	H	600UL	340944
2184			0.57	77	MBM	5	05H	+13.32	TECTEH			F6623	reso	22H00058	H	600UL	340944
2185	78	64			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
2186			0.08	113	SCI	P 1	TSH	+0.16	TSHTSH	0.2		F6623	reso	22H00147	H	600PP	345291
2187			0.00	0	SCI	1	TSH	+0.16	TSHTSH	0.0		F6623	reso	22H00147	H	600PP	345291
2188			0.12	142	PID	P 1	TSH	+0.16	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
2189	84	64	0.97	91	MBM	5	05H	+10.20	TECTEH			F6623	reso	22H00058	H	600UL	340944
2190			0.46	83	MBM	5	05C	+25.37	TECTEH			F6623	reso	22H00058	H	600UL	340944
2191			2.13	182	DNG	P 1	01C	+7.83	TECTEH			M0945	seco	22H00058	H	600UL	340944
2192	94	64			NDF		09H	+0.18	09H09H			T2170	seco	22H00197	H	600PP	345329
2193			5.07	178	DNT	P 1	09H	+0.18	TECTEH			D4576	seco	22H00038	H	600UL	340972
2194	98	64	18.87	182	DNT	P 1	09H	-0.02	TECTEH			I3805	seco	22H00039	H	600UL	331895
2195	100	64	0.43	96	MBM	5	04H	+27.03	TECTEH			N5432	reso	22H00038	H	600UL	340972
2196			0.55	87	MBM	5	05H	+14.71	TECTEH			N5432	reso	22H00038	H	600UL	340972
2197			4.73	176	DNT	P 1	09H	+0.02	TECTEH			M1637	seco	22H00038	H	600UL	340972
2198	102	64	3.23	182	DNT	P 1	09H	-0.17	TECTEH			I3805	seco	22H00039	H	600UL	331895
	108	64	0.35	75	MBM	5	03C	+17.89	TECTEH			N5432	reso	22H00038	H	600UL	340972
	110	64	5.60	180	DNG	P 1	VH	+23.93	TECTEH			F3453	reso	22H00039	H	600UL	331895
2201	112	64	2.01	180	DNG	P 1	VH	+28.90	TECTEH			M1637	seco	22H00038	H	600UL	340972
2202			2.10	178	DNT	P 1	VM	+1.95	TECTEH			M1637	seco	22H00038	H	600UL	340972
2203	120	64	4.94	176	DNT	P 1	09H	+0.05	TECTEH			M1637	seco	22H00038	H	600UL	340972
2204	122	64	8.37	182	DNT	P 1	10H	-0.02	TECTEH			I3805	seco	22H00039	H	600UL	331895

2205			2.33	182	DNG	P 1	08C	+16.34	TECTEH			I3805	seco	22H00039	H	600UL	331895

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 46

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2206	124	64	11.66	181	DNT	P 1	10H	-0.02	TECTEH			M1637	seco	22H00038	H	600UL	340972
2207	126	64	1.08	80	MBM	5	07H	+7.08	TECTEH			F3453	reso	22H00039	H	600UL	331895
2208			5.84	181	DNT	P 1	09H	-0.09	TECTEH			I3805	seco	22H00039	H	600UL	331895
2209			1.81	184	INR	P 1	09H	+19.69	TECTEH			I3805	seco	22H00039	H	600UL	331895
2210			0.53	75	MBM	5	03C	+26.04	TECTEH			F3453	reso	22H00039	H	600UL	331895
2211	128	64	2.23	186	DNT	P 1	09H	+0.45	TECTEH			M1637	seco	22H00038	H	600UL	340972
2212			3.05	179	DNG	P 1	10C	+10.09	TECTEH			M1637	seco	22H00038	H	600UL	340972
2213	130	64	31.62	181	DNT	P 1	09H	+0.02	TECTEH			I3805	seco	22H00039	H	600UL	331895
2214			0.54	49	DSI	P 1	10H	-0.07	TECTEH			B4165	prim	22H00039	H	600UL	331895
2215					NDF		10H	-0.07	10H10H			T2170	seco	22H00197	H	600PP	345329
2216			3.83	179	DNG	P 1	VC	+10.75	TECTEH			I3805	seco	22H00039	H	600UL	331895
2217	134	64	0.21	80	PLP	9	TSH	+0.41	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2218			5.26	177	DNT	P 1	09H	-0.43	TECTEH			M1637	seco	22H00073	H	600UL	340927
2219			8.46	175	DNT	P 1	09H	+0.56	TECTEH			M1637	seco	22H00073	H	600UL	340927
2220	136	64	0.42	80	PLP	9	TSH	+1.07	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2221			2.62	93	MBM	6	VM	+25.54	TECTEH			M7006	reso	22H00073	H	600UL	340927
2222	25	65			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
			0.12	123	PID	4	TSH	+0.90	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
			0.00	0	SAI	1	TSH	+0.90	TSHTSH	0.0		C5542	reso	22H00166	H	600PP	345329
2225			0.09	119	SAI	2	TSH	+0.90	TSHTSH	0.2		C5542	reso	22H00166	H	600PP	345329
2226	45	65	0.82	91	MBM	5	05C	+12.08	TECTEH			M7006	reso	22H00073	H	600UL	340927
2227	47	65	3.70	182	DNG	P 1	TSC	+24.21	TECTEH			I3805	seco	22H00072	H	600UL	340945
2228	75	65	2.88	179	DNG	P 1	01H	+26.68	TECTEH			M0945	seco	22H00058	H	600UL	340944
2229	79	65	2.86	176	DNG	P 1	01C	+11.60	TECTEH			M0945	seco	22H00058	H	600UL	340944
2230	87	65	0.67	93	MBM	5	04C	+35.99	TECTEH			F6623	reso	22H00058	H	600UL	340944
2231	93	65	7.67	178	DNG	P 1	TSH	+13.14	TECTEH			I3805	seco	22H00039	H	600UL	331895
2232			8.85	181	DNT	P 1	09H	-0.02	TECTEH			I3805	seco	22H00039	H	600UL	331895
2233			3.79	182	DNG	P 1	08C	+17.91	TECTEH			F3453	reso	22H00039	H	600UL	331895
2234	95	65	1.93	178	INR	P 1	09H	-0.41	TECTEH			D4576	seco	22H00038	H	600UL	340972
2235			4.11	181	DNG	P 1	08C	+4.52	TECTEH			D4576	seco	22H00038	H	600UL	340972
2236			3.39	179	DNG	P 1	07C	+3.71	TECTEH			D4576	seco	22H00038	H	600UL	340972
2237	97	65	2.42	182	DNG	P 1	08C	+6.71	TECTEH			I3805	seco	22H00039	H	600UL	331895
2238			5.31	179	DNG	P 1	08C	+7.59	TECTEH			I3805	seco	22H00039	H	600UL	331895
2239			2.31	179	DNG	P 1	08C	+8.93	TECTEH			I3805	seco	22H00039	H	600UL	331895
2240			6.44	179	DNG	P 1	08C	+9.94	TECTEH			I3805	seco	22H00039	H	600UL	331895
2241			2.80	179	DNG	P 1	08C	+19.11	TECTEH			I3805	seco	22H00039	H	600UL	331895
2242	99	65	13.33	180	DNT	P 1	09H	+0.02	TECTEH			D4576	seco	22H00038	H	600UL	340972
2243	105	65	33.62	181	DNT	P 1	09H	-0.02	TECTEH			M1637	seco	22H00038	H	600UL	340972
2244	109	65	0.47	84	MBM	5	VM	+17.72	TECTEH			N5432	reso	22H00038	H	600UL	340972
2245	111	65	0.27	84	MBM	5	03H	+18.19	TECTEH			F3453	reso	22H00039	H	600UL	331895
2246			2.30	180	DNG	P 1	VH	+2.97	TECTEH			I3805	seco	22H00039	H	600UL	331895
2247	113	65	7.04	181	DNT	P 1	09H	-0.26	TECTEH			M1637	seco	22H00038	H	600UL	340972
2248	115	65			NDF		09H	-0.02	09H09H			T2170	seco	22H00197	H	600PP	345329
			9.08	182	DNT	P 1	09H	-0.02	TECTEH			I3805	seco	22H00039	H	600UL	331895
2250	117	65	24.94	180	DNT	P 1	09H	-0.24	TECTEH			M1637	seco	22H00038	H	600UL	340972
2251	121	65	4.58	208	NRC	2	TSC	+0.00	TECTEH			M1680	reso	22H00038	H	600UL	340972
2252	123	65	2.18	177	DNT	P 1	10H	+0.00	TECTEH			I3805	seco	22H00039	H	600UL	331895
2253			0.24	53	MBM	5	TSC	+28.26	TECTEH			F3453	reso	22H00039	H	600UL	331895

2254	129	65	1.85	190	INR	P 1	01H	+14.62	TECTEH				N5432	reso	22H00038	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 47

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2255			1.49	178	INR	P 1	09H	+0.45	TECTEH			D4576	seco	22H00038	H	600UL	340972
2256	131	65	6.12	179	DNT	P 1	09H	-0.32	TECTEH			M1637	seco	22H00038	H	600UL	340972
2257					NDF		09H	+0.29	09H09H			F0075	seco	22H00204	H	600PP	345329
2258			26.01	179	DNT	P 1	09H	+0.29	TECTEH			M1637	seco	22H00038	H	600UL	340972
2259	133	65	2.00	184	DNG	P 1	VH	+3.43	TECTEH			I3805	seco	22H00072	H	600UL	340945
2260			2.86	179	DNG	P 1	VH	+7.66	TECTEH			I3805	seco	22H00072	H	600UL	340945
2261	135	65	0.38	82	PLP	9	TSH	+0.14	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2262			2.16	173	DNT	P 1	09H	-0.40	TECTEH			I3805	seco	22H00072	H	600UL	340945
2263			4.26	183	DNT	P 1	09H	+0.45	TECTEH			I3805	seco	22H00072	H	600UL	340945
2264	137	65	0.38	81	PLP	9	TSH	+0.21	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2265	28	66	3.35	179	DNT	P 1	VM	+1.61	TECTEH			I3805	seco	22H00079	H	600UL	340943
2266	32	66			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
2267			0.32	17	PID	4	TSH	-2.15	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
2268			0.08	18	SAI	2	TSH	-2.15	TSHTSH	0.2	PWSCC	L2157	reso	22H00165	H	600PP	345290
2269			0.06	10	SAI	1	TSH	-2.15	TSHTSH	0.3	PWSCC	L2157	reso	22H00165	H	600PP	345290
2270	38	66	2.83	182	DNG	P 1	02C	+36.80	TECTEH			N5977	seco	22H00079	H	600UL	331969
2271	40	66	3.56	184	DNG	P 1	VM	+9.82	TECTEH			I3805	seco	22H00079	H	600UL	340943
	60	66	4.21	181	DNG	P 1	VM	+19.95	TECTEH			M0945	seco	22H00058	H	600UL	340944
[illegible]	66	66	3.47	183	DNG	P 1	07H	+22.45	TECTEH			D4576	seco	22H00057	H	600UL	340945
2274			3.82	181	DNG	P 1	07C	+7.73	TECTEH			D4576	seco	22H00057	H	600UL	340945
2275	68	66	0.45	79	MBM	5	03C	+6.47	TECTEH			F6623	reso	22H00058	H	600UL	340944
2276	76	66	0.51	89	MBM	5	01H	+28.48	TECTEH			F6623	reso	22H00058	H	600UL	340944
2277	86	66	0.56	72	MBM	5	VM	+18.25	TECTEH			F3453	reso	22H00057	H	600UL	340945
2278	92	66	2.80	176	DNT	P 1	09C	+0.18	TECTEH			D4576	seco	22H00038	H	600UL	340972
2279			4.63	178	DNG	P 1	07C	+10.01	TECTEH			D4576	seco	22H00038	H	600UL	340972
2280			3.07	177	DNG	P 1	07C	+20.22	TECTEH			D4576	seco	22H00038	H	600UL	340972
2281			3.67	177	DNG	P 1	07C	+24.10	TECTEH			D4576	seco	22H00038	H	600UL	340972
2282	96	66	6.83	180	DNG	P 1	08H	+12.51	TECTEH			D4576	seco	22H00038	H	600UL	340972
2283			2.92	178	DNT	P 1	08C	-0.19	TECTEH			D4576	seco	22H00038	H	600UL	340972
2284	104	66	73.43	179	DNT	P 1	09H	+0.02	TECTEH			M1637	seco	22H00038	H	600UL	340972
2285					NDF		09H	+0.02	09H09H			T2170	seco	22H00197	H	600PP	345329
2286			0.57	79	MBM	5	VC	+4.26	TECTEH			N5432	reso	22H00038	H	600UL	340972
2287	106	66	85.53	179	DNT	P 1	09H	-0.02	TECTEH			I3805	seco	22H00039	H	600UL	331895
2288					NDF		09H	-0.02	09H09H			F0075	seco	22H00204	H	600PP	345329
2289	108	66	2.82	183	DNG	P 1	05H	+26.48	TECTEH			M1637	seco	22H00038	H	600UL	340972
2290	110	66	2.36	178	DNT	P 1	09H	-0.02	TECTEH			I3805	seco	22H00039	H	600UL	331895
2291			0.58	71	MBM	5	04C	+5.39	TECTEH			F3453	reso	22H00039	H	600UL	331895
2292			1.37	78	MBM	5	03C	+24.00	TECTEH			F3453	reso	22H00039	H	600UL	331895
2293			1.10	79	MBM	5	03C	+27.82	TECTEH			F3453	reso	22H00039	H	600UL	331895
2294			0.50	74	MBM	5	02C	+25.01	TECTEH			F3453	reso	22H00039	H	600UL	331895
2295	112	66			INF		09C	+16.72	TECTEH	HR		N5432	reso	22H00038	H	600UL	340972
2296	114	66	12.69	182	DNT	P 1	09H	-0.37	TECTEH			I3805	seco	22H00039	H	600UL	331895
[illegible]	116	66	30.27	181	DNT	P 1	09H	-0.13	TECTEH			M1637	seco	22H00038	H	600UL	340972
	118	66	2.06	180	DNG	P 1	09H	+3.25	TECTEH			I3805	seco	22H00039	H	600UL	331895
2299			2.72	181	DNG	P 1	09H	+18.48	TECTEH			I3805	seco	22H00039	H	600UL	331895
2300			4.53	178	DNG	P 1	09C	+13.71	TECTEH			I3805	seco	22H00039	H	600UL	331895
2301	120	66	2.00	181	DNG	P 1	05H	+11.87	TECTEH			M1637	seco	22H00038	H	600UL	340972
2302			5.13	177	DNG	P 1	06H	+13.11	TECTEH			M1637	seco	22H00038	H	600UL	340972

2303			11.69	178	DNG	P 1	08H	+5.16	TECTEH			M1637	seco	22H00038	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 48

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2304		7.18	180	DNG	P 1	09H	+6.65	TECTEH			M1637	seco	22H00038	H	600UL	340972
2305		5.14	180	DNG	P 1	09H	+7.50	TECTEH			M1637	seco	22H00038	H	600UL	340972
2306		4.36	182	DNG	P 1	09H	+8.55	TECTEH			M1637	seco	22H00038	H	600UL	340972
2307		5.42	179	DNG	P 1	09H	+17.81	TECTEH			M1637	seco	22H00038	H	600UL	340972
2308		3.17	175	DNG	P 1	09H	+18.73	TECTEH			M1637	seco	22H00038	H	600UL	340972
2309		8.68	179	DNG	P 1	09H	+19.69	TECTEH			M1637	seco	22H00038	H	600UL	340972
2310		14.64	181	DNG	P 1	10H	+1.88	TECTEH			M1637	seco	22H00038	H	600UL	340972
2311		3.57	177	DNG	P 1	VM	+3.59	TECTEH			M1637	seco	22H00038	H	600UL	340972
2312		10.48	175	DNT	P 1	10C	-0.71	TECTEH			M1637	seco	22H00038	H	600UL	340972
2313		36.72	179	DNT	P 1	10C	-0.36	TECTEH			M1637	seco	22H00038	H	600UL	340972
2314		3.75	171	DNT	P 1	10C	+0.30	TECTEH			M1637	seco	22H00038	H	600UL	340972
2315		13.08	183	DNT	P 1	10C	+0.64	TECTEH			M1637	seco	22H00038	H	600UL	340972
2316		12.93	180	DNG	P 1	09C	+19.44	TECTEH			M1637	seco	22H00038	H	600UL	340972
2317		11.59	181	DNG	P 1	09C	+19.91	TECTEH			M1637	seco	22H00038	H	600UL	340972
2318	124	2.67	180	DNG	P 1	08H	+18.38	TECTEH			M1637	seco	22H00038	H	600UL	340972
2319		4.37	181	DNG	P 1	09H	+19.35	TECTEH			M1637	seco	22H00038	H	600UL	340972
2320		8.44	182	DNG	P 1	09H	-1.25	TECTEH			M1637	seco	22H00038	H	600UL	340972
		3.16	181	DNT	P 1	09H	-0.37	TECTEH			M1637	seco	22H00038	H	600UL	340972
[illegible]		5.44	178	DNT	P 1	09H	+0.13	TECTEH			M1637	seco	22H00038	H	600UL	340972
2323		7.50	181	DNT	P 1	09H	+0.63	TECTEH			M1637	seco	22H00038	H	600UL	340972
2324		16.36	183	DNG	P 1	09H	+1.17	TECTEH			M1637	seco	22H00038	H	600UL	340972
2325		4.94	180	DNG	P 1	09H	+1.73	TECTEH			M1637	seco	22H00038	H	600UL	340972
2326		3.58	178	DNG	P 1	09H	+2.20	TECTEH			M1637	seco	22H00038	H	600UL	340972
2327		2.20	182	DNG	P 1	09H	+2.76	TECTEH			M1637	seco	22H00038	H	600UL	340972
2328		2.54	177	DNG	P 1	09H	+3.26	TECTEH			M1637	seco	22H00038	H	600UL	340972
2329		2.69	183	DNG	P 1	09H	+3.64	TECTEH			M1637	seco	22H00038	H	600UL	340972
2330		4.50	180	DNG	P 1	09H	+4.31	TECTEH			M1637	seco	22H00038	H	600UL	340972
2331		8.03	181	DNG	P 1	09H	+6.67	TECTEH			M1637	seco	22H00038	H	600UL	340972
2332		6.26	182	DNG	P 1	09H	+13.90	TECTEH			M1637	seco	22H00038	H	600UL	340972
2333		7.20	181	DNG	P 1	09H	+14.53	TECTEH			M1637	seco	22H00038	H	600UL	340972
2334		19.94	180	DNG	P 1	09H	+15.65	TECTEH			M1637	seco	22H00038	H	600UL	340972
2335		5.03	181	DNT	P 1	10H	+0.55	TECTEH			M1637	seco	22H00038	H	600UL	340972
2336		5.72	185	DNG	P 1	09C	+1.58	TECTEH			M1637	seco	22H00038	H	600UL	340972
2337		4.95	181	DNG	P 1	09C	+2.74	TECTEH			M1637	seco	22H00038	H	600UL	340972
2338		7.05	176	DNG	P 1	09C	+8.00	TECTEH			M1637	seco	22H00038	H	600UL	340972
2339		14.16	182	DNG	P 1	09C	+9.01	TECTEH			M1637	seco	22H00038	H	600UL	340972
2340		5.05	178	DNG	P 1	09C	+9.43	TECTEH			M1637	seco	22H00038	H	600UL	340972
2341	130	4.25	180	DNT	P 1	09H	-0.28	TECTEH			I3805	seco	22H00039	H	600UL	331895
2342		14.09	176	DNT	P 1	09H	+0.40	TECTEH			I3805	seco	22H00039	H	600UL	331895
2343		2.75	182	DNG	P 1	09C	+18.04	TECTEH			I3805	seco	22H00039	H	600UL	331895
2344	132	10.13	180	DNT	P 1	09H	+0.34	TECTEH			I3805	seco	22H00072	H	600UL	340945
2345	134	0.26	80	PLP	9	TSH	+0.11	TSHTSH			S8982	seco	22H00193	H	600PP	345345
[illegible]		2.66	178	DNG	P 1	VH	+25.45	TECTEH			M1637	seco	22H00073	H	600UL	340927
	31	1.43	81	MBM	6	01C	+28.90	TECTEH			C5542	reso	22H00078	H	600UL	331969
2348	67	3.71	178	DNG	P 1	04H	+14.07	TECTEH			D4576	seco	22H00057	H	600UL	340945
2349	77	0.81	81	MBM	5	05H	+30.87	TECTEH			F3453	reso	22H00057	H	600UL	340945
2350		0.36	77	MBM	5	01C	+23.76	TECTEH			F3453	reso	22H00057	H	600UL	340945
2351	81	0.50	72	MBM	5	03C	+26.75	TECTEH			F3453	reso	22H00057	H	600UL	340945

2352			0.52	71	MBM	5	02C	+21.32	TECTEH			F3453	reso	22H00057	H	600UL	340945

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 49

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2353	89	67	0.53	84	MBM	5	04H	+8.23	TECTEH			F3453	reso	22H00057	H	600UL	340945
2354	91	67			INF		08H	+6.94	TECTEH	HR		N5432	reso	22H00038	H	600UL	340972
2355			8.48	181	DNG	P 1	08H	+10.57	TECTEH			D4576	seco	22H00038	H	600UL	340972
2356			6.17	182	DNT	P 1	09H	-0.90	TECTEH			D4576	seco	22H00038	H	600UL	340972
2357	95	67	3.88	178	DNG	P 1	07C	+2.80	TECTEH			D4576	seco	22H00038	H	600UL	340972
2358			2.88	178	DNG	P 1	07C	+6.54	TECTEH			D4576	seco	22H00038	H	600UL	340972
2359			2.92	180	DNG	P 1	07C	+18.59	TECTEH			D4576	seco	22H00038	H	600UL	340972
2360	105	67	69.64	179	DNT	P 1	09H	-0.02	TECTEH			I3805	seco	22H00039	H	600UL	331895
2361					NDF		09H	-0.02	09H09H			T2170	seco	22H00197	H	600PP	345329
2362	111	67	0.75	72	MBM	5	04H	+31.22	TECTEH			N5432	reso	22H00038	H	600UL	340972
2363	113	67	13.05	180	DNT	P 1	09H	+0.02	TECTEH			I3805	seco	22H00039	H	600UL	331895
2364	115	67	36.21	182	DNT	P 1	09H	-0.06	TECTEH			N5432	reso	22H00038	H	600UL	340972
2365	117	67	2.53	183	DNT	P 1	10H	-0.02	TECTEH			I3805	seco	22H00039	H	600UL	331895
2366			5.06	179	DNT	P 1	10C	+0.57	TECTEH			I3805	seco	22H00039	H	600UL	331895
2367	121	67	2.21	28	NRC	2	TSC	+0.00	TECTEH			B4165	prim	22H00039	H	600UL	331895
2368	123	67	5.06	179	DNT	P 1	10H	-0.02	TECTEH			D4576	seco	22H00038	H	600UL	340972
2369	125	67	0.44	66	MBM	5	08C	+14.13	TECTEH			F3453	reso	22H00039	H	600UL	331895
	129	67	0.61	73	MBM	5	01H	+20.30	TECTEH			N5432	reso	22H00043	H	600UL	331895
			2.28	185	DNT	P 1	09H	-0.41	TECTEH			M2655	seco	22H00043	H	600UL	331895
2372			2.67	180	DNT	P 1	09H	+0.38	TECTEH			M2655	seco	22H00043	H	600UL	331895
2373			2.96	180	DNG	P 1	10C	+11.07	TECTEH			M2655	seco	22H00043	H	600UL	331895
2374	131	67	8.41	179	DNT	P 1	09H	+0.36	TECTEH			F0075	seco	22H00042	H	600UL	340972
2375	135	67	0.61	103	MBM	5	03C	+23.04	TECTEH			M7006	reso	22H00073	H	600UL	340927
2376	26	68	0.47	78	MBM	5	01C	+10.64	TECTEH			M7006	reso	22H00073	H	600UL	340927
2377	36	68	0.42	84	MBM	5	05C	+30.04	TECTEH			M7006	reso	22H00073	H	600UL	340927
2378	38	68	3.82	182	DNG	P 1	DH	+8.21	TECTEH			I3805	seco	22H00072	H	600UL	340945
2379	54	68	2.40	179	DNT	P 1	VM	+1.67	TECTEH			D4576	seco	22H00057	H	600UL	340945
2380	60	68	2.92	180	DNG	P 1	VM	+20.25	TECTEH			M0945	seco	22H00058	H	600UL	340944
2381	62	68	2.35	182	DNG	P 1	VM	+21.25	TECTEH			D4576	seco	22H00057	H	600UL	340945
2382	64	68	1.18	103	MBM	5	03H	+18.01	TECTEH			F6623	reso	22H00058	H	600UL	340944
2383			2.81	182	DNG	P 1	07C	+13.92	TECTEH			M0945	seco	22H00058	H	600UL	340944
2384					INF		07C	+25.06	TECTEH	HR		F6623	reso	22H00058	H	600UL	340944
2385			5.15	183	DNG	P 1	07C	+26.06	TECTEH			M0945	seco	22H00058	H	600UL	340944
2386	66	68	3.85	182	DNG	P 1	07H	+13.04	TECTEH			D4576	seco	22H00057	H	600UL	340945
2387	78	68			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
2388			0.17	68	SAI	2	TSH	+0.44	TSHTSH	0.3		F6623	reso	22H00144	H	600PP	345291
2389			0.17	69	PID	4	TSH	+0.44	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
2390			0.12	140	SAI	1	TSH	+0.44	TSHTSH	0.2		F6623	reso	22H00144	H	600PP	345291
2391	82	68	2.58	182	DNG	P 1	VH	+15.31	TECTEH			D4576	seco	22H00057	H	600UL	340945
2392	84	68			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
2393			0.00	0	SAI	1	TSH	+0.23	TSHTSH	0.0		A9608	reso	22H00145	H	600PP	345329
2394			0.08	112	SAI	2	TSH	+0.23	TSHTSH	0.2		A9608	reso	22H00145	H	600PP	345329
2395			0.10	140	PID	4	TSH	+0.23	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
	86	68	0.47	85	MBM	5	04H	+29.30	TECTEH			F3453	reso	22H00057	H	600UL	340945
2397	88	68	0.44	73	MBM	5	07H	+14.50	TECTEH			F3453	reso	22H00057	H	600UL	340945
2398			5.44	179	DNG	P 1	VC	+5.47	TECTEH			D4576	seco	22H00057	H	600UL	340945
2399			14.71	180	DNG	P 1	VC	+6.03	TECTEH			D4576	seco	22H00057	H	600UL	340945
2400			0.45	53	MBM	5	02C	+32.02	TECTEH			F3453	reso	22H00057	H	600UL	340945

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38
PLANT: CCNPP
UNIT: 2
SG: 22
DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 50

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2401	92	68	2.70	180	DNG	P 1	07C +20.65	TECTEH			F0075	seco	22H00042	H	600UL	340972
2402	112	68	14.49	182	DNT	P 1	09H -0.02	TECTEH			F0075	seco	22H00042	H	600UL	340972
2403	114	68			NDF		09H -0.15	09H09H			T2170	seco	22H00197	H	600PP	345329
2404			54.32	179	DNT	P 1	09H -0.15	TECTEH			M2655	seco	22H00043	H	600UL	331895
2405	116	68	31.30	181	DNT	P 1	09H -0.28	TECTEH			F0075	seco	22H00042	H	600UL	340972
2406	118	68			INF	P 1	08H -0.19	TECTEH	HR		N5432	reso	22H00043	H	600UL	331895
2407			47.29	181	DNT	P 1	09H -0.19	TECTEH			M2655	seco	22H00043	H	600UL	331895
2408					NDF		09H -0.19	09H09H			T2170	seco	22H00197	H	600PP	345329
2409	120	68	3.97	182	DNG	P 1	08H +11.41	TECTEH			F0075	seco	22H00042	H	600UL	340972
2410			3.65	179	DNT	P 1	09H -0.06	TECTEH			F0075	seco	22H00042	H	600UL	340972
2411			1.86	183	INR	P 1	09H +6.44	TECTEH			F0075	seco	22H00042	H	600UL	340972
2412			16.25	182	DNG	P 1	09H +11.87	TECTEH			F0075	seco	22H00042	H	600UL	340972
2413			5.73	180	DNG	P 1	09H +12.76	TECTEH			F0075	seco	22H00042	H	600UL	340972
2414			4.18	182	DNT	P 1	10C +0.27	TECTEH			F0075	seco	22H00042	H	600UL	340972
2415			0.54	62	MBM	5	03C +22.37	TECTEH			F3453	reso	22H00042	H	600UL	340972
2416	124	68	4.18	179	DNT	P 1	09H +0.02	TECTEH			F0075	seco	22H00042	H	600UL	340972
2417			5.54	179	DNG	P 1	09H +9.77	TECTEH			F0075	seco	22H00042	H	600UL	340972
2418			4.04	179	DNG	P 1	09H +16.74	TECTEH			F0075	seco	22H00042	H	600UL	340972
			3.25	180	DNG	P 1	09H +17.03	TECTEH			F0075	seco	22H00042	H	600UL	340972
			2.25	182	DNG	P 1	09H +18.11	TECTEH			F0075	seco	22H00042	H	600UL	340972
2421			2.52	180	DNG	P 1	09H +18.85	TECTEH			F0075	seco	22H00042	H	600UL	340972
2422			2.37	179	DNG	P 1	09H +20.26	TECTEH			F0075	seco	22H00042	H	600UL	340972
2423			2.44	177	DNT	P 1	10H -0.02	TECTEH			F0075	seco	22H00042	H	600UL	340972
2424	126	68	2.12	177	DNG	P 1	02H +34.67	TECTEH			M2655	seco	22H00043	H	600UL	331895
2425			4.42	182	DNT	P 1	06H +0.50	TECTEH			M2655	seco	22H00043	H	600UL	331895
2426			3.34	176	DNT	P 1	09H -0.04	TECTEH			M2655	seco	22H00043	H	600UL	331895
2427	128	68	5.36	182	DNG	P 1	TSH +2.90	TECTEH			F0075	seco	22H00042	H	600UL	340972
2428					NDF		09H +0.00	09H09H			N5432	reso	22H00190	H	600PP	345345
2429			13.16	180	DNT	P 1	09H +0.00	TECTEH			F0075	seco	22H00042	H	600UL	340972
2430	132	68			NDF		09H +0.34	09H09H			S8982	seco	22H00193	H	600PP	345345
2431			7.68	182	DNT	P 1	09H +0.34	TECTEH			I3805	seco	22H00072	H	600UL	340945
2432	27	69	2.58	179	DNG	P 1	VM +3.55	TECTEH			M1637	seco	22H00073	H	600UL	340927
2433	47	69	1.88	80	MBM	6	05C +2.36	TECTEH			F6623	reso	22H00058	H	600UL	340944
2434			5.45	183	DNG	P 1	TSC +29.49	TECTEH			M0945	seco	22H00058	H	600UL	340944
2435	53	69	2.79	182	DNG	P 1	02C +9.95	TECTEH			D4576	seco	22H00057	H	600UL	340945
2436	57	69	0.65	77	MBM	5	03H +34.27	TECTEH			F3453	reso	22H00057	H	600UL	340945
2437	61	69	2.41	181	DNG	P 1	01H +12.02	TECTEH			D4576	seco	22H00057	H	600UL	340945
2438	85	69	0.64	84	MBM	5	TSH +25.78	TECTEH			F3453	reso	22H00057	H	600UL	340945
2439	87	69	0.73	3	IDM	2	TSC -1.04	TSCTSC	HR		C3340	reso	22C00039	C	600PP	345352
2440	93	69	4.65	184	DNG	P 1	08C +14.11	TECTEH			M2655	seco	22H00043	H	600UL	331895
2441	95	69			NDF		09C +0.15	09C09C			F6623	reso	22C00087	C	600PP	345298
2442			0.79	38	DSI	P 1	09C +0.15	TECTEH			F0075	seco	22H00042	H	600UL	340972
2443			2.93	180	DNG	P 1	08C +8.90	TECTEH			F0075	seco	22H00042	H	600UL	340972
2444	97	69			NDF		09C +0.11	09C09C			F6623	reso	22C00087	C	600PP	345298
			0.33	76	DSI	P 1	09C +0.11	TECTEH			H3464	prim	22H00043	H	600UL	331895
2446	99	69	10.28	179	DNT	P 1	09H +0.00	TECTEH			F0075	seco	22H00042	H	600UL	340972
2447			3.36	183	DNG	P 1	08C +10.85	TECTEH			F0075	seco	22H00042	H	600UL	340972
2448	105	69	5.00	180	DNT	P 1	09H -0.02	TECTEH			M2655	seco	22H00043	H	600UL	331895
2449			0.47	77	DSI	P 1	09C +0.15	TECTEH			M2655	seco	22H00043	H	600UL	331895

2450					NDF		09C	+0.15	09C09C			F6623	reso	22C00087	C	600PP	345298

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 51

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2451	109	69	2.08	179	DNG	P 1	TSH	+13.93	TECTEH			M2655	seco	22H00043	H	600UL	331895
2452			2.39	180	DNG	P 1	VM	+28.36	TECTEH			M2655	seco	22H00043	H	600UL	331895
2453	111	69	0.39	87	MBM	5	TSH	+22.00	TECTEH			F3453	reso	22H00042	H	600UL	340972
2454			0.74	81	MBM	5	03H	+14.29	TECTEH			F3453	reso	22H00042	H	600UL	340972
2455			0.35	70	MBM	5	03H	+17.35	TECTEH			F3453	reso	22H00042	H	600UL	340972
2456			4.31	178	DNT	P 1	09H	-0.04	TECTEH			F0075	seco	22H00042	H	600UL	340972
2457			3.64	176	DNG	P 1	VH	+3.53	TECTEH			F0075	seco	22H00042	H	600UL	340972
2458	113	69	0.98	82	MBM	5	04H	+13.22	TECTEH			N5432	reso	22H00043	H	600UL	331895
2459	115	69			NDF		08H	-0.33	08H08H			F0075	seco	22H00204	H	600PP	345329
2460			16.83	184	DNT	P 1	08H	-0.33	TECTEH			F0075	seco	22H00042	H	600UL	340972
2461	117	69	27.43	181	DNT	P 1	09H	-0.24	TECTEH			M2655	seco	22H00043	H	600UL	331895
2462	121	69	2.30	179	DNG	P 1	07H	+18.89	TECTEH			M2655	seco	22H00043	H	600UL	331895
2463			7.09	178	DNG	P 1	07H	+22.08	TECTEH			M2655	seco	22H00043	H	600UL	331895
2464			7.03	179	DNG	P 1	08H	+15.16	TECTEH			M2655	seco	22H00043	H	600UL	331895
2465			21.93	178	DNG	P 1	08H	+20.93	TECTEH			M2655	seco	22H00043	H	600UL	331895
2466			5.29	180	DNT	P 1	09H	-0.43	TECTEH			M2655	seco	22H00043	H	600UL	331895
2467			5.29	177	DNG	P 1	09H	+1.50	TECTEH			M2655	seco	22H00043	H	600UL	331895
			2.57	177	DNG	P 1	09H	+4.66	TECTEH			M2655	seco	22H00043	H	600UL	331895
			24.90	178	DNG	P 1	09H	+5.71	TECTEH			N5432	reso	22H00043	H	600UL	331895
2470			2.86	175	DNG	P 1	09H	+6.37	TECTEH			M2655	seco	22H00043	H	600UL	331895
2471			3.46	176	DNG	P 1	09H	+7.27	TECTEH			M2655	seco	22H00043	H	600UL	331895
2472			8.92	180	DNG	P 1	09H	+16.60	TECTEH			M2655	seco	22H00043	H	600UL	331895
2473			2.15	178	DNT	P 1	10H	+0.79	TECTEH			M2655	seco	22H00043	H	600UL	331895
2474			2.74	182	DNT	P 1	10C	-0.55	TECTEH			M2655	seco	22H00043	H	600UL	331895
2475					INF	P 1	09C	-1.25	TECTEH	HR		N5432	reso	22H00043	H	600UL	331895
2476			2.92	179	DNT	P 1	09C	-0.70	TECTEH			M2655	seco	22H00043	H	600UL	331895
2477			19.89	179	DNG	P 1	09C	+9.66	TECTEH			M2655	seco	22H00043	H	600UL	331895
2478			6.21	181	DNG	P 1	08C	+21.35	TECTEH			M2655	seco	22H00043	H	600UL	331895
2479			5.11	213	NRC	2	TSC	+0.00	TECTEH			M1680	reso	22H00043	H	600UL	331895
2480	127	69	1.00	106	INR	6	05H	+11.63	TECTEH			F0075	seco	22H00042	H	600UL	340972
2481			2.54	181	DNT	P 1	06H	+0.26	TECTEH			F0075	seco	22H00042	H	600UL	340972
2482			8.50	181	DNT	P 1	09H	-0.06	TECTEH			F0075	seco	22H00042	H	600UL	340972
2483	129	69	40.98	177	DNT	P 1	09H	+0.04	TECTEH			M2655	seco	22H00043	H	600UL	331895
2484			11.80	180	DNT	P 1	10H	-0.09	TECTEH			M2655	seco	22H00043	H	600UL	331895
2485					NDF		10H	-0.09	10H10H			J9815	prim	22H00192	H	5602C	326272
2486			2.25	178	DNT	P 1	VH	-1.98	TECTEH			M2655	seco	22H00043	H	600UL	331895
2487	133	69	10.80	179	DNT	P 1	09H	+0.40	TECTEH			I3805	seco	22H00072	H	600UL	340945
2488	137	69	10.27	175	DNG	P 1	DH	+3.84	TECTEH			H4599	seco	22H00090	H	600UL	340943
2489	32	70			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
2490			0.29	15	SAI	1	TSH	-2.10	TSHTSH	0.3	PWSCC	L2157	reso	22H00145	H	600PP	345329
2491			0.88	23	PID	4	TSH	-2.10	TSHTSH	080		F3453	reso	22H00181	H	600PP	345332
2492			0.38	21	SAI	2	TSH	-2.10	TSHTSH	0.2	PWSCC	L2157	reso	22H00145	H	600PP	345329
[illegible]	38	70	2.85	182	DNG	P 1	VM	+8.94	TECTEH			M1637	seco	22H00073	H	600UL	340927
	42	70	3.37	179	DNG	P 1	VM	+10.98	TECTEH			M1637	seco	22H00073	H	600UL	340927
2495	52	70	0.54	86	MBM	5	02C	+17.39	TECTEH			F3453	reso	22H00057	H	600UL	340945
2496	54	70	0.75	75	MBM	5	01H	+29.48	TECTEH			F6623	reso	22H00058	H	600UL	340944
2497			1.19	84	MBM	5	01H	+34.31	TECTEH			F6623	reso	22H00058	H	600UL	340944
2498			1.36	88	MBM	5	02H	+23.26	TECTEH			F6623	reso	22H00058	H	600UL	340944

2499			0.55	154	21	P 2	03H	-0.50	TECTEH				F6623	reso	22H00058	H	600UL	340944

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 52

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2500	56	70	1.49	47	MBM	5	03H	+5.16	TECTEH			F3453	reso	22H00057	H	600UL	340945
2501			1.16	44	MBM	5	03H	+8.22	TECTEH			F3453	reso	22H00057	H	600UL	340945
2502			1.03	46	MBM	5	03H	+10.31	TECTEH			F3453	reso	22H00057	H	600UL	340945
2503	58	70	2.54	182	DNG	P 1	VM	+19.27	TECTEH			M0945	seco	22H00058	H	600UL	340944
2504			2.48	179	DNG	P 1	TSC	+7.62	TECTEH			M0945	seco	22H00058	H	600UL	340944
2505	60	70	3.30	184	DNG	P 1	VM	+20.01	TECTEH			D4576	seco	22H00057	H	600UL	340945
2506	70	70	4.57	182	DNG	P 1	DH	+29.83	TECTEH			M0945	seco	22H00058	H	600UL	340944
2507					INF		DH	+32.14	TECTEH	HR		F6623	reso	22H00058	H	600UL	340944
2508	82	70	0.76	62	MBM	5	TSH	+8.23	TECTEH			F3453	reso	22H00057	H	600UL	340945
2509	84	70			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
2510			0.10	69	PID	4	TSH	+0.37	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
2511			0.18	53	SAI	1	TSH	+0.37	TSHTSH	0.2		L2157	reso	22H00145	H	600PP	345329
2512			0.10	108	SAI	2	TSH	+0.37	TSHTSH	0.3		L2157	reso	22H00145	H	600PP	345329
2513	90	70	1.53	183	INR	P 1	01H	+3.04	TECTEH			D4576	seco	22H00057	H	600UL	340945
2514	92	70			NDF		09H	+0.02	09H09H			T7451	seco	22H00190	H	600PP	345345
2515			5.05	181	DNT	P 1	09H	+0.02	TECTEH			F0075	seco	22H00042	H	600UL	340972
2516			3.24	178	DNT	P 1	08C	+1.12	TECTEH			F0075	seco	22H00042	H	600UL	340972
			2.01	181	DNG	P 1	08C	+18.32	TECTEH			F0075	seco	22H00042	H	600UL	340972
[illegible]	100	70	123.7	175	DNT	P 1	09H	+0.16	TECTEH			F0075	seco	22H00042	H	600UL	340972
2519					NDF		09H	+0.16	09H09H			T7451	seco	22H00190	H	600PP	345345
2520	102	70	34.87	181	DNT	P 1	09H	-0.13	TECTEH			M2655	seco	22H00043	H	600UL	331895
2521	106	70	0.63	86	MBM	5	03H	+20.02	TECTEH			N5432	reso	22H00043	H	600UL	331895
2522			2.63	182	DNT	P 1	06H	+0.28	TECTEH			M2655	seco	22H00043	H	600UL	331895
2523	108	70			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
2524			0.09	25	SAI	1	TSH	+1.09	TSHTSH	0.2		D8661	reso	22H00134	H	600PP	345291
2525			0.12	87	PID	4	TSH	+1.09	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
2526			0.13	99	SAI	2	TSH	+1.09	TSHTSH	0.2		D8661	reso	22H00134	H	600PP	345291
2527	112	70	2.20	183	DNG	P 1	VH	+24.50	TECTEH			F0075	seco	22H00042	H	600UL	340972
2528	116	70	4.98	182	DNG	P 1	TSH	+13.88	TECTEH			F0075	seco	22H00042	H	600UL	340972
2529			32.24	181	DNT	P 1	09H	-0.22	TECTEH			F0075	seco	22H00042	H	600UL	340972
2530			3.45	181	DNG	P 1	05C	+9.60	TECTEH			F0075	seco	22H00042	H	600UL	340972
2531	122	70	1.79	180	INR	P 1	08H	+4.58	TECTEH			M2655	seco	22H00043	H	600UL	331895
2532			6.17	179	DNG	P 1	08H	+9.11	TECTEH			M2655	seco	22H00043	H	600UL	331895
2533			2.91	175	DNT	P 1	09H	-0.17	TECTEH			M2655	seco	22H00043	H	600UL	331895
2534			5.34	178	DNT	P 1	09H	+0.92	TECTEH			M2655	seco	22H00043	H	600UL	331895
2535			2.84	179	DNG	P 1	09H	+7.54	TECTEH			M2655	seco	22H00043	H	600UL	331895
2536			8.63	179	DNG	P 1	09H	+19.15	TECTEH			M2655	seco	22H00043	H	600UL	331895
2537			2.98	179	DNT	P 1	10H	-0.64	TECTEH			M2655	seco	22H00043	H	600UL	331895
2538	124	70	1.82	183	INR	P 1	06H	+0.23	TECTEH			F0075	seco	22H00042	H	600UL	340972
2539			12.92	181	DNT	P 1	09H	+0.00	TECTEH			F0075	seco	22H00042	H	600UL	340972
2540			3.05	178	DNG	P 1	09H	+3.50	TECTEH			F0075	seco	22H00042	H	600UL	340972
2541			3.25	179	DNG	P 1	09H	+7.24	TECTEH			F0075	seco	22H00042	H	600UL	340972
[illegible]	130	70	2.53	176	DNG	P 1	05C	+23.16	TECTEH			M2655	seco	22H00043	H	600UL	331895
			2.09	179	DNG	P 1	03C	+12.44	TECTEH			M2655	seco	22H00043	H	600UL	331895
2544	132	70	2.61	189	DNT	P 1	09H	+0.47	TECTEH			I3805	seco	22H00072	H	600UL	340945
2545	134	70	4.31	174	DNT	P 1	09H	-0.49	TECTEH			M1637	seco	22H00073	H	600UL	340927
2546			19.31	177	DNT	P 1	09H	+0.34	TECTEH			M1637	seco	22H00073	H	600UL	340927
2547			4.77	179	DNG	P 1	09H	+20.35	TECTEH			M1637	seco	22H00073	H	600UL	340927

2548				2.42	177	DNG	P 1	09H	+21.18		TECTEH			M1637	seco	22H00073	H	600UL	340927

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 53

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT		UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2549						NDF		10H	-0.16		10H10H		S8982	seco	22H00193	H	600PP	345345
2550			6.75	178	DNT	P 1		10H	-0.16		TECTEH		M1637	seco	22H00073	H	600UL	340927
2551			5.36	179	DNG	P 1		VH	+29.34		TECTEH		M1637	seco	22H00073	H	600UL	340927
2552			5.91	178	DNG	P 1		10C	+17.20		TECTEH		M1637	seco	22H00073	H	600UL	340927
2553			3.97	182	DNG	P 1		09C	+9.99		TECTEH		M1637	seco	22H00073	H	600UL	340927
2554			2.26	183	DNG	P 1		09C	+12.97		TECTEH		M7006	reso	22H00073	H	600UL	340927
2555			3.85	178	DNG	P 1		09C	+13.90		TECTEH		M1637	seco	22H00073	H	600UL	340927
2556			4.33	180	DNG	P 1		09C	+14.00		TECTEH		M7006	reso	22H00073	H	600UL	340927
2557			4.33	181	DNG	P 1		09C	+14.25		TECTEH		M7006	reso	22H00073	H	600UL	340927
2558			5.27	179	DNG	P 1		09C	+14.64		TECTEH		M1637	seco	22H00073	H	600UL	340927
2559	136	70	0.26	83	PLP	9		TSH	+0.19		TSHTSH		S8982	seco	22H00193	H	600PP	345345
2560			0.32	83	PLP	9		TSH	+1.01		TSHTSH		S8982	seco	22H00193	H	600PP	345345
2561			0.75	75	MBM	5		08C	+14.51		TECTEH		F3453	reso	22H00093	H	600UL	340929
2562	138	70	0.24	81	PLP	9		TSH	+0.84		TSHTSH		S8982	seco	22H00193	H	600PP	345345
2563			3.70	175	DNG	P 1		VH	+3.95		TECTEH		H4599	seco	22H00090	H	600UL	340943
2564	51	71	2.86	182	DNT	P 1		05H	+0.20		TECTEH		D4576	seco	22H00057	H	600UL	340945
2565			2.67	182	DNT	P 1		06H	+0.28		TECTEH		D4576	seco	22H00057	H	600UL	340945
	55	71	3.68	177	DNG	P 1		TSC	+5.23		TECTEH		D4576	seco	22H00057	H	600UL	340945
[illegible]	61	71	0.94	101	INR	6		03H	+2.94		TECTEH		M0945	seco	22H00058	H	600UL	340944
2568			1.40	93	INR	6		03H	+8.54		TECTEH		S4373	reso	22H00058	H	600UL	340944
2569	67	71	4.78	185	DNG	P 1		TSH	+11.57		TECTEH		D4576	seco	22H00057	H	600UL	340945
2570	69	71	0.90	70	MBM	6		01H	+21.00		TECTEH		F6623	reso	22H00058	H	600UL	340944
2571			1.02	83	MBM	6		TSC	+11.97		TECTEH		F6623	reso	22H00058	H	600UL	340944
2572	77	71	0.41	7	IDM	2		TSH	-3.18	TO+3.87	TSHTSH		F6623	reso	22H00144	H	600PP	345291
2573	79	71	0.67	74	MBM	5		TSH	+21.89		TECTEH		F3453	reso	22H00057	H	600UL	340945
2574			0.66	72	MBM	5		01H	+5.52		TECTEH		F3453	reso	22H00057	H	600UL	340945
2575			0.93	67	MBM	5		01H	+8.07		TECTEH		F3453	reso	22H00057	H	600UL	340945
2576			0.57	68	MBM	5		01H	+12.59		TECTEH		F3453	reso	22H00057	H	600UL	340945
2577			0.58	63	MBM	5		01H	+13.53		TECTEH		F3453	reso	22H00057	H	600UL	340945
2578			1.41	88	MBM	6		02H	+5.26		TECTEH		F3453	reso	22H00057	H	600UL	340945
2579			0.65	61	MBM	5		02C	+32.73		TECTEH		F3453	reso	22H00057	H	600UL	340945
2580	89	71			NDF			TSH	+1.29		TSHTSH		F4645	seco	22H00144	H	600PP	345291
2581			0.76	49	NQI	P 1		TSH	+1.29		TECTEH		J9815	prim	22H00057	H	600UL	340945
2582	91	71	0.70	58	DSI	P 1		09H	-0.02		TECTEH		F0075	seco	22H00042	H	600UL	340972
2583					NDF			09H	-0.02		09H09H		T7451	seco	22H00190	H	600PP	345345
2584			2.54	179	DNG	P 1		08C	+2.85		TECTEH		F0075	seco	22H00042	H	600UL	340972
2585	97	71	0.47	78	MBM	5		01C	+6.58		TECTEH		N5432	reso	22H00043	H	600UL	331895
2586	99	71	1.88	185	INR	P 1		01H	+32.94		TECTEH		F0075	seco	22H00042	H	600UL	340972
2587			46.83	179	DNT	P 1		09H	+0.02		TECTEH		F0075	seco	22H00042	H	600UL	340972
2588	101	71	22.92	179	DNT	P 1		09H	+0.07		TECTEH		M2655	seco	22H00043	H	600UL	331895
2589			3.66	178	DNG	P 1		09C	+8.38		TECTEH		M2655	seco	22H00043	H	600UL	331895
2590	103	71	0.57	75	MBM	5		04H	+30.43		TECTEH		F3453	reso	22H00042	H	600UL	340972
[illegible]	107	71	0.73	88	MBM	5		07H	+21.27		TECTEH		F3453	reso	22H00042	H	600UL	340972
			2.11	182	DNT	P 1		09H	-0.04		TECTEH		F0075	seco	22H00042	H	600UL	340972
2593					NDF			09C	+0.04		09C09C		F6623	reso	22C00087	C	600PP	345298
2594			1.35	150	DSI	P 1		09C	+0.04		TECTEH		T6956	prim	22H00042	H	600UL	340972
2595	111	71	4.65	178	DNG	P 1		VM	+27.26		TECTEH		F0075	seco	22H00042	H	600UL	340972
2596			0.62	75	MBM	5		01C	+14.46		TECTEH		F3453	reso	22H00042	H	600UL	340972

2597	115	71	3.80	180	DNT	P 1	08H	-0.38	TECTEH				F0075	seco	22H00042	H	600UL		340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 54

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2598	117	71	3.42	177	DNG	P 1	03H	+5.71	TECTEH			M2655	seco	22H00043	H	600UL	331895
2599			5.30	178	DNG	P 1	08H	+13.82	TECTEH			M2655	seco	22H00043	H	600UL	331895
2600			5.64	178	DNG	P 1	08H	+17.52	TECTEH			M2655	seco	22H00043	H	600UL	331895
2601			7.15	178	DNG	P 1	08H	+18.91	TECTEH			M2655	seco	22H00043	H	600UL	331895
2602			8.24	178	DNT	P 1	09H	-1.05	TECTEH			M2655	seco	22H00043	H	600UL	331895
2603			12.13	181	DNT	P 1	09H	-0.30	TECTEH			M2655	seco	22H00043	H	600UL	331895
2604			5.39	178	DNG	P 1	09H	+1.28	TECTEH			M2655	seco	22H00043	H	600UL	331895
2605			10.45	179	DNT	P 1	10H	-0.14	TECTEH			M2655	seco	22H00043	H	600UL	331895
2606	121	71	4.49	177	DNG	P 1	10C	+3.53	TECTEH			M2655	seco	22H00043	H	600UL	331895
2607			5.08	201	NRC	2	TSC	+0.00	TECTEH			M1680	reso	22H00043	H	600UL	331895
2608	123	71	2.04	177	DNG	P 1	09H	-0.66	TECTEH			F3453	reso	22H00042	H	600UL	340972
2609			7.56	182	DNG	P 1	09H	+9.93	TECTEH			F0075	seco	22H00042	H	600UL	340972
2610			2.48	178	DNG	P 1	09H	+11.32	TECTEH			F3453	reso	22H00042	H	600UL	340972
2611			13.35	182	DNG	P 1	09H	+12.11	TECTEH			F0075	seco	22H00042	H	600UL	340972
2612			10.09	181	DNG	P 1	09H	+17.11	TECTEH			F0075	seco	22H00042	H	600UL	340972
2613			2.69	179	DNG	P 1	09H	+20.06	TECTEH			F0075	seco	22H00042	H	600UL	340972
2614			9.28	181	DNG	P 1	09H	+21.07	TECTEH			F0075	seco	22H00042	H	600UL	340972
	125	71	20.98	180	DNT	P 1	09H	-0.06	TECTEH			M2655	seco	22H00043	H	600UL	331895
	129	71	2.16	180	DNG	P 1	07H	+2.39	TECTEH			M2655	seco	22H00043	H	600UL	331895
2617			1.97	182	INR	P 1	09H	+7.61	TECTEH			M2655	seco	22H00043	H	600UL	331895
2618	131	71	6.46	182	DNT	P 1	09H	-0.06	TECTEH			F0075	seco	22H00042	H	600UL	340972
2619	133	71	0.31	77	PLP	9	TSH	+0.36	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2620			0.61	82	MBM	5	03H	+29.69	TECTEH			C3340	reso	22H00072	H	600UL	340945
2621	135	71	0.22	85	PLP	9	TSH	+0.37	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2622			0.30	80	PLP	9	TSH	+0.71	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2623			3.82	178	DNG	P 1	VM	+3.03	TECTEH			M1637	seco	22H00073	H	600UL	340927
2624	52	72	3.73	180	DNG	P 1	TSC	+21.55	TECTEH			M0945	seco	22H00054	H	600UL	340944
2625	54	72	3.32	180	DNT	P 1	VM	+1.45	TECTEH			D4576	seco	22H00053	H	600UL	340945
2626	58	72	2.38	182	DNG	P 1	VM	+18.35	TECTEH			D4576	seco	22H00053	H	600UL	340945
2627	86	72			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
2628			0.25	91	SAI	2	TSH	+0.30	TSHTSH	0.7		F6623	reso	22H00144	H	600PP	345291
2629			0.26	49	SAI	1	TSH	+0.30	TSHTSH	0.7		F6623	reso	22H00144	H	600PP	345291
2630			0.26	96	SAI	2	TSH	+0.53	TSHTSH	0.3		F6623	reso	22H00144	H	600PP	345291
2631			0.18	42	SAI	1	TSH	+0.53	TSHTSH	0.3		F6623	reso	22H00144	H	600PP	345291
2632			0.25	98	SAI	1	TSH	+0.80	TSHTSH	0.3		F6623	reso	22H00144	H	600PP	345291
2633			0.27	102	SAI	2	TSH	+0.80	TSHTSH	0.3		F6623	reso	22H00144	H	600PP	345291
2634			0.25	112	PID	4	TSH	+0.80	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
2635					NDF		TSC	+0.02	TSCTSC			S4373	reso	22C00039	C	600PP	345352
2636			4.95	71	DTI	P 3	TSC	+0.02	TECTEH			F6623	reso	22H00058	H	600UL	340944
2637	96	72	8.00	180	DNT	P 1	09H	+0.02	TECTEH			F0075	seco	22H00042	H	600UL	340972
2638	106	72	0.56	78	MBM	5	09C	+6.69	TECTEH			N5432	reso	22H00043	H	600UL	331895
2639	116	72	5.91	184	DNT	P 1	09H	-0.21	TECTEH			F0075	seco	22H00042	H	600UL	340972
2640	120	72	3.02	178	DNT	P 1	08H	+0.33	TECTEH			F0075	seco	22H00042	H	600UL	340972
			2.53	178	DNG	P 1	08H	+5.23	TECTEH			F0075	seco	22H00042	H	600UL	340972
2642			2.45	179	DNG	P 1	08H	+5.95	TECTEH			F0075	seco	22H00042	H	600UL	340972
2643			2.47	180	DNG	P 1	09H	+8.01	TECTEH			F0075	seco	22H00042	H	600UL	340972
2644	122	72	1.09	90	MBM	6	05H	+22.81	TECTEH			N5432	reso	22H00043	H	600UL	331895
2645	124	72	4.28	180	DNG	P 1	09H	+15.53	TECTEH			F0075	seco	22H00042	H	600UL	340972

2646			3.01	178	DNG	P 1	09H	+20.31	TECTEH			F0075	seco	22H00042	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 55

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2647		2.34	181	DNT	P 1	10H	+0.62	TECTEH			F0075	seco	22H00042	H	600UL	340972
2648	132	72	0.47	71	PLP	9	TSH	+0.15	TSHTSH		S8982	seco	22H00193	H	600PP	345345
2649			2.52	186	DNG	P 1	01C	+22.32	TECTEH		I3805	seco	22H00072	H	600UL	340945
2650	134	72	2.03	182	DNT	P 1	09H	+0.35	TECTEH		M1637	seco	22H00073	H	600UL	340927
2651			3.20	175	DNG	P 1	VH	+28.24	TECTEH		M1637	seco	22H00073	H	600UL	340927
2652	136	72	1.06	151	NQI	5	TSH	+0.49	TECTEH		D6502	prim	22H00093	H	600UL	340929
2653			0.43	82	PLP	9	TSH	+0.67	TSHTSH		C3340	reso	22H00193	H	600PP	345345
2654			5.82	181	DNG	P 1	09H	+18.00	TECTEH		A6997	seco	22H00093	H	600UL	340929
2655			9.92	181	DNG	P 1	10H	-1.10	TECTEH		A6997	seco	22H00093	H	600UL	340929
2656	138	72	0.10	86	PLP	9	TSH	+0.32	TSHTSH		C3340	reso	22H00193	H	600PP	345345
2657	33	73	0.96	44	29	P 2	DH	+1.71	TECTEH	LOCOK	S4373	reso	22H00054	H	600UL	340944
2658	51	73	3.63	184	DNG	P 1	04H	+10.60	TECTEH		D4576	seco	22H00053	H	600UL	340945
2659	53	73	0.87	89	MBM	5	01C	+11.78	TECTEH		N5432	reso	22H00054	H	600UL	340944
2660	65	73	3.55	183	DNG	P 1	06H	+9.32	TECTEH		M0945	seco	22H00054	H	600UL	340944
2661			8.80	183	DNG	P 1	07C	+8.17	TECTEH		M0945	seco	22H00054	H	600UL	340944
2662			5.95	186	DNG	P 1	07C	+9.13	TECTEH		M0945	seco	22H00054	H	600UL	340944
2663			3.37	184	DNG	P 1	07C	+12.08	TECTEH		M0945	seco	22H00054	H	600UL	340944
			2.71	180	DNG	P 1	07C	+13.36	TECTEH		M0945	seco	22H00054	H	600UL	340944
			15.43	180	DNG	P 1	07C	+16.31	TECTEH		M0945	seco	22H00054	H	600UL	340944
2666	69	73	3.30	182	DNG	P 1	06C	+17.44	TECTEH		M0945	seco	22H00054	H	600UL	340944
2667	75	73	5.91	181	DNG	P 1	07H	-1.50	TECTEH		D4576	seco	22H00053	H	600UL	340945
2668			2.91	183	DNT	P 1	07H	+0.89	TECTEH		D4576	seco	22H00053	H	600UL	340945
2669	89	73			TBS				TECTEH		D3858	reso	22H00044	H	600UL	331892
2670			0.08	76	PID	4	TSH	+0.40	TSHTSH	080	F3453	reso	22H00180	H	600PP	345290
2671			0.00	0	SAI	1	TSH	+0.40	TSHTSH	0.0	F6623	reso	22H00144	H	600PP	345291
2672			0.08	103	SAI	2	TSH	+0.40	TSHTSH	0.2	F6623	reso	22H00144	H	600PP	345291
2673	91	73	3.19	182	DNT	P 1	06H	-0.44	TECTEH		F0075	seco	22H00042	H	600UL	340972
2674			2.11	182	DNT	P 1	08C	+0.50	TECTEH		F0075	seco	22H00042	H	600UL	340972
2675			2.83	179	DNG	P 1	08C	+5.40	TECTEH		F0075	seco	22H00042	H	600UL	340972
2676			4.80	183	DNG	P 1	08C	+6.40	TECTEH		F0075	seco	22H00042	H	600UL	340972
2677			3.90	184	DNG	P 1	07C	+23.37	TECTEH		F0075	seco	22H00042	H	600UL	340972
2678			0.83	64	MBM	5	TSC	+7.81	TECTEH		F3453	reso	22H00042	H	600UL	340972
2679	97	73	0.93	87	MBM	6	03H	+20.84	TECTEH		N5432	reso	22H00043	H	600UL	331895
2680			1.08	76	MBM	5	04H	+36.12	TECTEH		N5432	reso	22H00043	H	600UL	331895
2681			3.31	179	DNG	P 1	02C	+24.35	TECTEH		M2655	seco	22H00043	H	600UL	331895
2682	107	73			NDF		09H	-0.22	09H09H		N5432	reso	22H00190	H	600PP	345345
2683			21.59	182	DNT	P 1	09H	-0.22	TECTEH		F0075	seco	22H00042	H	600UL	340972
2684	111	73	2.99	177	DNT	P 1	09H	-0.02	TECTEH		F0075	seco	22H00042	H	600UL	340972
2685			2.37	182	DNG	P 1	VH	+4.82	TECTEH		F0075	seco	22H00042	H	600UL	340972
2686	113	73	13.27	180	DNT	P 1	09H	-0.15	TECTEH		M2655	seco	22H00043	H	600UL	331895
2687	115	73			INF		05H	+38.55	TECTEH	HR	D8661	reso	22H00042	H	600UL	340972
2688			7.02	184	DNT	P 1	06H	-0.44	TECTEH		F0075	seco	22H00042	H	600UL	340972
[illegible]					INF		08H	+22.15	TECTEH	HR	D8661	reso	22H00042	H	600UL	340972
			5.91	180	DNT	P 1	09H	-0.30	TECTEH		F0075	seco	22H00042	H	600UL	340972
2691	117	73	4.51	179	DNT	P 1	09H	-0.41	TECTEH		M2655	seco	22H00043	H	600UL	331895
2692			2.64	181	DNT	P 1	VH	+2.01	TECTEH		M2655	seco	22H00043	H	600UL	331895
2693			4.29	180	DNT	P 1	10C	+0.16	TECTEH		M2655	seco	22H00043	H	600UL	331895
2694			3.32	182	DNT	P 1	10C	+0.56	TECTEH		M2655	seco	22H00043	H	600UL	331895

2695	119	73			NDF	06H	+0.31		06H06H				T7451	seco	22H00190	H	600PP	345345

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 56

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2696			5.38	177	DNT	P 1	06H	+0.31	TECTEH			F0075	seco	22H00042	H	600UL	340972
2697	121	73	1.48	83	MBM	5	05H	+32.31	TECTEH			N5432	reso	22H00043	H	600UL	331895
2698					INF		07H	+0.43	TECTEH	HR		N5432	reso	22H00043	H	600UL	331895
2699			3.18	177	DNG	P 1	09H	+17.94	TECTEH			M2655	seco	22H00043	H	600UL	331895
2700			2.86	175	DNT	P 1	10H	+0.11	TECTEH			M2655	seco	22H00043	H	600UL	331895
2701			25.15	177	DNT	P 1	10H	+0.98	TECTEH			M2655	seco	22H00043	H	600UL	331895
2702			2.10	185	DNG	P 1	VH	+6.70	TECTEH			M2655	seco	22H00043	H	600UL	331895
2703			3.20	184	DNG	P 1	09C	+6.39	TECTEH			M2655	seco	22H00043	H	600UL	331895
2704			7.04	180	DNG	P 1	09C	+7.00	TECTEH			M2655	seco	22H00043	H	600UL	331895
2705			9.19	179	DNG	P 1	09C	+7.49	TECTEH			M2655	seco	22H00043	H	600UL	331895
2706			17.47	177	DNG	P 1	09C	+8.54	TECTEH			M2655	seco	22H00043	H	600UL	331895
2707			2.45	185	DNG	P 1	08C	+15.77	TECTEH			M2655	seco	22H00043	H	600UL	331895
2708			4.65	207	NRC	2	TSC	+0.00	TECTEH			M1680	reso	22H00043	H	600UL	331895
2709	123	73	8.10	182	DNT	P 1	10H	+0.00	TECTEH			F0075	seco	22H00042	H	600UL	340972
2710					NDF		10H	+0.00	10H10H			J9815	prim	22H00192	H	5602C	326272
2711	125	73	2.26	179	DNT	P 1	09H	-0.09	TECTEH			M2655	seco	22H00043	H	600UL	331895
2712	129	73	2.44	177	DNG	P 1	02C	+12.46	TECTEH			M2655	seco	22H00043	H	600UL	331895
	135	73	2.03	187	DNG	P 1	VH	+30.35	TECTEH			M1637	seco	22H00073	H	600UL	340927
			2.25	179	DNT	P 1	VM	-1.87	TECTEH			M1637	seco	22H00073	H	600UL	340927
2715	137	73	0.32	71	PLP	9	TSH	+0.35	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2716	139	73			INF		10H	+16.72	TECTEH	HR		F3453	reso	22H00093	H	600UL	340929
2717			5.67	183	DNG	P 1	10H	+18.87	TECTEH			A6997	seco	22H00093	H	600UL	340929
2718	40	74	6.13	183	DNG	P 1	04H	+5.69	TECTEH			D4576	seco	22H00053	H	600UL	340945
2719	46	74			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
2720			0.13	67	MAI	2	TSH	+2.47	TSHTSH	0.5		F6623	reso	22H00144	H	600PP	345291
2721			0.00	0	MAI	1	TSH	+2.47	TSHTSH	0.0		F6623	reso	22H00144	H	600PP	345291
2722			0.12	72	PID	4	TSH	+2.47	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
2723			4.46	182	DNG	P 1	VM	+3.09	TECTEH			M0945	seco	22H00054	H	600UL	340944
2724	54	74	0.92	5	IDM	2	TSH	-3.04 TO+4.08	TSHTSH			F6623	reso	22H00144	H	600PP	345291
2725			2.47	183	DNG	P 1	VM	+17.00	TECTEH			M0945	seco	22H00054	H	600UL	340944
2726	60	74	2.84	182	DNG	P 1	VM	+19.75	TECTEH			D4576	seco	22H00053	H	600UL	340945
2727	64	74	3.96	177	DNG	P 1	07C	+25.22	TECTEH			D4576	seco	22H00053	H	600UL	340945
2728	70	74	4.70	184	DNT	P 1	07H	+0.85	TECTEH			M0945	seco	22H00054	H	600UL	340944
2729			21.25	178	DNG	P 1	07H	+7.78	TECTEH			M0945	seco	22H00054	H	600UL	340944
2730					INF		07H	+9.46	TECTEH	HR		N5432	reso	22H00054	H	600UL	340944
2731	74	74	2.38	182	DNG	P 1	07H	+10.98	TECTEH			M0945	seco	22H00054	H	600UL	340944
2732			2.84	181	DNG	P 1	07C	+8.87	TECTEH			M0945	seco	22H00054	H	600UL	340944
2733			2.58	176	DNG	P 1	TSC	+21.17	TECTEH			M0945	seco	22H00054	H	600UL	340944
2734	76	74	0.62	83	MBM	5	03C	+9.24	TECTEH			F3453	reso	22H00053	H	600UL	340945
2735			0.63	73	MBM	5	02C	+17.86	TECTEH			F3453	reso	22H00053	H	600UL	340945
2736	78	74			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
2737			0.13	104	PID	4	TSH	+0.95	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
[illegible]			0.14	90	SAI	2	TSH	+0.95	TSHTSH	0.3		F6623	reso	22H00144	H	600PP	345291
			0.21	40	SAI	1	TSH	+0.95	TSHTSH	0.3		F6623	reso	22H00144	H	600PP	345291
2740			0.72	82	MBM	6	02C	+28.94	TECTEH			N5432	reso	22H00054	H	600UL	340944
2741	92	74	3.37	177	DNT	P 1	09C	+0.18	TECTEH			F0075	seco	22H00042	H	600UL	340972
2742			3.55	180	DNG	P 1	07C	+16.02	TECTEH			F0075	seco	22H00042	H	600UL	340972
2743	94	74	2.42	183	DNG	P 1	DH	+5.91	TECTEH			F0075	seco	22H00042	H	600UL	340972

2744			1.03	84	MBM	5	03C	+26.77	TECTEH			C5542	reso	22H00042	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 57

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2745	96	74	4.08	182	DNG	P 1	08H +18.75	TECTEH			F0075	seco	22H00042	H	600UL	340972
2746	100	74	8.23	182	DNT	P 1	09H -0.02	TECTEH			F0075	seco	22H00042	H	600UL	340972
2747	102	74	2.36	175	DNT	P 1	09H -0.24	TECTEH			M2655	seco	22H00043	H	600UL	331895
2748	104	74	0.66	81	MBM	5	01H +31.30	TECTEH			F3453	reso	22H00042	H	600UL	340972
2749	106	74	9.12	179	DNT	P 1	09H -0.13	TECTEH			M2655	seco	22H00043	H	600UL	331895
2750	108	74			NDF		09C +0.13	09C09C			F6623	reso	22C00087	C	600PP	345298
2751			0.43	103	DSI	P 1	09C +0.13	TECTEH			F0075	seco	22H00042	H	600UL	340972
2752	112	74	3.67	177	DNG	P 1	03H +36.22	TECTEH			F0075	seco	22H00042	H	600UL	340972
2753			3.42	178	DNG	P 1	09H +15.91	TECTEH			F0075	seco	22H00042	H	600UL	340972
2754	114	74	19.03	180	DNT	P 1	09H -0.15	TECTEH			M2655	seco	22H00043	H	600UL	331895
2755					NDF		09H -0.15	09H09H			T7451	seco	22H00190	H	600PP	345345
2756	116	74			INF		05H +6.84	TECTEH	HR		D8661	reso	22H00042	H	600UL	340972
2757			12.24	182	DNT	P 1	09H -0.09	TECTEH			F0075	seco	22H00042	H	600UL	340972
2758	120	74			INF		DH +23.89	TECTEH	HR		D8661	reso	22H00042	H	600UL	340972
2759			7.25	185	DNG	P 1	DH +25.23	TECTEH			F0075	seco	22H00042	H	600UL	340972
2760	122	74	4.64	177	DNT	P 1	09H -1.08	TECTEH			M2655	seco	22H00043	H	600UL	331895
2761			3.74	177	DNT	P 1	09H -0.32	TECTEH			M2655	seco	22H00043	H	600UL	331895
			2.58	180	DNG	P 1	09H +3.19	TECTEH			M2655	seco	22H00043	H	600UL	331895
[illegible]			22.26	178	DNG	P 1	09H +4.12	TECTEH			M2655	seco	22H00043	H	600UL	331895
2764			8.21	178	DNG	P 1	09H +5.15	TECTEH			M2655	seco	22H00043	H	600UL	331895
2765			20.39	178	DNG	P 1	09H +6.04	TECTEH			M2655	seco	22H00043	H	600UL	331895
2766			1.89	180	INR	P 1	09H +7.79	TECTEH			M2655	seco	22H00043	H	600UL	331895
2767			4.40	177	DNG	P 1	09H +8.22	TECTEH			M2655	seco	22H00043	H	600UL	331895
2768			28.40	177	DNG	P 1	09H +15.93	TECTEH			N5432	reso	22H00043	H	600UL	331895
2769			3.29	178	DNG	P 1	09H +16.37	TECTEH			M2655	seco	22H00043	H	600UL	331895
2770			7.13	180	DNT	P 1	10C +0.15	TECTEH			M2655	seco	22H00043	H	600UL	331895
2771			2.27	182	DNG	P 1	10C +1.29	TECTEH			M2655	seco	22H00043	H	600UL	331895
2772			13.48	179	DNG	P 1	09C +6.05	TECTEH			M2655	seco	22H00043	H	600UL	331895
2773			3.55	177	DNG	P 1	09C +7.09	TECTEH			M2655	seco	22H00043	H	600UL	331895
2774			10.56	178	DNG	P 1	09C +8.15	TECTEH			M2655	seco	22H00043	H	600UL	331895
2775	128	74	0.26	98	DSI	P 1	09H +0.07	TECTEH			F0075	seco	22H00042	H	600UL	340972
2776					NDF		09H +0.07	09H09H			J9815	prim	22H00197	H	600PP	345329
2777	130	74	1.86	74	MBM	6	08C +6.66	TECTEH			N5432	reso	22H00043	H	600UL	331895
2778	132	74	17.22	186	DNG	P 1	09H +2.61	TECTEH			I3805	seco	22H00072	H	600UL	340945
2779			2.46	73	MBM	6	09H +3.51	TECTEH			C3340	reso	22H00072	H	600UL	340945
2780			4.68	182	DNG	P 1	09H +4.32	TECTEH			I3805	seco	22H00072	H	600UL	340945
2781			7.54	185	DNG	P 1	09H +4.79	TECTEH			I3805	seco	22H00072	H	600UL	340945
2782			1.98	180	INR	P 1	10H +13.35	TECTEH			I3805	seco	22H00072	H	600UL	340945
2783	134	74	2.58	177	DNG	P 1	VH +29.24	TECTEH			M1637	seco	22H00073	H	600UL	340927
2784	136	74	0.35	80	PLP	9	TSH +0.04	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2785	138	74	0.30	80	PLP	9	TSH +0.12	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2786			3.07	182	DNT	P 1	10H +0.46	TECTEH			A6997	seco	22H00093	H	600UL	340929
[illegible]	41	75			TBP			TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
			0.00	0	SAI	1	TSH +2.00	TSHTSH	0.0		F6623	reso	22H00144	H	600PP	345291
2789			0.09	129	PID	4	TSH +2.00	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
2790			0.09	114	SAI	2	TSH +2.00	TSHTSH	0.4		F6623	reso	22H00144	H	600PP	345291
2791			5.09	178	DNG	P 1	06H +2.16	TECTEH			D4576	seco	22H00053	H	600UL	340945
2792			3.14	178	DNG	P 1	06H +14.07	TECTEH			D4576	seco	22H00053	H	600UL	340945

2793	47	75	3.07	184	DNG	P 1	TSC	+6.45	TECTEH			M0945	seco	22H00054	H	600UL		340944

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 58

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2794	51	75	0.40	67	MBM	5	01H +19.54	TECTEH			N5432	reso	22H00054	H	600UL	340944
2795			0.75	77	MBM	5	04C +17.91	TECTEH			N5432	reso	22H00054	H	600UL	340944
2796	67	75	5.15	182	DNG	P 1	07C +13.60	TECTEH			M0945	seco	22H00054	H	600UL	340944
2797	95	75	19.52	182	DNT	P 1	09H +0.02	TECTEH			F0075	seco	22H00042	H	600UL	340972
2798	99	75	24.28	181	DNT	P 1	09H +0.02	TECTEH			F0075	seco	22H00042	H	600UL	340972
2799	101	75	14.85	181	DNT	P 1	09H -0.02	TECTEH			M2655	seco	22H00043	H	600UL	331895
2800	105	75	0.36	122	DSI	P 1	07H -0.86	TECTEH			H3464	prim	22H00043	H	600UL	331895
2801			0.18	120	VOL	P 1	07H -0.75	07H07H			N5432	reso	22H00190	H	600PP	345345
2802	107	75	0.72	96	MBM	5	05C +3.41	TECTEH			C5542	reso	22H00042	H	600UL	340972
2803	111	75	4.54	180	DNT	P 1	06H -0.31	TECTEH			F0075	seco	22H00042	H	600UL	340972
2804	113	75	7.76	179	DNT	P 1	09H -0.28	TECTEH			M2655	seco	22H00043	H	600UL	331895
2805	115	75	22.02	183	DNT	P 1	09H -0.05	TECTEH			F0075	seco	22H00042	H	600UL	340972
2806					NDF		09H -0.05	09H09H			T7451	seco	22H00190	H	600PP	345345
2807			4.51	177	DNG	P 1	09H +3.81	TECTEH			F0075	seco	22H00042	H	600UL	340972
2808			3.15	180	DNG	P 1	VH +2.87	TECTEH			F0075	seco	22H00042	H	600UL	340972
2809			0.54	73	MBM	5	04C +28.78	TECTEH			C5542	reso	22H00042	H	600UL	340972
2810	117	75			NDF		09H -0.29	09H09H			T7451	seco	22H00190	H	600PP	345345
			13.39	181	DNT	P 1	09H -0.29	TECTEH			T7451	seco	22H00086	H	600UL	340912
	119	75	7.26	89	MBM	6	04H +4.93	TECTEH			C5542	reso	22H00042	H	600UL	340972
2813					NDF		09H -0.32	09H09H			T7451	seco	22H00190	H	600PP	345345
2814			16.55	183	DNT	P 1	09H -0.32	TECTEH			F0075	seco	22H00042	H	600UL	340972
2815	121	75	2.62	178	DNT	P 1	10H +0.62	TECTEH			T7451	seco	22H00086	H	600UL	340912
2816			5.51	205	NRC	2	TSC +0.00	TECTEH			M7006	reso	22H00086	H	600UL	340912
2817	123	75	2.06	182	DNG	P 1	09C +6.94	TECTEH			F0075	seco	22H00042	H	600UL	340972
2818	131	75	3.91	181	DNT	P 1	09H +0.04	TECTEH			F0075	seco	22H00042	H	600UL	340972
2819	133	75	2.20	184	DNG	P 1	09H +14.53	TECTEH			I3805	seco	22H00072	H	600UL	340945
2820			3.63	178	DNT	P 1	10C -0.94	TECTEH			I3805	seco	22H00072	H	600UL	340945
2821			3.76	181	DNG	P 1	09C +6.88	TECTEH			I3805	seco	22H00072	H	600UL	340945
2822			3.42	182	DNG	P 1	09C +18.17	TECTEH			I3805	seco	22H00072	H	600UL	340945
2823			3.55	182	DNG	P 1	09C +20.56	TECTEH			I3805	seco	22H00072	H	600UL	340945
2824	135	75	0.36	80	PLP	9	TSH +0.10	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2825	137	75	0.20	85	PLP	9	TSH +0.39	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2826	139	75	0.41	81	PLP	9	TSH +0.20	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2827			5.09	177	DNG	P 1	TSH +2.31	TECTEH			F3453	reso	22H00093	H	600UL	340929
2828			2.58	183	DNG	P 1	10H +19.04	TECTEH			A6997	seco	22H00093	H	600UL	340929
2829	40	76			TBP			TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
2830			0.14	108	SAI	2	TSH +1.59	TSHTSH	0.3		C5542	reso	22H00142	H	600PP	345291
2831			0.11	145	PID	4	TSH +1.59	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
2832			0.00	0	SAI	1	TSH +1.59	TSHTSH	0.0		C5542	reso	22H00142	H	600PP	345291
2833	52	76	2.37	183	DNG	P 1	VM +16.38	TECTEH			M0945	seco	22H00054	H	600UL	340944
2834	56	76	2.70	182	DNG	P 1	VM +18.65	TECTEH			M0945	seco	22H00054	H	600UL	340944
2835	60	76	3.26	181	DNG	P 1	VM +19.97	TECTEH			M0945	seco	22H00054	H	600UL	340944
	72	76	2.80	183	DNG	P 1	01C +28.57	TECTEH			M0945	seco	22H00054	H	600UL	340944
	78	76			TBS			TECTEH			D3858	reso	22H00044	H	600UL	331892
2838			0.22	87	PID	4	TSH +1.43	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
2839			0.45	31	MAI	1	TSH +1.43	TSHTSH	0.4		C5542	reso	22H00142	H	600PP	345291
2840			0.20	96	MAI	2	TSH +1.43	TSHTSH	0.4		C5542	reso	22H00142	H	600PP	345291
2841	92	76	2.48	180	DNG	P 1	03H +12.31	TECTEH			F4645	seco	22H00046	H	600UL	340972

2842			4.48	177	DNT	P 1	09C	+0.20	TECTEH			F4645	seco	22H00046	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 59

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2843	94	76	0.50	77	MBM	5	01H +27.86	TECTEH			F6623	reso	22H00046	H	600UL	340972
2844	96	76	37.60	183	DNT	P 1	09H +0.02	TECTEH			F4645	seco	22H00046	H	600UL	340972
2845	110	76			NDF		09H -0.09	09H09H			N5432	reso	22H00190	H	600PP	345345
2846			16.33	184	DNT	P 1	09H -0.09	TECTEH			T7451	seco	22H00086	H	600UL	340912
2847	112	76	2.59	180	DNG	P 1	DH +19.76	TECTEH			T7451	seco	22H00086	H	600UL	340912
2848	116	76	4.65	182	DNT	P 1	09H -0.41	TECTEH			F4645	seco	22H00046	H	600UL	340972
2849	118	76	9.29	182	DNT	P 1	09H -0.21	TECTEH			T7451	seco	22H00086	H	600UL	340912
2850	120	76	2.25	182	DNG	P 1	VH +29.08	TECTEH			F4645	seco	22H00046	H	600UL	340972
2851	126	76	3.03	187	DNG	P 1	04C +18.41	TECTEH			T7451	seco	22H00086	H	600UL	340912
2852	134	76	0.34	80	PLP	9	TSH +0.18	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2853			5.68	176	INR	P 1	10C +17.18	TECTEH			M7006	reso	22H00073	H	600UL	340927
2854	138	76	1.91	180	INR	P 1	09H +0.55	TECTEH			A6997	seco	22H00093	H	600UL	340929
2855			3.17	187	DNT	P 1	10H +0.42	TECTEH			A6997	seco	22H00093	H	600UL	340929
2856	140	76			NDF		TSH +0.30	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2857			6.60	15	NQI	P 1	TSH +0.30	TECTEH			D6502	prim	22H00093	H	600UL	340929
2858			3.59	180	DNT	P 1	09H +0.34	TECTEH			A6997	seco	22H00093	H	600UL	340929
2859			7.33	181	DNT	P 1	10H -0.52	TECTEH			A6997	seco	22H00093	H	600UL	340929
			19.09	182	DNT	P 1	10H +0.40	TECTEH			A6997	seco	22H00093	H	600UL	340929
			2.77	184	DNG	P 1	09C +3.78	TECTEH			A6997	seco	22H00093	H	600UL	340929
2862			2.80	185	DNG	P 1	04C +1.49	TECTEH			A6997	seco	22H00093	H	600UL	340929
2863			2.97	185	DNG	P 1	02C +20.25	TECTEH			A6997	seco	22H00093	H	600UL	340929
2864	37	77	0.39	61	16	P 2	06H -0.93	TECTEH			M0945	seco	22H00054	H	600UL	340944
2865	59	77	4.64	189	DNG	P 1	04H +15.59	TECTEH			M0945	seco	22H00054	H	600UL	340944
2866	65	77	0.57	81	MBM	5	01C +26.41	TECTEH			F3453	reso	22H00053	H	600UL	340945
2867	69	77			TBP			TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
2868			0.14	146	PID	4	TSH +1.69	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
2869			0.10	99	SAI	2	TSH +1.69	TSHTSH	0.4		C5542	reso	22H00142	H	600PP	345291
2870			0.00	0	SAI	1	TSH +1.69	TSHTSH	0.0		C5542	reso	22H00142	H	600PP	345291
2871			0.00	0	SAI	1	TSH +2.15	TSHTSH	0.0		C5542	reso	22H00142	H	600PP	345291
2872			0.13	86	SAI	2	TSH +2.15	TSHTSH	0.2		C5542	reso	22H00142	H	600PP	345291
2873	71	77	17.18	180	DNG	P 1	06H +22.44	TECTEH			M0945	seco	22H00054	H	600UL	340944
2874			6.75	184	DNG	P 1	06H +23.07	TECTEH			M0945	seco	22H00054	H	600UL	340944
2875			6.02	181	DNG	P 1	07H +9.75	TECTEH			M0945	seco	22H00054	H	600UL	340944
2876			2.42	181	DNT	P 1	07C +0.70	TECTEH			M0945	seco	22H00054	H	600UL	340944
2877	93	77	9.46	181	DNT	P 1	09H +0.02	TECTEH			T7451	seco	22H00086	H	600UL	340912
2878	99	77	23.30	183	DNT	P 1	09H +0.02	TECTEH			F4645	seco	22H00046	H	600UL	340972
2879	101	77	8.39	181	DNT	P 1	09H -0.02	TECTEH			S8982	seco	22H00047	H	600UL	331895
2880	107	77	1.47	89	MBM	5	03H +6.13	TECTEH			F6623	reso	22H00046	H	600UL	340972
2881			0.66	74	MBM	6	03H +31.04	TECTEH			F6623	reso	22H00046	H	600UL	340972
2882			0.97	85	MBM	5	04H +2.74	TECTEH			F6623	reso	22H00046	H	600UL	340972
2883	109	77			INF		09C +13.72	TECTEH	HR		M7006	reso	22H00086	H	600UL	340912
2884			1.25	95	MBM	5	09C +14.87	TECTEH			M7006	reso	22H00086	H	600UL	340912
2885	111	77	5.02	178	DNG	P 1	VM +28.49	TECTEH			F4645	seco	22H00046	H	600UL	340972
	117	77	5.93	181	DNT	P 1	10C +0.46	TECTEH			S8982	seco	22H00047	H	600UL	331895
2887	121	77	4.41	182	DNG	P 1	10C +3.57	TECTEH			T7451	seco	22H00086	H	600UL	340912
2888			5.18	29	NRC	2	TSC +0.00	TECTEH			D6502	prim	22H00086	H	600UL	340912
2889	125	77	3.51	179	DNG	P 1	08H +17.35	TECTEH			S8982	seco	22H00047	H	600UL	331895
2890			4.82	180	DNG	P 1	08H +20.58	TECTEH			S8982	seco	22H00047	H	600UL	331895

2891				5.44	182	DNT	P 1	09H	-0.30	TECTEH			S8982	seco	22H00047	H	600UL	331895

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 60

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2892			4.96	184	DNG	P 1	09H	+2.11	TECTEH			S8982	seco	22H00047	H	600UL	331895
2893			3.84	178	DNG	P 1	09H	+5.15	TECTEH			S8982	seco	22H00047	H	600UL	331895
2894			12.21	180	DNG	P 1	09H	+6.16	TECTEH			S8982	seco	22H00047	H	600UL	331895
2895			3.91	181	DNG	P 1	09C	+14.48	TECTEH			S8982	seco	22H00047	H	600UL	331895
2896	131	77	4.29	181	DNG	P 1	08H	+18.92	TECTEH			F4645	seco	22H00046	H	600UL	340972
2897	133	77	4.21	183	DNG	P 1	04H	+24.85	TECTEH			I3805	seco	22H00072	H	600UL	340945
2898	135	77	0.42	82	PLP	9	TSH	+0.15	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2899			2.94	186	DNT	P 1	10H	+0.41	TECTEH			M1637	seco	22H00073	H	600UL	340927
2900	137	77	0.47	73	PLP	9	TSH	+0.23	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2901	139	77	0.40	73	PLP	9	TSH	+0.13	TSHTSH			S8982	seco	22H00193	H	600PP	345345
2902			8.76	182	DNT	P 1	10H	+0.37	TECTEH			A6997	seco	22H00093	H	600UL	340929
2903			2.10	183	DNG	P 1	10H	+19.14	TECTEH			A6997	seco	22H00093	H	600UL	340929
2904	36	78	0.73	133	INR	P 1	07H	-1.47	TECTEH			M0945	seco	22H00054	H	600UL	340944
2905	40	78	4.10	181	DNG	P 1	VM	+10.26	TECTEH			M0945	seco	22H00054	H	600UL	340944
2906	44	78	3.41	179	DNG	P 1	VM	+10.18	TECTEH			M0945	seco	22H00054	H	600UL	340944
2907	56	78	2.00	180	DNG	P 1	VM	+10.51	TECTEH			M0945	seco	22H00054	H	600UL	340944
2908	58	78	2.75	181	DNG	P 1	VM	+18.57	TECTEH			D4576	seco	22H00053	H	600UL	340945
			0.40	77	MBM	5	04C	+7.72	TECTEH			F3453	reso	22H00053	H	600UL	340945
	60	78	3.13	181	DNG	P 1	VM	+19.92	TECTEH			M0945	seco	22H00054	H	600UL	340944
2911	62	78	0.62	83	MBM	5	01C	+12.69	TECTEH			F3453	reso	22H00053	H	600UL	340945
2912	66	78	8.65	183	DNG	P 1	07H	+13.35	TECTEH			D4576	seco	22H00053	H	600UL	340945
2913	68	78	3.87	180	DNG	P 1	05H	+22.57	TECTEH			M0945	seco	22H00054	H	600UL	340944
2914	72	78	0.48	70	MBM	6	02H	+10.10	TECTEH			N5432	reso	22H00054	H	600UL	340944
2915			0.53	71	MBM	6	04H	+31.68	TECTEH			N5432	reso	22H00054	H	600UL	340944
2916			0.60	85	MBM	5	05H	+10.37	TECTEH			N5432	reso	22H00054	H	600UL	340944
2917			0.37	73	MBM	5	05H	+13.13	TECTEH			N5432	reso	22H00054	H	600UL	340944
2918			0.54	85	MBM	5	05H	+15.33	TECTEH			N5432	reso	22H00054	H	600UL	340944
2919			0.51	86	MBM	5	05H	+16.00	TECTEH			N5432	reso	22H00054	H	600UL	340944
2920			0.82	77	MBM	5	05H	+23.19	TECTEH			N5432	reso	22H00054	H	600UL	340944
2921			0.44	85	MBM	5	04C	+4.74	TECTEH			N5432	reso	22H00054	H	600UL	340944
2922	80	78	1.13	75	MBM	5	03H	+14.24	TECTEH			F3453	reso	22H00053	H	600UL	340945
2923	82	78			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
2924			0.16	93	SAI	2	TSH	+0.77	TSHTSH	0.2		C5542	reso	22H00142	H	600PP	345291
2925			0.15	101	PID	4	TSH	+0.77	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
2926			0.10	45	SAI	1	TSH	+0.77	TSHTSH	0.2		C5542	reso	22H00142	H	600PP	345291
2927	112	78	2.47	187	DNG	P 1	VH	+28.45	TECTEH			F4645	seco	22H00046	H	600UL	340972
2928	116	78	17.59	184	DNT	P 1	09H	-0.04	TECTEH			F4645	seco	22H00046	H	600UL	340972
2929	118	78	19.13	183	DNT	P 1	09H	-0.17	TECTEH			S8982	seco	22H00047	H	600UL	331895
2930	120	78	5.88	183	DNG	P 1	09H	+4.83	TECTEH			F4645	seco	22H00046	H	600UL	340972
2931	126	78			NDF		09C	+0.13	09C09C			F6623	reso	22C00087	C	600PP	345298
2932			0.55	92	DSI	P 1	09C	+0.13	TECTEH			H3464	prim	22H00047	H	600UL	331895
2933	134	78			NDF		09H	-0.04	09H09H			S8982	seco	22H00193	H	600PP	345345
2934			10.55	180	DNT	P 1	09H	-0.04	TECTEH			M1637	seco	22H00073	H	600UL	340927
			6.39	176	DNG	P 1	VH	+28.34	TECTEH			M1637	seco	22H00073	H	600UL	340927
2936	138	78	0.50	82	MBM	5	TSH	+12.00	TECTEH			F3453	reso	22H00093	H	600UL	340929
2937			5.06	183	DNT	P 1	10H	+0.53	TECTEH			A6997	seco	22H00093	H	600UL	340929
2938	140	78	3.05	178	DNG	P 1	01H	+11.76	TECTEH			A6997	seco	22H00093	H	600UL	340929
2939			5.17	182	DNT	P 1	10H	-0.51	TECTEH			A6997	seco	22H00093	H	600UL	340929

2940			5.41	183	DNT	P 1	10H	+0.33	TECTEH			A6997	seco	22H00093	H	600UL		340929

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 61

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2941			0.59	70	MBM	5	05C	+3.40	TECTEH			F3453	reso	22H00093	H	600UL	340929
2942	41	79			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
2943			0.08	98	SAI	1	TSH	+0.63	TSHTSH	0.2		C5542	reso	22H00143	H	600PP	345329
2944			0.14	90	SAI	2	TSH	+0.63	TSHTSH	0.2		C5542	reso	22H00143	H	600PP	345329
2945			0.15	93	PID	4	TSH	+0.63	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
2946	43	79			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
2947			0.00	0	MAI	3	TSH	+1.42	TSHTSH	0.0		F3453	reso	22H00180	H	600PP	345290
2948			0.09	91	MAI	4	TSH	+1.42	TSHTSH	0.3		F3453	reso	22H00180	H	600PP	345290
2949			0.14	84	SAI	4	TSH	+1.77	TSHTSH	0.2		F3453	reso	22H00180	H	600PP	345290
2950			0.00	0	SAI	3	TSH	+1.77	TSHTSH	0.0		F3453	reso	22H00180	H	600PP	345290
2951			0.14	97	PID	4	TSH	+1.77	TSHTSH	080		L2157	reso	22H00195	H	600PP	345355
2952			0.08	63	SAI	4	TSH	+1.96	TSHTSH	0.2		F3453	reso	22H00180	H	600PP	345290
2953			0.00	0	SAI	3	TSH	+1.96	TSHTSH	0.0		F3453	reso	22H00180	H	600PP	345290
2954	47	79			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
2955			0.0	0	SAI	1	TSC	+1.99	TSCTSC	0.0		M1680	reso	22C00037	C	600PP	345352
2956			0.12	108	PID	4	TSC	+1.99	TSCTSC	080		N5432	reso	22C00070	C	600PP	345324
2957			0.12	115	SAI	2	TSC	+1.99	TSCTSC	0.2		M1680	reso	22C00037	C	600PP	345352
	59	79	2.70	177	DNG	P 1	03C	+6.95	TECTEH			D3858	reso	22H00050	H	600UL	340945
.	67	79	3.00	181	DNG	P 1	02C	+19.89	TECTEH			M0945	seco	22H00050	H	600UL	340945
2960	69	79			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
2961			0.18	59	SAI	1	TSH	+1.96	TSHTSH	0.4		C5542	reso	22H00143	H	600PP	345329
2962			0.15	113	SAI	2	TSH	+1.96	TSHTSH	0.4		C5542	reso	22H00143	H	600PP	345329
2963			0.12	114	MAI	2	TSH	+2.60	TSHTSH	0.3		C5542	reso	22H00143	H	600PP	345329
2964			0.00	0	MAI	1	TSH	+2.60	TSHTSH	0.0		C5542	reso	22H00143	H	600PP	345329
2965			0.18	137	PID	4	TSH	+2.60	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
2966			2.38	180	DNG	P 1	06C	+19.67	TECTEH			D4576	seco	22H00049	H	600UL	340944
2967	75	79	0.67	80	MBM	5	07C	+8.54	TECTEH			D3858	reso	22H00050	H	600UL	340945
2968	79	79			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
2969			0.19	83	MAI	2	TSH	+0.87	TSHTSH	0.3		C5542	reso	22H00142	H	600PP	345291
2970			0.17	92	PID	4	TSH	+0.87	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
2971			0.16	105	MAI	1	TSH	+0.87	TSHTSH	0.3		C5542	reso	22H00142	H	600PP	345291
2972			0.00	0	SAI	1	TSH	+1.34	TSHTSH	0.0		C5542	reso	22H00142	H	600PP	345291
2973			0.12	112	SAI	2	TSH	+1.34	TSHTSH	0.2		C5542	reso	22H00142	H	600PP	345291
2974			0.18	82	SAI	2	TSH	+1.58	TSHTSH	0.3		C5542	reso	22H00142	H	600PP	345291
2975			0.22	71	SAI	1	TSH	+1.58	TSHTSH	0.3		C5542	reso	22H00142	H	600PP	345291
2976	85	79			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
2977			0.91	110	NQI	P 1	TSH	+0.63	TECTEH			D3858	reso	22H00050	H	600UL	340945
2978			0.24	93	MAI	2	TSH	+0.64	TSHTSH	0.7		C5542	reso	22H00142	H	600PP	345291
2979			0.23	98	PID	4	TSH	+0.64	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
2980			0.27	75	MAI	1	TSH	+0.64	TSHTSH	0.5		C5542	reso	22H00142	H	600PP	345291
2981			0.00	0	SAI	1	TSH	+3.14	TSHTSH	0.0		C5542	reso	22H00142	H	600PP	345291
2982			0.12	113	SAI	2	TSH	+3.14	TSHTSH	0.2		C5542	reso	22H00142	H	600PP	345291
2983	87	79			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
			0.00	0	SAI	1	TSH	+0.60	TSHTSH	0.0		C5542	reso	22H00142	H	600PP	345291
2985			0.16	109	PID	4	TSH	+0.60	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
2986			0.16	101	SAI	2	TSH	+0.60	TSHTSH	0.3		C5542	reso	22H00142	H	600PP	345291
2987	91	79	0.78	86	MBM	5	04H	+23.38	TECTEH			F6623	reso	22H00046	H	600UL	340972
2988	103	79	0.83	83	MBM	5	02H	+34.84	TECTEH			F6623	reso	22H00046	H	600UL	340972

2989			0.55	85	MBM	5	03H	+11.50	TECTEH			F6623	reso	22H00046	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 62

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2990		0.55	76	MBM	5	05H	+35.98	TECTEH			F6623	reso	22H00046	H	600UL	340972
2991		0.84	98	MBM	5	08H	+19.80	TECTEH			F6623	reso	22H00046	H	600UL	340972
2992		0.62	72	MBM	5	VH	+22.74	TECTEH			F6623	reso	22H00046	H	600UL	340972
2993	105	0.61	81	MBM	5	05H	+23.04	TECTEH			M7006	reso	22H00086	H	600UL	340912
2994	107			NDF		TSH	+15.02	TSH01H			M7006	reso	22H00190	H	600PP	345345
2995		0.26	108	NQI	P 1	TSH	+15.02	TECTEH			J9815	prim	22H00046	H	600UL	340972
2996	109	1.01	83	MBM	5	08H	+10.53	TECTEH			M7006	reso	22H00086	H	600UL	340912
2997	111	3.98	182	DNG	P 1	VH	+2.42	TECTEH			F4645	seco	22H00046	H	600UL	340972
2998	115	10.62	183	DNT	P 1	09H	-0.02	TECTEH			F4645	seco	22H00046	H	600UL	340972
2999	117	20.89	181	DNT	P 1	09H	-0.13	TECTEH			S8982	seco	22H00047	H	600UL	331895
3000		3.99	181	DNT	P 1	10C	+0.48	TECTEH			S8982	seco	22H00047	H	600UL	331895
3001	119	0.78	83	MBM	5	02C	+26.64	TECTEH			F6623	reso	22H00046	H	600UL	340972
3002	121	2.39	178	DNG	P 1	10C	+3.19	TECTEH			S8982	seco	22H00047	H	600UL	331895
3003		4.83	205	NRC	2	TSC	+0.00	TECTEH			H3464	prim	22H00047	H	600UL	331895
3004	123	0.30	77	MBM	5	02H	+32.22	TECTEH			F6623	reso	22H00046	H	600UL	340972
3005		0.67	70	MBM	5	03H	+12.00	TECTEH			F6623	reso	22H00046	H	600UL	340972
3006		2.14	183	DNG	P 1	08H	+13.20	TECTEH			F4645	seco	22H00046	H	600UL	340972
		0.52	95	MBM	5	VM	+13.19	TECTEH			F6623	reso	22H00046	H	600UL	340972
[illegible]	129	9.76	181	DNG	P 1	07H	+16.25	TECTEH			S8982	seco	22H00047	H	600UL	331895
3009		3.30	180	DNG	P 1	07H	+17.61	TECTEH			S8982	seco	22H00047	H	600UL	331895
3010		3.04	179	DNG	P 1	07H	+21.99	TECTEH			S8982	seco	22H00047	H	600UL	331895
3011		3.59	180	DNG	P 1	07H	+24.36	TECTEH			S8982	seco	22H00047	H	600UL	331895
3012		8.57	179	DNG	P 1	08H	-1.40	TECTEH			S8982	seco	22H00047	H	600UL	331895
3013		7.48	179	DNT	P 1	08H	-1.14	TECTEH			S8982	seco	22H00047	H	600UL	331895
3014		25.25	180	DNT	P 1	08H	-0.43	TECTEH			S8982	seco	22H00047	H	600UL	331895
3015		4.33	179	DNG	P 1	08H	+1.94	TECTEH			S8982	seco	22H00047	H	600UL	331895
3016		3.94	184	DNG	P 1	08H	+16.36	TECTEH			S8982	seco	22H00047	H	600UL	331895
3017		3.70	181	DNT	P 1	10C	+0.45	TECTEH			S8982	seco	22H00047	H	600UL	331895
3018		11.45	179	DNG	P 1	10C	+1.43	TECTEH			S8982	seco	22H00047	H	600UL	331895
3019		2.50	182	DNG	P 1	09C	+14.92	TECTEH			S8982	seco	22H00047	H	600UL	331895
3020		3.00	182	DNG	P 1	09C	+19.02	TECTEH			S8982	seco	22H00047	H	600UL	331895
3021		4.59	181	DNG	P 1	08C	+17.49	TECTEH			S8982	seco	22H00047	H	600UL	331895
3022	131	2.42	181	DNG	P 1	05H	-1.36	TECTEH			F4645	seco	22H00046	H	600UL	340972
3023	137	6.32	180	DNT	P 1	10H	+0.37	TECTEH			A6997	seco	22H00093	H	600UL	340929
3024		2.36	182	DNG	P 1	VM	+2.91	TECTEH			A6997	seco	22H00093	H	600UL	340929
3025	40	3.48	181	DNG	P 1	VM	+10.25	TECTEH			D4576	seco	22H00049	H	600UL	340944
3026	42	2.41	181	DNG	P 1	VM	+9.85	TECTEH			D3858	reso	22H00050	H	600UL	340945
3027	54	2.58	185	DNT	P 1	05H	-0.24	TECTEH			D3858	reso	22H00050	H	600UL	340945
3028	56	3.27	178	DNG	P 1	VM	+18.19	TECTEH			D4576	seco	22H00049	H	600UL	340944
3029	60	3.48	182	DNG	P 1	VM	+20.20	TECTEH			D4576	seco	22H00049	H	600UL	340944
3030	68	2.37	182	DNG	P 1	02C	+3.16	TECTEH			D4576	seco	22H00049	H	600UL	340944
3031	72			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
[illegible]		0.00	0	SAI	1	TSH	+2.56	TSHTSH	0.0		C5542	reso	22H00142	H	600PP	345291
		0.06	94	SAI	2	TSH	+2.56	TSHTSH	0.2		C5542	reso	22H00142	H	600PP	345291
3034		0.07	100	PID	4	TSH	+2.56	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
3035	80	2.24	89	MBM	6	03C	+25.52	TECTEH			N5432	reso	22H00049	H	600UL	340944
3036	86			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3037		0.00	0	SAI	1	TSH	+0.88	TSHTSH	0.0		C5542	reso	22H00142	H	600PP	345291

3038			0.09	90	SAI	2	TSH	+0.88	TSHTSH	0.2			C5542	reso	22H00142	H	600PP	345291

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 63

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3039		0.10	130	PID	4	TSH	+0.88	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
3040	94	5.63	184	DNT	P 1	09H	-0.02	TECTEH			F4645	seco	22H00046	H	600UL	340972
3041	98	0.40	64	MBM	5	09H	+3.24	TECTEH			F3453	reso	22H00047	H	600UL	331895
3042	108	5.18	182	DNG	P 1	08H	+4.10	TECTEH			F4645	seco	22H00046	H	600UL	340972
3043		2.03	183	DNG	P 1	08H	+11.39	TECTEH			F4645	seco	22H00046	H	600UL	340972
3044	110	0.57	73	MBM	5	05C	+3.49	TECTEH			F3453	reso	22H00047	H	600UL	331895
3045	114	22.93	182	DNT	P 1	09H	+0.02	TECTEH			S8982	seco	22H00047	H	600UL	331895
3046	116	42.52	182	DNT	P 1	09H	-0.09	TECTEH			F4645	seco	22H00046	H	600UL	340972
3047	120	3.17	175	DNT	P 1	07H	-0.96	TECTEH			F4645	seco	22H00046	H	600UL	340972
3048		3.60	180	DNG	P 1	09H	-1.16	TECTEH			F4645	seco	22H00046	H	600UL	340972
3049	128	2.49	181	DNG	P 1	08H	+9.69	TECTEH			F4645	seco	22H00046	H	600UL	340972
3050		2.57	182	DNG	P 1	09H	+15.32	TECTEH			F4645	seco	22H00046	H	600UL	340972
3051		2.93	190	DNG	P 1	10H	+10.07	TECTEH			F4645	seco	22H00046	H	600UL	340972
3052	132	3.75	183	DNG	P 1	09C	+15.45	TECTEH			I3805	seco	22H00072	H	600UL	340945
3053		2.64	182	DNG	P 1	09C	+16.69	TECTEH			I3805	seco	22H00072	H	600UL	340945
3054	134	5.72	180	DNT	P 1	09H	-0.02	TECTEH			M1637	seco	22H00073	H	600UL	340927
3055		2.63	179	DNG	P 1	09H	+13.64	TECTEH			M1637	seco	22H00073	H	600UL	340927
		4.70	176	DNT	P 1	10H	-0.43	TECTEH			M1637	seco	22H00073	H	600UL	340927
		6.06	183	DNT	P 1	10H	+0.37	TECTEH			M1637	seco	22H00073	H	600UL	340927
3058		2.46	176	DNG	P 1	VH	+28.50	TECTEH			M1637	seco	22H00073	H	600UL	340927
3059	136	6.76	182	DNG	P 1	10H	-1.38	TECTEH			A6997	seco	22H00093	H	600UL	340929
3060		23.70	181	DNT	P 1	10H	-0.20	TECTEH			A6997	seco	22H00093	H	600UL	340929
3061		16.26	181	DNT	P 1	10H	+0.37	TECTEH			A6997	seco	22H00093	H	600UL	340929
3062	138	10.29	180	DNT	P 1	10H	-0.43	TECTEH			A6997	seco	22H00093	H	600UL	340929
3063		6.72	183	DNT	P 1	10H	+0.37	TECTEH			A6997	seco	22H00093	H	600UL	340929
3064		1.28	86	MBM	5	02C	+36.22	TECTEH			F3453	reso	22H00093	H	600UL	340929
3065	140	4.23	79	DTI	P 3	TSH	+0.26	TECTEH			D6502	prim	22H00093	H	600UL	340929
3066				NDF		TSH	+0.26	TSHTSH			M1680	reso	22H00193	H	600PP	345345
3067		4.03	181	DNG	P 1	09H	+12.51	TECTEH			A6997	seco	22H00093	H	600UL	340929
3068		19.13	180	DNT	P 1	10H	-0.45	TECTEH			A6997	seco	22H00093	H	600UL	340929
3069		19.73	182	DNT	P 1	10H	+0.44	TECTEH			A6997	seco	22H00093	H	600UL	340929
3070	41	3.91	177	DNT	P 1	07H	-0.95	TECTEH			D4576	seco	22H00049	H	600UL	340944
3071	67	7.18	182	DNG	P 1	07H	+1.40	TECTEH			M0945	seco	22H00050	H	600UL	340945
3072		8.22	183	DNG	P 1	07H	+7.86	TECTEH			M0945	seco	22H00050	H	600UL	340945
3073		4.02	182	DNG	P 1	07H	+9.79	TECTEH			M0945	seco	22H00050	H	600UL	340945
3074		11.65	181	DNG	P 1	07H	+12.28	TECTEH			M0945	seco	22H00050	H	600UL	340945
3075		12.10	179	DNG	P 1	07H	+14.16	TECTEH			M0945	seco	22H00050	H	600UL	340945
3076		5.59	183	DNG	P 1	07C	+1.53	TECTEH			M0945	seco	22H00050	H	600UL	340945
3077		4.45	180	DNG	P 1	07C	+4.02	TECTEH			M0945	seco	22H00050	H	600UL	340945
3078		2.38	182	DNG	P 1	07C	+7.49	TECTEH			M0945	seco	22H00050	H	600UL	340945
3079	75	5.69	182	DNG	P 1	06H	+21.99	TECTEH			M0945	seco	22H00050	H	600UL	340945
3080		3.93	182	DNG	P 1	07H	+11.05	TECTEH			M0945	seco	22H00050	H	600UL	340945
		13.69	182	DNG	P 1	07H	+13.53	TECTEH			M0945	seco	22H00050	H	600UL	340945
	91	4.33	180	DNG	P 1	09H	-1.64	TECTEH			F4645	seco	22H00046	H	600UL	340972
3083		7.35	189	DNT	P 1	09H	-0.49	TECTEH			F4645	seco	22H00046	H	600UL	340972
3084		2.01	185	DNG	P 1	07C	+18.38	TECTEH			F4645	seco	22H00046	H	600UL	340972
3085	97	4.04	184	DNT	P 1	09H	+0.00	TECTEH			S8982	seco	22H00047	H	600UL	331895
3086		2.18	181	DNG	P 1	07C	+23.66	TECTEH			S8982	seco	22H00047	H	600UL	331895

3087	115	81		NDF	09H	+0.00	09H09H				T7451	seco	22H00190	H	600PP	345345

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 64

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3088		19.59	186	DNT	P 1	09H	+0.00	TECTEH			F4645	seco	22H00046	H	600UL	340972
3089	117	3.32	186	DNT	P 1	10C	-0.49	TECTEH			S8982	seco	22H00047	H	600UL	331895
3090		10.03	180	DNT	P 1	10C	+0.54	TECTEH			S8982	seco	22H00047	H	600UL	331895
3091	119	8.99	183	DNG	P 1	08H	+3.54	TECTEH			F4645	seco	22H00046	H	600UL	340972
3092		3.19	180	DNG	P 1	08H	+10.73	TECTEH			F4645	seco	22H00046	H	600UL	340972
3093		3.21	182	DNG	P 1	08H	+12.56	TECTEH			F4645	seco	22H00046	H	600UL	340972
3094		4.85	181	DNG	P 1	08H	+20.14	TECTEH			F4645	seco	22H00046	H	600UL	340972
3095		2.36	182	DNG	P 1	09H	+1.35	TECTEH			F4645	seco	22H00046	H	600UL	340972
3096	121	3.36	180	DNT	P 1	09H	-0.11	TECTEH			T7451	seco	22H00086	H	600UL	340912
3097		4.16	212	NRC	2	TSC	+0.00	TECTEH			D6502	prim	22H00086	H	600UL	340912
3098	131			NDF		TSH	+0.00	TSHTSH			H3464	prim	22H00138	H	600PP	345291
3099		12.43	40	DTI	P 3	TSH	+0.00	TECTEH			J9815	prim	22H00046	H	600UL	340972
3100		4.19	180	DNG	P 1	07H	+10.32	TECTEH			F4645	seco	22H00046	H	600UL	340972
3101	137	9.25	183	DNT	P 1	10H	-0.50	TECTEH			A6997	seco	22H00093	H	600UL	340929
3102		13.54	182	DNT	P 1	10H	+0.55	TECTEH			A6997	seco	22H00093	H	600UL	340929
3103	139	5.58	179	DNT	P 1	10H	-0.62	TECTEH			A6997	seco	22H00093	H	600UL	340929
3104		3.25	181	DNT	P 1	10H	+0.55	TECTEH			A6997	seco	22H00093	H	600UL	340929
	46			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
		0.15	84	PID	4	TSH	+1.59	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
3107		0.14	81	SAI	1	TSH	+1.59	TSHTSH	0.3		C5542	reso	22H00142	H	600PP	345291
3108		0.14	102	SAI	2	TSH	+1.59	TSHTSH	0.3		C5542	reso	22H00142	H	600PP	345291
3109	58	4.71	181	DNG	P 1	VM	+19.24	TECTEH			D4576	seco	22H00049	H	600UL	340944
3110	70	3.40	181	DNG	P 1	07H	+5.52	TECTEH			D4576	seco	22H00049	H	600UL	340944
3111	82			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3112		0.09	91	SAI	2	TSH	+0.86	TSHTSH	0.2		C5542	reso	22H00142	H	600PP	345291
3113		0.10	136	PID	4	TSH	+0.86	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
3114		0.00	0	SAI	1	TSH	+0.86	TSHTSH	0.0		C5542	reso	22H00142	H	600PP	345291
3115	96			NDF		09H	-0.02	09H09H			T7451	seco	22H00190	H	600PP	345345
3116		20.42	183	DNT	P 1	09H	-0.02	TECTEH			F4645	seco	22H00046	H	600UL	340972
3117		2.21	181	DNG	P 1	07C	+21.83	TECTEH			F4645	seco	22H00046	H	600UL	340972
3118		3.51	184	DNG	P 1	07C	+22.69	TECTEH			F4645	seco	22H00046	H	600UL	340972
3119		0.48	89	MBM	5	TSC	+21.28	TECTEH			F6623	reso	22H00046	H	600UL	340972
3120	102	62.55	179	DNT	P 1	09H	+0.16	TECTEH			S8982	seco	22H00047	H	600UL	331895
3121				NDF		09H	+0.16	09H09H			T7451	seco	22H00190	H	600PP	345345
3122	106	0.88	81	MBM	5	06C	+15.06	TECTEH			F3453	reso	22H00047	H	600UL	331895
3123	108	16.09	181	DNG	P 1	TSC	+24.82	TECTEH			F4645	seco	22H00046	H	600UL	340972
3124	110	15.69	185	DNT	P 1	09H	-0.07	TECTEH			T7451	seco	22H00086	H	600UL	340912
3125	118	28.56	182	DNT	P 1	09H	-0.13	TECTEH			S8982	seco	22H00047	H	600UL	331895
3126	120	0.37	73	MBM	5	03H	+14.71	TECTEH			F6623	reso	22H00046	H	600UL	340972
3127		0.64	88	MBM	5	07H	+15.02	TECTEH			F6623	reso	22H00046	H	600UL	340972
3128		31.06	183	DNT	P 1	09H	-0.11	TECTEH			F4645	seco	22H00046	H	600UL	340972
3129				NDF		09H	-0.11	09H09H			T7451	seco	22H00190	H	600PP	345345
[illegible]	122	2.77	179	DNG	P 1	09H	+7.29	TECTEH			S8982	seco	22H00047	H	600UL	331895
		3.50	183	DNG	P 1	09H	+8.25	TECTEH			S8982	seco	22H00047	H	600UL	331895
3132	124	0.47	72	MBM	5	01H	+11.86	TECTEH			F6623	reso	22H00046	H	600UL	340972
3133	128	3.67	185	DNT	P 1	03H	+1.00	TECTEH			F4645	seco	22H00046	H	600UL	340972
3134		1.97	188	INR	P 1	VC	+7.74	TECTEH			F4645	seco	22H00046	H	600UL	340972
3135	130	13.00	181	DNT	P 1	09H	+0.02	TECTEH			T7451	seco	22H00086	H	600UL	340912

3136	132	82	1.65	186	INR	P 1	06H	+5.00	TECTEH				I3805	seco	22H00072	H	600UL	340945

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 65

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3137			0.82	91	MBM	5	10H	+4.34	TECTEH			C3340	reso	22H00072	H	600UL	340945
3138			5.91	183	DNG	P 1	09C	+17.95	TECTEH			I3805	seco	22H00072	H	600UL	340945
3139	134	82			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
3140			4.21	180	DNT	P 1	09H	-0.15	TECTEH			M1637	seco	22H00073	H	600UL	340927
3141			2.35	183	DNG	P 1	09H	+10.10	TECTEH			M1637	seco	22H00073	H	600UL	340927
3142			2.54	180	DNG	P 1	09H	+14.32	TECTEH			M1637	seco	22H00073	H	600UL	340927
3143			4.50	180	DNT	P 1	10H	-0.42	TECTEH			M1637	seco	22H00073	H	600UL	340927
3144			9.16	181	DNT	P 1	10H	+0.39	TECTEH			M1637	seco	22H00073	H	600UL	340927
3145			3.95	176	DNG	P 1	VH	+29.17	TECTEH			M1637	seco	22H00073	H	600UL	340927
3146			0.12	67	PLP	9	TSC	+0.15	TSCTSC			A9608	reso	22C00047	C	600PP	345352
3147			0.25	121	LPI	1	TSC	+0.16	TSCTSC	0.3	0.2	A9608	reso	22C00047	C	600PP	345352
3148			0.29	109	PID	4	TSC	+0.16	TSCTSC	080		N5432	reso	22C00070	C	600PP	345324
3149			0.26	117	LPI	2	TSC	+0.16	TSCTSC	0.2	0.4	A9608	reso	22C00047	C	600PP	345352
3150	136	82			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
3151			0.31	78	PLP	9	TSH	+0.15	TSHTSH			S8982	seco	22H00193	H	600PP	345345
3152			0.31	81	PID	12	TSH	+0.15	TSHTSH	080		M1680	reso	22H00235	H	600PP	345330
3153			5.07	181	DNT	P 1	10H	-0.47	TECTEH			A6997	seco	22H00093	H	600UL	340929
			4.57	180	DNT	P 1	10H	-0.09	TECTEH			A6997	seco	22H00093	H	600UL	340929
			17.11	181	DNT	P 1	10H	+0.42	TECTEH			A6997	seco	22H00093	H	600UL	340929
3156	138	82	0.29	79	PLP	9	TSH	+0.28	TSHTSH			C3340	reso	22H00193	H	600PP	345345
3157			17.69	178	DNT	P 1	10H	-0.25	TECTEH			A6997	seco	22H00093	H	600UL	340929
3158			20.93	181	DNT	P 1	10H	+0.35	TECTEH			A6997	seco	22H00093	H	600UL	340929
3159	140	82	12.33	179	DNT	P 1	10H	-0.47	TECTEH			A6997	seco	22H00093	H	600UL	340929
3160			5.08	179	DNT	P 1	10H	+0.51	TECTEH			A6997	seco	22H00093	H	600UL	340929
3161			3.32	184	DNG	P 1	03C	+4.43	TECTEH			A6997	seco	22H00093	H	600UL	340929
3162			4.84	184	DNG	P 1	02C	+15.69	TECTEH			A6997	seco	22H00093	H	600UL	340929
3163			4.33	184	DNG	P 1	02C	+17.93	TECTEH			A6997	seco	22H00093	H	600UL	340929
3164	41	83	3.25	184	DNG	P 1	05C	+24.52	TECTEH			D4576	seco	22H00049	H	600UL	340944
3165	45	83	0.78	78	MBM	6	04C	+28.16	TECTEH			N5432	reso	22H00049	H	600UL	340944
3166	51	83	3.32	183	DNT	P 1	05H	-0.33	TECTEH			D3858	reso	22H00050	H	600UL	340945
3167	89	83			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3168			0.00	0	SAI	1	TSH	+0.65	TSHTSH	0.0		C5542	reso	22H00142	H	600PP	345291
3169			0.11	137	PID	4	TSH	+0.65	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
3170			0.11	105	SAI	2	TSH	+0.65	TSHTSH	0.2		C5542	reso	22H00142	H	600PP	345291
3171	91	83			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
3172			0.22	55	SAI	1	TSH	+0.20	TSHTSH	0.2		A9608	reso	22H00138	H	600PP	345291
3173			0.23	93	PID	4	TSH	+0.20	TSHTSH	080		F6623	reso	22H00155	H	600PP	345291
3174			0.23	94	SAI	2	TSH	+0.20	TSHTSH	0.2		A9608	reso	22H00138	H	600PP	345291
3175			1.17	100	MBM	5	VH	+3.71	TECTEH			F6623	reso	22H00046	H	600UL	340972
3176			2.57	185	DNT	P 1	08C	+0.47	TECTEH			F4645	seco	22H00046	H	600UL	340972
3177			6.86	186	DNG	P 1	07C	+23.82	TECTEH			F4645	seco	22H00046	H	600UL	340972
3178			2.79	182	DNG	P 1	07C	+24.74	TECTEH			F4645	seco	22H00046	H	600UL	340972
3179			0.76	79	MBM	5	01C	+20.38	TECTEH			F6623	reso	22H00046	H	600UL	340972
	93	83	2.95	181	DNG	P 1	07C	+19.38	TECTEH			S8982	seco	22H00047	H	600UL	331895
3181	95	83	26.04	185	DNT	P 1	09H	-0.02	TECTEH			F4645	seco	22H00046	H	600UL	340972
3182	99	83			NDF		09H	+0.00	09H09H			T7451	seco	22H00190	H	600PP	345345
3183			12.07	182	DNT	P 1	09H	+0.00	TECTEH			F4645	seco	22H00046	H	600UL	340972
3184			3.49	183	DNG	P 1	04C	+1.84	TECTEH			F4645	seco	22H00046	H	600UL	340972

3185	101	83	21.70	181	DNT	P 1	09H	-0.02	TECTEH				S8982	seco	22H00047	H	600UL	331895

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 66

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3186	103	83	44.30	184	DNT	P 1	09H	-0.09	TECTEH			F4645	seco	22H00046	H	600UL	340972
3187	105	83	2.61	182	DNG	P 1	03C	+4.29	TECTEH			S8982	seco	22H00047	H	600UL	331895
3188	109	83	1.49	82	MBM	5	04H	+7.01	TECTEH			F3453	reso	22H00047	H	600UL	331895
3189			0.64	91	MBM	5	04H	+24.12	TECTEH			F3453	reso	22H00047	H	600UL	331895
3190			0.42	74	MBM	5	04H	+27.88	TECTEH			F3453	reso	22H00047	H	600UL	331895
3191			0.44	85	MBM	5	07H	+20.38	TECTEH			F3453	reso	22H00047	H	600UL	331895
3192	111	83	1.29	93	MBM	5	03H	+25.51	TECTEH			F6623	reso	22H00046	H	600UL	340972
3193			0.94	84	MBM	5	03H	+26.18	TECTEH			F6623	reso	22H00046	H	600UL	340972
3194			4.31	182	DNG	P 1	VH	+2.90	TECTEH			F4645	seco	22H00046	H	600UL	340972
3195			3.10	180	DNG	P 1	VM	+24.31	TECTEH			F4645	seco	22H00046	H	600UL	340972
3196	113	83	0.71	85	MBM	5	TSC	+37.27	TECTEH			F3453	reso	22H00047	H	600UL	331895
3197	117	83	2.47	183	DNT	P 1	06H	-0.61	TECTEH			S8982	seco	22H00047	H	600UL	331895
3198			3.99	184	DNT	P 1	10C	-0.41	TECTEH			S8982	seco	22H00047	H	600UL	331895
3199			5.50	180	DNT	P 1	10C	+0.51	TECTEH			S8982	seco	22H00047	H	600UL	331895
3200	119	83			NDF		09H	-0.02	09H09H			T7451	seco	22H00190	H	600PP	345345
~~3201~~			~~91.57~~	~~180~~	~~DNT~~	~~P 1~~	~~09H~~	~~-0.02~~	~~TECTEH~~			~~F4645~~	~~seco~~	~~22H00046~~	~~H~~	~~600UL~~	~~340972~~
3202	121	83	3.35	180	DNG	P 1	09C	+1.36	TECTEH			M7006	reso	22H00086	H	600UL	340912
			4.57	211	NRC	2	TSC	+0.00	TECTEH			D6502	prim	22H00086	H	600UL	340912
	123	83	2.56	187	DNG	P 1	04C	+24.49	TECTEH			F6623	reso	22H00046	H	600UL	340972
3205	129	83	0.53	61	MBM	5	VC	+9.10	TECTEH			F3453	reso	22H00047	H	600UL	331895
3206	131	83	2.58	188	DNG	P 1	06H	+7.54	TECTEH			F4645	seco	22H00046	H	600UL	340972
3207			6.38	187	DNG	P 1	07H	+9.95	TECTEH			F4645	seco	22H00046	H	600UL	340972
3208	133	83	3.25	179	DNG	P 1	08H	+20.24	TECTEH			I3805	seco	22H00072	H	600UL	340945
3209			0.23	87	INR	5	09H	+9.63	TECTEH			I3805	seco	22H00072	H	600UL	340945
3210			2.47	189	DNT	P 1	10H	-0.40	TECTEH			I3805	seco	22H00072	H	600UL	340945
3211			3.93	184	DNT	P 1	10H	+0.41	TECTEH			I3805	seco	22H00072	H	600UL	340945
3212	135	83	0.26	80	PLP	9	TSH	+0.25	TSHTSH			S8982	seco	22H00193	H	600PP	345345
3213			3.58	179	DNG	P 1	VM	+3.45	TECTEH			M1637	seco	22H00073	H	600UL	340927
3214	137	83	0.30	80	PLP	9	TSH	+0.43	TSHTSH			S8982	seco	22H00193	H	600PP	345345
3215			0.17	82	PLP	9	TSH	+0.93	TSHTSH			S8982	seco	22H00193	H	600PP	345345
3216			11.20	181	DNT	P 1	10H	-0.47	TECTEH			A6997	seco	22H00093	H	600UL	340929
3217			21.95	181	DNT	P 1	10H	+0.48	TECTEH			A6997	seco	22H00093	H	600UL	340929
3218	42	84	1.19	79	MBM	6	01C	+25.17	TECTEH			N5432	reso	22H00049	H	600UL	340944
3219	46	84	8.76	180	DNT	P 1	06H	-0.22	TECTEH			D4576	seco	22H00049	H	600UL	340944
3220	52	84			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
3221			0.07	67	PID	4	TSH	+2.33	TSHTSH	080		F3453	reso	22H00180	H	600PP	345290
3222			0.06	63	SAI	2	TSH	+2.33	TSHTSH	0.2		C5542	reso	22H00142	H	600PP	345291
3223			0.00	0	SAI	1	TSH	+2.33	TSHTSH	0.0		C5542	reso	22H00142	H	600PP	345291
3224			0.53	86	MBM	5	03H	+25.24	TECTEH			D3858	reso	22H00050	H	600UL	340945
3225	54	84	1.65	73	MBM	6	03C	+23.26	TECTEH			N5432	reso	22H00049	H	600UL	340944
3226	58	84	4.55	181	DNG	P 1	VM	+19.37	TECTEH			D4576	seco	22H00049	H	600UL	340944
3227	94	84	2.63	181	DNG	P 1	08C	+17.88	TECTEH			F4645	seco	22H00046	H	600UL	340972
3228	96	84	0.33	74	MBM	5	03H	+17.75	TECTEH			F6623	reso	22H00046	H	600UL	340972
			20.86	182	DNT	P 1	09H	+0.00	TECTEH			F4645	seco	22H00046	H	600UL	340972
3230	98	84	2.17	184	DNG	P 1	TSH	+23.02	TECTEH			S8982	seco	22H00047	H	600UL	331895
3231			72.78	178	DNT	P 1	09H	+0.02	TECTEH			S8982	seco	22H00047	H	600UL	331895
3232					NDF		09H	+0.02	09H09H			T7451	seco	22H00190	H	600PP	345345
3233	104	84	2.10	185	DNG	P 1	08H	+14.00	TECTEH			F6623	reso	22H00046	H	600UL	340972

3234	108	84	3.86	179	DNG	P 1	04C	+3.89	TECTEH			F4645	seco	22H00046	H	600UL	340972

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 67

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3235	110	84	1.85	181	INR	P 1	01C	+25.81	TECTEH			S8982	seco	22H00047	H	600UL	331895
3236	118	84	24.29	181	DNT	P 1	09H	-0.09	TECTEH			S8982	seco	22H00047	H	600UL	331895
3237	126	84	0.49	77	MBM	5	07H	+18.17	TECTEH			F3453	reso	22H00047	H	600UL	331895
3238	130	84	16.58	182	DNT	P 1	09H	-0.04	TECTEH			T7451	seco	22H00086	H	600UL	340912
3239	132	84	0.53	80	MBM	5	VH	+14.38	TECTEH			M7006	reso	22H00073	H	600UL	340927
3240	134	84	5.72	180	DNT	P 1	10H	-0.42	TECTEH			I3805	seco	22H00072	H	600UL	340945
3241			8.83	182	DNT	P 1	10H	+0.39	TECTEH			I3805	seco	22H00072	H	600UL	340945
3242			1.93	181	INR	P 1	DH	+29.50	TECTEH			I3805	seco	22H00072	H	600UL	340945
3243	136	84	11.41	179	DNT	P 1	10H	-0.34	TECTEH			A6997	seco	22H00093	H	600UL	340929
3244			20.16	181	DNT	P 1	10H	+0.42	TECTEH			A6997	seco	22H00093	H	600UL	340929
3245	140	84	2.43	177	DNG	P 1	TSH	+14.59	TECTEH			A6997	seco	22H00093	H	600UL	340929
3246			4.98	180	DNG	P 1	TSH	+17.23	TECTEH			A6997	seco	22H00093	H	600UL	340929
3247			0.62	100	MBM	5	02H	+21.65	TECTEH			F3453	reso	22H00093	H	600UL	340929
3248			1.32	81	MBM	5	03H	+18.60	TECTEH			F3453	reso	22H00093	H	600UL	340929
3249			20.60	180	DNT	P 1	10H	-0.55	TECTEH			A6997	seco	22H00093	H	600UL	340929
3250			12.24	183	DNT	P 1	10H	+0.26	TECTEH			A6997	seco	22H00093	H	600UL	340929
3251	55	85	1.64	83	MBM	5	05H	+17.33	TECTEH			D3858	reso	22H00050	H	600UL	340945
	57	85	3.12	180	DNG	P 1	01C	+1.95	TECTEH			D4576	seco	22H00049	H	600UL	340944
			3.26	181	DNG	P 1	01C	+3.23	TECTEH			D4576	seco	22H00049	H	600UL	340944
3254			2.22	182	DNG	P 1	TSC	+30.74	TECTEH			D4576	seco	22H00049	H	600UL	340944
3255			2.89	181	DNG	P 1	TSC	+32.14	TECTEH			D4576	seco	22H00049	H	600UL	340944
3256	65	85	1.05	79	MBM	6	03H	+7.80	TECTEH			N5432	reso	22H00049	H	600UL	340944
3257	75	85	4.02	179	DNG	P 1	06H	+18.17	TECTEH			D4576	seco	22H00049	H	600UL	340944
3258			9.43	179	DNG	P 1	07H	+5.74	TECTEH			D4576	seco	22H00049	H	600UL	340944
3259	95	85	22.08	184	DNT	P 1	09H	-0.02	TECTEH			F4645	seco	22H00046	H	600UL	340972
3260	97	85	78.14	179	DNT	P 1	09H	+0.27	TECTEH			S8982	seco	22H00047	H	600UL	331895
3261					NDF		09H	+0.27	09H09H			N5432	reso	22H00190	H	600PP	345345
3262	99	85	105.2	181	DNT	P 1	09H	-0.02	TECTEH			F4645	seco	22H00046	H	600UL	340972
3263					NDF		09H	-0.02	09H09H			T7451	seco	22H00190	H	600PP	345345
3264			2.66	178	DNG	P 1	09H	+3.89	TECTEH			F4645	seco	22H00046	H	600UL	340972
3265			0.95	66	MBM	6	VH	+10.37	TECTEH			F6623	reso	22H00046	H	600UL	340972
3266			2.94	161	INR	P 1	09C	+0.00	TECTEH			F6623	reso	22H00046	H	600UL	340972
3267	107	85	0.71	96	MBM	5	04C	+25.48	TECTEH			F6623	reso	22H00046	H	600UL	340972
3268	111	85	6.47	178	DNG	P 1	VM	+29.06	TECTEH			T7451	seco	22H00086	H	600UL	340912
3269	113	85	6.42	181	DNG	P 1	TSH	+37.73	TECTEH			T7451	seco	22H00086	H	600UL	340912
3270			2.14	180	DNG	P 1	01C	+14.71	TECTEH			T7451	seco	22H00086	H	600UL	340912
3271	117	85	4.63	178	DNT	P 1	10H	-0.33	TECTEH			D4576	seco	22H00049	H	600UL	340944
3272	119	85	4.57	179	DNT	P 1	09H	+0.00	TECTEH			M0945	seco	22H00050	H	600UL	340945
3273			6.44	181	DNT	P 1	10H	-0.14	TECTEH			M0945	seco	22H00050	H	600UL	340945
3274	121	85	6.00	180	DNT	P 1	10H	-0.05	TECTEH			D4576	seco	22H00049	H	600UL	340944
3275			4.81	27	NRC	2	TSC	-0.04	TECTEH			J9815	prim	22H00049	H	600UL	340944
3276	129	85	4.00	185	DNT	P 1	09H	-0.13	TECTEH			D4576	seco	22H00049	H	600UL	340944
	131	85	16.80	181	DNT	P 1	09H	+0.09	TECTEH			D3858	reso	22H00050	H	600UL	340945
	133	85	3.27	181	DNG	P 1	VH	+7.43	TECTEH			A9608	reso	22H00073	H	600UL	340927
3279	135	85	4.32	183	DNT	P 1	10H	-0.38	TECTEH			I3805	seco	22H00072	H	600UL	340945
3280			12.94	180	DNT	P 1	10H	+0.41	TECTEH			I3805	seco	22H00072	H	600UL	340945
3281	68	86	3.15	185	DNG	P 1	TSH	+30.32	TECTEH			H2949	seco	22H00110	H	600UL	340929
3282	70	86			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892

3283			0.21	112	MAI	2	TSH	+1.68	TSHTSH	0.4			L2157	reso	22H00170	H	600PP	345290

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 68

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3284		0.16	108	MAI	1	TSH	+1.68	TSHTSH	0.3		L2157	reso	22H00170	H	600PP	345290
3285		0.23	112	PID	4	TSH	+1.68	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
3286		3.02	184	DNG	P 1	07H	+17.02	TECTEH			H2949	seco	22H00110	H	600UL	340929
3287	72	2.71	184	DNG	P 1	04C	+4.43	TECTEH			H2949	seco	22H00110	H	600UL	340929
3288		5.01	185	DNG	P 1	04C	+6.37	TECTEH			H2949	seco	22H00110	H	600UL	340929
3289	74	0.73	79	MBM	5	TSH	+11.87	TECTEH			M7006	reso	22H00110	H	600UL	340929
3290	94	11.69	183	DNT	P 1	09H	-0.13	TECTEH			A9574	seco	22H00003	H	600UL	331939
3291	98	73.86	181	DNT	P 1	09H	+0.00	TECTEH			M9715	seco	22H00004	H	600UL	331888
3292				NDF		09H	+0.00	09H09H			M7007	prim	22H00203	H	600PP	345330
3293	110	21.21	182	DNT	P 1	09H	-0.15	TECTEH			M9715	seco	22H00004	H	600UL	331888
3294	116	0.60	84	MBM	5	02H	+13.62	TECTEH			C5542	reso	22H00004	H	600UL	331888
3295		3.90	181	DNT	P 1	09H	-0.02	TECTEH			M9715	seco	22H00004	H	600UL	331888
3296		0.65	93	MBM	6	DH	+11.30	TECTEH			C5542	reso	22H00004	H	600UL	331888
3297		0.63	65	MBM	5	VH	+28.73	TECTEH			C5542	reso	22H00004	H	600UL	331888
3298		0.57	75	MBM	5	08C	+2.88	TECTEH			C5542	reso	22H00004	H	600UL	331888
3299	118	19.35	183	DNT	P 1	09H	-0.07	TECTEH			A9574	seco	22H00003	H	600UL	331939
3300	128	0.54	76	MBM	5	04C	+22.35	TECTEH			C5542	reso	22H00004	H	600UL	331888
	132	2.24	181	DNT	P 1	09H	+0.18	TECTEH			A6997	seco	22H00093	H	600UL	340929
	134	6.04	184	DNT	P 1	10H	+0.42	TECTEH			A6997	seco	22H00093	H	600UL	340929
3303	136	0.17	82	PLP	9	TSH	+0.42	TSHTSH			A9608	reso	22H00191	H	600PP	345326
3304		6.71	183	DNT	P 1	10H	-0.49	TECTEH			A6997	seco	22H00093	H	600UL	340929
3305		18.84	180	DNT	P 1	10H	+0.51	TECTEH			A6997	seco	22H00093	H	600UL	340929
3306	138	0.29	78	PLP	9	TSH	+0.67	TSHTSH			A9608	reso	22H00191	H	600PP	345326
3307		17.73	179	DNT	P 1	10H	-0.48	TECTEH			A6997	seco	22H00093	H	600UL	340929
3308		25.49	180	DNT	P 1	10H	+0.44	TECTEH			A6997	seco	22H00093	H	600UL	340929
3309	140	0.49	74	MBM	5	TSH	+5.19	TECTEH			F3453	reso	22H00093	H	600UL	340929
3310		30.18	180	DNT	P 1	10H	-0.44	TECTEH			A6997	seco	22H00093	H	600UL	340929
3311		14.20	183	DNT	P 1	10H	+0.40	TECTEH			A6997	seco	22H00093	H	600UL	340929
3312		2.98	177	DNT	P 1	10C	-0.58	TECTEH			A6997	seco	22H00093	H	600UL	340929
3313		4.18	181	DNT	P 1	10C	+0.24	TECTEH			A6997	seco	22H00093	H	600UL	340929
3314		2.53	182	DNG	P 1	09C	+16.48	TECTEH			A6997	seco	22H00093	H	600UL	340929
3315		2.46	181	DNG	P 1	09C	+19.14	TECTEH			A6997	seco	22H00093	H	600UL	340929
3316		7.93	183	DNG	P 1	09C	+20.07	TECTEH			A6997	seco	22H00093	H	600UL	340929
3317	37	0.53	83	MBM	5	01C	+27.29	TECTEH			M7006	reso	22H00110	H	600UL	340929
3318	47			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
3319		0.09	94	SAI	2	TSH	+2.19	TSHTSH	0.2		L2157	reso	22H00170	H	600PP	345290
3320		0.11	87	PID	4	TSH	+2.19	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
3321		0.09	43	SAI	1	TSH	+2.19	TSHTSH	0.3		L2157	reso	22H00170	H	600PP	345290
3322	77			NDF		03H	+36.91	03H04H			M7007	prim	22H00203	H	600PP	345330
3323		0.81	118	NQI	5	03H	+36.91	TECTEH			D3858	reso	22H00045	H	600UL	340830
3324	89			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3325		0.17	38	PID	4	TSH	+0.43	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
		0.09	23	SAI	1	TSH	+0.43	TSHTSH	0.3		L2157	reso	22H00170	H	600PP	345290
		0.15	72	SAI	2	TSH	+0.43	TSHTSH	0.2		L2157	reso	22H00170	H	600PP	345290
3328		0.97	79	MBM	5	03H	+19.21	TECTEH			C3340	reso	22H00048	H	600UL	340948
3329	91	3.16	182	DNG	P 1	08C	+4.20	TECTEH			A9574	seco	22H00003	H	600UL	331939
3330		2.72	182	DNG	P 1	08C	+5.65	TECTEH			A9574	seco	22H00003	H	600UL	331939
3331		7.16	183	DNG	P 1	08C	+6.57	TECTEH			A9574	seco	22H00003	H	600UL	331939

3332			6.90	183	DNG	P 1	08C	+8.19	TECTEH			A9574	seco	22H00003	H	600UL	331939

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 69

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3333	95	87	2.25	178	DNG	P 1	07C	+8.53	TECTEH			M9715	seco	22H00004	H	600UL	331888
3334	101	87	0.92	83	MBM	5	TSH	+3.64	TECTEH			N5432	reso	22H00003	H	600UL	331939
3335	109	87	1.88	39	PVN	2	TSC	+1.53	TSCTSC			T7451	seco	22C00027	C	600PP	345294
3336	111	87	2.80	180	DNG	P 1	VH	+7.97	TECTEH			M9715	seco	22H00004	H	600UL	331888
3337	113	87	2.10	178	DNG	P 1	07H	+9.46	TECTEH			A9574	seco	22H00003	H	600UL	331939
3338			4.16	179	DNG	P 1	08H	+5.89	TECTEH			A9574	seco	22H00003	H	600UL	331939
3339			2.23	185	DNT	P 1	09H	+0.54	TECTEH			A9574	seco	22H00003	H	600UL	331939
3340	119	87			NDF		09H	+0.09	09H09H			M7007	prim	22H00203	H	600PP	345330
3341			0.29	112	DSI	P 1	09H	+0.09	TECTEH			M7007	prim	22H00004	H	600UL	331888
3342	121	87	3.91	180	DNT	P 1	09H	-0.24	TECTEH			A9574	seco	22H00003	H	600UL	331939
3343			2.80	180	DNG	P 1	VH	+6.37	TECTEH			A9574	seco	22H00003	H	600UL	331939
3344			4.28	211	NRC	2	TSC	+0.00	TECTEH			M1029	prim	22H00003	H	600UL	331939
3345	131	87	3.88	178	DNT	P 1	10H	-0.20	TECTEH			M9715	seco	22H00004	H	600UL	331888
3346			1.71	184	INR	P 1	10C	+0.20	TECTEH			C5542	reso	22H00004	H	600UL	331888
3347	133	87	4.07	181	DNT	P 1	09H	-0.06	TECTEH			A6997	seco	22H00093	H	600UL	340929
3348	135	87	9.10	183	DNT	P 1	10H	+0.44	TECTEH			A6997	seco	22H00093	H	600UL	340929
3349	137	87	6.36	181	DNT	P 1	10H	-0.40	TECTEH			A6997	seco	22H00093	H	600UL	340929
			18.69	181	DNT	P 1	10H	+0.51	TECTEH			A6997	seco	22H00093	H	600UL	340929
	139	87	30.56	181	DNT	P 1	10H	-0.57	TECTEH			A6997	seco	22H00093	H	600UL	340929
3352			20.19	180	DNT	P 1	10H	+0.55	TECTEH			A6997	seco	22H00093	H	600UL	340929
3353	36	88	0.49	129	23	P 2	DH	+1.76	TECTEH			A6997	seco	22H00114	H	600UL	340929
3354	38	88	4.29	178	DNG	P 1	02H	+21.48	TECTEH			H2949	seco	22H00113	H	600UL	331931
3355	40	88	4.22	179	DNG	P 1	VM	+10.01	TECTEH			A6997	seco	22H00114	H	600UL	340929
3356	46	88	0.68	89	MBM	5	03C	+28.71	TECTEH			C3340	reso	22H00113	H	600UL	331931
3357	60	88	10.64	186	DNG	P 1	05H	+7.12	TECTEH			H2949	seco	22H00110	H	600UL	340929
3358	66	88	0.85	94	MBM	5	04C	+29.96	TECTEH			M7006	reso	22H00110	H	600UL	340929
3359			0.79	65	MBM	6	02C	+23.30	TECTEH			M7006	reso	22H00110	H	600UL	340929
3360			0.63	74	MBM	5	02C	+25.48	TECTEH			M7006	reso	22H00110	H	600UL	340929
3361	68	88	5.95	181	DNG	P 1	07H	+6.73	TECTEH			H2949	seco	22H00110	H	600UL	340929
3362			8.63	182	DNG	P 1	07C	+11.39	TECTEH			H2949	seco	22H00110	H	600UL	340929
3363	70	88			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
3364			0.30	113	MAI	2	TSH	+1.81	TSHTSH	0.5		L2157	reso	22H00170	H	600PP	345290
3365			0.19	68	MAI	1	TSH	+1.81	TSHTSH	0.5		L2157	reso	22H00170	H	600PP	345290
3366			0.31	140	PID	4	TSH	+1.81	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
3367			0.10	128	SAI	2	TSH	+2.08	TSHTSH	0.3		L2157	reso	22H00170	H	600PP	345290
3368			0.14	47	SAI	1	TSH	+2.08	TSHTSH	0.3		L2157	reso	22H00170	H	600PP	345290
3369	80	88			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3370			0.15	124	PID	4	TSH	+1.05	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
3371			0.15	111	MAI	1	TSH	+1.05	TSHTSH	0.5		L2157	reso	22H00170	H	600PP	345290
3372			0.11	67	MAI	2	TSH	+1.05	TSHTSH	0.5		L2157	reso	22H00170	H	600PP	345290
3373	92	88	1.99	84	MBM	6	TSH	+33.86	TECTEH			N5432	reso	22H00003	H	600UL	331939
3374					INF		05H	+6.99	TECTEH	HR		N5432	reso	22H00003	H	600UL	331939
3375					INF		05H	+14.53	TECTEH	HR		N5432	reso	22H00003	H	600UL	331939
			0.58	54	MBM	6	05H	+22.66	TECTEH			N5432	reso	22H00003	H	600UL	331939
3377	100	88	4.63	177	DNG	P 1	02C	+5.65	TECTEH			A9574	seco	22H00003	H	600UL	331939
3378	102	88	11.03	182	DNT	P 1	09H	-0.25	TECTEH			M9715	seco	22H00004	H	600UL	331888
3379	112	88			INF		09C	+16.15	TECTEH	HR		N5432	reso	22H00003	H	600UL	331939
3380			4.06	182	DNG	P 1	09C	+18.08	TECTEH			A9574	seco	22H00003	H	600UL	331939

3381	120	88	2.15	180	DNG	P 1	VH	+29.65	TECTEH				A9574	seco	22H00003	H	600UL	331939

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 70

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3382	122	88	2.31	182	DNG	P 1	10H	+3.85	TECTEH			M9715	seco	22H00004	H	600UL	331888
3383			0.58	85	MBM	5	DH	+24.09	TECTEH			C5542	reso	22H00004	H	600UL	331888
3384			0.57	68	MBM	5	VC	+18.34	TECTEH			C5542	reso	22H00004	H	600UL	331888
3385			0.52	74	MBM	5	VC	+22.57	TECTEH			C5542	reso	22H00004	H	600UL	331888
3386			0.97	91	MBM	5	09C	+2.34	TECTEH			C5542	reso	22H00004	H	600UL	331888
3387			1.12	91	MBM	5	09C	+6.53	TECTEH			C5542	reso	22H00004	H	600UL	331888
3388			0.62	77	MBM	5	07C	+10.62	TECTEH			C5542	reso	22H00004	H	600UL	331888
3389			1.07	83	MBM	5	07C	+16.65	TECTEH			C5542	reso	22H00004	H	600UL	331888
3390			0.76	91	MBM	5	06C	+10.47	TECTEH			C5542	reso	22H00004	H	600UL	331888
3391			0.81	92	MBM	5	03C	+15.02	TECTEH			C5542	reso	22H00004	H	600UL	331888
3392			0.81	89	MBM	5	02C	+36.91	TECTEH			C5542	reso	22H00004	H	600UL	331888
3393	124	88	2.33	183	DNG	P 1	TSH	+30.39	TECTEH			A9574	seco	22H00003	H	600UL	331939
3394	134	88	3.44	181	DNG	P 1	07H	+7.23	TECTEH			A6997	seco	22H00093	H	600UL	340929
3395			4.02	181	DNG	P 1	08H	+10.06	TECTEH			A6997	seco	22H00093	H	600UL	340929
3396			9.16	181	DNT	P 1	09H	+0.27	TECTEH			A6997	seco	22H00093	H	600UL	340929
3397			2.41	185	DNG	P 1	09H	+18.14	TECTEH			F3453	reso	22H00093	H	600UL	340929
3398			3.56	181	DNG	P 1	09H	+18.65	TECTEH			A6997	seco	22H00093	H	600UL	340929
			2.91	176	DNT	P 1	10H	-0.46	TECTEH			A6997	seco	22H00093	H	600UL	340929
			2.98	187	DNT	P 1	10H	+0.42	TECTEH			A6997	seco	22H00093	H	600UL	340929
3401			0.46	80	MBM	5	VH	+25.07	TECTEH			F3453	reso	22H00093	H	600UL	340929
3402	136	88	3.16	178	DNG	P 1	05H	+12.34	TECTEH			A6997	seco	22H00093	H	600UL	340929
3403			4.50	180	DNT	P 1	10H	-0.40	TECTEH			A6997	seco	22H00093	H	600UL	340929
3404			13.46	182	DNT	P 1	10H	+0.48	TECTEH			A6997	seco	22H00093	H	600UL	340929
3405	138	88	21.16	179	DNT	P 1	10H	-0.57	TECTEH			A6997	seco	22H00093	H	600UL	340929
3406			28.73	179	DNT	P 1	10H	+0.53	TECTEH			A6997	seco	22H00093	H	600UL	340929
3407			0.70	82	MBM	5	VH	+5.42	TECTEH			F3453	reso	22H00093	H	600UL	340929
3408			0.74	100	MBM	5	VH	+6.61	TECTEH			F3453	reso	22H00093	H	600UL	340929
3409			4.32	185	DNT	P 1	10C	-0.52	TECTEH			A6997	seco	22H00093	H	600UL	340929
3410	140	88	41.83	179	DNT	P 1	10H	-0.54	TECTEH			A6997	seco	22H00093	H	600UL	340929
3411			25.51	179	DNT	P 1	10H	+0.48	TECTEH			A6997	seco	22H00093	H	600UL	340929
3412			0.62	66	DNI	P 1	10H	+0.74	TECTEH	25.51		F3453	reso	22H00093	H	600UL	340929
3413					NDF		10H	+0.74	10H10H			S8982	seco	22H00193	H	600PP	345345
3414			2.75	178	DNT	P 1	10C	-0.63	TECTEH			A6997	seco	22H00093	H	600UL	340929
3415			2.72	181	DNG	P 1	09C	+18.31	TECTEH			A6997	seco	22H00093	H	600UL	340929
3416	47	89			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
3417			0.35	71	SAI	1	TSH	+1.85	TSHTSH	0.4		L2157	reso	22H00170	H	600PP	345290
3418			0.14	74	SAI	2	TSH	+1.85	TSHTSH	0.3		L2157	reso	22H00170	H	600PP	345290
3419			0.13	114	PID	4	TSH	+1.85	TSHTSH	080		M1680	reso	22H00207	H	600PP	345329
3420	79	89			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3421			0.16	98	PID	4	TSH	+1.22	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
3422			0.14	106	MAI	2	TSH	+1.22	TSHTSH	0.4		L2157	reso	22H00170	H	600PP	345290
3423			0.20	108	MAI	1	TSH	+1.22	TSHTSH	0.4		L2157	reso	22H00170	H	600PP	345290
3424	105	89	3.39	179	DNG	P 1	TSC	+26.98	TECTEH			A9574	seco	22H00003	H	600UL	331939
	107	89	2.14	180	DNG	P 1	01H	+8.15	TECTEH			M9715	seco	22H00004	H	600UL	331888
3426			0.81	96	MBM	5	05H	+6.39	TECTEH			C5542	reso	22H00004	H	600UL	331888
3427	109	89	0.48	73	MBM	5	VH	+19.09	TECTEH			N5432	reso	22H00003	H	600UL	331939
3428	111	89	0.74	90	MBM	5	08H	+11.09	TECTEH			C5542	reso	22H00004	H	600UL	331888
3429			2.54		INF		DH	+19.10	TECTEH	HR		D3858	reso	22H00004	H	600UL	331888

3430			2.54	174	DNT	P	1	VH	-1.81	TECTEH				M9715	seco	22H00004	H	600UL	331888

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 71

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3431			3.14	180	DNT	P	1	VH	+1.96	TECTEH			M9715	seco	22H00004	H	600UL	331888
3432			2.19	177	DNG	P	1	VH	+3.14	TECTEH			M9715	seco	22H00004	H	600UL	331888
3433			5.74	177	DNG	P	1	VH	+7.82	TECTEH			M9715	seco	22H00004	H	600UL	331888
3434	113	89	0.88	76	MBM	5		08H	+15.44	TECTEH			N5432	reso	22H00003	H	600UL	331939
3435	117	89	21.09	182	DNT	P	1	10H	-0.02	TECTEH			A9574	seco	22H00003	H	600UL	331939
3436	121	89	3.64	179	DNG	P	1	VH	+5.52	TECTEH			A9574	seco	22H00003	H	600UL	331939
3437			4.30	214	NRC	2		TSC	+0.07	TECTEH			M1029	prim	22H00003	H	600UL	331939
3438	123	89	12.84	181	DNT	P	1	10H	-0.02	TECTEH			M9715	seco	22H00004	H	600UL	331888
3439	131	89	5.57	179	DNG	P	1	05C	+5.98	TECTEH			M9715	seco	22H00004	H	600UL	331888
3440	135	89	3.53	181	DNG	P	1	08H	+15.42	TECTEH			A6997	seco	22H00093	H	600UL	340929
3441			2.74	181	DNG	P	1	09H	+3.65	TECTEH			A6997	seco	22H00093	H	600UL	340929
3442			7.36	181	DNG	P	1	09H	+14.13	TECTEH			A6997	seco	22H00093	H	600UL	340929
3443			3.71	181	DNG	P	1	09H	+16.29	TECTEH			A6997	seco	22H00093	H	600UL	340929
3444			4.53	185	DNT	P	1	10H	-0.49	TECTEH			A6997	seco	22H00093	H	600UL	340929
3445			6.19	186	DNT	P	1	10H	+0.44	TECTEH			A6997	seco	22H00093	H	600UL	340929
3446	137	89	0.33	181	DNT	P	1	10H	-0.30	TECTEH			A6997	seco	22H00093	H	600UL	340929
3447			26.43	181	DNT	P	1	10H	+0.51	TECTEH			A6997	seco	22H00093	H	600UL	340929
			2.86	186	DNT	P	1	10C	-0.48	TECTEH			A6997	seco	22H00093	H	600UL	340929
	139	89	30.69	181	DNT	P	1	10H	-0.56	TECTEH			A6997	seco	22H00093	H	600UL	340929
3450			24.24	181	DNT	P	1	10H	+0.48	TECTEH			A6997	seco	22H00093	H	600UL	340929
3451			4.48	186	DNT	P	1	10C	-0.48	TECTEH			F3453	reso	22H00093	H	600UL	340929
3452			3.66	178	DNT	P	1	10C	+0.40	TECTEH			A6997	seco	22H00093	H	600UL	340929
3453	38	90	0.39	96	19	P	2	DC	+1.67	TECTEH	LOCOK		S4373	reso	22H00114	H	600UL	340929
3454			0.46	80	MBM	5		TSC	+23.47	TECTEH			F3453	reso	22H00114	H	600UL	340929
3455	52	90	4.44	180	DNT	P	1	06H	-0.24	TECTEH			A6997	seco	22H00114	H	600UL	340929
3456	60	90	4.37	178	DNG	P	1	03C	+10.79	TECTEH			H2949	seco	22H00113	H	600UL	331931
3457	66	90	4.36	179	DNT	P	1	06H	+0.56	TECTEH			A6997	seco	22H00114	H	600UL	340929
3458			4.74	179	DNG	P	1	07H	+11.26	TECTEH			A6997	seco	22H00114	H	600UL	340929
3459			3.19	183	DNG	P	1	07C	+24.97	TECTEH			A6997	seco	22H00114	H	600UL	340929
3460	70	90			TBP					TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
3461			0.20	105	PID	4		TSH	+2.22	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
3462			0.23	102	SAI	2		TSH	+2.22	TSHTSH	0.2		L2157	reso	22H00170	H	600PP	345290
3463			0.09	48	SAI	1		TSH	+2.22	TSHTSH	0.3		L2157	reso	22H00170	H	600PP	345290
3464			11.65	177	DNG	P	1	07H	+13.49	TECTEH			A6997	seco	22H00114	H	600UL	340929
3465	72	90	0.81	62	MBM	6		03H	+19.11	TECTEH			C3340	reso	22H00113	H	600UL	331931
3466	74	90	3.81	178	DNG	P	1	TSC	+6.40	TECTEH			H2949	seco	22H00048	H	600UL	340948
3467	76	90			TBS					TECTEH			D3858	reso	22H00044	H	600UL	331892
3468			0.11	119	SAI	2		TSH	+1.23	TSHTSH	0.2		A9608	reso	22H00171	H	600PP	345329
3469			0.00	144	SAI	1		TSH	+1.23	TSHTSH	0.0		A9608	reso	22H00171	H	600PP	345329
3470			0.15	92	PID	4		TSH	+1.23	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
3471	78	90			TBS					TECTEH			D3858	reso	22H00044	H	600UL	331892
3472			0.20	83	MAI	1		TSH	+1.25	TSHTSH	0.6		L2157	reso	22H00170	H	600PP	345290
3473			0.19	114	MAI	2		TSH	+1.25	TSHTSH	0.7		L2157	reso	22H00170	H	600PP	345290
			0.20	123	PID	4		TSH	+1.25	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
3475			0.12	31	SAI	1		TSH	+1.92	TSHTSH	0.2		L2157	reso	22H00170	H	600PP	345290
3476			0.13	71	SAI	2		TSH	+1.92	TSHTSH	0.3		L2157	reso	22H00170	H	600PP	345290
3477	94	90			TBS					TECTEH			D3858	reso	22H00044	H	600UL	331892
3478			0.10	85	PID	4		TSH	+3.16	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330

3479			0.13	88	SAI	2	TSH	+3.16	TSHTSH	0.2			F6623	reso	22H00172	H	600PP	345353

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 72

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3480			0.00	0	SAI	1	TSH	+3.16	TSHTSH	0.0		F6623	reso	22H00172	H	600PP	345353
3481	98	90	3.43	183	DNT	P 1	06H	+0.51	TECTEH			A9574	seco	22H00006	H	600UL	331891
3482			76.78	182	DNT	P 1	09H	-0.04	TECTEH			A9574	seco	22H00006	H	600UL	331891
3483					NDF		09H	-0.04	09H09H			M7007	prim	22H00203	H	600PP	345330
3484			2.99	182	DNG	P 1	VH	+26.99	TECTEH			L2157	reso	22H00006	H	600UL	331891
3485	102	90	5.54	182	DNG	P 1	07H	+9.33	TECTEH			A9574	seco	22H00006	H	600UL	331891
3486	118	90	13.52	182	DNT	P 1	10H	+0.02	TECTEH			A9574	seco	22H00006	H	600UL	331891
3487					NDF		10H	+0.02	10H10H			M7007	prim	22H00203	H	600PP	345330
3488			4.46	180	DNT	P 1	DC	+0.95	TECTEH			A9574	seco	22H00006	H	600UL	331891
3489	122	90	2.30	178	DNG	P 1	DC	+10.78	TECTEH			A9574	seco	22H00006	H	600UL	331891
3490	124	90	2.54	178	DNG	P 1	06H	+6.11	TECTEH			M2655	seco	22H00005	H	600UL	340906
3491	126	90	0.81	83	MBM	5	04C	+31.08	TECTEH			L2157	reso	22H00030	H	600UL	331892
3492	128	90	0.52	61	MBM	5	09H	+8.12	TECTEH			C5542	reso	22H00005	H	600UL	340906
3493	134	90	2.51	180	DNG	P 1	08H	+1.58	TECTEH			A6997	seco	22H00093	H	600UL	340929
3494			7.60	180	DNG	P 1	08H	+17.72	TECTEH			A6997	seco	22H00093	H	600UL	340929
3495			2.44	180	DNG	P 1	08H	+19.92	TECTEH			A6997	seco	22H00093	H	600UL	340929
3496			1.86	181	INR	P 1	09H	-0.70	TECTEH			F3453	reso	22H00093	H	600UL	340929
			2.97	179	DNT	P 1	09H	+0.27	TECTEH			A6997	seco	22H00093	H	600UL	340929
[illegible]			5.78	181	DNT	P 1	09H	+1.03	TECTEH			A6997	seco	22H00093	H	600UL	340929
3499			3.11	182	DNG	P 1	09H	+3.30	TECTEH			A6997	seco	22H00093	H	600UL	340929
3500			2.77	178	DNG	P 1	09H	+6.05	TECTEH			A6997	seco	22H00093	H	600UL	340929
3501			2.79	180	DNG	P 1	09H	+7.64	TECTEH			A6997	seco	22H00093	H	600UL	340929
3502			4.82	181	DNG	P 1	09H	+9.46	TECTEH			A6997	seco	22H00093	H	600UL	340929
3503			3.00	180	DNG	P 1	09H	+10.63	TECTEH			A6997	seco	22H00093	H	600UL	340929
3504			9.30	185	DNG	P 1	09H	+12.59	TECTEH			A6997	seco	22H00093	H	600UL	340929
3505			36.10	180	DNT	P 1	09H	+13.49	TECTEH			A6997	seco	22H00093	H	600UL	340929
3506			5.06	181	DNG	P 1	09H	+13.98	TECTEH			A6997	seco	22H00093	H	600UL	340929
3507			3.77	180	DNG	P 1	09H	+14.32	TECTEH			A6997	seco	22H00093	H	600UL	340929
3508			14.51	180	DNG	P 1	09H	+14.75	TECTEH			A6997	seco	22H00093	H	600UL	340929
3509			2.70	181	DNG	P 1	09H	+15.44	TECTEH			A6997	seco	22H00093	H	600UL	340929
3510			18.48	180	DNG	P 1	09H	+16.27	TECTEH			A6997	seco	22H00093	H	600UL	340929
3511			5.80	181	DNG	P 1	09H	+16.72	TECTEH			A6997	seco	22H00093	H	600UL	340929
3512			3.36	184	DNG	P 1	09H	+17.24	TECTEH			A6997	seco	22H00093	H	600UL	340929
3513			23.49	178	DNG	P 1	09H	+17.73	TECTEH			A6997	seco	22H00093	H	600UL	340929
3514			7.58	178	DNG	P 1	09H	+18.36	TECTEH			A6997	seco	22H00093	H	600UL	340929
3515			1.38	181	INR	P 1	09H	+19.30	TECTEH			F3453	reso	22H00093	H	600UL	340929
3516			3.11	179	DNT	P 1	10H	-0.36	TECTEH			A6997	seco	22H00093	H	600UL	340929
3517			6.46	179	DNT	P 1	10H	+0.68	TECTEH			A6997	seco	22H00093	H	600UL	340929
3518			8.14	182	DNG	P 1	VC	+13.64	TECTEH			A6997	seco	22H00093	H	600UL	340929
3519			3.39	183	DNG	P 1	VC	+17.13	TECTEH			A6997	seco	22H00093	H	600UL	340929
3520			12.06	183	DNG	P 1	VC	+22.48	TECTEH			A6997	seco	22H00093	H	600UL	340929
3521			5.39	185	DNT	P 1	10C	+0.52	TECTEH			A6997	seco	22H00093	H	600UL	340929
[illegible]			4.05	183	DNG	P 1	09C	+14.85	TECTEH			A6997	seco	22H00093	H	600UL	340929
			3.89	184	DNG	P 1	09C	+17.38	TECTEH			A6997	seco	22H00093	H	600UL	340929
3524	140	90	25.37	181	DNT	P 1	10H	-0.56	TECTEH			A6997	seco	22H00093	H	600UL	340929
3525			32.65	179	DNT	P 1	10H	+0.48	TECTEH			A6997	seco	22H00093	H	600UL	340929
3526			5.69	186	DNT	P 1	10C	-0.57	TECTEH			A6997	seco	22H00093	H	600UL	340929
3527			6.11	181	DNT	P 1	10C	+0.36	TECTEH			A6997	seco	22H00093	H	600UL	340929

3528	37	91	2.67	176	DNG	P 1	TSC	+24.00	TECTEH				A6997	seco	22H00114	H	600UL	340929

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 73

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3529	47	91			TBP			TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
3530			0.12	84	SAI	2	TSH +1.84	TSHTSH	0.2		A9608	reso	22H00171	H	600PP	345329
3531			0.13	125	SAI	1	TSH +1.84	TSHTSH	0.2		A9608	reso	22H00171	H	600PP	345329
3532			0.13	132	SAI	1	TSH +2.03	TSHTSH	0.2		A9608	reso	22H00171	H	600PP	345329
3533			0.10	115	SAI	2	TSH +2.03	TSHTSH	0.2		A9608	reso	22H00171	H	600PP	345329
3534			0.46	91	NQI	P 1	TSH +2.54	TECTEH			H2949	seco	22H00113	H	600UL	331931
3535			0.23	101	PID	4	TSH +2.57	TSHTSH	080		M1680	reso	22H00207	H	600PP	345329
3536			0.22	109	SAI	2	TSH +2.57	TSHTSH	0.3		M7006	reso	22H00171	H	600PP	345329
3537			0.19	117	SAI	1	TSH +2.57	TSHTSH	0.2		M7006	reso	22H00171	H	600PP	345329
3538	69	91			TBP			TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
3539			0.13	96	PID	4	TSH +2.08	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
3540			0.14	117	SAI	2	TSH +2.08	TSHTSH	0.3		L2157	reso	22H00170	H	600PP	345290
3541			0.14	62	SAI	1	TSH +2.08	TSHTSH	0.2		L2157	reso	22H00170	H	600PP	345290
3542	73	91	2.26	181	DNG	P 1	TSH +23.09	TECTEH			H2949	seco	22H00048	H	600UL	340948
3543	77	91	2.72	180	DNG	P 1	VM +2.83	TECTEH			D3858	reso	22H00045	H	600UL	340830
3544	81	91	7.12	180	DNG	P 1	TSC +20.13	TECTEH			H2949	seco	22H00048	H	600UL	340948
3545	105	91	4.75	182	DNG	P 1	TSC +30.16	TECTEH			A9574	seco	22H00006	H	600UL	331891
	111	91	0.67	83	MBM	6	06C +14.15	TECTEH			L2157	reso	22H00030	H	600UL	331892
	121	91	0.88	88	MBM	5	04H +26.50	TECTEH			L2157	reso	22H00030	H	600UL	331892
3548			0.71	89	MBM	5	04H +31.53	TECTEH			L2157	reso	22H00030	H	600UL	331892
3549			2.58	186	DNG	P 1	08H +19.46	TECTEH			K2032	seco	22H00030	H	600UL	331892
3550			4.00	216	NRC	2	TSC +0.00	TECTEH			A9608	reso	22H00030	H	600UL	331892
3551	127	91	3.90	183	DNT	P 1	10H +0.55	TECTEH			K2032	seco	22H00030	H	600UL	331892
3552	129	91	2.89	179	DNG	P 1	02C +2.50	TECTEH			A9574	seco	22H00006	H	600UL	331891
3553	131	91	8.79	183	DNG	P 1	07H +2.56	TECTEH			K2032	seco	22H00030	H	600UL	331892
3554			2.37	182	DNG	P 1	07H +5.09	TECTEH			K2032	seco	22H00030	H	600UL	331892
3555			5.45	181	DNG	P 1	09H +3.91	TECTEH			K2032	seco	22H00030	H	600UL	331892
3556			3.13	184	DNG	P 1	09H +4.30	TECTEH			K2032	seco	22H00030	H	600UL	331892
3557			18.15	183	DNG	P 1	09H +4.93	TECTEH			K2032	seco	22H00030	H	600UL	331892
3558			8.33	182	DNG	P 1	09H +6.72	TECTEH			K2032	seco	22H00030	H	600UL	331892
3559			4.52	182	DNG	P 1	09H +10.02	TECTEH			K2032	seco	22H00030	H	600UL	331892
3560			4.63	182	DNG	P 1	09C +7.93	TECTEH			K2032	seco	22H00030	H	600UL	331892
3561	135	91	2.60	191	DNT	P 1	10H +0.26	TECTEH			A6997	seco	22H00093	H	600UL	340929
3562	137	91	7.72	185	DNT	P 1	10H +0.42	TECTEH			A6997	seco	22H00093	H	600UL	340929
3563			2.13	4	INR	P 1	04C +11.93	TECTEH			F3453	reso	22H00093	H	600UL	340929
3564			3.47	179	DNG	P 1	04C +12.06	TECTEH			A6997	seco	22H00093	H	600UL	340929
3565	139	91	1.18	93	MBM	5	04H +6.19	TECTEH			F3453	reso	22H00093	H	600UL	340929
3566			18.10	181	DNT	P 1	10H -0.46	TECTEH			A6997	seco	22H00093	H	600UL	340929
3567			31.83	180	DNT	P 1	10H +0.48	TECTEH			A6997	seco	22H00093	H	600UL	340929
3568			3.71	187	DNT	P 1	10C -0.59	TECTEH			A6997	seco	22H00093	H	600UL	340929
3569	46	92	2.38	175	DNG	P 1	TSH +9.72	TECTEH			A6997	seco	22H00114	H	600UL	340929
3570	52	92			TBP			TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
			0.11	39	SAI	1	TSH +2.51	TSHTSH	0.2		A9608	reso	22H00171	H	600PP	345329
			0.16	94	PID	4	TSH +2.51	TSHTSH	080		M1680	reso	22H00207	H	600PP	345329
3573			0.16	101	SAI	2	TSH +2.51	TSHTSH	0.2		A9608	reso	22H00171	H	600PP	345329
3574	58	92	2.57	185	DNG	P 1	VM +16.32	TECTEH			A6997	seco	22H00114	H	600UL	340929
3575			4.82	182	DNG	P 1	VM +19.01	TECTEH			A6997	seco	22H00114	H	600UL	340929
3576	66	92	4.98	183	DNG	P 1	07H +2.77	TECTEH			H2949	seco	22H00113	H	600UL	331931

3577			9.39	182	DNG	P 1	07H	+6.44	TECTEH			H2949	seco	22H00113	H	600UL	331931

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 74

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3578	68	92	2.16	176	DNG	P 1	03H	+12.13	TECTEH			A6997	seco	22H00114	H	600UL	340929
3579	74	92	2.61	181	DNG	P 1	TSC	+15.22	TECTEH			D3858	reso	22H00045	H	600UL	340830
3580	114	92	2.98	187	INR	P 1	09H	+21.04	TECTEH			M2655	seco	22H00005	H	600UL	340906
3581	120	92	0.51	90	MBM	5	VM	+23.66	TECTEH			L2157	reso	22H00034	H	600UL	331892
3582					INF		VM	+24.90	TECTEH	HR		L2157	reso	22H00034	H	600UL	331892
3583			4.47	182	DNG	P 1	09C	+5.05	TECTEH			N5877	seco	22H00034	H	600UL	331892
3584	122	92	1.57	84	MBM	6	04H	+14.53	TECTEH			C5542	reso	22H00005	H	600UL	340906
3585			0.86	65	MBM	6	04H	+18.76	TECTEH			C5542	reso	22H00005	H	600UL	340906
3586			2.39	180	DNG	P 1	09C	+5.07	TECTEH			M2655	seco	22H00005	H	600UL	340906
3587			5.18	183	DNG	P 1	09C	+10.20	TECTEH			M2655	seco	22H00005	H	600UL	340906
3588	136	92	3.76	186	DNT	P 1	10H	+0.35	TECTEH			F3453	reso	22H00093	H	600UL	340929
3589			4.02	183	DNG	P 1	05C	+4.56	TECTEH			A6997	seco	22H00093	H	600UL	340929
3590	138	92	2.32	173	DNT	P 1	10H	-0.39	TECTEH			A6997	seco	22H00093	H	600UL	340929
3591			5.26	182	DNT	P 1	10H	+0.46	TECTEH			A6997	seco	22H00093	H	600UL	340929
3592	140	92	0.36	75	PLP	9	TSH	+0.29	TSHTSH			S8982	seco	22H00193	H	600PP	345345
3593			2.26	170	DNT	P 1	09H	+0.58	TECTEH			A6997	seco	22H00093	H	600UL	340929
3594			8.04	179	DNT	P 1	10H	-0.60	TECTEH			A6997	seco	22H00093	H	600UL	340929
			25.15	181	DNT	P 1	10H	+0.46	TECTEH			A6997	seco	22H00093	H	600UL	340929
			4.07	184	DNT	P 1	10C	-0.60	TECTEH			A6997	seco	22H00093	H	600UL	340929
3597			2.67	184	DNG	P 1	05C	+34.58	TECTEH			A6997	seco	22H00093	H	600UL	340929
3598			4.03	184	DNG	P 1	05C	+35.57	TECTEH			A6997	seco	22H00093	H	600UL	340929
3599			3.49	184	DNG	P 1	05C	+36.84	TECTEH			A6997	seco	22H00093	H	600UL	340929
3600	49	93	6.66	179	DNG	P 1	DH	+11.25	TECTEH			H2949	seco	22H00113	H	600UL	331931
3601	53	93	2.29	185	DNG	P 1	05C	+33.88	TECTEH			H2949	seco	22H00113	H	600UL	331931
3602	67	93	0.96	73	MBM	5	03H	+27.23	TECTEH			F3453	reso	22H00114	H	600UL	340929
3603	71	93	11.82	181	DNG	P 1	06H	+18.67	TECTEH			H2949	seco	22H00113	H	600UL	331931
3604			11.81	180	DNG	P 1	07H	+4.24	TECTEH			H2949	seco	22H00113	H	600UL	331931
3605			4.62	181	DNG	P 1	07H	+12.51	TECTEH			H2949	seco	22H00113	H	600UL	331931
3606			10.70	178	DNG	P 1	07C	+10.69	TECTEH			H2949	seco	22H00113	H	600UL	331931
3607	75	93	0.19	113	INR	P 1	TSH	+5.58	TECTEH			D3858	reso	22H00045	H	600UL	340830
3608	79	93			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3609			0.55	75	NQI	P 1	TSH	+1.13	TECTEH			H2949	seco	22H00048	H	600UL	340948
3610			0.33	42	MAI	1	TSH	+1.27	TSHTSH	0.5		M7006	reso	22H00171	H	600PP	345329
3611			0.17	100	MAI	2	TSH	+1.27	TSHTSH	0.3		A9608	reso	22H00171	H	600PP	345329
3612			0.18	101	PID	4	TSH	+1.27	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
3613			0.15	86	MAI	1	TSH	+1.47	TSHTSH	0.3		A9608	reso	22H00171	H	600PP	345329
3614			0.25	102	MAI	2	TSH	+1.47	TSHTSH	0.3		A9608	reso	22H00171	H	600PP	345329
3615	89	93			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3616			0.13	107	SAI	2	TSH	+0.27	TSHTSH	0.3		L2157	reso	22H00170	H	600PP	345290
3617			0.16	75	PID	4	TSH	+0.27	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
3618			0.20	79	SAI	1	TSH	+0.27	TSHTSH	0.3		L2157	reso	22H00170	H	600PP	345290
3619	93	93	3.38	188	DNG	P 1	04H	+14.01	TECTEH			A9574	seco	22H00006	H	600UL	331891
3620			1.02	146	NQI	P 1	TSC	+0.98	TECTEH			A9608	reso	22H00006	H	600UL	331891
					NDF		TSC	+0.98	TSCTSC			S4373	reso	22C00025	C	600PP	345294
3622	97	93	2.32	181	DNG	P 1	07H	+24.04	TECTEH			A9574	seco	22H00006	H	600UL	331891
3623			4.35	183	DNG	P 1	09C	+1.80	TECTEH			D3858	reso	22H00006	H	600UL	331891
3624			4.39	184	DNG	P 1	09C	+2.27	TECTEH			D3858	reso	22H00006	H	600UL	331891
3625			2.08	181	DNG	P 1	08C	+12.07	TECTEH			A9574	seco	22H00006	H	600UL	331891

3626			6.74	183	DNG	P 1	08C	+13.04	TECTEH			A9574	seco	22H00006	H	600UL	331891

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 75

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3627			3.30	181	DNG	P 1	08C	+14.35	TECTEH			A9574	seco	22H00006	H	600UL	331891
3628			10.36	182	DNG	P 1	08C	+15.36	TECTEH			A9574	seco	22H00006	H	600UL	331891
3629			3.27	181	DNG	P 1	08C	+18.23	TECTEH			A9574	seco	22H00006	H	600UL	331891
3630			2.81	182	DNG	P 1	07C	+10.99	TECTEH			A9574	seco	22H00006	H	600UL	331891
3631			2.49	182	DNG	P 1	07C	+16.23	TECTEH			A9574	seco	22H00006	H	600UL	331891
3632			18.91	182	DNG	P 1	01C	+29.98	TECTEH			A9574	seco	22H00006	H	600UL	331891
3633	101	93	12.97	186	DNT	P 1	09H	-0.02	TECTEH			A9574	seco	22H00006	H	600UL	331891
3634			4.62	183	DNG	P 1	08C	+16.52	TECTEH			A9574	seco	22H00006	H	600UL	331891
3635	103	93	2.68	182	DNG	P 1	08C	+10.01	TECTEH			M2655	seco	22H00005	H	600UL	340906
3636			2.50	183	DNT	P 1	05C	-0.81	TECTEH	LOCOK		S4373	reso	22H00005	H	600UL	340906
3637			1.09	5	INR	P 1	04C	+38.15	TECTEH	LOCOK		S4373	reso	22H00005	H	600UL	340906
3638	107	93	2.40	180	DNG	P 1	TSH	+28.89	TECTEH			M2655	seco	22H00005	H	600UL	340906
3639	109	93	6.84	183	DNG	P 1	09C	+15.33	TECTEH			A9574	seco	22H00006	H	600UL	331891
3640	111	93	5.95	178	DNG	P 1	VH	+3.29	TECTEH			D3858	reso	22H00005	H	600UL	340906
3641			3.04	178	DNG	P 1	VH	+4.39	TECTEH			M2655	seco	22H00005	H	600UL	340906
3642	117	93	4.24	180	DNT	P 1	10C	+0.55	TECTEH			N5877	seco	22H00034	H	600UL	331892
3643	119	93	7.68	183	DNT	P 1	10H	-0.08	TECTEH			M2655	seco	22H00005	H	600UL	340906
			4.05	183	DNG	P 1	VH	+2.97	TECTEH			C5542	reso	22H00005	H	600UL	340906
	121	93	2.75		NRC	2	TSC	+0.00	TECTEH			N5877	seco	22H00034	H	600UL	331892
3646	125	93	5.12	184	DNG	P 1	10C	+1.56	TECTEH			D3858	reso	22H00006	H	600UL	331891
3647	129	93	4.92	182	DNG	P 1	09H	+4.61	TECTEH			A9574	seco	22H00006	H	600UL	331891
3648	131	93	2.14	183	DNT	P 1	VH	-2.09	TECTEH			M2655	seco	22H00005	H	600UL	340906
3649	133	93	2.25	181	DNG	P 1	09H	+9.89	TECTEH			A6997	seco	22H00093	H	600UL	340929
3650	135	93	1.89	193	INR	P 1	09H	+0.49	TECTEH			A6997	seco	22H00093	H	600UL	340929
3651	137	93	3.33	190	DNT	P 1	10H	+0.46	TECTEH			A6997	seco	22H00093	H	600UL	340929
3652	139	93	0.39	78	PLP	9	TSH	+0.37	TSHTSH			S8982	seco	22H00193	H	600PP	345345
3653			3.26	182	DNG	P 1	08H	+18.71	TECTEH			A6997	seco	22H00093	H	600UL	340929
3654			3.26	182	DNG	P 1	08H	+18.77	TECTEH			A6997	seco	22H00093	H	600UL	340929
3655			5.66	180	DNT	P 1	09H	-0.67	TECTEH			A6997	seco	22H00093	H	600UL	340929
3656			6.77	181	DNT	P 1	09H	+0.58	TECTEH			A6997	seco	22H00093	H	600UL	340929
3657			6.74	181	DNT	P 1	09H	+1.64	TECTEH			F3453	reso	22H00093	H	600UL	340929
3658			4.24	181	DNG	P 1	09H	+4.17	TECTEH			A6997	seco	22H00093	H	600UL	340929
3659			13.93	181	DNG	P 1	09H	+5.30	TECTEH			A6997	seco	22H00093	H	600UL	340929
3660			4.24	186	DNG	P 1	09H	+5.76	TECTEH			A6997	seco	22H00093	H	600UL	340929
3661			4.70	184	DNG	P 1	09H	+9.75	TECTEH			A6997	seco	22H00093	H	600UL	340929
3662			8.64	184	DNG	P 1	09H	+10.67	TECTEH			A6997	seco	22H00093	H	600UL	340929
3663			2.23	182	DNG	P 1	09H	+11.92	TECTEH			A6997	seco	22H00093	H	600UL	340929
3664			2.24	186	DNG	P 1	09H	+12.66	TECTEH			A6997	seco	22H00093	H	600UL	340929
3665			6.46	181	DNT	P 1	10H	-0.41	TECTEH			A6997	seco	22H00093	H	600UL	340929
3666			9.10	181	DNT	P 1	10H	+0.88	TECTEH			A6997	seco	22H00093	H	600UL	340929
3667			4.68	179	DNG	P 1	DH	+27.22	TECTEH			A6997	seco	22H00093	H	600UL	340929
3668			3.23	184	DNG	P 1	03C	+2.10	TECTEH			A6997	seco	22H00093	H	600UL	340929
3669	36	94	0.70	63	MBM	5	01H	+21.98	TECTEH			N5432	reso	22H00125	H	600UL	340929
	38	94	0.76	100	MBM	5	04H	+3.28	TECTEH			C3340	reso	22H00124	H	600UL	331931
3671	46	94	1.06	100	MBM	6	06C	+17.16	TECTEH			C3340	reso	22H00124	H	600UL	331931
3672			0.67	89	MBM	5	06C	+18.87	TECTEH			C3340	reso	22H00124	H	600UL	331931
3673	50	94	3.51	183	DNT	P 1	06H	-0.37	TECTEH			A6997	seco	22H00114	H	600UL	340929
3674	64	94	0.63	87	MBM	5	TSH	+30.91	TECTEH			C3340	reso	22H00113	H	600UL	331931

3675	68	94			TBP			TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL		331892

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 76

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3676		0.11	93	SAI	2	TSH	+1.56	TSHTSH	0.2		M7006	reso	22H00171	H	600PP	345329
3677		0.00	0	SAI	1	TSH	+1.56	TSHTSH	0.0		M7006	reso	22H00171	H	600PP	345329
3678		0.14	113	PID	4	TSH	+1.56	TSHTSH	080		M1680	reso	22H00207	H	600PP	345329
3679	70	4.53	179	DNG	P 1	07H	+9.31	TECTEH			H2949	seco	22H00048	H	600UL	340948
3680	72	2.35	180	DNG	P 1	03H	+15.50	TECTEH			T7451	seco	22H00045	H	600UL	340830
3681		1.25	91	MBM	5	TSC	+5.64	TECTEH			D3858	reso	22H00045	H	600UL	340830
3682	92	2.67	188	DNT	P 1	09H	-0.02	TECTEH			A9574	seco	22H00006	H	600UL	331891
3683	94	5.56	183	DNG	P 1	08C	+4.27	TECTEH			M2655	seco	22H00005	H	600UL	340906
3684	108			OBS		DC	-5.01	DC TEH			L2157	reso	22H00006	H	600UL	331891
3685	118	2.45	181	DNG	P 1	08H	+17.04	TECTEH			M2655	seco	22H00005	H	600UL	340906
3686		5.28	182	DNG	P 1	08H	+18.23	TECTEH			M2655	seco	22H00005	H	600UL	340906
3687		3.40	184	DNT	P 1	10C	-0.44	TECTEH			M2655	seco	22H00005	H	600UL	340906
3688	120	0.74	81	MBM	5	05C	+29.12	TECTEH			L2157	reso	22H00034	H	600UL	331892
3689		0.45	79	MBM	5	05C	+30.57	TECTEH			L2157	reso	22H00034	H	600UL	331892
3690	122	1.93	185	INR	P 1	07H	+7.42	TECTEH			M2655	seco	22H00005	H	600UL	340906
3691		2.59	183	DNG	P 1	08H	+6.09	TECTEH			M2655	seco	22H00005	H	600UL	340906
3692		3.81	186	DNT	P 1	09H	+0.55	TECTEH			M2655	seco	22H00005	H	600UL	340906
		18.98	183	DNG	P 1	09H	+1.61	TECTEH			M2655	seco	22H00005	H	600UL	340906
		3.12	181	DNG	P 1	09H	+3.08	TECTEH			M2655	seco	22H00005	H	600UL	340906
3695		2.21	183	DNG	P 1	09H	+4.22	TECTEH			M2655	seco	22H00005	H	600UL	340906
3696		2.85	184	DNG	P 1	09H	+15.50	TECTEH			M2655	seco	22H00005	H	600UL	340906
3697		18.83	183	DNG	P 1	09H	+16.49	TECTEH			M2655	seco	22H00005	H	600UL	340906
3698		4.21	182	DNT	P 1	10H	+1.16	TECTEH	LOCOK		D3858	reso	22H00005	H	600UL	340906
3699		11.59	184	DNG	P 1	09C	+6.87	TECTEH			M2655	seco	22H00005	H	600UL	340906
3700		5.31	184	DNG	P 1	09C	+17.88	TECTEH			M2655	seco	22H00005	H	600UL	340906
3701	128	5.00	185	DNG	P 1	09H	+1.95	TECTEH			A9574	seco	22H00006	H	600UL	331891
3702		3.33	185	DNG	P 1	09H	+16.55	TECTEH			A9574	seco	22H00006	H	600UL	331891
3703	130	4.30	185	DNT	P 1	09C	+0.11	TECTEH			M2655	seco	22H00005	H	600UL	340906
3704	134	2.43	175	DNG	P 1	VH	+29.23	TECTEH			A6997	seco	22H00093	H	600UL	340929
3705	136	2.21	195	DNT	P 1	09H	+0.35	TECTEH			A6997	seco	22H00093	H	600UL	340929
3706	138	2.29	185	DNT	P 1	09H	+0.55	TECTEH			A6997	seco	22H00093	H	600UL	340929
3707		3.59	187	DNT	P 1	10H	+0.33	TECTEH			A6997	seco	22H00093	H	600UL	340929
3708		0.76	101	27	P 2	DH	+1.75	TECTEH			A6997	seco	22H00093	H	600UL	340929
3709	45	0.80	79	MBM	5	03H	+7.85	TECTEH			C3340	reso	22H00124	H	600UL	331931
3710	49	6.59	181	DNT	P 1	06H	-0.31	TECTEH			N2574	seco	22H00124	H	600UL	331931
3711				NDF		06H	-0.31	06H06H			N2574	seco	22H00207	H	600PP	345329
3712	53	0.96	63	MBM	5	05C	+37.00	TECTEH			C3340	reso	22H00124	H	600UL	331931
3713	57	2.57	183	DNT	P 1	06H	+0.30	TECTEH			N2574	seco	22H00124	H	600UL	331931
3714	61	0.50	74	MBM	5	01H	+30.88	TECTEH			C3340	reso	22H00124	H	600UL	331931
3715	63	2.20	186	INR	P 1	01C	+30.07	TECTEH			N5877	seco	22H00125	H	600UL	340929
3716	67	0.17	144	VOL	2	TSC	+2.20	TSCTSC			F3453	reso	22C00035	C	600PP	345283
3717		1.28	82	MBM	5	TSC	+2.21	TECTEH			F3453	reso	22H00114	H	600UL	340929
3718	71	2.60	188	DNG	P 1	03C	+27.70	TECTEH			H2949	seco	22H00048	H	600UL	340948
	85			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3720		0.21	58	MAI	1	TSH	+0.38	TSHTSH	0.7		L2157	reso	22H00170	H	600PP	345290
3721		0.22	104	PID	4	TSH	+0.38	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
3722		0.18	101	MAI	2	TSH	+0.38	TSHTSH	0.8		L2157	reso	22H00170	H	600PP	345290
3723	87	3.30	179	DNG	P 1	02H	+30.20	TECTEH			H2949	seco	22H00048	H	600UL	340948

3724			1.13		INF	02H	+38.47	TECTEH	HR			C3340	reso	22H00048	H	600UL	340948

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 77

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3725			2.33	179	DNT	P 1	03H	-0.49	TECTEH			H2949	seco	22H00048	H	600UL	340948
3726			2.65	176	DNG	P 1	04C	+28.99	TECTEH			H2949	seco	22H00048	H	600UL	340948
3727	89	95	0.75	72	MBM	5	01H	+14.40	TECTEH			D3858	reso	22H00045	H	600UL	340830
3728	95	95	11.09	186	DNT	P 1	09H	+0.02	TECTEH			M2655	seco	22H00005	H	600UL	340906
3729			6.82	182	DNG	P 1	07C	+23.06	TECTEH			M2655	seco	22H00005	H	600UL	340906
3730	99	95	0.46	42	MBM	5	05H	+21.13	TECTEH			C5542	reso	22H00005	H	600UL	340906
3731	103	95	1.03	77	MBM	5	TSH	+17.38	TECTEH			C5542	reso	22H00005	H	600UL	340906
3732	115	95	0.08	62	INR	P 1	09H	+11.83	TECTEH			D3858	reso	22H00005	H	600UL	340906
3733			2.69	180	DNG	P 1	DH	+19.31	TECTEH			M2655	seco	22H00005	H	600UL	340906
3734	119	95	3.84	181	DNT	P 1	09H	+0.44	TECTEH			M2655	seco	22H00005	H	600UL	340906
3735			3.70	182	DNG	P 1	10C	+1.57	TECTEH			C5542	reso	22H00005	H	600UL	340906
3736	121	95	2.65	180	DNG	P 1	08H	+18.14	TECTEH			N5877	seco	22H00034	H	600UL	331892
3737			3.36	180	DNG	P 1	09H	+2.27	TECTEH			N5877	seco	22H00034	H	600UL	331892
3738			2.65	181	DNG	P 1	09H	+4.03	TECTEH			N5877	seco	22H00034	H	600UL	331892
3739			2.50	182	DNG	P 1	09C	+8.86	TECTEH			N5877	seco	22H00034	H	600UL	331892
3740			3.00	182	DNG	P 1	08C	+9.50	TECTEH			N5877	seco	22H00034	H	600UL	331892
3741			4.16	183	DNG	P 1	08C	+20.32	TECTEH			N5877	seco	22H00034	H	600UL	331892
			4.15		NRC	2	TSC	+0.00	TECTEH			N5877	seco	22H00034	H	600UL	331892
[illegible]	127	95	5.38	186	DNT	P 1	10H	-0.04	TECTEH			M2655	seco	22H00005	H	600UL	340906
3744	129	95	0.72	86	MBM	5	05H	+19.95	TECTEH			L2157	reso	22H00034	H	600UL	331892
3745			1.23	85	MBM	5	06H	+19.70	TECTEH			L2157	reso	22H00034	H	600UL	331892
3746			3.26	179	DNG	P 1	09H	+12.62	TECTEH			L2157	reso	22H00034	H	600UL	331892
3747			8.38	181	DNG	P 1	09H	+13.63	TECTEH			N5877	seco	22H00034	H	600UL	331892
3748	131	95	4.58	183	DNT	P 1	10H	-0.02	TECTEH			M2655	seco	22H00005	H	600UL	340906
3749	133	95	2.42	182	DNG	P 1	09H	+19.07	TECTEH			A6997	seco	22H00093	H	600UL	340929
3750	135	95	2.81	185	DNT	P 1	09H	+0.42	TECTEH			A6997	seco	22H00093	H	600UL	340929
3751			2.13	181	DNG	P 1	09H	+13.49	TECTEH			A6997	seco	22H00093	H	600UL	340929
3752			2.25	182	DNT	P 1	10H	+0.88	TECTEH			A6997	seco	22H00093	H	600UL	340929
3753	137	95	0.80	84	NQI	5	TSH	+7.15	TECTEH			F3453	reso	22H00093	H	600UL	340929
3754					NDF		TSH	+7.15	TSH01H			C3340	reso	22H00193	H	600PP	345345
3755			3.02	182	DNT	P 1	09H	+0.50	TECTEH			A6997	seco	22H00093	H	600UL	340929
3756	139	95	4.33	186	DNT	P 1	09H	+0.40	TECTEH			A6997	seco	22H00093	H	600UL	340929
3757			4.91	186	DNT	P 1	10H	+0.64	TECTEH			A6997	seco	22H00093	H	600UL	340929
3758			6.66	178	DNG	P 1	DH	+2.78	TECTEH			A6997	seco	22H00093	H	600UL	340929
3759	40	96	4.61	180	DNG	P 1	VM	+9.94	TECTEH			N5877	seco	22H00125	H	600UL	340929
3760	54	96	2.63	175	DNG	P 1	TSC	+13.69	TECTEH			N2574	seco	22H00124	H	600UL	331931
3761	76	96			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3762			0.07	118	SAI	2	TSH	+1.04	TSHTSH	0.2		L2157	reso	22H00170	H	600PP	345290
3763			0.09	129	PID	4	TSH	+1.04	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
3764			0.19	113	SAI	1	TSH	+1.04	TSHTSH	0.3		L2157	reso	22H00170	H	600PP	345290
3765	88	96			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3766			0.29	80	SAI	1	TSH	+0.57	TSHTSH	0.2		M7006	reso	22H00171	H	600PP	345329
[illegible]			0.15	77	PID	4	TSH	+0.57	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
			0.15	80	SAI	2	TSH	+0.57	TSHTSH	0.4		M7006	reso	22H00171	H	600PP	345329
3769			0.35	78	MBM	5	04H	+31.20	TECTEH			C3340	reso	22H00048	H	600UL	340948
3770	90	96			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3771			0.21	57	PID	4	TSH	+0.23	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
3772			0.14	84	SAI	1	TSH	+0.23	TSHTSH	0.2		L2157	reso	22H00170	H	600PP	345290

3773			0.14	51	SAI	2	TSH	+0.23	TSHTSH	0.2			L2157	reso	22H00170	H	600PP	345290

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 78

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3774			2.32	176	DNG	P 1	09C	+2.15	TECTEH			D3858	reso	22H00045	H	600UL	340830
3775	102	96	0.63	78	MBM	5	01C	+31.72	TECTEH			C5542	reso	22H00005	H	600UL	340906
3776	110	96	3.75	184	DNG	P 1	TSC	+13.17	TECTEH			M2655	seco	22H00005	H	600UL	340906
3777	112	96	2.93	183	DNG	P 1	VH	+28.69	TECTEH			N5877	seco	22H00034	H	600UL	331892
3778			1.88	181	INR	P 1	VM	+2.08	TECTEH			L2157	reso	22H00034	H	600UL	331892
3779	116	96	1.64	179	INR	P 1	DH	+3.36	TECTEH			L2157	reso	22H00034	H	600UL	331892
3780			1.64	179	INR	P 1	DH	+3.59	TECTEH			L2157	reso	22H00034	H	600UL	331892
3781			2.35	178	DNG	P 1	VH	+3.28	TECTEH			N5877	seco	22H00034	H	600UL	331892
3782			2.01	85	MBM	5	08C	+15.05	TECTEH			L2157	reso	22H00034	H	600UL	331892
3783	118	96	2.33	182	DNG	P 1	02H	+37.80	TECTEH	LOCOK		D3858	reso	22H00005	H	600UL	340906
3784			2.54	182	DNG	P 1	04C	+28.45	TECTEH			M2655	seco	22H00005	H	600UL	340906
3785	126	96	0.11	105	VOL	2	TSH	+2.29	TSHTSH			F3453	reso	22H00173	H	600PP	345326
3786	128	96	0.79	65	MBM	6	VH	+6.02	TECTEH			L2157	reso	22H00006	H	600UL	331891
3787	130	96	3.05	181	DNG	P 1	09H	+7.25	TECTEH			N5877	seco	22H00034	H	600UL	331892
3788			2.35	182	DNG	P 1	09H	+8.85	TECTEH			N5877	seco	22H00034	H	600UL	331892
3789			2.46	182	DNG	P 1	09H	+16.36	TECTEH			N5877	seco	22H00034	H	600UL	331892
3790			2.96	185	DNG	P 1	09H	+18.89	TECTEH			N5877	seco	22H00034	H	600UL	331892
			6.62	181	DNG	P 1	09H	+19.18	TECTEH			N5877	seco	22H00034	H	600UL	331892
			6.32	184	DNG	P 1	09H	+19.82	TECTEH			N5877	seco	22H00034	H	600UL	331892
3793			2.48	181	DNG	P 1	09H	+20.46	TECTEH			N5877	seco	22H00034	H	600UL	331892
3794			4.76	181	DNT	P 1	10H	-0.07	TECTEH			N5877	seco	22H00034	H	600UL	331892
3795			2.91	181	DNT	P 1	10H	+0.96	TECTEH			N5877	seco	22H00034	H	600UL	331892
3796			3.28	182	DNT	P 1	10C	-0.56	TECTEH			N5877	seco	22H00034	H	600UL	331892
3797			4.12	182	DNT	P 1	10C	+0.00	TECTEH			N5877	seco	22H00034	H	600UL	331892
3798	134	96	2.37	179	DNG	P 1	09H	+7.37	TECTEH			A6997	seco	22H00093	H	600UL	340929
3799			6.54	181	DNT	P 1	10H	+0.75	TECTEH			A6997	seco	22H00093	H	600UL	340929
3800			13.60	181	DNG	P 1	10H	+1.71	TECTEH			A6997	seco	22H00093	H	600UL	340929
3801			2.50	182	DNT	P 1	10C	-0.52	TECTEH			A6997	seco	22H00093	H	600UL	340929
3802			2.13	170	DNT	P 1	09C	+0.30	TECTEH			A6997	seco	22H00093	H	600UL	340929
3803			1.75	170	INR	P 1	09C	+13.89	TECTEH			A6997	seco	22H00093	H	600UL	340929
3804			10.46	183	DNG	P 1	09C	+15.00	TECTEH			A6997	seco	22H00093	H	600UL	340929
3805			3.63	180	DNG	P 1	09C	+16.43	TECTEH			A6997	seco	22H00093	H	600UL	340929
3806			8.58	181	DNG	P 1	09C	+17.41	TECTEH			A6997	seco	22H00093	H	600UL	340929
3807			5.46	181	DNG	P 1	09C	+18.76	TECTEH			A6997	seco	22H00093	H	600UL	340929
3808			3.90	180	DNG	P 1	09C	+19.65	TECTEH			A6997	seco	22H00093	H	600UL	340929
3809	136	96	7.60	179	DNT	P 1	09H	+0.57	TECTEH			A6997	seco	22H00093	H	600UL	340929
3810			3.32	182	DNG	P 1	09H	+18.08	TECTEH			A6997	seco	22H00093	H	600UL	340929
3811			2.46	181	DNG	P 1	10H	+1.58	TECTEH			A6997	seco	22H00093	H	600UL	340929
3812	138	96	1.92	196	INR	P 1	10H	+0.48	TECTEH			A6997	seco	22H00093	H	600UL	340929
3813			0.57	70	MBM	5	08C	+12.91	TECTEH			F3453	reso	22H00093	H	600UL	340929
3814	37	97	1.70	84	MBM	5	01H	+11.41	TECTEH			F6623	reso	22H00120	H	600UL	331931
3815			1.05	83	MBM	5	01H	+14.74	TECTEH			F6623	reso	22H00120	H	600UL	331931
[illegible]	39	97	0.88	71	MBM	5	01C	+27.33	TECTEH			F3453	reso	22H00121	H	600UL	340929
			0.92	64	MBM	5	01C	+28.58	TECTEH			F3453	reso	22H00121	H	600UL	340929
3818	51	97	5.74	182	DNG	P 1	04C	+7.47	TECTEH			N2574	seco	22H00124	H	600UL	331931
3819			4.53	183	DNG	P 1	04C	+8.04	TECTEH			N2574	seco	22H00124	H	600UL	331931
3820			2.36	182	DNG	P 1	04C	+8.74	TECTEH			N2574	seco	22H00124	H	600UL	331931
3821	59	97			NDF		02H	+19.42	02H03H			N2574	seco	22H00207	H	600PP	345329

3822			0.64	77	NQI	5	02H	+19.42	TECTEH			C3340	reso	22H00124	H	600UL	331931

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 79

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3823	75	97	7.68	183	DNG	P 1	07H	+23.99	TECTEH			H2949	seco	22H00048	H	600UL	340948
3824			6.55	8	PVN	P 1	DH	+25.18	TECTEH			T5565	prim	22H00048	H	600UL	340948
3825			3.06	183	DNG	P 1	07C	+14.69	TECTEH			H2949	seco	22H00048	H	600UL	340948
3826	77	97	0.43	65	MBM	5	TSH	+22.20	TECTEH			D3858	reso	22H00045	H	600UL	340830
3827	85	97			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3828			0.20	96	PID	4	TSH	+0.45	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
3829			0.19	113	MAI	1	TSH	+0.45	TSHTSH	0.8		L2157	reso	22H00170	H	600PP	345290
3830			0.21	92	MAI	2	TSH	+0.45	TSHTSH	0.9		L2157	reso	22H00170	H	600PP	345290
3831	95	97	9.96	187	DNT	P 1	09C	+0.09	TECTEH			A9574	seco	22H00006	H	600UL	331891
3832	97	97	1.53	85	MBM	6	03H	+9.67	TECTEH	IDOK		S4373	reso	22H00006	H	600UL	331891
3833			0.97	89	MBM	5	03H	+9.71	TECTEH			C5542	reso	22H00005	H	600UL	340906
3834			11.34	187	DNT	P 1	09H	+0.02	TECTEH	IDOK		S4373	reso	22H00006	H	600UL	331891
3835			12.06	185	DNT	P 1	09H	+0.04	TECTEH			M2655	seco	22H00005	H	600UL	340906
3836	99	97	0.39	73	MBM	5	DH	+9.90	TECTEH			C5542	reso	22H00005	H	600UL	340906
3837	107	97	2.62	182	DNG	P 1	05H	+34.49	TECTEH			M2655	seco	22H00005	H	600UL	340906
3838	109	97			INF		09C	+13.73	TECTEH	HR		L2157	reso	22H00006	H	600UL	331891
3839			6.53	185	DNG	P 1	09C	+15.15	TECTEH			L2157	reso	22H00006	H	600UL	331891
	117	97	4.71	184	DNT	P 1	10C	+0.53	TECTEH			A9574	seco	22H00006	H	600UL	331891
	119	97	8.00	186	DNT	P 1	09C	+0.02	TECTEH			M2655	seco	22H00005	H	600UL	340906
3842			0.93	78	MBM	5	02C	+8.38	TECTEH			C5542	reso	22H00005	H	600UL	340906
3843			0.60	81	MBM	5	02C	+18.39	TECTEH			C5542	reso	22H00005	H	600UL	340906
3844	121	97	4.22		NRC	2	TSC	+0.00	TECTEH			N5877	seco	22H00034	H	600UL	331892
3845	129	97	3.07	184	DNG	P 1	VH	+3.87	TECTEH			A9574	seco	22H00006	H	600UL	331891
3846	133	97	0.66	82	MBM	5	06C	+3.11	TECTEH			F3453	reso	22H00093	H	600UL	340929
3847	135	97	10.68	179	DNT	P 1	09H	+0.42	TECTEH			A6997	seco	22H00093	H	600UL	340929
3848			19.78	182	DNT	P 1	10H	-0.02	TECTEH			A6997	seco	22H00093	H	600UL	340929
3849			2.66	181	DNG	P 1	VM	+2.88	TECTEH			A6997	seco	22H00093	H	600UL	340929
3850			4.46	185	DNT	P 1	09C	+0.55	TECTEH			A6997	seco	22H00093	H	600UL	340929
3851	137	97	5.51	181	DNT	P 1	09H	+0.80	TECTEH			A6997	seco	22H00093	H	600UL	340929
3852			2.95	176	DNT	P 1	10H	+0.68	TECTEH			A6997	seco	22H00093	H	600UL	340929
3853	30	98	2.60	179	DNG	P 1	01H	+20.57	TECTEH			M0945	seco	22H00121	H	600UL	340929
3854			5.34	186	DNG	P 1	05C	+14.88	TECTEH			M0945	seco	22H00121	H	600UL	340929
3855	42	98			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3856			0.18	38	MAI	1	TSH	+2.49	TSHTSH	0.4		F3453	reso	22H00175	H	600PP	345329
3857			0.25	93	MAI	2	TSH	+2.49	TSHTSH	0.4		F3453	reso	22H00175	H	600PP	345329
3858			0.26	81	PID	4	TSH	+2.49	TSHTSH	080		M1680	reso	22H00207	H	600PP	345329
3859	46	98	2.67	182	DNG	P 1	02C	+23.22	TECTEH			H2949	seco	22H00120	H	600UL	331931
3860			0.84	62	MBM	5	01C	+5.48	TECTEH			F6623	reso	22H00120	H	600UL	331931
3861			1.40	74	MBM	5	01C	+7.64	TECTEH			F6623	reso	22H00120	H	600UL	331931
3862	52	98	7.87	176	DNG	P 1	01H	+25.78	TECTEH			N5877	seco	22H00125	H	600UL	340929
3863			4.42	179	DNG	P 1	03H	+12.68	TECTEH			N5877	seco	22H00125	H	600UL	340929
3864	54	98	0.98	58	MBM	5	05C	+5.21	TECTEH			C3340	reso	22H00124	H	600UL	331931
3865	70	98	1.79	182	INR	P 1	DH	+1.76	TECTEH			H2949	seco	22H00048	H	600UL	340948
			2.77	178	DNG	P 1	DH	+30.50	TECTEH			H2949	seco	22H00048	H	600UL	340948
3867	80	98	0.76	81	MBM	5	02H	+20.23	TECTEH			C3340	reso	22H00048	H	600UL	340948
3868	82	98			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3869			0.15	94	MAI	2	TSH	+0.61	TSHTSH	0.5		F3453	reso	22H00174	H	600PP	345290
3870			0.19	49	MAI	1	TSH	+0.61	TSHTSH	0.6		F3453	reso	22H00174	H	600PP	345290

3871			0.15	86	PID	4	TSH	+0.61	TSHTSH	080			M1680	reso	22H00198	H	600PP	345345

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 80

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3872			0.00	0	MAI	1	TSH	+0.96	TSHTSH	0.0		F3453	reso	22H00174	H	600PP	345290
3873			0.08	99	MAI	2	TSH	+0.96	TSHTSH	0.3		F3453	reso	22H00174	H	600PP	345290
3874			3.25	183	DNG	P 1	08C	+14.05	TECTEH			T7451	seco	22H00045	H	600UL	340830
3875	86	98			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3876			0.17	65	PID	4	TSH	+0.51	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
3877			0.15	82	SAI	2	TSH	+0.51	TSHTSH	0.3		F3453	reso	22H00174	H	600PP	345290
3878			0.19	52	SAI	1	TSH	+0.51	TSHTSH	0.3		F3453	reso	22H00174	H	600PP	345290
3879			0.12	86	MAI	2	TSH	+0.80	TSHTSH	0.4		F3453	reso	22H00174	H	600PP	345290
3880			0.18	58	MAI	1	TSH	+0.80	TSHTSH	0.4		F3453	reso	22H00174	H	600PP	345290
3881			0.15	27	SAI	1	TSH	+1.10	TSHTSH	0.2		F3453	reso	22H00174	H	600PP	345290
3882			0.08	126	SAI	2	TSH	+1.10	TSHTSH	0.2		F3453	reso	22H00174	H	600PP	345290
3883	92	98	65.82	185	DNT	P 1	09H	+0.11	TECTEH			A9574	seco	22H00006	H	600UL	331891
3884					NDF		09H	+0.11	09H09H			M7007	prim	22H00203	H	600PP	345330
3885			2.34	185	DNG	P 1	08C	+11.04	TECTEH			A9574	seco	22H00006	H	600UL	331891
3886			7.04	183	DNG	P 1	08C	+11.98	TECTEH			A9574	seco	22H00006	H	600UL	331891
3887			4.27	183	DNG	P 1	08C	+12.28	TECTEH			A9574	seco	22H00006	H	600UL	331891
3888	98	98			NDF	3	09H	+0.02	09H09H			M7007	prim	22H00203	H	600PP	345330
			51.45	185	DNT	P 1	09H	+0.02	TECTEH			M2655	seco	22H00005	H	600UL	340906
	104	98			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3891			0.12	104	PID	4	TSH	+2.60	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
3892			0.00	0	SAI	1	TSH	+2.60	TSHTSH	0.0		F6623	reso	22H00172	H	600PP	345353
3893			0.10	109	SAI	2	TSH	+2.60	TSHTSH	0.4		F6623	reso	22H00172	H	600PP	345353
3894			1.03	86	MBM	5	07H	+7.37	TECTEH			L2157	reso	22H00034	H	600UL	331892
3895	106	98	3.19	182	DNG	P 1	08H	+16.86	TECTEH			M2655	seco	22H00005	H	600UL	340906
3896	112	98			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3897			0.26	21	PID	P 1	TSH	-0.14	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
3898			0.19	30	SCI	P 2	TSH	-0.14	TSHTSH	0.4	PWSCC	F6623	reso	22H00172	H	600PP	345353
3899			0.00	0	SCI	1	TSH	-0.14	TSHTSH	0.0		F6623	reso	22H00172	H	600PP	345353
3900			3.59	181	DNT	P 1	VM	+1.91	TECTEH			N5877	seco	22H00034	H	600UL	331892
3901	114	98	2.83	187	DNT	P 1	06H	-0.68	TECTEH			M2655	seco	22H00005	H	600UL	340906
3902	118	98	4.16	182	DNG	P 1	08H	+8.30	TECTEH			M2655	seco	22H00005	H	600UL	340906
3903			9.10	185	DNT	P 1	10H	+0.06	TECTEH			M2655	seco	22H00005	H	600UL	340906
3904	126	98	3.62	185	DNT	P 1	09H	-0.08	TECTEH			M2655	seco	22H00005	H	600UL	340906
3905			3.46	184	DNG	P 1	DC	+10.86	TECTEH			M2655	seco	22H00005	H	600UL	340906
3906	130	98	0.43	58	MBM	5	TSH	+13.80	TECTEH			M7006	reso	22H00012	H	600UL	340906
3907			0.60	83	MBM	5	02H	+36.96	TECTEH			M7006	reso	22H00012	H	600UL	340906
3908	134	98	10.86	179	DNT	P 1	09H	+0.38	TECTEH			A6997	seco	22H00093	H	600UL	340929
3909	136	98	18.11	179	DNT	P 1	09H	+0.39	TECTEH			A6997	seco	22H00093	H	600UL	340929
3910			3.26	181	DNG	P 1	09H	+16.43	TECTEH			A6997	seco	22H00093	H	600UL	340929
3911			7.81	183	DNG	P 1	09C	+3.77	TECTEH			A6997	seco	22H00093	H	600UL	340929
3912			4.03	181	DNG	P 1	09C	+10.38	TECTEH			A6997	seco	22H00093	H	600UL	340929
3913	138	98	1.97	177	INR	P 1	VH	+1.32	TECTEH			A6997	seco	22H00093	H	600UL	340929
3914	27	99	3.38	180	DNG	P 1	VM	+3.24	TECTEH			M0945	seco	22H00121	H	600UL	340929
			3.21	178	DNG	P 1	06C	+16.35	TECTEH			M0945	seco	22H00121	H	600UL	340929
3916	35	99	6.72	181	DNT	P 1	06H	-0.11	TECTEH			M0945	seco	22H00121	H	600UL	340929
3917					NDF		06H	-0.11	06H06H			N2574	seco	22H00207	H	600PP	345329
3918	77	99			TBP				TECTEH	FAILSLV	ADDTBP	D3858	reso	22H00044	H	600UL	331892
3919			0.00	0	SAI	1	TSH	+1.22	TSHTSH	0.0		F3453	reso	22H00175	H	600PP	345329

3920			0.12	96	SAI	2	TSH	+1.22	TSHTSH	0.4			F3453	reso	22H00175	H	600PP	345329

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 81

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3921			0.10	96	PID	4	TSH	+1.22	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
3922			0.54	88	MBM	5	04H	+34.88	TECTEH			C3340	reso	22H00048	H	600UL	340948
3923	81	99			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3924			0.16	86	PID	4	TSH	+0.36	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
3925			0.15	93	MAI	2	TSH	+0.36	TSHTSH	0.5		F3453	reso	22H00174	H	600PP	345290
3926			0.00	0	MAI	1	TSH	+0.36	TSHTSH	0.0		F3453	reso	22H00174	H	600PP	345290
3927	105	99	6.54	184	DNT	P 1	09H	-0.02	TECTEH			D4576	seco	22H00012	H	600UL	340906
3928	109	99	3.96	183	DNT	P 1	06H	+0.59	TECTEH			N2574	seco	22H00012	H	600UL	340906
3929	111	99	5.15	180	DNT	P 1	09C	-0.82	TECTEH	LOCOK		D3858	reso	22H00011	H	600UL	331891
3930			2.10	177	DNG	P 1	08C	+12.59	TECTEH			N2574	seco	22H00011	H	600UL	331891
3931			3.43	179	DNG	P 1	08C	+20.24	TECTEH			N2574	seco	22H00011	H	600UL	331891
3932			0.84	62	MBM	5	02C	+20.63	TECTEH			M7006	reso	22H00011	H	600UL	331891
3933	115	99	2.99	178	DNG	P 1	04C	+5.74	TECTEH			N2574	seco	22H00011	H	600UL	331891
3934	117	99	6.55	182	DNG	P 1	VH	+4.27	TECTEH			M7006	reso	22H00012	H	600UL	340906
3935			4.14	183	DNT	P 1	10C	-0.73	TECTEH	LOCOK		D3858	reso	22H00012	H	600UL	340906
3936			4.14	183	DNT	P 1	10C	-0.46	TECTEH			D3858	reso	22H00012	H	600UL	340906
3937			5.81	182	DNT	P 1	10C	+0.46	TECTEH			N2574	seco	22H00012	H	600UL	340906
			4.14		INF	P 1	09C	+22.04	TECTEH	HR		D3858	reso	22H00012	H	600UL	340906
	119	99	3.90	181	DNT	P 1	VC	+2.15	TECTEH			N2574	seco	22H00011	H	600UL	331891
3940	121	99	5.82	200	NRC	2	TSC	+0.00	TECTEH			W4892	prim	22H00012	H	600UL	340906
3941	131	99	2.92	186	DNT	P 1	09C	+0.47	TECTEH			N2574	seco	22H00011	H	600UL	331891
3942	133	99	0.87	86	MBM	6	06H	+16.84	TECTEH			F3453	reso	22H00093	H	600UL	340929
3943			2.17	181	DNG	P 1	08H	+2.41	TECTEH			A6997	seco	22H00093	H	600UL	340929
3944					NDF		09H	+0.40	09H09H			S8982	seco	22H00193	H	600PP	345345
3945			13.89	178	DNT	P 1	09H	+0.40	TECTEH			A6997	seco	22H00093	H	600UL	340929
3946			3.47	179	DNG	P 1	09H	+4.10	TECTEH			A6997	seco	22H00093	H	600UL	340929
3947			2.31	181	DNG	P 1	09H	+14.17	TECTEH			A6997	seco	22H00093	H	600UL	340929
3948			3.89	180	DNT	P 1	09C	+0.24	TECTEH			A6997	seco	22H00093	H	600UL	340929
3949			2.92	181	DNG	P 1	09C	+15.25	TECTEH			A6997	seco	22H00093	H	600UL	340929
3950	135	99	3.90	181	DNT	P 1	09H	-0.41	TECTEH			A6997	seco	22H00093	H	600UL	340929
3951			16.87	181	DNT	P 1	09H	+0.35	TECTEH			A6997	seco	22H00093	H	600UL	340929
3952	137	99	2.51	182	DNG	P 1	10C	+18.11	TECTEH			A6997	seco	22H00093	H	600UL	340929
3953	26	100	1.04	78	23	P 2	DH	-1.94	TECTEH			M0945	seco	22H00121	H	600UL	340929
3954			0.65	87	16	P 2	VM	+1.73	TECTEH			M0945	seco	22H00121	H	600UL	340929
3955	58	100	4.12	178	DNG	P 1	VM	+18.79	TECTEH			N5877	seco	22H00125	H	600UL	340929
3956	60	100	0.55	137	24	P 2	VM	-2.00	TECTEH			K6388	prim	22H00124	H	600UL	331931
3957	70	100	2.34	181	DNG	P 1	06C	+3.01	TECTEH			I3805	seco	22H00041	H	600UL	340830
3958	84	100			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3959			0.18	91	MAI	2	TSH	+0.54	TSHTSH	0.8		F3453	reso	22H00175	H	600PP	345329
3960			0.00	0	MAI	1	TSH	+0.54	TSHTSH	0.0		F3453	reso	22H00175	H	600PP	345329
3961			0.18	95	PID	4	TSH	+0.54	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
3962			0.00	0	SAI	1	TSH	+0.97	TSHTSH	0.0		F3453	reso	22H00175	H	600PP	345329
[illegible]			0.10	127	SAI	2	TSH	+0.97	TSHTSH	0.2		F3453	reso	22H00175	H	600PP	345329
	96	100	0.57	69	MBM	5	04H	+35.01	TECTEH			C5542	reso	22H00013	H	600UL	340915
3965	100	100	0.77	81	MBM	6	04C	+31.73	TECTEH			C5542	reso	22H00013	H	600UL	340915
3966	108	100	0.57	56	MBM	5	VM	+20.75	TECTEH			C5542	reso	22H00013	H	600UL	340915
3967	110	100	3.83	178	DNG	P 1	06H	+6.50	TECTEH			D4576	seco	22H00012	H	600UL	340906
3968	112	100	2.81	179	DNT	P 1	06H	-0.42	TECTEH			N5877	seco	22H00034	H	600UL	331892

3969			3.74	179	DNG	P 1	VH	+27.56	TECTEH			N5877	seco	22H00034	H	600UL	331892

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 82

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3970	116	100	2.58	181	DNG	P 1	VH	+3.60	TECTEH			D4576	seco	22H00013	H	600UL	340915
3971	130	100	8.39	181	DNT	P 1	10H	-0.02	TECTEH			D4576	seco	22H00012	H	600UL	340906
3972					NDF		10H	-0.02	10H10H			M7007	prim	22H00203	H	600PP	345330
3973			4.26	178	DNT	P 1	09C	+0.46	TECTEH			D4576	seco	22H00012	H	600UL	340906
3974	132	100	18.32	181	DNT	P 1	09H	+0.05	TECTEH			A6997	seco	22H00093	H	600UL	340929
3975			2.60	178	DNG	P 1	TSC	+5.47	TECTEH			A6997	seco	22H00093	H	600UL	340929
3976	134	100	2.32	178	DNT	P 1	09H	-0.59	TECTEH			A6997	seco	22H00093	H	600UL	340929
3977			10.56	179	DNT	P 1	09H	+0.32	TECTEH			A6997	seco	22H00093	H	600UL	340929
3978	136	100	0.40	73	PLP	9	TSH	+0.37	TSHTSH			S8982	seco	22H00193	H	600PP	345345
3979			1.03	98	MBM	5	07H	+16.93	TECTEH			F3453	reso	22H00093	H	600UL	340929
3980	138	100	0.42	74	PLP	9	TSH	+0.36	TSHTSH			S8982	seco	22H00193	H	600PP	345345
3981			0.59	74	MBM	5	TSH	+21.64	TECTEH			F3453	reso	22H00093	H	600UL	340929
3982			2.63	182	DNG	P 1	09H	+4.88	TECTEH			A6997	seco	22H00093	H	600UL	340929
3983	33	101	3.05	182	DNT	P 1	VM	-1.66	TECTEH			H2949	seco	22H00120	H	600UL	331931
3984	59	101	0.84	64	MBM	6	01C	+15.59	TECTEH			N5432	reso	22H00125	H	600UL	340929
3985			0.93	81	MBM	5	01C	+27.10	TECTEH			N5432	reso	22H00125	H	600UL	340929
3986	65	101			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
			0.16	48	PID	4	TSH	+0.97	TSHTSH	080		M1680	reso	22H00207	H	600PP	345329
[illegible]			0.09	50	SAI	2	TSH	+0.97	TSHTSH	0.2		F3453	reso	22H00174	H	600PP	345290
3989			0.00	0	SAI	1	TSH	+0.97	TSHTSH	0.0		F3453	reso	22H00174	H	600PP	345290
3990	67	101	1.55	78	MBM	5	TSH	+14.60	TECTEH			F6623	reso	22H00040	H	600UL	331892
3991	77	101	0.70	105	MBM	5	04H	+32.17	TECTEH			C3340	reso	22H00041	H	600UL	340830
3992	79	101			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
3993			0.27	102	PID	4	TSH	+0.88	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
3994			0.27	97	MAI	2	TSH	+0.88	TSHTSH	0.7		F3453	reso	22H00175	H	600PP	345329
3995			0.00	0	MAI	1	TSH	+0.88	TSHTSH	0.0		F3453	reso	22H00175	H	600PP	345329
3996	81	101	0.87	99	MBM	5	03H	+33.62	TECTEH			C3340	reso	22H00041	H	600UL	340830
3997			1.32	93	MBM	5	06H	+15.35	TECTEH			C3340	reso	22H00041	H	600UL	340830
3998	109	101	1.83	75	MBM	6	04H	+32.54	TECTEH			C5542	reso	22H00013	H	600UL	340915
3999			1.59	68	MBM	6	04H	+36.65	TECTEH			C5542	reso	22H00013	H	600UL	340915
4000	111	101	0.51	67	MBM	5	02H	+13.16	TECTEH			M7006	reso	22H00012	H	600UL	340906
4001	113	101	2.11	180	DNG	P 1	VM	+28.44	TECTEH			N5877	seco	22H00034	H	600UL	331892
4002	117	101	6.15	181	DNT	P 1	08H	+0.81	TECTEH			N5877	seco	22H00034	H	600UL	331892
4003			6.65	178	DNG	P 1	VM	+29.99	TECTEH			N5877	seco	22H00034	H	600UL	331892
4004					INF		VM	+31.81	TECTEH	HR		L2157	reso	22H00034	H	600UL	331892
4005			2.04	186	DNT	P 1	10C	+0.02	TECTEH			N5877	seco	22H00034	H	600UL	331892
4006			7.71	182	DNG	P 1	09C	+6.62	TECTEH			N5877	seco	22H00034	H	600UL	331892
4007	119	101	0.32	273	PLP	10	TSC	+0.33	TSCTSC			C5542	reso	22C00023	C	600PP	345294
4008	121	101	12.28	184	DNT	P 1	10H	+0.00	TECTEH			D4576	seco	22H00013	H	600UL	340915
4009			4.35	210	NRC	2	TSC	+0.00	TECTEH			D6502	prim	22H00013	H	600UL	340915
4010	123	101	4.27	178	DNG	P 1	09H	+3.10	TECTEH			D4576	seco	22H00012	H	600UL	340906
4011			2.67	178	DNG	P 1	09H	+7.35	TECTEH			D4576	seco	22H00012	H	600UL	340906
[illegible]	125	101	0.87	69	MBM	6	04C	+30.63	TECTEH			C5542	reso	22H00013	H	600UL	340915
	127	101	12.81	182	DNT	P 1	10H	-0.02	TECTEH			D4576	seco	22H00012	H	600UL	340906
4014	129	101	3.65	178	DNG	P 1	VH	+3.74	TECTEH			D4576	seco	22H00013	H	600UL	340915
4015	131	101	49.80	181	DNT	P 1	09H	-0.04	TECTEH			D4576	seco	22H00012	H	600UL	340906
4016			2.93	186	DNT	P 1	09C	+0.50	TECTEH			D4576	seco	22H00012	H	600UL	340906
4017	133	101	16.13	181	DNT	P 1	09H	-0.11	TECTEH			A6997	seco	22H00093	H	600UL	340929

4018					NDF	09H	+0.36	09H09H				S8982	seco	22H00193	H	600PP	345345

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 83

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4019		22.66	178	DNT	P 1	09H	+0.36	TECTEH			A6997	seco	22H00093	H	600UL	340929
4020	135	5.72	177	DNT	P 1	09H	-0.62	TECTEH			A6997	seco	22H00093	H	600UL	340929
4021		14.67	184	DNT	P 1	09H	+0.25	TECTEH			A6997	seco	22H00093	H	600UL	340929
4022	137	0.19	73	PLP	9	TSH	+0.54	TSHTSH			S8982	seco	22H00193	H	600PP	345345
4023		2.95	180	DNG	P 1	10H	+18.69	TECTEH			A6997	seco	22H00093	H	600UL	340929
4024	32	3.17	185	DNG	P 1	02C	+21.35	TECTEH			M0945	seco	22H00121	H	600UL	340929
4025	36	2.45	181	DNG	P 1	02H	+34.17	TECTEH			M0945	seco	22H00121	H	600UL	340929
4026	42	19.92	180	DNG	P 1	06C	+17.45	TECTEH			H2949	seco	22H00120	H	600UL	331931
4027		2.83	182	DNG	P 1	05C	+1.67	TECTEH			H2949	seco	22H00120	H	600UL	331931
4028	46			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
4029		0.14	105	MAI	2	TSH	+0.17	TSHTSH	0.3		F3453	reso	22H00175	H	600PP	345329
4030		0.00	0	MAI	1	TSH	+0.17	TSHTSH	0.0		F3453	reso	22H00175	H	600PP	345329
4031		0.13	90	PID	4	TSH	+0.17	TSHTSH	080		M1680	reso	22H00207	H	600PP	345329
4032		6.74	176	DNG	P 1	04H	+29.46	TECTEH			M0945	seco	22H00121	H	600UL	340929
4033	48			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4034		0.14	114	SAI	2	TSH	+0.15	TSHTSH	0.2		F3453	reso	22H00174	H	600PP	345290
4035		0.00	0	SAI	1	TSH	+0.15	TSHTSH	0.0		F3453	reso	22H00174	H	600PP	345290
		0.17	70	PID	4	TSH	+0.15	TSHTSH	080		M1680	reso	22H00207	H	600PP	345329
	52			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4038		0.11	93	PID	4	TSH	+0.47	TSHTSH	080		M1680	reso	22H00207	H	600PP	345329
4039		0.07	103	SAI	2	TSH	+0.47	TSHTSH	0.2		F3453	reso	22H00174	H	600PP	345290
4040		0.00	0	SAI	1	TSH	+0.47	TSHTSH	0.0		F3453	reso	22H00174	H	600PP	345290
4041	58	4.08	182	DNG	P 1	VM	+18.87	TECTEH			M0945	seco	22H00121	H	600UL	340929
4042	66	0.43	75	MBM	5	TSH	+12.53	TECTEH			F6623	reso	22H00040	H	600UL	331892
4043	68	0.70	90	MBM	5	03C	+14.86	TECTEH			C3340	reso	22H00041	H	600UL	340830
4044	70	1.78	188	INR	P 1	DH	+28.10	TECTEH			F6623	reso	22H00040	H	600UL	331892
4045	72	0.63	83	MBM	5	07H	+6.72	TECTEH			C3340	reso	22H00041	H	600UL	340830
4046	80	3.74	187	DNG	P 1	05H	+38.63	TECTEH			H4599	seco	22H00040	H	600UL	331892
4047	86	0.46	93	MBM	5	06H	+11.23	TECTEH			C3340	reso	22H00041	H	600UL	340830
4048	96	2.14	183	DNG	P 1	DC	+10.39	TECTEH			D4576	seco	22H00013	H	600UL	340915
4049	98	31.41	180	DNT	P 1	09H	+0.00	TECTEH			D4576	seco	22H00012	H	600UL	340906
4050	100	18.98	185	DNT	P 1	09H	+0.02	TECTEH			D4576	seco	22H00013	H	600UL	340915
4051	112	0.65	83	MBM	5	03C	+23.48	TECTEH			L2157	reso	22H00034	H	600UL	331892
4052	114	4.12	182	DNT	P 1	09H	-0.30	TECTEH			D4576	seco	22H00012	H	600UL	340906
4053		1.87	79	MBM	6	07C	+16.02	TECTEH			M7006	reso	22H00012	H	600UL	340906
4054		1.81	80	MBM	6	05C	+4.45	TECTEH			M7006	reso	22H00012	H	600UL	340906
4055		1.44	83	MBM	6	04C	+21.61	TECTEH			M7006	reso	22H00012	H	600UL	340906
4056		1.01	98	MBM	6	03C	+25.55	TECTEH			M7006	reso	22H00012	H	600UL	340906
4057		1.77	77	MBM	6	03C	+34.52	TECTEH			M7006	reso	22H00012	H	600UL	340906
4058	116	2.83	178	DNG	P 1	VH	+3.27	TECTEH			N5877	seco	22H00034	H	600UL	331892
4059	118	3.28	180	DNG	P 1	08H	+14.87	TECTEH			D4576	seco	22H00012	H	600UL	340906
4060		2.62	178	DNG	P 1	08H	+16.49	TECTEH			D4576	seco	22H00012	H	600UL	340906
[illegible]		2.06	179	DNG	P 1	09H	+1.64	TECTEH			D4576	seco	22H00012	H	600UL	340906
	120	5.34	182	DNT	P 1	10H	+0.02	TECTEH			N5877	seco	22H00034	H	600UL	331892
4063		2.36	180	DNG	P 1	VC	+3.20	TECTEH			N5877	seco	22H00034	H	600UL	331892
4064	122	2.83	181	DNG	P 1	DH	+28.66	TECTEH			D4576	seco	22H00012	H	600UL	340906
4065		2.83	181	DNG	P 1	VH	+28.75	TECTEH			D4576	seco	22H00012	H	600UL	340906
4066	124	3.30	179	DNT	P 1	10C	+0.44	TECTEH			D4576	seco	22H00013	H	600UL	340915

4067	128	102	24.09	184	DNT	P 1	10H	-0.07	TECTEH			D4576	seco	22H00013	H	600UL	340915

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 84

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4068					NDF			10H -0.07	10H10H			M7007	prim	22H00203	H	600PP	345330
4069	132	102			NDF			09H -0.11	09H09H			S8982	seco	22H00193	H	600PP	345345
4070			28.78	182	DNT	P 1		09H -0.11	TECTEH			A6997	seco	22H00093	H	600UL	340929
4071	134	102	3.61	176	DNT	P 1		09H -0.59	TECTEH			A6997	seco	22H00093	H	600UL	340929
4072			10.92	183	DNT	P 1		09H +0.41	TECTEH			A6997	seco	22H00093	H	600UL	340929
4073	136	102	0.44	80	MBM	5		TSH +11.98	TECTEH			F3453	reso	22H00093	H	600UL	340929
4074			0.68	93	MBM	5		02H +30.43	TECTEH			F3453	reso	22H00093	H	600UL	340929
4075			2.04	177	DNT	P 1		09H -0.47	TECTEH			A6997	seco	22H00093	H	600UL	340929
4076			3.67	176	DNT	P 1		09H +0.44	TECTEH			A6997	seco	22H00093	H	600UL	340929
4077			1.83	182	INR	P 1		10C +17.15	TECTEH			A6997	seco	22H00093	H	600UL	340929
4078	27	103	2.80	180	DNG	P 1		VM +3.37	TECTEH			M0945	seco	22H00121	H	600UL	340929
4079	45	103			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
4080			0.00	0	SCI	1		TSH +0.08	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
4081			0.21	116	PID	P 1		TSH +0.08	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4082			0.17	106	SCI	P 1		TSH +0.08	TSHTSH	1.1		F3453	reso	22H00177	H	600PP	345290
4083	49	103			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4084			0.10	100	MAI	2		TSH +0.27	TSHTSH	0.2		F6623	reso	22H00178	H	600PP	345329
			0.12	99	PID	4		TSH +0.27	TSHTSH	080		M1680	reso	22H00207	H	600PP	345329
			0.00	0	MAI	1		TSH +0.27	TSHTSH	0.0		F6623	reso	22H00178	H	600PP	345329
4087	53	103	8.65	182	DNT	P 1		05H -0.37	TECTEH			M0945	seco	22H00121	H	600UL	340929
4088					OBS			TEC +0.00	TECTEC			H4599	seco	22C00050	C	600PP	345295
4089					OBS			TEC +0.00	TECTEC			M2655	seco	22C00071	C	600PP	345298
4090	57	103	5.65	183	DNG	P 1		06H +22.34	TECTEH			H2949	seco	22H00120	H	600UL	331931
4091			3.24	181	DNG	P 1		07H -1.83	TECTEH			F6623	reso	22H00120	H	600UL	331931
4092			11.84	183	DNG	P 1		07H -1.24	TECTEH			H2949	seco	22H00120	H	600UL	331931
4093			4.90	182	DNT	P 1		07H +0.99	TECTEH			F6623	reso	22H00120	H	600UL	331931
4094			2.66	182	DNG	P 1		06C +21.53	TECTEH			F6623	reso	22H00120	H	600UL	331931
4095	77	103			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4096			0.10	73	MAI	2		TSH +0.72	TSHTSH	0.6		F3453	reso	22H00177	H	600PP	345290
4097			0.00	0	MAI	1		TSH +0.72	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
4098			0.11	67	PID	4		TSH +0.72	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4099	85	103	0.45	93	MBM	5		06H +10.34	TECTEH			C3340	reso	22H00041	H	600UL	340830
4100	93	103	12.02	186	DNT	P 1		09H -0.11	TECTEH			D4576	seco	22H00013	H	600UL	340915
4101			0.86	90	MBM	5		VH +18.29	TECTEH			C5542	reso	22H00013	H	600UL	340915
4102	103	103	2.41	178	DNG	P 1		01C +27.74	TECTEH			D4576	seco	22H00012	H	600UL	340906
4103	107	103	17.60	183	DNT	P 1		09H -0.02	TECTEH			D4576	seco	22H00012	H	600UL	340906
4104	109	103	3.80	187	DNT	P 1		06H -0.58	TECTEH			D4576	seco	22H00013	H	600UL	340915
4105	115	103	0.79	68	MBM	5		07H +7.35	TECTEH			M7006	reso	22H00012	H	600UL	340906
4106	117	103	2.83	185	DNG	P 1		08H +5.26	TECTEH			D4576	seco	22H00013	H	600UL	340915
4107			6.16	187	DNT	P 1		10C -0.47	TECTEH			D4576	seco	22H00013	H	600UL	340915
4108			8.19	184	DNT	P 1		10C +0.45	TECTEH			D4576	seco	22H00013	H	600UL	340915
4109			4.12	184	DNT	P 1		09C -0.11	TECTEH			D4576	seco	22H00013	H	600UL	340915
4110			6.16	188	INR	P 1		09C +22.09	TECTEH			C5542	reso	22H00013	H	600UL	340915
			2.18	184	DNG	P 1		01C +21.14	TECTEH			D4576	seco	22H00013	H	600UL	340915
4112	119	103	3.24	180	DNG	P 1		VH +3.04	TECTEH			D4576	seco	22H00012	H	600UL	340906
4113	121	103			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
4114			0.46	125	DSI	P 1		01H +0.88	TECTEH			N5877	seco	22H00034	H	600UL	331892
4115			0.00	0	SVI	4		01H +0.93	01H01H	0.0		F3453	reso	22H00203	H	600PP	345330

4116			0.14	115	PID	4	01H	+0.93	01H01H	080			N5432	reso	22H00210	H	600PP	345330

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 85

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4117		0.17	95	SVI	4	01H	+0.93	01H01H	0.2		F3453	reso	22H00203	H	600PP	345330
4118		2.35	179	DNT	P 1	10C	-0.58	TECTEH			N5877	seco	22H00034	H	600UL	331892
4119		3.56	182	DNT	P 1	10C	+0.52	TECTEH			N5877	seco	22H00034	H	600UL	331892
4120		3.01		NRC	2	TSC	+0.00	TECTEH			N5877	seco	22H00034	H	600UL	331892
4121	127	0.97	87	MBM	6	05H	+23.95	TECTEH			M7006	reso	22H00012	H	600UL	340906
4122	129	2.27	185	DNT	P 1	10H	+0.47	TECTEH			N5877	seco	22H00034	H	600UL	331892
4123		2.81	182	DNT	P 1	09C	+0.49	TECTEH			N5877	seco	22H00034	H	600UL	331892
4124	131	2.49	182	DNT	P 1	09H	+0.47	TECTEH			D4576	seco	22H00012	H	600UL	340906
4125	133	4.47	182	DNT	P 1	09H	-0.48	TECTEH			F3453	reso	22H00093	H	600UL	340929
4126		18.91	180	DNT	P 1	09H	+0.30	TECTEH			A6997	seco	22H00093	H	600UL	340929
4127		3.73	183	DNG	P 1	06C	+19.36	TECTEH			A6997	seco	22H00093	H	600UL	340929
4128		2.80	185	DNG	P 1	06C	+20.63	TECTEH			A6997	seco	22H00093	H	600UL	340929
4129	135	3.18	181	DNT	P 1	09H	+0.36	TECTEH			A6997	seco	22H00093	H	600UL	340929
4130		3.00	181	DNG	P 1	05C	+26.80	TECTEH			A6997	seco	22H00093	H	600UL	340929
4131	22			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
4132		0.00	0	SAI	1	TSH	+0.63	TSHTSH	0.0		D8661	reso	22H00189	H	600PP	345298
4133		0.24	92	SAI	2	TSH	+0.63	TSHTSH	0.2		D8661	reso	22H00189	H	600PP	345298
		0.24	111	PID	4	TSH	+0.63	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
		0.12	93	SAI	2	TSH	+0.99	TSHTSH	0.2		D8661	reso	22H00189	H	600PP	345298
4136		0.20	126	SAI	1	TSH	+0.99	TSHTSH	0.2		D8661	reso	22H00189	H	600PP	345298
4137	32	6.12	183	DNT	P 1	06H	+0.56	TECTEH			H2949	seco	22H00120	H	600UL	331931
4138		4.23	181	DNG	P 1	VM	+2.31	TECTEH			H2949	seco	22H00120	H	600UL	331931
4139	52			TBP				TECTEH	FAILSLV	ADDTBP	D3858	reso	22H00044	H	600UL	331892
4140		0.29	109	PID	4	TSH	+0.20	TSHTSH	080		M1680	reso	22H00207	H	600PP	345329
4141		0.34	91	SAI	2	TSH	+0.20	TSHTSH	0.3		F3453	reso	22H00177	H	600PP	345290
4142		0.36	45	SAI	1	TSH	+0.20	TSHTSH	0.3		F3453	reso	22H00177	H	600PP	345290
4143		0.08	102	SAI	2	TSH	+0.59	TSHTSH	0.2		F3453	reso	22H00177	H	600PP	345290
4144		0.00	0	SAI	1	TSH	+0.59	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
4145		0.08	89	MAI	2	TSH	+0.69	TSHTSH	0.3		F3453	reso	22H00177	H	600PP	345290
4146		0.00	0	MAI	1	TSH	+0.69	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
4147	68			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4148		0.00	0	SAI	1	TSH	+0.17	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
4149		0.09	114	SAI	2	TSH	+0.17	TSHTSH	0.2		F3453	reso	22H00177	H	600PP	345290
4150		0.06	138	SAI	2	TSH	+0.50	TSHTSH	0.2		F3453	reso	22H00177	H	600PP	345290
4151		0.00	0	SAI	1	TSH	+0.50	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
4152		0.13	120	PID	4	TSH	+0.84	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4153		0.10	123	MAI	2	TSH	+0.84	TSHTSH	0.2		F3453	reso	22H00177	H	600PP	345290
4154		0.00	0	MAI	1	TSH	+0.84	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
4155	78			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4156		0.11	123	SAI	2	TSH	+0.56	TSHTSH	0.3		F6623	reso	22H00178	H	600PP	345329
4157		0.28	28	SAI	1	TSH	+0.56	TSHTSH	0.2		F6623	reso	22H00178	H	600PP	345329
4158		0.12	86	PID	4	TSH	+0.56	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
[illegible]	82			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
		0.20	115	PID	4	TSH	+0.29	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4161		0.17	110	SAI	2	TSH	+0.29	TSHTSH	0.3		F6623	reso	22H00178	H	600PP	345329
4162		0.22	48	SAI	1	TSH	+0.29	TSHTSH	0.3		F6623	reso	22H00178	H	600PP	345329
4163	84	0.90	74	MBM	5	01H	+34.93	TECTEH			C3340	reso	22H00041	H	600UL	340830
4164	90			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892

4165				0.12	128	SCI	P 1	TSH	+0.00	TSHTSH	0.3			F3453	reso	22H00177	H	600PP	345290

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 86

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4166			0.22	136	PID	P 1	TSH	+0.00	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4167			0.00	0	SCI	1	TSH	+0.00	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
4168	98	104	6.76	179	DNG	P 1	VH	+27.84	TECTEH			D4576	seco	22H00012	H	600UL	340906
4169	100	104	2.32	184	DNG	P 1	DC	+10.41	TECTEH			D4576	seco	22H00013	H	600UL	340915
4170	106	104	3.07	180	DNT	P 1	06H	-0.22	TECTEH			D4576	seco	22H00012	H	600UL	340906
4171	112	104	2.01	184	DNG	P 1	VH	+28.73	TECTEH			N5877	seco	22H00034	H	600UL	331892
4172	114	104	5.18	176	DNG	P 1	VC	+2.87	TECTEH			D4576	seco	22H00012	H	600UL	340906
4173	116	104	2.10	183	DNG	P 1	05H	+11.76	TECTEH			D4576	seco	22H00013	H	600UL	340915
4174	130	104	3.58	176	DNT	P 1	09H	+0.39	TECTEH			D4576	seco	22H00012	H	600UL	340906
4175			4.54	180	DNT	P 1	09C	+0.48	TECTEH			D4576	seco	22H00012	H	600UL	340906
4176	132	104	1.16	93	MBM	5	TSH	+9.70	TECTEH			F3453	reso	22H00093	H	600UL	340929
4177			3.20	174	DNT	P 1	09H	-0.44	TECTEH			A6997	seco	22H00093	H	600UL	340929
4178			29.83	180	DNT	P 1	09H	+0.38	TECTEH			A6997	seco	22H00093	H	600UL	340929
4179	134	104	11.19	181	DNT	P 1	09H	-0.63	TECTEH			A6997	seco	22H00093	H	600UL	340929
4180			22.89	180	DNT	P 1	09H	+0.27	TECTEH			A6997	seco	22H00093	H	600UL	340929
4181			3.34	179	DNC	P 1	09H	+2.51	TECTEH			A6997	seco	22H00093	H	600UL	340929
4182			2.33	178	DNG	P 1	VH	+25.62	TECTEH			A6997	seco	22H00093	H	600UL	340929
	136	104	2.54	175	DNT	P 1	09H	+0.38	TECTEH			A6997	seco	22H00093	H	600UL	340929
	15	105	9.02	181	DNG	P 1	06C	+9.27	TECTEH			A6997	seco	22H00114	H	600UL	340929
4185	37	105	4.03	181	DNT	P 1	VM	-1.17	TECTEH			M0945	seco	22H00121	H	600UL	340929
4186	39	105	0.87	93	MBM	5	TSH	+13.02	TECTEH			F6623	reso	22H00120	H	600UL	331931
4187	43	105	7.02	185	DNG	P 1	03H	+24.64	TECTEH			H2949	seco	22H00120	H	600UL	331931
4188			2.97	182	DNG	P 1	03H	+36.47	TECTEH			H2949	seco	22H00120	H	600UL	331931
4189			3.28	184	DNG	P 1	06H	+7.80	TECTEH			H2949	seco	22H00120	H	600UL	331931
4190	51	105			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4191			0.25	68	SAI	1	TSH	+0.81	TSHTSH	0.3		F6623	reso	22H00178	H	600PP	345329
4192			0.15	116	SAI	2	TSH	+0.81	TSHTSH	0.3		F6623	reso	22H00178	H	600PP	345329
4193			0.13	73	PID	4	TSH	+0.81	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4194	67	105	3.92	186	DNG	P 1	05H	+36.70	TECTEH			H4599	seco	22H00040	H	600UL	331892
4195	71	105			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4196			0.10	90	SAI	2	TSH	+0.71	TSHTSH	0.3		F6623	reso	22H00178	H	600PP	345329
4197			0.09	92	PID	4	TSH	+0.71	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4198			0.00	0	SAI	1	TSH	+0.71	TSHTSH	0.0		F6623	reso	22H00178	H	600PP	345329
4199	75	105			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4200			0.14	88	SAI	2	TSH	+0.58	TSHTSH	0.2		F6623	reso	22H00178	H	600PP	345329
4201			0.00	0	SAI	1	TSH	+0.58	TSHTSH	0.0		F6623	reso	22H00178	H	600PP	345329
4202			0.13	94	PID	4	TSH	+0.58	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4203	81	105	0.38	82	MBM	5	02H	+16.98	TECTEH			C3340	reso	22H00041	H	600UL	340830
4204			1.05	91	MBM	5	03H	+12.60	TECTEH			C3340	reso	22H00041	H	600UL	340830
4205	83	105	0.62	82	MBM	5	03C	+8.46	TECTEH			F6623	reso	22H00040	H	600UL	331892
4206	91	105	0.52	78	MBM	5	05H	+15.21	TECTEH			C5542	reso	22H00016	H	600UL	332250
4207	93	105	3.84	180	DNG	P 1	TSH	+35.73	TECTEH			F7467	seco	22H00016	H	600UL	332250
4208	95	105	0.84	78	MBM	6	02H	+32.67	TECTEH			F6623	reso	22H00017	H	600UL	340906
			2.40	180	DNG	P 1	07C	+12.62	TECTEH			M0945	seco	22H00017	H	600UL	340906
4210	97	105	1.30	96	MBM	5	VH	+24.91	TECTEH			C5542	reso	22H00016	H	600UL	332250
4211			1.03	100	MBM	5	VM	+20.06	TECTEH			C5542	reso	22H00016	H	600UL	332250
4212			0.43	100	MBM	5	VM	+21.00	TECTEH			C5542	reso	22H00016	H	600UL	332250
4213	103	105	2.37	184	DNG	P 1	03C	+16.31	TECTEH			F7467	seco	22H00016	H	600UL	332250

4214	115	105	7.72	176	DNG	P 1	VM	+24.84	TECTEH				F6623	reso	22H00017	H	600UL		340906

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 87

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4215	117	105	9.22	183	DNT	P 1	10H	-0.02	TECTEH			F7467	seco	22H00016	H	600UL	332250
4216			2.15	181	DNG	P 1	VM	+31.15	TECTEH			C5542	reso	22H00016	H	600UL	332250
4217	119	105	2.50	178	DNG	P 1	08H	+11.96	TECTEH			M0945	seco	22H00017	H	600UL	340906
4218			5.83	183	DNT	P 1	09H	-0.13	TECTEH			M0945	seco	22H00017	H	600UL	340906
4219			2.53	182	DNG	P 1	10H	+1.60	TECTEH			M0945	seco	22H00017	H	600UL	340906
4220			3.10	178	DNG	P 1	VH	+2.95	TECTEH			M0945	seco	22H00017	H	600UL	340906
4221					INF		VH	+31.88	TECTEH	HR		S4373	reso	22H00017	H	600UL	340906
4222			2.22	178	DNT	P 1	VM	-0.94	TECTEH			M0945	seco	22H00017	H	600UL	340906
4223	121	105	4.09	22	NRC	2	TSC	+0.00	TECTEH			M7988	prim	22H00016	H	600UL	332250
4224	123	105	3.82	179	DNG	P 1	10C	+5.46	TECTEH			M0945	seco	22H00017	H	600UL	340906
4225	129	105	6.86	180	DNG	P 1	TSH	+23.51	TECTEH			N5877	seco	22H00034	H	600UL	331892
4226			0.81	88	MBM	5	05H	+19.54	TECTEH			L2157	reso	22H00034	H	600UL	331892
4227			4.26	179	DNT	P 1	09C	+0.49	TECTEH			N5877	seco	22H00034	H	600UL	331892
4228	131	105	3.83	175	DNT	P 1	09H	-0.34	TECTEH			D4576	seco	22H00012	H	600UL	340906
4229			14.80	177	DNT	P 1	09H	+0.46	TECTEH			D4576	seco	22H00012	H	600UL	340906
4230					NDF		09H	+0.46	09H09H			M7987	prim	22H00203	H	600PP	345330
4231			1.64	177	INR	P 1	DH	+30.04	TECTEH			D4576	seco	22H00012	H	600UL	340906
			2.46	179	DNT	P 1	10C	+0.34	TECTEH			D4576	seco	22H00012	H	600UL	340906
	133	105	23.63	181	DNT	P 1	09H	-0.51	TECTEH			A6997	seco	22H00093	H	600UL	340929
4234					NDF		09H	+0.25	09H09H			B6768	prim	22H00193	H	600PP	345345
4235			65.22	179	DNT	P 1	09H	+0.25	TECTEH			A6997	seco	22H00093	H	600UL	340929
4236	135	105	1.67	182	INR	P 1	09H	-0.44	TECTEH			F3453	reso	22H00093	H	600UL	340929
4237			6.93	178	DNT	P 1	09H	+0.34	TECTEH			A6997	seco	22H00093	H	600UL	340929
4238	28	106	2.17	183	DNG	P 1	01H	+23.65	TECTEH			I3805	seco	22H00063	H	600UL	340948
4239	38	106	4.66	180	DNG	P 1	04C	+7.98	TECTEH			M0945	seco	22H00121	H	600UL	340929
4240	40	106	7.50	183	DNG	P 1	07C	+1.32	TECTEH			H2949	seco	22H00120	H	600UL	331931
4241	52	106			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4242			0.10	131	SCI	P 1	TSH	+0.08	TSHTSH	0.2		F3453	reso	22H00177	H	600PP	345290
4243			0.10	152	PID	P 1	TSH	+0.08	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4244			0.00	0	SCI	1	TSH	+0.08	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
4245			0.10	57	SAI	2	TSH	+0.23	TSHTSH	0.2		M1680	reso	22H00177	H	600PP	345290
4246			0.00	0	SAI	1	TSH	+0.23	TSHTSH	0.0		M1680	reso	22H00177	H	600PP	345290
4247			3.01	182	DNG	P 1	01H	+20.96	TECTEH			H2949	seco	22H00120	H	600UL	331931
4248	54	106			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4249			0.11	119	SAI	2	TSH	+0.28	TSHTSH	0.1		M1680	reso	22H00178	H	600PP	345329
4250			0.00	0	SAI	1	TSH	+0.28	TSHTSH	0.0		M1680	reso	22H00178	H	600PP	345329
4251			0.17	97	SAI	2	TSH	+0.55	TSHTSH	0.5		F6623	reso	22H00178	H	600PP	345329
4252			0.15	103	PID	4	TSH	+0.55	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4253			0.28	73	SAI	1	TSH	+0.55	TSHTSH	0.4		F6623	reso	22H00178	H	600PP	345329
4254	58	106			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4255			0.12	124	SAI	2	TSH	+1.26	TSHTSH	0.3		F6623	reso	22H00178	H	600PP	345329
4256			0.00	0	SAI	1	TSH	+1.26	TSHTSH	0.0		F6623	reso	22H00178	H	600PP	345329
[illegible]			0.14	134	PID	4	TSH	+1.26	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
	70	106	2.75	184	DNG	P 1	DH	+29.28	TECTEH			F6623	reso	22H00040	H	600UL	331892
4259	72	106	2.94	182	DNG	P 1	TSH	+7.10	TECTEH			I3805	seco	22H00041	H	600UL	340830
4260	84	106	0.61	81	MBM	5	01H	+35.70	TECTEH			C3340	reso	22H00041	H	600UL	340830
4261	92	106	7.37	182	DNG	P 1	08H	+17.50	TECTEH			F7467	seco	22H00016	H	600UL	332250
4262			2.41	181	DNG	P 1	07C	+11.11	TECTEH			F7467	seco	22H00016	H	600UL	332250

4263	98	106	3.83	181	DNG	P 1	VH	+28.14	TECTEH			M0945	seco	22H00017	H	600UL	340906

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 88

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4264	100	106			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4265			0.18	74	PID	P 1	TSH	+0.07	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
4266			0.19	95	SCI	P 1	TSH	+0.07	TSHTSH	0.4		L2157	reso	22H00168	H	600PP	345354
4267			0.29	75	SCI	1	TSH	+0.07	TSHTSH	0.3		L2157	reso	22H00168	H	600PP	345354
4268	102	106	2.11	184	DNT	P 1	09H	-0.02	TECTEH			M0945	seco	22H00017	H	600UL	340906
4269	108	106	1.81	181	INR	P 1	08H	+0.66	TECTEH			F7467	seco	22H00016	H	600UL	332250
4270			2.28	181	DNG	P 1	08H	+9.44	TECTEH			F7467	seco	22H00016	H	600UL	332250
4271	112	106	13.40	180	DNG	P 1	VH	+27.84	TECTEH			F7467	seco	22H00016	H	600UL	332250
4272	118	106	3.05	184	DNT	P 1	10C	-0.44	TECTEH			M0945	seco	22H00017	H	600UL	340906
4273	120	106	2.50	182	DNG	P 1	08H	+14.01	TECTEH			F7467	seco	22H00016	H	600UL	332250
4274			4.85	184	DNG	P 1	08H	+14.81	TECTEH			F7467	seco	22H00016	H	600UL	332250
4275			5.46	184	DNG	P 1	VC	+3.19	TECTEH			F7467	seco	22H00016	H	600UL	332250
4276			2.83	182	DNT	P 1	10C	+0.59	TECTEH			F7467	seco	22H00016	H	600UL	332250
4277	122	106	7.63	180	DNG	P 1	08H	+15.47	TECTEH			M0945	seco	22H00017	H	600UL	340906
4278			6.66	180	DNG	P 1	10C	+4.31	TECTEH			M0945	seco	22H00017	H	600UL	340906
4279	124	106	0.79	90	MBM	5	02H	+24.38	TECTEH			C5542	reso	22H00016	H	600UL	332250
4280	130	106	0.52	85	MBM	5	03H	+33.80	TECTEH			M7006	reso	22H00104	H	600UL	340824
			3.66	181	DNT	P 1	09H	+0.18	TECTEH			M7006	reso	22H00104	H	600UL	340824
			3.73	186	DNT	P 1	09C	+0.40	TECTEH			F1726	seco	22H00104	H	600UL	340824
4283	132	106	3.95	177	DNT	P 1	09H	-0.53	TECTEH			A6997	seco	22H00093	H	600UL	340929
4284					NDF		09H	+0.38	09H09H			S8982	seco	22H00193	H	600PP	345345
4285			12.96	182	DNT	P 1	09H	+0.38	TECTEH			A6997	seco	22H00093	H	600UL	340929
4286	134	106	8.07	181	DNT	P 1	09H	-0.62	TECTEH			A6997	seco	22H00093	H	600UL	340929
4287			17.40	181	DNT	P 1	09H	+0.27	TECTEH			A6997	seco	22H00093	H	600UL	340929
4288	7	107	2.46	180	DNG	P 1	01C	+2.90	TECTEH			H2949	seco	22H00113	H	600UL	331931
4289	39	107			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4290			0.00	0	SAI	1	TSH	+0.25	TSHTSH	0.0		D8661	reso	22H00189	H	600PP	345298
4291			0.18	68	SAI	2	TSH	+0.25	TSHTSH	0.3		D8661	reso	22H00189	H	600PP	345298
4292			0.19	71	PID	4	TSH	+0.25	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4293			3.58	180	DNT	P 1	VM	-0.98	TECTEH			H2949	seco	22H00120	H	600UL	331931
4294	41	107	0.83	72	MBM	5	01C	+12.91	TECTEH			F3453	reso	22H00121	H	600UL	340929
4295	59	107	2.84	183	DNT	P 1	05C	+1.07	TECTEH			H2949	seco	22H00120	H	600UL	331931
4296	61	107	2.03	63	MBM	5	01C	+27.52	TECTEH			F6623	reso	22H00120	H	600UL	331931
4297	63	107	0.30	114	INR	P 1	TSH	+6.77	TECTEH			M1680	reso	22H00040	H	600UL	331892
4298			2.16	184	DNG	P 1	03C	+34.86	TECTEH			H4599	seco	22H00040	H	600UL	331892
4299			2.12	185	DNG	P 1	03C	+37.22	TECTEH			H4599	seco	22H00040	H	600UL	331892
4300	75	107	2.05	184	DNG	P 1	03H	+13.49	TECTEH			H4599	seco	22H00040	H	600UL	331892
4301	83	107	0.43	95	MBM	5	VM	+9.31	TECTEH			F6623	reso	22H00040	H	600UL	331892
4302	85	107	0.47	77	MBM	5	06H	+18.31	TECTEH			C3340	reso	22H00041	H	600UL	340830
4303	87	107	7.94	183	DNT	P 1	06H	+0.20	TECTEH			H4599	seco	22H00040	H	600UL	331892
4304					NDF		06H	+0.20	06H06H			M7007	prim	22H00203	H	600PP	345330
4305					INF		TSC	+31.44	TECTEH	HR		F6623	reso	22H00040	H	600UL	331892
[illegible]	95	107	1.10	86	MBM	5	06H	+20.29	TECTEH			F6623	reso	22H00017	H	600UL	340906
	109	107	5.55	184	DNG	P 1	VM	+22.09	TECTEH			M0945	seco	22H00017	H	600UL	340906
4308					INF		VM	+23.44	TECTEH	HR		C3340	reso	22H00017	H	600UL	340906
4309			2.17	179	DNG	P 1	VM	+27.13	TECTEH			M0945	seco	22H00017	H	600UL	340906
4310	111	107	12.36	182	DNG	P 1	08H	+14.49	TECTEH			F7467	seco	22H00016	H	600UL	332250
4311			5.61	181	DNG	P 1	VM	+27.94	TECTEH			F7467	seco	22H00016	H	600UL	332250

4312				4.04	185	DNT	P 1	09C	+0.13	TECTEH			F7467	seco	22H00016	H	600UL	332250

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 89

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4313			2.92	182	DNG	P 1	09C	+0.99	TECTEH			D3858	reso	22H00016	H	600UL	332250
4314			7.83	182	DNG	P 1	08C	+20.31	TECTEH			F7467	seco	22H00016	H	600UL	332250
4315	117	107	19.07	183	DNT	P 1	10H	-0.09	TECTEH			M0945	seco	22H00017	H	600UL	340906
4316			2.09	183	DNT	P 1	VC	-2.13	TECTEH			M0945	seco	22H00017	H	600UL	340906
4317	119	107	3.00	183	DNG	P 1	08H	+19.55	TECTEH			F7467	seco	22H00016	H	600UL	332250
4318			14.32	186	DNT	P 1	10H	-0.05	TECTEH			C5542	reso	22H00016	H	600UL	332250
4319			3.72	183	DNG	P 1	VM	+29.76	TECTEH			F7467	seco	22H00016	H	600UL	332250
4320			4.68	185	DNG	P 1	08C	+18.47	TECTEH			F7467	seco	22H00016	H	600UL	332250
4321	121	107	2.63	181	DNT	P 1	VC	+1.96	TECTEH			M0945	seco	22H00017	H	600UL	340906
4322			2.07	45	NRC	2	TSC	+0.00	TECTEH			M0945	seco	22H00017	H	600UL	340906
4323	123	107	0.98	86	MBM	5	05H	+15.38	TECTEH			F6623	reso	22H00017	H	600UL	340906
4324			8.36	179	DNT	P 1	VC	+2.05	TECTEH			M0945	seco	22H00017	H	600UL	340906
4325			3.63	180	DNG	P 1	10C	+5.47	TECTEH			M0945	seco	22H00017	H	600UL	340906
4326	125	107	2.33	183	DNG	P 1	05H	+6.26	TECTEH			M0945	seco	22H00017	H	600UL	340906
4327			2.22	183	DNG	P 1	VM	+30.04	TECTEH			M0945	seco	22H00017	H	600UL	340906
4328	127	107	5.65	184	DNT	P 1	10H	-0.15	TECTEH			F7467	seco	22H00016	H	600UL	332250
4329	129	107	2.98	183	DNT	P 1	09H	+0.41	TECTEH			M0945	seco	22H00017	H	600UL	340906
			4.60	183	DNT	P 1	09C	+0.46	TECTEH			M0945	seco	22H00017	H	600UL	340906
	133	107	1.43	91	NQI	5	02H	+29.25	TECTEH			F3453	reso	22H00093	H	600UL	340929
4332			0.36	117	VOL	4	02H	+29.53	02H03H			F3453	reso	22H00203	H	600PP	345330
4333			3.65	135	VOL	2	03H	+3.33	03H04H			C3340	reso	22H00193	H	600PP	345345
4334			2.32	96	NQI	5	03H	+3.33	TECTEH			F3453	reso	22H00093	H	600UL	340929
4335			7.30	180	DNT	P 1	09H	-0.41	TECTEH			A6997	seco	22H00093	H	600UL	340929
4336			20.59	182	DNT	P 1	09H	+0.34	TECTEH			A6997	seco	22H00093	H	600UL	340929
4337			4.90	182	DNG	P 1	09H	+7.42	TECTEH			A6997	seco	22H00093	H	600UL	340929
4338			2.26	182	DNG	P 1	10C	-1.26	TECTEH			A6997	seco	22H00093	H	600UL	340929
4339			5.79	182	DNT	P 1	10C	+1.05	TECTEH			A6997	seco	22H00093	H	600UL	340929
4340			3.28	182	DNG	P 1	02C	+3.36	TECTEH			A6997	seco	22H00093	H	600UL	340929
4341	20	108	3.12	184	DNT	P 1	04C	-0.62	TECTEH			A9574	seco	22H00064	H	600UL	340930
4342	22	108	2.55	183	DNG	P 1	06C	+13.55	TECTEH			I3805	seco	22H00063	H	600UL	340948
4343	36	108			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4344			0.20	91	MAI	2	TSH	+0.15	TSHTSH	0.2		A9608	reso	22H00188	H	600PP	345326
4345			0.22	102	PID	4	TSH	+0.15	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4346			0.11	38	MAI	1	TSH	+0.15	TSHTSH	0.2		A9608	reso	22H00188	H	600PP	345326
4347	38	108			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4348			0.20	73	MAI	2	TSH	+0.06	TSHTSH	0.5		F6623	reso	22H00178	H	600PP	345329
4349			0.22	70	PID	4	TSH	+0.06	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4350			0.00	0	MAI	1	TSH	+0.06	TSHTSH	0.0		F6623	reso	22H00178	H	600PP	345329
4351	42	108			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4352			0.13	85	MAI	2	TSH	+0.31	TSHTSH	0.4		F6623	reso	22H00178	H	600PP	345329
4353			0.28	85	MAI	1	TSH	+0.31	TSHTSH	0.3		F6623	reso	22H00178	H	600PP	345329
4354			0.24	129	PID	4	TSH	+0.31	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4355	52	108	3.79	182	DNG	P 1	06H	+14.86	TECTEH			H2949	seco	22H00120	H	600UL	331931
	56	108			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
4357			0.88	148	NQI	P 1	TSC	+1.44	TECTEH			F6623	reso	22H00120	H	600UL	331931
4358			0.23	139	MAI	1	TSC	+1.54	TSCTSC	0.3		C5542	reso	22C00049	C	600PP	345352
4359			0.22	118	PID	4	TSC	+1.54	TSCTSC	080		N5432	reso	22C00071	C	600PP	345298
4360			0.22	109	MAI	2	TSC	+1.54	TSCTSC	0.4		C5542	reso	22C00049	C	600PP	345352

4361	60	108	0.59	99	26	P 2	VM	-1.85	TECTEH			F6623	reso	22H00120	H	600UL	331931

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 90

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4362			2.46	185	DNG	P 1	VM	+19.99	TECTEH			H2949	seco	22H00120	H	600UL	331931
4363	66	108	6.87	186	DNT	P 1	07H	+0.95	TECTEH			H4599	seco	22H00040	H	600UL	331892
4364			4.24	185	DNG	P 1	07H	+5.58	TECTEH			H4599	seco	22H00040	H	600UL	331892
4365			6.74	188	DNG	P 1	07H	+10.08	TECTEH			H4599	seco	22H00040	H	600UL	331892
4366			3.82	187	DNG	P 1	07H	+15.70	TECTEH			H4599	seco	22H00040	H	600UL	331892
4367			9.48	187	DNG	P 1	DH	+12.99	TECTEH			H4599	seco	22H00040	H	600UL	331892
4368			2.63	185	DNT	P 1	07C	+0.79	TECTEH			H4599	seco	22H00040	H	600UL	331892
4369			3.38	183	DNG	P 1	07C	+8.83	TECTEH			H4599	seco	22H00040	H	600UL	331892
4370			8.45	182	DNG	P 1	07C	+13.80	TECTEH			H4599	seco	22H00040	H	600UL	331892
4371			3.12	187	DNG	P 1	06C	+19.65	TECTEH			H4599	seco	22H00040	H	600UL	331892
4372	68	108			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4373			0.22	132	PID	4	TSH	+0.49	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4374			0.19	97	SAI	2	TSH	+0.49	TSHTSH	0.3		F6623	reso	22H00178	H	600PP	345329
4375			0.41	114	SAI	1	TSH	+0.49	TSHTSH	0.3		F6623	reso	22H00178	H	600PP	345329
4376			0.56	159	NQI	P 1	TSH	+0.68	TECTEH			I3805	seco	22H00041	H	600UL	340830
4377	72	108			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4378			0.14	91	SAI	2	TSH	+0.69	TSHTSH	0.3		F6623	reso	22H00178	H	600PP	345329
			0.00	0	SAI	1	TSH	+0.69	TSHTSH	0.0		F6623	reso	22H00178	H	600PP	345329
			0.14	97	PID	4	TSH	+0.69	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4381	80	108	0.80	75	MBM	5	07C	+12.24	TECTEH			C3340	reso	22H00041	H	600UL	340830
4382			0.35	66	MBM	6	03C	-1.47	TECTEH			C3340	reso	22H00041	H	600UL	340830
4383	96	108	7.80	181	DNG	P 1	08H	+2.84	TECTEH			F1726	seco	22H00104	H	600UL	340824
4384	100	108	0.77	169	INR	6	VH	+6.96	TECTEH			D3858	reso	22H00016	H	600UL	332250
4385	112	108	3.93	185	DNG	P 1	VH	+28.53	TECTEH			F7467	seco	22H00016	H	600UL	332250
4386					INF		VM	-2.99	TECTEH	HR		D3858	reso	22H00016	H	600UL	332250
4387	114	108	4.92	178	DNT	P 1	VC	-1.09	TECTEH			F1726	seco	22H00104	H	600UL	340824
4388			2.74	177	DNT	P 1	VC	+2.29	TECTEH			F1726	seco	22H00104	H	600UL	340824
4389	116	108	2.62	180	DNT	P 1	VC	-1.33	TECTEH			F7467	seco	22H00016	H	600UL	332250
4390			2.64	185	DNG	P 1	VC	+2.90	TECTEH			F7467	seco	22H00016	H	600UL	332250
4391	118	108	3.39	179	DNT	P 1	10H	+0.02	TECTEH			M0945	seco	22H00017	H	600UL	340906
4392	122	108	2.27	173	DNT	P 1	10H	-0.13	TECTEH			M0945	seco	22H00017	H	600UL	340906
4393			2.13	182	DNG	P 1	10H	+3.59	TECTEH			M0945	seco	22H00017	H	600UL	340906
4394			1.56	16	INR	P 1	10H	+4.87	TECTEH			F6623	reso	22H00017	H	600UL	340906
4395			2.13	179	DNT	P 1	10C	+0.51	TECTEH			M0945	seco	22H00017	H	600UL	340906
4396	124	108	1.17	96	MBM	5	VH	+5.30	TECTEH			C5542	reso	22H00016	H	600UL	332250
4397			2.77	185	DNG	P 1	VH	+25.58	TECTEH			C5542	reso	22H00016	H	600UL	332250
4398			0.79	100	MBM	5	VM	+12.56	TECTEH			C5542	reso	22H00016	H	600UL	332250
4399	126	108	2.88	180	DNG	P 1	10C	+8.41	TECTEH			M0945	seco	22H00017	H	600UL	340906
4400	128	108	3.11	183	DNG	P 1	08H	+12.75	TECTEH			F7467	seco	22H00016	H	600UL	332250
4401			3.93	184	DNG	P 1	08H	+13.41	TECTEH			F7467	seco	22H00016	H	600UL	332250
4402			3.87	183	DNG	P 1	08H	+13.74	TECTEH			F7467	seco	22H00016	H	600UL	332250
4403			3.47	184	DNG	P 1	08H	+14.16	TECTEH			F7467	seco	22H00016	H	600UL	332250
4404			2.87	184	DNG	P 1	08H	+15.12	TECTEH			F7467	seco	22H00016	H	600UL	332250
			5.59	181	DNG	P 1	08H	+18.83	TECTEH			F7467	seco	22H00016	H	600UL	332250
4406			7.49	185	DNG	P 1	08H	+19.78	TECTEH			F7467	seco	22H00016	H	600UL	332250
4407			6.87	182	DNG	P 1	08H	+20.33	TECTEH			F7467	seco	22H00016	H	600UL	332250
4408			2.14	183	DNG	P 1	09H	-1.67	TECTEH			F7467	seco	22H00016	H	600UL	332250
4409			7.75	184	DNG	P 1	09H	-1.30	TECTEH			F7467	seco	22H00016	H	600UL	332250

4410			3.51	182	DNT	P 1	09H	-0.77		TECTEH	LOCOK			D3858	reso	22H00016	H	600UL	332250

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 91

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4411		6.77	184	DNT	P 1	09H	+0.39	TECTEH			F7467	seco	22H00016	H	600UL	332250
4412		3.34	184	DNT	P 1	09H	+0.82	TECTEH	LOCOK		D3858	reso	22H00016	H	600UL	332250
4413		2.14	184	DNG	P 1	09H	+1.32	TECTEH			F7467	seco	22H00016	H	600UL	332250
4414		2.27	183	DNG	P 1	09H	+2.34	TECTEH			F7467	seco	22H00016	H	600UL	332250
4415		2.12	184	DNG	P 1	09H	+3.31	TECTEH			F7467	seco	22H00016	H	600UL	332250
4416		5.09	183	DNG	P 1	09H	+9.32	TECTEH			F7467	seco	22H00016	H	600UL	332250
4417		9.41	185	DNG	P 1	09H	+10.34	TECTEH			F7467	seco	22H00016	H	600UL	332250
4418		2.76	183	DNG	P 1	09H	+11.25	TECTEH			F7467	seco	22H00016	H	600UL	332250
4419		2.78	183	DNG	P 1	09H	+12.09	TECTEH			F7467	seco	22H00016	H	600UL	332250
4420		3.08	183	DNT	P 1	10H	+0.23	TECTEH			F7467	seco	22H00016	H	600UL	332250
4421		6.94	183	DNT	P 1	09C	+0.40	TECTEH			F7467	seco	22H00016	H	600UL	332250
4422		3.12	183	DNG	P 1	09C	+18.35	TECTEH			F7467	seco	22H00016	H	600UL	332250
4423	130	20.09	177	DNT	P 1	09H	+0.38	TECTEH			M0945	seco	22H00017	H	600UL	340906
4424		2.02	179	DNT	P 1	10H	-0.21	TECTEH			M0945	seco	22H00017	H	600UL	340906
4425		2.09	182	DNT	P 1	09C	+0.50	TECTEH			M0945	seco	22H00017	H	600UL	340906
4426	132	7.34	183	DNT	P 1	09H	-0.56	TECTEH			A6997	seco	22H00093	H	600UL	340929
4427		13.66	182	DNT	P 1	09H	+0.34	TECTEH			A6997	seco	22H00093	H	600UL	340929
	134	3.46	181	DNT	P 1	09H	-0.56	TECTEH			A6997	seco	22H00093	H	600UL	340929
		5.55	180	DNT	P 1	09H	+0.45	TECTEH			A6997	seco	22H00093	H	600UL	340929
4430		2.38	182	DNG	P 1	09C	+9.70	TECTEH			A6997	seco	22H00093	H	600UL	340929
4431		5.22	182	DNG	P 1	09C	+14.13	TECTEH			A6997	seco	22H00093	H	600UL	340929
4432	7	0.60	77	MBM	5	01C	+25.43	TECTEH			C3340	reso	22H00113	H	600UL	331931
4433	19	3.66	180	DNG	P 1	06H	+10.81	TECTEH			S8982	seco	22H00059	H	600UL	340948
4434	35			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4435		0.21	93	MAI	2	TSH	+0.23	TSHTSH	0.2		D8661	reso	22H00189	H	600PP	345298
4436		0.20	81	PID	4	TSH	+0.23	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4437		0.00	0	MAI	1	TSH	+0.23	TSHTSH	0.0		C3340	reso	22H00189	H	600PP	345298
4438	37			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4439		0.15	53	MAI	1	TSH	+0.15	TSHTSH	0.3		A9608	reso	22H00188	H	600PP	345326
4440		0.19	86	MAI	2	TSH	+0.15	TSHTSH	0.3		A9608	reso	22H00188	H	600PP	345326
4441		0.21	91	PID	4	TSH	+0.15	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4442	41			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4443		0.41	102	PID	4	TSH	+0.34	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4444		0.37	108	SAI	2	TSH	+0.34	TSHTSH	0.6		A9608	reso	22H00188	H	600PP	345326
4445		0.55	79	SAI	1	TSH	+0.34	TSHTSH	0.3		A9608	reso	22H00188	H	600PP	345326
4446		0.46	78	MBM	5	01H	+35.31	TECTEH			F3453	reso	22H00121	H	600UL	340929
4447		3.05	176	DNG	P 1	02H	+20.95	TECTEH			M0945	seco	22H00121	H	600UL	340929
4448		3.28	178	DNT	P 1	VM	-1.36	TECTEH			M0945	seco	22H00121	H	600UL	340929
4449	43	2.61	184	DNG	P 1	TSH	+26.31	TECTEH			H2949	seco	22H00120	H	600UL	331931
4450	45			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4451		0.15	110	SAI	2	TSH	+0.75	TSHTSH	0.2		A9608	reso	22H00188	H	600PP	345326
4452		0.11	93	PID	4	TSH	+0.75	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4453		0.00	0	SAI	1	TSH	+0.75	TSHTSH	0.0		A9608	reso	22H00188	H	600PP	345326
	49			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4455		0.11	123	SAI	2	TSH	+0.55	TSHTSH	0.2		A9608	reso	22H00188	H	600PP	345326
4456		0.16	53	SAI	1	TSH	+0.55	TSHTSH	0.2		A9608	reso	22H00188	H	600PP	345326
4457		0.17	116	PID	4	TSH	+0.81	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4458		0.17	98	MAI	2	TSH	+0.81	TSHTSH	0.3		A9608	reso	22H00188	H	600PP	345326

4459			0.17	151	MAI	1	TSH	+0.81	TSHTSH	0.2			A9608	reso	22H00188	H	600PP	345326

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 92

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4460	55	109	3.30	187	DNG	P 1	TSC	+5.13	TECTEH			H2949	seco	22H00120	H	600UL	331931
4461	65	109	1.10	83	MBM	5	06H	+13.36	TECTEH			C3340	reso	22H00041	H	600UL	340830
4462	73	109	0.92	78	MBM	5	02H	+3.94	TECTEH			C3340	reso	22H00041	H	600UL	340830
4463	81	109	0.51	86	MBM	5	02H	+30.93	TECTEH			C3340	reso	22H00041	H	600UL	340830
4464	85	109	0.59	87	MBM	5	06H	+16.88	TECTEH			C3340	reso	22H00041	H	600UL	340830
4465	91	109	2.55	182	DNG	P 1	08C	+8.14	TECTEH			S8982	seco	22H00020	H	600UL	340911
4466			2.46	184	DNG	P 1	08C	+10.32	TECTEH			S8982	seco	22H00020	H	600UL	340911
4467	99	109	5.52	180	DNT	P 1	09C	-0.29	TECTEH			S8982	seco	22H00020	H	600UL	340911
4468			3.13	181	DNG	P 1	08C	+9.40	TECTEH			S8982	seco	22H00020	H	600UL	340911
4469			2.62	180	DNG	P 1	08C	+18.07	TECTEH			S8982	seco	22H00020	H	600UL	340911
4470	101	109	3.04	180	DNG	P 1	08H	+11.26	TECTEH			S8982	seco	22H00020	H	600UL	340911
4471			3.94	178	DNG	P 1	08H	+19.33	TECTEH			S8982	seco	22H00020	H	600UL	340911
4472			6.01	181	DNG	P 1	09H	+1.21	TECTEH			S8982	seco	22H00020	H	600UL	340911
4473			35.85	181	DNG	P 1	09H	+2.24	TECTEH			S8982	seco	22H00020	H	600UL	340911
4474			0.76	81	MBM	5	VH	+10.33	TECTEH			F6623	reso	22H00020	H	600UL	340911
4475			0.45	77	MBM	5	VH	+25.18	TECTEH			F6623	reso	22H00020	H	600UL	340911
4476			1.13	88	MBM	5	VM	+11.08	TECTEH			F6623	reso	22H00020	H	600UL	340911
			0.61	71	MBM	5	VM	+15.85	TECTEH			F6623	reso	22H00020	H	600UL	340911
[illegible]					NDF		VC	+1.91	VC VC			L2157	reso	22C00090	C	5602C	326272
4479			0.33	121	14	P 2	VC	+1.91	TECTEH			F6623	reso	22H00020	H	600UL	340911
4480			0.48	89	MBM	5	VC	+3.81	TECTEH			F6623	reso	22H00020	H	600UL	340911
4481			5.33	180	DNG	P 1	07C	+12.83	TECTEH			S8982	seco	22H00020	H	600UL	340911
4482	103	109			INF		09C	+8.88	TECTEH	HR		M1680	reso	22H00021	H	600UL	340830
4483	111	109	1.74	175	INR	P 1	08H	+8.73	TECTEH			S8982	seco	22H00021	H	600UL	340830
4484			5.41	176	DNT	P 1	09H	-0.16	TECTEH			S8982	seco	22H00021	H	600UL	340830
4485					NDF		09H	-0.16	09H09H			M7007	prim	22H00203	H	600PP	345330
4486			2.45	178	DNG	P 1	08C	+15.11	TECTEH			S8982	seco	22H00021	H	600UL	340830
4487	117	109	9.34	181	DNT	P 1	10H	+0.02	TECTEH			S8982	seco	22H00020	H	600UL	340911
4488			3.04	183	DNT	P 1	10C	-0.49	TECTEH			S8982	seco	22H00020	H	600UL	340911
4489			4.93	181	DNT	P 1	10C	+0.44	TECTEH			S8982	seco	22H00020	H	600UL	340911
4490	121	109	2.59	180	DNT	P 1	08H	+0.28	TECTEH			F1726	seco	22H00104	H	600UL	340824
4491			2.99	184	DNT	P 1	08H	+1.12	TECTEH			F1726	seco	22H00104	H	600UL	340824
4492			3.90	182	DNG	P 1	08H	+13.89	TECTEH			F1726	seco	22H00104	H	600UL	340824
4493			8.28	183	DNG	P 1	08H	+14.92	TECTEH			F1726	seco	22H00104	H	600UL	340824
4494			3.39	183	DNT	P 1	09H	-1.01	TECTEH			F1726	seco	22H00104	H	600UL	340824
4495			5.02	182	DNT	P 1	09H	-0.06	TECTEH			F1726	seco	22H00104	H	600UL	340824
4496					NDF		09H	-0.06	09H09H			M7007	prim	22H00203	H	600PP	345330
4497			2.95	184	DNG	P 1	09H	+9.20	TECTEH			F1726	seco	22H00104	H	600UL	340824
4498			4.08	34	NRC	2	TSC	+0.00	TECTEH			P2952	prim	22H00104	H	600UL	340824
4499	127	109	1.63	176	INR	P 1	09H	+0.00	TECTEH			M0945	seco	22H00017	H	600UL	340906
4500			2.62	176	DNT	P 1	10H	-0.02	TECTEH			M0945	seco	22H00017	H	600UL	340906
4501	129	109	2.69	184	DNT	P 1	09H	+0.42	TECTEH			F7467	seco	22H00016	H	600UL	332250
[illegible]	131	109	7.65	183	DNT	P 1	09H	-0.34	TECTEH			M0945	seco	22H00017	H	600UL	340906
			40.60	180	DNT	P 1	09H	+0.33	TECTEH			M0945	seco	22H00017	H	600UL	340906
4504	133	109	3.21	176	DNT	P 1	09H	-0.54	TECTEH			A6997	seco	22H00093	H	600UL	340929
4505			7.62	179	DNT	P 1	09H	+0.34	TECTEH			A6997	seco	22H00093	H	600UL	340929
4506	4	110			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
4507			0.18	79	SAI	2	TSH	+0.12	TSHTSH	0.2		A9608	reso	22H00188	H	600PP	345326

4508			0.27	24	SAI	1	TSH	+0.12	TSHTSH	0.2			A9608	reso	22H00188	H	600PP	345326

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 93

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4509		0.13	117	PID	4	TSH	+0.12	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4510	6	1.26	106	VOL	2	05H	+18.20	06C05H			N5432	reso	22C00106	H	5602C	340935
4511		1.31	93	ADR	6	05H	+18.41 TO+17.62	TECTEH			S4373	reso	22H00113	H	600UL	331931
4512	28			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
4513		0.29	108	PID	4	TSH	+0.28	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4514		0.29	99	MAI	2	TSH	+0.28	TSHTSH	0.3		A9608	reso	22H00188	H	600PP	345326
4515		0.27	81	MAI	1	TSH	+0.28	TSHTSH	0.2		A9608	reso	22H00188	H	600PP	345326
4516		2.13	183	DNG	P 1	05H	+16.20	TECTEH			S8982	seco	22H00059	H	600UL	340948
4517		3.15	179	DNG	P 1	05H	+17.00	TECTEH			S8982	seco	22H00059	H	600UL	340948
4518		4.29	181	DNG	P 1	05H	+29.59	TECTEH			S8982	seco	22H00059	H	600UL	340948
4519	30			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
4520		0.15	51	MAI	1	TSH	+0.39	TSHTSH	0.3		D8661	reso	22H00189	H	600PP	345298
4521		0.18	107	MAI	2	TSH	+0.39	TSHTSH	0.4		D8661	reso	22H00189	H	600PP	345298
4522		0.21	98	PID	4	TSH	+0.39	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4523		0.00	0	SAI	1	TSH	+0.79	TSHTSH	0.0		D8661	reso	22H00189	H	600PP	345298
4524		0.15	63	SAI	2	TSH	+0.79	TSHTSH	0.2		D8661	reso	22H00189	H	600PP	345298
4525	34			TBP				TECTEH	DISSLV	ADDTBP	D3858	reso	22H00044	H	600UL	331892
				DIS	3	SBH	+23.94	SBHSTH			G9427	prim	22H00239	H	500PP	326655
		1.47	24	PID	3	SBH	+23.94	SBHSTH			D3858	reso	22H00239	H	500PP	326655
4528		0.00	0	SAI	1	TSH	+0.16	TSHTSH	0.0		D8661	reso	22H00189	H	600PP	345298
4529		0.10	101	SAI	2	TSH	+0.16	TSHTSH	0.2		D8661	reso	22H00189	H	600PP	345298
4530		0.13	118	PID	4	TSH	+0.17	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4531		0.00	0	SAI	1	TSH	+0.17	TSHTSH	0.0		A9608	reso	22H00188	H	600PP	345326
4532		0.12	92	SAI	2	TSH	+0.17	TSHTSH	0.2		A9608	reso	22H00188	H	600PP	345326
4533		6.70	185	DNG	P 1	DH	+7.45	TECTEH			I3805	seco	22H00063	H	600UL	340948
4534	36			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4535		0.47	104	PID	4	TSH	+0.32	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4536		0.50	100	MAI	2	TSH	+0.32	TSHTSH	0.5		A9608	reso	22H00188	H	600PP	345326
4537		0.69	81	MAI	1	TSH	+0.32	TSHTSH	0.4		A9608	reso	22H00188	H	600PP	345326
4538	40	2.68	180	DNG	P 1	VM	+9.87	TECTEH			I3805	seco	22H00063	H	600UL	340948
4539	52	2.56	182	DNG	P 1	VM	+15.87	TECTEH			H2949	seco	22H00120	H	600UL	331931
4540	54			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4541		0.17	73	PID	4	TSH	+1.36	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4542		0.00	0	SAI	1	TSH	+1.36	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
4543		0.18	93	SAI	2	TSH	+1.36	TSHTSH	0.2		F3453	reso	22H00177	H	600PP	345290
4544	70			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4545		0.18	68	SAI	1	TSH	+0.76	TSHTSH	0.6		F3453	reso	22H00177	H	600PP	345290
4546		0.17	114	PID	4	TSH	+0.76	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4547		0.15	123	SAI	2	TSH	+0.76	TSHTSH	0.6		F3453	reso	22H00177	H	600PP	345290
4548	72	2.89	179	DNT	P 1	06H	-0.39	TECTEH			I3805	seco	22H00041	H	600UL	340830
4549		4.73	179	DNT	P 1	VM	+1.99	TECTEH			I3805	seco	22H00041	H	600UL	340830
4550		1.16	95	MBM	5	TSC	+26.85	TECTEH			C3340	reso	22H00041	H	600UL	340830
	76	0.79	92	MBM	5	05C	+14.39	TECTEH			C3340	reso	22H00041	H	600UL	340830
		0.76	87	MBM	5	05C	+31.67	TECTEH			C3340	reso	22H00041	H	600UL	340830
4553	86	0.49	76	MBM	5	02H	+20.17	TECTEH			F6623	reso	22H00040	H	600UL	331892
4554		0.47	97	MBM	5	03H	+26.22	TECTEH			F6623	reso	22H00040	H	600UL	331892
4555		0.48	99	MBM	5	03H	+33.85	TECTEH			F6623	reso	22H00040	H	600UL	331892
4556	98	4.66	182	DNT	P 1	09H	+0.02	TECTEH			S8982	seco	22H00020	H	600UL	340911

4557	100	110	0.55	79	MBM	5	02H	+4.81	TECTEH				N5432	reso	22H00021	H	600UL	340830

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 94

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4558			0.36	82	MBM	5	04H	+4.96	TECTEH			N5432	reso	22H00021	H	600UL	340830
4559			3.87	181	DNT	P 1	09H	+0.11	TECTEH			S8982	seco	22H00021	H	600UL	340830
4560	104	110	0.69	89	MBM	6	03C	+25.50	TECTEH			N5432	reso	22H00021	H	600UL	340830
4561	110	110	1.83	175	INR	P 1	08H	+13.08	TECTEH			S8982	seco	22H00021	H	600UL	340830
4562			3.91	173	DNG	P 1	08H	+16.04	TECTEH			S8982	seco	22H00021	H	600UL	340830
4563			7.00	175	DNG	P 1	08H	+16.54	TECTEH			S8982	seco	22H00021	H	600UL	340830
4564			3.27	171	DNG	P 1	08H	+18.18	TECTEH			S8982	seco	22H00021	H	600UL	340830
4565			4.14	172	DNG	P 1	08H	+18.88	TECTEH			S8982	seco	22H00021	H	600UL	340830
4566			2.85	172	DNG	P 1	08H	+19.42	TECTEH			S8982	seco	22H00021	H	600UL	340830
4567			2.32	171	DNG	P 1	08H	+19.99	TECTEH			S8982	seco	22H00021	H	600UL	340830
4568			3.92	175	DNG	P 1	09H	-1.00	TECTEH			S8982	seco	22H00021	H	600UL	340830
4569			31.75	177	DNT	P 1	09H	-0.17	TECTEH			S8982	seco	22H00021	H	600UL	340830
4570			2.10	175	DNG	P 1	VM	-2.70	TECTEH			S8982	seco	22H00021	H	600UL	340830
4571			3.05	174	DNG	P 1	08C	+14.81	TECTEH			S8982	seco	22H00021	H	600UL	340830
4572			4.60	174	DNG	P 1	08C	+17.74	TECTEH			S8982	seco	22H00021	H	600UL	340830
4573			4.69	175	DNG	P 1	08C	+19.91	TECTEH			M1680	reso	22H00021	H	600UL	340830
4574			2.58	176	DNG	P 1	08C	+21.26	TECTEH	LOCOK		S4373	reso	22H00021	H	600UL	340830
	114	110	16.81	179	DNT	P 1	09H	-0.11	TECTEH			S8982	seco	22H00021	H	600UL	340830
	116	110	0.47	81	MBM	5	04C	+14.77	TECTEH			F6623	reso	22H00020	H	600UL	340911
4577	118	110	2.04	184	DNT	P 1	10C	-0.43	TECTEH			S8982	seco	22H00021	H	600UL	340830
4578	120	110	2.08	178	DNG	P 1	02C	+34.68	TECTEH			S8982	seco	22H00020	H	600UL	340911
4579	124	110	2.78	177	DNT	P 1	10C	+0.41	TECTEH			S8982	seco	22H00020	H	600UL	340911
4580	128	110	3.26	180	DNT	P 1	09H	+0.44	TECTEH			S8982	seco	22H00020	H	600UL	340911
4581			2.23	180	DNT	P 1	10H	-0.02	TECTEH			S8982	seco	22H00020	H	600UL	340911
4582			5.68	182	DNG	P 1	VC	+2.32	TECTEH			S8982	seco	22H00020	H	600UL	340911
4583			3.58	187	DNT	P 1	09C	+0.40	TECTEH			S8982	seco	22H00020	H	600UL	340911
4584	130	110	3.88	169	DNT	P 1	09H	+0.33	TECTEH			S8982	seco	22H00021	H	600UL	340830
4585			5.45	171	DNT	P 1	09C	+0.41	TECTEH			S8982	seco	22H00021	H	600UL	340830
4586	132	110	3.30	178	DNT	P 1	10C	-0.64	TECTEH			A6997	seco	22H00093	H	600UL	340929
4587			3.73	177	DNT	P 1	10C	+0.27	TECTEH			A6997	seco	22H00093	H	600UL	340929
4588	19	111	0.34	81	PLP	9	TSH	+0.82	TSHTSH			A9608	reso	22H00188	H	600PP	345326
4589	25	111			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
4590			0.00	0	SAI	1	TSH	+0.23	TSHTSH	0.0		D8661	reso	22H00189	H	600PP	345298
4591			0.14	126	SAI	2	TSH	+0.23	TSHTSH	0.1		D8661	reso	22H00189	H	600PP	345298
4592			0.18	130	PID	4	TSH	+0.23	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4593	47	111			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4594			0.14	91	SAI	2	TSH	+0.38	TSHTSH	0.1		D8661	reso	22H00189	H	600PP	345298
4595			0.12	100	PID	4	TSH	+0.38	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4596			0.00	0	SAI	1	TSH	+0.38	TSHTSH	0.0		C3340	reso	22H00189	H	600PP	345298
4597			0.00	0	SAI	1	TSH	+0.79	TSHTSH	0.0		D8661	reso	22H00189	H	600PP	345298
4598			0.10	124	SAI	2	TSH	+0.79	TSHTSH	0.1		D8661	reso	22H00189	H	600PP	345298
4599	49	111			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
[illegible]			0.00	0	SCI	1	TSH	+0.19	TSHTSH	0.0		A9608	reso	22H00188	H	600PP	345326
			0.14	90	SCI	P 1	TSH	+0.19	TSHTSH	0.2		A9608	reso	22H00188	H	600PP	345326
4602			0.09	113	PID	P 1	TSH	+0.19	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4603	57	111	5.16	183	DNT	P 1	06H	+0.37	TECTEH			H2949	seco	22H00120	H	600UL	331931
4604	63	111			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4605			0.10	84	SAI	2	TSH	+0.68	TSHTSH	0.3		F6623	reso	22H00178	H	600PP	345329

4606			0.00	0	SAI	1	TSH	+0.68	TSHTSH	0.0			F6623	reso	22H00178	H	600PP	345329

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 95

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4607			0.10	88	MAI	2	TSH	+1.15	TSHTSH	0.2		F6623	reso	22H00178	H	600PP	345329
4608			0.11	85	PID	4	TSH	+1.15	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4609			0.00	0	MAI	1	TSH	+1.15	TSHTSH	0.0		F6623	reso	22H00178	H	600PP	345329
4610	71	111	0.43	93	MBM	5	DH	+12.41	TECTEH			F6623	reso	22H00040	H	600UL	331892
4611	75	111	0.46	54	MBM	5	03C	+31.53	TECTEH			F6623	reso	22H00040	H	600UL	331892
4612	81	111			INF		VH	+4.15	TECTEH	HR		C3340	reso	22H00041	H	600UL	340830
4613			0.65	110	MBM	5	VH	+6.12	TECTEH			C3340	reso	22H00041	H	600UL	340830
4614	95	111	0.77	84	MBM	6	TSH	+14.55	TECTEH			N5432	reso	22H00021	H	600UL	340830
4615			2.26	182	DNT	P 1	09H	+0.02	TECTEH			S8982	seco	22H00021	H	600UL	340830
4616	99	111	0.82	81	MBM	5	03H	+23.99	TECTEH			N5432	reso	22H00021	H	600UL	340830
4617			6.81	178	DNG	P 1	08H	+17.92	TECTEH			S8982	seco	22H00021	H	600UL	340830
4618			2.69	174	DNT	P 1	09C	-0.73	TECTEH			S8982	seco	22H00021	H	600UL	340830
4619			2.88	175	DNG	P 1	08C	+5.44	TECTEH			S8982	seco	22H00021	H	600UL	340830
4620			2.74	176	DNG	P 1	08C	+9.41	TECTEH			S8982	seco	22H00021	H	600UL	340830
4621			18.62	177	DNG	P 1	08C	+10.42	TECTEH			S8982	seco	22H00021	H	600UL	340830
4622	103	111	1.21	79	MBM	6	05H	+6.12	TECTEH			N5432	reso	22H00021	H	600UL	340830
4623			0.94	56	MBM	6	05H	+17.03	TECTEH			N5432	reso	22H00021	H	600UL	340830
			2.14	178	DNG	P 1	05C	+1.54	TECTEH			S4373	reso	22H00021	H	600UL	340830
	107	111	2.05	176	DNG	P 1	08C	+7.39	TECTEH			S8982	seco	22H00021	H	600UL	340830
4626			3.13	177	DNG	P 1	08C	+9.35	TECTEH			S8982	seco	22H00021	H	600UL	340830
4627			2.36	175	DNG	P 1	08C	+12.81	TECTEH			S8982	seco	22H00021	H	600UL	340830
4628			3.80	175	DNG	P 1	08C	+13.79	TECTEH			S8982	seco	22H00021	H	600UL	340830
4629	109	111	2.22	185	DNG	P 1	08H	+4.08	TECTEH			S8982	seco	22H00020	H	600UL	340911
4630			6.86	183	DNG	P 1	08H	+4.94	TECTEH			S8982	seco	22H00020	H	600UL	340911
4631			5.11	183	DNG	P 1	08H	+19.93	TECTEH			S8982	seco	22H00020	H	600UL	340911
4632			2.83	184	DNG	P 1	08H	+20.88	TECTEH			S8982	seco	22H00020	H	600UL	340911
4633			19.17	184	DNT	P 1	09H	-0.56	TECTEH			S8982	seco	22H00020	H	600UL	340911
4634			4.01	182	DNT	P 1	09H	-0.20	TECTEH			F6623	reso	22H00020	H	600UL	340911
4635			14.98	184	DNT	P 1	09H	+0.18	TECTEH			S8982	seco	22H00020	H	600UL	340911
4636			37.40	184	DNG	P 1	09H	+0.93	TECTEH			S4373	reso	22H00020	H	600UL	340911
4637			3.78	185	DNT	P 1	VM	-0.32	TECTEH			S8982	seco	22H00020	H	600UL	340911
4638			6.13	182	DNG	P 1	09C	-1.07	TECTEH			S8982	seco	22H00020	H	600UL	340911
4639			4.84	182	DNG	P 1	08C	+2.42	TECTEH			S8982	seco	22H00020	H	600UL	340911
4640			2.70	181	DNG	P 1	08C	+10.05	TECTEH			S8982	seco	22H00020	H	600UL	340911
4641			6.93	183	DNG	P 1	08C	+19.01	TECTEH			S8982	seco	22H00020	H	600UL	340911
4642			2.23	183	DNG	P 1	05C	+16.09	TECTEH			S8982	seco	22H00020	H	600UL	340911
4643	111	111	44.73	178	DNT	P 1	09H	+0.15	TECTEH			S8982	seco	22H00021	H	600UL	340830
4644			3.36	174	DNG	P 1	VM	+22.76	TECTEH			S8982	seco	22H00021	H	600UL	340830
4645			5.52	181	DNG	P 1	VM	+28.79	TECTEH			N5432	reso	22H00021	H	600UL	340830
4646			4.31	181	DNG	P 1	VM	+29.35	TECTEH			N5432	reso	22H00021	H	600UL	340830
4647					INF		VC	-3.17	TECTEH	HR		N5432	reso	22H00021	H	600UL	340830
4648					INF		VC	-2.59	TECTEH	HR		N5432	reso	22H00021	H	600UL	340830
[illegible]			1.95	88	MBM	6	07C	+10.17	TECTEH			N5432	reso	22H00021	H	600UL	340830
	115	111	6.29	181	DNT	P 1	09H	-0.21	TECTEH			S8982	seco	22H00021	H	600UL	340830
4651	117	111	36.79	183	DNT	P 1	10H	+0.00	TECTEH			S8982	seco	22H00020	H	600UL	340911
4652			3.15	185	DNT	P 1	10C	-0.44	TECTEH			S8982	seco	22H00020	H	600UL	340911
4653			4.17	181	DNT	P 1	10C	+0.39	TECTEH			S8982	seco	22H00020	H	600UL	340911
4654			0.79	102	MBM	5	05C	+7.15	TECTEH			F6623	reso	22H00020	H	600UL	340911

4655	119	111	4.06	177	DNG	P 1	07H	+21.81	TECTEH				S8982	seco	22H00021	H	600UL	340830

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 96

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4656			2.06	176	DNG	P 1	09H	+13.54	TECTEH			S8982	seco	22H00021	H	600UL	340830
4657			2.10	177	DNG	P 1	VH	+2.86	TECTEH			S8982	seco	22H00021	H	600UL	340830
4658	121	111	2.45	182	DNG	P 1	10C	+3.36	TECTEH			S8982	seco	22H00020	H	600UL	340911
4659			2.31	29	NRC	2	TSC	+0.00	TECTEH			M1680	reso	22H00020	H	600UL	340911
4660	123	111	2.91	181	DNT	P 1	09H	-0.15	TECTEH			S8982	seco	22H00021	H	600UL	340830
4661			3.01	176	DNG	P 1	09H	+17.96	TECTEH			S8982	seco	22H00021	H	600UL	340830
4662	125	111	4.18	182	DNT	P 1	10H	-0.32	TECTEH			S8982	seco	22H00020	H	600UL	340911
4663			2.30	184	DNT	P 1	10H	+0.56	TECTEH			S8982	seco	22H00020	H	600UL	340911
4664	127	111	2.46	171	DNT	P 1	10C	+0.31	TECTEH			S8982	seco	22H00021	H	600UL	340830
4665	129	111	2.31	169	DNT	P 1	09H	-0.38	TECTEH			F6623	reso	22H00020	H	600UL	340911
4666					NDF		09H	-0.38	09H09H			M7007	prim	22H00203	H	600PP	345330
4667			1.97	165	DNI	P 1	09H	-0.38	TECTEH	2.31		F6623	reso	22H00020	H	600UL	340911
4668			4.48	184	DNT	P 1	09H	+0.39	TECTEH			S8982	seco	22H00020	H	600UL	340911
4669			5.97	184	DNT	P 1	09C	+0.44	TECTEH			S8982	seco	22H00020	H	600UL	340911
4670	131	111	2.53	170	DNT	P 1	09H	-0.47	TECTEH			S8982	seco	22H00021	H	600UL	340830
4671			13.95	174	DNT	P 1	09H	+0.27	TECTEH			S8982	seco	22H00021	H	600UL	340830
4672	133	111	5.58	180	DNG	P 1	08H	+20.62	TECTEH			A6997	seco	22H00093	H	600UL	340929
			2.85	185	DNT	P 1	09H	-0.55	TECTEH			F3453	reso	22H00093	H	600UL	340929
			3.10	176	DNT	P 1	09H	+0.38	TECTEH			A6997	seco	22H00093	H	600UL	340929
4675			3.68	181	DNG	P 1	09H	+5.72	TECTEH			A6997	seco	22H00093	H	600UL	340929
4676			2.04	178	DNG	P 1	09H	+8.99	TECTEH			A6997	seco	22H00093	H	600UL	340929
4677			7.68	181	DNG	P 1	09H	+13.51	TECTEH			A6997	seco	22H00093	H	600UL	340929
4678			2.39	182	DNG	P 1	01C	+5.68	TECTEH			A6997	seco	22H00093	H	600UL	340929
4679	20	112	2.61	180	DNG	P 1	TSH	+16.29	TECTEH			S8982	seco	22H00059	H	600UL	340948
4680	22	112	5.97	181	DNG	P 1	06C	+9.01	TECTEH			D3858	reso	22H00060	H	600UL	340830
4681	28	112	0.77	64	MBM	5	01H	+12.02	TECTEH			N5432	reso	22H00059	H	600UL	340948
4682			0.68	75	MBM	5	01H	+16.54	TECTEH			N5432	reso	22H00059	H	600UL	340948
4683			1.81	89	MBM	5	03H	+6.62	TECTEH			N5432	reso	22H00059	H	600UL	340948
4684			0.71	52	MBM	6	03H	+7.63	TECTEH			N5432	reso	22H00059	H	600UL	340948
4685	30	112			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
4686			0.22	133	PID	4	TSH	+0.40	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4687			0.17	104	MAI	2	TSH	+0.40	TSHTSH	0.2		C3340	reso	22H00189	H	600PP	345298
4688			0.13	142	MAI	1	TSH	+0.40	TSHTSH	0.1		D8661	reso	22H00189	H	600PP	345298
4689			2.51	181	DNG	P 1	01H	+23.58	TECTEH			F7467	seco	22H00060	H	600UL	340830
4690			3.28	185	DNG	P 1	02H	+34.01	TECTEH			S4373	reso	22H00060	H	600UL	340830
4691	32	112	4.33	182	DNG	P 1	VM	+2.47	TECTEH			S8982	seco	22H00059	H	600UL	340948
4692			9.27	180	DNG	P 1	TSC	+7.39	TECTEH			S8982	seco	22H00059	H	600UL	340948
4693	38	112			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4694			0.19	118	PID	4	TSH	+0.33	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4695			0.00	0	SAI	1	TSH	+0.33	TSHTSH	0.0		A9608	reso	22H00188	H	600PP	345326
4696			0.20	89	SAI	2	TSH	+0.33	TSHTSH	0.2		A9608	reso	22H00188	H	600PP	345326
4697			12.29	179	DNT	P 1	VM	+1.99	TECTEH			A9574	seco	22H00064	H	600UL	340930
[illegible]	40	112	3.85	184	DNT	P 1	DC	-0.36	TECTEH			I3805	seco	22H00063	H	600UL	340948
	58	112			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4700			0.12	102	SAI	2	TSH	+0.57	TSHTSH	0.2		F6623	reso	22H00178	H	600PP	345329
4701			0.17	50	SAI	1	TSH	+0.57	TSHTSH	0.2		F6623	reso	22H00178	H	600PP	345329
4702			0.14	119	PID	4	TSH	+0.57	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4703	72	112	2.15	181	DNG	P 1	03H	+11.99	TECTEH			O8795	seco	22H00040	H	600UL	331892

4704	74	112	2.79	176	DNG	P 1	03H	+20.18	TECTEH				I3805	seco	22H00041	H	600UL	340830

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 97

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4705			2.96	178	DNG	P 1	04C	+2.75	TECTEH			I3805	seco	22H00041	H	600UL	340830
4706			2.30	177	DNG	P 1	03C	+11.77	TECTEH			I3805	seco	22H00041	H	600UL	340830
4707	78	112	0.47	93	MBM	5	04H	+23.44	TECTEH			C3340	reso	22H00041	H	600UL	340830
4708	80	112	0.53	65	MBM	5	06C	+20.64	TECTEH			F6623	reso	22H00040	H	600UL	331892
4709	86	112	2.03	184	DNG	P 1	04C	+13.02	TECTEH			F6623	reso	22H00040	H	600UL	331892
4710	88	112	0.51	94	MBM	5	03H	+13.08	TECTEH			C3340	reso	22H00041	H	600UL	340830
4711			0.69	71	MBM	5	01C	+7.38	TECTEH			C3340	reso	22H00041	H	600UL	340830
4712	90	112	0.54	84	MBM	5	03H	+36.47	TECTEH			F6623	reso	22H00040	H	600UL	331892
4713			0.70	82	MBM	5	VH	+16.00	TECTEH			F6623	reso	22H00040	H	600UL	331892
4714	92	112	2.89	184	DNT	P 1	08C	-0.39	TECTEH			S8982	seco	22H00020	H	600UL	340911
4715	94	112	4.19	178	DNT	P 1	06H	-0.26	TECTEH			S8982	seco	22H00021	H	600UL	340830
4716	96	112	0.56	91	MBM	5	02H	+34.75	TECTEH			F6623	reso	22H00020	H	600UL	340911
4717	108	112	1.66	94	MBM	5	04H	+13.94	TECTEH			F6623	reso	22H00020	H	600UL	340911
4718			1.32	87	MBM	5	04H	+18.95	TECTEH			F6623	reso	22H00020	H	600UL	340911
4719			0.41	66	MBM	5	04H	+19.47	TECTEH			F6623	reso	22H00020	H	600UL	340911
4720			0.87	115	MBM	5	05H	+29.61	TECTEH			F6623	reso	22H00020	H	600UL	340911
4721			2.42	180	DNG	P 1	07H	+21.92	TECTEH			S8982	seco	22H00020	H	600UL	340911
			0.90	103	MBM	5	09C	+4.89	TECTEH			F6623	reso	22H00020	H	600UL	340911
[illegible]	110	112	4.26	177	DNT	P 1	VC	-1.70	TECTEH			S8982	seco	22H00021	H	600UL	340830
4724	112	112	2.52	179	DNG	P 1	VC	+3.01	TECTEH			S8982	seco	22H00020	H	600UL	340911
4725			2.21	181	DNG	P 1	VC	+7.78	TECTEH			S8982	seco	22H00020	H	600UL	340911
4726	114	112	0.38	79	MBM	6	02H	+7.67	TECTEH			N5432	reso	22H00021	H	600UL	340830
4727			2.36	177	DNG	P 1	VC	+2.80	TECTEH			S8982	seco	22H00021	H	600UL	340830
4728	120	112	5.11	179	DNG	P 1	TSC	+31.31	TECTEH			S8982	seco	22H00020	H	600UL	340911
4729	124	112	3.30	181	DNT	P 1	10H	-0.02	TECTEH			S8982	seco	22H00020	H	600UL	340911
4730	126	112	8.74	181	DNT	P 1	09H	+0.09	TECTEH			S8982	seco	22H00021	H	600UL	340830
4731	128	112	2.59	183	DNT	P 1	09H	-0.44	TECTEH			S8982	seco	22H00020	H	600UL	340911
4732			6.37	182	DNT	P 1	09H	+0.41	TECTEH			S8982	seco	22H00020	H	600UL	340911
4733					NDF		09H	+0.41	09H09H			M7007	prim	22H00203	H	600PP	345330
4734			4.67	182	DNG	P 1	09H	+1.28	TECTEH			S8982	seco	22H00020	H	600UL	340911
4735			2.62	179	DNG	P 1	VC	+2.74	TECTEH			S8982	seco	22H00020	H	600UL	340911
4736			4.02	188	DNT	P 1	09C	+0.38	TECTEH			S8982	seco	22H00020	H	600UL	340911
4737			3.31	181	DNG	P 1	02C	+1.39	TECTEH			S4373	reso	22H00020	H	600UL	340911
4738	130	112	3.84	170	DNT	P 1	09H	+0.38	TECTEH			S8982	seco	22H00021	H	600UL	340830
4739			4.57	176	DNG	P 1	09H	+1.10	TECTEH			S4373	reso	22H00021	H	600UL	340830
4740			1.78	177	INR	P 1	09H	+11.50	TECTEH			S8982	seco	22H00021	H	600UL	340830
4741			2.37	175	DNG	P 1	09H	+12.21	TECTEH			S8982	seco	22H00021	H	600UL	340830
4742			6.33	176	DNG	P 1	09H	+13.64	TECTEH			S8982	seco	22H00021	H	600UL	340830
4743			1.93	193	INR	P 1	10H	+0.61	TECTEH			S4373	reso	22H00021	H	600UL	340830
4744	132	112	3.33	189	DNT	P 1	09H	-0.53	TECTEH			F3453	reso	22H00093	H	600UL	340929
4745			6.22	184	DNT	P 1	09H	+0.36	TECTEH			F3453	reso	22H00093	H	600UL	340929
4746	1	113			PSP				06CTEC			D3858	reso	22C00067	C	600CS	341611
[illegible]					PSP				06HTEH			D3858	reso	22H00105	H	600UL	340824
					TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
4749			1.99	85	PID	8	TSC	+0.00	01CTEC			C3340	reso	22C00108	C	600UL	332244
4750	37	113			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4751			0.16	115	PID	4	TSH	+0.94	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4752			0.00	0	SAI	1	TSH	+0.94	TSHTSH	0.0		A9608	reso	22H00188	H	600PP	345326

4753			0.14	104	SAI	2	TSH	+0.94	TSHTSH	0.2			A9608	reso	22H00188	H	600PP	345326

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 98

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4754		0.00	0	SAI	1	TSH	+1.08	TSHTSH	0.0		A9608	reso	22H00188	H	600PP	345326
4755		0.13	88	SAI	2	TSH	+1.08	TSHTSH	0.2		A9608	reso	22H00188	H	600PP	345326
4756	39	113		TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4757		0.35	111	NQI	P 1	TSH	+0.52	TECTEH			A9574	seco	22H00064	H	600UL	340930
4758		0.20	99	PID	4	TSH	+0.92	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4759		0.20	98	SAI	2	TSH	+0.92	TSHTSH	0.2		D8661	reso	22H00189	H	600PP	345298
4760		0.17	109	SAI	1	TSH	+0.92	TSHTSH	0.1		D8661	reso	22H00189	H	600PP	345298
4761	41	113	5.01	185	DNG	P 1	VM	+13.59	TECTEH		I3805	seco	22H00063	H	600UL	340948
4762	59	113	7.75	183	DNT	P 1	06H	+0.41	TECTEH		D3858	reso	22H00060	H	600UL	340830
4763	83	113	0.56	67	MBM	5	02H	+15.72	TECTEH		L2157	reso	22H00034	H	600UL	331892
4764	87	113	2.72	185	DNT	P 1	06H	-0.53	TECTEH		N5877	seco	22H00034	H	600UL	331892
4765	91	113	1.07	78	MBM	5	02H	+7.65	TECTEH		F6623	reso	22H00020	H	600UL	340911
4766	93	113	0.57	70	MBM	5	VH	+26.44	TECTEH		F6623	reso	22H00020	H	600UL	340911
4767	95	113	0.59	91	INR	6	TSH	+23.94	TECTEH		J9815	prim	22H00021	H	600UL	340830
4768	99	113	3.04	176	DNG	P 1	08C	+7.24	TECTEH		S8982	seco	22H00021	H	600UL	340830
4769	103	113	2.54	176	DNG	P 1	09C	-0.88	TECTEH		S4373	reso	22H00021	H	600UL	340830
4770			3.66	173	DNT	P 1	09C	+0.35	TECTEH		S8982	seco	22H00021	H	600UL	340830
	105	113	8.57	184	DNT	P 1	09H	-0.02	TECTEH		S8982	seco	22H00020	H	600UL	340911
[illegible]	111	113	5.50	181	DNT	P 1	09H	-0.24	TECTEH		S8982	seco	22H00021	H	600UL	340830
4773			19.38	177	DNG	P 1	VM	+29.10	TECTEH		S8982	seco	22H00021	H	600UL	340830
4774			2.21	176	DNG	P 1	08C	+12.28	TECTEH		S8982	seco	22H00021	H	600UL	340830
4775	113	113	0.60	110	MBM	5	06C	+2.49	TECTEH		F6623	reso	22H00020	H	600UL	340911
4776	117	113	2.64	182	DNG	P 1	VH	+2.91	TECTEH		F6623	reso	22H00020	H	600UL	340911
4777			2.43	183	DNT	P 1	10C	-0.46	TECTEH		S8982	seco	22H00020	H	600UL	340911
4778			7.07	184	DNT	P 1	10C	+0.35	TECTEH		S8982	seco	22H00020	H	600UL	340911
4779	119	113	2.02	177	DNG	P 1	09H	-0.84	TECTEH		S4373	reso	22H00021	H	600UL	340830
4780			2.46	175	DNG	P 1	09H	+3.03	TECTEH		S8982	seco	22H00021	H	600UL	340830
4781			4.32	176	DNG	P 1	09H	+5.34	TECTEH		S8982	seco	22H00021	H	600UL	340830
4782			5.31	177	DNG	P 1	09H	+5.82	TECTEH		S8982	seco	22H00021	H	600UL	340830
4783			3.29	175	DNG	P 1	09H	+7.58	TECTEH		S8982	seco	22H00021	H	600UL	340830
4784			6.06	176	DNG	P 1	09H	+8.95	TECTEH		S8982	seco	22H00021	H	600UL	340830
4785			1.10	69	MBM	5	VM	+14.06	TECTEH		N5432	reso	22H00021	H	600UL	340830
4786			2.40	190	DNT	P 1	10C	-0.51	TECTEH		S8982	seco	22H00021	H	600UL	340830
4787			4.48	172	DNT	P 1	10C	+0.39	TECTEH		S8982	seco	22H00021	H	600UL	340830
4788			4.57	177	DNG	P 1	09C	+2.63	TECTEH		S8982	seco	22H00021	H	600UL	340830
4789	121	113	2.24	184	DNT	P 1	10H	-0.05	TECTEH		S8982	seco	22H00020	H	600UL	340911
4790			5.56	181	DNG	P 1	VM	+29.34	TECTEH		S8982	seco	22H00020	H	600UL	340911
4791			8.63	180	DNT	P 1	VC	+1.97	TECTEH		S8982	seco	22H00020	H	600UL	340911
4792			2.38	35	NRC	2	TSC	+0.00	TECTEH		M1680	reso	22H00020	H	600UL	340911
4793	123	113	0.43	54	MBM	5	05H	+9.61	TECTEH		N5432	reso	22H00021	H	600UL	340830
4794			4.53	177	DNT	P 1	VC	+2.08	TECTEH		S8982	seco	22H00021	H	600UL	340830
4795					INF		TSC	+34.92	TECTEH	HR	M1680	reso	22H00021	H	600UL	340830
[illegible]			0.91	35	MBM	6	TSC	+36.53	TECTEH		N5432	reso	22H00021	H	600UL	340830
	125	113	2.20	180	DNG	P 1	VC	+3.52	TECTEH		S8982	seco	22H00020	H	600UL	340911
4798	127	113			INF		09H	+0.53	TECTEH	HR	M1680	reso	22H00021	H	600UL	340830
4799	129	113	4.17	188	DNT	P 1	09H	+0.41	TECTEH		S8982	seco	22H00020	H	600UL	340911
4800			2.02	183	DNG	P 1	VH	+3.05	TECTEH		S8982	seco	22H00020	H	600UL	340911
4801			3.15	192	DNT	P 1	09C	+0.44	TECTEH		S8982	seco	22H00020	H	600UL	340911

4802	131	113	8.67	176	DNT	P	1	09H	+0.47	TECTEH				S8982	seco	22H00021	H	600UL	340830

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 99

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4803	12	114	13.63	181	DNG	P	1	06C +8.01	TECTEH			S8982	seco	22H00059	H	600UL	340948
4804	18	114			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
4805			0.00	0	SAI	1	TSH	+0.29	TSHTSH	0.0		A9608	reso	22H00188	H	600PP	345326
4806			0.12	74	SAI	2	TSH	+0.29	TSHTSH	0.2		A9608	reso	22H00188	H	600PP	345326
4807			0.14	140	PID	4	TSH	+0.29	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4808	38	114	4.62	183	DNG	P	1	07H +1.99	TECTEH			S8982	seco	22H00059	H	600UL	340948
4809			28.16	178	DNT	P	1	VM -0.99	TECTEH			S8982	seco	22H00059	H	600UL	340948
4810	42	114	3.67	182	DNG	P	1	02H +11.41	TECTEH			I3805	seco	22H00063	H	600UL	340948
4811	48	114	4.60	181	DNG	P	1	04H +37.21	TECTEH			A9574	seco	22H00064	H	600UL	340930
4812	52	114	4.78	181	DNG	P	1	07H +6.01	TECTEH			I3805	seco	22H00063	H	600UL	340948
4813	68	114	4.37	180	DNG	P	1	VM +10.59	TECTEH			S8982	seco	22H00059	H	600UL	340948
4814			6.77	183	DNG	P	1	07C +14.13	TECTEH			S8982	seco	22H00059	H	600UL	340948
4815			8.61	180	DNG	P	1	07C +16.45	TECTEH			S8982	seco	22H00059	H	600UL	340948
4816	82	114	0.59	117	INR	6		06C +5.04	TECTEH			F6623	reso	22H00040	H	600UL	331892
4817	88	114	1.12	78	MBM	6		VH +17.70	TECTEH			L2157	reso	22H00034	H	600UL	331892
4818	90	114	0.40	69	MBM	5		TSH +27.92	TECTEH			N5432	reso	22H00035	H	600UL	340830
4819	92	114	5.42	183	DNG	P	1	08H +13.80	TECTEH			S8982	seco	22H00020	H	600UL	340911
			2.60	181	DNG	P	1	08H +16.32	TECTEH			S8982	seco	22H00020	H	600UL	340911
			7.57	183	DNG	P	1	08H +17.42	TECTEH			S8982	seco	22H00020	H	600UL	340911
4822			3.15	184	DNG	P	1	08C +2.24	TECTEH			S8982	seco	22H00020	H	600UL	340911
4823	112	114	4.31	185	DNG	P	1	VM -2.98	TECTEH			S8982	seco	22H00020	H	600UL	340911
4824	120	114	3.39	182	DNG	P	1	08H +5.96	TECTEH			S8982	seco	22H00020	H	600UL	340911
4825			2.25	183	DNG	P	1	08H +8.18	TECTEH			S8982	seco	22H00020	H	600UL	340911
4826			7.03	182	DNG	P	1	08H +13.97	TECTEH			S8982	seco	22H00020	H	600UL	340911
4827			4.50	182	DNG	P	1	08H +17.61	TECTEH			S8982	seco	22H00020	H	600UL	340911
4828			3.06	182	DNG	P	1	09H +0.85	TECTEH			S4373	reso	22H00020	H	600UL	340911
4829			3.11	183	DNG	P	1	09H +4.08	TECTEH			S8982	seco	22H00020	H	600UL	340911
4830			2.51	181	DNG	P	1	TSC +8.82	TECTEH			S8982	seco	22H00020	H	600UL	340911
4831	122	114	2.97	176	DNG	P	1	03C +6.81	TECTEH			S8982	seco	22H00021	H	600UL	340830
4832	124	114	5.92	184	DNT	P	1	09H +0.11	TECTEH			S8982	seco	22H00020	H	600UL	340911
4833			4.36	182	DNG	P	1	VC +2.79	TECTEH			S8982	seco	22H00020	H	600UL	340911
4834	126	114	0.63	95	INR	6		02C +37.04	TECTEH			J9815	prim	22H00021	H	600UL	340830
4835			0.64	80	MBM	6		01C +33.70	TECTEH			N5432	reso	22H00021	H	600UL	340830
4836	128	114	2.71	186	DNT	P	1	09H +0.39	TECTEH			S8982	seco	22H00020	H	600UL	340911
4837			9.36	184	DNT	P	1	10H -0.02	TECTEH			S8982	seco	22H00020	H	600UL	340911
4838			2.82	181	DNT	P	1	10C +0.28	TECTEH			S8982	seco	22H00020	H	600UL	340911
4839			3.36	190	DNT	P	1	09C +0.42	TECTEH			S8982	seco	22H00020	H	600UL	340911
4840	130	114	4.85	176	DNT	P	1	09H +0.47	TECTEH			S8982	seco	22H00021	H	600UL	340830
4841	21	115	3.04	182	DNT	P	1	06H +0.41	TECTEH			D3858	reso	22H00060	H	600UL	340830
4842	51	115			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4843			0.33	21	PID	P	1	TSH +0.01	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4844			0.13	19	SCI	P	1	TSH +0.01	TSHTSH	0.2	PWSCC	D8661	reso	22H00189	H	600PP	345298
[illegible]			0.00	0	SCI	1		TSH +0.01	TSHTSH	0.0	PWSCC	D8661	reso	22H00189	H	600PP	345298
	57	115	2.06	177	DNG	P	1	04H +10.57	TECTEH			D3858	reso	22H00060	H	600UL	340830
4847			2.64	184	DNG	P	1	05H +31.44	TECTEH			F7467	seco	22H00060	H	600UL	340830
4848			12.11	180	DNT	P	1	06H +1.19	TECTEH			F7467	seco	22H00060	H	600UL	340830
4849			2.58	177	DNG	P	1	06H +7.29	TECTEH			F7467	seco	22H00060	H	600UL	340830
4850	73	115	2.60	180	DNG	P	1	06H +15.04	TECTEH			N5877	seco	22H00034	H	600UL	331892

4851	91	115	8.76	184	DNG	P 1	08H	+4.45	TECTEH			S8982	seco	22H00020	H	600UL	340911

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 100

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4852			6.67	188	DNG	P 1	08H	+5.24	TECTEH			F6623	reso	22H00020	H	600UL	340911
4853	93	115	5.06	183	DNG	P 1	07H	+16.37	TECTEH			S8982	seco	22H00020	H	600UL	340911
4854			3.31	181	DNG	P 1	08H	+3.15	TECTEH			S8982	seco	22H00020	H	600UL	340911
4855			2.73	182	DNG	P 1	08H	+4.74	TECTEH			S8982	seco	22H00020	H	600UL	340911
4856			6.74	182	DNG	P 1	08H	+5.75	TECTEH			S8982	seco	22H00020	H	600UL	340911
4857			3.55	181	DNG	P 1	08H	+6.11	TECTEH			S8982	seco	22H00020	H	600UL	340911
4858			21.07	185	DNG	P 1	08H	+6.93	TECTEH			F6623	reso	22H00020	H	600UL	340911
4859			4.48	185	DNG	P 1	08H	+7.81	TECTEH			S8982	seco	22H00020	H	600UL	340911
4860			5.78	185	DNT	P 1	09H	+0.11	TECTEH			S8982	seco	22H00020	H	600UL	340911
4861			4.88	188	DNT	P 1	09C	-0.43	TECTEH			S8982	seco	22H00020	H	600UL	340911
4862			6.64	184	DNT	P 1	09C	-0.06	TECTEH			S8982	seco	22H00020	H	600UL	340911
4863					OBS		09C	+0.00	09C09C			M7007	prim	22C00087	C	600PP	345298
4864			5.34	187	DNT	P 1	09C	+0.42	TECTEH			S8982	seco	22H00020	H	600UL	340911
4865			55.96	183	DNT	P 1	09C	+0.70	TECTEH			D3858	reso	22H00020	H	600UL	340911
4866					NDF		09C	+0.70	09C09C			M7007	prim	22C00088	C	500DP	344850
4867			3.67	183	DNG	P 1	09C	+1.61	TECTEH			S4373	reso	22H00020	H	600UL	340911
4868			9.84	183	DNG	P 1	08C	+1.77	TECTEH			S8982	seco	22H00020	H	600UL	340911
			4.72	183	DNG	P 1	08C	+2.75	TECTEH			S8982	seco	22H00020	H	600UL	340911
[illegible]			10.20	183	DNG	P 1	08C	+3.90	TECTEH			S8982	seco	22H00020	H	600UL	340911
4871			1.95	181	INR	P 1	08C	+8.32	TECTEH			F6623	reso	22H00020	H	600UL	340911
4872			9.52	182	DNG	P 1	08C	+8.44	TECTEH			S8982	seco	22H00020	H	600UL	340911
4873	97	115	0.49	68	MBM	5	01C	+23.70	TECTEH			N5432	reso	22H00021	H	600UL	340830
4874	103	115	0.74	80	MBM	5	05H	+25.70	TECTEH			F6623	reso	22H00020	H	600UL	340911
4875			1.31	85	MBM	5	05H	+32.60	TECTEH			F6623	reso	22H00020	H	600UL	340911
4876			0.67	100	MBM	5	06H	+3.85	TECTEH			F6623	reso	22H00020	H	600UL	340911
4877			0.69	100	MBM	5	06H	+8.96	TECTEH			F6623	reso	22H00020	H	600UL	340911
4878			0.62	94	MBM	5	06H	+14.18	TECTEH			F6623	reso	22H00020	H	600UL	340911
4879			0.80	91	MBM	5	08H	+3.86	TECTEH			F6623	reso	22H00020	H	600UL	340911
4880	105	115	1.82	177	INR	P 1	09H	+11.81	TECTEH			S8982	seco	22H00021	H	600UL	340830
4881			6.14	177	DNG	P 1	08C	+7.44	TECTEH			S8982	seco	22H00021	H	600UL	340830
4882			2.10	175	DNG	P 1	08C	+16.26	TECTEH			S8982	seco	22H00021	H	600UL	340830
4883	111	115	0.29	55	INR	P 1	TSH	+2.56	TECTEH			F6623	reso	22H00020	H	600UL	340911
4884			2.74	181	DNG	P 1	VH	+2.65	TECTEH			S8982	seco	22H00020	H	600UL	340911
4885	113	115	2.15	181	DNG	P 1	05H	+23.27	TECTEH			S8982	seco	22H00021	H	600UL	340830
4886	115	115	0.50	94	MBM	5	01H	+13.92	TECTEH			F6623	reso	22H00020	H	600UL	340911
4887			0.52	101	MBM	5	06H	+10.77	TECTEH			F6623	reso	22H00020	H	600UL	340911
4888	117	115	5.40	175	DNT	P 1	10C	+0.34	TECTEH			S8982	seco	22H00021	H	600UL	340830
4889	119	115	2.69	181	DNG	P 1	08H	+16.02	TECTEH			S8982	seco	22H00020	H	600UL	340911
4890			3.49	181	DNG	P 1	08H	+18.92	TECTEH			S8982	seco	22H00020	H	600UL	340911
4891			3.98	181	DNG	P 1	08H	+20.76	TECTEH			S8982	seco	22H00020	H	600UL	340911
4892			3.98	184	DNG	P 1	09H	-1.64	TECTEH			S8982	seco	22H00020	H	600UL	340911
4893			3.18	180	DNG	P 1	09H	+1.34	TECTEH			S8982	seco	22H00020	H	600UL	340911
[illegible]			2.39	189	INR	P 1	VM	+2.04	TECTEH			F6623	reso	22H00020	H	600UL	340911
			4.23	188	INR	P 1	VM	+3.45	TECTEH			F6623	reso	22H00020	H	600UL	340911
4896			5.66	187	INR	P 1	VM	+4.76	TECTEH			F6623	reso	22H00020	H	600UL	340911
4897			4.83	188	INR	P 1	VM	+5.92	TECTEH			F6623	reso	22H00020	H	600UL	340911
4898			3.06	183	DNG	P 1	09C	+5.32	TECTEH			S8982	seco	22H00020	H	600UL	340911
4899			0.43	62	MBM	5	03C	+6.14	TECTEH			F6623	reso	22H00020	H	600UL	340911

4900	121	115	2.21	182	DNT	P 1	10H	-0.02	TECTEH				S8982	seco	22H00021	H	600UL	340830

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 101

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4901			2.07	173	DNG	P 1	10C	+2.35	TECTEH			S8982	seco	22H00021	H	600UL	340830
4902			0.78	69	MBM	5	05C	+2.05	TECTEH			N5432	reso	22H00021	H	600UL	340830
4903			3.77	22	NRC	2	TSC	+0.00	TECTEH			J9815	prim	22H00021	H	600UL	340830
4904	123	115	2.71	182	DNG	P 1	10C	+4.71	TECTEH			S8982	seco	22H00020	H	600UL	340911
4905	127	115	2.80	181	DNG	P 1	08H	+8.25	TECTEH			S8982	seco	22H00020	H	600UL	340911
4906			2.56	181	DNG	P 1	09H	+9.24	TECTEH			S8982	seco	22H00020	H	600UL	340911
4907			2.02	182	DNG	P 1	09H	+10.21	TECTEH			S8982	seco	22H00020	H	600UL	340911
4908			3.18	182	DNG	P 1	09H	+15.56	TECTEH			S8982	seco	22H00020	H	600UL	340911
4909	129	115	3.84	173	DNT	P 1	09H	+0.47	TECTEH			S8982	seco	22H00021	H	600UL	340830
4910			3.24	183	DNT	P 1	10H	-0.02	TECTEH			S8982	seco	22H00021	H	600UL	340830
4911	18	116	7.57	179	DNG	P 1	06C	+10.46	TECTEH			D3858	reso	22H00056	H	600UL	340830
4912			1.30	78	MBM	5	TSC	+36.83	TECTEH			D3858	reso	22H00056	H	600UL	340830
4913	22	116	4.31	181	DNT	P 1	06H	+0.31	TECTEH			D3858	reso	22H00056	H	600UL	340830
4914	36	116			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4915			0.51	23	SCI	1	TSH	-0.02	TSHTSH	0.3	PWSCC	A9608	reso	22H00188	H	600PP	345326
4916			0.30	28	SCI	P 1	TSH	-0.02	TSHTSH	0.3	PWSCC	A9608	reso	22H00188	H	600PP	345326
4917			0.60	26	PID	P 1	TSH	-0.02	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
	38	116	5.64	181	DNT	P 1	VM	+1.08	TECTEH			D3858	reso	22H00056	H	600UL	340830
[illegible]	44	116	16.31	179	DNG	P 1	04C	+5.88	TECTEH			S8982	seco	22H00055	H	600UL	340948
4920	58	116	2.14	179	DNG	P 1	05H	+2.69	TECTEH			F7467	seco	22H00060	H	600UL	340830
4921			2.38	179	DNG	P 1	05H	+3.34	TECTEH			F7467	seco	22H00060	H	600UL	340830
4922	76	116	0.44	82	MBM	5	TSH	+14.74	TECTEH			N5432	reso	22H00035	H	600UL	340830
4923	82	116			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
4924			0.27	108	MCI	P 1	TSH	+0.10	TSHTSH	0.4		F6623	reso	22H00178	H	600PP	345329
4925			0.32	58	MCI	1	TSH	+0.10	TSHTSH	0.4		F6623	reso	22H00178	H	600PP	345329
4926			0.21	86	PID	P 1	TSH	+0.10	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
4927	100	116	38.26	186	DNT	P 1	09H	-0.02	TECTEH			S8982	seco	22H00020	H	600UL	340911
4928	104	116	12.60	183	DNG	P 1	08H	+19.29	TECTEH			S8982	seco	22H00020	H	600UL	340911
4929			14.71	184	DNT	P 1	09H	+0.41	TECTEH			S8982	seco	22H00020	H	600UL	340911
4930			3.96	185	DNT	P 1	09C	-0.54	TECTEH			S8982	seco	22H00020	H	600UL	340911
4931			2.87	183	DNT	P 1	09C	+0.04	TECTEH			S8982	seco	22H00020	H	600UL	340911
4932			5.44	185	DNT	P 1	09C	+0.69	TECTEH			S8982	seco	22H00020	H	600UL	340911
4933			20.36	186	DNG	P 1	09C	+1.08	TECTEH			S4373	reso	22H00020	H	600UL	340911
4934			2.63	183	DNG	P 1	08C	+13.98	TECTEH			S8982	seco	22H00020	H	600UL	340911
4935			11.91	183	DNG	P 1	08C	+16.27	TECTEH			S8982	seco	22H00020	H	600UL	340911
4936			10.62	183	DNG	P 1	08C	+17.17	TECTEH			S8982	seco	22H00020	H	600UL	340911
4937			3.39	181	DNG	P 1	08C	+19.18	TECTEH			S8982	seco	22H00020	H	600UL	340911
4938			3.96	184	DNG	P 1	08C	+20.61	TECTEH			S8982	seco	22H00020	H	600UL	340911
4939			2.87	180	DNG	P 1	08C	+21.18	TECTEH			S8982	seco	22H00020	H	600UL	340911
4940	106	116	3.00	177	DNG	P 1	07H	+14.99	TECTEH			S8982	seco	22H00021	H	600UL	340830
4941			2.39	174	DNT	P 1	09H	-0.15	TECTEH			S8982	seco	22H00021	H	600UL	340830
4942			4.91	177	DNT	P 1	09H	+0.69	TECTEH			S8982	seco	22H00021	H	600UL	340830
[illegible]			2.96	178	DNG	P 1	08C	+9.23	TECTEH			S8982	seco	22H00021	H	600UL	340830
			2.73	177	DNG	P 1	08C	+13.40	TECTEH			S8982	seco	22H00021	H	600UL	340830
4945			2.92	177	DNG	P 1	08C	+17.06	TECTEH			S8982	seco	22H00021	H	600UL	340830
4946	110	116	38.23	180	DNT	P 1	09H	-0.02	TECTEH			S8982	seco	22H00021	H	600UL	340830
4947	112	116	4.82	184	DNG	P 1	09C	+14.96	TECTEH			S8982	seco	22H00020	H	600UL	340911
4948			2.29	183	DNG	P 1	08C	+13.36	TECTEH			S8982	seco	22H00020	H	600UL	340911

4949	116	116	0.63	74	MBM	5	05C	+13.74	TECTEH				F6623	reso	22H00020	H	600UL	340911

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 102

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4950	120	116	0.92	93	MBM	5	06H	+10.96	TECTEH			F6623	reso	22H00020	H	600UL	340911
4951	122	116	2.09	178	DNG	P 1	10C	+4.42	TECTEH			S8982	seco	22H00021	H	600UL	340830
4952	124	116	5.71	184	DNT	P 1	09H	-0.11	TECTEH			S8982	seco	22H00020	H	600UL	340911
4953					NDF		09H	-0.11	09H09H			M7007	prim	22H00203	H	600PP	345330
4954			2.22	183	DNT	P 1	10H	+0.44	TECTEH			S8982	seco	22H00020	H	600UL	340911
4955	126	116	2.77	169	DNT	P 1	10H	+0.32	TECTEH			S8982	seco	22H00021	H	600UL	340830
4956	128	116	3.39	186	DNG	P 1	TSH	+19.55	TECTEH			S8982	seco	22H00020	H	600UL	340911
4957	9	117	13.62	183	DNG	P 1	06C	+6.12	TECTEH			S8982	seco	22H00055	H	600UL	340948
4958	31	117			NDF		TSH	+37.43	TSH01H			N2574	seco	22H00207	H	600PP	345329
4959			0.90	21	NQI	P 1	TSH	+37.43	TECTEH			D3858	reso	22H00056	H	600UL	340830
4960	35	117			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
4961			0.00	134	SAI	1	TSH	+0.49	TSHTSH	0.0		A9608	reso	22H00188	H	600PP	345326
4962			0.12	121	PID	4	TSH	+0.49	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
4963			0.11	93	SAI	2	TSH	+0.49	TSHTSH	0.4		A9608	reso	22H00188	H	600PP	345326
4964	39	117	0.60	0	IDM	2	TSH	+1.32	TSHTSH			A9574	seco	22H00188	H	600PP	345326
4965	73	117	0.78	77	MBM	5	06H	+7.36	TECTEH			N5432	reso	22H00035	H	600UL	340830
4966			0.92	66	MBM	6	06H	+11.97	TECTEH			N5432	reso	22H00035	H	600UL	340830
	87	117			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
[illegible]			0.16	89	SCI	P 1	TSH	+0.07	TSHTSH	0.2		F3453	reso	22H00177	H	600PP	345290
4969			0.14	86	PID	P 1	TSH	+0.07	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
4970			0.00	0	SCI	P 1	TSH	+0.07	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
4971	91	117	3.01	183	DNG	P 1	VM	+3.04	TECTEH			T7451	seco	22H00026	H	600UL	331892
4972	93	117	34.23	182	DNT	P 1	09H	-0.09	TECTEH			D4576	seco	22H00027	H	600UL	340830
4973			3.58	180	DNG	P 1	08C	+9.48	TECTEH			D4576	seco	22H00027	H	600UL	340830
4974			2.25	177	DNG	P 1	08C	+10.04	TECTEH			D4576	seco	22H00027	H	600UL	340830
4975			8.76	179	DNG	P 1	08C	+10.60	TECTEH			D4576	seco	22H00027	H	600UL	340830
4976	97	117	3.06	178	DNG	P 1	VM	+2.71	TECTEH			D4576	seco	22H00027	H	600UL	340830
4977	99	117	19.01	184	DNT	P 1	09H	+0.00	TECTEH			T7451	seco	22H00026	H	600UL	331892
4978	117	117	2.57	179	DNT	P 1	10C	+0.23	TECTEH			S8982	seco	22H00021	H	600UL	340830
4979			0.52	88	MBM	6	TSC	+33.36	TECTEH			M1680	reso	22H00021	H	600UL	340830
4980	121	117	2.61	34	NRC	2	TSC	+0.00	TECTEH			M1680	reso	22H00020	H	600UL	340911
4981	123	117	1.99	186	INR	P 1	09H	+20.47	TECTEH			S8982	seco	22H00020	H	600UL	340911
4982			6.06	184	DNG	P 1	10H	-1.02	TECTEH			S4373	reso	22H00020	H	600UL	340911
4983			3.50	186	DNT	P 1	10H	+0.40	TECTEH			S8982	seco	22H00020	H	600UL	340911
4984			3.89	186	DNT	P 1	10C	+0.68	TECTEH			S8982	seco	22H00020	H	600UL	340911
4985			2.97	185	DNG	P 1	09C	+13.25	TECTEH			S8982	seco	22H00020	H	600UL	340911
4986			19.19	185	DNG	P 1	09C	+14.39	TECTEH			S8982	seco	22H00020	H	600UL	340911
4987			2.70	182	DNG	P 1	09C	+17.91	TECTEH			S8982	seco	22H00020	H	600UL	340911
4988	125	117	4.56	168	DNT	P 1	10H	+0.37	TECTEH			S8982	seco	22H00021	H	600UL	340830
4989	127	117	4.39	191	DNT	P 1	10H	+0.27	TECTEH			S8982	seco	22H00020	H	600UL	340911
4990	38	118	4.69	180	DNG	P 1	TSC	+10.85	TECTEH			D3858	reso	22H00056	H	600UL	340830
4991	48	118	0.71	64	MBM	5	07H	+12.17	TECTEH			F3453	reso	22H00055	H	600UL	340948
[illegible]			1.22	52	MBM	5	07H	+15.46	TECTEH			F3453	reso	22H00055	H	600UL	340948
	62	118	2.98	181	DNG	P 1	VM	+20.79	TECTEH			D3858	reso	22H00056	H	600UL	340830
4994	66	118	1.19	73	MBM	5	TSH	+16.16	TECTEH			D3858	reso	22H00056	H	600UL	340830
4995			0.57	71	MBM	5	TSH	+19.16	TECTEH			D3858	reso	22H00056	H	600UL	340830
4996	78	118	1.04	86	MBM	5	VH	+13.47	TECTEH			L2157	reso	22H00034	H	600UL	331892
4997			1.11	77	MBM	5	03C	+8.43	TECTEH			L2157	reso	22H00034	H	600UL	331892

4998			0.93	83	MBM	5	01C	+23.37	TECTEH			L2157	reso	22H00034	H	600UL	331892

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 103

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4999	82	118			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
5000			0.26	97	PID	P 1	TSH	+0.11	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
5001			0.27	116	SCI	P 1	TSH	+0.11	TSHTSH	0.6		F3453	reso	22H00177	H	600PP	345290
5002			0.00	0	SCI	1	TSH	+0.11	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
5003	88	118			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
5004			0.30	81	PID	4	TSH	+0.12	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
5005			0.30	22	MCI	1	TSH	+0.12	TSHTSH	0.5		F6623	reso	22H00178	H	600PP	345329
5006			0.23	95	MCI	P 1	TSH	+0.12	TSHTSH	0.5		F6623	reso	22H00178	H	600PP	345329
5007	90	118	0.87	84	MBM	5	02H	+4.49	TECTEH			N5432	reso	22H00035	H	600UL	340830
5008			1.65	66	MBM	5	06H	+18.97	TECTEH			N5432	reso	22H00035	H	600UL	340830
5009			4.52	183	DNG	P 1	06H	+19.14	TECTEH			I3805	seco	22H00035	H	600UL	340830
5010	92	118	2.82	178	DNG	P 1	08H	+11.65	TECTEH			T7451	seco	22H00026	H	600UL	331892
5011			13.92	181	DNG	P 1	08H	+12.88	TECTEH			T7451	seco	22H00026	H	600UL	331892
5012			2.10	180	DNG	P 1	08H	+14.61	TECTEH			T7451	seco	22H00026	H	600UL	331892
5013			3.11	181	DNG	P 1	08H	+16.13	TECTEH			T7451	seco	22H00026	H	600UL	331892
5014			19.74	183	DNG	P 1	09C	+1.38	TECTEH			T7451	seco	22H00026	H	600UL	331892
5015			2.16	180	DNG	P 1	08C	+5.14	TECTEH			T7451	seco	22H00026	H	600UL	331892
			4.61	181	DNG	P 1	08C	+9.30	TECTEH			T7451	seco	22H00026	H	600UL	331892
[illegible]			12.12	181	DNG	P 1	08C	+10.20	TECTEH			T7451	seco	22H00026	H	600UL	331892
5018			2.99	179	DNG	P 1	08C	+10.64	TECTEH			T7451	seco	22H00026	H	600UL	331892
5019			1.77	183	INR	P 1	07C	+23.31	TECTEH			N5432	reso	22H00026	H	600UL	331892
5020	96	118	1.98	183	INR	P 1	08C	+10.35	TECTEH			T7451	seco	22H00026	H	600UL	331892
5021			1.86	181	INR	P 1	07C	+13.52	TECTEH			T7451	seco	22H00026	H	600UL	331892
5022			4.59	181	DNG	P 1	07C	+17.41	TECTEH			T7451	seco	22H00026	H	600UL	331892
5023	100	118	59.78	182	DNT	P 1	09H	+0.05	TECTEH			T7451	seco	22H00026	H	600UL	331892
5024					NDF		09H	+0.05	09H09H			M7007	prim	22H00203	H	600PP	345330
5025	110	118	34.25	181	DNT	P 1	09H	-0.06	TECTEH			D4576	seco	22H00027	H	600UL	340830
5026					NDF		09H	-0.06	09H09H			M7007	prim	22H00203	H	600PP	345330
5027			3.31	182	DNG	P 1	VH	+28.56	TECTEH			D4576	seco	22H00027	H	600UL	340830
5028	112	118	2.18	179	DNG	P 1	04H	+34.57	TECTEH			T7451	seco	22H00026	H	600UL	331892
5029			3.17	177	DNG	P 1	06H	+19.38	TECTEH			T7451	seco	22H00026	H	600UL	331892
5030					INF		09C	+15.68	TECTEH	HR		N5432	reso	22H00026	H	600UL	331892
5031			4.46	182	DNG	P 1	09C	+18.78	TECTEH			T7451	seco	22H00026	H	600UL	331892
5032			4.46	185	DNG	P 1	09C	+18.83	TECTEH			T7451	seco	22H00026	H	600UL	331892
5033	116	118	0.48	80	MBM	5	02C	+36.75	TECTEH			N5432	reso	22H00026	H	600UL	331892
5034	122	118	5.37	176	DNT	P 1	10H	+0.28	TECTEH			D4576	seco	22H00027	H	600UL	340830
5035	124	118	5.22	179	DNT	P 1	10H	+0.18	TECTEH			T7451	seco	22H00026	H	600UL	331892
5036			2.38	179	DNT	P 1	10C	+0.39	TECTEH			T7451	seco	22H00026	H	600UL	331892
5037	128	118	2.48	185	DNT	P 1	09H	+0.58	TECTEH			D4576	seco	22H00027	H	600UL	340830
5038			3.64	178	DNG	P 1	09H	+3.51	TECTEH			D4576	seco	22H00027	H	600UL	340830
5039			3.17	179	DNG	P 1	09H	+5.16	TECTEH			D4576	seco	22H00027	H	600UL	340830
5040			2.16	178	DNG	P 1	09H	+6.67	TECTEH			D4576	seco	22H00027	H	600UL	340830
[illegible]			8.88	179	DNG	P 1	09H	+7.74	TECTEH			D4576	seco	22H00027	H	600UL	340830
			5.78	178	DNG	P 1	09H	+8.52	TECTEH			D4576	seco	22H00027	H	600UL	340830
5043			5.17	181	DNG	P 1	09H	+10.09	TECTEH			D4576	seco	22H00027	H	600UL	340830
5044			21.65	179	DNG	P 1	09H	+11.12	TECTEH			D4576	seco	22H00027	H	600UL	340830
5045			3.06	185	DNT	P 1	10C	+0.49	TECTEH			D4576	seco	22H00027	H	600UL	340830
5046			8.91	181	DNG	P 1	09C	+20.21	TECTEH			D4576	seco	22H00027	H	600UL	340830

5047	1	119	0.48	0	PLP	9	TSH	+0.26	TSHTSH				W4892	prim	22H00189	H	600PP	345298

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 104

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5048			0.35	74	MBM	5	03C	+33.08	06CTEC			L2157	reso	22C00067	C	600CS	341611
5049	7	119			PRC				TSHTSH	080		C3340	reso	22H00198	H	600PP	345345
5050			0.47	79	PLP	9	TSH	+2.35	TSHTSH			A9608	reso	22H00188	H	600PP	345326
5051	9	119	2.79	183	DNG	P 1	04H	+27.06	TECTEH			S8982	seco	22H00055	H	600UL	340948
5052			2.84	182	DNG	P 1	04H	+29.60	TECTEH			S8982	seco	22H00055	H	600UL	340948
5053			3.97	184	DNT	P 1	05H	+0.37	TECTEH			S8982	seco	22H00055	H	600UL	340948
5054	11	119	4.05	187	DNG	P 1	03C	+22.79	TECTEH			H4599	seco	22H00056	H	600UL	340830
5055			3.37	176	DNG	P 1	03C	+23.22	TECTEH			H4599	seco	22H00056	H	600UL	340830
5056	39	119			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
5057			2.20	179	DNT	P 1	VM	-1.48	TECTEH			H4599	seco	22H00056	H	600UL	340830
5058			0.71	149	26	P 2	VM	+1.24	TECTEH			H4599	seco	22H00056	H	600UL	340830
5059			0.18	32	PID	2	VM	+1.24	VM VM			D3858	reso	22C00090	H	5602C	326272
5060	51	119	0.76	101	MBM	5	06C	+17.73	TECTEH			D3858	reso	22H00056	H	600UL	340830
5061	61	119			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
5062			0.09	113	SAI	2	TSH	+0.70	TSHTSH	0.2		F6623	reso	22H00178	H	600PP	345329
5063			0.12	142	PID	4	TSH	+0.70	TSHTSH	080		M1600	reso	22H00207	H	600PP	345329
5064			0.00	0	SAI	1	TSH	+0.70	TSHTSH	0.0		F6623	reso	22H00178	H	600PP	345329
	79	119			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
			0.10	66	SCI	P 1	TSH	+0.08	TSHTSH	0.2		F3453	reso	22H00177	H	600PP	345290
5067			0.00	0	SCI	1	TSH	+0.08	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
5068			0.10	96	PID	P 1	TSH	+0.08	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
5069	93	119			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
5070			0.0	0	SCI	1	TSH	+0.12	TSHTSH	0.0		L2157	reso	22H00163	H	600PP	345354
5071			0.24	128	SCI	P 1	TSH	+0.12	TSHTSH	0.2		L2157	reso	22H00163	H	600PP	345354
5072			0.27	122	PID	P 1	TSH	+0.12	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5073			3.18	183	DNG	P 1	08H	+7.52	TECTEH			T7451	seco	22H00026	H	600UL	331892
5074			4.37	183	DNG	P 1	08H	+19.22	TECTEH			T7451	seco	22H00026	H	600UL	331892
5075			2.23	181	DNT	P 1	09H	-0.37	TECTEH			T7451	seco	22H00026	H	600UL	331892
5076			4.14	182	DNT	P 1	09C	-0.02	TECTEH			T7451	seco	22H00026	H	600UL	331892
5077			4.57	182	DNG	P 1	08C	+2.21	TECTEH			T7451	seco	22H00026	H	600UL	331892
5078			6.72	181	DNG	P 1	08C	+6.94	TECTEH			T7451	seco	22H00026	H	600UL	331892
5079			7.27	184	DNG	P 1	08C	+13.80	TECTEH			T7451	seco	22H00026	H	600UL	331892
5080			3.30	182	DNG	P 1	08C	+18.64	TECTEH			T7451	seco	22H00026	H	600UL	331892
5081	95	119	1.83	183	INR	P 1	08C	+14.32	TECTEH			D4576	seco	22H00027	H	600UL	340830
5082	97	119			NDF		09H	-0.07	09H09H			M7007	prim	22H00203	H	600PP	345330
5083			38.20	183	DNT	P 1	09H	-0.07	TECTEH			T7451	seco	22H00026	H	600UL	331892
5084			4.10	181	DNG	P 1	VM	+2.96	TECTEH			T7451	seco	22H00026	H	600UL	331892
5085	99	119	74.71	178	DNT	P 1	09H	+0.02	TECTEH			D4576	seco	22H00027	H	600UL	340830
5086					NDF		09H	+0.02	09H09H			M7007	prim	22H00203	H	600PP	345330
5087	101	119	48.27	183	DNT	P 1	09H	+0.16	TECTEH			T7451	seco	22H00026	H	600UL	331892
5088	109	119	2.27	180	DNG	P 1	07H	+17.46	TECTEH			T7451	seco	22H00026	H	600UL	331892
5089	111	119	1.40	91	MBM	5	04H	+6.16	TECTEH			F6623	reso	22H00027	H	600UL	340830
5090			0.68	81	MBM	5	04H	+12.76	TECTEH			F6623	reso	22H00027	H	600UL	340830
			0.73	83	MBM	5	08C	+6.59	TECTEH			F6623	reso	22H00027	H	600UL	340830
5092			2.56	177	DNG	P 1	TSC	+4.80	TECTEH			D4576	seco	22H00027	H	600UL	340830
5093	115	119	4.19	178	DNG	P 1	05C	+14.58	TECTEH			D4576	seco	22H00027	H	600UL	340830
5094	117	119	2.55	180	DNT	P 1	10H	+0.69	TECTEH			T7451	seco	22H00026	H	600UL	331892
5095			3.09	179	DNT	P 1	10H	+33.13	TECTEH			T7451	seco	22H00026	H	600UL	331892

5096			3.09	180	DNT	P 1	DH	-2.05	TECTEH			T7451	seco	22H00026	H	600UL		331892

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 105

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5097		3.09	180	DNG	P 1	VH	-2.18	TECTEH			N5432	reso	22H00026	H	600UL	331892
5098		3.01	178	DNT	P 1	10C	-0.91	TECTEH			T7451	seco	22H00026	H	600UL	331892
5099		4.61	178	DNT	P 1	10C	-0.52	TECTEH			T7451	seco	22H00026	H	600UL	331892
5100		15.65	179	DNT	P 1	10C	+2.20	TECTEH			T7451	seco	22H00026	H	600UL	331892
5101		5.99	178	DNG	P 1	09C	+20.81	TECTEH			T7451	seco	22H00026	H	600UL	331892
5102	119	7.26	182	DNT	P 1	10H	+0.41	TECTEH			D4576	seco	22H00027	H	600UL	340830
5103		3.35	181	DNG	P 1	10H	+1.88	TECTEH			D4576	seco	22H00027	H	600UL	340830
5104	121	5.11	210	NRC	2	TSC	+0.00	TECTEH			A9608	reso	22H00026	H	600UL	331892
5105	123	2.30	188	DNT	P 1	10C	-0.48	TECTEH			D4576	seco	22H00027	H	600UL	340830
5106		5.77	183	DNG	P 1	10C	+5.45	TECTEH			F6623	reso	22H00027	H	600UL	340830
5107		2.18	180	DNG	P 1	01C	+26.51	TECTEH			D4576	seco	22H00027	H	600UL	340830
5108	127	4.22	187	DNT	P 1	10C	-0.48	TECTEH			F6623	reso	22H00027	H	600UL	340830
5109	4	0.37	84	PLP	9	TSC	+0.19	TSCTSC			B4052	prim	22C00029	C	600PP	345283
5110	6	0.28	88	PLP	9	TSH	+1.20	TSHTSH			L2157	reso	22H00186	H	600PP	345298
5111	20	3.12	185	DNG	P 1	05H	+25.97	TECTEH			H4599	seco	22H00056	H	600UL	340830
5112		3.99	179	DNG	P 1	05H	+23.47	TECTEH			H4599	seco	22H00056	H	600UL	340830
5113		3.48	177	DNG	P 1	05H	+30.08	TECTEH			H4599	seco	22H00056	H	600UL	340830
	36			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
[illegible]		0.00	0	SAI	1	TSH	+0.80	TSHTSH	0.0		D8661	reso	22H00189	H	600PP	345298
5116		0.11	101	PID	4	TSH	+0.80	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
5117		0.09	95	SAI	2	TSH	+0.80	TSHTSH	0.2		D8661	reso	22H00189	H	600PP	345298
5118	40	3.87	179	DNG	P 1	03H	+1.61	TECTEH			H4599	seco	22H00056	H	600UL	340830
5119		4.16	180	DNG	P 1	VM	+10.30	TECTEH			H4599	seco	22H00056	H	600UL	340830
5120	54	1.88	65	MBM	5	TSH	+28.50	TECTEH			D3858	reso	22H00056	H	600UL	340830
5121	58	1.72	176	INR	P 1	TSH	+23.61	TECTEH			D3858	reso	22H00056	H	600UL	340830
5122	68			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
5123		0.14	68	PID	4	TSH	+0.52	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
5124		0.12	76	SAI	2	TSH	+0.52	TSHTSH	0.2		F3453	reso	22H00177	H	600PP	345290
5125		0.00	0	SAI	1	TSH	+0.52	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
5126		0.10	100	SAI	2	TSH	+0.69	TSHTSH	0.2		F3453	reso	22H00177	H	600PP	345290
5127		0.00	0	SAI	1	TSH	+0.69	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
5128	74	0.75	83	MBM	5	05H	+15.61	TECTEH			F3453	reso	22H00055	H	600UL	340948
5129	76	1.67	193	INR	P 1	02H	+12.39	TECTEH			S8982	seco	22H00055	H	600UL	340948
5130	86			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
5131		0.13	118	PID	4	TSH	+0.15	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
5132		0.00	0	MAI	1	TSH	+0.15	TSHTSH	0.0		F3453	reso	22H00177	H	600PP	345290
5133		0.12	117	MAI	2	TSH	+0.15	TSHTSH	0.2		F3453	reso	22H00177	H	600PP	345290
5134	96	7.53	181	DNG	P 1	08H	+5.11	TECTEH			D4576	seco	22H00027	H	600UL	340830
5135		8.99	180	DNG	P 1	08H	+16.57	TECTEH			D4576	seco	22H00027	H	600UL	340830
5136		9.17	178	DNG	P 1	07C	+3.04	TECTEH			D4576	seco	22H00027	H	600UL	340830
5137	100	37.93	182	DNT	P 1	09H	-0.02	TECTEH			D4576	seco	22H00027	H	600UL	340830
5138	104	3.91	180	DNT	P 1	08H	-0.93	TECTEH			D4576	seco	22H00027	H	600UL	340830
[illegible]		3.99	180	DNG	P 1	08H	+14.58	TECTEH			D4576	seco	22H00027	H	600UL	340830
		6.45	180	DNG	P 1	08H	+18.58	TECTEH			D4576	seco	22H00027	H	600UL	340830
5141		3.60	180	DNG	P 1	09H	+1.62	TECTEH			D4576	seco	22H00027	H	600UL	340830
5142		1.89	183	INR	P 1	08C	+1.77	TECTEH			F6623	reso	22H00027	H	600UL	340830
5143		6.76	181	DNG	P 1	08C	+2.88	TECTEH			D4576	seco	22H00027	H	600UL	340830
5144		3.92	180	DNG	P 1	08C	+10.29	TECTEH			D4576	seco	22H00027	H	600UL	340830

5145			6.55	181	DNG	P 1	08C	+10.90		TECTEH				D4576	seco	22H00027	H	600UL	340830

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 106

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5146		3.15	181	DNG	P 1	08C	+18.01	TECTEH			D4576	seco	22H00027	H	600UL	340830
5147		4.43	180	DNG	P 1	07C	+23.64	TECTEH			D4576	seco	22H00027	H	600UL	340830
5148	108	120	48.28	180	DNT	P 1	09H	-0.09	TECTEH		D4576	seco	22H00027	H	600UL	340830
5149	112	120	2.26	179	DNG	P 1	08H	+18.56	TECTEH		D4576	seco	22H00027	H	600UL	340830
5150			4.14	178	DNT	P 1	09H	+0.61	TECTEH		D4576	seco	22H00027	H	600UL	340830
5151	118	120	0.68	81	MBM	5	01H	+8.78	TECTEH		N5432	reso	22H00026	H	600UL	331892
5152			2.04	178	DNG	P 1	07H	+12.23	TECTEH		T7451	seco	22H00026	H	600UL	331892
5153			10.87	177	DNT	P 1	10H	+0.25	TECTEH		T7451	seco	22H00026	H	600UL	331892
5154			10.87	181	DNT	P 1	10H	+0.27	TECTEH		T7451	seco	22H00026	H	600UL	331892
5155	120	120	2.82	183	DNG	P 1	10C	+2.37	TECTEH		F6623	reso	22H00027	H	600UL	340830
5156	124	120	6.88	187	DNT	P 1	10C	-0.48	TECTEH		D4576	seco	22H00027	H	600UL	340830
5157			1.25	83	MBM	5	TSC	+26.13	TECTEH		F6623	reso	22H00027	H	600UL	340830
5158	126	120			TBP				TSHTEH		D3858	reso	22H00044	H	600UL	331892
5159			0.36	110	NQI	P 1	TSH	+13.28	TECTEH		F6623	reso	22H00027	H	600UL	340830
5160			0.31	94	SVI	4	TSH	+13.54	TSH01H	0.3	F3453	reso	22H00203	H	600PP	345330
5161			0.38	119	SVI	3	TSH	+13.54	TSH01H	0.3	F3453	reso	22H00203	H	600PP	345330
5162			0.32	90	PID	4	TSH	+13.54	TSHTSH	080	N5432	reso	22H00210	H	600PP	345330
			3.01	180	DNG	P 1	08H	+13.50	TECTEH		D4576	seco	22H00027	H	600UL	340830
			10.68	181	DNT	P 1	10C	-0.48	TECTEH		D4576	seco	22H00027	H	600UL	340830
5165	5	121	0.75	65	MBM	5	03H	+26.85	06HTEH		C5542	reso	22H00105	H	600UL	340824
5166			16.27	181	DNG	P 1	06C	+5.01	06HTEC		D4576	seco	22C00066	C	600CS	341219
5167	7	121	0.89	333	INR	P 1	06H	+3.42 TO+5.75	TECTEH		D3858	reso	22H00056	H	600UL	340830
5168	45	121	3.53	173	DNG	P 1	01C	+26.11	TECTEH		C3340	reso	22H00051	H	600UL	340948
5169	67	121	8.17	180	DNG	P 1	07H	+16.52	TECTEH		D3858	reso	22H00052	H	600UL	340830
5170	73	121			INF		DH	+16.10	TECTEH	HR	C3340	reso	22H00051	H	600UL	340948
5171			3.27	178	DNG	P 1	DH	+18.97	TECTEH		C3340	reso	22H00051	H	600UL	340948
5172	91	121	6.55	184	DNT	P 1	09H	+0.50	TECTEH		T7451	seco	22H00026	H	600UL	331892
5173	93	121	0.45	73	MBM	5	02H	+22.15	TECTEH		F6623	reso	22H00027	H	600UL	340830
5174			2.40	180	DNG	P 1	08C	+18.52	TECTEH		D4576	seco	22H00027	H	600UL	340830
5175	95	121	3.60	181	DNG	P 1	08C	+13.22	TECTEH		T7451	seco	22H00026	H	600UL	331892
5176			15.34	182	DNG	P 1	08C	+14.20	TECTEH		T7451	seco	22H00026	H	600UL	331892
5177	97	121	0.68	71	MBM	5	06C	+8.14	TECTEH		F6623	reso	22H00027	H	600UL	340830
5178	101	121	0.70	96	MBM	5	03C	+19.19	TECTEH		F6623	reso	22H00027	H	600UL	340830
5179			0.65	72	MBM	5	03C	+21.86	TECTEH		F6623	reso	22H00027	H	600UL	340830
5180			0.61	78	MBM	5	03C	+24.33	TECTEH		F6623	reso	22H00027	H	600UL	340830
5181	105	121	5.14	179	DNG	P 1	08H	+15.95	TECTEH		D4576	seco	22H00027	H	600UL	340830
5182			4.03	178	DNG	P 1	08H	+18.60	TECTEH		D4576	seco	22H00027	H	600UL	340830
5183			2.70	178	DNG	P 1	08C	+6.37	TECTEH		D4576	seco	22H00027	H	600UL	340830
5184			9.67	180	DNG	P 1	08C	+7.29	TECTEH		D4576	seco	22H00027	H	600UL	340830
5185			4.86	178	DNG	P 1	07C	+20.33	TECTEH		D4576	seco	22H00027	H	600UL	340830
5186	107	121	1.23	93	MBM	5	01C	+34.45	TECTEH		N5432	reso	22H00026	H	600UL	331892
5187			2.30	175	DNG	P 1	01C	+35.80	TECTEH		T7451	seco	22H00026	H	600UL	331892
[illegible]	109	121	2.70	178	DNG	P 1	DH	+7.09	TECTEH		D4576	seco	22H00027	H	600UL	340830
	119	121	2.62	179	DNT	P 1	08H	+0.09	TECTEH		T7451	seco	22H00026	H	600UL	331892
5190	121	121	6.55	188	DNT	P 1	10C	-0.69	TECTEH		D4576	seco	22H00027	H	600UL	340830
5191			4.85	23	NRC	2	TSC	+0.00	TECTEH		J9815	prim	22H00027	H	600UL	340830
5192	123	121	0.45	146	INR	P 1	09H	+0.05	TECTEH		N5432	reso	22H00026	H	600UL	331892
5193			6.93	186	DNT	P 1	10C	-0.59	TECTEH		T7451	seco	22H00026	H	600UL	331892

5194			6.26	178	DNT	P 1	10C	+0.48	TECTEH			T7451	seco	22H00026	H	600UL	331892

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 107

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5195					INF		10C	+4.43	TECTEH	HR		A9608	reso	22H00026	H	600UL	331892
5196			7.44	183	DNG	P 1	10C	+5.87	TECTEH			T7451	seco	22H00026	H	600UL	331892
5197	125	121	3.24	179	DNT	P 1	10C	+0.44	TECTEH			D4576	seco	22H00027	H	600UL	340830
5198	4	122			PRC				TSHTSH	080		C3340	reso	22H00198	H	600PP	345345
5199			0.30	78	PLP	9	TSH	+0.16	TSHTSH			D8661	reso	22H00185	H	600PP	345326
5200	6	122	0.53	74	MBM	5	04H	+7.77	TECTEH			C3340	reso	22H00051	H	600UL	340948
5201	16	122	0.18	120	INR	2	TSC	+2.61	TSCTSC			A9608	reso	22C00030	C	600PP	345294
5202	22	122	5.80	179	DNG	P 1	06C	+4.30	TECTEH			A6997	seco	22H00051	H	600UL	340948
5203	24	122	0.27	54	NQI	5	04C	+16.36	TECTEH			D3858	reso	22H00052	H	600UL	340830
5204					NDF		04C	+16.36	05C04C			T6956	prim	22C00091	C	600PP	345343
5205	32	122			NDF		TSH	+19.83	TSH01H			D9424	prim	22H00207	H	600PP	345329
5206			0.37	85	NQI	5	TSH	+19.83	TECTEH			D3858	reso	22H00052	H	600UL	340830
5207			5.05	180	DNG	P 1	DH	+11.19	TECTEH			S8982	seco	22H00052	H	600UL	340830
5208	38	122	17.26	175	DNT	P 1	VM	-0.91	TECTEH			A6997	seco	22H00051	H	600UL	340948
5209			3.41	175	DNT	P 1	VM	+2.02	TECTEH			C3340	reso	22H00051	H	600UL	340948
5210	70	122	0.76	56	MBM	5	01H	+23.34	TECTEH			C3340	reso	22H00051	H	600UL	340948
5211	76	122	0.29	72	MBM	5	04H	+17.07	TECTEH			D3858	reso	22H00052	H	600UL	340830
	78	122			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
[illegible]			0.34	116	MMI	2	TSH	+0.14	TSHTSH	0.3	0.3	F3453	reso	22H00177	H	600PP	345290
5214			0.28	117	PID	P 1	TSH	+0.14	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
5215			0.81	125	MMI	1	TSH	+0.14	TSHTSH	0.4	0.5	F3453	reso	22H00177	H	600PP	345290
5216	80	122	3.19	178	DNG	P 1	02C	+36.48	TECTEH			D3858	reso	22H00052	H	600UL	340830
5217	86	122			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
5218			0.00	0	SCI	1	TSH	+0.06	TSHTSH	0.0		F3453	reso	22H00183	H	600PP	345346
5219			0.25	92	PID	P 1	TSH	+0.06	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
5220			0.34	78	SCI	P 1	TSH	+0.06	TSHTSH	0.3		F3453	reso	22H00183	H	600PP	345346
5221	92	122	2.70	181	DNG	P 1	07H	+2.25	TECTEH			T7451	seco	22H00026	H	600UL	331892
5222			2.51	179	DNG	P 1	07H	+13.46	TECTEH			T7451	seco	22H00026	H	600UL	331892
5223			5.27	183	DNT	P 1	08H	+0.45	TECTEH			T7451	seco	22H00026	H	600UL	331892
5224			5.87	181	DNG	P 1	08H	+1.49	TECTEH			T7451	seco	22H00026	H	600UL	331892
5225			4.12	181	DNG	P 1	08H	+10.10	TECTEH			N5432	reso	22H00026	H	600UL	331892
5226			20.19	183	DNG	P 1	08H	+11.21	TECTEH			N5432	reso	22H00026	H	600UL	331892
5227			7.86	182	DNG	P 1	08H	+12.16	TECTEH			N5432	reso	22H00026	H	600UL	331892
5228			3.82	181	DNG	P 1	08H	+13.51	TECTEH			N5432	reso	22H00026	H	600UL	331892
5229			3.82	179	DNG	P 1	08H	+13.53	TECTEH			T7451	seco	22H00026	H	600UL	331892
5230			2.71	179	DNG	P 1	08H	+19.34	TECTEH			T7451	seco	22H00026	H	600UL	331892
5231			8.90	181	DNG	P 1	08H	+20.19	TECTEH			T7451	seco	22H00026	H	600UL	331892
5232			4.14	183	DNG	P 1	08H	+20.54	TECTEH			T7451	seco	22H00026	H	600UL	331892
5233			12.00	182	DNT	P 1	09H	+0.05	TECTEH			T7451	seco	22H00026	H	600UL	331892
5234			22.03	183	DNT	P 1	09C	+0.11	TECTEH			N5432	reso	22H00026	H	600UL	331892
5235			8.76	358	INR	P 1	09C	+1.32	TECTEH			N5432	reso	22H00026	H	600UL	331892
5236			2.74	176	DNT	P 1	08C	+0.98	TECTEH			T7451	seco	22H00026	H	600UL	331892
[illegible]			12.01	182	DNG	P 1	08C	+1.92	TECTEH			T7451	seco	22H00026	H	600UL	331892
			2.50	179	DNG	P 1	08C	+2.27	TECTEH			T7451	seco	22H00026	H	600UL	331892
5239			4.81	181	DNG	P 1	08C	+2.64	TECTEH			T7451	seco	22H00026	H	600UL	331892
5240			23.00	183	DNG	P 1	08C	+3.58	TECTEH			T7451	seco	22H00026	H	600UL	331892
5241			4.59	178	INR	P 1	08C	+21.76	TECTEH			N5432	reso	22H00026	H	600UL	331892
5242			6.19	183	DNG	P 1	07C	+15.38	TECTEH			T7451	seco	22H00026	H	600UL	331892

5243	96	122	2.47	181	DNT	P 1	09H	-1.00	TECTEH			T7451	seco	22H00026	H	600UL	331892

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 108

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5244			3.23	186	DNT	P 1	09C	+1.37	TECTEH			T7451	seco	22H00026	H	600UL	331892
5245			6.84	182	DNG	P 1	08C	+17.69	TECTEH			T7451	seco	22H00026	H	600UL	331892
5246	102	122	2.89	178	DNG	P 1	07H	+12.96	TECTEH			D4576	seco	22H00027	H	600UL	340830
5247			3.63	178	DNG	P 1	07H	+18.64	TECTEH			D4576	seco	22H00027	H	600UL	340830
5248			2.72	179	DNG	P 1	07H	+21.08	TECTEH			D4576	seco	22H00027	H	600UL	340830
5249			7.06	179	DNG	P 1	07H	+22.01	TECTEH			D4576	seco	22H00027	H	600UL	340830
5250			3.33	177	DNG	P 1	08H	+3.98	TECTEH			D4576	seco	22H00027	H	600UL	340830
5251			2.49	179	DNG	P 1	08H	+8.64	TECTEH			D4576	seco	22H00027	H	600UL	340830
5252			7.12	180	DNG	P 1	08H	+9.62	TECTEH			D4576	seco	22H00027	H	600UL	340830
5253			2.23	177	DNG	P 1	08H	+17.21	TECTEH			D4576	seco	22H00027	H	600UL	340830
5254	110	122	2.08	178	DNG	P 1	09C	+15.91	TECTEH			D4576	seco	22H00027	H	600UL	340830
5255	112	122	2.81	175	DNT	P 1	09C	+0.32	TECTEH			T7451	seco	22H00026	H	600UL	331892
5256			2.07	177	DNG	P 1	06C	+8.51	TECTEH			T7451	seco	22H00026	H	600UL	331892
5257	114	122	3.55	178	DNT	P 1	09H	-0.48	TECTEH			D4576	seco	22H00027	H	600UL	340830
5258	118	122	5.81	179	DNG	P 1	07H	+22.08	TECTEH			D4576	seco	22H00027	H	600UL	340830
5259			4.21	179	DNT	P 1	09H	-0.15	TECTEH			D4576	seco	22H00027	H	600UL	340830
5260			4.98	179	DNG	P 1	09H	+1.01	TECTEH			S4373	reso	22H00027	H	600UL	340830
			2.20	178	DNG	P 1	09H	+4.25	TECTEH			D4576	seco	22H00027	H	600UL	340830
[illegible]			3.76	178	DNG	P 1	09H	+5.03	TECTEH			D4576	seco	22H00027	H	600UL	340830
5263			2.91	179	DNG	P 1	10H	-1.34	TECTEH			D4576	seco	22H00027	H	600UL	340830
5264			8.10	181	DNT	P 1	10C	-0.44	TECTEH			D4576	seco	22H00027	H	600UL	340830
5265			3.18	181	DNG	P 1	09C	+12.13	TECTEH			D4576	seco	22H00027	H	600UL	340830
5266			2.02	178	DNG	P 1	09C	+14.42	TECTEH			D4576	seco	22H00027	H	600UL	340830
5267	120	122	3.11	181	DNT	P 1	DC	-0.52	TECTEH			T7451	seco	22H00026	H	600UL	331892
5268			6.32	182	DNT	P 1	10C	-0.53	TECTEH			T7451	seco	22H00026	H	600UL	331892
5269			6.02	176	DNT	P 1	10C	+0.50	TECTEH			T7451	seco	22H00026	H	600UL	331892
5270			2.03	185	DNG	P 1	10C	+2.64	TECTEH			T7451	seco	22H00026	H	600UL	331892
5271	122	122	9.55	182	DNT	P 1	10C	-0.59	TECTEH			D4576	seco	22H00027	H	600UL	340830
5272			3.91	177	DNT	P 1	10C	+0.54	TECTEH			D4576	seco	22H00027	H	600UL	340830
5273	124	122			OBS		TEH	+0.00	TEHTEH			F6623	reso	22H00027	H	600UL	340830
5274					OBS		TEH	+0.00	TEHTEH			L2157	reso	22H00163	H	600PP	345354
5275			14.11	180	DNT	P 1	10C	-0.71	TECTEH			I3805	seco	22H00031	H	600UL	340830
5276			7.32	179	DNT	P 1	10C	+0.57	TECTEH			I3805	seco	22H00031	H	600UL	340830
5277	1	123	0.18	0	INR	9	TSH	+0.12	TSHTSH			L2157	reso	22H00186	H	600PP	345298
5278	3	123	0.18	0	INR	9	TSH	+0.58	TSHTSH			N5432	reso	22H00185	H	600PP	345326
5279			3.98	183	DNT	P 1	05H	-0.22	06HTEH			D8661	reso	22H00105	H	600UL	340824
5280			2.20	178	DNG	P 1	06H	+1.30	06HTEH			C5542	reso	22H00105	H	600UL	340824
5281			2.24	179	DNG	P 1	06H	+1.95	06HTEC			D4576	seco	22C00066	C	600CS	341219
5282	5	123			PRC				TSHTSH	080		C3340	reso	22H00198	H	600PP	345345
5283			0.53	81	PLP	9	TSH	+0.11	TSHTSH			L2157	reso	22H00186	H	600PP	345298
5284	15	123	1.87	180	INR	P 1	06C	+11.67	TECTEH			C3340	reso	22H00051	H	600UL	340948
5285	29	123	2.51	179	DNG	P 1	04H	+24.13	TECTEH			D3858	reso	22H00052	H	600UL	340830
[illegible]	39	123			NDF		06H	+0.69	06H06H			N2574	seco	22H00207	H	600PP	345329
			5.73	179	DNT	P 1	06H	+0.69	TECTEH			A6997	seco	22H00051	H	600UL	340948
5288			8.09	173	DNG	P 1	TSC	+6.44	TECTEH			A6997	seco	22H00051	H	600UL	340948
5289	57	123	4.20	182	DNT	P 1	07H	+0.95	TECTEH			D3858	reso	22H00052	H	600UL	340830
5290	65	123			TBP				TECTEH	SVISLV	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5291			0.95	37	SVI	3	SBH	+2.40	SBHSTH			D3858	prim	22H00236	H	500PP	326655

5292			1.28	22	PID	3	SBH	+2.40	SBHSTH				D3858	prim	22H00238	H	500PP	326655

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 109

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5293			0.09	113	PID	4	TSH	+0.46	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
5294			0.21	134	SAI	1	TSH	+0.46	TSHTSH	0.2		F6623	reso	22H00178	H	600PP	345329
5295			0.09	111	SAI	2	TSH	+0.46	TSHTSH	0.3		F6623	reso	22H00178	H	600PP	345329
5296	69	123	0.45	100	MBM	5	02C	+6.39	TECTEH			D3858	reso	22H00052	H	600UL	340830
5297	75	123	0.60	74	MBM	5	03C	+6.63	TECTEH			C3340	reso	22H00051	H	600UL	340948
5298	79	123			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
5299			0.25	54	MCI	P 1	TSH	+0.11	TSHTSH	0.7		F3453	reso	22H00183	H	600PP	345346
5300			0.23	104	PID	P 1	TSH	+0.11	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
5301			0.00	0	MCI	1	TSH	+0.11	TSHTSH	0.0		F3453	reso	22H00183	H	600PP	345346
5302	101	123	2.08	185	DNG	P 1	08C	+15.81	TECTEH			K2032	seco	22H00030	H	600UL	331892
5303			3.82	182	DNG	P 1	07C	+22.01	TECTEH			K2032	seco	22H00030	H	600UL	331892
5304	111	123	2.49	181	DNG	P 1	08C	+2.75	TECTEH			I3805	seco	22H00031	H	600UL	340830
5305	113	123	2.27	179	DNG	P 1	09C	+9.31	TECTEH			T7451	seco	22H00026	H	600UL	331892
5306	115	123	2.55	180	DNG	P 1	03H	+13.51	TECTEH			D4576	seco	22H00027	H	600UL	340830
5307	117	123	4.53	181	DNT	P 1	10C	-0.49	TECTEH			T7451	seco	22H00026	H	600UL	331892
5308			2.91	170	DNT	P 1	10C	+0.44	TECTEH			T7451	seco	22H00026	H	600UL	331892
5309	119	123			NDF		03H	-0.84	03H03H			N2574	seco	22H00203	H	600PP	345330
			0.69	55	DSI	P 1	03H	-0.84	TECTEH			J9815	prim	22H00027	H	600UL	340830
					NDF		09H	-0.15	09H09H			N2574	seco	22H00203	H	600PP	345330
5312			5.41	183	DNT	P 1	09H	-0.15	TECTEH			D4576	seco	22H00027	H	600UL	340830
5313			6.86	183	DNT	P 1	10C	-0.48	TECTEH			D4576	seco	22H00027	H	600UL	340830
5314			3.97	181	DNT	P 1	10C	+0.50	TECTEH			D4576	seco	22H00027	H	600UL	340830
5315	18	124			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5316			0.15	58	SAI	1	TSH	+2.03	TSHTSH	0.2		N5432	reso	22H00185	H	600PP	345326
5317			0.25	86	SAI	2	TSH	+2.03	TSHTSH	0.5		N5432	reso	22H00185	H	600PP	345326
5318			0.27	128	PID	4	TSH	+2.03	TSHTSH	080		M1680	reso	22H00198	H	600PP	345345
5319	24	124	0.55	86	MBM	5	04H	+2.87	TECTEH			C3340	reso	22H00051	H	600UL	340948
5320			0.88	75	MBM	6	04H	+19.16	TECTEH			C3340	reso	22H00051	H	600UL	340948
5321			3.66	178	DNG	P 1	04H	+19.76	TECTEH			A6997	seco	22H00051	H	600UL	340948
5322	30	124	6.59	180	DNT	P 1	VM	+1.53	TECTEH			D3858	reso	22H00052	H	600UL	340830
5323	38	124	4.34	179	DNT	P 1	07H	+0.99	TECTEH			S8982	seco	22H00052	H	600UL	340830
5324			16.25	177	DNT	P 1	VM	-1.25	TECTEH			S8982	seco	22H00052	H	600UL	340830
5325			13.31	179	DNT	P 1	VM	+1.68	TECTEH			S8982	seco	22H00052	H	600UL	340830
5326	40	124	3.51	177	DNG	P 1	VM	+9.93	TECTEH			A6997	seco	22H00051	H	600UL	340948
5327	60	124	2.48	177	DNG	P 1	VM	+19.88	TECTEH			A6997	seco	22H00051	H	600UL	340948
5328	70	124	1.04	85	MBM	5	03C	+5.96	TECTEH			D3858	reso	22H00052	H	600UL	340830
5329	86	124			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
5330			0.00	0	MCI	1	TSH	+0.08	TSHTSH	0.0		F3453	reso	22H00183	H	600PP	345346
5331			0.21	43	PID	P 1	TSH	+0.08	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
5332			0.17	87	MCI	P 1	TSH	+0.08	TSHTSH	0.4		F3453	reso	22H00183	H	600PP	345346
5333			3.37	179	DNG	P 1	TSH	+35.15	TECTEH			N5877	seco	22H00034	H	600UL	331892
5334			1.49	184	INR	P 1	05C	+23.28	TECTEH			N5877	seco	22H00034	H	600UL	331892
5335	92	124	31.64	182	DNT	P 1	09H	+0.06	TECTEH			K2032	seco	22H00030	H	600UL	331892
	96	124	2.52	176	DNG	P 1	08H	+10.49	TECTEH			K2032	seco	22H00030	H	600UL	331892
5337			9.92	180	DNG	P 1	08H	+11.45	TECTEH			K2032	seco	22H00030	H	600UL	331892
5338			2.39	179	DNG	P 1	08H	+14.15	TECTEH			K2032	seco	22H00030	H	600UL	331892
5339			14.17	180	DNG	P 1	08H	+18.67	TECTEH			K2032	seco	22H00030	H	600UL	331892
5340			2.80	175	DNT	P 1	09C	-0.04	TECTEH			K2032	seco	22H00030	H	600UL	331892

5341			17.45	181	DNT	P 1	09C	+1.05	TECTEH				K2032	seco	22H00030	H	600UL		331892

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 110

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5342			4.23	183	DNT	P 1	08C	+1.12	TECTEH			K2032	seco	22H00030	H	600UL	331892
5343			2.06	183	DNG	P 1	08C	+2.37	TECTEH			K2032	seco	22H00030	H	600UL	331892
5344			6.92	179	DNG	P 1	08C	+3.37	TECTEH			K2032	seco	22H00030	H	600UL	331892
5345	98	124	2.83	182	DNT	P 1	09C	+0.09	TECTEH			I3805	seco	22H00031	H	600UL	340830
5346	100	124	3.23	174	DNT	P 1	VM	+1.58	TECTEH			K2032	seco	22H00030	H	600UL	331892
5347	108	124	3.72	182	DNT	P 1	09H	-0.15	TECTEH			K2032	seco	22H00030	H	600UL	331892
5348	116	124	5.08	183	DNT	P 1	09H	-0.18	TECTEH			K2032	seco	22H00030	H	600UL	331892
5349	118	124	2.27	180	DNG	P 1	08H	+14.35	TECTEH			I3805	seco	22H00031	H	600UL	340830
5350			8.30	178	DNT	P 1	10C	+0.43	TECTEH			I3805	seco	22H00031	H	600UL	340830
5351	120	124	2.81	180	DNG	P 1	07H	+2.82	TECTEH			K2032	seco	22H00030	H	600UL	331892
5352			2.48	189	DNG	P 1	07H	+10.37	TECTEH			K2032	seco	22H00030	H	600UL	331892
5353			2.07	182	DNG	P 1	08H	+7.43	TECTEH			K2032	seco	22H00030	H	600UL	331892
5354			4.56	178	DNT	P 1	10C	+0.51	TECTEH			K2032	seco	22H00030	H	600UL	331892
5355	122	124	2.06	181	DNT	P 1	10C	-0.65	TECTEH			I3805	seco	22H00031	H	600UL	340830
5356			1.26	87	MBM	5	07C	+11.13	TECTEH			F6623	reso	22H00031	H	600UL	340830
5357	3	125			CBS		06C	+5.59	06CTEC			L2157	reso	22C00066	C	600CS	341219
5358	5	125	5.49	84	INR	9	TSC	+2.25	TSCTSC			C5542	reso	22C00029	C	600PP	345283
	9	125	22.83	178	DNG	P 1	06C	+6.23	TECTEH			D3858	reso	22H00052	H	600UL	340830
[illegible]	15	125	2.05	173	INR	P 1	06C	+8.83	TECTEH			C3340	reso	22H00051	H	600UL	340948
5361	57	125			TBP				TECTEH	FAILSLV	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5362			0.09	97	SAI	2	TSH	+0.54	TSHTSH	0.2		F6623	reso	22H00182	H	600PP	345326
5363			0.06	124	PID	4	TSH	+0.54	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
5364			0.00	0	SAI	1	TSH	+0.54	TSHTSH	0.0		F6623	reso	22H00182	H	600PP	345326
5365	61	125	3.56	182	DNG	P 1	03C	+22.86	TECTEH			D3858	reso	22H00052	H	600UL	340830
5366	69	125			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
5367			0.24	84	PID	4	TSH	+0.24	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
5368			0.15	54	SAI	1	TSH	+0.24	TSHTSH	0.3		F6623	reso	22H00182	H	600PP	345326
5369			0.24	90	SAI	2	TSH	+0.24	TSHTSH	0.2		F6623	reso	22H00182	H	600PP	345326
5370	71	125			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
5371			0.13	84	PID	4	TSH	+0.19	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
5372			0.00	0	SAI	1	TSH	+0.19	TSHTSH	0.0		F3453	reso	22H00183	H	600PP	345346
5373			0.17	85	SAI	2	TSH	+0.19	TSHTSH	0.2		F3453	reso	22H00183	H	600PP	345346
5374	85	125	1.12	76	MBM	6	03H	+32.27	TECTEH			L2157	reso	22H00034	H	600UL	331892
5375	93	125	9.47	181	DNG	P 1	08H	+7.20	TECTEH			K2032	seco	22H00030	H	600UL	331892
5376			2.48	182	DNG	P 1	08H	+8.14	TECTEH			K2032	seco	22H00030	H	600UL	331892
5377			4.83	184	DNT	P 1	09H	+0.66	TECTEH			K2032	seco	22H00030	H	600UL	331892
5378			5.30	181	DNT	P 1	09C	-0.92	TECTEH			K2032	seco	22H00030	H	600UL	331892
5379			2.61	181	DNG	P 1	08C	+9.40	TECTEH			K2032	seco	22H00030	H	600UL	331892
5380			10.46	182	DNG	P 1	07C	+23.42	TECTEH			K2032	seco	22H00030	H	600UL	331892
5381	97	125	3.30	180	DNG	P 1	07H	+13.91	TECTEH			I3805	seco	22H00031	H	600UL	340830
5382			3.84	180	DNG	P 1	07H	+19.34	TECTEH			I3805	seco	22H00031	H	600UL	340830
5383			2.86	181	DNT	P 1	08H	-1.09	TECTEH			I3805	seco	22H00031	H	600UL	340830
[illegible]	101	125	1.02	88	MBM	5	02C	+21.20	TECTEH			F6623	reso	22H00031	H	600UL	340830
	109	125	15.78	182	DNT	P 1	09H	-0.09	TECTEH			I3805	seco	22H00031	H	600UL	340830
5386	111	125	4.88	181	DNG	P 1	08H	+7.49	TECTEH			K2032	seco	22H00030	H	600UL	331892
5387			5.09	180	DNG	P 1	08H	+15.89	TECTEH			K2032	seco	22H00030	H	600UL	331892
5388			3.93	179	DNG	P 1	VH	+2.78	TECTEH			K2032	seco	22H00030	H	600UL	331892
5389			2.26	177	DNG	P 1	03C	+8.05	TECTEH			K2032	seco	22H00030	H	600UL	331892

5390	113	125			NDF		01H	+0.55	01H01H				M7007	prim	22H00203	H	600PP	345330

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 111

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5391			0.38	105	DSI	P 1	01H	+0.55	TECTEH			I3805	seco	22H00031	H	600UL	340830
5392			2.35	182	DNG	P 1	VC	+14.17	TECTEH			F6623	reso	22H00031	H	600UL	340830
5393			4.18	182	DNT	P 1	09C	+0.04	TECTEH			I3805	seco	22H00031	H	600UL	340830
5394	117	125	5.52	180	DNT	P 1	10C	-0.48	TECTEH			I3805	seco	22H00031	H	600UL	340830
5395			11.00	180	DNT	P 1	10C	+0.45	TECTEH			I3805	seco	22H00031	H	600UL	340830
5396	119	125	3.84	194	INR	P 1	10C	-0.38	TECTEH			L2157	reso	22H00030	H	600UL	331892
5397			11.63	178	DNT	P 1	10C	+0.48	TECTEH			K2032	seco	22H00030	H	600UL	331892
5398	121	125	4.83	180	DNG	P 1	06H	+14.23	TECTEH			I3805	seco	22H00031	H	600UL	340830
5399			2.67	178	DNG	P 1	07H	+19.46	TECTEH			I3805	seco	22H00031	H	600UL	340830
5400			2.98	179	DNG	P 1	07H	+24.37	TECTEH			I3805	seco	22H00031	H	600UL	340830
5401			4.56	179	DNG	P 1	08H	+3.19	TECTEH			I3805	seco	22H00031	H	600UL	340830
5402			3.41	179	DNG	P 1	08H	+11.49	TECTEH			I3805	seco	22H00031	H	600UL	340830
5403			2.79	181	DNG	P 1	08H	+17.58	TECTEH			I3805	seco	22H00031	H	600UL	340830
5404			3.75	183	DNT	P 1	09H	+0.09	TECTEH			I3805	seco	22H00031	H	600UL	340830
5405			2.27	182	DNG	P 1	09H	+1.72	TECTEH			I3805	seco	22H00031	H	600UL	340830
5406			10.14	181	DNG	P 1	09H	+2.77	TECTEH			I3805	seco	22H00031	H	600UL	340830
5407			2.71	178	DNG	P 1	09H	+5.68	TECTEH			I3805	seco	22H00031	H	600UL	340830
			7.82	179	DNG	P 1	09H	+6.67	TECTEH			I3805	seco	22H00031	H	600UL	340830
[illegible]			7.40	180	DNG	P 1	09H	+12.57	TECTEH			I3805	seco	22H00031	H	600UL	340830
5410			10.93	180	DNG	P 1	09H	+15.88	TECTEH			I3805	seco	22H00031	H	600UL	340830
5411			5.65	180	DNT	P 1	10C	-0.61	TECTEH			I3805	seco	22H00031	H	600UL	340830
5412			4.53	176	DNT	P 1	10C	+0.38	TECTEH			I3805	seco	22H00031	H	600UL	340830
5413			3.94	184	DNG	P 1	10C	+12.17	TECTEH			F6623	reso	22H00031	H	600UL	340830
5414			3.74	179	DNT	P 1	09C	+0.50	TECTEH			S4373	reso	22H00031	H	600UL	340830
5415			2.93	177	DNG	P 1	08C	+7.54	TECTEH			I3805	seco	22H00031	H	600UL	340830
5416			12.22	181	DNG	P 1	08C	+8.54	TECTEH			I3805	seco	22H00031	H	600UL	340830
5417			2.04	180	DNG	P 1	08C	+10.69	TECTEH			I3805	seco	22H00031	H	600UL	340830
5418			9.58	182	DNG	P 1	08C	+16.67	TECTEH			I3805	seco	22H00031	H	600UL	340830
5419			3.90	187	DNG	P 1	08C	+17.50	TECTEH			I3805	seco	22H00031	H	600UL	340830
5420			5.35	28	NRC	2	TSC	+0.00	TECTEH			K5380	prim	22H00031	H	600UL	340830
5421	10	126			OBS		06H	+13.77	06HTEH			H2949	seco	22H00110	H	600UL	340929
5422			19.52	177	DNT	P 1	VM	+0.00	TEHTEC			L2157	reso	22C00065	H	580UL	287821
5423					OBS		06C	+6.68	06CTEC			H3464	prim	22C00064	H	600CS	341611
5424	20	126	9.19	181	DNT	P 1	06C	+0.67	TECTEH			H2949	seco	22H00110	H	600UL	340929
5425	38	126	4.00	5	INR	P 1	06H	+5.50	TECTEH			F1726	seco	22H00104	H	600UL	340824
5426	40	126	4.74	180	DNG	P 1	VM	+9.97	TECTEH			N5877	seco	22H00102	H	600UL	340929
5427			2.26	174	DNG	P 1	06C	+12.99	TECTEH			N5877	seco	22H00102	H	600UL	340929
5428	42	126	4.37	181	DNG	P 1	07C	+1.60	TECTEH			F1726	seco	22H00104	H	600UL	340824
5429	46	126			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5430					OBS		TEH	+0.00	TEHTEH			C5542	reso	22H00130	H	600PP	345352
5431					OBS		TEH	+0.00	TEHTEH			M7006	reso	22H00104	H	600UL	340824
5432					OBS		TEH	+0.00	TEHTEH			O1057	prim	22H00179	H	600PP	345326
[illegible]					OBS		TSH	-21.23	TSHTEC			L2157	reso	22C00065	H	580UL	287821
					OBS		TSH	-20.82	TSHTEC			H3464	prim	22C00064	H	600CS	341611
5435			0.11	101	PID	2	TSH	+0.63	TSHTSH			D9424	prim	22H00212	H	500DP	290406
5436			0.12	72	MAI	2	TSH	+0.63	TSHTSH	0.5		F3453	reso	22H00209	H	500DP	290406
5437			0.00	0	MAI	1	TSH	+0.63	TSHTSH	0.0		F3453	reso	22H00209	H	500DP	290406
5438			4.00	182	DNG	P 1	02C	+15.28	TSHTEC			H2949	seco	22C00065	H	580UL	287821

5439			3.48	180	DNG	P 1	02C	+15.46	TSHTEC			D4576	seco	22C00064	H	600CS	341611

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 112

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5440	50	126			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5441			0.00	0	MAI	3	TSH	+0.66	TSHTSH	0.0		F3453	reso	22H00179	H	600PP	345326
5442			0.15	98	MAI	4	TSH	+0.66	TSHTSH	0.3		F3453	reso	22H00179	H	600PP	345326
5443			0.12	62	PID	4	TSH	+0.66	TSHTSH	080		M1680	reso	22H00200	H	600PP	345330
5444	58	126	2.55	183	DNG	P 1	VM	+19.25	TECTEH			F1726	seco	22H00104	H	600UL	340824
5445	68	126			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
5446			0.17	91	PID	4	TSH	+0.16	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5447			0.16	106	SAI	2	TSH	+0.16	TSHTSH	0.2		C5542	reso	22H00131	H	600PP	345295
5448			0.00	0	SAI	1	TSH	+0.16	TSHTSH	0.0		D8661	reso	22H00131	H	600PP	345295
5449	82	126	0.68	73	MBM	5	01H	+9.15	TECTEH			M7006	reso	22H00104	H	600UL	340824
5450	96	126	16.72	181	DNG	P 1	08H	+12.79	TECTEH			K2032	seco	22H00030	H	600UL	331892
5451			46.75	177	DNG	P 1	08H	+13.94	TECTEH			K2032	seco	22H00030	H	600UL	331892
5452			10.61	183	DNG	P 1	08H	+15.98	TECTEH			K2032	seco	22H00030	H	600UL	331892
5453					INF		08H	+17.03	TECTEH	HR		A9608	reso	22H00030	H	600UL	331892
5454			2.00	182	DNT	P 1	09H	+0.45	TECTEH			K2032	seco	22H00030	H	600UL	331892
5455			0.64	61	MBM	5	VM	+11.20	TECTEH			L2157	reso	22H00030	H	600UL	331892
5456			4.18	180	DNG	P 1	08C	+7.97	TECTEH			K2032	seco	22H00030	H	600UL	331892
			3.68	181	DNG	P 1	07C	+3.10	TECTEH			K2032	seco	22H00030	H	600UL	331892
[illegible]			7.84	181	DNG	P 1	07C	+15.46	TECTEH			K2032	seco	22H00030	H	600UL	331892
5459			0.44	67	MBM	5	02C	+31.96	TECTEH			L2157	reso	22H00030	H	600UL	331892
5460	98	126	2.67	182	DNG	P 1	08C	+5.25	TECTEH			I3805	seco	22H00031	H	600UL	340830
5461			0.68	75	MBM	5	02C	+7.44	TECTEH			F6623	reso	22H00031	H	600UL	340830
5462	102	126	3.73	180	DNG	P 1	08H	+7.61	TECTEH			I3805	seco	22H00031	H	600UL	340830
5463			2.33	180	DNG	P 1	08H	+10.68	TECTEH			I3805	seco	22H00031	H	600UL	340830
5464			2.27	180	DNG	P 1	08C	+19.22	TECTEH			I3805	seco	22H00031	H	600UL	340830
5465	104	126	1.49	93	MBM	5	03H	+9.56	TECTEH			L2157	reso	22H00030	H	600UL	331892
5466	110	126	4.67	180	DNG	P 1	08H	+4.45	TECTEH			I3805	seco	22H00031	H	600UL	340830
5467	112	126			INF		09H	-1.62	TECTEH	HR		L2157	reso	22H00030	H	600UL	331892
5468			4.33	181	DNG	P 1	09H	+1.57	TECTEH			K2032	seco	22H00030	H	600UL	331892
5469			2.85	183	DNG	P 1	08C	+12.26	TECTEH			K2032	seco	22H00030	H	600UL	331892
5470	114	126	63.66	183	DNT	P 1	09H	-0.02	TECTEH			I3805	seco	22H00031	H	600UL	340830
5471					NDF		09H	-0.02	09H09H			M7007	prim	22H00203	H	600PP	345330
5472	118	126	9.27	181	DNT	P 1	10C	+0.55	TECTEH			I3805	seco	22H00031	H	600UL	340830
5473	120	126	5.83	182	DNT	P 1	10C	+0.43	TECTEH			I3805	seco	22H00031	H	600UL	340830
5474	3	127	0.58	90	INR	9	TSH	+0.40	TSHTSH			C5542	reso	22H00131	H	600PP	345295
5475	13	127	2.49	188	DNG	P 1	01H	+3.01	TECTEH			F0075	seco	22H00100	H	600UL	340824
5476	35	127			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5477			0.16	28	SAI	1	TSH	+0.71	TSHTSH	0.3		C5542	reso	22H00131	H	600PP	345295
5478			0.24	87	SAI	2	TSH	+0.71	TSHTSH	0.2		C5542	reso	22H00131	H	600PP	345295
5479			0.17	111	PID	4	TSH	+0.71	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5480	49	127	2.17	179	DNG	P 1	03C	+13.32	TECTEH			F0075	seco	22H00100	H	600UL	340824
5481	55	127	0.60	95	MBM	5	02H	+19.67	TECTEH			C3340	reso	22H00099	H	600UL	331890
[illegible]	57	127	0.58	74	MBM	5	04H	+8.46	TECTEH			F6623	reso	22H00100	H	600UL	340824
	65	127	3.37	182	DNG	P 1	04C	+12.87	TECTEH			K2032	seco	22H00099	H	600UL	331890
5484	77	127			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
5485			0.18	70	PID	4	TSH	+0.22	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5486			0.00	0	SAI	1	TSH	+0.22	TSHTSH	0.0		A9608	reso	22H00130	H	600PP	345352
5487			0.19	92	SAI	2	TSH	+0.22	TSHTSH	0.2		C5542	reso	22H00130	H	600PP	345352

5488			0.54	108	MBM	5	07C	+9.57	TECTEH			F6623	reso	22H00100	H	600UL	340824

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 113

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5489			0.43	103	MBM	5	03C	+29.93	TECTEH			F6623	reso	22H00100	H	600UL	340824
5490	91	127	7.81	183	DNT	P 1	09H	-0.21	TECTEH			K2032	seco	22H00030	H	600UL	331892
5491	93	127	1.30	58	MBM	6	TSH	+14.93	TECTEH			L2157	reso	22H00030	H	600UL	331892
5492	95	127	1.25	93	MBM	5	01H	+18.39	TECTEH			F6623	reso	22H00031	H	600UL	340830
5493			39.72	183	DNT	P 1	09H	-0.13	TECTEH			I3805	seco	22H00031	H	600UL	340830
5494	97	127	2.19	179	DNT	P 1	09H	-0.02	TECTEH			K2032	seco	22H00030	H	600UL	331892
5495	101	127	0.52	85	MBM	5	05H	+12.87	TECTEH			L2157	reso	22H00030	H	600UL	331892
5496	107	127	2.84	180	DNG	P 1	02H	+1.47	TECTEH			S4373	reso	22H00031	H	600UL	340830
5497	115	127	2.68	181	DNG	P 1	02C	+35.33	TECTEH			I3805	seco	22H00031	H	600UL	340830
5498	117	127			INF		DH	+22.40	TECTEH	HR		L2157	reso	22H00030	H	600UL	331892
5499			2.62	178	DNG	P 1	DH	+24.19	TECTEH			L2157	reso	22H00030	H	600UL	331892
5500			2.44	88	MBM	6	04C	+33.10	TECTEH			L2157	reso	22H00030	H	600UL	331892
5501	2	128	0.39	79	PLP	9	TSH	+0.64	TSHTSH			A9608	reso	22H00137	H	600PP	345295
5502	10	128	4.83	1	IDM	2	06C	+3.12	05H06C			N5432	reso	22H00213	H	5602C	340934
5503	20	128			TBP				TECTEH	SVISLV	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5504			1.67	29	PID	3	SBH	+2.39	SBHSTH			D3858	prim	22H00238	H	500PP	326655
5505			1.52	47	SVI	3	SBH	+2.39	SBHSTH			D3858	prim	22H00236	H	500PP	326655
			0.15	15	SCI	1	TSH	-0.04	TSHTSH	0.1	PWSCC	C5542	reso	22H00136	H	600PP	345352
			0.27	22	PID	P 1	TSH	-0.04	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5508			0.20	22	SCI	P 1	TSH	-0.04	TSHTSH	0.1	PWSCC	C5542	reso	22H00136	H	600PP	345352
5509	32	128	4.60	179	DNT	P 1	VM	+1.29	TECTEH			F0075	seco	22H00100	H	600UL	340824
5510	36	128	3.80	183	DNG	P 1	TSH	+14.21	TECTEH			K2032	seco	22H00099	H	600UL	331890
5511	38	128	2.35	181	DNG	P 1	04H	+35.78	TECTEH			F0075	seco	22H00100	H	600UL	340824
5512	60	128			TBS				TECTEH			D3858	reso	22H00044	H	600UL	331892
5513			0.18	105	PID	4	TSH	+0.27	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5514			0.17	97	MAI	2	TSH	+0.27	TSHTSH	0.2		C5542	reso	22H00130	H	600PP	345352
5515			0.16	83	MAI	1	TSH	+0.27	TSHTSH	0.2		C5542	reso	22H00130	H	600PP	345352
5516	68	128			TBP				TECTEH	FAILSLV	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5517			0.15	79	PID	4	TSH	+0.20	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
5518			0.00	0	SAI	3	TSH	+0.20	TSHTSH	0.0		F3453	reso	22H00179	H	600PP	345326
5519			0.16	76	SAI	4	TSH	+0.20	TSHTSH	0.2		F3453	reso	22H00179	H	600PP	345326
5520	70	128	4.42	188	DNG	P 1	01H	+36.78	TECTEH			F0075	seco	22H00100	H	600UL	340824
5521	80	128	2.93	186	DNG	P 1	04C	+37.27	TECTEH			F6623	reso	22H00100	H	600UL	340824
5522	94	128	3.33	182	DNG	P 1	08H	+12.01	TECTEH			I3805	seco	22H00031	H	600UL	340830
5523			2.86	181	DNG	P 1	08H	+14.92	TECTEH			I3805	seco	22H00031	H	600UL	340830
5524			2.34	183	DNG	P 1	08H	+17.17	TECTEH			I3805	seco	22H00031	H	600UL	340830
5525			4.14	182	DNG	P 1	08C	+4.86	TECTEH			I3805	seco	22H00031	H	600UL	340830
5526			7.41	184	DNG	P 1	08C	+9.62	TECTEH			I3805	seco	22H00031	H	600UL	340830
5527	96	128	2.18	180	DNG	P 1	06H	+5.66	TECTEH			K2032	seco	22H00030	H	600UL	331892
5528			2.42	178	DNG	P 1	07H	+3.03	TECTEH			K2032	seco	22H00030	H	600UL	331892
5529			2.75	179	DNG	P 1	07H	+16.50	TECTEH			K2032	seco	22H00030	H	600UL	331892
5530			3.64	179	DNG	P 1	07H	+21.91	TECTEH			K2032	seco	22H00030	H	600UL	331892
			5.62	182	DNG	P 1	07H	+22.51	TECTEH			K2032	seco	22H00030	H	600UL	331892
			2.37	178	DNG	P 1	07H	+23.32	TECTEH			K2032	seco	22H00030	H	600UL	331892
5533			13.04	179	DNG	P 1	07H	+24.30	TECTEH			K2032	seco	22H00030	H	600UL	331892
5534			21.48	181	DNG	P 1	08H	+12.60	TECTEH			K2032	seco	22H00030	H	600UL	331892
5535			24.82	180	DNG	P 1	08H	+13.68	TECTEH			K2032	seco	22H00030	H	600UL	331892
5536			6.00	179	DNG	P 1	08H	+14.13	TECTEH			K2032	seco	22H00030	H	600UL	331892

5537			9.29	178	DNG	P 1	08H	+14.40		TECTEH				K2032	seco	22H00030	H	600UL	331892

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 114

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5538			6.43	180	DNG	P 1	08H	+14.55	TECTEH			K2032	seco	22H00030	H	600UL	331892
5539			6.56	179	DNG	P 1	08H	+15.20	TECTEH			K2032	seco	22H00030	H	600UL	331892
5540			9.32	181	DNG	P 1	08H	+15.47	TECTEH			K2032	seco	22H00030	H	600UL	331892
5541			6.14	177	DNG	P 1	08H	+16.46	TECTEH			K2032	seco	22H00030	H	600UL	331892
5542			4.45	172	DNG	P 1	08H	+17.51	TECTEH			K2032	seco	22H00030	H	600UL	331892
5543			3.73	171	DNG	P 1	08H	+18.31	TECTEH			K2032	seco	22H00030	H	600UL	331892
5544			7.22	173	DNG	P 1	08H	+18.92	TECTEH			K2032	seco	22H00030	H	600UL	331892
5545			5.48	174	DNG	P 1	08H	+19.48	TECTEH			K2032	seco	22H00030	H	600UL	331892
5546			8.12	176	DNG	P 1	08H	+20.35	TECTEH			K2032	seco	22H00030	H	600UL	331892
5547			9.32	175	DNG	P 1	08H	+21.13	TECTEH			K2032	seco	22H00030	H	600UL	331892
5548			14.18	178	DNT	P 1	09H	-0.83	TECTEH			K2032	seco	22H00030	H	600UL	331892
5549			17.19	178	DNT	P 1	09H	-0.56	TECTEH			K2032	seco	22H00030	H	600UL	331892
5550			10.93	180	DNT	P 1	09H	+0.11	TECTEH			K2032	seco	22H00030	H	600UL	331892
5551			44.38	178	DNT	P 1	09H	+0.55	TECTEH			K2032	seco	22H00030	H	600UL	331892
5552			14.32	180	DNT	P 1	09C	+0.07	TECTEH			K2032	seco	22H00030	H	600UL	331892
5553			21.50	181	DNT	P 1	09C	+0.70	TECTEH			K2032	seco	22H00030	H	600UL	331892
5554			9.19	180	DNT	P 1	09C	+1.43	TECTEH			K2032	seco	22H00030	H	600UL	331892
			4.24	177	DNG	P 1	08C	+2.66	TECTEH			K2032	seco	22H00030	H	600UL	331892
	98	128	6.24	183	DNT	P 1	09H	-0.26	TECTEH			I3805	seco	22H00031	H	600UL	340830
5557			3.93	184	DNG	P 1	VH	+27.75	TECTEH			F6623	reso	22H00031	H	600UL	340830
5558			2.97	185	DNG	P 1	09C	+1.14	TECTEH			S4373	reso	22H00031	H	600UL	340830
5559	108	128	8.53	181	DNT	P 1	09H	+0.00	TECTEH			K2032	seco	22H00030	H	600UL	331892
5560					NDF		09H	+0.00	09H09H			M7007	prim	22H00203	H	600PP	345330
5561	114	128	14.68	184	DNT	P 1	09H	-0.22	TECTEH			I3805	seco	22H00031	H	600UL	340830
5562	1	129			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
5563			0.21	79	INR	9	TSH	+0.19	TSHTSH			A9608	reso	22H00137	H	600PP	345295
5564			0.23	58	SVI	1	TSH	+0.28	TSHTSH	0.3		A9608	reso	22H00137	H	600PP	345295
5565			0.19	106	SVI	2	TSH	+0.28	TSHTSH	0.2		A9608	reso	22H00137	H	600PP	345295
5566			0.20	102	PID	4	TSH	+0.28	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5567	5	129	0.33	80	PLP	9	TSH	+0.39	TSHTSH			A9608	reso	22H00137	H	600PP	345295
5568	7	129	6.13	177	DNG	P 1	06H	+9.61	TECTEH			C3340	reso	22H00099	H	600UL	331890
5569	15	129			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
5570			3.88	179	DNG	P 1	06H	+3.51	TECTEH			K2032	seco	22H00099	H	600UL	331890
5571			2.07	54	GEO	P 1	VM	-0.18	05H06C			D3858	reso	22H00213	H	5602C	340934
5572			0.34	21	PID	2	VM	-0.18	05H06C			S4373	reso	22H00232	H	5602C	340984
5573			24.18	181	DNT	P 1	VM	-0.11	TECTEH			K2032	seco	22H00099	H	600UL	331890
5574	17	129	0.53	62	MBM	5	02C	+6.08	TECTEH			F6623	reso	22H00100	H	600UL	340824
5575	37	129			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5576			0.09	63	PID	4	TSH	+0.69	TSHTSH	080		M1680	reso	22H00200	H	600PP	345330
5577			0.12	91	SAI	4	TSH	+0.69	TSHTSH	0.2		F3453	reso	22H00179	H	600PP	345326
5578			0.00	0	SAI	3	TSH	+0.69	TSHTSH	0.0		F3453	reso	22H00179	H	600PP	345326
5579	49	129			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5580			0.13	84	SAI	2	TSH	+0.15	TSHTSH	0.2		A9608	reso	22H00137	H	600PP	345295
			0.00	0	SAI	1	TSH	+0.15	TSHTSH	0.0		A9608	reso	22H00137	H	600PP	345295
5582			0.15	149	PID	4	TSH	+0.15	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5583			2.78	182	DNG	P 1	02H	+32.55	TECTEH			K2032	seco	22H00099	H	600UL	331890
5584	63	129	4.93	178	DNG	P 1	01C	+29.99	TECTEH			F0075	seco	22H00100	H	600UL	340824
5585	77	129	1.67	66	ADR	6	VH	+10.60 TO+12.78	TECTEH			F6623	reso	22H00100	H	600UL	340824

5586					NDF	VH		+10.60 TO+12.78	DH 08C				S4373	reso	22C00092	H	5602C	326272

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 115

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5587		0.18	113	VOL	2	VH	+12.32 TO+13.54	DH 08C			L2157	reso	22C00092	H	5602C	326272
5588		0.21	122	VOL	2	VH	+18.02	DH 08C			L2157	reso	22C00092	H	5602C	326272
5589	83 129	0.56	59	MBM	6	03H	+31.82	TECTEH			C3340	reso	22H00099	H	600UL	331890
5590		0.47	51	MBM	6	04C	+23.39	TECTEH			C3340	reso	22H00099	H	600UL	331890
5591	87 129	1.08	74	MBM	5	TSH	+8.99	TECTEH			C3340	reso	22H00099	H	600UL	331890
5592	91 129	3.33	182	DNG	P 1	07H	+19.29	TECTEH			K2032	seco	22H00030	H	600UL	331892
5593		2.56	174	DNT	P 1	08H	+0.86	TECTEH			K2032	seco	22H00030	H	600UL	331892
5594		13.99	180	DNG	P 1	08H	+7.97	TECTEH			K2032	seco	22H00030	H	600UL	331892
5595		9.68	178	DNG	P 1	08H	+9.89	TECTEH			K2032	seco	22H00030	H	600UL	331892
5596		20.29	180	DNG	P 1	08H	+10.93	TECTEH			K2032	seco	22H00030	H	600UL	331892
5597		4.85	182	DNG	P 1	07C	+12.31	TECTEH			K2032	seco	22H00030	H	600UL	331892
5598		2.52	180	DNG	P 1	07C	+24.04	TECTEH			K2032	seco	22H00030	H	600UL	331892
5599	93 129	16.38	180	DNT	P 1	09H	+1.32	TECTEH			K2032	seco	22H00030	H	600UL	331892
5600		3.03	177	DNG	P 1	08C	+8.67	TECTEH			K2032	seco	22H00030	H	600UL	331892
5601		2.90	177	DNG	P 1	08C	+14.67	TECTEH			K2032	seco	22H00030	H	600UL	331892
5602	101 129	0.66	100	MBM	5	02H	+5.63	TECTEH			F6623	reso	22H00031	H	600UL	340830
5603	103 129	19.87	182	DNT	P 1	09H	-0.09	TECTEH			K2032	seco	22H00030	H	600UL	331892
	6 130			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
[illegible]		0.41	12	PID	4	TSH	-3.96	TSHTSH	080		C3340	reso	22H00202	H	600PP	345330
5606		0.12	19	SAI	2	TSH	-3.96	TSHTSH	0.2	PWSCC	C5542	reso	22H00137	H	600PP	345295
5607		0.18	17	SAI	1	TSH	-3.96	TSHTSH	0.2	PWSCC	C5542	reso	22H00137	H	600PP	345295
5608	30 130	2.05	175	DNG	P 1	01C	+26.40	TECTEH			M9715	seco	22H00097	H	600UL	331890
5609	40 130	3.54	173	DNG	P 1	05H	+29.78	TECTEH			M9715	seco	22H00097	H	600UL	331890
5610	42 130			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5611		0.15	85	PID	4	TSH	+0.62	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5612		0.20	113	SAI	1	TSH	+0.62	TSHTSH	0.2		C5542	reso	22H00136	H	600PP	345352
5613		0.16	94	SAI	2	TSH	+0.62	TSHTSH	0.3		C5542	reso	22H00136	H	600PP	345352
5614		2.19	177	DNT	P 1	06H	+0.38	TECTEH			M9715	seco	22H00097	H	600UL	331890
5615		2.41	184	DNT	P 1	07C	+0.51	TECTEH			M9715	seco	22H00097	H	600UL	331890
5616	50 130			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5617		0.11	93	SAI	2	TSH	+0.08	TSHTSH	0.2		C5542	reso	22H00136	H	600PP	345352
5618		0.09	105	PID	4	TSH	+0.08	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5619		0.00	0	SAI	1	TSH	+0.08	TSHTSH	0.0		C5542	reso	22H00136	H	600PP	345352
5620	52 130			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5621		0.25	39	SAI	1	TSH	+0.20	TSHTSH	0.2		A9608	reso	22H00137	H	600PP	345295
5622		0.21	85	SAI	2	TSH	+0.20	TSHTSH	0.2		A9608	reso	22H00137	H	600PP	345295
5623		0.24	81	PID	4	TSH	+0.20	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5624		0.09	93	SAI	2	TSH	+0.52	TSHTSH	0.2		A9608	reso	22H00137	H	600PP	345295
5625		0.00	0	SAI	1	TSH	+0.52	TSHTSH	0.0		C5542	reso	22H00137	H	600PP	345295
5626	72 130	2.10	175	DNG	P 1	03H	+14.64	TECTEH			K2032	seco	22H00099	H	600UL	331890
5627	92 130	2.98	179	DNT	P 1	08H	-0.42	TECTEH			K2032	seco	22H00030	H	600UL	331892
5628		8.58	180	DNG	P 1	08H	+1.62	TECTEH			K2032	seco	22H00030	H	600UL	331892
[illegible]		4.62	178	DNG	P 1	08H	+2.16	TECTEH			K2032	seco	22H00030	H	600UL	331892
		4.62	179	DNG	P 1	08H	+2.18	TECTEH			K2032	seco	22H00030	H	600UL	331892
5631		2.70	178	DNG	P 1	08H	+2.68	TECTEH			K2032	seco	22H00030	H	600UL	331892
5632		2.70	182	DNG	P 1	08H	+2.70	TECTEH			K2032	seco	22H00030	H	600UL	331892
5633		1.70	181	INR	P 1	08C	+2.46	TECTEH			L2157	reso	22H00030	H	600UL	331892
5634		4.44	180	DNG	P 1	08C	+6.20	TECTEH			K2032	seco	22H00030	H	600UL	331892

5635			9.23	181	DNG	P	1	08C	+8.03		TECTEH				K2032	seco	22H00030	H	600UL	331892

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 116

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5636		12.36	181	DNG	P	1	08C +9.90	TECTEH			K2032	seco	22H00030	H	600UL	331892
5637		1.63	183	INR	P	1	08C +19.85	TECTEH			L2157	reso	22H00030	H	600UL	331892
5638		2.64	181	DNG	P	1	07C +22.17	TECTEH			K2032	seco	22H00030	H	600UL	331892
5639		4.30	177	DNG	P	1	07C +23.03	TECTEH			K2032	seco	22H00030	H	600UL	331892
5640	96	12.18	179	DNG	P	1	08H +2.73	TECTEH			K2032	seco	22H00030	H	600UL	331892
5641		13.55	179	DNG	P	1	08H +13.06	TECTEH			K2032	seco	22H00030	H	600UL	331892
5642		2.67	182	DNT	P	1	09C -0.07	TECTEH			K2032	seco	22H00030	H	600UL	331892
5643		2.25	174	DNG	P	1	09C +1.35	TECTEH			K2032	seco	22H00030	H	600UL	331892
5644		5.53	180	DNG	P	1	09C +2.22	TECTEH			K2032	seco	22H00030	H	600UL	331892
5645		9.25	180	DNG	P	1	08C +8.31	TECTEH			K2032	seco	22H00030	H	600UL	331892
5646		2.00	179	DNG	P	1	08C +19.99	TECTEH			K2032	seco	22H00030	H	600UL	331892
5647		1.79	183	INR	P	1	07C +18.13	TECTEH			L2157	reso	22H00030	H	600UL	331892
5648	98	4.97	181	DNG	P	1	08H +12.24	TECTEH			I3805	seco	22H00031	H	600UL	340830
5649	106	2.07	185	DNG	P	1	09C +12.69	TECTEH			F6623	reso	22H00031	H	600UL	340830
5650	110	0.74	75	MBM		5	03H +22.11	TECTEH			F6623	reso	22H00031	H	600UL	340830
5651	112	0.63	83	MBM		5	TSH +8.53	TECTEH			L2157	reso	22H00030	H	600UL	331892
5652		0.54	83	MBM		5	TSH +13.69	TECTEH			L2157	reso	22H00030	H	600UL	331892
		0.49	70	MBM		5	TSH +16.19	TECTEH			L2157	reso	22H00030	H	600UL	331892
		2.87	181	DNT	P	1	VH +1.66	TECTEH			K2032	seco	22H00030	H	600UL	331892
5655	9			NDF			VM -2.39 TO-1.15	05H06C			D9573	prim	22H00213	H	5602C	340934
5656		2.42	141	ADR		6	VM -2.39 TO-1.15	TECTEH			F6623	reso	22H00097	H	600UL	331890
5657	11	0.45	71	MBM		5	02C +33.00	TECTEH			F6623	reso	22H00097	H	600UL	331890
5658	15	0.83	89	MBM		5	TSH +16.14	TECTEH			F6623	reso	22H00097	H	600UL	331890
5659		0.41	86	MBM		5	TSH +19.87	TECTEH			F6623	reso	22H00097	H	600UL	331890
5660		0.34	70	MBM		5	TSH +32.67	TECTEH			F6623	reso	22H00097	H	600UL	331890
5661		0.72	91	MBM		5	TSH +34.03	TECTEH			F6623	reso	22H00097	H	600UL	331890
5662		0.60	92	MBM		5	TSH +37.51	TECTEH			F6623	reso	22H00097	H	600UL	331890
5663		0.62	81	MBM		5	01H +5.11	TECTEH			F6623	reso	22H00097	H	600UL	331890
5664	17	0.44	70	MBM		5	TSH +29.64	TECTEH			F6623	reso	22H00097	H	600UL	331890
5665		0.31	78	MBM		5	TSH +30.80	TECTEH			F6623	reso	22H00097	H	600UL	331890
5666	19	2.92	178	DNG	P	1	04H +10.46	TECTEH			M9715	seco	22H00097	H	600UL	331890
5667	43	3.21	174	DNG	P	1	03C +35.99	TECTEH			M9715	seco	22H00097	H	600UL	331890
5668	45			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5669		0.14	105	SAI		2	TSH +0.39	TSHTSH	0.3		C5542	reso	22H00136	H	600PP	345352
5670		0.16	120	PID		4	TSH +0.39	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5671		0.18	68	SAI		1	TSH +0.39	TSHTSH	0.3		C5542	reso	22H00136	H	600PP	345352
5672		2.24	178	DNG	P	1	01C +16.52	TECTEH			M9715	seco	22H00097	H	600UL	331890
5673		3.73	177	DNG	P	1	01C +19.11	TECTEH			M9715	seco	22H00097	H	600UL	331890
5674		2.92	177	DNG	P	1	01C +20.38	TECTEH			M9715	seco	22H00097	H	600UL	331890
5675	51	5.41	176	DNT	P	1	05H -0.39	TECTEH			M9715	seco	22H00097	H	600UL	331890
5676	59	0.75	96	MBM		5	05C +14.03	TECTEH			F6623	reso	22H00097	H	600UL	331890
5677	61	2.94	179	DNG	P	1	02C +37.01	TECTEH			M9715	seco	22H00097	H	600UL	331890
[illegible]	71	0.59	80	MBM		5	05H +32.44	TECTEH			F6623	reso	22H00097	H	600UL	331890
	79	3.05	174	DNG	P	1	04C +25.56	TECTEH			M9715	seco	22H00097	H	600UL	331890
5680	91	6.72	181	DNG	P	1	06H +21.67	TECTEH			K2032	seco	22H00030	H	600UL	331892
5681		4.64	183	DNT	P	1	09C -0.48	TECTEH			K2032	seco	22H00030	H	600UL	331892
5682		3.78	181	DNG	P	1	08C +2.35	TECTEH			K2032	seco	22H00030	H	600UL	331892
5683		2.71	181	DNG	P	1	08C +7.94	TECTEH			K2032	seco	22H00030	H	600UL	331892

5684			5.15	180	DNG	P 1	08C	+20.98	TECTEH			K2032	seco	22H00030	H	600UL		331892

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 117

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5685	95	131	3.11	181	DNG	P 1	08H	+6.54	TECTEH			I3805	seco	22H00031	H	600UL	340830
5686	101	131	9.29	188	DNT	P1	09H	+0.05	TECTEH			K2032	seco	22H00030	H	600UL	331892
5687	103	131	6.60	178	DNT	P 1	09H	+0.20	TECTEH			I3805	seco	22H00031	H	600UL	340830
5688			2.16	181	DNG	P 1	05C	+1.70	TECTEH			S4373	reso	22H00031	H	600UL	340830
5689	105	131	1.89	181	INR	P 1	08C	+7.89	TECTEH			L2157	reso	22H00030	H	600UL	331892
5690	30	132	9.62	178	DNT	P 1	06H	+0.09	TECTEH			M9715	seco	22H00097	H	600UL	331890
5691	42	132			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5692			0.21	100	SAI	2	TSH	+0.16	TSHTSH	0.3		C5542	reso	22H00136	H	600PP	345352
5693			0.22	36	SAI	1	TSH	+0.16	TSHTSH	0.3		C5542	reso	22H00136	H	600PP	345352
5694			0.23	113	PID	4	TSH	+0.16	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5695	48	132	3.36	174	DNT	P 1	03H	-1.12	TECTEH			M9715	seco	22H00097	H	600UL	331890
5696	54	132	3.84	187	DNG	P 1	VM	+16.29	TECTEH			H2949	seco	22H00110	H	600UL	340929
5697	60	132	3.63	178	DNG	P 1	VM	+19.76	TECTEH			M9715	seco	22H00097	H	600UL	331890
5698			2.84	181	DNG	P 1	03C	+15.44	TECTEH			M9715	seco	22H00097	H	600UL	331890
5699			2.51	180	DNG	P 1	03C	+23.52	TECTEH			M9715	seco	22H00097	H	600UL	331890
5700			2.25	179	DNG	P 1	03C	+29.93	TECTEH			M9715	seco	22H00097	H	600UL	331890
5701			2.20	177	DNG	P 1	03C	+32.87	TECTEH			M9715	seco	22H00097	H	600UL	331890
	62	132	0.73	83	MBM	5	03H	+17.97	TECTEH			F6623	reso	22H00097	H	600UL	331890
	92	132	4.05	182	DNG	P 1	08C	+5.17	TECTEH			K2032	seco	22H00030	H	600UL	331892
5704	96	132	2.89	176	DNG	P 1	08H	+14.52	TECTEH			K2032	seco	22H00030	H	600UL	331892
5705			14.84	180	DNG	P 1	08H	+15.56	TECTEH			K2032	seco	22H00030	H	600UL	331892
5706			3.58	182	DNG	P 1	07C	+15.05	TECTEH			K2032	seco	22H00030	H	600UL	331892
5707	104	132	3.88	182	DNG	P 1	08H	+2.45	TECTEH			K2032	seco	22H00030	H	600UL	331892
5708	110	132	16.77	181	DNG	P 1	VH	+28.34	TECTEH			I3805	seco	22H00031	H	600UL	340830
5709	112	132	0.51	84	MBM	5	03H	+2.50	TECTEH			L2157	reso	22H00030	H	600UL	331892
5710	5	133	0.71	80	MBM	6	TSC	+6.05	06HTEC			L2157	reso	22C00066	C	600CS	341219
5711	15	133	1.91	178	INR	P 1	01C	+27.61	TECTEH			F6623	reso	22H00097	H	600UL	331890
5712	19	133	4.26	174	DNG	P 1	04H	+12.31	TECTEH			F7467	seco	22H00097	H	600UL	331890
5713	27	133			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5714			0.11	92	PID	4	TSH	+0.69	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5715			0.14	84	SAI	2	TSH	+0.69	TSHTSH	0.2		C5542	reso	22H00136	H	600PP	345352
5716			0.00	0	SAI	1	TSH	+0.69	TSHTSH	0.0		C5542	reso	22H00136	H	600PP	345352
5717	41	133	0.83	62	MBM	5	DH	+7.29	TECTEH			F6623	reso	22H00097	H	600UL	331890
5718			0.61	87	MBM	5	03C	+2.43	TECTEH			F6623	reso	22H00097	H	600UL	331890
5719			0.50	77	MBM	5	02C	+4.51	TECTEH			F6623	reso	22H00097	H	600UL	331890
5720			0.50	96	MBM	5	02C	+8.33	TECTEH			F6623	reso	22H00097	H	600UL	331890
5721			0.48	83	MBM	5	02C	+29.74	TECTEH			F6623	reso	22H00097	H	600UL	331890
5722			0.72	105	MBM	5	02C	+36.52	TECTEH			F6623	reso	22H00097	H	600UL	331890
5723	43	133	4.23	184	DNG	P 1	03H	+13.12	TECTEH			F0075	seco	22H00096	H	600UL	340909
5724			3.10	180	DNG	P 1	01C	+33.34	TECTEH			F0075	seco	22H00096	H	600UL	340909
5725	67	133	8.48	178	DNG	P 1	07H	+2.40	TECTEH			F7467	seco	22H00097	H	600UL	331890
5726			7.55	178	DNG	P 1	07H	+14.33	TECTEH			F7467	seco	22H00097	H	600UL	331890
	69	133	3.18	180	DNG	P 1	TSH	+21.38	TECTEH			F4645	seco	22H00096	H	600UL	340909
	87	133	1.45	87	MBM	5	08C	+12.09	TECTEH			F6623	reso	22H00097	H	600UL	331890
5729	91	133	3.98	190	DNT	P 1	09H	+0.69	TECTEH			K2032	seco	22H00030	H	600UL	331892
5730			7.85	181	DNG	P 1	08C	+16.77	TECTEH			K2032	seco	22H00030	H	600UL	331892
5731			5.30	179	DNG	P 1	08C	+17.34	TECTEH			K2032	seco	22H00030	H	600UL	331892
5732			13.85	180	DNG	P 1	08C	+18.41	TECTEH			K2032	seco	22H00030	H	600UL	331892

5733					INF	08C	+19.63	TECTEH	HR			L2157	reso	22H00030	H	600UL	331892

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 118

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5734	93	133	2.68	182	DNG	P 1	08H +13.48	TECTEH			K2032	seco	22H00030	H	600UL	331892
5735			6.67	181	DNG	P 1	08H +15.25	TECTEH			K2032	seco	22H00030	H	600UL	331892
5736			5.79	181	DNG	P 1	08C +3.22	TECTEH			K2032	seco	22H00030	H	600UL	331892
5737			2.46	177	DNG	P 1	08C +4.95	TECTEH			K2032	seco	22H00030	H	600UL	331892
5738			4.94	179	DNG	P 1	08C +5.91	TECTEH			K2032	seco	22H00030	H	600UL	331892
5739			3.00	176	DNG	P 1	08C +6.50	TECTEH			K2032	seco	22H00030	H	600UL	331892
5740			4.91	180	DNG	P 1	08C +7.38	TECTEH			K2032	seco	22H00030	H	600UL	331892
5741			3.72	182	DNG	P 1	08C +17.14	TECTEH			K2032	seco	22H00030	H	600UL	331892
5742					INF	08C	+18.50	TECTEH	HR		L2157	reso	22H00030	H	600UL	331892
5743			3.78	181	DNG	P 1	08C +19.55	TECTEH			K2032	seco	22H00030	H	600UL	331892
5744	30	134	2.16	180	DNT	P 1	VM +1.93	TECTEH			T7451	seco	22H00095	H	600UL	331890
5745	34	134	0.91	86	MBM	5	02C +16.33	TECTEH			F6623	reso	22H00094	H	600UL	340909
5746	40	134	3.26	179	DNG	P 1	VM +9.86	TECTEH			H4599	seco	22H00094	H	600UL	340909
5747	46	134			TBP			TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5748			0.10	95	PID	4	TSH +0.24	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5749			0.11	100	SAI	2	TSH +0.24	TSHTSH	0.2		C5542	reso	22H00136	H	600PP	345352
5750			0.00	0	SAI	1	TSH +0.24	TSHTSH	0.0		C5542	reso	22H00136	H	600PP	345352
	56	134	3.16	177	DNG	P 1	VM +17.62	TECTEH			F7467	seco	22H00097	H	600UL	331890
[illegible]			2.06	180	DNG	P 1	TSC +18.66	TECTEH			F7467	seco	22H00097	H	600UL	331890
5753	68	134	3.29	175	DNG	P 1	06H +5.95	TECTEH			F7467	seco	22H00097	H	600UL	331890
5754			5.81	175	DNG	P 1	07H +1.55	TECTEH			F7467	seco	22H00097	H	600UL	331890
5755			3.45	175	DNG	P 1	07H +13.67	TECTEH			F7467	seco	22H00097	H	600UL	331890
5756			11.73	176	DNG	P 1	07H +18.22	TECTEH			F7467	seco	22H00097	H	600UL	331890
5757			16.77	177	DNG	P 1	07C +12.33	TECTEH			F7467	seco	22H00097	H	600UL	331890
5758			7.41	175	DNG	P 1	07C +13.31	TECTEH			F7467	seco	22H00097	H	600UL	331890
5759			2.68	178	DNG	P 1	06C +12.82	TECTEH			F7467	seco	22H00097	H	600UL	331890
5760	70	134	0.71	69	MBM	5	DH +6.89	TECTEH			F3453	reso	22H00096	H	600UL	340909
5761			1.35	90	MBM	5	04C +23.62	TECTEH			F3453	reso	22H00096	H	600UL	340909
5762	76	134	0.56	91	MBM	5	VH +28.33	TECTEH			F6623	reso	22H00097	H	600UL	331890
5763	80	134	5.56	175	DNG	P 1	TSH +18.71	TECTEH			F7467	seco	22H00097	H	600UL	331890
5764	92	134	2.38	180	DNG	P 1	08H +7.51	TECTEH			K2032	seco	22H00030	H	600UL	331892
5765			3.23	180	DNT	P 1	08C -0.16	TECTEH			K2032	seco	22H00030	H	600UL	331892
5766			4.30	178	DNT	P 1	08C +0.81	TECTEH			K2032	seco	22H00030	H	600UL	331892
5767	94	134	0.25	111	12	P 2	VC +0.48	TECTEH			F6623	reso	22H00031	H	600UL	340830
5768	96	134	7.21	180	DNG	P 1	08H +19.00	TECTEH			K2032	seco	22H00030	H	600UL	331892
5769			2.29	182	DNT	P 1	09H +0.48	TECTEH			K2032	seco	22H00030	H	600UL	331892
5770			11.68	180	DNT	P 1	09H +1.07	TECTEH			K2032	seco	22H00030	H	600UL	331892
5771			3.79	177	DNG	P 1	07C +18.43	TECTEH			K2032	seco	22H00030	H	600UL	331892
5772	98	134	0.70	94	MBM	5	01C +21.18	TECTEH			F6623	reso	22H00031	H	600UL	340830
5773	110	134	2.80	181	DNG	P 1	VH +28.43	TECTEH			K2032	seco	22H00030	H	600UL	331892
5774	112	134	6.96	184	DNT	P 1	09H +0.35	TECTEH			I3805	seco	22H00031	H	600UL	340830
5775	29	135			TBP			TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
[illegible]			0.09	72	PID	4	TSH +0.95	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
			0.00	0	SAI	1	TSH +0.95	TSHTSH	0.0		C5542	reso	22H00140	H	600PP	345352
5778			0.09	80	SAI	2	TSH +0.95	TSHTSH	0.2		C5542	reso	22H00140	H	600PP	345352
5779	35	135			TBP			TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5780			0.23	88	SAI	2	TSH +0.66	TSHTSH	0.2		S4373	reso	22H00140	H	600PP	345352
5781			0.17	99	PID	4	TSH +0.66	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326

5782			0.18	55	SAI	1	TSH	+0.66	TSHTSH	0.2			S4373	reso	22H00140	H	600PP	345352

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 119

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5783	73	135	3.03	179	DNG	P	1	08C +6.08	TECTEH			H4599	seco	22H00094	H	600UL	340909
5784	91	135	0.34	78	MBM	5	1	01H +4.64	TECTEH			L2157	reso	22H00030	H	600UL	331892
5785	101	135	7.24	182	DNT	P	1	09H +0.02	TECTEH			I3805	seco	22H00031	H	600UL	340830
5786	103	135	2.90	182	DNG	P	1	07H +21.64	TECTEH			K2032	seco	22H00030	H	600UL	331892
5787			1.97	183	INR	P	1	04C +19.26	TECTEH			L2157	reso	22H00030	H	600UL	331892
5788	107	135	4.99	182	DNG	P	1	01H +8.07	TECTEH			K2032	seco	22H00030	H	600UL	331892
5789	38	136	6.88	183	DNG	P	1	VM +2.35	TECTEH			F6623	reso	22H00094	H	600UL	340909
5790	54	136	2.15	178	DNG	P	1	05C +22.17	TECTEH			H4599	seco	22H00094	H	600UL	340909
5791	62	136	0.74	81	MBM	5	1	05H +16.72	TECTEH			F3453	reso	22H00095	H	600UL	331890
5792			1.39	71	MBM	6	1	07H +4.61	TECTEH			F3453	reso	22H00095	H	600UL	331890
5793	80	136	5.51	177	DNG	P	1	TSH +7.60	TECTEH			H4599	seco	22H00094	H	600UL	340909
5794	94	136	2.67	180	DNG	P	1	08H +18.38	TECTEH			I3805	seco	22H00031	H	600UL	340830
5795			43.58	183	DNT	P	1	09H -0.11	TECTEH			I3805	seco	22H00031	H	600UL	340830
5796			6.44	180	DNG	P	1	09H +1.57	TECTEH			I3805	seco	22H00031	H	600UL	340830
5797	96	136	7.07	183	DNT	P	1	09H -0.07	TECTEH			K2032	seco	22H00030	H	600UL	331892
5798	98	136	49.26	182	DNT	P	1	09H +0.07	TECTEH			F6623	reso	22H00031	H	600UL	340830
5799	100	136			NDF			09H +0.11	09H09H			M7007	prim	22H00203	H	600PP	345330
			90.85	178	DNT	P	1	09H +0.11	TECTEH			K2032	seco	22H00030	H	600UL	331892
	102	136	0.52	89	MBM	5	1	08H +14.11	TECTEH			F6623	reso	22H00031	H	600UL	340830
5802					NDF			09H -0.07	09H09H			M7007	prim	22H00203	H	600PP	345330
5803			70.73	183	DNT	P	1	09H -0.07	TECTEH			I3805	seco	22H00031	H	600UL	340830
5804	104	136	4.60	181	DNT	P	1	09H +0.34	TECTEH			K2032	seco	22H00030	H	600UL	331892
5805	5	137	3.37	176	DNG	P	1	03C +36.78	06HTEC			D4576	seco	22C00066	C	600CS	341219
5806	7	137			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
5807			0.47	72	MBM	5	1	02H +26.26	TECTEH			F6623	reso	22H00094	H	600UL	340909
5808					OBS			06H +15.23	05H06H			B4052	prim	22H00218	H	5602C	325931
5809			0.81	86	SAI	2	1	VM +2.43	05H06C	0.2		D8661	reso	22H00233	H	5602C	340984
5810			1.29	11	SAI	1	1	VM +2.43	05H06C	0.2		D8661	reso	22H00233	H	5602C	340984
5811			0.95	66	PID	2	1	VM +2.43	05H06C			N5432	reso	22H00234	H	5602C	340984
5812			0.06	177	SAI	1	1	VM +3.10	05H06C	0.2		D8661	reso	22H00233	H	5602C	340984
5813			0.58	79	SAI	2	1	VM +3.10	05H06C	0.2		D8661	reso	22H00233	H	5602C	340984
5814	17	137	2.29	180	INR	P	1	DH +3.48	TECTEH			T7451	seco	22H00095	H	600UL	331890
5815			2.38	181	INR	P	1	VM -1.89	TECTEH			F3453	reso	22H00095	H	600UL	331890
5816			2.94	181	INR	P	1	VM +1.96	TECTEH			F3453	reso	22H00095	H	600UL	331890
5817	25	137	2.77	176	DNG	P	1	03C +36.44	TECTEH			H4599	seco	22H00094	H	600UL	340909
5818	33	137	3.59	184	DNT	P	1	VM -1.77	TECTEH			H4599	seco	22H00094	H	600UL	340909
5819	41	137	7.32	186	DNG	P	1	07C +8.37	TECTEH			H4599	seco	22H00094	H	600UL	340909
5820	45	137			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
5821			0.17	123	SAI	2	1	TSH +0.31	TSHTSH	0.3		N5432	reso	22H00141	H	600PP	345327
5822			0.18	130	PID	4	1	TSH +0.31	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5823			0.28	120	SAI	1	1	TSH +0.31	TSHTSH	0.2		N5432	reso	22H00141	H	600PP	345327
5824			0.88	72	MBM	6	1	04H +36.37	TECTEH			F6623	reso	22H00094	H	600UL	340909
5825	47	137	10.40	180	DNG	P	1	06H +5.67	TECTEH			T7451	seco	22H00095	H	600UL	331890
			4.87	180	DNG	P	1	06H +5.99	TECTEH			T7451	seco	22H00095	H	600UL	331890
5827			10.41	181	DNG	P	1	06H +8.22	TECTEH			T7451	seco	22H00095	H	600UL	331890
5828			4.87	183	DNG	P	1	06H +8.76	TECTEH			T7451	seco	22H00095	H	600UL	331890
5829			7.60	182	DNG	P	1	07H +1.00	TECTEH			T7451	seco	22H00095	H	600UL	331890
5830			5.23	179	DNG	P	1	DH +18.79	TECTEH			T7451	seco	22H00095	H	600UL	331890

5831			6.89	180	DNG	P 1	VM	+2.76	TECTEH			T7451	seco	22H00095	H	600UL	331890

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 120

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5832			2.71	177	DNG	P 1	06C	+1.91	TECTEH			T7451	seco	22H00095	H	600UL	331890
5833			8.68	179	DNG	P 1	06C	+7.58	TECTEH			T7451	seco	22H00095	H	600UL	331890
5834			8.68	180	DNG	P 1	06C	+10.92	TECTEH			T7451	seco	22H00095	H	600UL	331890
5835			6.76	182	DNG	P 1	06C	+12.84	TECTEH			T7451	seco	22H00095	H	600UL	331890
5836	53	137	4.78	187	DNG	P 1	01C	+1.93	TECTEH			F6623	reso	22H00094	H	600UL	340909
5837	63	137	0.69	72	MBM	5	01H	+19.51	TECTEH			F3453	reso	22H00095	H	600UL	331890
5838			0.48	69	MBM	5	01H	+21.45	TECTEH			F3453	reso	22H00095	H	600UL	331890
5839	71	137	0.47	73	MBM	5	01H	+26.59	TECTEH			F3453	reso	22H00095	H	600UL	331890
5840			0.38	71	MBM	5	02H	+3.92	TECTEH			F3453	reso	22H00095	H	600UL	331890
5841			0.64	93	INR	6	03H	+28.93	TECTEH			T7451	seco	22H00095	H	600UL	331890
5842			0.51	72	MBM	5	04H	+10.80	TECTEH			F3453	reso	22H00095	H	600UL	331890
5843			0.52	67	MBM	5	04H	+16.11	TECTEH			F3453	reso	22H00095	H	600UL	331890
5844			0.58	89	MBM	5	04H	+26.69	TECTEH			F3453	reso	22H00095	H	600UL	331890
5845			0.69	84	MBM	5	04H	+37.24	TECTEH			F3453	reso	22H00095	H	600UL	331890
5846					INF	5	05H	-1.66	TECTEH	HR		F3453	reso	22H00095	H	600UL	331890
5847	73	137	0.66	87	MBM	5	02C	+29.21	TECTEH			F6623	reso	22H00094	H	600UL	340909
5848	75	137	3.84	184	DNG	P 1	TSH	+23.42	TECTEH			T7451	seco	22H00095	H	600UL	331890
	85	137	6.07	187	DNG	P 1	04C	+8.20	TECTEH			H4599	seco	22H00094	H	600UL	340909
	95	137	4.71	182	DNT	P 1	09H	+0.02	TECTEH			I3805	seco	22H00031	H	600UL	340830
5851			3.86	183	DNT	P 1	09C	+0.46	TECTEH			I3805	seco	22H00031	H	600UL	340830
5852	97	137	10.19	186	DNT	P 1	09H	-0.07	TECTEH			K2032	seco	22H00030	H	600UL	331892
5853	99	137	2.96	189	DNT	P 1	09H	+0.00	TECTEH			I3805	seco	22H00031	H	600UL	340830
5854	101	137	3.81	185	DNG	P 1	06H	+6.22	TECTEH			K2032	seco	22H00030	H	600UL	331892
5855			2.18	185	DNG	P 1	06H	+9.86	TECTEH			K2032	seco	22H00030	H	600UL	331892
5856			41.56	181	DNT	P 1	09H	-0.09	TECTEH			K2032	seco	22H00030	H	600UL	331892
5857			4.16	189	DNT	P 1	09C	+0.45	TECTEH			K2032	seco	22H00030	H	600UL	331892
5858			3.12	183	DNG	P 1	08C	+9.72	TECTEH			K2032	seco	22H00030	H	600UL	331892
5859			2.39	184	DNG	P 1	08C	+20.10	TECTEH			K2032	seco	22H00030	H	600UL	331892
5860	103	137	14.33	179	DNT	P 1	09H	+0.33	TECTEH			I3805	seco	22H00031	H	600UL	340830
5861	105	137	10.14	180	DNT	P 1	09H	+0.34	TECTEH			K2032	seco	22H00030	H	600UL	331892
5862			2.61	173	DNT	P 1	09C	+0.44	TECTEH			K2032	seco	22H00030	H	600UL	331892
5863	6	138	0.66	67	MBM	5	01H	+13.81	TECTEH			F6623	reso	22H00094	H	600UL	340909
5864	22	138			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5865			0.12	109	PID	4	TSH	+0.66	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5866			0.16	96	SAI	2	TSH	+0.66	TSHTSH	0.3		F6623	reso	22H00146	H	600PP	345352
5867			0.11	67	SAI	1	TSH	+0.66	TSHTSH	0.2		F6623	reso	22H00146	H	600PP	345352
5868	32	138			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5869			0.14	108	SAI	2	TSH	+0.71	TSHTSH	0.3		F6623	reso	22H00146	H	600PP	345352
5870			0.12	90	PID	4	TSH	+0.71	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5871			0.20	49	SAI	1	TSH	+0.71	TSHTSH	0.3		F6623	reso	22H00146	H	600PP	345352
5872	60	138	3.10	180	DNG	P 1	VM	+19.80	TECTEH			T7451	seco	22H00095	H	600UL	331890
5873	68	138	0.34	38	MBM	5	VM	+13.28	TECTEH			F3453	reso	22H00095	H	600UL	331890
5874			2.59	183	DNG	P 1	VM	+24.16	TECTEH			T7451	seco	22H00095	H	600UL	331890
	92	138	2.09	180	DNG	P 1	07H	+20.49	TECTEH			K2032	seco	22H00030	H	600UL	331892
5876			2.95	180	DNG	P 1	08H	+10.16	TECTEH			K2032	seco	22H00030	H	600UL	331892
5877			4.76	183	DNG	P 1	08C	+10.55	TECTEH			K2032	seco	22H00030	H	600UL	331892
5878	94	138	2.89	180	DNG	P 1	08H	+19.30	TECTEH			I3805	seco	22H00031	H	600UL	340830
5879	96	138	3.14	180	DNG	P 1	07H	+8.70	TECTEH			K2032	seco	22H00030	H	600UL	331892

5880			2.13	183	DNG	P 1	07H	+19.09	TECTEH			K2032	seco	22H00030	H	600UL	331892

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 121

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5881			2.92	179	DNG	P 1	07H	+20.95	TECTEH			K2032	seco	22H00030	H	600UL	331892
5882			8.08	183	DNG	P 1	07H	+21.88	TECTEH			K2032	seco	22H00030	H	600UL	331892
5883			3.42	182	DNG	P 1	08H	+11.89	TECTEH			K2032	seco	22H00030	H	600UL	331892
5884			3.55	182	DNG	P 1	08H	+19.70	TECTEH			K2032	seco	22H00030	H	600UL	331892
5885			7.76	183	DNG	P 1	08H	+20.94	TECTEH			K2032	seco	22H00030	H	600UL	331892
5886					INF		08H	+22.10	TECTEH	HR		L2157	reso	22H00030	H	600UL	331892
5887					INF		09H	-1.39	TECTEH	HR		L2157	reso	22H00030	H	600UL	331892
5888			5.85	178	DNT	P 1	09H	+0.16	TECTEH			K2032	seco	22H00030	H	600UL	331892
5889			3.10	189	DNT	P 1	09C	-0.50	TECTEH			K2032	seco	22H00030	H	600UL	331892
5890			3.70	175	DNT	P 1	09C	+0.44	TECTEH			K2032	seco	22H00030	H	600UL	331892
5891			6.36	184	DNG	P 1	08C	+6.39	TECTEH			K2032	seco	22H00030	H	600UL	331892
5892			2.48	182	DNG	P 1	08C	+8.58	TECTEH			K2032	seco	22H00030	H	600UL	331892
5893			3.27	183	DNG	P 1	08C	+14.25	TECTEH			K2032	seco	22H00030	H	600UL	331892
5894	98	138	2.92	190	DNT	P 1	09H	+0.44	TECTEH			I3805	seco	22H00031	H	600UL	340830
5895			3.03	186	DNT	P 1	09C	-0.50	TECTEH			I3805	seco	22H00031	H	600UL	340830
5896			4.38	187	DNT	P 1	09C	+0.40	TECTEH			I3805	seco	22H00031	H	600UL	340830
5897			0.57	82	MBM	5	03C	+16.92	TECTEH			F6623	reso	22H00031	H	600UL	340830
	100	138	12.44	180	DNT	P 1	09H	+0.36	TECTEH			K2032	seco	22H00030	H	600UL	331892
	102	138	5.18	180	DNT	P 1	09H	-0.54	TECTEH			I3805	seco	22H00031	H	600UL	340830
5900			17.53	180	DNT	P 1	09H	+0.27	TECTEH			I3805	seco	22H00031	H	600UL	340830
5901	104	138	4.75	188	DNT	P 1	09H	+0.45	TECTEH			K2032	seco	22H00030	H	600UL	331892
5902			2.98	183	DNT	P 1	09C	-0.45	TECTEH			K2032	seco	22H00030	H	600UL	331892
5903	106	138	7.07	184	DNT	P 1	09H	-0.48	TECTEH			I3805	seco	22H00031	H	600UL	340830
5904			5.33	181	DNT	P 1	09H	+0.33	TECTEH			I3805	seco	22H00031	H	600UL	340830
5905	7	139			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
5906					OBS		06H	+14.94	05H06H			F6623	reso	22H00218	H	5602C	325931
5907			4.56	10	SAI	1	VM	+2.00	05H06C	0.2		D8661	reso	22H00233	H	5602C	340984
5908			0.87	79	PID	2	VM	+2.00	05H06C			N5432	reso	22H00234	H	5602C	340984
5909			0.83	75	SAI	2	VM	+2.00	05H06C	0.2		D8661	reso	22H00233	H	5602C	340984
5910	15	139	7.76	180	DNG	P 1	06H	+10.01	TECTEH			T7451	seco	22H00095	H	600UL	331890
5911			5.51	179	DNG	P 1	06C	+9.27	TECTEH			T7451	seco	22H00095	H	600UL	331890
5912			0.72	82	MBM	5	TSC	+0.65	TECTEH			F3453	reso	22H00095	H	600UL	331890
5913	23	139			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5914			0.23	55	SAI	1	TSH	+0.21	TSHTSH	0.2		F6623	reso	22H00146	H	600PP	345352
5915			0.31	90	SAI	2	TSH	+0.21	TSHTSH	0.2		F6623	reso	22H00146	H	600PP	345352
5916			0.28	87	PID	4	TSH	+0.21	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5917			0.23	113	MAI	2	TSH	+0.71	TSHTSH	0.5		F6623	reso	22H00146	H	600PP	345352
5918			0.23	71	MAI	1	TSH	+0.71	TSHTSH	0.4		F6623	reso	22H00146	H	600PP	345352
5919	37	139			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5920			0.00	0	SAI	1	TSH	+1.68	TSHTSH	0.0		N5432	reso	22H00141	H	600PP	345327
5921			0.08	81	SAI	2	TSH	+1.68	TSHTSH	0.1		N5432	reso	22H00141	H	600PP	345327
5922			0.40	34	NQI	P 1	TSH	+1.74	TECTEH			T5565	prim	22H00095	H	600UL	331890
5923			0.16	90	SAI	2	TSH	+1.89	TSHTSH	0.4		N5432	reso	22H00141	H	600PP	345327
			0.12	87	PID	4	TSH	+1.89	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5925			0.38	36	SAI	1	TSH	+1.89	TSHTSH	0.5		N5432	reso	22H00141	H	600PP	345327
5926	43	139	0.93	85	MBM	5	01C	+11.39	TECTEH			F6623	reso	22H00094	H	600UL	340909
5927	47	139	3.35	179	DNG	P 1	VM	+2.96	TECTEH			T7451	seco	22H00095	H	600UL	331890
5928			3.47	182	DNG	P 1	05C	+15.03	TECTEH			T7451	seco	22H00095	H	600UL	331890

5929			0.43	121	22	P 2	04C	+0.32	TECTEH			T7451	seco	22H00095	H	600UL	331890

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 122

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5930	65	139	2.66	182	DNG	P 1	06H	-1.43	TECTEH			F4645	seco	22H00091	H	600UL	340909
5931	85	139	4.07	175	DNG	P 1	TSH	+21.18	TECTEH			F4645	seco	22H00091	H	600UL	340909
5932	91	139	1.02	76	MBM	5	05H	+3.89	TECTEH			A9608	reso	22H00030	H	600UL	331892
5933			0.75	86	MBM	5	05H	+19.59	TECTEH			L2157	reso	22H00030	H	600UL	331892
5934	93	139	3.06	182	DNT	P 1	09C	-0.56	TECTEH			K2032	seco	22H00030	H	600UL	331892
5935			4.52	198	DNT	P 1	09C	+0.45	TECTEH			K2032	seco	22H00030	H	600UL	331892
5936	95	139	1.33	69	MBM	6	TSH	+35.37	TECTEH			L2157	reso	22H00030	H	600UL	331892
5937			2.58	197	DNT	P 1	09H	+0.36	TECTEH			K2032	seco	22H00030	H	600UL	331892
5938			3.21	183	DNT	P 1	09C	+0.56	TECTEH			K2032	seco	22H00030	H	600UL	331892
5939	97	139	13.74	178	DNT	P 1	09H	+0.44	TECTEH			I3805	seco	22H00031	H	600UL	340830
5940			3.75	187	DNT	P 1	09C	-0.47	TECTEH			I3805	seco	22H00031	H	600UL	340830
5941			3.34	188	DNT	P 1	09C	+0.50	TECTEH			I3805	seco	22H00031	H	600UL	340830
5942	101	139	4.37	183	DNT	P 1	09H	+0.42	TECTEH			I3805	seco	22H00031	H	600UL	340830
5943			7.79	185	DNT	P 1	09C	-0.39	TECTEH			I3805	seco	22H00031	H	600UL	340830
5944			4.89	182	DNT	P 1	09C	+0.41	TECTEH			I3805	seco	22H00031	H	600UL	340830
5945	103	139	2.32	181	DNG	P 1	08H	+12.63	TECTEH			K2032	seco	22H00030	H	600UL	331892
5946			10.36	177	DNT	P 1	09H	-0.44	TECTEH			K2032	seco	22H00030	H	600UL	331892
			17.33	179	DNT	P 1	09H	+0.36	TECTEH			K2032	seco	22H00030	H	600UL	331892
[illegible]			5.12	182	DNT	P 1	09C	-0.46	TECTEH			K2032	seco	22H00030	H	600UL	331892
5949	8	140			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
5950			0.33	103	PID	2	DC	-0.55	05H06C			N5432	reso	22H00234	H	5602C	340984
5951			0.81	71	SAI	2	DC	-0.55	05H06C	0.2	LOCOK	S4373	reso	22H00233	H	5602C	340984
5952			4.60	11	SAI	1	DC	-0.55	05H06C	0.2	LOCOK	S4373	reso	22H00233	H	5602C	340984
5953	24	140			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5954			0.22	150	SAI	1	TSH	+0.84	TSHTSH	0.2		N5432	reso	22H00141	H	600PP	345327
5955			0.11	26	PID	4	TSH	+0.84	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5956			0.06	88	SAI	2	TSH	+0.84	TSHTSH	0.3		N5432	reso	22H00141	H	600PP	345327
5957	30	140			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5958			0.12	70	PID	4	TSH	+0.61	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5959			0.21	83	SAI	1	TSH	+0.61	TSHTSH	0.3		F6623	reso	22H00146	H	600PP	345352
5960			0.16	80	SAI	2	TSH	+0.61	TSHTSH	0.3		F6623	reso	22H00146	H	600PP	345352
5961	32	140	3.17	176	DNG	P 1	06C	+13.78	TECTEH			H4599	seco	22H00092	H	600UL	331890
5962			2.37	175	DNG	P 1	05C	+15.60	TECTEH			H4599	seco	22H00092	H	600UL	331890
5963			2.57	176	DNG	P 1	05C	+23.38	TECTEH			H4599	seco	22H00092	H	600UL	331890
5964	54	140	2.38	183	DNG	P 1	06C	+11.83	TECTEH			F4645	seco	22H00091	H	600UL	340909
5965			3.74	182	DNG	P 1	06C	+22.86	TECTEH			F4645	seco	22H00091	H	600UL	340909
5966	56	140			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
5967			0.00	0	SAI	1	TSH	+0.66	TSHTSH	0.0		N5432	reso	22H00141	H	600PP	345327
5968			0.10	90	PID	4	TSH	+0.66	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
5969			0.09	86	SAI	2	TSH	+0.66	TSHTSH	0.5		N5432	reso	22H00141	H	600PP	345327
5970			2.21	175	DNG	P 1	05H	+33.96	TECTEH			H4599	seco	22H00092	H	600UL	331890
5971	60	140	2.96	177	DNG	P 1	VM	+20.12	TECTEH			H4599	seco	22H00092	H	600UL	331890
[illegible]			0.49	85	MBM	5	05C	+8.68	TECTEH			F3453	reso	22H00092	H	600UL	331890
			0.56	73	MBM	5	05C	+24.21	TECTEH			F3453	reso	22H00092	H	600UL	331890
5974	66	140	3.19	184	DNT	P 1	06H	+0.09	TECTEH			F4645	seco	22H00091	H	600UL	340909
5975	68	140	1.05	58	MBM	6	06H	+17.72	TECTEH			F3453	reso	22H00092	H	600UL	331890
5976	92	140	3.18	183	DNG	P 1	07H	+14.95	TECTEH			K2032	seco	22H00030	H	600UL	331892
5977			3.50	182	DNG	P 1	07H	+15.93	TECTEH			K2032	seco	22H00030	H	600UL	331892

5978			2.82	194	INR	P 1	07H	+17.69	TECTEH			L2157	reso	22H00030	H	600UL	331892

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 123

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
5979			3.98	183	DNG	P 1	07H	+18.73	TECTEH			K2032	seco	22H00030	H	600UL	331892
5980			4.90	182	DNG	P 1	07H	+19.70	TECTEH			K2032	seco	22H00030	H	600UL	331892
5981			2.42	185	DNG	P 1	07H	+21.15	TECTEH			K2032	seco	22H00030	H	600UL	331892
5982			3.16	182	DNG	P 1	07H	+22.10	TECTEH			K2032	seco	22H00030	H	600UL	331892
5983			4.48	183	DNG	P 1	07H	+24.32	TECTEH			K2032	seco	22H00030	H	600UL	331892
5984			3.11	182	DNT	P 1	08H	+0.11	TECTEH			K2032	seco	22H00030	H	600UL	331892
5985			3.21	180	DNT	P 1	08H	+1.08	TECTEH			K2032	seco	22H00030	H	600UL	331892
5986			2.63	182	DNG	P 1	08H	+2.27	TECTEH			K2032	seco	22H00030	H	600UL	331892
5987			2.84	183	DNG	P 1	08H	+7.28	TECTEH			K2032	seco	22H00030	H	600UL	331892
5988			1.85	187	INR	P 1	08H	+13.53	TECTEH			K2032	seco	22H00030	H	600UL	331892
5989			5.06	182	DNG	P 1	08H	+15.37	TECTEH			K2032	seco	22H00030	H	600UL	331892
5990			9.97	181	DNT	P 1	09H	-0.02	TECTEH			K2032	seco	22H00030	H	600UL	331892
5991			4.29	180	DNT	P 1	09H	+0.55	TECTEH			K2032	seco	22H00030	H	600UL	331892
5992			4.66	185	DNG	P 1	09H	+2.15	TECTEH			K2032	seco	22H00030	H	600UL	331892
5993			4.66	182	DNG	P 1	09C	+2.70	TECTEH			K2032	seco	22H00030	H	600UL	331892
5994			4.31	184	DNG	P 1	09C	+4.09	TECTEH			K2032	seco	22H00030	H	600UL	331892
5995			3.15	183	DNG	P 1	08C	+7.51	TECTEH			K2032	seco	22H00030	H	600UL	331892
			2.59	184	DNG	P 1	08C	+10.68	TECTEH			K2032	seco	22H00030	H	600UL	331892
			7.83	183	DNG	P 1	08C	+15.03	TECTEH			K2032	seco	22H00030	H	600UL	331892
5998					INF		08C	+16.90	TECTEH	HR		L2157	reso	22H00030	H	600UL	331892
5999			2.26	183	DNG	P 1	07C	+18.90	TECTEH			K2032	seco	22H00030	H	600UL	331892
6000	94	140	4.15	186	DNT	P 1	09H	+0.40	TECTEH			I3805	seco	22H00031	H	600UL	340830
6001			2.28	184	DNT	P 1	09C	-0.43	TECTEH			I3805	seco	22H00031	H	600UL	340830
6002			4.25	190	DNT	P 1	09C	+0.53	TECTEH			I3805	seco	22H00031	H	600UL	340830
6003	96	140	6.41	182	DNG	P 1	07H	+15.92	TECTEH			K2032	seco	22H00030	H	600UL	331892
6004			9.57	180	DNG	P 1	07H	+18.10	TECTEH			K2032	seco	22H00030	H	600UL	331892
6005			22.73	182	DNG	P 1	07H	+19.14	TECTEH			K2032	seco	22H00030	H	600UL	331892
6006			3.19	179	DNG	P 1	08H	+9.03	TECTEH			K2032	seco	22H00030	H	600UL	331892
6007			17.45	183	DNG	P 1	08H	+10.07	TECTEH			K2032	seco	22H00030	H	600UL	331892
6008			5.23	185	DNG	P 1	08H	+10.54	TECTEH			K2032	seco	22H00030	H	600UL	331892
6009			8.45	180	DNG	P 1	08H	+11.65	TECTEH			K2032	seco	22H00030	H	600UL	331892
6010			5.52	180	DNG	P 1	08H	+11.83	TECTEH			K2032	seco	22H00030	H	600UL	331892
6011			2.68	180	DNG	P 1	08H	+12.21	TECTEH			K2032	seco	22H00030	H	600UL	331892
6012			2.81	181	DNG	P 1	08H	+12.76	TECTEH			K2032	seco	22H00030	H	600UL	331892
6013			3.62	180	DNG	P 1	08H	+15.34	TECTEH			K2032	seco	22H00030	H	600UL	331892
6014			3.02	181	DNG	P 1	08H	+16.39	TECTEH			K2032	seco	22H00030	H	600UL	331892
6015			3.82	176	DNT	P 1	09H	-0.42	TECTEH			K2032	seco	22H00030	H	600UL	331892
6016			18.58	179	DNT	P 1	09H	+0.43	TECTEH			K2032	seco	22H00030	H	600UL	331892
6017			6.14	185	DNT	P 1	09C	-0.55	TECTEH			K2032	seco	22H00030	H	600UL	331892
6018			4.87	186	DNT	P 1	09C	+0.49	TECTEH			K2032	seco	22H00030	H	600UL	331892
6019			5.87	184	DNG	P 1	09C	+0.80	TECTEH			L2157	reso	22H00030	H	600UL	331892
6020			4.43	179	DNG	P 1	08C	+6.75	TECTEH			K2032	seco	22H00030	H	600UL	331892
			3.60	179	DNG	P 1	08C	+8.09	TECTEH			K2032	seco	22H00030	H	600UL	331892
			5.37	179	DNG	P 1	08C	+8.81	TECTEH			K2032	seco	22H00030	H	600UL	331892
6023			2.94	178	DNG	P 1	08C	+9.93	TECTEH			K2032	seco	22H00030	H	600UL	331892
6024			4.18	181	DNG	P 1	07C	+23.74	TECTEH			K2032	seco	22H00030	H	600UL	331892
6025	98	140	2.11	192	DNT	P 1	09H	-0.48	TECTEH			I3805	seco	22H00031	H	600UL	340830
6026			3.38	189	DNT	P 1	09H	+0.49	TECTEH			I3805	seco	22H00031	H	600UL	340830

6027			6.34	185	DNT	P 1	09C	-0.44		TECTEH				I3805	seco	22H00031	H	600UL		340830

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 124

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
6028		4.90	185	DNT	P 1	09C	+0.55	TECTEH			I3805	seco	22H00031	H	600UL	340830
6029	100	140	5.90	181	DNT	P 1	09H	+0.36	TECTEH			K2032	seco	22H00030	H	600UL	331892
6030			7.22	185	DNT	P 1	09C	-0.50	TECTEH			K2032	seco	22H00030	H	600UL	331892
6031			3.78	190	DNT	P 1	09C	+0.40	TECTEH			L2157	reso	22H00030	H	600UL	331892
6032	102	140	4.43	183	DNT	P 1	09C	+0.35	TECTEH			I3805	seco	22H00031	H	600UL	340830
6033	104	140	2.30	184	DNG	P 1	03H	+13.64	TECTEH			I3805	seco	22H00031	H	600UL	340830
6034			0.36	82	NQI	5	03H	+26.88 TO+34.74	TECTEH			F6623	reso	22H00031	H	600UL	340830
6035					NDF		03H	+26.88 TO+34.74	03H04H			M7007	prim	22H00203	H	600PP	345330
6036					NDF		04H	+2.34 TO+3.32	04H05H			F0075	seco	22H00210	H	600PP	345330
6037			0.19	71	NQI	5	04H	+2.34 TO+3.32	TECTEH			F6623	reso	22H00031	H	600UL	340830
6038			2.69	186	DNT	P 1	09H	+0.42	TECTEH			I3805	seco	22H00031	H	600UL	340830
6039			0.67	12	INR	P 1	DH	+19.04	TECTEH			I3805	seco	22H00031	H	600UL	340830
6040	1	141	0.48	78	MBM	5	03H	+6.99	06HTEH			C5542	reso	22H00105	H	600UL	340824
6041	21	141			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
6042			0.09	135	PID	4	TSH	+0.35	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
6043			0.00	0	SAI	1	TSH	+0.35	TSHTSH	0.0		N5432	reso	22H00141	H	600PP	345327
6044			0.08	112	SAI	2	TSH	+0.35	TSHTSH	0.2		N5432	reso	22H00141	H	600PP	345327
	27	141	2.32	187	DNG	P 1	01H	+33.83	TECTEH			F3453	reso	22H00092	H	600UL	331890
[illegible]			4.12	183	DNG	P 1	01H	+34.66	TECTEH			H4599	seco	22H00092	H	600UL	331890
6047			2.06	181	DNG	P 1	06C	+18.27	TECTEH			F3453	reso	22H00092	H	600UL	331890
6048	37	141	2.75	180	DNT	P 1	07H	+1.24	TECTEH			F4645	seco	22H00091	H	600UL	340909
6049	41	141			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
6050			0	0	SVI	1	TSH	+2.64	TSHTSH			D3858	reso	22H00141	H	600PP	345327
6051			0.21	71	PID	4	TSH	+2.64	TSHTSH	080		M1680	reso	22H00207	H	600PP	345329
6052			0.18	69	SVI	2	TSH	+2.64	TSHTSH	0.59		D3858	reso	22H00141	H	600PP	345327
6053			3.65	178	DNG	P 1	02H	+1.67	TECTEH			F4645	seco	22H00091	H	600UL	340909
6054	49	141	2.30	175	DNG	P 1	TSH	+34.26	TECTEH			F4645	seco	22H00091	H	600UL	340909
6055	91	141	0.81	78	MBM	6	04H	+31.57	TECTEH			L2157	reso	22H00030	H	600UL	331892
6056			7.32	182	DNT	P 1	09H	+0.43	TECTEH			K2032	seco	22H00030	H	600UL	331892
6057			4.27	188	DNT	P 1	09C	-0.44	TECTEH			K2032	seco	22H00030	H	600UL	331892
6058	93	141	7.48	180	DNT	P 1	09H	+0.30	TECTEH			K2032	seco	22H00030	H	600UL	331892
6059			5.54	184	DNT	P 1	09C	-0.39	TECTEH			K2032	seco	22H00030	H	600UL	331892
6060			4.59	189	DNT	P 1	09C	+0.36	TECTEH			K2032	seco	22H00030	H	600UL	331892
6061	95	141	4.55	188	DNT	P 1	09C	-0.51	TECTEH			I3805	seco	22H00031	H	600UL	340830
6062			3.67	182	DNT	P 1	09C	+0.61	TECTEH			I3805	seco	22H00031	H	600UL	340830
6063	97	141	7.63	183	DNT	P 1	08H	+1.65	TECTEH			K2032	seco	22H00030	H	600UL	331892
6064			2.48	176	DNG	P 1	08H	+12.59	TECTEH			K2032	seco	22H00030	H	600UL	331892
6065			10.90	183	DNG	P 1	08H	+13.54	TECTEH			K2032	seco	22H00030	H	600UL	331892
6066			3.29	178	DNG	P 1	08H	+20.52	TECTEH			K2032	seco	22H00030	H	600UL	331892
6067			3.29	178	DNG	P 1	08H	+20.52	TECTEH			K2032	seco	22H00030	H	600UL	331892
6068			17.84	182	DNT	P 1	09H	-0.96	TECTEH			K2032	seco	22H00030	H	600UL	331892
6069					NDF		09H	-0.42	09H09H			M7007	prim	22H00203	H	600PP	345330
[illegible]			12.40	183	DNT	P 1	09H	-0.42	TECTEH			K2032	seco	22H00030	H	600UL	331892
			34.47	184	DNT	P 1	09H	+0.43	TECTEH			K2032	seco	22H00030	H	600UL	331892
6072			7.86	182	DNT	P 1	09C	-0.55	TECTEH			K2032	seco	22H00030	H	600UL	331892
6073			7.86	182	DNT	P 1	09C	-0.48	TECTEH			K2032	seco	22H00030	H	600UL	331892
6074			7.47	185	DNT	P 1	09C	+0.58	TECTEH			K2032	seco	22H00030	H	600UL	331892
6075	99	141	10.97	181	DNT	P 1	09C	-0.51	TECTEH			I3805	seco	22H00031	H	600UL	340830

6076			13.96	183	DNT	P 1	09C	+0.28		TECTEH				I3805	seco	22H00031	H	600UL	340830

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 125

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
6077	24	142			TBP				TECTEH	RMVTBS	ADDTBP	D3858	reso	22H00044	H	600UL	331892
6078			0.00	0	SAI	1	TSH	+0.20	TSHTSH	0.0		F6623	reso	22H00150	H	600PP	345327
6079			0.17	68	SAI	2	TSH	+0.20	TSHTSH	0.3		F6623	reso	22H00150	H	600PP	345327
6080			0.17	69	PID	4	TSH	+0.20	TSHTSH	080		F3453	reso	22H00179	H	600PP	345326
6081	28	142	2.73	184	DNG	P 1	TSC	+15.31	TECTEH			F4645	seco	22H00091	H	600UL	340909
6082			5.37	185	DNG	P 1	TSC	+30.36	TECTEH			F4645	seco	22H00091	H	600UL	340909
6083	36	142	2.59	182	DNT	P 1	VM	+1.58	TECTEH			F4645	seco	22H00091	H	600UL	340909
6084	62	142	0.79	66	MBM	6	04H	+23.31	TECTEH			F3453	reso	22H00092	H	600UL	331890
6085	84	142	2.32	95	MBM	5	04C	+2.48	TECTEH			C3340	reso	22H00091	H	600UL	340909
6086	86	142	2.94	180	DNG	P 1	08C	+16.26	TECTEH			H4599	seco	22H00092	H	600UL	331890
6087	94	142	2.29	178	DNG	P 1	07H	+15.49	TECTEH			I3805	seco	22H00031	H	600UL	340830
6088			5.11	182	DNT	P 1	09C	-0.39	TECTEH			I3805	seco	22H00031	H	600UL	340830
6089			4.04	183	DNT	P 1	09C	+0.63	TECTEH			I3805	seco	22H00031	H	600UL	340830
6090	96	142	2.35	182	DNG	P 1	05H	+12.02	TECTEH			K2032	seco	22H00030	H	600UL	331892
6091			2.81	184	DNT	P 1	08H	+0.96	TECTEH			K2032	seco	22H00030	H	600UL	331892
6092			3.68	184	DNG	P 1	08H	+12.24	TECTEH			K2032	seco	22H00030	H	600UL	331892
6093			21.22	185	DNG	P 1	08H	+13.28	TECTEH			K2032	seco	22H00030	H	600UL	331892
			7.39	180	DNT	P 1	09H	-0.42	TECTEH			K2032	seco	22H00030	H	600UL	331892
			26.17	179	DNT	P 1	09H	+0.46	TECTEH			K2032	seco	22H00030	H	600UL	331892
6096			23.20	184	DNT	P 1	09C	-0.61	TECTEH			L2157	reso	22H00030	H	600UL	331892
6097			9.12	184	DNT	P 1	09C	+0.51	TECTEH			L2157	reso	22H00030	H	600UL	331892
6098			9.44	183	DNG	P 1	08C	+3.89	TECTEH			K2032	seco	22H00030	H	600UL	331892
6099			6.43	182	DNG	P 1	08C	+4.59	TECTEH			K2032	seco	22H00030	H	600UL	331892
6100			11.60	181	DNG	P 1	08C	+5.54	TECTEH			K2032	seco	22H00030	H	600UL	331892
6101	9	143	11.77	184	INR	P 1	06H	+6.99	TECTEH			C3340	reso	22H00091	H	600UL	340909
6102	41	143	3.16	180	DNG	P 1	01C	+34.52	TECTEH			F4645	seco	22H00091	H	600UL	340909
6103	59	143	2.71	175	DNG	P 1	03H	+10.10	TECTEH			H4599	seco	22H00092	H	600UL	331890
6104	75	143	0.53	61	MBM	6	TSH	+18.21	TECTEH			F3453	reso	22H00092	H	600UL	331890
6105			2.39	175	DNG	P 1	03H	+13.50	TECTEH			H4599	seco	22H00092	H	600UL	331890
6106	91	143	8.19	183	DNT	P 1	09H	+0.41	TECTEH			K2032	seco	22H00030	H	600UL	331892
6107					NDF		09H	+0.41	09H09H			O1057	prim	22H00221	H	5602C	325931
6108			17.46	184	DNT	P 1	09C	-0.48	TECTEH			K2032	seco	22H00030	H	600UL	331892
6109			10.48	183	DNT	P 1	09C	+0.47	TECTEH			K2032	seco	22H00030	H	600UL	331892
6110	93	143	3.29	180	DNT	P 1	09H	-0.51	TECTEH			K2032	seco	22H00030	H	600UL	331892
6111			3.74	183	DNT	P 1	09H	+0.48	TECTEH			L2157	reso	22H00030	H	600UL	331892
6112			7.43	186	DNT	P 1	09C	-0.40	TECTEH			K2032	seco	22H00030	H	600UL	331892
6113	95	143	2.45	181	DNG	P 1	07H	+18.74	TECTEH			I3805	seco	22H00031	H	600UL	340830
6114			3.95	186	DNT	P 1	09C	-0.43	TECTEH			I3805	seco	22H00031	H	600UL	340830
6115			4.90	186	DNT	P 1	09C	+0.48	TECTEH			I3805	seco	22H00031	H	600UL	340830
6116	6	144	2.07	179	DNG	P 1	02H	+30.50	TECTEH			A6997	seco	22H00088	H	600UL	331890
6117	14	144	0.51	67	NQI	5	05H	+20.30	TECTEH			D3858	reso	22H00088	H	600UL	331890
6118			0.14	100	VOL	2	05H	+20.38	05H06C			F6623	reso	22H00222	H	5602C	325931
6119	28	144	3.10	185	DNG	P 1	02H	+37.09	TECTEH			T7451	seco	22H00089	H	600UL	340909
			3.08	187	DNG	P 1	04H	+36.18	TECTEH			T7451	seco	22H00089	H	600UL	340909
6121	34	144	3.20	179	DNG	P 1	05H	+7.24	TECTEH			A6997	seco	22H00088	H	600UL	331890
6122	46	144	2.95	178	DNG	P 1	01H	+36.00	TECTEH			A6997	seco	22H00088	H	600UL	331890
6123			2.15	177	DNG	P 1	02H	+35.01	TECTEH			A6997	seco	22H00088	H	600UL	331890
6124	50	144	3.14	180	DNG	P 1	TSH	+14.83	TECTEH			A6997	seco	22H00088	H	600UL	331890

6125	52	144	0.36	102	MBM	5	06C	+12.98	TECTEH				M7006	reso	22H00089	H	600UL	340909

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 126

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
6126			1.13	53	MBM	6	06C	+17.74	TECTEH			M7006	reso	22H00089	H	600UL	340909
6127			0.47	76	MBM	5	05C	+28.99	TECTEH			M7006	reso	22H00089	H	600UL	340909
6128	56	144	1.98	90	MBM	6	04H	+12.85	TECTEH			M7006	reso	22H00089	H	600UL	340909
6129	60	144	2.56	181	DNG	P 1	VM	+19.56	TECTEH			T7451	seco	22H00089	H	600UL	340909
6130	80	144	9.87	180	DNG	P 1	02C	+36.03	TECTEH			T7451	seco	22H00089	H	600UL	340909
6131			0.85	71	PVN	2	TSC	-0.15	TSCTSC			H4599	seco	22C00013	C	600PP	345294
6132	88	144	2.32	179	DNG	P 1	04C	+18.50	TECTEH			T7451	seco	22H00089	H	600UL	340909
6133	94	144	4.86	180	DNT	P 1	09H	-0.39	TECTEH			I3805	seco	22H00031	H	600UL	340830
6134					NDF		09H	+0.51	09H09H			M7007	prim	22H00203	H	600PP	345330
6135			7.06	182	DNT	P 1	09H	+0.51	TECTEH			I3805	seco	22H00031	H	600UL	340830
6136			8.15	183	DNT	P 1	09C	-0.41	TECTEH			I3805	seco	22H00031	H	600UL	340830
6137			13.21	180	DNT	P 1	09C	+0.50	TECTEH			I3805	seco	22H00031	H	600UL	340830
6138	5	145	8.98	178	DNT	P 1	VM	-2.74	06HTEC			L2157	reso	22C00066	C	600CS	341219
6139			5.23	177	DNT	P 1	VM	-1.33	06HTEC			L2157	reso	22C00066	C	600CS	341219
6140			9.41	178	DNT	P 1	VM	-0.12	06HTEC			L2157	reso	22C00066	C	600CS	341219
6141			15.71	177	DNT	P 1	VM	+2.50	06HTEC			L2157	reso	22C00066	C	600CS	341219
6142			14.82	178	DNG	P 1	06C	+7.27	06HTEC			L2157	reso	22C00066	C	600CS	341219
			14.83	178	DNG	P 1	06C	+8.36	06HTEC			L2157	reso	22C00066	C	600CS	341219
					INF		06C	+9.54	06HTEC	HR		L2157	reso	22C00066	C	600CS	341219
6145	11	145			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
6146			0.47	31	SVI	1	DH	+0.41	06H06C	0.2		M1680	reso	22H00222	H	5602C	325931
6147			0.27	82	PID	2	DH	+0.41	06C06H			O1057	prim	22C00107	H	5602C	340935
6148			0.30	45	SVI	2	DH	+0.41	06H06C	0.1		M1680	reso	22H00222	H	5602C	325931
6149	21	145	5.24	180	DNG	P 1	02H	+19.92	TECTEH			T7451	seco	22H00089	H	600UL	340909
6150	27	145	1.09	87	MBM	6	02C	+11.86	TECTEH			M7006	reso	22H00088	H	600UL	331890
6151	43	145	2.86	184	DNG	P 1	04C	+34.78	TECTEH			A6997	seco	22H00085	H	600UL	331890
6152	51	145	0.62	78	MBM	5	06H	+3.30	TECTEH			M7006	reso	22H00085	H	600UL	331890
6153	55	145	2.43	193	DNG	P 1	03H	+4.37	TECTEH			A6997	seco	22H00085	H	600UL	331890
6154	63	145	2.45	175	DNG	P 1	05C	+33.07	TECTEH			A6997	seco	22H00085	H	600UL	331890
6155	65	145	3.20	177	DNG	P 1	03C	+6.30	TECTEH			H4599	seco	22H00084	H	600UL	340914
6156			2.36	176	DNG	P 1	03C	+8.45	TECTEH			H4599	seco	22H00084	H	600UL	340914
6157			4.38	178	DNG	P 1	02C	+35.03	TECTEH			H4599	seco	22H00084	H	600UL	340914
6158			5.40	181	DNG	P 1	02C	+35.44	TECTEH			H4599	seco	22H00084	H	600UL	340914
6159	69	145	2.45	180	DNG	P 1	05H	+4.18	TECTEH			H4599	seco	22H00084	H	600UL	340914
6160			5.04	177	DNG	P 1	07H	+8.49	TECTEH			H4599	seco	22H00084	H	600UL	340914
6161			3.90	179	DNG	P 1	07C	+10.25	TECTEH			H4599	seco	22H00084	H	600UL	340914
6162			4.76	179	DNG	P 1	06C	+11.25	TECTEH			H4599	seco	22H00084	H	600UL	340914
6163	79	145	2.16	180	DNG	P 1	04C	+25.25	TECTEH			A6997	seco	22H00085	H	600UL	331890
6164			1.34	100	MBM	6	02C	+4.86	TECTEH			M7006	reso	22H00085	H	600UL	331890
6165	81	145	0.37	56	12	P 2	05H	+0.40	TECTEH			T5565	prim	22H00084	H	600UL	340914
6166	91	145	7.83	181	DNT	P 1	09H	-0.23	TECTEH			K2032	seco	22H00030	H	600UL	331892
6167			14.42	182	DNT	P 1	09H	+0.34	TECTEH			K2032	seco	22H00030	H	600UL	331892
[illegible]					NDF		09H	+0.34	09H09H			N2574	seco	22H00207	H	600PP	345329
			16.04	184	DNT	P 1	09C	-0.48	TECTEH			K2032	seco	22H00030	H	600UL	331892
6170			10.71	184	DNT	P 1	09C	+0.54	TECTEH			K2032	seco	22H00030	H	600UL	331892
6171	4	146	0.49	61	MBM	5	05H	+1.81	06HTEH			M7006	reso	22H00104	H	600UL	340824
6172	10	146	2.32	177	DNG	P 1	02H	+30.01	TECTEH			A6997	seco	22H00085	H	600UL	331890
6173	12	146			INF		06C	+6.23	TECTEH	HR		M7006	reso	22H00084	H	600UL	340914

6174			12.25	175	DNG	P 1	06C	+8.11	TECTEH			H4599	seco	22H00084	H	600UL	340914

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 127

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
6175	14	146	2.17	178	DNG	P 1	05H	+17.57	TECTEH			A6997	seco	22H00085	H	600UL	331890
6176			5.43	182	DNG	P 1	05H	+19.99	TECTEH			A6997	seco	22H00085	H	600UL	331890
6177			2.94	177	DNG	P 1	05H	+20.50	TECTEH			A6997	seco	22H00085	H	600UL	331890
6178			6.91	179	DNG	P 1	05H	+20.83	TECTEH			A6997	seco	22H00085	H	600UL	331890
6179			7.28	178	DNG	P 1	05H	+20.91	TECTEH			M7006	reso	22H00085	H	600UL	331890
6180			2.10	179	DNG	P 1	05H	+21.87	TECTEH			A6997	seco	22H00085	H	600UL	331890
6181			2.88	186	DNG	P 1	05C	+18.51	TECTEH			A6997	seco	22H00085	H	600UL	331890
6182			2.25	182	DNG	P 1	05C	+18.93	TECTEH			A6997	seco	22H00085	H	600UL	331890
6183	28	146	2.82	179	DNG	P 1	TSC	+4.30	TECTEH			H4599	seco	22H00084	H	600UL	340914
6184			4.03	186	DNG	P 1	TSC	+9.34	TECTEH			H4599	seco	22H00084	H	600UL	340914
6185			2.58	175	DNG	P 1	TSC	+11.18	TECTEH			H4599	seco	22H00084	H	600UL	340914
6186			4.76	180	DNG	P 1	TSC	+14.53	TECTEH			H4599	seco	22H00084	H	600UL	340914
6187	40	146	0.54	72	MBM	5	01H	+5.32	TECTEH			M7006	reso	22H00084	H	600UL	340914
6188	46	146	2.21	183	DNG	P 1	TSC	+10.77	TECTEH			A6997	seco	22H00085	H	600UL	331890
6189	54	146	2.99	183	DNG	P 1	07H	+16.23	TECTEH			A6997	seco	22H00085	H	600UL	331890
6190	68	146	0.79	66	MBM	6	06H	+18.08	TECTEH			M7006	reso	22H00084	H	600UL	340914
6191			0.56	75	MBM	6	06H	+21.70	TECTEH			M7006	reso	22H00084	H	600UL	340914
	72	146	2.26	171	DNG	P 1	DH	+18.20	TECTEH			H4599	seco	22H00084	H	600UL	340914
[illegible]	74	146	5.45	180	DNG	P 1	05H	+7.47	TECTEH			A6997	seco	22H00085	H	600UL	331890
6194	11	147	2.96	177	DNG	P 1	06H	+12.49	TECTEH			H4599	seco	22H00084	H	600UL	340914
6195	19	147	2.65	184	DNG	P 1	06H	+10.53	TECTEH			H4599	seco	22H00084	H	600UL	340914
6196	23	147	3.51	176	DNG	P 1	04H	+20.38	TECTEH			H4599	seco	22H00084	H	600UL	340914
6197	27	147	1.62	71	MBM	6	01C	+22.14	TECTEH			M7006	reso	22H00084	H	600UL	340914
6198	45	147	2.67	177	DNG	P 1	03H	+13.73	TECTEH			A6997	seco	22H00085	H	600UL	331890
6199	75	147	0.52	105	MBM	5	03H	+4.13	TECTEH			M7006	reso	22H00084	H	600UL	340914
6200			0.49	107	MBM	5	03H	+9.74	TECTEH			M7006	reso	22H00084	H	600UL	340914
6201	79	147	1.23	71	MBM	6	06C	+13.64	TECTEH			M7006	reso	22H00084	H	600UL	340914
6202	10	148	2.92	180	DNG	P 1	05C	+8.97	TECTEH			H2949	seco	22H00110	H	600UL	340929
6203			2.93	175	DNG	P 1	05C	+9.00	TSCTEH			H4599	seco	22H00084	H	600UL	340914
6204	12	148	11.74	180	DNG	P 1	06C	+8.07	TECTEH			A6997	seco	22H00085	H	600UL	331890
6205	14	148	3.99	179	DNG	P 1	06H	+11.78	TECTEH			H4599	seco	22H00084	H	600UL	340914
6206	52	148	1.09	75	MBM	6	02C	+10.72	TECTEH			M7006	reso	22H00084	H	600UL	340914
6207			0.97	64	MBM	6	02C	+14.39	TECTEH			M7006	reso	22H00084	H	600UL	340914
6208	60	148	2.80	180	DNG	P 1	VM	+19.64	TECTEH			H4599	seco	22H00084	H	600UL	340914
6209	70	148	4.80	4	INR	P 1	08C	+8.87	TECTEH			A6997	seco	22H00085	H	600UL	331890
6210	5	149	21.50	182	DNG	P 1	06H	+4.27	06HTEH			M9715	seco	22H00104	H	600UL	340824
6211			23.35	181	DNG	P 1	06H	+5.36	06HTEC			L2157	reso	22C00066	C	600CS	341219
6212					INF		06H	+6.25	06HTEH	HR		M7006	reso	22H00104	H	600UL	340824
6213	7	149			OBS		06H	+15.86	06H05H			F6623	reso	22H00222	H	5602C	325931
6214	15	149	19.61	178	DNG	P 1	06C	+9.35	TECTEH			H4599	seco	22H00084	H	600UL	340914
6215	25	149			NDF		VM	+4.54	DH DC			T7451	seco	22C00092	H	5602C	326272
6216			0.79	68	NQI	5	VM	+4.54	TECTEH			M7006	reso	22H00110	H	600UL	340929
[illegible]	45	149	7.83	182	DNG	P 1	01C	+7.35	TECTEH			H2949	seco	22H00110	H	600UL	340929
	26	150	3.16	182	DNG	P 1	04C	+12.55	TECTEH			A9574	seco	22H00080	H	600UL	340914
6219	28	150	0.48	86	MBM	5	TSC	+5.57	TECTEH			C5542	reso	22H00080	H	600UL	340914
6220	36	150	0.64	85	MBM	5	01H	+35.09	TECTEH			C5542	reso	22H00080	H	600UL	340914
6221	40	150	0.84	33	MBM	5	03H	+7.77	TECTEH			C5542	reso	22H00080	H	600UL	340914
6222			2.79	180	DNG	P 1	VM	+9.74	TECTEH			A9574	seco	22H00080	H	600UL	340914

6223			2.93	179	DNG	P 1	06C	+15.05	TECTEH				A9574	seco	22H00080	H	600UL	340914

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 128

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
6224	58	150	2.15	187	DNG	P 1	VM	+18.70	TECTEH			H4599	seco	22H00080	H	600UL	340914
6225	66	150	11.93	180	DNG	P 1	07H	+11.17	TECTEH			H4599	seco	22H00080	H	600UL	340914
6226			4.51	189	DNG	P 1	06C	+17.26	TECTEH			H4599	seco	22H00080	H	600UL	340914
6227	5	151	2.64	180	DNG	P 1	03H	+31.49	06HTEH			M9715	seco	22H00104	H	600UL	340824
6228	9	151	19.07	181	DNG	P 1	06C	+7.05	TECTEH			A9574	seco	22H00080	H	600UL	340914
6229	13	151			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
6230			0.87	150	SAI	1	VM	-0.23	05H06C	0.0		S4373	reso	22H00223	H	5602C	340984
6231			0.17	83	PID	2	VM	-0.23	05H06C			N5432	reso	22H00234	H	5602C	340984
6232			0.36	160	SAI	2	VM	-0.23	05H06C	0.3		S4373	reso	22H00223	H	5602C	340984
6233	15	151	19.32	181	DNG	P 1	06C	+8.52	TECTEH			C5542	reso	22H00080	H	600UL	340914
6234	31	151	4.80	182	DNT	P 1	VM	-1.92	TECTEH			A9574	seco	22H00080	H	600UL	340914
6235	33	151	16.49	179	DNT	P 1	VM	-0.55	TECTEH			M2655	seco	22H00074	H	600UL	340914
6236	41	151	4.66	181	DNG	P 1	01H	+32.44	TECTEH			M2655	seco	22H00074	H	600UL	340914
6237			8.67	182	DNG	P 1	07C	+9.31	TECTEH			M2655	seco	22H00074	H	600UL	340914
6238	47	151	0.98	59	MBM	6	03C	+36.13	TECTEH			C5542	reso	22H00074	H	600UL	340914
6239	4	152	2.12	90	MBM	6	05H	+15.66	06HTEH			M7006	reso	22H00104	H	600UL	340824
6240	8	152	0.69	50	MBM	5	05C	+20.43	TECTEH			C5542	reso	22H00074	H	600UL	340914
	12	152	11.00	179	DNG	P 1	06C	+7.87	TECTEH			M2655	seco	22H00074	H	600UL	340914
[illegible]	28	152	2.61	184	DNG	P 1	03H	+12.09	TECTEH			H2949	seco	22H00110	H	600UL	340929
6243	36	152	2.74	185	DNG	P 1	02H	+21.17	TECTEH			H2949	seco	22H00110	H	600UL	340929
6244			3.58	185	DNG	P 1	02H	+22.38	TECTEH			H2949	seco	22H00110	H	600UL	340929
6245	54	152	3.43	188	DNG	P 1	VM	+17.06	TECTEH			M2655	seco	22H00074	H	600UL	340914
6246	58	152	2.50	186	DNG	P 1	VM	+18.14	TECTEH			M2655	seco	22H00074	H	600UL	340914
6247	62	152	4.03	188	DNG	P 1	DH	+18.55	TECTEH			M2655	seco	22H00074	H	600UL	340914
6248			1.85	179	INR	P 1	VM	+9.99	TECTEH			M2655	seco	22H00074	H	600UL	340914
6249			2.40	182	DNG	P 1	VM	+20.23	TECTEH			M2655	seco	22H00074	H	600UL	340914
6250	72	152	1.45	73	MBM	5	TSH	+18.11	TECTEH			M7006	reso	22H00110	H	600UL	340929
6251	76	152	2.80	178	DNG	P 1	04H	+4.29	TECTEH			M2655	seco	22H00074	H	600UL	340914
6252	7	153	3.77	177	DNG	P 1	01H	+5.37	TECTEH			M2655	seco	22H00074	H	600UL	340914
6253			2.68	184	DNT	P 1	05H	+0.00	TECTEH			M2655	seco	22H00074	H	600UL	340914
6254	15	153	19.02	181	DNG	P 1	06C	+9.41	TECTEH			M2655	seco	22H00074	H	600UL	340914
6255			1.65	181	INR	P 1	02C	+14.71	TECTEH			M2655	seco	22H00074	H	600UL	340914
6256	33	153	10.01	180	DNT	P 1	VM	-1.58	TECTEH			M2655	seco	22H00074	H	600UL	340914
6257	61	153	4.17	184	DNT	P 1	VM	-1.75	TECTEH			M2655	seco	22H00074	H	600UL	340914
6258	69	153	5.12	178	DNG	P 1	TSH	+32.35	TECTEH			M2655	seco	22H00074	H	600UL	340914
6259			5.77	180	DNG	P 1	01H	+9.07	TECTEH			M2655	seco	22H00074	H	600UL	340914
6260	71	153	1.05	108	MBM	6	TSH	+21.50	TECTEH			C5542	reso	22H00075	H	600UL	340930
6261	73	153	1.55	62	MBM	6	04C	+33.09	TECTEH			C5542	reso	22H00074	H	600UL	340914
6262	12	154	10.56	180	DNG	P 1	06C	+8.24	TECTEH			M2655	seco	22H00074	H	600UL	340914
6263	14	154	8.37	183	DNG	P 1	TSC	+21.91	TECTEH			A9574	seco	22H00075	H	600UL	340930
6264	22	154	0.34	79	PLP	10	TSC	+0.23	TSCTSC			M7006	reso	22C00008	C	600PP	340919
6265	28	154	2.68	182	DNG	P 1	01H	+10.13	TECTEH			M2655	seco	22H00074	H	600UL	340914
[illegible]			3.03	187	DNG	P 1	01H	+12.59	TECTEH			M2655	seco	22H00074	H	600UL	340914
			3.78	184	DNG	P 1	01H	+13.14	TECTEH			M2655	seco	22H00074	H	600UL	340914
6268	40	154	0.77	0	IDM	2	TSH	+5.04	TSHTSH			F3453	reso	22H00157	H	600PP	326412
6269			6.08	6	BLG	P 1	TSH	+14.11	TECTEH			M2655	seco	22H00074	H	600UL	340914
6270	48	154	0.78	44	MBM	5	06H	+6.63	TECTEH			C5542	reso	22H00074	H	600UL	340914
6271	58	154	2.25	177	DNG	P 1	03H	+14.81	TECTEH			A9574	seco	22H00075	H	600UL	340930

6272	60	154	3.06	177	DNG	P 1	TSC	+35.04	TECTEH			M2655	seco	22H00074	H	600UL		340914

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 129

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
6273	64	154	3.86	10	BLG	P 1	05C	+1.32	TECTEH			M2655	seco	22H00074	H	600UL	340914
6274			2.74	181	DNT	P 1	03C	+0.11	TECTEH			M2655	seco	22H00074	H	600UL	340914
6275	7	155	5.87	181	DNG	P 1	06H	+10.46	TECTEH			M2655	seco	22H00074	H	600UL	340914
6276	15	155	18.11	180	DNG	P 1	06C	+8.85	TECTEH			M2655	seco	22H00074	H	600UL	340914
6277	27	155	0.83	55	MBM	5	06H	+15.89	TECTEH			C5542	reso	22H00074	H	600UL	340914
6278	31	155	3.87	183	DNT	P 1	VM	-2.05	TECTEH			M2655	seco	22H00074	H	600UL	340914
6279	33	155	4.67	78	MBM	6	04C	+22.95	TECTEH			C5542	reso	22H00075	H	600UL	340930
6280	35	155	3.99	182	DNT	P 1	VM	-1.81	TECTEH			M2655	seco	22H00074	H	600UL	340914
6281	45	155	0.88	68	MBM	5	05C	+37.05	TECTEH			C5542	reso	22H00075	H	600UL	340930
6282	53	155	5.30	185	DNT	P 1	02H	+0.83	TECTEH			A9574	seco	22H00075	H	600UL	340930
6283			2.38	183	DNG	P 1	02H	+17.38	TECTEH			A9574	seco	22H00075	H	600UL	340930
6284			2.91	183	DNG	P 1	02H	+30.31	TECTEH			A9574	seco	22H00075	H	600UL	340930
6285	8	156			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
6286			0.10	129	VOL	P 1	05H	+3.86	05H06C			D8661	reso	22H00233	H	5602C	340984
6287			0.11	158	VOL	2	05H	+3.87	05H06H			F6623	reso	22H00225	H	5602C	325931
6288			1.27	50	NQI	6	05H	+3.90	TECTEH			D3858	reso	22H00071	H	600UL	340914
6289			0.08	111	VOL	P 1	05H	+15.25	05H06C			D8661	reso	22H00233	H	5602C	340984
			0.12	132	VOL	2	05H	+15.35	05H06H			F6623	reso	22H00225	H	5602C	325931
[illegible]			0.15	51	SAI	2	06H	+9.41	05H06C	0.1		D8661	reso	22H00233	H	5602C	340984
6292			0.77	7	SAI	1	06H	+9.41	05H06C	0.2		D8661	reso	22H00233	H	5602C	340984
6293					OBS		06H	+10.98	05H06H			F6623	reso	22H00225	H	5602C	325931
6294			1.06	13	SAI	1	06H	+13.08	05H06C	0.2		D8661	reso	22H00233	H	5602C	340984
6295			0.19	75	PID	2	06H	+13.08	05H06C			N5432	reso	22H00234	H	5602C	340984
6296			0.06	317	SAI	2	06H	+13.08	05H06C	0.2		D8661	reso	22H00233	H	5602C	340984
6297	10	156	3.20	182	DNG	P 1	05H	+34.53	TECTEH			N5877	seco	22H00070	H	600UL	340930
6298	26	156	2.25	181	DNT	P 1	06H	+0.22	TECTEH			N5877	seco	22H00070	H	600UL	340930
6299	30	156	0.76	75	MBM	6	04H	+6.88	TECTEH			N5432	reso	22H00070	H	600UL	340930
6300			2.14	178	DNG	P 1	TSC	+21.35	TECTEH			N5877	seco	22H00070	H	600UL	340930
6301	32	156	8.32	182	DNT	P 1	DC	-1.32	TECTEH			A9574	seco	22H00071	H	600UL	340914
6302	38	156	18.68	10	PVN	P 1	02H	+7.00	TECTEH			N5877	seco	22H00070	H	600UL	340930
6303	42	156	4.20	184	DNG	P 1	02C	+1.81	TECTEH			N5877	seco	22H00070	H	600UL	340930
6304	44	156	2.67	179	DNG	P 1	VM	+11.76	TECTEH			A9574	seco	22H00071	H	600UL	340914
6305			3.53	181	DNG	P 1	06C	+5.38	TECTEH			A9574	seco	22H00071	H	600UL	340914
6306	58	156	2.27	188	DNG	P 1	VM	+18.77	TECTEH			A9608	reso	22H00075	H	600UL	340930
6307			0.33	85	MBM	5	TSC	+29.72	TECTEH			C5542	reso	22H00075	H	600UL	340930
6308	9	157	18.66	179	DNG	P 1	VM	+5.00	TECTEH			A9574	seco	22H00071	H	600UL	340914
6309					INF		06C	+6.49	TECTEH	HR		N5432	reso	22H00071	H	600UL	340914
6310	15	157	2.63	176	DNG	P 1	01C	+29.04	TECTEH			N5877	seco	22H00070	H	600UL	340930
6311			2.16	176	DNG	P 1	01C	+37.13	TECTEH			N5877	seco	22H00070	H	600UL	340930
6312	53	157	23.89	182	DNT	P 1	VM	+1.08	TECTEH			A9574	seco	22H00069	H	600UL	340948
6313			2.15	185	DNG	P 1	03C	+4.17	TECTEH			A9574	seco	22H00069	H	600UL	340948
6314			6.09	180	DNG	P 1	03C	+4.52	TECTEH			A9574	seco	22H00069	H	600UL	340948
[illegible]	14	158	20.03	184	DNG	P 1	06H	+9.58	TECTEH			N5877	seco	22H00070	H	600UL	340930
	34	158			INF	P 1	VM	-1.55	TECTEH	HR		N5432	reso	22H00070	H	600UL	340930
6317			4.16	181	DNT	P 1	VM	+1.89	TECTEH			N5877	seco	22H00070	H	600UL	340930
6318	40	158	3.14	183	DNG	P 1	VM	+9.89	TECTEH			A9574	seco	22H00069	H	600UL	340948
6319	44	158	4.49	185	DNT	P 1	06H	+0.24	TECTEH			A9574	seco	22H00069	H	600UL	340948
6320	52	158	4.96	189	DNT	P 1	05H	+0.75	TECTEH			A9574	seco	22H00069	H	600UL	340948

6321	58	158	4.00	183	DNG	P 1	VM	+18.90	TECTEH				A9574	seco	22H00069	H	600UL	340948

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 130

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
6322	7	159	7.20	184	DNG	P 1	06H	+10.72	TECTEH			A9574	seco	22H00069	H	600UL	340948
6323	15	159	23.78	182	DNG	P 1	06C	+9.56	TECTEH			A9574	seco	22H00069	H	600UL	340948
6324	27	159	4.81	179	DNG	P 1	VM	+3.71	TECTEH			I3805	seco	22H00063	H	600UL	340948
6325	33	159	15.71	180	DNT	P 1	VM	-1.82	TECTEH			A9574	seco	22H00064	H	600UL	340930
6326	35	159	2.53	186	DNT	P 1	VM	-2.10	TECTEH			I3805	seco	22H00063	H	600UL	340948
6327	41	159	4.08	184	DNT	P 1	VM	-1.18	TECTEH			A9574	seco	22H00064	H	600UL	340930
6328			0.57	85	MBM	5	TSC	+17.95	TECTEH			F3453	reso	22H00064	H	600UL	340930
6329	45	159	2.64	183	DNG	P 1	01C	+3.35	TECTEH			A9574	seco	22H00064	H	600UL	340930
6330	30	160	2.34	177	DNG	P 1	01H	+36.54	TECTEH			A9574	seco	22H00064	H	600UL	340930
6331	38	160	3.74	185	DNT	P 1	VM	+1.15	TECTEH			A9574	seco	22H00064	H	600UL	340930
6332	15	161	22.22	182	DNG	P 1	06C	+9.28	TECTEH			I3805	seco	22H00063	H	600UL	340948
6333	27	161	0.59	72	MBM	5	02C	+27.47	TECTEH			F3453	reso	22H00063	H	600UL	340948
6334	39	161	4.01	183	DNT	P 1	VM	-1.80	TECTEH			I3805	seco	22H00063	H	600UL	340948
6335	43	161	1.78	180	INR	P 1	06H	+16.97	TECTEH			I3805	seco	22H00063	H	600UL	340948
6336	6	162			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
6337			0.23	113	SVI	2	06H	-0.46	05H06C	0.4		M1680	reso	22H00226	H	5602C	340984
6338			0.39	117	SVI	1	06H	-0.48	05H06C	0.4		M1680	reso	22H00226	H	5602C	340984
			0.20	122	PID	2	06H	-0.48	05H06C			P5436	prim	22H00233	H	5602C	340984
[illegible]	8	162			OBS		06H	+15.21	05H06H			F6623	reso	22H00225	H	5602C	325931
6341	10	162	3.43	182	DNG	P 1	03C	+36.63	TECTEH			I3805	seco	22H00063	H	600UL	340948
6342	14	162	2.27	185	DNG	P 1	06H	+12.38	TECTEH			I3805	seco	22H00063	H	600UL	340948
6343	28	162	6.15	182	DNT	P 1	VM	+2.26	TECTEH			A9574	seco	22H00064	H	600UL	340930
6344	36	162	16.48	180	DNT	P 1	VM	+1.89	TECTEH			A9574	seco	22H00064	H	600UL	340930
6345	38	162	13.30	182	DNT	P 1	VM	-1.09	TECTEH			I3805	seco	22H00063	H	600UL	340948
6346			6.30	183	DNT	P 1	VM	+0.55	TECTEH			I3805	seco	22H00063	H	600UL	340948
6347	1	163	8.65	79	PLP	9	TSH	+0.63	TSHTSH			P5436	prim	22H00160	H	600PP	345327
6348	7	163	5.16	182	DNG	P 1	06H	+10.26	TECTEH			H2949	seco	22H00110	H	600UL	340929
6349	29	163	5.88	182	DNT	P 1	VM	-1.78	TECTEH			I3805	seco	22H00063	H	600UL	340948
6350	8	164	0.54	79	MBM	5	03H	+18.75	TECTEH			M7006	reso	22H00110	H	600UL	340929
6351	14	164	0.91	81	MBM	6	02C	+10.66	TECTEH			F3453	reso	22H00064	H	600UL	340930
6352	26	164	0.25	80	11	P 2	VM	+0.97	TECTEH			A9574	seco	22H00064	H	600UL	340930
6353	1	165	0.22	88	PLP	9	TSC	+0.73	TSCTSC			K2032	seco	22C00002	C	600PP	345296
6354	13	165	1.87	181	INR	P 1	02C	+14.08	TECTEH			M7006	reso	22H00110	H	600UL	340929
6355	17	165	5.06	184	DNG	P 1	06C	+11.58	TECTEH			H2949	seco	22H00110	H	600UL	340929
6356	29	165	13.95	182	DNT	P 1	VM	-1.88	TECTEH			I3805	seco	22H00063	H	600UL	340948
6357			3.65	185	DNT	P 1	VM	-1.67	TECTEH			I3805	seco	22H00063	H	600UL	340948
6358			0.69	75	MBM	5	05C	+14.57	TECTEH			F3453	reso	22H00063	H	600UL	340948
6359	12	166	10.93	182	DNG	P 1	06C	+8.06	TECTEH			H2949	seco	22H00110	H	600UL	340929
6360	5	167	3.77	176	DNG	P 1	05C	+30.11	06HTEC			H2949	seco	22C00067	C	600CS	341611
6361	9	167			TBP				TSHTEH			D3858	reso	22H00044	H	600UL	331892
6362			14.19	185	DNG	P 1	06H	+6.10	TECTEH			H2949	seco	22H00110	H	600UL	340929
6363			0.91	71	PID	2	06C	+11.83	05H06C			P5436	prim	22H00233	H	5602C	340984
[illegible]			1.13	65	SAI	2	06C	+11.83	05H06C	0.1		N5432	reso	22H00230	H	5602C	340984
			6.12	12	SAI	1	06C	+11.83	05H06C	0.1		N5432	reso	22H00230	H	5602C	340984
6366	15	167	16.41	183	DNG	P 1	06C	+9.58	TECTEH			H2949	seco	22H00110	H	600UL	340929
6367			0.38	36	16	P 2	02C	-0.86	TECTEH			M7006	reso	22H00110	H	600UL	340929

SG 22 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 23,2001 10:38

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0301_Final PAGE 131

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE	PROBE S/N

QUERY REPORT SUMMARY:

QUERY PARAMETER	ENTRIES	TUBES
0 to 100 Percent	43	40
ADR Indication Code	4	4
BLG Indication Code	2	2
CUD Indication Code	0	0
DEP Indication Code	0	0
DIS Indication Code	1	1
DNG Indication Code	2178	1097
DNI Indication Code	2	2
DNT Indication Code	1319	913
DRI Indication Code	0	0
DSI Indication Code	25	23
DTI Indication Code	3	3
ETL Indication Code	0	0
EXP Indication Code	0	0
GEO Indication Code	4	4
IDC Indication Code	0	0
IDM Indication Code	8	8
INF Indication Code	76	69
INR Indication Code	190	162
LDE Indication Code	0	0
LPI Indication Code	2	1
MAI Indication Code	138	66
MBM Indication Code	874	598
MCI Indication Code	28	14
MMI Indication Code	2	1
MSI Indication Code	0	0
MVI Indication Code	0	0
NDF Indication Code	167	163
NQI Indication Code	36	34
NRC Indication Code	41	41
NRH Indication Code	0	0
NSY Indication Code	0	0
OBS Indication Code	40	19
PBC Indication Code	0	0
PID Indication Code	296	293
PLP Indication Code	54	51
PPS Indication Code	0	0
PRC Indication Code	3	3
PSP Indication Code	2	1
PTS Indication Code	0	0
PVN Indication Code	8	8
SAI Indication Code	408	180
SCI Indication Code	82	41

SVI	Indication Code	18	10
TBP	Indication Code	138	138
TBS	Indication Code	155	155
UDE	Indication Code	0	0
VOL	Indication Code	15	10
WAR	Indication Code	5	4

TOTAL ENTRIES: 6367

TOTAL TUBES: 2553

SG 21 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final

****
* INSPECTION SUMMARY QUERY REPORT *
****

* All Test Plans in the database are included in summary: 20 *

Test Plan Name:	Probe Type:	Probe Code:	Leg:
1. F/L Rows >5	BOBBIN	600UL	HL
2. 100% TSH	MRPC	600PP	HL
3. 100% Steam Blanket Region	MRPC	5602C	HL
4. H/L Special Interest Straights	MRPC	600PP	HL
5. H/L Special Interest Ubend	MRPC	5602C	HL
6. Either Leg Ubend Rows <90	MRPC	5602C	HL
7. H/L SI DNT's =>5v 20% Sample	MRPC	600PP	HL
8. H/L SI DNT's =>50v Ubends	MRPC	5602C	HL
9. Either DNT's =>50v Ubend Row<90	MRPC	5602C	HL
10. Row 1-5, H/L Straights	BOBBIN	600CS	HL
11. EC on New Sleeves	MRPC	500PP	HL
12. EXP #1 Steam Blanket Row 5	MRPC	600UL	HL
13. Rows 3-5 Candy Cane	BOBBIN	600CS	CL
14. Rows 1-2 Straight	BOBBIN	600CS	CL
15. 100% TSC	MRPC	600PP	CL
16. 100% Rows 1-2 Ubends	MRPC	560FH	CL
17. C/L Special Interest Straights	MRPC	5602C	CL
18. C/L Special Interest Ubend	MRPC	5602C	CL
19. C/L SI DNT's =>50v Straights	MRPC	600PP	CL
20. C/L SI DNT's =>50v Ubends	MRPC	5602C	CL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL
COL	ALL
VOLTS	ALL
DEGREES	ALL
PERCENT	0 to 100
LOCATION	ALL
ELEVATION	ALL
EXTENT	ALL
UTILITY1	ALL
UTILITY2	ALL
NAME	ALL
EVAL TYPE	ALL
CAL GROUP	ALL
PROBE CODE(s)	ALL
IND. CODES	ADR BLG CUD DEP DIS
	DNG DNI DNT DRI DSI
	DTI ETL EXP GEO IDC
	IDM INF INR LDE LPI

MAI	MBM	MCI	MMI	MSI
MVI	NDF	NQI	NRC	NRH
NSY	OBS	PBC	PID	PLP
PPS	PRC	PSP	PTS	PVN
SAI	SCI	SVI	TBP	TBS
UDE	VOL	WAR		

CHANNELS ALL

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 1

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1	3	1	0.46	109	21	P 2	01C	+0.86	06HTEC			K6388	prim	21C00058	C 0	600CS	341613
2			0.43	85	PLP	9	TSC	+0.21	TSCTSC			M7006	reso	21C00074	C 2	600PP	345293
3	13	1	3.05	187	DNG	P 1	03H	+2.03	TECTEH			N2574	seco	21H00002	H 0	600UL	331933
4			9.10	183	DNG	P 1	06H	+9.57	TECTEH			N2574	seco	21H00002	H 0	600UL	331933
5			4.07	180	DNG	P 1	02C	+30.04	TECTEH			N2574	seco	21H00002	H 0	600UL	331933
6	15	1			TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
7			8.21	176	DNT	P 1	TSH	+0.99	TECTEH			N5877	seco	21H00001	H 0	600UL	332253
8			0.39	42	17	P 2	02H	-1.02	TECTEH			L2157	reso	21H00001	H 0	600UL	332253
9			0.35	130	PID	2	02H	-0.80	02H02H			D3858	reso	21H00170	H999	600PP	345325
10	2	2	0.45	86	PLP	9	TSC	+0.38	TSCTSC			M7006	reso	21C00074	C 2	600PP	345293
	6	2	12.24	185	DNG	P 1	06H	+6.12	TECTEH			F1726	seco	21H00028	H 0	600UL	331933
-	8	2	0.59	72	DNI	P 1	04C	+5.38	TECTEH	12.58		M7006	reso	21H00027	H 0	600UL	332253
13					NDF		04C	+5.38	04C05C			F6623	reso	21C00082	C 4	600PP	345344
14			12.58	185	DNG	P 1	04C	+5.72	TECTEH			S4373	reso	21H00027	H 0	600UL	332253
15	20	2	1.20	116	MBM	6	04C	+7.60	TECTEH			M7006	reso	21H00027	H 0	600UL	332253
16			0.60	105	MBM	6	03C	+25.97	TECTEH			M7006	reso	21H00027	H 0	600UL	332253
17	24	2	0.69	72	MBM	6	04C	+18.61	TECTEH			M7006	reso	21H00027	H 0	600UL	332253
18	5	3	2.04	186	DNG	P 1	04C	+30.27	06HTEC			N2574	seco	21C00057	C 0	600CS	341612
19	10	4			TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
20			0.37	55	SAI	1	VM	-0.03	05H06C	0.3		L2157	reso	21H00203	H 2	5602C	326245
21			0.16	107	SAI	2	VM	-0.03	05H06C	0.3		L2157	reso	21H00203	H 2	5602C	326245
22			0.13	156	PID	2	VM	-0.03	06H06C			T6956	prim	21H00218	H999	5602C	340933
23			2.33	158	INR	P 1	VM	+0.00	TECTEH			F1726	seco	21H00028	H 0	600UL	331933
24	28	4	1.27	70	MBM	6	05H	+17.15	TECTEH			M7006	reso	21H00027	H 0	600UL	332253
25	30	4	0.45	92	DSI	P 1	03H	+0.66	TECTEH			F1726	seco	21H00028	H 0	600UL	331933
26					NDF		03H	+0.66	03H03H			S8982	seco	21H00170	H 3	600PP	345325
27	36	4	0.24	118	VOL	2	07H	+6.63	DH 07H			F3453	reso	21C00085	H 5	5602C	326280
28			0.49	84	NQI	5	07H	+8.07	TECTEH			A9608	reso	21H00027	H 0	600UL	332253
29					NDF		07H	+8.07	DH 07H			D9424	prim	21C00085	H 5	5602C	326280
30			0.42	85	MBM	6	02C	+6.59	TECTEH			M7006	reso	21H00027	H 0	600UL	332253
31	1	5	2.09	191	DNG	P 1	05C	+10.73	06CTEC			M9715	seco	21C00058	C 1	600CS	341613
32	15	5	2.24	186	DNG	P 1	01H	+4.81	TECTEH			N2574	seco	21H00027	H 0	600UL	332253
33	17	5	7.31	179	DNT	P 1	DH	+2.22	TECTEH			F1726	seco	21H00028	H 0	600UL	331933
34	14	6	0.84	42	MBM	5	05C	+26.05	TECTEH			C5542	reso	21H00028	H 0	600UL	331933
35	20	6	8.93	185	DNG	P 1	06C	+3.50	TECTEH			N2574	seco	21H00027	H 0	600UL	332253
-			4.80	185	DNG	P 1	06C	+11.90	TECTEH			N2574	seco	21H00027	H 0	600UL	332253
			0.87	92	MBM	6	02C	+28.77	TECTEH			M7006	reso	21H00027	H 0	600UL	332253
38	26	6	0.88	75	MBM	6	05H	+14.60	TECTEH			C5542	reso	21H00028	H 0	600UL	331933
39			0.96	105	MBM	6	05H	+16.52	TECTEH			C5542	reso	21H00028	H 0	600UL	331933
40					NDF		DC	+1.73	DC DC			A9608	reso	21C00086	H 5	5602C	326280
41			0.27	153	12	P 2	DC	+1.73	TECTEH	LOCOK		S4373	reso	21H00028	H 0	600UL	331933

42				0.40	70	MBM	5	06C	+13.64	TECTEH			C5542	reso	21H00028	H 0	600UL	331933
43	32	6				TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
44				0.44	29	18	P 2	05C	-0.76	TECTEH			N2574	seco	21H00027	H 0	600UL	332253
[illegible]				0.69	155	PID	P 2	05C	-0.76	TEHTEC			N5432	reso	21C00100	H999	600UL	332242
	40	6		1.75	181	INR	P 1	01H	+15.03	TECTEH			N2574	seco	21H00027	H 0	600UL	332253
47	44	6				TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
48				1.14	148	PID	P 2	03H	-0.96	TEHTEC			N5432	reso	21C00100	H999	600UL	332242
49				0.52	137	20	P 2	03H	-0.96	TECTEH			N2574	seco	21H00027	H 0	600UL	332253

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 2

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
50	48	6	0.26	83	MBM	5	04C	+6.78	TECTEH			M7006	reso	21H00027	H 0	600UL	332253
51			0.36	133	MBM	5	04C	+22.95	TECTEH			M7006	reso	21H00027	H 0	600UL	332253
52	15	7	3.07	184	DNG	P 1	01H	+2.99	TECTEH			F1726	seco	21H00028	H 0	600UL	331933
53			0.59	76	MBM	5	02H	+22.94	TECTEH			C5542	reso	21H00028	H 0	600UL	331933
54	17	7	1.57	125	MBM	5	TSH	+28.87	TECTEH			M7006	reso	21H00027	H 0	600UL	332253
55			0.88	87	MBM	5	04H	+9.64	TECTEH			M7006	reso	21H00027	H 0	600UL	332253
56			6.66	182	DNT	P 1	DH	+1.87	TECTEH			N2574	seco	21H00027	H 0	600UL	332253
	31	7	0.42	94	MBM	5	01H	+34.11	TECTEH			C5542	reso	21H00028	H 0	600UL	331933
[illegible]	49	7	2.34	184	DNG	P 1	05C	+10.59	TECTEH			N2574	seco	21H00027	H 0	600UL	332253
59			4.55	185	DNG	P 1	05C	+11.65	TECTEH			N2574	seco	21H00027	H 0	600UL	332253
60			2.98	183	DNG	P 1	05C	+12.70	TECTEH			N2574	seco	21H00027	H 0	600UL	332253
61	53	7	0.54	24	MBM	6	01H	+24.28	TECTEH			M7006	reso	21H00027	H 0	600UL	332253
62	1	9	1.74	94	MBM	5	03H	+10.62	06HTEH			M7006	reso	21H00085	H 9	600UL	331933
63			1.04	94	MBM	5	03H	+17.87	06HTEH			M7006	reso	21H00085	H 9	600UL	331933
64			2.56	83	MBM	6	03H	+24.51	06HTEH			M7006	reso	21H00085	H 9	600UL	331933
65	15	9	3.69	180	DNG	P 1	02H	+30.95	TECTEH			F1726	seco	21H00028	H 0	600UL	331933
66	17	9	5.04	179	DNT	P 1	DH	+1.98	TECTEH			N2574	seco	21H00027	H 0	600UL	332253
67	19	9	2.08	173	DNG	P 1	03C	+35.76	TECTEH			F1726	seco	21H00028	H 0	600UL	331933
68	21	9	2.52	186	DNG	P 1	06C	+12.46	TECTEH			N2574	seco	21H00027	H 0	600UL	332253
69			1.32	89	MBM	5	01C	+27.62	TECTEH			M7006	reso	21H00027	H 0	600UL	332253
70	23	9	0.56	79	MBM	5	01C	+36.46	TECTEH			C5542	reso	21H00028	H 0	600UL	331933
71	29	9	0.58	66	MBM	5	03C	+25.12	TECTEH			C5542	reso	21H00028	H 0	600UL	331933
72	49	9	0.70	78	MBM	6	TSH	+18.55	TECTEH			C5542	reso	21H00028	H 0	600UL	331933
73			0.39	83	MBM	5	03H	+15.98	TECTEH			C5542	reso	21H00028	H 0	600UL	331933
74			0.92	91	MBM	5	04H	+32.28	TECTEH			C5542	reso	21H00028	H 0	600UL	331933
75	57	9	1.86	187	INR	P 1	01C	+16.00	TECTEH			F1726	seco	21H00028	H 0	600UL	331933
76	59	9	0.24	72	INR	P 1	04C	-0.45	TECTEH			N2574	seco	21H00027	H 0	600UL	332253
77	2	10	4.01	178	DNT	P 1	06H	+0.76	06HTEH			F4645	seco	21H00085	H 9	600UL	331933
78					INF		06H	+2.02	06HTEH	HR		S4373	reso	21H00085	H 9	600UL	331933
79	8	10	0.61	68	MBM	5	01C	+10.11	TECTEH			C3340	reso	21H00023	H 0	600UL	332253
80	12	10	0.67	82	MBM	5	TSH	+2.77	TECTEH			C3340	reso	21H00023	H 0	600UL	332253
81			1.23	126	VOL	P 1	TSH	+2.87	TSHTSH			N5432	reso	21H00124	H 1	600PP	345337
[illegible]	30	10	0.46	5	IDM	2	TSH	+0.56	TSHTSH			M2655	seco	21H00125	H 1	600PP	345281
			2.70	176	DNG	P 1	05H	+31.66	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
84	50	10	2.45	176	DNG	P 1	04C	+8.13	TECTEH			F1726	seco	21H00028	H 0	600UL	331933
85	13	11	0.76	86	MBM	6	03C	+36.02	TECTEH			D8661	reso	21H00024	H 0	600UL	331933
86	15	11	3.40	181	DNG	P 1	02C	+29.76	TECTEH			F7467	seco	21H00023	H 0	600UL	332253
87	17	11	8.22	178	DNT	P 1	DH	+1.85	TECTEH			M0945	seco	21H00024	H 0	600UL	331933

88	33	11	3.49	186	DNG	P 1	04H	+32.77	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
89			6.79	186	DNG	P 1	04H	+33.76	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
90			1.68	71	MBM	6	06H	+23.52	TECTEH			D8661	reso	21H00024	H 0	600UL	331933
[illegible]	41	11	0.86	82	MBM	5	04H	+16.06	TECTEH			D8661	reso	21H00024	H 0	600UL	331933
	45	11	1.54	83	MBM	6	05C	+21.04	TECTEH			D8661	reso	21H00024	H 0	600UL	331933
93			0.68	82	MBM	5	03C	+20.53	TECTEH			D8661	reso	21H00024	H 0	600UL	331933
94	65	11	12.74	180	DNG	P 1	DH	+27.76	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
95					INF		VM	-3.26	TECTEH	HR		M7006	reso	21H00024	H 0	600UL	331933
96	10	12	3.54	179	DNG	P 1	04C	+29.66	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
97			3.79	180	DNG	P 1	04C	+30.20	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
98	14	12	0.47	77	MBM	5	02C	+25.04	TECTEH			D8661	reso	21H00024	H 0	600UL	331933

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 3

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
99	28	12	0.28	140	12	P 2	03H	+0.72	TECTEH			M7988	prim	21H00023	H 0	600UL	332253
100	30	12	2.49	177	DNG	P 1	01H	+35.23	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
101	34	12	0.85	68	MBM	5	01C	+4.70	TECTEH			D8661	reso	21H00024	H 0	600UL	331933
102			0.52	71	MBM	5	01C	+13.97	TECTEH			D8661	reso	21H00024	H 0	600UL	331933
	40	12	3.10	181	DNG	P 1	02C	+8.47	TECTEH			F7467	seco	21H00023	H 0	600UL	332253
[illegible]	46	12	0.97	84	MBM	5	02H	+26.53	TECTEH			D8661	reso	21H00024	H 0	600UL	331933
105	60	12	0.41	28	INR	P 1	01H	-1.35	TECTEH			M7988	prim	21H00023	H 0	600UL	332253
106	64	12	1.96	184	INR	P 1	TSH	+20.30	TECTEH			C3340	reso	21H00023	H 0	600UL	332253
107	1	13	0.88	99	MBM	5	03C	+8.27	06CTEC			N5432	reso	21C00058	C 1	600CS	341613
108			0.82	88	MBM	5	02C	+30.92	06CTEC			N5432	reso	21C00058	C 1	600CS	341613
109	13	13	0.67	90	INR	9	TSC	+0.09	TSCTSC			C5542	reso	21C00073	C 2	600PP	326401
110	15	13	2.77	179	DNG	P 1	01C	+2.72	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
111	17	13	6.54	178	DNT	P 1	DH	+1.83	TECTEH			S4373	reso	21H00023	H 0	600UL	332253
112	53	13			INF		TSC	+0.17	TSCTSC	HR		C5542	reso	21C00073	C 2	600PP	326401
113	61	13	3.40	3	IDM	2	TSH	+0.34	TSHTSH			F0075	seco	21H00124	H 1	600PP	345337
114	63	13	1.03	76	MBM	6	VM	+3.06	TECTEH			D8661	reso	21H00024	H 0	600UL	331933
115	73	13			TBP				TSHTSH	SSI		D3858	reso	21H00115	H 1	600PP	326403
116	6	14	3.61	182	DNT	P 1	VM	-0.66	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
117	10	14			NDF		04C	+27.26	03C05C			D4576	seco	21C00082	C 4	600PP	345344
118			0.65	64	NQI	5	04C	+27.26	TECTEH			M7006	reso	21H00024	H 0	600UL	331933
119					NDF		04C	+28.61	03C05C			D4576	seco	21C00082	C 4	600PP	345344
120			0.52	64	NQI	5	04C	+28.61	TECTEH			M7006	reso	21H00024	H 0	600UL	331933
121					NDF		03C	+37.20	03C05C			D4576	seco	21C00082	C 4	600PP	345344
122			0.46	76	NQI	5	03C	+37.20	TECTEH			D8661	reso	21H00024	H 0	600UL	331933
123	18	14	0.60	74	MBM	5	05C	+26.61	TECTEH			D8661	reso	21H00024	H 0	600UL	331933
124	20	14	0.55	79	MBM	5	02H	+4.37	TECTEH			C3340	reso	21H00023	H 0	600UL	332253
125	22	14	0.79	64	MBM	5	05C	+5.87	TECTEH			D8661	reso	21H00024	H 0	600UL	331933
126			1.51	76	MBM	6	05C	+9.80	TECTEH			D8661	reso	21H00024	H 0	600UL	331933
127			0.85	79	MBM	5	05C	+13.22	TECTEH			D8661	reso	21H00024	H 0	600UL	331933
[illegible]			0.62	84	MBM	5	05C	+15.58	TECTEH			D8661	reso	21H00024	H 0	600UL	331933
	28	14	3.36	178	DNT	P 1	VM	+1.99	TECTEH			F7467	seco	21H00023	H 0	600UL	332253
130	36	14	0.48	80	MBM	5	02C	+32.34	TECTEH			C3340	reso	21H00023	H 0	600UL	332253
131	44	14	0.51	99	MBM	5	06H	+21.10	TECTEH			C3340	reso	21H00023	H 0	600UL	332253
132	52	14	0.71	73	MBM	5	TSC	+8.05	TECTEH			C3340	reso	21H00023	H 0	600UL	332253
133	74	14			TBP				TSHTSH	SSI		D3858	reso	21H00115	H 1	600PP	326403

134				6.68	184	DNG	P 1	VM	+3.69	TECTEH			F7467	seco	21H00023	H 0	600UL	332253
135	9	15				TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
136				0.00	0	SAI	1	VM	+0.27	05H06C	0.0		C3340	reso	21H00200	H 2	5602C	326245
				0.19	81	SAI	2	VM	+0.27	05H06C	0.3		C3340	reso	21H00200	H 2	5602C	326245
				0.22	109	SAI	2	VM	+1.26	05H06C	0.3		C3340	reso	21H00200	H 2	5602C	326245
139				0.00	0	SAI	1	VM	+1.26	05H06C	0.0		C3340	reso	21H00200	H 2	5602C	326245
140				0.21	101	PID	2	VM	+1.26	05H06C			P2952	prim	21H00213	H999	5602C	340933
141	15	15		3.84	180	DNT	P 1	01H	+1.08	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
142				2.41	180	DNG	P 1	02H	+26.22	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
143	17	15		5.54	178	DNT	P 1	DH	+1.91	TECTEH			F7467	seco	21H00023	H 0	600UL	332253
144				0.17	68	INR	9	TSC	+0.79	TSCTSC			C5542	reso	21C00073	C 2	600PP	326401
145	19	15		0.13	70	INR	9	TSC	+0.79	TSCTSC			A9574	seco	21C00074	C 2	600PP	345293
146	21	15		5.20	16	IDM	2	TSH	-1.35	TSHTSH			F0075	seco	21H00124	H 1	600PP	345337
147	43	15		3.55	179	DNG	P 1	TSH	+4.64	TECTEH			M0945	seco	21H00024	H 0	600UL	331933

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP,

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final

MAY. 17,2001 13:47

PAGE 4

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
148			6.25	180	DNT	P 1	01H	+1.03	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
	59	15	2.27	183	DNG	P 1	TSH	+25.97	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
			2.25	181	DNG	P 1	01C	+9.41	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
151	8	16	1.18	72	MBM	5	05C	+7.83	TECTEH			N5432	reso	21H00019	H 0	600UL	332253
152			0.55	77	MBM	5	05C	+16.31	TECTEH			N5432	reso	21H00019	H 0	600UL	332253
153			0.42	86	MBM	5	05C	+23.12	TECTEH			N5432	reso	21H00019	H 0	600UL	332253
154			0.83	87	MBM	5	05C	+25.57	TECTEH			N5432	reso	21H00019	H 0	600UL	332253
155	10	16	5.37	183	DNG	P 1	04C	+28.98	TECTEH			F4645	seco	21H00020	H 0	600UL	331933
156			5.29	183	DNG	P 1	04C	+29.50	TECTEH			F4645	seco	21H00020	H 0	600UL	331933
157	26	16	7.15	179	DNG	P 1	06C	+17.35	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
158	46	16	2.88	181	DNT	P 1	VM	+1.95	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
159	48	16	1.03	93	MBM	5	03H	+18.04	TECTEH			C3340	reso	21H00023	H 0	600UL	332253
160			0.99	80	MBM	5	03H	+23.79	TECTEH			C3340	reso	21H00023	H 0	600UL	332253
161			0.70	72	MBM	5	03H	+25.61	TECTEH			C3340	reso	21H00023	H 0	600UL	332253
162			0.47	84	MBM	5	03H	+26.84	TECTEH			C3340	reso	21H00023	H 0	600UL	332253
163	54	16	1.62	185	INR	P 1	02H	+16.75	TECTEH			M0945	seco	21H00024	H 0	600UL	331933
164	78	16			TBP				TSHTSH	SSI		D3858	reso	21H00115	H 1	600PP	326403
165	80	16			TBP				TSHTSH	SSI		D3858	reso	21H00115	H 1	600PP	326403
166			6.10	184	DNT	P 1	VM	+1.39	TECTEH			F7467	seco	21H00023	H 0	600UL	332253
167			4.62	177	DNT	P 1	VM	+1.88	TECTEH			F7467	seco	21H00023	H 0	600UL	332253
168	15	17	1.35	57	MBM	6	04H	+7.34	TECTEH			N5432	reso	21H00019	H 0	600UL	332253
169	17	17	6.98	175	DNT	P 1	DH	+1.81	TECTEH			F4645	seco	21H00020	H 0	600UL	331933
170	41	17	8.27	180	DNG	P 1	TSC	+19.61	TECTEH			F4645	seco	21H00020	H 0	600UL	331933
171	53	17	5.21	183	DNG	P 1	TSH	+20.13	TECTEH			F4645	seco	21H00020	H 0	600UL	331933
172	55	17	1.67	177	INR	P 1	02C	+29.87	TECTEH			D8661	reso	21H00019	H 0	600UL	332253
173	57	17	0.50	93	NQI	P 1	07C	+7.74	TECTEH			C3340	reso	21H00020	H 0	600UL	331933
					NDF		07C	+7.74	07CDC			D9424	prim	21C00085	H 5	5602C	326280
					NDF		07C	+7.74	07CDC	IDOK		D3858	reso	21C00086	H 5	5602C	326280
176	63	17	0.64	90	INR	9	TSC	+0.36	TSCTSC			C5542	reso	21C00073	C 2	600PP	326401
177	65	17	1.05	78	MBM	6	04H	+13.32	TECTEH			C3340	reso	21H00020	H 0	600UL	331933
178	71	17	0.52	81	MBM	5	02H	+27.26	TECTEH			D8661	reso	21H00019	H 0	600UL	332253
179			0.40	74	MBM	5	06H	+19.74	TECTEH			D8661	reso	21H00019	H 0	600UL	332253

180			0.45	66	MBM	5	05C	+29.47	TECTEH			D8661	reso	21H00019	H	0	600UL	332253
181	77	17	2.94	179	DNG	P 1	04C	+12.67	TECTEH			F4645	seco	21H00020	H	0	600UL	331933
182	81	17			TBP				TSHTSH	SSI		D3858	reso	21H00115	H	1	600PP	326403
	83	17			TBP				TSHTSH	SSI		D3858	reso	21H00115	H	1	600PP	326403
	6	18	0.69	88	MBM	5	01C	+28.05	TECTEH			C3340	reso	21H00020	H	0	600UL	331933
185	12	18	0.72	69	MBM	6	03C	+35.13	TECTEH			D8661	reso	21H00019	H	0	600UL	332253
186	24	18			TBS				TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
187			0.20	102	MAI	2	TSH	+1.71	TSHTSH	0.5		F6623	reso	21H00118	H	1	600PP	345337
188			0.00	0	MAI	1	TSH	+1.71	TSHTSH	0.0		F6623	reso	21H00118	H	1	600PP	345337
189			0.22	108	PID	4	TSH	+1.71	TSHTSH	080		M1680	reso	21H00151	H999	600PP		345281
190	32	18	3.09	183	DNT	P 1	VM	+2.12	TECTEH			F4645	seco	21H00020	H	0	600UL	331933
191	36	18	3.18	182	DNG	P 1	04H	+26.41	TECTEH			F4645	seco	21H00020	H	0	600UL	331933
192	52	18	8.02	181	DNG	P 1	TSH	+9.85	TECTEH			F4645	seco	21H00020	H	0	600UL	331933
193	56	18	2.91	181	DNG	P 1	01C	+31.47	TECTEH			F4645	seco	21H00020	H	0	600UL	331933
194	62	18	2.37	181	DNG	P 1	01H	+23.93	TECTEH			F7467	seco	21H00019	H	0	600UL	332253
195	1	19	2.16	180	DNT	P 1	06H	-0.40	06HTEH			F4645	seco	21H00085	H	9	600UL	331933
196	7	19	1.69	181	INR	P 1	02C	+24.34	TECTEH			D8661	reso	21H00019	H	0	600UL	332253

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 5

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
197	15	19	0.48	64	MBM	5	02H	+23.30	TECTEH			D8661	reso	21H00019	H	0 600UL	332253
198	17	19	7.56	178	DNT	P 1	DH	+1.92	TECTEH			F4645	seco	21H00020	H	0 600UL	331933
199	61	19	1.02	179	IDM	2	TSH	+2.41	TSHTSH			M1680	reso	21H00119	H	1 600PP	345281
200	63	19	0.18	256	INR	10	TSC	+0.68	TSCTSC			C5542	reso	21C00073	C	2 600PP	326401
201	65	19	0.36	78	INR	9	TSC	+0.07	TSCTSC			A9574	seco	21C00074	C	2 600PP	345293
202	83	19	3.81	183	DNT	P 1	08H	+0.45	TECTEH			F7467	seco	21H00019	H	0 600UL	332253
203			0.93	83	MBM	5	VM	+21.23	TECTEH			D8661	reso	21H00019	H	0 600UL	332253
204	32	20	0.60	72	MBM	5	02H	+17.43	TECTEH			D8661	reso	21H00019	H	0 600UL	332253
205			3.22	179	DNT	P 1	VM	+1.89	TECTEH			F7467	seco	21H00019	H	0 600UL	332253
206	54	20	0.97	81	MBM	6	05H	+32.38	TECTEH			C3340	reso	21H00020	H	0 600UL	331933
207	62	20	6.39	8	INR	P 1	TSC	+10.18	TECTEH			F4645	seco	21H00020	H	0 600UL	331933
208	70	20	0.73	76	MBM	5	05C	+13.94	TECTEH			C3340	reso	21H00020	H	0 600UL	331933
209	72	20	0.79	64	MBM	5	01H	+5.46	TECTEH			D8661	reso	21H00019	H	0 600UL	332253
210	82	20	0.83	80	MBM	5	04H	+19.83	TECTEH			C3340	reso	21H00020	H	0 600UL	331933
211			0.63	79	MBM	5	05H	+17.15	TECTEH			C3340	reso	21H00020	H	0 600UL	331933
212	86	20	4.19	182	DNG	P 1	03H	+10.07	TECTEH			F7467	seco	21H00019	H	0 600UL	332253
213	3	21	7.42	184	DNG	P 1	06H	+1.93	06HTEH			F4645	seco	21H00085	H	9 600UL	331933
214			8.50	182	DNG	P 1	06H	+2.60	06HTEC			N2574	seco	21C00057	C	0 600CS	341612
215	11	21	0.75	69	MBM	5	TSH	+13.90	TECTEH			C3340	reso	21H00020	H	0 600UL	331933
216	17	21	6.63	178	DNT	P 1	DH	+1.78	TECTEH			F4645	seco	21H00020	H	0 600UL	331933
217	43	21	2.48	183	DNG	P 1	TSH	+36.00	TECTEH			D4576	seco	21H00017	H	0 600UL	332253
218	55	21	5.78	7	PVN	P 1	03C	+4.10	TECTEH			D4576	seco	21H00017	H	0 600UL	332253
219	57	21	2.26	180	DNG	P 1	03H	+12.99	TECTEH			A6997	seco	21H00018	H	0 600UL	331933
			1.73	180	INR	P 1	03C	+15.94	TECTEH			A6997	seco	21H00018	H	0 600UL	331933
	63	21	2.27	177	DNG	P 1	07C	+24.49	TECTEH			A6997	seco	21H00018	H	0 600UL	331933
222	73	21	1.68	181	INR	P 1	03H	+10.86	TECTEH			D4576	seco	21H00017	H	0 600UL	332253
223			3.01	179	DNG	P 1	08C	+6.65	TECTEH			D4576	seco	21H00017	H	0 600UL	332253
224	81	21	4.25	182	DNG	P 1	07C	+18.11	TECTEH			D4576	seco	21H00017	H	0 600UL	332253
225	85	21	2.14	178	DNG	P 1	TSH	+4.26	TECTEH			A6997	seco	21H00018	H	0 600UL	331933

226	91	21			TBP				TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
227			0.15	10	IDM	2	TSH	+1.89	TSHTSH			L2157	reso	21H00139	H	1	600PP	345281
228			1.83	112	PID	P 2	06C	-0.19	TEHTEC			N5432	reso	21C00100	H999		600UL	332242
-			1.14	101	34	P 2	06C	-0.19	TECTEH			F6623	reso	21H00049	H	0	600UL	332253
	10	22	0.61	37	MBM	5	TSC	+26.82	TECTEH			M7006	reso	21H00017	H	0	600UL	332253
231			0.84	90	MBM	5	TSC	+28.10	TECTEH			M7006	reso	21H00017	H	0	600UL	332253
232			0.63	120	MBM	5	TSC	+29.54	TECTEH			M7006	reso	21H00017	H	0	600UL	332253
233	26	22	5.51	180	DNG	P 1	06C	+17.39	TECTEH			D4576	seco	21H00017	H	0	600UL	332253
234			0.48	56	MBM	5	05C	+25.89	TECTEH			M7006	reso	21H00017	H	0	600UL	332253
235			0.53	77	MBM	5	05C	+27.00	TECTEH			M7006	reso	21H00017	H	0	600UL	332253
236			0.39	91	MBM	5	05C	+28.10	TECTEH			M7006	reso	21H00017	H	0	600UL	332253
237	32	22	5.28	180	DNT	P 1	VM	+1.77	TECTEH			D4576	seco	21H00017	H	0	600UL	332253
238	34	22			TBS				TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
239			0.12	94	SAI	2	TSH	+0.17	TSHTSH	0.2		M1680	reso	21H00119	H	1	600PP	345281
240			0.12	85	PID	4	TSH	+0.17	TSHTSH	080		D8661	reso	21H00150	H999		600PP	345337
241			0.12	33	SAI	1	TSH	+0.17	TSHTSH	0.2		M1680	reso	21H00119	H	1	600PP	345281
242	72	22	1.30	97	MBM	5	VM	+20.44	TECTEH			M7006	reso	21H00017	H	0	600UL	332253
243	92	22	0.62	73	MBM	5	03H	+15.77	TECTEH			F6623	reso	21H00049	H	0	600UL	332253
244	7	23			TBP				TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
245			0.37	16	SAI	2	VM	-0.07	05H06C	0.17		D3858	reso	21H00196	H	2	5602C	326252

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 6

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
246			0.28	158	PID	2	VM	-0.07	06H06C			K5380	prim	21H00216	H999	5602C	340933
247			6.35	7	SAI	1	VM	-0.07	05H06C	0.20		D3858	reso	21H00196	H	2 5602C	326252
248	29	23	3.32	182	DNG	P 1	06H	+20.02	TECTEH			D4576	seco	21H00017	H	0 600UL	332253
249			3.25	179	DNG	P 1	05C	+11.78	TECTEH			D4576	seco	21H00017	H	0 600UL	332253
250	31	23			TBS				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
251			0.17	88	PID	4	TSH	+0.42	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
252			0.15	81	MAI	2	TSH	+0.42	TSHTSH	0.2		M1680	reso	21H00119	H	1 600PP	345281
253			0.15	142	MAI	1	TSH	+0.42	TSHTSH	0.2		M1680	reso	21H00119	H	1 600PP	345281
254	33	23			TBS				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
255			0.11	89	SAI	2	TSH	+0.37	TSHTSH	0.3		F6623	reso	21H00118	H	1 600PP	345337
256			0.09	78	PID	4	TSH	+0.37	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
257			0.00	0	SAI	1	TSH	+0.37	TSHTSH	0.0		F6623	reso	21H00118	H	1 600PP	345337
258	35	23	2.26	181	DNG	P 1	01C	+3.76	TECTEH			A6997	seco	21H00018	H	0 600UL	331933
259	39	23			TBS				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
260			0.12	89	PID	4	TSH	+0.24	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
261			0.13	100	SAI	2	TSH	+0.24	TSHTSH	0.2		M1680	reso	21H00119	H	1 600PP	345281
262			0.00	0	SAI	1	TSH	+0.24	TSHTSH	0.0		M1680	reso	21H00119	H	1 600PP	345281
263	43	23	2.08	180	DNG	P 1	01C	+24.49	TECTEH			A6997	seco	21H00018	H	0 600UL	331933
264	45	23	2.45	182	DNT	P 1	VM	-1.70	TECTEH			D4576	seco	21H00017	H	0 600UL	332253
265			0.57	96	MBM	5	05C	+17.33	TECTEH			M7006	reso	21H00017	H	0 600UL	332253
-	51	23	0.81	71	MBM	5	05C	+4.90	TECTEH			C5542	reso	21H00018	H	0 600UL	331933
			3.29	185	DNG	P 1	02C	+27.00	TECTEH			A6997	seco	21H00018	H	0 600UL	331933
268	53	23	3.58	184	DNG	P 1	TSH	+7.88	TECTEH			D4576	seco	21H00017	H	0 600UL	332253
269	55	23	0.76	88	MBM	5	07H	+5.95	TECTEH			C5542	reso	21H00018	H	0 600UL	331933
270	57	23	0.24	71	INR	9	TSC	+0.43	TSCTSC			M7006	reso	21C00075	C	2 600PP	326401
271	71	23	3.94	177	DNG	P 1	08C	+4.88	TECTEH			A6997	seco	21H00018	H	0 600UL	331933

272	81	23	2.08	180	DNG	P 1	08C	+12.96	TECTEH			D4576	seco	21H00017	H 0	600UL	332253
273	83	23	0.44	66	MBM	6	02H	+16.61	TECTEH			C5542	reso	21H00018	H 0	600UL	331933
274			0.65	86	MBM	5	02H	+18.18	TECTEH			C5542	reso	21H00018	H 0	600UL	331933
-	87	23	0.53	54	MBM	6	02C	+11.63	TECTEH			C5542	reso	21H00018	H 0	600UL	331933
	89	23	2.37	182	DNG	P 1	TSC	+30.99	TECTEH			M7006	reso	21H00017	H 0	600UL	332253
[illegible]	95	23	2.67	178	DNG	P 1	05C	+34.72	TECTEH			A6997	seco	21H00049	H 0	600UL	332253
278	6	24	1.01	71	MBM	5	02H	+3.50	TECTEH			M7006	reso	21H00027	H 0	600UL	332253
279			0.96	72	MBM	5	02H	+3.78	06HTEH			C5542	reso	21H00018	H 0	600UL	331933
280			0.54	69	MBM	5	02H	+4.24	TECTEH			M7006	reso	21H00027	H 0	600UL	332253
281			0.50	77	MBM	5	02H	+4.52	06HTEH			C5542	reso	21H00018	H 0	600UL	331933
282	18	24	2.60	91	MBM	5	04H	+18.29	TECTEH			M7006	reso	21H00017	H 0	600UL	332253
283			1.13	89	MBM	5	04H	+19.71	TECTEH			M7006	reso	21H00017	H 0	600UL	332253
284			3.56	181	DNG	P 1	06C	+9.98	TECTEH			D4576	seco	21H00017	H 0	600UL	332253
285	20	24			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
286			0.14	90	PID	4	TSH	+0.70	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
287			0.15	49	SAI	1	TSH	+0.70	TSHTSH	0.4		F6623	reso	21H00118	H 1	600PP	345337
288			0.14	81	SAI	2	TSH	+0.70	TSHTSH	0.3		F6623	reso	21H00118	H 1	600PP	345337
289	26	24	7.21	178	DNG	P 1	06C	+17.32	TECTEH			D4576	seco	21H00017	H 0	600UL	332253
290	34	24			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
291			0.34	85	MAI	2	TSH	+0.21	TSHTSH	0.5		F6623	reso	21H00118	H 1	600PP	345337
292			0.36	79	PID	4	TSH	+0.21	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
293			0.31	81	MAI	1	TSH	+0.21	TSHTSH	0.3		F6623	reso	21H00118	H 1	600PP	345337
294			0.06	136	MAI	1	TSH	+0.50	TSHTSH	0.3		F6623	reso	21H00118	H 1	600PP	345337

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 7

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
295			0.10	98	MAI	2	TSH	+0.50	TSHTSH	0.3		F6623	reso	21H00118	H 1	600PP	345337
296	42	24			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
297			0.11	83	SAI	2	TSH	+0.25	TSHTSH	0.2		M1680	reso	21H00119	H 1	600PP	345281
298			0.00	0	SAI	1	TSH	+0.25	TSHTSH	0.0		M1680	reso	21H00119	H 1	600PP	345281
299			0.12	102	PID	4	TSH	+0.25	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
300			0.88	79	MBM	6	01C	+11.94	TECTEH			C5542	reso	21H00018	H 0	600UL	331933
301			0.80	101	MBM	5	01C	+36.35	TECTEH			C5542	reso	21H00018	H 0	600UL	331933
302	48	24	7.98	178	DNG	P 1	04H	+14.66	TECTEH			D4576	seco	21H00017	H 0	600UL	332253
303			5.38	180	DNG	P 1	04H	+24.70	TECTEH			D4576	seco	21H00017	H 0	600UL	332253
304	56	24	0.02	83	INR	9	TSC	+2.46	TSCTSC			M7006	reso	21C00075	C 2	600PP	326401
305	78	24	2.14	178	DNG	P 1	08C	+10.92	TECTEH			A6997	seco	21H00018	H 0	600UL	331933
306	80	24	0.59	86	MBM	5	05H	+6.91	TECTEH			M7006	reso	21H00017	H 0	600UL	332253
307			0.62	101	MBM	5	07H	+19.61	TECTEH			M7006	reso	21H00017	H 0	600UL	332253
308	17	25	7.97	178	DNT	P 1	DH	+1.85	TECTEH			C5542	reso	21H00018	H 0	600UL	331933
309	49	25	2.49	176	DNG	P 1	03C	+32.45	TECTEH			D4576	seco	21H00017	H 0	600UL	332253
310	51	25	0.66	87	MBM	5	TSH	+34.51	TECTEH			C5542	reso	21H00018	H 0	600UL	331933
311			0.74	85	MBM	5	01H	+1.73	TECTEH			A9608	reso	21H00018	H 0	600UL	331933
-	55	25	1.91	178	INR	P 1	VM	-2.01	TECTEH			A6997	seco	21H00018	H 0	600UL	331933
	61	25	0.63	12	IDM	2	TSH	+1.97	TSHTSH			F3453	reso	21H00116	H 1	600PP	345337
314			0.48	0	IDM	2	TSH	+3.48	TSHTSH			F3453	reso	21H00116	H 1	600PP	345337
315	75	25	0.65	80	MBM	5	03C	+5.21	TECTEH			C5542	reso	21H00018	H 0	600UL	331933
316	79	25	2.01	179	DNG	P 1	TSH	+20.45	TECTEH			D3858	reso	21H00018	H 0	600UL	331933
317	83	25	2.98	181	DNG	P 1	08C	+15.05	TECTEH			A6997	seco	21H00018	H 0	600UL	331933

318	89	25	0.64	83	MBM	5	04C	+31.09	TECTEH			M7006	reso	21H00017	H	0	600UL	332253
319			2.01	177	DNG	P 1	TSC	+17.16	TECTEH			D4576	seco	21H00017	H	0	600UL	332253
320	97	25	0.94	74	MBM	5	02H	+3.76	TECTEH			M7006	reso	21H00050	H	0	600UL	331933
?	10	26	7.86	180	DNG	P 1	03H	+7.31	TECTEH			F4645	seco	21H00013	H	0	600UL	332253
			6.34	178	DNG	P 1	06H	+10.37	TECTEH			F4645	seco	21H00013	H	0	600UL	332253
323			3.31	177	DNG	P 1	03C	+27.39	TECTEH			F4645	seco	21H00013	H	0	600UL	332253
324	24	26	0.49	90	MBM	5	05H	+8.78	TECTEH			M7006	reso	21H00013	H	0	600UL	332253
325	42	26			TBS				TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
326			0.21	88	MAI	1	TSH	+0.26	TSHTSH	0.4		F3453	reso	21H00116	H	1	600PP	345337
327			0.16	104	PID	4	TSH	+0.26	TSHTSH	080		D8661	reso	21H00150	H999		600PP	345337
328			0.14	104	MAI	2	TSH	+0.26	TSHTSH	0.6		F3453	reso	21H00116	H	1	600PP	345337
329	70	26	0.48	77	MBM	5	02H	+13.89	TECTEH			C5542	reso	21H00014	H	0	600UL	331933
330			0.57	69	MBM	5	02H	+17.01	TECTEH			C5542	reso	21H00014	H	0	600UL	331933
331	90	26	6.10	181	DNG	P 1	02C	+17.81	TECTEH			D4576	seco	21H00017	H	0	600UL	332253
332	96	26	0.40	111	14	P 2	VC	-2.03	TECTEH			M7006	reso	21H00050	H	0	600UL	331933
333			3.98	180	DNG	P 1	09C	+4.42	TECTEH			D4576	seco	21H00050	H	0	600UL	331933
334	15	27	2.16	184	DNG	P 1	02C	+27.42	TECTEH			F4645	seco	21H00013	H	0	600UL	332253
335			4.64	179	DNG	P 1	01C	+2.18	TECTEH			F4645	seco	21H00013	H	0	600UL	332253
336	17	27	6.96	179	DNT	P 1	DH	+1.98	TECTEH			D3858	reso	21H00014	H	0	600UL	331933
337	45	27	3.42	177	DNG	P 1	04C	+13.07	TECTEH			F4645	seco	21H00013	H	0	600UL	332253
338	55	27	13.67	180	DNT	P 1	VM	-1.65	TECTEH			D3858	reso	21H00014	H	0	600UL	331933
339	61	27	3.32	180	DNG	P 1	TSH	+4.35	TECTEH			F4645	seco	21H00013	H	0	600UL	332253
340	65	27	0.39	76	MBM	5	07H	+6.40	TECTEH			M7006	reso	21H00013	H	0	600UL	332253
341	79	27	2.00	182	DNG	P 1	TSH	+21.06	TECTEH			C5542	reso	21H00014	H	0	600UL	331933
342	87	27	1.09	85	MBM	5	02H	+6.65	TECTEH			C5542	reso	21H00014	H	0	600UL	331933
343			0.43	82	MBM	5	04H	+18.43	TECTEH			C5542	reso	21H00014	H	0	600UL	331933

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 8

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
344			0.68	93	MBM	5	02C	+2.56	TECTEH			C5542	reso	21H00014	H	0 600UL	331933
345	89	27	0.42	78	MBM	5	04H	+18.28	TECTEH			F4645	seco	21H00013	H	0 600UL	332253
346	95	27	1.43	181	INR	P 1	TSH	+29.11	TECTEH			D4576	seco	21H00050	H	0 600UL	331933
347			0.32	89	11	P 2	VH	+1.17	TECTEH			M7006	reso	21H00050	H	0 600UL	331933
348			0.93	86	MBM	5	08C	+15.46	TECTEH			M7006	reso	21H00050	H	0 600UL	331933
349	97	27	6.59	177	DNG	P 1	DH	+1.25	TECTEH			A6997	seco	21H00049	H	0 600UL	332253
350	4	28	0.82	81	MBM	5	03C	+28.25	06HTEC			N5432	reso	21C00057	C	0 600CS	341612
351	34	28			TBS				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
352			0.00	0	SAI	1	TSH	+0.21	TSHTSH	0.0		F3453	reso	21H00116	H	1 600PP	345337
353			0.13	61	PID	4	TSH	+0.21	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
354			0.11	105	SAI	2	TSH	+0.21	TSHTSH	0.2		F3453	reso	21H00116	H	1 600PP	345337
355			0.00	0	SAI	1	TSH	+1.35	TSHTSH	0.0		F3453	reso	21H00116	H	1 600PP	345337
356			0.10	88	SAI	2	TSH	+1.35	TSHTSH	0.3		F3453	reso	21H00116	H	1 600PP	345337
357	38	28			TBS				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
-			0.09	108	PID	4	TSH	+0.79	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
			0.10	113	SAI	2	TSH	+0.79	TSHTSH	0.2		F3453	reso	21H00116	H	1 600PP	345337
360			0.00	0	SAI	1	TSH	+0.79	TSHTSH	0.0		F3453	reso	21H00116	H	1 600PP	345337
361	50	28			TBS				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
362			0.20	106	MAI	2	TSH	+0.36	TSHTSH	0.7		N5432	reso	21H00117	H	1 600PP	345281
363			0.20	102	MAI	1	TSH	+0.36	TSHTSH	0.6		N5432	reso	21H00117	H	1 600PP	345281

364			0.17	100	PID	4	TSH	+0.36	TSHTSH	080		M1680	reso	21H00151	H999	600PP	345281
365	52	28			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
366			0.21	83	MAI	2	TSH	+0.14	TSHTSH	0.3		F3453	reso	21H00116	H 1	600PP	345337
-			0.25	79	PID	4	TSH	+0.14	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
			0.22	71	MAI	1	TSH	+0.14	TSHTSH	0.3		F3453	reso	21H00116	H 1	600PP	345337
369	62	28	1.40	95	MBM	5	05C	+10.64	TECTEH			C5542	reso	21H00014	H 0	600UL	331933
370	66	28	0.36	93	INR	5	07H	+5.45	TECTEH			C5542	reso	21H00014	H 0	600UL	331933
371			0.22	81	PLP	9	TSC	+0.17	TSCTSC			A9608	reso	21C00078	C 2	600PP	345293
372	70	28	8.91	183	DNG	P 1	07H	+10.93	TECTEH			C5542	reso	21H00014	H 0	600UL	331933
373	76	28	1.48	181	INR	P 1	03H	+15.74	TECTEH			M7006	reso	21H00013	H 0	600UL	332253
374			10.38	180	DNG	P 1	07H	+17.70	TECTEH			F4645	seco	21H00013	H 0	600UL	332253
375	80	28	2.21	179	DNG	P 1	03H	+11.99	TECTEH			F4645	seco	21H00013	H 0	600UL	332253
376	11	29	0.64	84	MBM	5	01H	+22.57	TECTEH			C5542	reso	21H00014	H 0	600UL	331933
377			0.60	73	MBM	5	01H	+23.07	TECTEH			C5542	reso	21H00014	H 0	600UL	331933
378			0.96	88	MBM	5	02H	+31.30	TECTEH			C5542	reso	21H00014	H 0	600UL	331933
379			11.71	177	DNG	P 1	VM	+11.14	TECTEH			C5542	reso	21H00014	H 0	600UL	331933
380	17	29	4.71	178	DNG	P 1	VM	+4.34	TECTEH			C5542	reso	21H00014	H 0	600UL	331933
381	55	29			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
382			0.23	79	SAI	2	TSH	+0.45	TSHTSH	0.7		N5432	reso	21H00117	H 1	600PP	345281
383			0.23	62	SAI	1	TSH	+0.45	TSHTSH	0.4		N5432	reso	21H00117	H 1	600PP	345281
384			0.24	75	PID	4	TSH	+0.45	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
385	59	29			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
386			0.12	92	PID	4	TSH	+0.40	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
387			0.14	91	SAI	2	TSH	+0.40	TSHTSH	0.5		N5432	reso	21H00117	H 1	600PP	345281
388			0.14	121	SAI	1	TSH	+0.40	TSHTSH	0.5		N5432	reso	21H00117	H 1	600PP	345281
389	63	29	0.60	75	MBM	6	TSH	+18.42	TECTEH			C5542	reso	21H00014	H 0	600UL	331933
390			0.50	81	MBM	5	01H	+7.65	TECTEH			C5542	reso	21H00014	H 0	600UL	331933
391	65	29	0.88	76	MBM	5	01H	+21.79	TECTEH			M7006	reso	21H00013	H 0	600UL	332253
392	71	29	0.82	70	MBM	5	01H	+27.81	TECTEH			C5542	reso	21H00014	H 0	600UL	331933

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 9

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
393	73	29	3.46	180	DNG	P 1	VC	+11.26	TECTEH	LOCOK		S4373	reso	21H00013	H 0	600UL	332253
394	89	29	0.43	80	MBM	5	03C	+15.93	TECTEH			M7006	reso	21H00013	H 0	600UL	332253
395	93	29	2.31	180	DNG	P 1	01H	+21.46	TECTEH			F6623	reso	21H00049	H 0	600UL	332253
396	101	29	1.33	91	MBM	5	TSC	+21.41	TECTEH			F6623	reso	21H00049	H 0	600UL	332253
397	16	30	3.11	184	DNG	P 1	05H	+16.07	TECTEH			F4645	seco	21H00013	H 0	600UL	332253
398	28	30			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
399			0.20	126	MAI	1	TSH	+0.66	TSHTSH	0.5		F3453	reso	21H00116	H 1	600PP	345337
400			0.23	138	PID	4	TSH	+0.66	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
401			0.21	128	MAI	2	TSH	+0.66	TSHTSH	0.6		F3453	reso	21H00116	H 1	600PP	345337
402	58	30			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
403			0.16	112	PID	4	TSH	+0.42	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
			0.15	103	SAI	2	TSH	+0.42	TSHTSH	0.3		N5432	reso	21H00117	H 1	600PP	345281
			0.20	59	SAI	1	TSH	+0.42	TSHTSH	0.2		N5432	reso	21H00117	H 1	600PP	345281
406	60	30	0.86	94	MBM	5	TSH	+30.64	TECTEH			M7006	reso	21H00013	H 0	600UL	332253
407	76	30	2.15	188	DNT	P 1	05C	-1.04	TECTEH			M7006	reso	21H00013	H 0	600UL	332253
408	92	30	0.58	67	MBM	5	03H	+14.15	TECTEH			C5542	reso	21H00046	H 0	600UL	331933
409	98	30	0.95	94	MBM	5	04H	+16.34	TECTEH			C5542	reso	21H00045	H 0	600UL	332253

410	23	31	1.02	81	MBM	5	04C	+26.45	TECTEH			F4645	seco	21H00013	H 0	600UL	332253
411	71	31	0.88	96	MBM	5	04C	+11.20	TECTEH			C5542	reso	21H00014	H 0	600UL	331933
412	87	31	0.66	89	MBM	5	05C	+5.20	TECTEH			C5542	reso	21H00010	H 0	600UL	331933
	89	31	0.42	80	MBM	6	02H	+28.33	TECTEH			C5542	reso	21H00009	H 0	600UL	332253
	95	31	0.52	117	20 P	2	VM	-1.08	TECTEH			A6997	seco	21H00045	H 0	600UL	332253
415	2	32	0.50	64	MBM	5	01C	+15.65	06CTEC			N5432	reso	21C00058	C 1	600CS	341613
416	12	32			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
417			0.16	106	PID	4	TSH	+2.29	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
418			0.00	0	SAI	1	TSH	+2.29	TSHTSH	0.0		A9608	reso	21H00113	H 1	600PP	345281
419			0.15	98	SAI	2	TSH	+2.29	TSHTSH	0.2		A9608	reso	21H00113	H 1	600PP	345281
420	26	32	0.50	39	NQI P	1	TSH	+1.03	TECTEH			S8982	seco	21H00009	H 0	600UL	332253
421					NDF		TSH	+1.03	TSHTSH			C3340	reso	21H00112	H 1	600PP	345337
422	28	32			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
423			0.13	122	SAI	2	TSH	+0.79	TSHTSH	0.2		C5542	reso	21H00113	H 1	600PP	345281
424			0.22	111	PID	4	TSH	+0.79	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
425			0.15	62	SAI	1	TSH	+0.79	TSHTSH	0.2		C5542	reso	21H00113	H 1	600PP	345281
426	36	32			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
427			0.40	60	NQI P	1	TSH	+0.64	TECTEH			S8982	seco	21H00009	H 0	600UL	332253
428			0.00	0	SAI	1	TSH	+0.78	TSHTSH	0.0		M1680	reso	21H00112	H 1	600PP	345337
429			0.12	98	PID	4	TSH	+0.78	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
430			0.13	97	SAI	2	TSH	+0.78	TSHTSH	0.3		M1680	reso	21H00112	H 1	600PP	345337
431			0.75	78	MBM	5	04C	+27.87	TECTEH			C5542	reso	21H00009	H 0	600UL	332253
432	84	32	0.51	51	MBM	6	01H	+3.04	TECTEH			C5542	reso	21H00010	H 0	600UL	331933
433	98	32	0.69	85	MBM	5	05C	+6.29	TECTEH			C5542	reso	21H00045	H 0	600UL	332253
434	3	33	2.52	180	DNG P	1	02C	+8.31	06HTEC			N2574	seco	21C00057	C 0	600CS	341612
435	17	33	6.43	180	DNT P	1	DC	-2.05	TECTEH			D3858	reso	21H00009	H 0	600UL	332253
436	61	33			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
437			0.14	77	PID	4	TSH	+0.87	TSHTSH	080		M1680	reso	21H00151	H999	600PP	345281
438			0.12	79	SAI	2	TSH	+0.87	TSHTSH	0.3		F6623	reso	21H00112	H 1	600PP	345337
			0.16	130	SAI	1	TSH	+0.87	TSHTSH	0.3		F6623	reso	21H00112	H 1	600PP	345337
	63	33			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
441			0.09	120	PID	4	TSH	+0.49	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 10

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
442			0.06	119	SAI	2	TSH	+0.49	TSHTSH	0.2		C5542	reso	21H00113	H 1	600PP	345281
443			0.00	0	SAI	1	TSH	+0.49	TSHTSH	0.0		A9608	reso	21H00113	H 1	600PP	345281
444	65	33	2.48	183	DNG P	1	TSH	+32.01	TECTEH			N2574	seco	21H00027	H 0	600UL	332253
445	87	33	0.46	72	MBM	5	02C	+31.07	TECTEH			C5542	reso	21H00010	H 0	600UL	331933
446	89	33	0.49	75	MBM	5	05H	+8.13	TECTEH			C5542	reso	21H00009	H 0	600UL	332253
447	99	33	5.55	176	DNG P	1	08C	+18.74	TECTEH			A6997	seco	21H00045	H 0	600UL	332253
448	109	33	2.25	75	MBM	5	07C	+23.46	TECTEH			C5542	reso	21H00045	H 0	600UL	332253
449	28	34			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
			0.19	102	SAI	2	TSH	+0.73	TSHTSH	0.4		C5542	reso	21H00113	H 1	600PP	345281
			0.40	100	SAI	1	TSH	+0.73	TSHTSH	0.3		C5542	reso	21H00113	H 1	600PP	345281
452			0.21	91	PID	4	TSH	+0.73	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
453			0.40	68	MBM	5	02H	+25.62	TECTEH			C5542	reso	21H00010	H 0	600UL	331933
454	58	34			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
455			0.26	86	PID	4	TSH	+0.42	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337

456				0.16	121	SAI	1	TSH	+0.42	TSHTSH	0.4			F6623	reso	21H00112	H 1	600PP	345337
457				0.11	84	SAI	2	TSH	+0.42	TSHTSH	0.3			F6623	reso	21H00112	H 1	600PP	345337
458				0.31	63	MAI	1	TSH	+0.73	TSHTSH	0.4			F6623	reso	21H00112	H 1	600PP	345337
				0.16	108	MAI	2	TSH	+0.73	TSHTSH	0.3			F6623	reso	21H00112	H 1	600PP	345337
	66	34		0.98	94	MBM	5	07H	+10.89	TECTEH				C5542	reso	21H00009	H 0	600UL	332253
461	92	34		0.62	85	MBM	5	03H	+14.57	TECTEH				C5542	reso	21H00046	H 0	600UL	331933
462				10.48	180	DNT	P 1	09C	+0.46	TECTEH				T2170	seco	21H00046	H 0	600UL	331933
463	98	34		9.34	181	DNT	P 1	09H	+0.24	TECTEH				A6997	seco	21H00045	H 0	600UL	332253
464						NDF		09H	+0.24	09H09H				W4892	prim	21H00169	H 6	600PP	345337
465	1	35		0.23	81	PLP	9	TSC	+0.52	TSCTSC				A9608	reso	21C00078	C 2	600PP	345293
466	9	35		3.38	180	DNG	P 1	06H	+10.44	TECTEH				T2170	seco	21H00010	H 0	600UL	331933
467						NDF		VM	-0.61	05H06C				C3340	reso	21H00195	H 2	5602C	326252
468				0.44	141	DSI	P 1	VM	-0.61	TECTEH				D3858	reso	21H00010	H 0	600UL	331933
469	73	35		31.16	178	DNG	P 1	03C	+2.21	TECTEH				S8982	seco	21H00009	H 0	600UL	332253
470	81	35		2.58	177	DNG	P 1	VM	+2.78	TECTEH				S8982	seco	21H00009	H 0	600UL	332253
471	83	35		0.33	71	MBM	5	VH	+8.55	TECTEH				C5542	reso	21H00010	H 0	600UL	331933
472	89	35		0.55	83	MBM	5	04C	+14.46	TECTEH				C5542	reso	21H00009	H 0	600UL	332253
473				0.54	90	MBM	5	TSC	+12.94	TECTEH				C5542	reso	21H00009	H 0	600UL	332253
474	113	35		0.89	80	MBM	5	05C	+7.85	TECTEH				C5542	reso	21H00045	H 0	600UL	332253
475	2	36		0.23	77	INR	9	TSH	+0.05	TSHTSH				H3464	prim	21H00113	H 1	600PP	345281
476	10	36		7.50	183	DNG	P 1	04C	+29.01	TECTEH				T2170	seco	21H00006	H 0	600UL	331933
477				6.62	182	DNG	P 1	04C	+29.55	TECTEH				T2170	seco	21H00006	H 0	600UL	331933
478	24	36		0.83	104	MBM	5	04C	+26.72	TECTEH				C5542	reso	21H00005	H 0	600UL	332253
479	28	36		0.44	68	MBM	5	TSH	+34.06	TECTEH				C5542	reso	21H00006	H 0	600UL	331933
480	36	36				TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
481				0.21	79	SAI	1	TSH	+0.97	TSHTSH	0.3			C5542	reso	21H00113	H 1	600PP	345281
482				0.15	111	PID	4	TSH	+0.97	TSHTSH	080			D8661	reso	21H00150	H999	600PP	345337
483				0.16	103	SAI	2	TSH	+0.97	TSHTSH	0.3			C5542	reso	21H00113	H 1	600PP	345281
484	90	36		1.84	175	INR	P 1	TSH	+16.98	TECTEH				S8982	seco	21H00009	H 0	600UL	332253
	92	36		2.78	177	DNG	P 1	VH	+28.24	TECTEH				T2170	seco	21H00046	H 0	600UL	331933
	106	36		1.42	83	MBM	6	04H	+26.95	TECTEH				C5542	reso	21H00045	H 0	600UL	332253
487				0.60	34	INR	P 1	08H	-0.31	TECTEH				C5542	reso	21H00045	H 0	600UL	332253
488	1	37				TBP				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
489				3.45	12	GEO	2	06H	+7.16	06C06H				C3340	reso	21C00091	C 3	560FH	345357
490				3.91	11	PID	2	06H	+7.16	06C06H				G2927	prim	21C00093	C999	560FH	345360

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 11

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
491	3	37	2.10	182	DNT	P 1	06H	-0.11	06HTEC			N2574	seco	21C00057	C 0	600CS	341612
492			2.00	186	DNT	P 1	06H	-0.07	06HTEH			S4373	reso	21H00080	H 9	600UL	331933
493	15	37	1.87	179	INR	P 1	02H	+29.27	TECTEH			A6997	seco	21H00005	H 0	600UL	332253
494	25	37				TBS			TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
495			0.10	96	MAI	2	TSH	+0.27	TSHTSH	0.4		L2157	reso	21H00112	H 1	600PP	345337
			0.09	63	MAI	1	TSH	+0.27	TSHTSH	0.3		L2157	reso	21H00112	H 1	600PP	345337
			0.09	104	PID	4	TSH	+0.27	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
498			0.14	111	MAI	2	TSH	+0.79	TSHTSH	0.4		L2157	reso	21H00112	H 1	600PP	345337
499			0.15	49	MAI	1	TSH	+0.79	TSHTSH	0.4		L2157	reso	21H00112	H 1	600PP	345337
500			0.10	82	SAI	2	TSH	+1.49	TSHTSH	0.39		S4373	reso	21H00112	H 1	600PP	345337
501			0.20	69	SAI	1	TSH	+1.49	TSHTSH	0.23		D3858	reso	21H00112	H 1	600PP	345337

502	27	37	1.01	62	MBM	5	01C	+1.65	TECTEH			C5542	reso	21H00006	H 0	600UL	331933
503	31	37	0.62	86	MBM	5	TSC	+29.42	TECTEH			C5542	reso	21H00006	H 0	600UL	331933
504	35	37	2.41	181	DNG	P 1	05H	+28.19	TECTEH			T2170	seco	21H00006	H 0	600UL	331933
	49	37			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
			0.16	82	PID	4	TSH	+0.36	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
507			0.20	54	SAI	1	TSH	+0.36	TSHTSH	0.3		L2157	reso	21H00112	H 1	600PP	345337
508			0.14	79	SAI	2	TSH	+0.36	TSHTSH	0.4		L2157	reso	21H00112	H 1	600PP	345337
509			0.00	0	SAI	1	TSH	+1.06	TSHTSH	0.0		M1680	reso	21H00112	H 1	600PP	345337
510			0.10	93	SAI	2	TSH	+1.06	TSHTSH	0.3		M1680	reso	21H00112	H 1	600PP	345337
511	69	37	1.19	91	MBM	5	05H	+14.10	TECTEH			C5542	reso	21H00006	H 0	600UL	331933
512	77	37	0.56	76	MBM	5	01C	+25.61	TECTEH			C5542	reso	21H00005	H 0	600UL	332253
513	95	37	0.95	89	MBM	5	05H	+16.25	TECTEH			C5542	reso	21H00045	H 0	600UL	332253
514			0.59	87	MBM	5	TSC	+16.10	TECTEH			C5542	reso	21H00045	H 0	600UL	332253
515	99	37	0.40	79	MBM	5	03H	+18.63	TECTEH			C5542	reso	21H00045	H 0	600UL	332253
516	101	37	0.34	63	MBM	5	09H	+2.90	TECTEH			C5542	reso	21H00046	H 0	600UL	331933
517	113	37	0.63	70	MBM	5	01H	+25.61	TECTEH			C5542	reso	21H00046	H 0	600UL	331933
518			1.09	84	MBM	5	05H	+32.27	TECTEH			C5542	reso	21H00046	H 0	600UL	331933
519	115	37	0.78	87	MBM	5	01H	+16.45	TECTEH			C5542	reso	21H00045	H 0	600UL	332253
520			0.44	89	MBM	5	01H	+37.58	TECTEH			C5542	reso	21H00045	H 0	600UL	332253
521	2	38	0.28	82	PLP	9	TSC	+0.33	TSCTSC			A9608	reso	21C00078	C 2	600PP	345293
522	18	38			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
523			0.05	71	SAI	1	TSH	+0.63	TSHTSH	0.2		C5542	reso	21H00108	H 1	600PP	345281
524			0.10	95	SAI	2	TSH	+0.63	TSHTSH	0.3		C5542	reso	21H00108	H 1	600PP	345281
525			0.12	107	PID	4	TSH	+0.63	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
526			0.44	83	MBM	5	TSH	+18.32	TECTEH			C5542	reso	21H00005	H 0	600UL	332253
527			0.41	82	MBM	5	01H	+12.55	TECTEH			C5542	reso	21H00005	H 0	600UL	332253
528			0.47	81	MBM	5	01H	+31.92	TECTEH			C5542	reso	21H00005	H 0	600UL	332253
529	26	38			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
530			0.17	119	MAI	2	TSH	+0.62	TSHTSH	0.3		A9608	reso	21H00108	H 1	600PP	345281
			0.00	0	MAI	1	TSH	+0.62	TSHTSH	0.0		A9608	reso	21H00108	H 1	600PP	345281
			0.14	123	PID	4	TSH	+0.62	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
533	32	38	2.81	182	DNT	P 1	VM	+1.48	TECTEH			A9574	seco	21H00006	H 0	600UL	331933
534	36	38	0.55	75	MBM	5	01H	+7.19	TECTEH			C5542	reso	21H00006	H 0	600UL	331933
535	38	38	1.80	178	INR	P 1	04C	+8.05	TECTEH			A6997	seco	21H00005	H 0	600UL	332253
536	44	38	1.56	49	MBM	6	05C	+1.60	TECTEH			C5542	reso	21H00006	H 0	600UL	331933
537			3.98	57	MBM	6	04C	+36.94	TECTEH			C5542	reso	21H00006	H 0	600UL	331933
538	46	38			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
539			0.17	86	PID	4	TSH	+0.57	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 12

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
540		0.22	83	MAI	2	TSH	+0.57	TSHTSH	0.4		C5542	reso	21H00108	H 1	600PP	345281
541		0.00	0	MAI	1	TSH	+0.57	TSHTSH	0.0		A9608	reso	21H00108	H 1	600PP	345281
	60 38	4.52	179	DNG	P 1	04H	+31.09	TECTEH			A6997	seco	21H00005	H 0	600UL	332253
	64 38	1.21	61	MBM	5	TSH	+4.06	TECTEH			C5542	reso	21H00005	H 0	600UL	332253
544		0.52	152	VOL	P 1	TSH	+4.14	TSHTSH			C5542	reso	21H00108	H 1	600PP	345281
545	74 38	0.28	75	NQI	5	01H	+27.49	TECTEH			C5542	reso	21H00005	H 0	600UL	332253
546				NDF		02H	-11.51	02H02H	ENCODE		D3858	reso	21H00169	H 3	600PP	345337
547	84 38	0.43	84	MBM	5	08H	+3.49	TECTEH			C5542	reso	21H00005	H 0	600UL	332253

548	92	38	3.74	176	DNG	P 1	VH	+28.57	TECTEH			T2170	seco	21H00046	H 0	600UL	331933
549			6.58	180	DNT	P 1	09C	-0.40	TECTEH			T2170	seco	21H00046	H 0	600UL	331933
550	98	38	4.25	179	DNG	P 1	07H	+19.39	TECTEH			A6997	seco	21H00045	H 0	600UL	332253
			8.07	179	DNT	P 1	08H	+0.61	TECTEH			A6997	seco	21H00045	H 0	600UL	332253
			4.17	179	DNG	P 1	08H	+1.92	TECTEH			A6997	seco	21H00045	H 0	600UL	332253
553			9.05	177	DNG	P 1	08H	+2.91	TECTEH			A6997	seco	21H00045	H 0	600UL	332253
554			2.09	179	DNG	P 1	08H	+12.13	TECTEH			A6997	seco	21H00045	H 0	600UL	332253
555			6.34	179	DNT	P 1	07C	-0.52	TECTEH			A6997	seco	21H00045	H 0	600UL	332253
556			2.36	175	DNG	P 1	07C	+1.49	TECTEH			A6997	seco	21H00045	H 0	600UL	332253
557			3.37	177	DNG	P 1	07C	+4.67	TECTEH			A6997	seco	21H00045	H 0	600UL	332253
558	104	38	3.61	172	DNG	P 1	05H	+6.59	TECTEH			T2170	seco	21H00046	H 0	600UL	331933
559	106	38	3.01	178	DNG	P 1	07H	+23.72	TECTEH			A6997	seco	21H00045	H 0	600UL	332253
560			3.17	176	DNT	P 1	08H	-0.27	TECTEH			A6997	seco	21H00045	H 0	600UL	332253
561			7.79	177	DNG	P 1	08H	+6.03	TECTEH			A6997	seco	21H00045	H 0	600UL	332253
562			9.60	171	INR	P 1	09C	+14.03	TECTEH			A6997	seco	21H00045	H 0	600UL	332253
563	110	38	1.05	93	MBM	5	04H	+35.30	TECTEH			C5542	reso	21H00045	H 0	600UL	332253
564	116	38	0.53	69	MBM	5	TSH	+4.75	TECTEH			C5542	reso	21H00045	H 0	600UL	332253
565	11	39	10.58	180	DNG	P 1	06H	+7.59	TECTEH			N5877	seco	21H00005	H 0	600UL	332253
566	15	39	3.34	181	DNG	P 1	02C	+30.08	TECTEH			N5877	seco	21H00005	H 0	600UL	332253
567	19	39			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
568			0.26	77	PID	4	TSH	+0.18	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
569			0.08	103	SAI	1	TSH	+0.18	TSHTSH	0.2		C5542	reso	21H00108	H 1	600PP	345281
570			0.21	77	SAI	2	TSH	+0.18	TSHTSH	0.2		C5542	reso	21H00108	H 1	600PP	345281
571	37	39	0.75	59	MBM	6	02H	+29.26	TECTEH			C5542	reso	21H00005	H 0	600UL	332253
572			1.18	33	MBM	6	02H	+34.67	TECTEH			C5542	reso	21H00005	H 0	600UL	332253
573	49	39	2.19	182	DNG	P 1	04C	+15.01	TECTEH			A9574	seco	21H00006	H 0	600UL	331933
574	51	39	0.72	63	MBM	5	03C	+31.72	TECTEH			C5542	reso	21H00005	H 0	600UL	332253
575	57	39	2.07	181	DNG	P 1	TSC	+2.88	TECTEH			N5877	seco	21H00005	H 0	600UL	332253
576			5.32	185	DNG	P 1	TSC	+3.38	TECTEH			N5877	seco	21H00005	H 0	600UL	332253
			7.33	181	DNG	P 1	TSC	+10.50	TECTEH			N5877	seco	21H00005	H 0	600UL	332253
	91	39	1.53	179	INR	P 1	TSC	+21.90	TECTEH			C5542	reso	21H00046	H 0	600UL	331933
579	95	39	0.74	128	DSI	P 1	09H	+0.04	TECTEH			B4165	prim	21H00046	H 0	600UL	331933
580					NDF		09H	+0.04	09H09H			W4892	prim	21H00169	H 3	600PP	345337
581			2.40	177	DNG	P 1	VM	+3.79	TECTEH			T2170	seco	21H00046	H 0	600UL	331933
582			0.32	82	MBM	5	04C	+30.52	TECTEH			C5542	reso	21H00046	H 0	600UL	331933
583	97	39	5.93	181	DNG	P 1	08H	+1.63	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
584			4.69	181	DNG	P 1	08H	+2.52	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
585			14.40	180	DNG	P 1	08H	+3.44	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
586			10.00	183	DNG	P 1	08H	+3.96	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
587			9.46	180	DNG	P 1	08H	+4.36	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
588			2.53	182	DNG	P 1	08H	+5.25	TECTEH			C5542	reso	21H00079	H 0	600UL	340882

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 13

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
			8.10	179	DNG	P 1	08H	+6.76	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
590			24.15	180	DNG	P 1	08H	+7.69	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
591			6.98	182	DNG	P 1	08H	+8.28	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
592			10.51	180	DNG	P 1	08H	+17.50	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
593			7.59	179	DNG	P 1	08H	+19.10	TECTEH			F7467	seco	21H00079	H 0	600UL	340882

594				3.50	179	DNG	P 1	08H	+19.79	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
595				4.11	180	DNG	P 1	08H	+20.44	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
596				3.99	181	DNG	P 1	09H	-1.54	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
				1.96	183	INR	P 1	09H	-0.87	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
				3.14	186	DNT	P 1	09H	+0.52	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
599				3.17	178	DNG	P 1	09C	-1.25	TECTEH			C5542	reso	21H00079	H 0	600UL	340882
600				19.64	179	DNT	P 1	09C	-0.41	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
601				9.01	176	DNT	P 1	09C	+0.25	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
602				5.45	177	DNT	P 1	08C	-0.33	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
603				2.87	180	DNT	P 1	08C	+0.39	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
604				10.80	180	DNG	P 1	08C	+10.46	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
605				10.78	179	DNG	P 1	08C	+12.14	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
606				28.68	180	DNG	P 1	08C	+13.30	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
607				4.59	179	DNG	P 1	08C	+15.37	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
608				3.64	183	DNG	P 1	08C	+15.76	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
609				5.32	182	DNG	P 1	08C	+17.84	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
610				9.55	182	DNG	P 1	08C	+18.66	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
611				10.75	183	DNG	P 1	08C	+19.64	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
612				13.15	180	DNG	P 1	08C	+20.66	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
613				6.04	180	DNG	P 1	07C	+19.10	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
614				8.57	181	DNG	P 1	07C	+20.62	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
615				2.23	178	DNG	P 1	07C	+22.18	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
616				11.59	180	DNG	P 1	07C	+23.12	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
617				25.55	178	DNG	P 1	07C	+24.42	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
618				2.95	178	DNG	P 1	06C	+21.40	TECTEH			F7467	seco	21H00079	H 0	600UL	340882
619	2	40		5.54	179	DNG	P 1	05H	+32.33	06HTEH			M0945	seco	21H00080	H 9	600UL	331933
620	18	40		0.70	99	MBM	5	02C	+25.89	TECTEH			C5542	reso	21H00005	H 0	600UL	332253
621				0.91	88	MBM	5	02C	+29.22	TECTEH			C5542	reso	21H00005	H 0	600UL	332253
622				0.55	83	MBM	5	01C	+29.69	TECTEH			C5542	reso	21H00005	H 0	600UL	332253
	28	40		0.44	40	INR	P 1	TSH	+1.16	TECTEH			A9608	reso	21H00006	H 0	600UL	331933
[illegible]	38	40		0.57	90	MBM	5	02C	+26.01	TECTEH			C5542	reso	21H00005	H 0	600UL	332253
625	46	40				TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
626				0.21	105	MAI	2	TSH	+0.54	TSHTSH	0.3		C5542	reso	21H00107	H 1	600PP	345333
627				0.19	121	PID	4	TSH	+0.54	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
628				0.14	141	MAI	1	TSH	+0.54	TSHTSH	0.3		C5542	reso	21H00107	H 1	600PP	345333
629				0.00	0	SAI	1	TSH	+1.27	TSHTSH	0.0		A9608	reso	21H00107	H 1	600PP	345333
630				0.14	66	SAI	2	TSH	+1.27	TSHTSH	0.2		C5542	reso	21H00107	H 1	600PP	345333
631	52	40		2.28	176	DNG	P 1	TSH	+28.89	TECTEH			A9574	seco	21H00006	H 0	600UL	331933
632				2.87	187	DNT	P 1	04C	-1.02	TECTEH			A9574	seco	21H00006	H 0	600UL	331933
633	80	40				TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
634				0.13	126	SAI	2	TSH	+0.66	TSHTSH	0.2		C5542	reso	21H00108	H 1	600PP	345281
635				0.00	0	SAI	1	TSH	+0.66	TSHTSH	0.0		A9608	reso	21H00108	H 1	600PP	345281
636				0.19	123	PID	4	TSH	+0.66	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
637	84	40		9.82	183	DNG	P 1	01H	+29.98	TECTEH			N5877	seco	21H00005	H 0	600UL	332253

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 14

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
638	104	40	3.61	178	DNG	P 1	09C	-2.04	TECTEH			T2170	seco	21H00046	H 0	600UL	331933
639	108	40	2.20	175	DNG	P 1	TSH	+11.44	TECTEH			T2170	seco	21H00046	H 0	600UL	331933

640				4.03	176	DNG	P	1	05H	+14.11	TECTEH			T2170	seco	21H00046	H	0	600UL	331933
641	116	40		0.78	88	MBM		5	04H	+22.29	TECTEH			C5542	reso	21H00045	H	0	600UL	332253
642	118	40		0.61	67	MBM		5	05C	+26.82	TECTEH			C5542	reso	21H00045	H	0	600UL	332253
[illegible]	7	41		0.66	79	NQI		5	02C	+17.27	TECTEH			L2157	reso	21H00001	H	0	600UL	332253
						NDF			02C	+17.27	02C03C			D4576	seco	21C00082	C	4	600PP	345344
645	15	41		20.34	179	DNG	P	1	06C	+14.39	TECTEH			L2157	reso	21H00001	H	0	600UL	332253
646	39	41		2.83	180	DNT	P	1	VM	-1.71	TECTEH			N2574	seco	21H00002	H	0	600UL	331933
647	45	41		3.51	180	DNG	P	1	TSH	+29.31	TECTEH			N5877	seco	21H00001	H	0	600UL	332253
648	77	41		0.37	89	NQI	P	1	TSH	+0.62	TECTEH			N5877	seco	21H00001	H	0	600UL	332253
649						NDF			TSH	+0.62	TSHTSH			F7467	seco	21H00107	H	1	600PP	345333
650	81	41		0.58	78	MBM		5	05C	+18.44	TECTEH			A9608	reso	21H00001	H	0	600UL	332253
651	85	41				TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
652				0.16	106	PID		4	TSH	+0.19	TSHTSH	080		D8661	reso	21H00150	H999		600PP	345337
653				0.19	23	MAI		1	TSH	+0.19	TSHTSH	0.3		C5542	reso	21H00107	H	1	600PP	345333
654				0.19	102	MAI		2	TSH	+0.19	TSHTSH	0.3		C5542	reso	21H00107	H	1	600PP	345333
655	89	41		2.42	182	DNG	P	1	05C	+14.27	TECTEH			N5877	seco	21H00001	H	0	600UL	332253
656				1.10	71	MBM		6	04C	+27.94	TECTEH			L2157	reso	21H00001	H	0	600UL	332253
657	91	41		2.50	176	DNG	P	1	TSH	+20.49	TECTEH			A6997	seco	21H00045	H	0	600UL	332253
658				3.19	181	DNT	P	1	09C	-0.53	TECTEH			A6997	seco	21H00045	H	0	600UL	332253
659	115	41		0.35	77	PLP		9	TSH	+0.50	TSHTSH			L2157	reso	21H00135	H	1	600PP	345281
660				9.24	180	DNT	P	1	09H	-0.25	TECTEH			A6997	seco	21H00045	H	0	600UL	332253
661				2.77	182	DNG	P	1	TSC	+7.02	TECTEH			A6997	seco	21H00045	H	0	600UL	332253
662	119	41				NDF			09H	+0.24	09H09H			S8982	seco	21H00170	H	3	600PP	345325
663				0.32	116	DSI	P	1	09H	+0.24	TECTEH			N9952	prim	21H00045	H	0	600UL	332253
664				4.40	180	DNG	P	1	10C	+2.22	TECTEH			A6997	seco	21H00045	H	0	600UL	332253
665	22	42				TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
666				0.11	36	SAI		1	TSH	+0.39	TSHTSH	0.5		C5542	reso	21H00108	H	1	600PP	345281
667				0.15	99	PID		4	TSH	+0.39	TSHTSH	080		D8661	reso	21H00150	H999		600PP	345337
668				0.13	90	SAI		2	TSH	+0.39	TSHTSH	0.4		C5542	reso	21H00108	H	1	600PP	345281
	24	42		0.67	73	MBM		5	TSH	+30.82	TECTEH			L2157	reso	21H00001	H	0	600UL	332253
[illegible]	26	42				TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
671				0.15	85	PID		4	TSH	+0.22	TSHTSH	080		D8661	reso	21H00150	H999		600PP	345337
672				0.15	86	SAI		2	TSH	+0.22	TSHTSH	0.2		C5542	reso	21H00108	H	1	600PP	345281
673				0.00	0	SAI		1	TSH	+0.22	TSHTSH	0.0		A9608	reso	21H00108	H	1	600PP	345281
674	46	42		0.86	69	MBM		6	02H	+32.79	TECTEH			L2157	reso	21H00001	H	0	600UL	332253
675	56	42		0.92	70	MBM		5	05H	+16.90	TECTEH			L2157	reso	21H00001	H	0	600UL	332253
676	62	42		0.30	5	INR	P	1	05C	-0.48	TECTEH			L2157	reso	21H00001	H	0	600UL	332253
677	66	42				NDF			01H	+26.81	01H02H			F6623	reso	21H00178	H	3	600PP	345339
678				0.48	66	NQI		5	01H	+26.81	TECTEH			L2157	reso	21H00001	H	0	600UL	332253
679	78	42				NDF			06C	+14.25	05C08C			D4576	seco	21C00082	C	4	600PP	345344
680				0.42	68	NQI		5	06C	+14.25	TECTEH			L2157	reso	21H00001	H	0	600UL	332253
681				1.61	86	MBM		6	05C	+1.23	TECTEH			L2157	reso	21H00001	H	0	600UL	332253
682						NDF			05C	+24.22	05C08C			D4576	seco	21C00082	C	4	600PP	345344
683				0.51	59	NQI		5	05C	+24.22	TECTEH			L2157	reso	21H00001	H	0	600UL	332253
684	86	42		3.38	179	DNG	P	1	02H	+28.14	TECTEH			N5877	seco	21H00001	H	0	600UL	332253
685	90	42		3.57	180	DNG	P	1	08H	+19.17	TECTEH			N5877	seco	21H00001	H	0	600UL	332253
686				2.82	179	DNG	P	1	09C	-1.25	TECTEH			N5877	seco	21H00001	H	0	600UL	332253

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N

687	114	42	9.58	182	DNT	P 1	09H	-0.32	TECTEH				A6997	seco	21H00045	H 0	600UL	332253
688	120	42	4.29	175	DNT	P 1	10C	+0.39	TECTEH				A6997	seco	21H00045	H 0	600UL	332253
			0.57	62	MBM	5	03C	+24.27	TECTEH				C5542	reso	21H00045	H 0	600UL	332253
	1	43			INF		TSH	+0.35	TSHTSH	HR			A9608	reso	21H00108	H 1	600PP	345281
691	17	43	5.05	180	DNT	P 1	DC	-2.13	TECTEH				N2574	seco	21H00002	H 0	600UL	331933
692	45	43	2.97	175	DNG	P 1	04C	+9.82	TECTEH				N5877	seco	21H00001	H 0	600UL	332253
693			3.44	180	DNG	P 1	04C	+14.34	TECTEH				N5877	seco	21H00001	H 0	600UL	332253
694			2.45	179	DNG	P 1	02C	+30.24	TECTEH				N5877	seco	21H00001	H 0	600UL	332253
695	47	43	4.65	184	DNG	P 1	04C	+20.06	TECTEH				N2574	seco	21H00002	H 0	600UL	331933
696			2.79	182	DNG	P 1	04C	+26.79	TECTEH				N2574	seco	21H00002	H 0	600UL	331933
697	59	43			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
698			0.22	51	SAI	1	TSH	+0.56	TSHTSH	0.2			A9608	reso	21H00103	H 1	600PP	345333
699			0.15	94	SAI	2	TSH	+0.56	TSHTSH	0.3			A9608	reso	21H00103	H 1	600PP	345333
700			0.21	106	PID	4	TSH	+0.56	TSHTSH	080			D8661	reso	21H00150	H999	600PP	345337
701			0.17	100	MAI	2	TSH	+0.96	TSHTSH	0.2			A9608	reso	21H00103	H 1	600PP	345333
702			0.13	23	MAI	1	TSH	+0.96	TSHTSH	0.2			A9608	reso	21H00103	H 1	600PP	345333
703			0.62	58	MBM	5	01H	+2.44	TECTEH				A9608	reso	21H00002	H 0	600UL	331933
704	67	43			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
705			0.12	59	PID	4	TSH	+0.67	TSHTSH	080			D8661	reso	21H00150	H999	600PP	345337
706			0.19	23	SAI	1	TSH	+0.67	TSHTSH	0.2			A9608	reso	21H00103	H 1	600PP	345333
707			0.07	79	SAI	2	TSH	+0.67	TSHTSH	0.2			A9608	reso	21H00103	H 1	600PP	345333
708			2.69	178	DNT	P 1	07C	+1.01	TECTEH				N5877	seco	21H00001	H 0	600UL	332253
709			8.00	182	DNG	P 1	07C	+14.48	TECTEH				N5877	seco	21H00001	H 0	600UL	332253
710	71	43			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
711			0.19	115	PID	4	TSH	+0.71	TSHTSH	080			D8661	reso	21H00150	H999	600PP	345337
712			0.14	94	SAI	2	TSH	+0.71	TSHTSH	0.3			A9608	reso	21H00103	H 1	600PP	345333
713			0.00	0	SAI	1	TSH	+0.71	TSHTSH	0.0			A9608	reso	21H00103	H 1	600PP	345333
714	75	43	0.64	84	MBM	5	03H	+13.10	TECTEH				M7006	reso	21H00002	H 0	600UL	331933
	77	43	0.40	77	NQI	5	02H	+26.53	TECTEH				L2157	reso	21H00001	H 0	600UL	332253
					NDF		02H	+26.53	02H03H				W4892	prim	21H00169	H 3	600PP	345337
717	81	43	2.14	177	DNG	P 1	04H	+25.55	TECTEH				N5877	seco	21H00001	H 0	600UL	332253
718			0.66	70	MBM	6	01C	+14.65	TECTEH				A9608	reso	21H00001	H 0	600UL	332253
719	109	43	0.68	85	MBM	5	05H	+2.78	TECTEH				C5542	reso	21H00046	H 0	600UL	331933
720	117	43	5.35	182	DNT	P 1	10C	-0.33	TECTEH				C5542	reso	21H00046	H 0	600UL	331933
721			21.90	175	DNT	P 1	10C	+0.22	TECTEH				C5542	reso	21H00046	H 0	600UL	331933
722	119	43	2.17	164	INR	P 1	DC	-0.79	TECTEH				C5542	reso	21H00041	H 0	600UL	332253
723			5.06	181	DNT	P 1	10C	-0.52	TECTEH				D4576	seco	21H00041	H 0	600UL	332253
724			5.64	180	DNT	P 1	10C	+0.41	TECTEH				D4576	seco	21H00041	H 0	600UL	332253
725			6.69	180	DNG	P 1	10C	+2.40	TECTEH				D4576	seco	21H00041	H 0	600UL	332253
726	2	44	0.31	64	INR	2	TSH	+2.47	TSHTSH				M7006	reso	21H00104	H 1	600PP	345297
727	16	44	3.14	181	DNT	P 1	DC	-0.45	TECTEH				L2157	reso	21H00001	H 0	600UL	332253
728			5.97	180	DNT	P 1	DC	+1.72	TECTEH				L2157	reso	21H00001	H 0	600UL	332253
729			6.03	180	DNT	P 1	DC	+2.23	TECTEH				L2157	reso	21H00001	H 0	600UL	332253
730	22	44			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
731			0.00	0	SAI	1	TSH	+0.16	TSHTSH	0.0			D3858	reso	21H00104	H 1	600PP	345297
732			0.16	105	SAI	2	TSH	+0.16	TSHTSH	0.18			M7006	reso	21H00104	H 1	600PP	345297
733			0.17	111	PID	4	TSH	+0.16	TSHTSH	080			D8661	reso	21H00150	H999	600PP	345337
734	50	44	2.71	185	DNG	P 1	01C	+16.99	TECTEH				N5877	seco	21H00001	H 0	600UL	332253
735	54	44	0.73	80	MBM	5	01H	+34.04	TECTEH				A9608	reso	21H00001	H 0	600UL	332253

SG 21 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP,

PLANT: CCNPP

UNIT: 2

SG: 21

MAY. 17,2001 13:47

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
	62	44			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
737			0.13	95	SAI	1	TSH	+0.54	TSHTSH	0.2		A9608	reso	21H00103	H 1	600PP	345333
738			0.15	88	SAI	2	TSH	+0.54	TSHTSH	0.3		A9608	reso	21H00103	H 1	600PP	345333
739			0.37	118	NQI	P 1	TSH	+0.77	TECTEH			D9424	prim	21H00001	H 0	600UL	332253
740			0.25	68	MAI	1	TSH	+0.98	TSHTSH	0.2		A9608	reso	21H00103	H 1	600PP	345333
741			0.23	94	PID	4	TSH	+0.98	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
742			0.20	104	MAI	2	TSH	+0.98	TSHTSH	0.5		A9608	reso	21H00103	H 1	600PP	345333
743	84	44			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
744			0.12	87	PID	4	TSH	+0.14	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
745			0.03	23	SAI	1	TSH	+0.14	TSHTSH	0.2		A9608	reso	21H00103	H 1	600PP	345333
746			0.12	99	SAI	2	TSH	+0.14	TSHTSH	0.2		A9608	reso	21H00103	H 1	600PP	345333
747			2.04	176	DNG	P 1	TSH	+29.32	TECTEH			N2574	seco	21H00002	H 0	600UL	331933
748	86	44	20.12	178	DNG	P 1	08H	+15.30	TECTEH			N5877	seco	21H00001	H 0	600UL	332253
749			15.74	177	DNG	P 1	08H	+15.84	TECTEH			N5877	seco	21H00001	H 0	600UL	332253
750			9.70	181	DNT	P 1	08C	+1.11	TECTEH			N5877	seco	21H00001	H 0	600UL	332253
751	88	44			NDF		04C	+3.76	04C05C			D4576	seco	21C00082	C 4	600PP	345344
752			0.54	80	NQI	5	04C	+3.76	TECTEH			L2157	reso	21H00001	H 0	600UL	332253
753	92	44	3.17	177	DNG	P 1	TSC	+21.97	TECTEH			D4576	seco	21H00041	H 0	600UL	332253
754	98	44	0.54	107	MBM	5	02C	+30.81	TECTEH			C5542	reso	21H00042	H 0	600UL	331933
755	106	44	3.64	178	DNG	P 1	04C	+6.02	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
756	110	44	0.41	80	MBM	5	05H	+8.02	TECTEH			C5542	reso	21H00042	H 0	600UL	331933
757	120	44	1.43	124	INR	6	05H	+20.33	TECTEH			D4576	seco	21H00041	H 0	600UL	332253
758			8.77	184	DNT	P 1	10C	-0.52	TECTEH			D4576	seco	21H00041	H 0	600UL	332253
759			8.59	182	DNT	P 1	10C	+0.49	TECTEH			D4576	seco	21H00041	H 0	600UL	332253
760	122	44	0.86	90	MBM	5	05H	+18.94	TECTEH			C5542	reso	21H00042	H 0	600UL	331933
	11	45			TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
			0.17	111	PID	2	VM	-0.17	05H06C			B6768	prim	21H00213	H999	5602C	340933
763			0.14	87	SAI	2	VM	-0.17	05H06C	0.2		L2157	reso	21H00188	H 2	5602C	326184
764			0.17	136	SAI	1	VM	-0.17	05H06C	0.3		A9608	reso	21H00188	H 2	5602C	326184
765			0.65	61	NQI	P 1	VM	-0.12	TECTEH			A9608	reso	21H00001	H 0	600UL	332253
766	17	45	5.67	180	DNT	P 1	DC	-1.86	TECTEH			D3858	reso	21H00002	H 0	600UL	331933
767			5.17	179	DNG	P 1	DC	+7.49	TECTEH			N2574	seco	21H00002	H 0	600UL	331933
768	31	45			NDF		VM	+4.62	DC VM			D9424	prim	21C00086	H 5	5602C	326280
769			0.59	73	NQI	5	VM	+4.62	TECTEH			L2157	reso	21H00001	H 0	600UL	332253
770	45	45	2.55	180	DNG	P 1	05H	+12.61	TECTEH			N2574	seco	21H00002	H 0	600UL	331933
771			2.90	180	DNG	P 1	05H	+13.77	TECTEH			N2574	seco	21H00002	H 0	600UL	331933
772			2.41	179	DNG	P 1	05H	+14.10	TECTEH			N2574	seco	21H00002	H 0	600UL	331933
773			2.61	182	DNG	P 1	03C	+34.58	TECTEH			N2574	seco	21H00002	H 0	600UL	331933
774	57	45	0.93	81	MBM	6	04H	+35.18	TECTEH			M7006	reso	21H00002	H 0	600UL	331933
775			0.67	94	MBM	5	07H	+8.99	TECTEH	HR		D3858	reso	21H00002	H 0	600UL	331933
776	59	45	0.31	70	NQI	5	DH	+15.92	TECTEH			L2157	reso	21H00001	H 0	600UL	332253
777					NDF		DH	+15.92	VM DH			D9424	prim	21C00086	H 5	5602C	326280
778	65	45			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
779			0.12	87	MAI	3	TSH	+0.49	TSHTSH	0.4		F6623	reso	21H00150	H 1	600PP	345337
780			0.25	95	MAI	4	TSH	+0.49	TSHTSH	0.7		F6623	reso	21H00150	H 1	600PP	345337
781			0.19	104	PID	4	TSH	+0.49	TSHTSH	080		M7006	reso	21H00172	H999	600PP	345337
782	67	45			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
783			0.25	138	MAI	1	TSH	+0.89	TSHTSH	0.4		C3340	reso	21H00098	H 1	600PP	345297
784			0.21	113	PID	4	TSH	+0.89	TSHTSH	080		M7006	reso	21H00172	H999	600PP	345337

SG 21 - All Calls (Excluding NDD and retest codes)

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
785			0.18	116	MAI	2	TSH	+0.89	TSHTSH	0.4		C3340	reso	21H00098	H 1	600PP	345297
786	69	45			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
787			0.18	116	PID	4	TSH	+0.71	TSHTSH	080		M7006	reso	21H00172	H999	600PP	345337
788			0.19	93	SAI	4	TSH	+0.71	TSHTSH	0.4		F6623	reso	21H00150	H 1	600PP	345337
789			0.23	54	SAI	3	TSH	+0.71	TSHTSH	0.3		F6623	reso	21H00150	H 1	600PP	345337
790	71	45	1.06	101	MBM	5	01H	+26.39	TECTEH			A9608	reso	21H00001	H 0	600UL	332253
791			3.51	176	DNG	P 1	01H	+26.45	TECTEH			N5877	seco	21H00001	H 0	600UL	332253
792			0.53	73	NQI	5	03H	+26.75	TECTEH			L2157	reso	21H00001	H 0	600UL	332253
793			1.51	143	VOL	2	04H	-12.57	04H04H	ENCODE		S4373	reso	21H00169	H 3	600PP	345337
794	91	45	2.17	177	DNG	P 1	TSH	+28.85	TECTEH			D4576	seco	21H00041	H 0	600UL	332253
795			2.01	183	DNT	P 1	09C	-0.46	TECTEH			D4576	seco	21H00041	H 0	600UL	332253
796	95	45	1.22	85	MBM	5	01H	+26.70	TECTEH			C5542	reso	21H00042	H 0	600UL	331933
797	97	45	4.26	177	DNG	P 1	06H	+17.29	TECTEH			D4576	seco	21H00041	H 0	600UL	332253
798			5.25	180	DNG	P 1	09C	+5.52	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
799	105	45	1.04	62	MBM	5	09H	+7.73	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
800	109	45	3.84	179	DNG	P 1	VC	+12.48	TECTEH			D4576	seco	21H00041	H 0	600UL	332253
801	117	45	5.07	179	DNG	P 1	DH	+8.31	TECTEH			D4576	seco	21H00041	H 0	600UL	332253
802			6.72	179	DNT	P 1	10C	+0.37	TECTEH			D4576	seco	21H00041	H 0	600UL	332253
803			4.33	181	DNT	P 1	10C	+0.70	TECTEH			D4576	seco	21H00041	H 0	600UL	332253
804	119	45	0.22	83	PLP	9	TSH	+0.57	TSHTSH			L2157	reso	21H00135	H 1	600PP	345281
805			4.07	188	DNT	P 1	10C	-0.44	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
806			7.37	182	DNG	P 1	10C	+2.12	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
	123	45	9.13	182	DNG	P 1	08C	+4.51	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
	2	46			TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
809			0.24	89	PID	4	TSH	+0.11	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
810			0.25	88	LPI	2	TSH	+0.11	TSHTSH			F3453	reso	21H00147	H 1	600PP	345281
811	8	46			TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
812			0.09	127	PID	2	06C	+8.78	06H06C			C3340	reso	21H00216	H999	5602C	340933
813			0.00	0	SAI	1	06C	+8.78	05H06C	0.0		M1680	reso	21H00206	H 2	5602C	326245
814			0.17	85	SAI	2	06C	+8.78	05H06C	0.2		M1680	reso	21H00206	H 2	5602C	326245
815	12	46			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
816			0.00	0	SAI	1	TSH	+0.89	TSHTSH	0.0		F3453	reso	21H00146	H 1	600PP	345337
817			0.08	104	SAI	2	TSH	+0.89	TSHTSH	0.2		F3453	reso	21H00146	H 1	600PP	345337
818			0.00	0	MAI	1	TSH	+1.88	TSHTSH	0.0		F3453	reso	21H00146	H 1	600PP	345337
819			0.15	66	PID	4	TSH	+1.88	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
820			0.11	114	MAI	2	TSH	+1.88	TSHTSH	0.6		F3453	reso	21H00146	H 1	600PP	345337
821	24	46	3.11	181	DNG	P 1	06C	+15.36	TECTEH			F6623	reso	21H00049	H 0	600UL	332253
822	32	46	3.88	183	DNT	P 1	VM	+1.55	TECTEH			T2170	seco	21H00050	H 0	600UL	331933
823	48	46	2.35	179	DNG	P 1	02H	+33.82	TECTEH			T2170	seco	21H00050	H 0	600UL	331933
824	50	46			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
825			0.60	24	NQI	P 1	TSH	+0.70	TECTEH			F6623	reso	21H00049	H 0	600UL	332253
826			0.14	105	PID	4	TSH	+0.71	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
827			0.13	110	SAI	2	TSH	+0.71	TSHTSH	0.2		F3453	reso	21H00147	H 1	600PP	345281
828			0.00	0	SAI	1	TSH	+0.71	TSHTSH	0.0		F3453	reso	21H00147	H 1	600PP	345281
829	52	46			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
830			0.21	84	PID	4	TSH	+0.64	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
831			0.00	0	SAI	1	TSH	+0.64	TSHTSH	0.0		F3453	reso	21H00146	H 1	600PP	345337
			0.21	82	SAI	2	TSH	+0.64	TSHTSH	0.6		F3453	reso	21H00146	H 1	600PP	345337
	84	46	1.34	80	MBM	5	04H	+17.97	TECTEH			F6623	reso	21H00049	H 0	600UL	332253

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 18

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
834	92	46	6.30	182	DNG	P 1	TSH	+3.48	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
835	94	46	3.35	180	DNG	P 1	02C	+16.51	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
836	100	46	1.16	78	MBM	6	05H	+7.77	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
837	108	46	0.87	78	MBM	5	01H	+7.89	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
838			0.74	80	MBM	5	05H	+31.17	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
839	120	46	0.39	83	PLP	9	TSH	+0.53	TSHTSH			L2157	reso	21H00134	H 1	600PP	345337
840			5.20	186	DNT	P 1	10C	-0.58	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
841			4.12	176	DNT	P 1	10C	+0.45	TECTEH			D4576	seco	21H00041	H 0	600UL	332253
842	122	46	9.36	182	DNT	P 1	10C	-0.64	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
843			6.48	181	DNT	P 1	10C	+0.57	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
844			3.19	182	DNG	P 1	10C	+5.54	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
845			4.13	180	DNG	P 1	10C	+6.37	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
846	27	47			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
847			0.18	78	SAI	2	TSH	+0.16	TSHTSH	0.2		M1680	reso	21H00146	H 1	600PP	345337
848			0.00	0	SAI	1	TSH	+0.16	TSHTSH	0.0		M1680	reso	21H00146	H 1	600PP	345337
849			0.18	77	PID	4	TSH	+0.16	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
850	53	47	0.56	79	MBM	5	05C	+15.23	TECTEH			M7006	reso	21H00050	H 0	600UL	331933
851	57	47	1.48	184	INR	P 1	TSH	+27.51	TECTEH			T2170	seco	21H00050	H 0	600UL	331933
852	59	47	3.87	181	DNT	P 1	06C	-0.61	TECTEH			A6997	seco	21H00049	H 0	600UL	332253
	65	47	0.19	108	VOL	2	TSH	+3.03	TSHTSH			A9608	reso	21H00159	H 1	600PP	345337
			1.58	143	MBM	5	TSH	+18.00	TECTEH			M7006	reso	21H00050	H 0	600UL	331933
855	73	47	0.68	90	MBM	5	03H	-1.74	TECTEH			M7006	reso	21H00050	H 0	600UL	331933
856			0.56	84	MBM	5	04H	+5.10	TECTEH			M7006	reso	21H00050	H 0	600UL	331933
857	79	47	3.19	177	DNG	P 1	08C	+11.42	TECTEH			A6997	seco	21H00049	H 0	600UL	332253
858	81	47			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
859			0.11	77	MAI	2	TSH	+0.67	TSHTSH	0.2		F3453	reso	21H00143	H 1	600PP	345281
860			0.0	0	MAI	1	TSH	+0.67	TSHTSH	0.0		F3453	reso	21H00143	H 1	600PP	345281
861			0.12	103	SAI	2	TSH	+1.01	TSHTSH	0.2		F3453	reso	21H00143	H 1	600PP	345281
862			0.13	122	PID	4	TSH	+1.01	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
863			0.00	0	SAI	1	TSH	+1.01	TSHTSH	0.0		F3453	reso	21H00143	H 1	600PP	345281
864			0.76	96	MBM	5	TSH	+20.19	TECTEH			F6623	reso	21H00049	H 0	600UL	332253
865			3.39	180	DNT	P 1	06H	+1.03	TECTEH			A6997	seco	21H00049	H 0	600UL	332253
866	87	47	0.65	79	MBM	5	02H	+28.98	TECTEH			F6623	reso	21H00049	H 0	600UL	332253
867			13.83	180	DNT	P 1	VH	+0.46	TECTEH			A6997	seco	21H00049	H 0	600UL	332253
868			1.77	184	INR	P 1	VH	+28.73	TECTEH			A6997	seco	21H00049	H 0	600UL	332253
869	91	47	0.76	84	MBM	5	03H	+4.99	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
870			2.16	176	DNG	P 1	TSC	+22.76	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
871	103	47			NDF		09H	+0.00	09H09H			W4892	prim	21H00169	H 3	600PP	345337
872			0.34	128	DSI	P 1	09H	+0.00	TECTEH			P5436	prim	21H00041	H 0	600UL	332253
873	107	47	4.97	178	DNG	P 1	09H	-1.07	TECTEH			S4373	reso	21H00041	H 0	600UL	332253
874	113	47	0.16	80	PLP	9	TSC	+2.17	TSCTSC			I3805	seco	21C00071	C 2	600PP	345293
875	115	47	0.17	84	PLP	9	TSC	+1.29	TSCTSC			N2574	seco	21C00072	C 2	600PP	326401
876	121	47	16.51	181	DNG	P 1	08H	+4.77	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
877	123	47	2.72	179	DNG	P 1	09C	+21.89	TECTEH	LOCOK		S4373	reso	21H00041	H 0	600UL	332253
			0.12	83	INR	9	TSC	+0.11	TSCTSC			N2574	seco	21C00072	C 2	600PP	326401
	125	47	5.06	188	DNT	P 1	10C	-0.52	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
880			3.58	186	DNT	P 1	10C	+0.47	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
881	6	48			TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
882			0.34	13	SAI	2	05H	+14.56	05H06H	0.3		S4373	reso	21H00206	H 2	5602C	326245

SG 21 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 19

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
883			0.30	9	PID	2	05H	+14.56	05H06H			P2952	prim	21H00213	H999	5602C	340933
884			0.00	0	SAI	1	05H	+14.56	05H06H	0.0	PWSCC	D3858	reso	21H00206	H 2	5602C	326245
885	10	48	2.41	175	DNG	P 1	TSC	+8.33	TECTEH			A6997	seco	21H00049	H 0	600UL	332253
886	12	48			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
887			0.09	118	SAI	2	TSH	+1.88	TSHTSH	0.3		F3453	reso	21H00147	H 1	600PP	345281
888			0.00	0	SAI	1	TSH	+1.88	TSHTSH	0.0		F3453	reso	21H00147	H 1	600PP	345281
889			0.07	86	PID	4	TSH	+1.88	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
890	14	48	10.92	175	DNG	P 1	06H	+12.43	TECTEH			A6997	seco	21H00049	H 0	600UL	332253
891	32	48	0.95	95	MBM	5	06C	+24.21	TECTEH			M7006	reso	21H00050	H 0	600UL	331933
892	38	48	6.14	178	DNG	P 1	07H	+1.65	TECTEH			A6997	seco	21H00049	H 0	600UL	332253
893	48	48	0.75	71	MBM	5	01C	+23.29	TECTEH			M7006	reso	21H00050	H 0	600UL	331933
894	52	48	3.92	184	DNG	P 1	05C	+8.61	TECTEH			T2170	seco	21H00050	H 0	600UL	331933
895	56	48	1.44	95	MBM	6	TSC	+26.32	TECTEH			M7006	reso	21H00050	H 0	600UL	331933
896	58	48	2.48	179	DNG	P 1	05H	+37.58	TECTEH			A6997	seco	21H00049	H 0	600UL	332253
897	60	48	2.91	180	DNG	P 1	04H	+29.42	TECTEH			T2170	seco	21H00050	H 0	600UL	331933
898	72	48	0.57	62	NQI	5	08H	+6.15	TECTEH			A9608	reso	21H00050	H 0	600UL	331933
					NDF		08H	+6.15	DH 08H			D9424	prim	21C00086	H 5	5602C	326280
[illegible]	90	48	3.67	182	DNT	P 1	05C	-0.61	TECTEH			A6997	seco	21H00049	H 0	600UL	332253
901	98	48	0.72	81	MBM	5	TSH	+30.03	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
902			0.65	83	MBM	6	04C	+25.06	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
903	112	48	0.55	94	MBM	5	04H	+34.72	TECTEH			C5542	reso	21H00042	H 0	600UL	331933
904			0.57	95	MBM	5	07H	+18.47	TECTEH			C5542	reso	21H00042	H 0	600UL	331933
905	118	48	2.53	182	DNT	P 1	09H	-0.32	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
906					INF		TSC	+0.46	TSCTSC	HR		F3453	reso	21C00072	C 2	600PP	326401
907	120	48			INF		TSC	+0.38	TSCTSC	HR		F6623	reso	21C00071	C 2	600PP	345293
908	124	48	2.44	177	DNT	P 1	10C	-0.54	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
909			4.08	180	DNG	P 1	10C	+7.20	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
910	9	49	2.42	178	DNG	P 1	02C	+10.09	TECTEH			A6997	seco	21H00049	H 0	600UL	332253
911	21	49	2.10	172	DNG	P 1	06H	+13.19	TECTEH			T2170	seco	21H00050	H 0	600UL	331933
912	23	49	0.66	89	MBM	5	05C	+4.62	TECTEH			F6623	reso	21H00049	H 0	600UL	332253
913	73	49	3.13	178	DNG	P 1	08C	+6.00	TECTEH			A9608	reso	21H00053	H 0	600UL	332253
914	89	49	1.79	179	INR	P 1	04H	+12.28	TECTEH			A9608	reso	21H00053	H 0	600UL	332253
915	91	49	0.52	85	MBM	5	02H	+31.61	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
916			9.41	180	DNG	P 1	07H	+21.89	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
917			7.82	180	DNG	P 1	08H	+11.75	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
918			3.11	179	DNG	P 1	08H	+20.43	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
919			1.97	185	INR	P 1	08C	+2.07	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
920			5.60	182	DNG	P 1	08C	+3.23	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
921			8.58	178	DNG	P 1	08C	+4.12	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
922			2.61	183	INR	P 1	08C	+6.13	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
923			2.27	184	DNG	P 1	08C	+7.34	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
			1.87	180	INR	P 1	08C	+7.98	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
			3.93	181	DNG	P 1	08C	+9.23	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
926			6.97	181	DNG	P 1	08C	+21.44	TECTEH	LOCOK		S4373	reso	21H00041	H 0	600UL	332253
927	95	49	2.11	180	DNG	P 1	01H	+12.80	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
928			4.14	183	DNG	P 1	07H	+21.54	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
929			4.44	180	DNG	P 1	07H	+23.12	TECTEH			A9574	seco	21H00042	H 0	600UL	331933

930				5.48	182	DNG	P 1	08H	+12.03	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
931				2.93	179	DNG	P 1	08H	+20.18	TECTEH			A9574	seco	21H00042	H 0	600UL	331933

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 20

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
932			3.59	180	DNG	P 1	08H	+21.01	TECTEH	LOCOK		S4373	reso	21H00042	H 0	600UL	331933
933			3.20	184	DNG	P 1	08H	+21.36	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
934			7.45	183	DNT	P 1	09H	-0.35	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
935			13.72	180	DNT	P 1	09H	+0.20	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
936			6.38	182	DNT	P 1	09H	+0.43	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
937			4.26	188	DNG	P 1	08C	+13.23	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
938			5.90	180	DNG	P 1	06C	+14.31	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
939	97	49	5.49	178	DNG	P 1	07H	+22.71	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
940			12.11	178	DNG	P 1	07H	+23.53	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
941			11.48	178	DNG	P 1	07H	+24.76	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
942			3.99	180	DNG	P 1	08H	-1.31	TECTEH			S4373	reso	21H00041	H 0	600UL	332253
943			12.38	179	DNT	P 1	08H	-0.36	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
944			4.00	179	DNG	P 1	08H	+1.60	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
			19.13	180	DNG	P 1	08H	+2.53	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
			2.57	186	DNG	P 1	08H	+4.68	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
947			14.09	180	DNG	P 1	08H	+5.61	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
948			4.59	181	DNG	P 1	08H	+6.60	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
949			12.06	178	DNG	P 1	08H	+7.57	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
950			6.41	179	DNG	P 1	08H	+9.66	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
951			5.63	181	DNG	P 1	08C	+11.38	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
952			3.61	178	DNG	P 1	08C	+13.99	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
953	101	49	0.28	146	10	P 2	VH	-1.32	TECTEH			P5436	prim	21H00041	H 0	600UL	332253
954	111	49	5.33	181	DNG	P 1	09C	+17.40	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
955	119	49	1.09	100	MBM	5	02H	+25.25	TECTEH			C5542	reso	21H00042	H 0	600UL	331933
956			1.32	93	MBM	5	04H	+14.85	TECTEH			C5542	reso	21H00042	H 0	600UL	331933
957					INF		TSC	+0.45	TSCTSC	HR		F6623	reso	21C00071	C 2	600PP	345293
958	121	49	6.99	179	DNG	P 1	10C	+3.91	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
959	127	49	2.18	187	DNT	P 1	10H	+0.77	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
960			4.04	175	DNT	P 1	VM	+1.92	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
961	10	50	2.46	185	DNT	P 1	05C	+1.10	TECTEH			A6997	seco	21H00054	H 0	600UL	331933
962	20	50	7.10	180	DNG	P 1	VM	+15.18	TECTEH			A6997	seco	21H00054	H 0	600UL	331933
963	26	50	6.05	177	DNG	P 1	06C	+17.10	TECTEH			A9608	reso	21H00053	H 0	600UL	332253
964	28	50	0.98	83	MBM	6	TSH	+18.65	TECTEH			L2157	reso	21H00054	H 0	600UL	331933
965	32	50	6.14	173	DNT	P 1	VM	+2.09	TECTEH			A6997	seco	21H00054	H 0	600UL	331933
966	40	50	4.21	186	DNG	P 1	TSC	+8.84	TECTEH			A6997	seco	21H00054	H 0	600UL	331933
967	68	50	0.72	68	MBM	5	06C	+21.40	TECTEH			L2157	reso	21H00054	H 0	600UL	331933
968	70	50			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
969			0.58	119	NQI	P 1	TSH	+0.64	TECTEH			A9608	reso	21H00053	H 0	600UL	332253
			0.22	85	PID	4	TSH	+0.81	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
			0.23	102	MAI	1	TSH	+0.81	TSHTSH	0.4		N5432	reso	21H00142	H 1	600PP	345337
972			0.26	93	MAI	2	TSH	+0.81	TSHTSH	0.6		N5432	reso	21H00142	H 1	600PP	345337
973	76	50			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
974			0.00	0	MAI	1	TSH	+0.64	TSHTSH	0.0		F3453	reso	21H00143	H 1	600PP	345281
975			0.16	96	PID	4	TSH	+0.64	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337

976			0.12	73	MAI	2	TSH	+0.64	TSHTSH	0.8		F3453	reso	21H00143	H 1	600PP	345281
977	82	50			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
978			0.43	67	MAI	1	TSH	+0.70	TSHTSH	0.7		N5432	reso	21H00142	H 1	600PP	345337
[illegible]			0.36	89	MAI	2	TSH	+0.70	TSHTSH	0.8		N5432	reso	21H00142	H 1	600PP	345337
			0.44	91	PID	4	TSH	+0.70	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 21

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
981	84	50			TBP				TSHTSH	RMVTBS	ADDTBP	D3858	reso	21H00115	H 1	600PP	326403
982			0.47	113	NQI	P 1	TSH	+0.61	TECTEH			A6997	seco	21H00054	H 0	600UL	331933
983			0.21	80	MAI	1	TSH	+0.66	TSHTSH	0.4		F3453	reso	21H00143	H 1	600PP	345281
984			0.13	118	MAI	2	TSH	+0.66	TSHTSH	0.4		F3453	reso	21H00143	H 1	600PP	345281
985			0.22	117	PID	4	TSH	+0.66	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
986	90	50	2.05	185	INR	P 1	02H	+4.81	TECTEH			A9608	reso	21H00053	H 0	600UL	332253
987	94	50	2.04	179	DNG	P 1	01C	+23.62	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
988	108	50	1.45	88	MBM	5	03C	+13.88	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
989	5	51			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
990			0.00	0	SAI	1	TSH	+0.40	TSHTSH	0.0		F3453	reso	21H00147	H 1	600PP	345281
			0.12	120	PID	4	TSH	+0.40	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
			0.12	121	SAI	2	TSH	+0.40	TSHTSH	0.5		F3453	reso	21H00147	H 1	600PP	345281
993	17	51			INF		DC	-2.03	TECTEH	HR		A9608	reso	21H00053	H 0	600UL	332253
994			5.49	175	DNT	P 1	DC	+1.82	TECTEH			A9608	reso	21H00053	H 0	600UL	332253
995	23	51			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
996			0.00	0	SAI	2	TSH	+0.57	TSHTSH	0.0		F3453	reso	21H00147	H 1	600PP	345281
997			0.18	114	SAI	2	TSH	+0.57	TSHTSH	0.4		F3453	reso	21H00147	H 1	600PP	345281
998			0.18	114	PID	4	TSH	+0.57	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
999	25	51	0.84	103	MBM	5	02C	+10.34	TECTEH			C5542	reso	21H00053	H 0	600UL	332253
1000	37	51	1.18	63	MBM	5	04H	+2.00	TECTEH			C5542	reso	21H00053	H 0	600UL	332253
1001	65	51	2.63	185	DNT	P 1	02C	-0.64	TECTEH			A6997	seco	21H00054	H 0	600UL	331933
1002	79	51	1.55	72	MBM	5	02H	+25.24	TECTEH			C5542	reso	21H00053	H 0	600UL	332253
1003	83	51			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1004			0.13	113	SAI	2	TSH	+0.21	TSHTSH	0.2		F3453	reso	21H00143	H 1	600PP	345281
1005			0.17	110	PID	4	TSH	+0.21	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
1006			0.00	0	SAI	1	TSH	+0.21	TSHTSH	0.0		F3453	reso	21H00143	H 1	600PP	345281
1007			3.10	181	DNG	P 1	08C	+14.83	TECTEH			A9608	reso	21H00053	H 0	600UL	332253
1008	87	51	0.47	56	MBM	5	08H	+4.94	TECTEH			C5542	reso	21H00053	H 0	600UL	332253
1009	93	51	19.30	181	DNT	P 1	09H	-0.06	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
1010	97	51	3.74	182	DNT	P 1	09H	-0.02	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
1011	99	51	1.32	60	MBM	6	05C	+14.77	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
1012	111	51	7.68	182	DNG	P 1	09C	+17.17	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
1013	119	51	1.01	58	MBM	6	02H	+36.53	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
1014			7.60	181	DNG	P 1	10C	+2.02	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
1015	121	51	5.49	183	DNG	P 1	10C	+3.88	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
[illegible]	127	51	0.25	74	PLP	9	TSH	+0.26	TSHTSH			L2157	reso	21H00134	H 1	600PP	345337
			0.69	88	MBM	5	02C	+34.93	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
1018	129	51	0.98	80	MBM	5	VH	+25.63	TECTEH			C5542	reso	21H00042	H 0	600UL	331933
1019			1.39	85	MBM	6	03C	+13.85	TECTEH			C5542	reso	21H00042	H 0	600UL	331933
1020	2	52	1.03	62	MBM	6	05H	+2.51	06HTEH			C5542	reso	21H00080	H 9	600UL	331933
1021	10	52			TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403

1022			0.50	53	ADR	6	VM	-0.48	TO+0.26	TECTEH				A9608	reso	21H00054	H 0	600UL	331933
1023			0.27	63	SAI	1	VM	+0.00		05H06C	0.4			L2157	reso	21H00207	H 2	5602C	340933
1024			0.17	128	PID	2	VM	+0.00		06H06C				P2952	prim	21H00213	H999	5602C	340933
			0.17	112	SAI	2	VM	+0.00		05H06C	0.3			L2157	reso	21H00207	H 2	5602C	340933
			0.60	68	MBM	5	04C	+27.14		TECTEH				L2157	reso	21H00054	H 0	600UL	331933
1027	16	52			TBS					TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
1028			0.00	0	SAI	1	TSH	+1.05		TSHTSH	0.0			F3453	reso	21H00146	H 1	600PP	345337
1029			0.12	108	SAI	2	TSH	+1.05		TSHTSH	0.2			F3453	reso	21H00146	H 1	600PP	345337

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 22

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1030			0.00	0	SAI	1	TSH	+1.57	TSHTSH	0.0		F3453	reso	21H00146	H 1	600PP	345337
1031			0.18	93	SAI	2	TSH	+1.57	TSHTSH	0.2		F3453	reso	21H00146	H 1	600PP	345337
1032			0.17	39	PID	4	TSH	+1.57	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
1033	24	52	3.13	181	DNG	P 1	06C	+15.33	TECTEH			A6997	seco	21H00054	H 0	600UL	331933
1034	46	52			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1035			0.45	24	PID	P 1	TSH	-3.56	TSHTSH	080		F3453	reso	21H00175	H999	600PP	345339
1036			0.11	11	SCI	1	TSH	-3.56	TSHTSH	0.3	PWSCC	A9608	reso	21H00160	H 1	600PP	345281
			0.25	24	SCI	P 1	TSH	-3.56	TSHTSH	0.2	PWSCC	A9608	reso	21H00160	H 1	600PP	345281
	48	52	1.02	77	MBM	5	02H	+3.28	TECTEH			L2157	reso	21H00054	H 0	600UL	331933
1039			4.73	187	DNT	P 1	04C	-0.56	TECTEH			A6997	seco	21H00054	H 0	600UL	331933
1040	84	52			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1041			0.20	57	MAI	1	TSH	+0.75	TSHTSH	0.3		F3453	reso	21H00143	H 1	600PP	345281
1042			0.19	99	PID	4	TSH	+0.75	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
1043			0.23	113	MAI	2	TSH	+0.75	TSHTSH	0.4		F3453	reso	21H00143	H 1	600PP	345281
1044	86	52	2.48	175	DNG	P 1	08H	+17.36	TECTEH			A9608	reso	21H00053	H 0	600UL	332253
1045	94	52			NDF		09H	-0.22	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1046			10.20	180	DNT	P 1	09H	-0.22	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
1047	96	52	50.13	182	DNT	P 1	09H	-0.02	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
1048					NDF		09H	-0.02	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1049	104	52	0.54	76	MBM	5	03H	+12.05	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
1050	110	52	2.03	171	DNT	P 1	09H	-0.35	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
1051	118	52	3.28	179	DNT	P 1	09H	-0.28	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
1052	120	52	8.90	181	DNG	P 1	VC	+18.48	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
1053	122	52	3.69	181	DNT	P 1	09C	+0.49	TECTEH			A9574	seco	21H00042	H 0	600UL	331933
1054	124	52	2.16	189	DNG	P 1	10C	+6.58	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
1055	11	53			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1056			0.10	73	PID	4	TSH	+1.10	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
1057			0.00	0	SAI	1	TSH	+1.10	TSHTSH	0.0		F3453	reso	21H00147	H 1	600PP	345281
1058			0.11	80	SAI	2	TSH	+1.10	TSHTSH	0.2		F3453	reso	21H00147	H 1	600PP	345281
1059			0.00	0	SAI	1	TSH	+1.32	TSHTSH	0.0		F3453	reso	21H00147	H 1	600PP	345281
1060			0.08	72	SAI	2	TSH	+1.32	TSHTSH	0.2		F3453	reso	21H00147	H 1	600PP	345281
1061			0.54	69	MBM	5	02H	+2.78	TECTEH			C5542	reso	21H00053	H 0	600UL	332253
	17	53	5.35	181	DNT	P 1	DC	+2.01	TECTEH			F6623	reso	21H00057	H 0	600UL	340882
	29	53			INF		DH	+9.95	TECTEH	HR		S4373	reso	21H00057	H 0	600UL	340882
1064			2.13	181	DNT	P 1	VM	-2.04	TECTEH			S4373	reso	21H00057	H 0	600UL	340882
1065	37	53	0.78	77	MBM	5	04H	+31.34	TECTEH			F6623	reso	21H00057	H 0	600UL	340882
1066	63	53	0.68	98	MBM	5	TSH	+13.66	TECTEH			F6623	reso	21H00058	H 0	600UL	331933
1067	77	53	0.72	70	MBM	5	02C	+35.49	TECTEH			F6623	reso	21H00057	H 0	600UL	340882

1068	83	53			TBS					TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
1069			0.21	106	PID	4	TSH	+0.81		TSHTSH	080			M1680	reso	21H00174	H999	600PP	345337
1070			0.21	128	SAI	1	TSH	+0.81		TSHTSH	0.3			F3453	reso	21H00143	H 1	600PP	345281
			0.20	93	SAI	2	TSH	+0.81		TSHTSH	0.3			F3453	reso	21H00143	H 1	600PP	345281
			4.49	182	DNG	P 1	08C	+15.38		TECTEH				A6997	seco	21H00058	H 0	600UL	331933
1073	87	53	0.97	91	MBM	5	04H	+16.59		TECTEH				F6623	reso	21H00057	H 0	600UL	340882
1074	91	53	2.34	177	DNG	P 1	TSH	+33.12		TECTEH				N2574	seco	21H00041	H 0	600UL	332253
1075	95	53	31.18	183	DNT	P 1	09H	+0.00		TECTEH				N2574	seco	21H00041	H 0	600UL	332253
1076	109	53	3.19	177	DNG	P 1	VC	+11.71		TECTEH				A9574	seco	21H00042	H 0	600UL	331933
1077	111	53	0.77	62	MBM	5	01H	+9.44		TECTEH				C5542	reso	21H00041	H 0	600UL	332253
1078	115	53	5.64	180	DNG	P 1	09C	+20.65		TECTEH				N2574	seco	21H00041	H 0	600UL	332253

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 23

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1079	119	53	7.05	180	DNG	P 1	10C	+2.09	TECTEH			N2574	seco	21H00041	H 0	600UL	332253
1080	10	54	5.56	176	DNG	P 1	04C	+28.49	TECTEH			A6997	seco	21H00058	H 0	600UL	331933
1081			5.76	175	DNG	P 1	04C	+29.05	TECTEH			A6997	seco	21H00058	H 0	600UL	331933
1082	14	54			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
			0.00	0	SAI	1	TSH	+0.12	TSHTSH	0.0		F3453	reso	21H00147	H 1	600PP	345281
			0.14	104	PID	4	TSH	+0.12	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
1085			0.11	113	SAI	2	TSH	+0.12	TSHTSH	0.2		F3453	reso	21H00147	H 1	600PP	345281
1086	20	54	7.81	179	DNG	P 1	06H	+12.59	TECTEH			A6997	seco	21H00058	H 0	600UL	331933
1087	26	54			NDF		TSH	+6.07	TSHTSH	ENCODE		D3858	reso	21H00169	H 3	600PP	345337
1088			0.26	63	NQI	P 1	TSH	+6.07	TECTEH			N9952	prim	21H00057	H 0	600UL	340882
1089	28	54	0.50	88	MBM	5	01C	+23.34	TECTEH			F6623	reso	21H00058	H 0	600UL	331933
1090	52	54			NDF		DH	+17.67	VM DH			L2157	reso	21C00087	H 5	5602C	326280
1091			0.62	111	NQI	P 1	DH	+17.67	TECTEH			F6623	reso	21H00058	H 0	600UL	331933
1092	68	54	2.30	184	DNG	P 1	04C	+26.72	TECTEH			A6997	seco	21H00058	H 0	600UL	331933
1093	76	54			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1094			0.29	113	PID	4	TSH	+0.90	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
1095			0.32	101	MAI	1	TSH	+0.90	TSHTSH	1.0		N5432	reso	21H00142	H 1	600PP	345337
1096			0.26	114	MAI	2	TSH	+0.90	TSHTSH	1.1		N5432	reso	21H00142	H 1	600PP	345337
1097	82	54			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1098			0.12	82	MAI	2	TSH	+0.94	TSHTSH	0.4		N5432	reso	21H00142	H 1	600PP	345337
1099			0.15	93	PID	4	TSH	+0.94	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
1100			0.11	36	MAI	1	TSH	+0.94	TSHTSH	0.3		N5432	reso	21H00142	H 1	600PP	345337
1101	92	54	0.99	82	MBM	6	03C	+20.48	TECTEH			M7006	reso	21H00037	H 0	600UL	332253
1102	96	54	3.34	186	DNG	P 1	04C	+13.56	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1103	100	54	0.42	161	14	P 2	VM	+1.90	TECTEH			P5436	prim	21H00041	H 0	600UL	332253
1104	104	54	1.90	184	INR	P 1	01H	+30.10	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
1105	116	54	1.82	185	INR	P 1	02C	+19.02	TECTEH			C5542	reso	21H00041	H 0	600UL	332253
1106	124	54	0.43	67	MBM	5	VC	+13.72	TECTEH			C5542	reso	21H00042	H 0	600UL	331933
1107	11	55			TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
			0.12	74	SAI	2	VM	+0.00	05H06C	0.2		L2157	reso	21H00207	H 2	5602C	340933
			0.11	98	PID	2	VM	+0.00	06H05C			M1680	reso	21H00213	H999	5602C	340933
1110			0.28	106	SAI	1	VM	+0.00	05H06C	0.3		L2157	reso	21H00207	H 2	5602C	340933
1111			1.25	154	NQI	P 1	VM	+0.11	TECTEH			S4373	reso	21H00057	H 0	600UL	340882
1112	45	55	0.39	159	INR	P 1	TSH	+0.87	TECTEH			O879S	seco	21H00074	H 0	600UL	331933
1113			2.48	179	DNG	P 1	02C	+25.78	TECTEH			C5542	reso	21H00074	H 0	600UL	331933

1114	61	55	0.60	74	MBM	5	01H	+14.03		TECTEH				M7006	reso	21H00068	H 0	600UL	331933
1115	71	55	3.16	182	DNG	P 1	07H	+5.85		TECTEH				M2655	seco	21H00067	H 0	600UL	340882
1116	73	55	2.92	178	DNG	P 1	07H	+24.08		TECTEH				F1726	seco	21H00068	H 0	600UL	331933
	75	55	4.70	189	DNG	P 1	06H	+12.95		TECTEH				M2655	seco	21H00067	H 0	600UL	340882
	77	55	0.58	92	MBM	6	05H	+8.35		TECTEH				M7006	reso	21H00067	H 0	600UL	340882
1119	79	55	0.56	62	MBM	6	02C	+15.48		TECTEH				M7006	reso	21H00067	H 0	600UL	340882
1120	83	55			TBS					TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
1121					DIS	3	SBH	+23.74		SBHSTH				G9427	prim	21H00223	H10	500PP	326656
1122			0.84	197	PID	3	SBH	+23.74		SBHSTH				D3858	prim	21H00226	H999	500PP	326656
1123			0.00	0	MAI	1	TSH	+0.75		TSHTSH	0.0			F3453	reso	21H00143	H 1	600PP	345281
1124			0.16	133	PID	4	TSH	+0.75		TSHTSH	080			M1680	reso	21H00174	H999	600PP	345337
1125			0.17	125	MAI	2	TSH	+0.75		TSHTSH	0.4			F3453	reso	21H00143	H 1	600PP	345281
1126	85	55			TBS					TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
1127			0.00	0	SAI	1	TSH	+0.75		TSHTSH	0.0			N5432	reso	21H00142	H 1	600PP	345337

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 24

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1128			0.13	83	SAI	2	TSH	+0.75	TSHTSH	0.3		N5432	reso	21H00142	H 1	600PP	345337
			0.14	85	PID	4	TSH	+0.75	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
[illegible]	91	55	2.53	183	DNT	P 1	09C	-0.50	TECTEH			S4373	reso	21H00037	H 0	600UL	332253
1131	99	55	1.59	87	MBM	5	08C	+20.89	TECTEH			L2157	reso	21H00038	H 0	600UL	331933
1132	105	55	10.16	177	DNG	P 1	09C	+16.64	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1133	109	55	1.11	87	MBM	6	03H	+36.72	TECTEH			M7006	reso	21H00037	H 0	600UL	332253
1134			3.07	180	DNG	P 1	VC	+12.87	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1135	117	55	3.70	182	DNT	P 1	09H	-0.17	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1136			2.64	178	DNT	P 1	10H	-0.18	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1137	119	55			NDF		10H	-0.07	10H10H			W4892	prim	21H00169	H 3	600PP	345337
1138			0.53	83	DSI	P 1	10H	-0.07	TECTEH			D9573	prim	21H00038	H 0	600UL	331933
1139			7.22	184	DNG	P 1	10C	+2.01	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1140	121	55	5.94	183	DNG	P 1	10C	+3.58	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1141	6	56			TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1142			2.22	13	SCI	1	TSH	-4.33	TSHTSH	0.4		F3453	reso	21H00146	H 1	600PP	345337
1143			1.42	30	PID	P 1	TSH	-4.33	TSHTSH	080		F3453	reso	21H00175	H999	600PP	345339
1144			1.75	32	SCI	P 1	TSH	-4.33	TSHTSH	0.3	PWSCC	F3453	reso	21H00146	H 1	600PP	345337
1145			0.44	39	SAI	1	05H	+0.55	05H06C	0.4		L2157	reso	21H00207	H 2	5602C	340933
1146			0.29	115	PID	2	05H	+0.55	05H06H			P2952	prim	21H00213	H999	5602C	340933
1147			0.31	90	SAI	2	05H	+0.55	05H06C	0.4		L2157	reso	21H00207	H 2	5602C	340933
1148					OBS		06H	+13.83	06HTEH			M2655	seco	21H00073	H 0	600UL	340882
1149	18	56			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1150			1.98	29	MCI	P 1	TSH	-4.25	TSHTSH	0.5	PWSCC	F3453	reso	21H00146	H 1	600PP	345337
1151			1.58	34	PID	P 1	TSH	-4.25	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
1152			3.85	19	MCI	1	TSH	-4.25	TSHTSH	0.6		F3453	reso	21H00146	H 1	600PP	345337
1153			0.00	0	MAI	1	TSH	+0.49	TSHTSH	0.0		F3453	reso	21H00146	H 1	600PP	345337
			0.15	103	MAI	2	TSH	+0.49	TSHTSH	0.5		F3453	reso	21H00146	H 1	600PP	345337
	48	56	1.08	100	MBM	6	03C	+24.44	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1156			0.79	75	MBM	5	03C	+33.78	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1157	54	56	17.74	178	DNG	P 1	07H	+20.90	TECTEH			C5542	reso	21H00074	H 0	600UL	331933
1158			14.14	179	DNG	P 1	07H	+21.84	TECTEH			C5542	reso	21H00074	H 0	600UL	331933
1159	60	56	1.88	40	MBM	6	02C	+9.70 TO+13.29	TECTEH			M7006	reso	21H00067	H 0	600UL	340882

1160	64	56	3.04	55	NRH	2	TSH	+0.00	TECTEH				M1029	prim	21H00068	H 0	600UL	331933
1161	68	56	2.11	47	MBM	6	03C	+28.90 TO+33.80	TECTEH				M7006	reso	21H00067	H 0	600UL	340882
1162	78	56	3.14	176	DNT	P 1	03H	+0.13	TECTEH				M2655	seco	21H00067	H 0	600UL	340882
	80	56	2.94	183	DNT	P 1	08C	-1.12	TECTEH				M2655	seco	21H00067	H 0	600UL	340882
			5.86	177	DNT	P 1	08C	+0.38	TECTEH				M2655	seco	21H00067	H 0	600UL	340882
1165	88	56	2.66	187	INR	P 1	08H	+18.95	TECTEH				M7006	reso	21H00067	H 0	600UL	340882
1166	100	56	2.59	171	DNG	P 1	01H	+26.97	TECTEH				M2655	seco	21H00037	H 0	600UL	332253
1167	110	56	2.03	184	DNG	P 1	01H	+20.04	TECTEH				N5877	seco	21H00038	H 0	600UL	331933
1168	120	56	3.18	173	DNT	P 1	09H	+0.04	TECTEH				M2655	seco	21H00037	H 0	600UL	332253
1169			9.31	181	DNG	P 1	VC	+19.23	TECTEH				M2655	seco	21H00037	H 0	600UL	332253
1170	124	56	2.50	182	DNG	P 1	10C	+6.70	TECTEH				M2655	seco	21H00037	H 0	600UL	332253
1171	126	56	3.25	177	DNT	P 1	09H	+0.38	TECTEH				N5877	seco	21H00038	H 0	600UL	331933
1172	128	56	4.91	182	DNG	P 1	10C	+9.10	TECTEH				M2655	seco	21H00037	H 0	600UL	332253
1173			4.21	183	DNG	P 1	10C	+9.75	TECTEH				M2655	seco	21H00037	H 0	600UL	332253
1174	132	56	1.16	80	MBM	6	03H	+7.47	TECTEH				M7006	reso	21H00068	H 0	600UL	331933
1175			3.74	178	DNG	P 1	VM	+4.81	TECTEH				F1726	seco	21H00068	H 0	600UL	331933
1176			1.72	65	MBM	6	08C	+18.34	TECTEH				M7006	reso	21H00068	H 0	600UL	331933

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1177			0.71	83	MBM	6	07C	+20.20	TECTEH			M7006	reso	21H00068	H 0	600UL	331933
1178	9	57	22.14	180	DNG	P 1	04C	+11.26	TECTEH			M2655	seco	21H00073	H 0	600UL	340882
1179	17	57	6.80	175	DNT	P 1	DC	+1.57	TECTEH			O8795	seco	21H00074	H 0	600UL	331933
1180	21	57	0.64	84	MBM	5	01H	+22.17	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1181	49	57			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1182			3.58	39	PID	P 1	TSH	-4.47	TSHTSH	080		F3453	reso	21H00175	H999	600PP	345339
1183			2.24	38	SCI	1	TSH	-4.47	TSHTSH	0.8	PWSCC	L2157	reso	21H00155	H 1	600PP	345337
1184			2.77	38	SCI	P 1	TSH	-4.47	TSHTSH	0.9	PWSCC	L2157	reso	21H00155	H 1	600PP	345337
1185			1.98	186	INR	P 1	VM	-1.50	TECTEH			M2655	seco	21H00073	H 0	600UL	340882
1186	51	57	2.34	182	DNG	P 1	TSH	+16.17	TECTEH			M2655	seco	21H00073	H 0	600UL	340882
1187			2.39	180	DNG	P 1	03H	+23.67	TECTEH			M2655	seco	21H00073	H 0	600UL	340882
1188	57	57	0.56	73	MBM	5	01H	+35.45	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1189	73	57			INF		05C	-1.64	TECTEH	HR		M7006	reso	21H00067	H 0	600UL	340882
1190			2.77	181	DNG	P 1	04C	+36.50	TECTEH			M2655	seco	21H00067	H 0	600UL	340882
1191	77	57			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1192			0.49	226	PID	3	SBH	+23.93	SBHSTH			D3858	prim	21H00226	H999	500PP	326656
1193					DIS	3	SBH	+23.93	SBHSTH			G9427	prim	21H00223	H10	500PP	326656
1194			0.16	102	SAI	1	TSH	+0.57	TSHTSH	0.4		N5432	reso	21H00142	H 1	600PP	345337
1195			0.19	101	SAI	2	TSH	+0.57	TSHTSH	0.5		N5432	reso	21H00142	H 1	600PP	345337
1196			0.20	103	PID	4	TSH	+0.57	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
1197	87	57	2.76	185	DNG	P 1	08C	+19.07	TECTEH			M2655	seco	21H00067	H 0	600UL	340882
1198	93	57	3.64	184	DNG	P 1	08H	+6.24	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1199			5.08	3	INR	P 1	08H	+6.68	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
			14.69	181	DNG	P 1	08H	+7.19	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
			7.90	182	DNG	P 1	08H	+7.66	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1202					INF	P 1	08H	+8.03	TECTEH	HR		M7006	reso	21H00037	H 0	600UL	332253
1203			45.39	181	DNG	P 1	08H	+8.60	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1204			2.51	178	DNT	P 1	09H	+0.70	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1205			4.50	178	DNT	P 1	09C	-0.63	TECTEH			M2655	seco	21H00037	H 0	600UL	332253

1206			7.32	179	DNT	P 1	09C	+0.02	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1207			14.00	181	DNG	P 1	09C	+1.04	TECTEH			S4373	reso	21H00037	H 0	600UL	332253
1208			8.57	176	DNG	P 1	09C	+21.42	TECTEH			M7006	reso	21H00037	H 0	600UL	332253
[illegible]			5.27	180	DNG	P 1	08C	+1.27	TECTEH			S4373	reso	21H00037	H 0	600UL	332253
			1.83	183	INR	P 1	08C	+1.89	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1211			4.52	182	DNG	P 1	08C	+2.29	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1212			2.63	178	DNG	P 1	08C	+19.39	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1213			2.63	178	DNG	P 1	08C	+20.53	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1214			8.82	179	DNG	P 1	08C	+21.00	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1215	97	57	0.48	75	MBM	5	08H	+7.40	TECTEH			M7006	reso	21H00037	H 0	600UL	332253
1216	111	57	2.54	188	DNT	P 1	08H	+1.20	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1217	119	57	2.63	175	DNT	P 1	09H	+0.00	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1218			6.14	180	DNG	P 1	10C	+2.09	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1219			0.42	91	MBM	5	09C	+9.06	TECTEH			M7006	reso	21H00037	H 0	600UL	332253
1220	121	57	11.22	186	DNG	P 1	10C	+3.83	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1221	127	57	7.09	182	DNT	P 1	09H	+0.36	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1222			1.97	184	INR	P 1	VM	+3.11	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1223	129	57	2.24	171	DNT	P 1	VM	+2.25	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1224	133	57	3.41	182	INR	P 1	VM	-2.23	TECTEH			F1726	seco	21H00068	H 0	600UL	331933
1225			10.14	183	DNG	P 1	10C	+14.06	TECTEH			F1726	seco	21H00068	H 0	600UL	331933

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 26

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1226	14	58	0.54	73	MBM	5	TSH	+22.27	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1227			0.56	82	MBM	5	TSH	+35.56	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1228			0.73	74	MBM	5	01H	+30.03	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1229			0.39	69	MBM	5	01H	+31.16	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1230			0.30	116	INR	P 1	02H	+0.52	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1231			0.67	63	MBM	6	03H	+15.77	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1232			0.50	90	MBM	5	03H	+15.79	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1233			0.74	73	MBM	5	05C	+29.62	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1234			1.03	84	MBM	5	04C	+31.61	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1235			0.62	76	MBM	5	04C	+32.48	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1236			0.42	68	MBM	5	01C	+20.93	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1237			0.42	80	MBM	5	01C	+24.26	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1238			1.00	77	MBM	5	TSC	+17.93	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1239			0.41	73	MBM	5	TSC	+26.10	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1240	16	58	0.26	87	MBM	5	TSH	+27.18	TECTEH			C5542	reso	21H00074	H 0	600UL	331933
1241	20	58	7.44	180	DNG	P 1	06H	+13.01	TECTEH			O8795	seco	21H00074	H 0	600UL	331933
1242	38	58	7.67	182	DNT	P 1	VM	+1.91	TECTEH			M2655	seco	21H00073	H 0	600UL	340882
1243	54	58	0.59	106	MBM	6	01H	+5.13	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1244			0.43	90	MBM	5	01H	+22.90	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1245			1.53	87	MBM	5	04C	+28.54	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
[illegible]	72	58			OBS		TEH	+0.00	TEHTEH			P2952	prim	21H00174	H 1	600PP	345337
					OBS		TEH	+0.00	TEHTEH			L2157	reso	21H00155	H 1	600PP	345337
1248					OBS		TEH	+0.00	TEHTEH			G2927	prim	21H00067	H 0	600UL	340882
1249					OBS		TEH	+0.00	TEHTEH			W4892	prim	21H00142	H 1	600PP	345337
1250					OBS		TEH	+0.00	TEHTEH			C5542	reso	21H00084	H 0	600UL	331963
1251					OBS		TSH	-20.88	TSHTEC			N2574	seco	21C00057	H 0	600CS	341612

1252						INF		07H	+11.92	TSHTEC	HR			N5432	reso	21C00057	H 0	600CS	341612
1253						INF		07H	+11.92	TEHTEC	HR			S4373	reso	21C00063	H 0	580UL	287747
1254				3.96	185	DNG	P 1	08C	+5.24	TSHTEC				S4373	reso	21C00057	H 0	600CS	341612
[illegible]				4.21	181	DNG	P 1	08C	+5.36	TEHTEC				D4576	seco	21C00063	H 0	580UL	287747
				2.79	191	DNG	P 1	07C	+15.09	TEHTEC				D4576	seco	21C00063	H 0	580UL	287747
1257				2.71	189	DNG	P 1	07C	+15.24	TSHTEC				S4373	reso	21C00057	H 0	600CS	341612
1258	74	58		0.41	79	MBM	5	03H	+3.77	TECTEH				M7006	reso	21H00067	H 0	600UL	340882
1259				0.37	92	MBM	5	07H	+9.60	TECTEH				M7006	reso	21H00067	H 0	600UL	340882
1260	76	58		21.23	177	DNG	P 1	08H	+2.94	TECTEH				F1726	seco	21H00068	H 0	600UL	331933
1261	86	58		3.70	181	DNG	P 1	08H	+18.58	TECTEH				M2655	seco	21H00067	H 0	600UL	340882
1262	88	58				TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
1263				0.15	101	SAI	2	TSH	+0.49	TSHTSH	0.4			N5432	reso	21H00142	H 1	600PP	345337
1264				0.15	87	PID	4	TSH	+0.49	TSHTSH	080			M1680	reso	21H00174	H999	600PP	345337
1265				0.17	109	SAI	1	TSH	+0.49	TSHTSH	0.3			N5432	reso	21H00142	H 1	600PP	345337
1266	94	58		0.64	70	MBM	5	TSH	+34.85	TECTEH				L2157	reso	21H00038	H 0	600UL	331933
1267	96	58		3.31	179	DNG	P 1	TSC	+13.07	TECTEH				M2655	seco	21H00037	H 0	600UL	332253
1268	106	58		0.65	73	MBM	5	08C	+9.37	TECTEH				L2157	reso	21H00038	H 0	600UL	331933
1269	110	58		0.49	72	MBM	5	01H	+28.81	TECTEH				L2157	reso	21H00038	H 0	600UL	331933
1270				0.92	91	MBM	5	04C	+6.51	TECTEH				L2157	reso	21H00038	H 0	600UL	331933
1271				0.25	70	INR	5	04C	+8.05	TECTEH				D9573	prim	21H00038	H 0	600UL	331933
1272				0.48	64	NQI	5	TSC	+21.28	TECTEH				L2157	reso	21H00038	H 0	600UL	331933
1273				0.16	81	VOL	P 1	TSC	+21.69	TSC01C				M7006	reso	21C00083	C 4	600PP	345344
1274	118	58		3.90	182	DNG	P 1	10C	+1.11	TECTEH				N5877	seco	21H00038	H 0	600UL	331933

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 27

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1275	17	59	5.27	178	DNT	P 1	DC	-2.00	TECTEH			M2655	seco	21H00073	H 0	600UL	340882
1276	19	59	0.35	85	MBM	5	02H	+24.69	TECTEH			C5542	reso	21H00074	H 0	600UL	331933
1277			0.37	76	MBM	5	02H	+30.52	TECTEH			C5542	reso	21H00074	H 0	600UL	331933
1278			0.76	84	MBM	5	03H	+28.84	TECTEH			C5542	reso	21H00074	H 0	600UL	331933
1279	21	59	0.84	40	MBM	6	TSH	+12.63	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1280			0.59	79	MBM	5	01H	+13.53	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1281			0.36	69	MBM	5	04H	+27.06	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1282	27	59	1.97	180	INR	P 1	TSC	+11.10	TECTEH			O8795	seco	21H00074	H 0	600UL	331933
1283	39	59	2.21	93	MBM	6	02H	+12.31 TO+15.49	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1284	59	59			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1285			1.00	21	PID	4	TSH	-4.63	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
1286			0.75	22	SAI	1	TSH	-4.63	TSHTSH	0.7	PWSCC	M1680	reso	21H00143	H 1	600PP	345281
1287			0.71	21	SAI	2	TSH	-4.63	TSHTSH	0.7	PWSCC	M1680	reso	21H00143	H 1	600PP	345281
1288			0.78	23	PRC	2	TSH	-4.63	TSHTSH			L2157	reso	21H00155	H 1	600PP	345337
1289	75	59	3.33	182	DNG	P 1	08C	+8.10	TECTEH			M2655	seco	21H00067	H 0	600UL	340882
1290	79	59	0.98	76	MBM	5	TSH	+19.44	TECTEH			M7006	reso	21H00067	H 0	600UL	340882
1291			0.34	69	MBM	5	01H	+13.97	TECTEH			M7006	reso	21H00067	H 0	600UL	340882
[illegible]			0.68	82	MBM	5	03H	+8.71	TECTEH			M7006	reso	21H00067	H 0	600UL	340882
			0.33	71	MBM	5	05H	+12.93	TECTEH			M7006	reso	21H00067	H 0	600UL	340882
1294	85	59			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1295			0.19	99	SAI	2	TSH	+0.83	TSHTSH	0.4		N5432	reso	21H00142	H 1	600PP	345337
1296			0.21	62	SAI	1	TSH	+0.83	TSHTSH	0.4		N5432	reso	21H00142	H 1	600PP	345337
1297			0.18	97	PID	4	TSH	+0.83	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337

1298	91	59	2.43	184	DNT	P 1	09C	-0.41	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1299	95	59	7.05	187	DNT	P 1	09H	-0.09	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1300			2.31	185	DNG	P 1	08C	+17.09	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
			2.69	186	DNG	P 1	08C	+20.03	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
	97	59	6.35	180	DNG	P 1	06H	+15.11	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1303			3.87	181	DNG	P 1	07H	+17.17	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1304			2.99	179	DNG	P 1	07H	+21.47	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1305			12.04	180	DNG	P 1	07H	+22.37	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1306			3.53	183	DNG	P 1	07H	+23.33	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1307			1.74	183	INR	P 1	07H	+24.23	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1308			2.31	182	DNG	P 1	07H	+24.81	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1309			3.51	182	DNT	P 1	08H	-0.71	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1310			2.93	182	DNT	P 1	08H	+0.17	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1311			7.56	180	DNG	P 1	08H	+2.22	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1312			13.92	181	DNG	P 1	08H	+3.24	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1313			3.08	180	DNG	P 1	08H	+8.62	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1314			2.74	178	DNG	P 1	08H	+10.45	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1315			17.63	180	DNG	P 1	08H	+11.37	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1316			4.57	182	DNG	P 1	08H	+11.96	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1317			7.87	184	DNG	P 1	08H	+12.95	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1318			39.61	180	DNG	P 1	08H	+13.86	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1319			45.89	180	DNG	P 1	08H	+15.06	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1320			10.34	179	DNG	P 1	08H	+15.68	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1321			6.05	182	DNG	P 1	08H	+17.08	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1322			33.21	180	DNG	P 1	08H	+17.96	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1323			33.06	180	DNG	P 1	08H	+18.83	TECTEH			M2655	seco	21H00037	H 0	600UL	332253

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 28

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1324			16.42	180	DNG	P 1	08H	+19.75	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1325					INF	P 1	08H	+20.47	TECTEH	HR		M7006	reso	21H00037	H 0	600UL	332253
1326			2.07	180	DNG	P 1	08H	+21.60	TECTEH	LOCOK		S4373	reso	21H00037	H 0	600UL	332253
1327			4.43	182	DNT	P 1	09H	+0.63	TECTEH			M7006	reso	21H00037	H 0	600UL	332253
1328			7.97	183	DNT	P 1	09C	-0.50	TECTEH			S4373	reso	21H00037	H 0	600UL	332253
1329			26.72	180	DNT	P 1	09C	+0.11	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1330			4.39	175	DNT	P 1	09C	+0.50	TECTEH			S4373	reso	21H00037	H 0	600UL	332253
1331			8.44	180	DNG	P 1	09C	+1.40	TECTEH			S4373	reso	21H00037	H 0	600UL	332253
1332			26.62	180	DNG	P 1	09C	+2.25	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1333			28.43	182	DNG	P 1	09C	+2.63	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1334			6.12	178	DNG	P 1	08C	+17.25	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1335			2.93	175	DNG	P 1	08C	+20.27	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1336			20.18	182	DNG	P 1	08C	+21.17	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1337	99	59	4.94	183	DNG	P 1	09H	+1.14	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
			22.85	183	DNG	P 1	09H	+2.08	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
	103	59	9.44	188	DNT	P 1	09H	+0.00	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1340	107	59	1.98	83	MBM	6	09H	+9.25	TECTEH			L2157	reso	21H00038	H 0	600UL	331933
1341	111	59	2.98	182	DNG	P 1	03C	+36.70	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1342			0.81	85	MBM	5	01C	+15.74	TECTEH			L2157	reso	21H00038	H 0	600UL	331933
1343	113	59	3.23	186	DNG	P 1	TSH	+34.89	TECTEH			M2655	seco	21H00037	H 0	600UL	332253

1344	115	59	3.50	183	DNT	P 1	09H	+0.02	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1345	117	59	3.62	181	DNT	P 1	10C	+0.53	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1346	119	59	4.22	184	DNG	P 1	10C	+2.02	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
-	127	59	3.12	187	DNG	P 1	05C	+34.11	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
			2.63	188	DNG	P 1	05C	+35.05	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1349	131	59	2.56	187	DNG	P 1	10H	+11.93	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1350			3.68	188	INR	P 1	10H	+13.10	TECTEH			L2157	reso	21H00038	H 0	600UL	331933
1351	133	59	0.30	85	PLP	9	TSC	+0.10	TSCTSC			F6623	reso	21C00039	C 2	600PP	345328
1352	10	60	5.03	178	DNG	P 1	VM	+6.60	TECTEH			O8795	seco	21H00074	H 0	600UL	331933
1353	20	60	2.07	178	DNG	P 1	06C	+1.76	TECTEH			M2655	seco	21H00073	H 0	600UL	340882
1354	26	60	0.65	66	MBM	5	TSH	+7.75	TECTEH			C5542	reso	21H00074	H 0	600UL	331933
1355	28	60	5.76	177	DNG	P 1	02H	+17.27	TECTEH			M2655	seco	21H00073	H 0	600UL	340882
1356			0.68	81	MBM	5	03H	+21.94	TECTEH			M7006	reso	21H00073	H 0	600UL	340882
1357	30	60	3.28	179	DNG	P 1	01C	+25.49	TECTEH			O8795	seco	21H00074	H 0	600UL	331933
1358	36	60	4.28	181	DNT	P 1	VM	+1.89	TECTEH			M2655	seco	21H00073	H 0	600UL	340882
1359	72	60	2.50	181	DNT	P 1	VM	+2.00	TECTEH			M2655	seco	21H00067	H 0	600UL	340882
1360	76	60	2.29	180	DNG	P 1	04C	+35.04	TECTEH			M2655	seco	21H00067	H 0	600UL	340882
1361	88	60			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1362			0.27	108	PID	4	TSH	+0.80	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
1363			0.24	109	MAI	2	TSH	+0.80	TSHTSH	0.5		F3453	reso	21H00143	H 1	600PP	345281
1364			0.34	32	MAI	1	TSH	+0.80	TSHTSH	0.4		F3453	reso	21H00143	H 1	600PP	345281
1365			0.64	73	MBM	6	01H	+31.74	TECTEH			M7006	reso	21H00068	H 0	600UL	331933
1366			0.81	67	MBM	6	02H	+17.11	TECTEH			M7006	reso	21H00068	H 0	600UL	331933
1367			1.05	74	MBM	6	02C	+34.93	TECTEH			M7006	reso	21H00068	H 0	600UL	331933
1368	92	60	40.24	182	DNT	P 1	09H	-0.04	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1369	96	60	7.83	181	DNT	P 1	09H	+0.00	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1370	98	60			PBC				TEHTEC			D3858	reso	21C00063	H 0	580UL	287747
1371					OBS		08H	+9.30	08HTEH			C3340	reso	21H00093	H 0	600UL	331963
1372			0.49	189	INR	P 1	08H	+9.48	TEHTEC			D4576	seco	21C00063	H 0	580UL	287747

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 29

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1373					OBS		09H	+0.00	09H09H			D9424	prim	21H00178	H 6	600PP	345339
1374			148.5	177	DNT	P 1	09H	+0.12	TEHTEC			D4576	seco	21C00063	H 0	580UL	287747
1375					OBS		09H	+0.12	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1376					NDF		09H	+0.12	09H09H			K2032	seco	21H00182	H 6	5602C	326184
1377					OBS		DH	-11.49	DH TEC			N2574	seco	21C00057	H 0	600CS	341612
1378			0.30	57	WAR	2	DH	+0.93	DH DH			L2157	reso	21H00182	H 4	5602C	326184
1379			0.65	159	24	P 2	DH	+1.30	DH TEC	LOCOK		D3858	reso	21C00057	H 0	600CS	341612
1380			2.19	181	DNG	P 1	01C	+11.75	DH TEC			S4373	reso	21C00057	H 0	600CS	341612
1381			2.03	182	DNG	P 1	01C	+11.78	TEHTEC			D4576	seco	21C00063	H 0	580UL	287747
1382	100	60	31.00	180	DNT	P 1	09H	-0.17	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1383	104	60	0.60	81	MBM	5	05H	+6.37	TECTEH			M7006	reso	21H00037	H 0	600UL	332253
			1.77	83	MBM	6	05H	+31.65	TECTEH			M7006	reso	21H00037	H 0	600UL	332253
			12.28	182	DNT	P 1	09H	-0.06	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1386			1.74	180	INR	P 1	01C	+10.35	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1387	112	60	2.52	185	DNT	P 1	08H	-1.06	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1388			2.44	179	DNT	P 1	VH	+0.78	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1389	120	60	8.78	177	DNG	P 1	VC	+18.60	TECTEH			M2655	seco	21H00037	H 0	600UL	332253

1390			3.27	184	DNG	P	1	10C	+3.23	TECTEH			M2655	seco	21H00037	H	0	600UL	332253
1391	124	60	3.88	178	DNG	P	1	10C	+6.92	TECTEH			M2655	seco	21H00037	H	0	600UL	332253
1392			3.27	173	DNG	P	1	09C	+19.81	TECTEH			M2655	seco	21H00037	H	0	600UL	332253
			3.25	173	DNG	P	1	09C	+21.07	TECTEH			M2655	seco	21H00037	H	0	600UL	332253
	126	60	8.36	179	DNT	P	1	09H	+0.33	TECTEH			N5877	seco	21H00038	H	0	600UL	331933
1395	128	60	2.77	180	DNG	P	1	10C	+10.60	TECTEH			M2655	seco	21H00037	H	0	600UL	332253
1396			0.25	74	PLP		9	TSC	+0.19	TSCTSC			D9573	prim	21C00051	C	2	600PP	345293
1397	132	60	0.26	86	PLP		9	TSC	+0.18	TSCTSC			F6623	reso	21C00038	C	2	600PP	345284
1398	11	61	10.00	180	INR	P	1	06C	+8.57	TECTEH			O8795	seco	21H00074	H	0	600UL	331933
1399			0.93	71	MBM		6	01C	+5.90	TECTEH			C5542	reso	21H00074	H	0	600UL	331933
1400			0.71	76	MBM		5	01C	+24.36	TECTEH			C5542	reso	21H00074	H	0	600UL	331933
1401	19	61	1.34	82	MBM		6	02C	+5.79	TECTEH			M7006	reso	21H00073	H	0	600UL	340882
1402	47	61	2.20	180	DNG	P	1	04C	+14.24	TECTEH			O8795	seco	21H00075	H	0	600UL	340882
1403	75	61	3.42	177	DNG	P	1	08C	+8.08	TECTEH			O8795	seco	21H00064	H	0	600UL	331933
1404	85	61			TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
1405			0.56	224	PID		3	SBH	+23.82	SBHSTH			D3858	prim	21H00226	H999		500PP	326656
1406					DIS		3	SBH	+23.82	SBHSTH			G9427	prim	21H00223	H10		500PP	326656
1407			0.00	0	SAI		1	TSH	+0.98	TSHTSH	0.0		N5432	reso	21H00142	H	1	600PP	345337
1408			0.13	102	PID		4	TSH	+0.98	TSHTSH	080		M1680	reso	21H00174	H999		600PP	345337
1409			0.16	103	SAI		2	TSH	+0.98	TSHTSH	0.5		N5432	reso	21H00142	H	1	600PP	345337
1410	91	61			OBS			09H	+0.00	09H09H			F6623	reso	21H00178	H	6	600PP	345339
1411					NDF			09H	+0.02	09H09H			K5380	prim	21H00182	H	6	5602C	326184
1412			59.49	181	DNT	P	1	09H	+0.02	TECTEH			M2655	seco	21H00037	H	0	600UL	332253
1413	93	61	16.12	181	DNT	P	1	09H	+0.09	TECTEH			M2655	seco	21H00037	H	0	600UL	332253
1414					NDF			09H	+0.09	09H09H			W4892	prim	21H00169	H	6	600PP	345337
1415	95	61	2.02	183	DNG	P	1	01H	+14.99	TECTEH			N5877	seco	21H00038	H	0	600UL	331933
1416	97	61	3.64	182	DNG	P	1	07H	+20.84	TECTEH			M2655	seco	21H00037	H	0	600UL	332253
1417			7.85	181	DNT	P	1	08H	-1.15	TECTEH			M2655	seco	21H00037	H	0	600UL	332253
[illegible]			3.89	179	DNT	P	1	08H	+0.30	TECTEH			M2655	seco	21H00037	H	0	600UL	332253
			3.89	179	DNT	P	1	08H	+0.66	TECTEH			M2655	seco	21H00037	H	0	600UL	332253
[illegible]			3.71	181	DNG	P	1	08H	+7.11	TECTEH			M2655	seco	21H00037	H	0	600UL	332253
1421			2.49	183	DNT	P	1	09H	+0.46	TECTEH			M2655	seco	21H00037	H	0	600UL	332253

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 30

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1422	109	61	3.21	178	DNG	P	1	VC	+12.48	TECTEH			M2655	seco	21H00037	H 0 600UL 332253
1423	111	61	5.08	184	DNT	P	1	09H	-0.15	TECTEH			N5877	seco	21H00038	H 0 600UL 331933
1424			0.41	93	MBM		5	03C	+4.42	TECTEH			L2157	reso	21H00038	H 0 600UL 331933
1425	113	61	28.23	181	DNT	P	1	09H	+0.00	TECTEH			M2655	seco	21H00037	H 0 600UL 332253
1426	117	61	2.57	177	DNT	P	1	10H	-0.27	TECTEH			M2655	seco	21H00037	H 0 600UL 332253
1427			4.19	172	DNT	P	1	VH	+0.84	TECTEH			M2655	seco	21H00037	H 0 600UL 332253
1428			3.88	181	DNT	P	1	10C	+0.53	TECTEH			M2655	seco	21H00037	H 0 600UL 332253
1429	119	61	1.28	5	INR	P	1	10C	+1.51	TECTEH			N5877	seco	21H00038	H 0 600UL 331933
	121	61	2.46	78	MBM		6	DH	+18.61	TECTEH			M7006	reso	21H00037	H 0 600UL 332253
	129	61	0.69	74	MBM		5	07H	+10.20	TECTEH			M7006	reso	21H00037	H 0 600UL 332253
1432	20	62	10.98	180	DNG	P	1	06H	+12.51	TECTEH			M2655	seco	21H00076	H 0 600UL 331933
1433	24	62			TBS					TSHTSH			D3858	reso	21H00115	H 1 600PP 326403
1434			0.16	98	SAI		2	TSH	+2.16	TSHTSH	0.5		L2157	reso	21H00155	H 1 600PP 345337
1435			0.14	98	PID		4	TSH	+2.16	TSHTSH	080		F3453	reso	21H00175	H999 600PP 345339

1436			0.06	155	SAI	1	TSH	+2.16	TSHTSH	0.6		L2157	reso	21H00155	H 1	600PP	345337
1437			4.29	182	DNT	P 1	VM	+1.68	TECTEH			M2655	seco	21H00076	H 0	600UL	331933
1438			3.30	185	DNG	P 1	06C	+10.45	TECTEH			M2655	seco	21H00076	H 0	600UL	331933
	26	62	3.05	184	DNG	P 1	02H	+7.43	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
	34	62	1.18	91	MBM	5	03C	+34.46	TECTEH			M7006	reso	21H00075	H 0	600UL	340882
1441	38	62	3.29	184	DNT	P 1	07C	+1.55	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1442	40	62	0.94	59	MBM	5	03H	+8.52	TECTEH			C5542	reso	21H00076	H 0	600UL	331933
1443	48	62	0.68	83	MBM	5	01H	+6.41	TECTEH			C5542	reso	21H00076	H 0	600UL	331933
1444	70	62	2.84	182	DNG	P 1	07C	+18.26	TECTEH			F1726	seco	21H00063	H 0	600UL	340882
1445			1.88	182	INR	P 1	07C	+19.53	TECTEH			F1726	seco	21H00063	H 0	600UL	340882
1446	80	62	0.32	89	MBM	5	07H	+17.62	TECTEH			M7006	reso	21H00063	H 0	600UL	340882
1447	84	62	0.42	78	MBM	5	05C	+6.52	TECTEH			M7006	reso	21H00064	H 0	600UL	331933
1448	92	62			OBS		08H	+14.82	08HTEH			F7467	seco	21H00079	H 0	600UL	340882
1449					OBS		08H	+16.03	08HTEH			J5670	prim	21H00037	H 0	600UL	332253
1450					NDF		09H	-0.12	09H09H			K5380	prim	21H00182	H 6	5602C	326184
1451					OBS		09H	-0.12	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1452			114.1	180	DNT	P 1	09H	-0.12	TEHTEC			D4576	seco	21C00063	H 0	580UL	287747
1453					OBS		09H	+0.00	09H09H			D9424	prim	21H00178	H 6	600PP	345339
1454					OBS		DH	-8.10	DH TEC			N2574	seco	21C00057	H 0	600CS	341612
1455	94	62	114.2	178	DNT	P 1	09H	+0.18	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1456					NDF		09H	+0.18	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1457			5.81	190	DNG	P 1	04C	+33.24	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1458	96	62	110.2	180	DNT	P 1	09H	+0.02	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1459					NDF		09H	+0.02	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1460			2.70	173	DNG	P 1	VC	+5.57	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1461	100	62	3.63	181	DNG	P 1	06H	+14.31	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1462			4.10	181	DNG	P 1	06H	+20.89	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1463	104	62			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1464			0.0	0	SAI	1	TSH	+0.23	TSHTSH	0.0		L2157	reso	21H00128	H 1	600PP	345337
			0.11	91	PID	4	TSH	+0.23	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
[illegible]			0.10	74	SAI	2	TSH	+0.23	TSHTSH	0.2		L2157	reso	21H00128	H 1	600PP	345337
1467	106	62	69.97	182	DNT	P 1	09H	-0.09	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1468					NDF		09H	-0.09	09H09H			F6623	reso	21H00178	H 6	600PP	345339
1469	112	62	3.14	178	DNT	P 1	09H	+0.02	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1470			1.34	97	MBM	6	01C	+19.82	TECTEH			M7006	reso	21H00037	H 0	600UL	332253

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 31

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1471	114	62	2.44	181	DNT	P 1	09H	-0.09	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1472	120	62	0.69	70	MBM	5	03H	+30.71	TECTEH			M7006	reso	21H00037	H 0	600UL	332253
1473	126	62	9.90	180	DNT	P 1	09H	+0.53	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1474	132	62	3.70	187	INR	P 1	VC	+26.69	TECTEH			M7006	reso	21H00067	H 0	600UL	340882
1475	17	63	6.82	179	DNT	P 1	DC	-1.74	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
			9.55	180	DNG	P 1	06C	+10.53	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
			1.02	81	MBM	6	TSC	+30.44	TECTEH			M7006	reso	21H00075	H 0	600UL	340882
1478	27	63	3.68	181	DNG	P 1	03H	+23.64	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1479			1.69	2	INR	P 1	04C	+6.77	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1480			2.01	185	DNG	P 1	02C	+35.79	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1481	53	63	0.58	67	MBM	5	06C	+7.29	TECTEH			M7006	reso	21H00075	H 0	600UL	340882

1482	57	63	2.41	179	DNG	P 1	01H	+4.80	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1483	75	63	3.50	179	DNG	P 1	08C	+8.12	TECTEH			M7006	reso	21H00064	H 0	600UL	331933
1484	79	63	4.85	6	INR	P 1	08C	+12.23	TECTEH			O8795	seco	21H00064	H 0	600UL	331933
	81	63	3.66	179	DNG	P 1	08C	+13.68	TECTEH			F1726	seco	21H00063	H 0	600UL	340882
	83	63	4.48	185	DNG	P 1	08C	+15.22	TECTEH			C5542	reso	21H00084	H 0	600UL	331963
1487	87	63	2.28	184	DNG	P 1	08H	+18.81	TECTEH			M7006	reso	21H00064	H 0	600UL	331933
1488			5.62	178	DNG	P 1	08C	+19.11	TECTEH			O8795	seco	21H00064	H 0	600UL	331933
1489	89	63	0.69	87	MBM	5	03H	+4.84	TECTEH			M7006	reso	21H00063	H 0	600UL	340882
1490			2.05	177	DNG	P 1	TSC	+16.38	TECTEH			F1726	seco	21H00063	H 0	600UL	340882
1491	91	63	2.08	180	DNG	P 1	TSH	+32.57	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1492			63.74	182	DNT	P 1	09H	-0.02	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1493					NDF		09H	-0.02	09H09H			K5380	prim	21H00182	H 6	5602C	326184
1494					OBS		09H	+0.00	09H09H			D9424	prim	21H00178	H 6	600PP	345339
1495	95	63	194.1	177	DNT	P 1	09H	+0.02	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1496					NDF		09H	+0.02	09H09H			F6623	reso	21H00178	H 6	600PP	345339
1497					OBS		09H	+0.02	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1498	97	63			NDF		09H	-0.04	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1499			54.32	183	DNT	P 1	09H	-0.04	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1500	101	63	0.39	65	MBM	5	03H	+26.17	TECTEH			M7006	reso	21H00037	H 0	600UL	332253
1501			3.25	180	DNT	P 1	09H	-0.11	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1502			0.82	44	MBM	6	TSC	+6.62	TECTEH			M7006	reso	21H00037	H 0	600UL	332253
1503	103	63	2.06	180	DNG	P 1	02H	+20.69	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1504	105	63	11.53	185	DNT	P 1	09H	+0.04	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1505	107	63			NDF		09H	+0.02	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1506			10.89	182	DNT	P 1	09H	+0.02	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1507			4.66	181	DNG	P 1	09H	+1.27	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1508			23.70	182	DNG	P 1	09H	+2.17	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1509	109	63	4.24	179	DNG	P 1	VC	+12.42	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1510	111	63			INF		08H	+13.18	TECTEH	HR		L2157	reso	21H00038	H 0	600UL	331933
			2.54	186	DNG	P 1	VH	+3.12	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
			3.85	189	DNG	P 1	09C	+16.31	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1513	113	63	3.55	185	DNG	P 1	08H	+11.07	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1514			4.08	177	DNT	P 1	09H	+0.09	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1515	117	63	3.38	177	DNT	P 1	10C	+0.56	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1516	119	63	5.24	186	DNG	P 1	10C	+2.03	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1517	121	63	3.35	175	DNG	P 1	VC	+3.83	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1518			9.15	181	DNG	P 1	10C	+3.85	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1519	123	63			NDF		10H	-0.07	10H10H			D4576	seco	21H00169	H 3	600PP	345337

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 32

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1520			0.75	69	DSI	P 1	10H	-0.07	TECTEH			D9424	prim	21H00038	H 0	600UL	331933
1521			4.84	182	DNG	P 1	05C	+24.98	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
	127	63	8.87	181	DNT	P 1	09H	+0.35	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
			2.79	182	DNG	P 1	09C	+21.45	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1524	133	63	4.29	183	DNG	P 1	08C	+4.28	TECTEH			M2655	seco	21H00067	H 0	600UL	340882
1525	135	63	1.59	82	MBM	5	TSC	+17.80	TECTEH			M7006	reso	21H00068	H 0	600UL	331933
1526			0.87	63	MBM	5	TSC	+18.33	TECTEH			M7006	reso	21H00068	H 0	600UL	331933
1527	18	64	2.27	184	DNT	P 1	06C	+0.94	TECTEH			M2655	seco	21H00076	H 0	600UL	331933

1528	20	64	9.43	179	DNG	P	1	06H	+11.48	TECTEH				O8795	seco	21H00075	H 0 600UL	340882
1529	24	64	4.97	181	DNG	P	1	VM	+2.31	TECTEH				O8795	seco	21H00075	H 0 600UL	340882
1530			4.73	179	DNG	P	1	06C	+12.94	TECTEH				O8795	seco	21H00075	H 0 600UL	340882
	48	64	5.32	178	INR	P	1	VM	+18.48	TECTEH				M2655	seco	21H00076	H 0 600UL	331933
	50	64			NDF			06H	-0.17	06H06H				W4892	prim	21H00169	H 3 600PP	345337
1533			0.61	107	DSI	P	1	06H	-0.17	TECTEH				M1029	prim	21H00076	H 0 600UL	331933
1534			2.38	181	DNG	P	1	02C	+11.13	TECTEH				D3858	reso	21H00076	H 0 600UL	331933
1535			0.78	191	INR	P	1	02C	+11.15	TECTEH				D3858	reso	21H00076	H 0 600UL	331933
1536	56	64	1.79	188	INR	P	1	02C	+35.06	TECTEH				C5542	reso	21H00076	H 0 600UL	331933
1537	60	64	2.01	179	DNG	P	1	04H	+32.47	TECTEH				M2655	seco	21H00076	H 0 600UL	331933
1538			0.58	107	DSI	P	1	04C	-1.26	TECTEH				M1029	prim	21H00076	H 0 600UL	331933
1539			0.26	119	VOL		2	04C	-1.21	03C04C				L2157	reso	21C00087	C 4 5602C	326280
1540	66	64	6.78	183	DNT	P	1	08C	-0.31	TECTEH				F1726	seco	21H00063	H 0 600UL	340882
1541	70	64	6.38	182	DNG	P	1	06H	+17.58	TECTEH				F1726	seco	21H00063	H 0 600UL	340882
1542			2.86	178	DNG	P	1	06H	+19.84	TECTEH				F1726	seco	21H00063	H 0 600UL	340882
1543			3.96	180	DNG	P	1	07H	+12.58	TECTEH				F1726	seco	21H00063	H 0 600UL	340882
1544			15.81	181	DNG	P	1	07H	+15.64	TECTEH				F1726	seco	21H00063	H 0 600UL	340882
1545					INF			07C	-2.22	TECTEH	HR			M7006	reso	21H00063	H 0 600UL	340882
1546			2.58	184	DNG	P	1	06C	+23.36	TECTEH				F1726	seco	21H00063	H 0 600UL	340882
1547	80	64	3.80	180	DNG	P	1	08C	+12.66	TECTEH				M7006	reso	21H00064	H 0 600UL	331933
1548	84	64			TBS					TSHTSH				D3858	reso	21H00115	H 1 600PP	326403
1549			0.36	21	PID		3	SBH	+23.92	SBHSTH				D3858	prim	21H00226	H999 500PP	326656
1550					DIS		3	SBH	+23.92	SBHSTH				G9427	prim	21H00223	H10 500PP	326656
1551			0.00	0	MAI		1	TSH	+0.38	TSHTSH	0.0			F3453	reso	21H00143	H 1 600PP	345281
1552			0.14	109	MAI		2	TSH	+0.38	TSHTSH	0.5			F3453	reso	21H00143	H 1 600PP	345281
1553			0.15	108	MAI		2	TSH	+0.80	TSHTSH	0.2			F3453	reso	21H00143	H 1 600PP	345281
1554			0.22	115	MAI		1	TSH	+0.80	TSHTSH	0.2			F3453	reso	21H00143	H 1 600PP	345281
1555			0.17	106	PID		4	TSH	+0.80	TSHTSH	080			M1680	reso	21H00174	H999 600PP	345337
1556	86	64			TBS					TSHTSH				D3858	reso	21H00115	H 1 600PP	326403
					DIS		3	SBH	+23.70	SBHSTH				G9427	prim	21H00223	H10 500PP	326656
			0.74	184	PID		3	SBH	+23.70	SBHSTH				D3858	prim	21H00226	H999 500PP	326656
1559			0.00	0	SAI		1	TSH	+0.83	TSHTSH	0.0			N5432	reso	21H00142	H 1 600PP	345337
1560			0.23	101	PID		4	TSH	+0.83	TSHTSH	080			M1680	reso	21H00174	H999 600PP	345337
1561			0.23	102	SAI		2	TSH	+0.83	TSHTSH	0.2			N5432	reso	21H00142	H 1 600PP	345337
1562	92	64	5.32	177	DNG	P	1	01H	+28.07	TECTEH				M2655	seco	21H00033	H 0 600UL	332253
1563					NDF			09H	+0.09	09H09H				W4892	prim	21H00169	H 6 600PP	345337
1564			70.48	175	DNT	P	1	09H	+0.09	TECTEH				M2655	seco	21H00033	H 0 600UL	332253
1565	96	64	86.75	178	DNT	P	1	09H	-0.09	TECTEH				M2655	seco	21H00037	H 0 600UL	332253
1566					OBS			09H	-0.09	09H09H				W4892	prim	21H00169	H 6 600PP	345337
1567					NDF			09H	-0.09	09H09H				K2032	seco	21H00182	H 6 5602C	326184
1568					OBS			09H	+0.00	09H09H				D9424	prim	21H00178	H 6 600PP	345339

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 33

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
			2.31	177	DNG	P	1	04C	+5.15	TECTEH				M2655	seco	21H00037	H 0 600UL	332253
1570	102	64	4.37	185	DNT	P	1	09H	-0.04	TECTEH				N5877	seco	21H00038	H 0 600UL	331933
1571	104	64	2.21	180	DNG	P	1	01C	+9.28	TECTEH				M2655	seco	21H00037	H 0 600UL	332253
1572	108	64	11.07	181	DNT	P	1	09H	+0.07	TECTEH				M2655	seco	21H00037	H 0 600UL	332253
1573			0.82	69	MBM		5	07C	+18.26	TECTEH				M7006	reso	21H00037	H 0 600UL	332253

1574	112	64	4.14	187	DNG	P 1	TSH	+14.02	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1575	114	64	2.85	184	DNG	P 1	VC	+3.02	TECTEH			L2157	reso	21H00038	H 0	600UL	331933
1576	116	64	0.78	69	MBM	5	05H	+14.36	TECTEH			M7006	reso	21H00037	H 0	600UL	332253
	124	64	2.28	176	DNG	P 1	VH	+30.11	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
			5.55	179	DNG	P 1	10C	+6.81	TECTEH			M2655	seco	21H00037	H 0	600UL	332253
1579	126	64	2.06	181	DNT	P 1	09H	+0.33	TECTEH			N5877	seco	21H00038	H 0	600UL	331933
1580			1.21	82	MBM	5	09H	+12.69	TECTEH			L2157	reso	21H00038	H 0	600UL	331933
1581	134	64	0.91	55	MBM	5	TSC	+17.39	TECTEH			M7006	reso	21H00067	H 0	600UL	340882
1582	45	65	2.24	180	DNG	P 1	03C	+29.23	TECTEH			M2655	seco	21H00076	H 0	600UL	331933
1583	49	65	2.53	179	DNG	P 1	VM	+13.90	TECTEH			M2655	seco	21H00076	H 0	600UL	331933
1584	51	65			NDF		02H	+1.08	02H02H			D4576	seco	21H00169	H 3	600PP	345337
1585			0.41	74	DSI	P 1	02H	+1.08	TECTEH			J5670	prim	21H00075	H 0	600UL	340882
1586	59	65	0.63	56	MBM	6	07C	+9.06	TECTEH			M7006	reso	21H00075	H 0	600UL	340882
1587	83	65	0.70	52	MBM	6	04C	+29.38	TECTEH			M7006	reso	21H00063	H 0	600UL	340882
1588	85	65	2.62	181	DNG	P 1	01C	+26.09	TECTEH			O8795	seco	21H00064	H 0	600UL	331933
1589	87	65	2.96	181	DNG	P 1	08C	+19.37	TECTEH			F1726	seco	21H00063	H 0	600UL	340882
1590	91	65			OBS		09H	+0.00	09H09H			D9424	prim	21H00178	H 6	600PP	345339
1591					NDF		09H	+0.02	09H09H			K5380	prim	21H00182	H 6	5602C	326184
1592					OBS		09H	+0.02	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1593			58.85	175	DNT	P 1	09H	+0.02	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1594	93	65			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1595			0.13	66	PID	4	TSH	+0.64	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
1596			0.27	104	SAI	1	TSH	+0.64	TSHTSH	0.3		L2157	reso	21H00128	H 1	600PP	345337
1597			0.17	99	SAI	2	TSH	+0.64	TSHTSH	0.2		L2157	reso	21H00128	H 1	600PP	345337
1598					NDF		09H	+0.11	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1599			105.4	174	DNT	P 1	09H	+0.11	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1600	95	65	83.55	183	DNT	P 1	09H	-0.11	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1601					NDF		09H	-0.11	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1602	97	65			NDF		09H	-0.06	09H09H			W4892	prim	21H00169	H 6	600PP	345337
			71.22	175	DNT	P 1	09H	-0.06	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
			2.83	173	DNG	P 1	VC	+13.38	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
1605	107	65	48.71	183	DNT	P 1	09H	+0.09	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1606					NDF		09H	+0.09	09H09H			S8982	seco	21H00170	H 6	600PP	345325
1607	109	65	47.77	175	DNT	P 1	09H	+0.00	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1608			4.48	171	DNG	P 1	VC	+12.48	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1609	111	65	0.45	83	NQI	5	VC	+3.38	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1610			0.19	125	VOL	2	VC	+3.50	DC VC			F3453	reso	21C00084	C 5	5602C	326280
1611	115	65			INF		09C	+18.87	TECTEH	HR		M7006	reso	21H00034	H 0	600UL	331933
1612			5.54	184	DNG	P 1	09C	+21.12	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1613	117	65	3.33	178	DNT	P 1	10C	+0.55	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1614	119	65	2.54	181	DNT	P 1	09H	+0.00	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1615			2.56	184	DNG	P 1	VH	+28.26	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1616					INF		VH	+29.92	TECTEH	HR		M7006	reso	21H00034	H 0	600UL	331933
1617			0.39	83	INR	9	TSC	+1.49	TSCTSC			D3858	reso	21C00051	C 2	600PP	345293

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 34

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1618	121	65	4.40	175	DNG	P 1	10C	+4.01	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1619	125	65	2.78	171	DNG	P 1	TSH	+33.86	TECTEH			M2655	seco	21H00033	H 0	600UL	332253

1620	127	65	1.85	79	MBM	6	03H	+28.92	TECTEH				M7006	reso	21H00034	H	0	600UL	331933
1621			0.76	85	MBM	5	03H	+31.47	TECTEH				M7006	reso	21H00034	H	0	600UL	331933
1622	129	65	2.39	171	DNG	P 1	DH	+26.59	TECTEH				M2655	seco	21H00033	H	0	600UL	332253
[illegible]	133	65	7.75	184	DNG	P 1	10C	+13.78	TECTEH				M2655	seco	21H00067	H	0	600UL	340882
[illegible]	137	65	0.77	79	MBM	5	02C	+19.07	TECTEH				M7006	reso	21H00068	H	0	600UL	331933
1625	32	66			TBS				TSHTSH				D3858	reso	21H00115	H	1	600PP	326403
1626			0.13	90	SAI	2	TSH	+2.41	TSHTSH	0.2			N5432	reso	21H00156	H	1	600PP	345281
1627			0.07	146	PID	4	TSH	+2.41	TSHTSH	080			F3453	reso	21H00175	H999		600PP	345339
1628			0.00	0	SAI	1	TSH	+2.41	TSHTSH	0.0			N5432	reso	21H00156	H	1	600PP	345281
1629	38	66	3.31	183	DNT	P 1	VM	+0.86	TECTEH				O8795	seco	21H00075	H	0	600UL	340882
1630	48	66	2.69	186	DNT	P 1	VM	+1.94	TECTEH				O8795	seco	21H00075	H	0	600UL	340882
1631	50	66	3.12	179	DNT	P 1	VM	+1.98	TECTEH				M2655	seco	21H00076	H	0	600UL	331933
1632	54	66	4.82	191	DNG	P 1	01H	+20.45	TECTEH				M2655	seco	21H00076	H	0	600UL	331933
1633			2.08	188	DNG	P 1	02H	+23.43	TECTEH				M2655	seco	21H00076	H	0	600UL	331933
1634	64	66	0.86	93	MBM	5	01C	+32.40	TECTEH				M7006	reso	21H00075	H	0	600UL	340882
1635	66	66	0.70	85	MBM	5	02C	+4.69	TECTEH				M7006	reso	21H00064	H	0	600UL	331933
1636	80	66	3.87	182	DNG	P 1	08C	+13.00	TECTEH				F1726	seco	21H00063	H	0	600UL	340882
1637	94	66			OBS		08H	+18.04	08HTEH				D6502	prim	21H00033	H	0	600UL	332253
1638					OBS		08H	+19.28	08HTEH				F7467	seco	21H00079	H	0	600UL	340882
1639					OBS		09H	+0.00	09H09H				D9424	prim	21H00178	H	6	600PP	345339
1640			170.3	177	DNT	P 1	09H	+0.12	TEHTEC				D4576	seco	21C00063	H	0	580UL	287747
1641					OBS		09H	+0.12	09H09H				W4892	prim	21H00169	H	6	600PP	345337
1642					NDF		09H	+0.12	09H09H				K5380	prim	21H00182	H	6	5602C	326184
1643					OBS		DH	-11.08	DH TEC				N2574	seco	21C00057	H	0	600CS	341612
1644			3.46	185	DNG	P 1	VM	+14.95	TEHTEC				D4576	seco	21C00063	H	0	580UL	287747
1645			2.80	186	INR	P 1	VM	+15.26	DH TEC				N2574	seco	21C00057	H	0	600CS	341612
1646			5.10	187	DNG	P 1	VM	+24.62	TEHTEC				D4576	seco	21C00063	H	0	580UL	287747
1647			4.80	188	INR	P 1	VM	+25.31	DH TEC				N2574	seco	21C00057	H	0	600CS	341612
1648	96	66	2.56	185	DNG	P 1	04H	+7.37	TECTEH				M9715	seco	21H00034	H	0	600UL	331933
					NDF		09H	+0.20	09H09H				D4576	seco	21H00169	H	6	600PP	345337
[illegible]			114.2	180	DNT	P 1	09H	+0.20	TECTEH				M9715	seco	21H00034	H	0	600UL	331933
1651	98	66	0.27	94	MBM	5	03H	+18.54	TECTEH				C5542	reso	21H00033	H	0	600UL	332253
1652			43.43	177	DNT	P 1	09H	+0.00	TECTEH				M2655	seco	21H00033	H	0	600UL	332253
1653	118	66	3.18	174	DNT	P 1	10C	+0.53	TECTEH				M2655	seco	21H00033	H	0	600UL	332253
1654	122	66	2.39	172	DNT	P 1	10C	+0.50	TECTEH				S4373	reso	21H00033	H	0	600UL	332253
1655			0.37	69	MBM	5	08C	+14.99	TECTEH				C5542	reso	21H00033	H	0	600UL	332253
1656	124	66			NDF		10H	-0.05	10H10H				W4892	prim	21H00169	H	3	600PP	345337
1657			0.84	104	DSI	P 1	10H	-0.05	TECTEH				D9424	prim	21H00034	H	0	600UL	331933
1658					NDF		10H	+0.04	10H10H				D4576	seco	21H00169	H	3	600PP	345337
1659			0.84	101	DSI	P 1	10H	+0.04	TECTEH				M9715	seco	21H00034	H	0	600UL	331933
1660			2.09	180	DNG	P 1	01C	+17.72	TECTEH				M9715	seco	21H00034	H	0	600UL	331933
1661	132	66	0.73	78	MBM	5	05H	+17.45	TECTEH				M7006	reso	21H00068	H	0	600UL	331933
1662	134	66	4.80	186	DNG	P 1	07H	+23.21	TECTEH				M2655	seco	21H00067	H	0	600UL	340882
1663	136	66	3.58	179	DNT	P 1	TSH	+38.44	TEHTEC				C5542	reso	21C00060	H	0	600CS	341613
1664			6.55	182	DNG	P 1	09C	+18.73	TEHTEC				M9715	seco	21C00060	H	0	600CS	341613
1665			3.21	179	DNG	P 1	08C	+6.52	TEHTEC				M9715	seco	21C00060	H	0	600CS	341613
1666	29	67			TBS				TSHTSH				D3858	reso	21H00115	H	1	600PP	326403

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 35

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N

1667			0.0	0	SAI	1	TSH	+0.40	TSHTSH	0.0			L2157	reso	21H00155	H 1	600PP	345337
1668			0.09	61	SAI	2	TSH	+0.40	TSHTSH	0.3			L2157	reso	21H00155	H 1	600PP	345337
			0.10	61	PID	4	TSH	+0.40	TSHTSH	080			F3453	reso	21H00175	H999	600PP	345339
	39	67			INF		DH	+13.78	TECTEH	HR			A9608	reso	21H00076	H 0	600UL	331933
[illegible]					INF		DH	+13.91	TECTEH	HR			A9608	reso	21H00076	H 0	600UL	331933
1672			9.33	176	DNG	P 1	DH	+16.03	TECTEH				M2655	seco	21H00076	H 0	600UL	331933
1673			6.75	176	DNT	P 1	VM	-1.71	TECTEH				M2655	seco	21H00076	H 0	600UL	331933
1674					INF		VM	-1.00	TECTEH	HR			A9608	reso	21H00076	H 0	600UL	331933
1675	41	67	5.76	179	DNG	P 1	02C	+14.73	TECTEH				O8795	seco	21H00075	H 0	600UL	340882
1676	65	67	0.83	75	MBM	6	03H	+21.02	TECTEH				M7006	reso	21H00063	H 0	600UL	340882
1677			0.31	51	MBM	6	05H	+13.58	TECTEH				M7006	reso	21H00063	H 0	600UL	340882
1678			0.36	65	MBM	5	VM	+10.18	TECTEH				M7006	reso	21H00063	H 0	600UL	340882
1679	79	67			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
1680			0.50	201	PID	3	SBH	+23.85	SBHSTH				D3858	prim	21H00226	H999	500PP	326656
1681					DIS	3	SBH	+23.85	SBHSTH				G9427	prim	21H00223	H10	500PP	326656
1682			0.15	75	SAI	1	TSH	+0.62	TSHTSH	0.3			F3453	reso	21H00143	H 1	600PP	345281
1683			0.10	124	SAI	2	TSH	+0.62	TSHTSH	0.4			F3453	reso	21H00143	H 1	600PP	345281
1684			0.14	118	PID	4	TSH	+0.62	TSHTSH	080			M1680	reso	21H00174	H999	600PP	345337
1685			1.68	187	INR	P 1	VH	+27.67	TECTEH				O8795	seco	21H00064	H 0	600UL	331933
1686			5.02	176	DNG	P 1	VM	+5.17	TECTEH				O8795	seco	21H00064	H 0	600UL	331933
1687			3.44	182	INR	P 1	08C	-0.56	TECTEH				O8795	seco	21H00064	H 0	600UL	331933
1688	81	67	2.92	177	DNG	P 1	01H	+8.19	TECTEH				F1726	seco	21H00063	H 0	600UL	340882
1689			2.86	178	DNG	P 1	07H	+6.68	TECTEH				F1726	seco	21H00063	H 0	600UL	340882
1690			5.44	179	DNG	P 1	07H	+8.70	TECTEH				F1726	seco	21H00063	H 0	600UL	340882
1691			2.39	182	DNG	P 1	07C	+16.44	TECTEH				F1726	seco	21H00063	H 0	600UL	340882
1692			4.89	182	DNG	P 1	07C	+17.40	TECTEH				F1726	seco	21H00063	H 0	600UL	340882
1693	83	67	0.39	73	MBM	6	02H	+33.89	TECTEH				M7006	reso	21H00064	H 0	600UL	331933
1694	85	67			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
					DIS	3	SBH	+23.88	SBHSTH				G9427	prim	21H00223	H10	500PP	326656
			0.62	186	PID	3	SBH	+23.88	SBHSTH				D3858	prim	21H00226	H999	500PP	326656
1697			0.12	121	MAI	2	TSH	+1.00	TSHTSH	0.6			N5432	reso	21H00142	H 1	600PP	345337
1698			0.10	115	PID	4	TSH	+1.00	TSHTSH	080			F6623	reso	21H00180	H999	600PP	345339
1699			0.14	45	MAI	1	TSH	+1.00	TSHTSH	0.4			N5432	reso	21H00142	H 1	600PP	345337
1700	93	67			OBS		09H	+0.00	09H09H				D9424	prim	21H00178	H 6	600PP	345339
1701					OBS		09H	+0.15	09H09H				W4892	prim	21H00169	H 6	600PP	345337
1702					NDF		09H	+0.15	09H09H				K2032	seco	21H00182	H 6	5602C	326184
1703			118.7	173	DNT	P 1	09H	+0.15	TECTEH				M2655	seco	21H00033	H 0	600UL	332253
1704	97	67	49.42	176	DNT	P 1	09H	-0.04	TECTEH				M2655	seco	21H00033	H 0	600UL	332253
1705					NDF		09H	-0.04	09H09H				W4892	prim	21H00169	H 6	600PP	345337
1706	99	67	8.21	185	DNG	P 1	09H	+9.42	TECTEH				M9715	seco	21H00034	H 0	600UL	331933
1707			11.65	184	DNG	P 1	09H	+10.05	TECTEH				M9715	seco	21H00034	H 0	600UL	331933
1708			31.83	183	DNG	P 1	09H	+11.98	TECTEH				M7006	reso	21H00034	H 0	600UL	331933
1709	105	67	2.84	176	DNG	P 1	06H	+7.62	TECTEH				M2655	seco	21H00033	H 0	600UL	332253
1710	107	67	1.53	78	MBM	6	04H	+6.18	TECTEH				M7006	reso	21H00034	H 0	600UL	331933
1711	109	67	3.10	174	DNG	P 1	VC	+12.93	TECTEH				M2655	seco	21H00033	H 0	600UL	332253
1712	115	67	6.42	188	DNG	P 1	09C	+20.63	TECTEH				M9715	seco	21H00034	H 0	600UL	331933
1713	117	67	3.77	178	DNT	P 1	10C	+0.53	TECTEH				M2655	seco	21H00033	H 0	600UL	332253
1714			0.41	83	INR	9	TSC	+1.63	TSCTSC				D3858	reso	21C00051	C 2	600PP	345293
1715	119	67	5.22	188	DNG	P 1	10C	+2.01	TECTEH				M9715	seco	21H00034	H 0	600UL	331933

SG 21 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
			0.46	83	INR	9	TSC	+0.56	TSCTSC			L2157	reso	21C00052	C 2	600PP	345341
1717	127	67	0.97	144	DSI	P 1	10H	-0.07	TECTEH			D9424	prim	21H00034	H 0	600UL	331933
1718					NDF		10H	-0.07	10H10H			S8982	seco	21H00170	H 3	600PP	345325
1719	135	67	1.60	91	MBM	5	05H	+1.72	TECTEH			M7006	reso	21H00068	H 0	600UL	331933
1720			1.95	87	MBM	6	06H	+10.59	TECTEH			M7006	reso	21H00068	H 0	600UL	331933
1721			1.92	90	MBM	5	06H	+18.09	TECTEH			M7006	reso	21H00068	H 0	600UL	331933
1722	26	68	5.88	181	DNG	P 1	06H	+18.43	TECTEH			M2655	seco	21H00076	H 0	600UL	331933
1723			4.42	181	DNG	P 1	06C	+17.30	TECTEH			D3858	reso	21H00076	H 0	600UL	331933
1724	32	68			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1725			0.80	130	INR	P 1	TSH	+1.38	TECTEH			M7006	reso	21H00075	H 0	600UL	340882
1726			0.00	0	MAI	1	TSH	+1.68	TSHTSH	0.0		F3453	reso	21H00143	H 1	600PP	345281
1727			0.19	96	PRC	2	TSH	+1.68	TSHTSH			K2032	seco	21H00155	H 1	600PP	345337
1728			0.15	79	PID	4	TSH	+1.68	TSHTSH	080		F3453	reso	21H00175	H999	600PP	345339
1729			0.13	89	MAI	2	TSH	+1.68	TSHTSH	1.0		F3453	reso	21H00143	H 1	600PP	345281
1730	36	68	3.39	181	DNG	P 1	05H	+36.93	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1731			2.31	175	DNG	P 1	05H	+37.31	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1732			2.33	179	DNT	P 1	06H	-1.82	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1733			11.18	180	DNG	P 1	06H	+7.12	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1734			4.13	181	DNT	P 1	07H	+0.93	TECTEH			D3858	reso	21H00075	H 0	600UL	340882
1735			3.50	183	DNT	P 1	VM	+1.94	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1736			6.72	181	DNG	P 1	07C	+7.55	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1737			18.19	182	DNG	P 1	07C	+8.14	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1738			3.29	6	INR	P 1	06C	+21.29	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1739	42	68			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1740			0.31	27	SCI	P 1	TSH	-3.83	TSHTSH	0.3	PWSCC	M1680	reso	21H00142	H 1	600PP	345337
			1.63	26	PID	4	TSH	-3.83	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
			0.28	16	SCI	1	TSH	-3.83	TSHTSH	0.3	PWSCC	M1680	reso	21H00142	H 1	600PP	345337
1743			0.72	22	PRC	P 1	TSH	-3.83	TSHTSH			L2157	reso	21H00155	H 1	600PP	345337
1744	50	68	8.48	175	DNT	P 1	VM	+1.97	TECTEH			M2655	seco	21H00076	H 0	600UL	331933
1745			2.12	174	DNG	P 1	VM	+13.36	TECTEH			M2655	seco	21H00076	H 0	600UL	331933
1746	66	68	3.39	178	DNT	P 1	08C	-0.11	TECTEH			O8795	seco	21H00064	H 0	600UL	331933
1747	68	68	0.83	93	MBM	6	03C	+24.87 TO+30.40	TECTEH			M7006	reso	21H00063	H 0	600UL	340882
1748	70	68	2.91	180	INR	P 1	08C	+2.84	TECTEH			M7006	reso	21H00064	H 0	600UL	331933
1749	88	68	0.30	81	MBM	5	05H	+7.58	TECTEH			M7006	reso	21H00063	H 0	600UL	340882
1750	94	68			OBS		08H	+19.43	08HTEH			C5542	reso	21H00033	H 0	600UL	332253
1751					OBS		09H	+0.00	09H09H			D9424	prim	21H00178	H 6	600PP	345339
1752			178.3	174	DNT	P 1	09H	+-0.00	DC TEH			S4373	reso	21H00079	H 0	600UL	340882
1753					OBS		09H	+0.00	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1754					NDF		09H	+0.00	09H09H			K2032	seco	21H00182	H 6	5602C	326184
1755	102	68	70.44	174	DNT	P 1	09H	-0.04	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1756					NDF		09H	-0.04	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1757	104	68	0.94	86	MBM	5	01C	+20.77	TECTEH			M7006	reso	21H00034	H 0	600UL	331933
1758	110	68	2.65	173	DNG	P 1	TSH	+10.92	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1759			3.85	170	DNG	P 1	VC	+18.48	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1760			3.85	170	DNG	P 1	VC	+20.27	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1761			3.29	170	DNT	P 1	DC	+0.02	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1762	112	68	3.85	185	DNG	P 1	VC	+2.59	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1763	118	68	2.64	179	DNT	P 1	09H	+0.00	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1764			1.51	184	INR	P 1	VM	+4.39	TECTEH			M7006	reso	21H00034	H 0	600UL	331933

SG 21 - All Calls (Excluding NDD and retest codes)

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1765			0.30	84	INR	9	TSC	+2.69	TSCTSC			D3858	reso	21C00052	C 2	600PP	345341
1766			0.20	85	INR	9	TSC	+2.72	TSCTSC			D3858	reso	21C00051	C 2	600PP	345293
1767	124	68	0.60	56	MBM	5	08H	+13.69	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
1768			3.82	175	DNG	P 1	10C	+6.81	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1769	134	68	2.82	179	DNG	P 1	05C	+19.59	TECTEH			M2655	seco	21H00067	H 0	600UL	340882
1770			4.51	189	DNG	P 1	02C	+8.67	TECTEH			M2655	seco	21H00067	H 0	600UL	340882
1771	29	69			TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1772			0.18	105	SAI	2	TSH	+0.58	TSHTSH	0.3		L2157	reso	21H00155	H 1	600PP	345337
1773			0.00	0	SAI	1	TSH	+0.58	TSHTSH	0.0		L2157	reso	21H00155	H 1	600PP	345337
1774			0.19	97	PID	4	TSH	+0.58	TSHTSH	080		F3453	reso	21H00175	H999	600PP	345339
1775			1.94	74	MBM	6	03H	+19.74	TECTEH			M7006	reso	21H00075	H 0	600UL	340882
1776	43	69	9.23	181	DNG	P 1	DH	+8.66	TECTEH			M2655	seco	21H00076	H 0	600UL	331933
1777	45	69	2.17	179	DNG	P 1	04C	+10.95	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1778	49	69	2.76	7	INR	P 1	VM	-1.48	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1779	53	69	2.40	182	DNG	P 1	02C	+7.49	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1780	85	69			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1781			0.36	92	NQI	P 1	TSH	+0.57	TECTEH			M7006	reso	21H00063	H 0	600UL	340882
1782			0.20	95	PID	4	TSH	+0.76	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
1783			0.28	96	SAI	2	TSH	+0.76	TSHTSH	0.5		N5432	reso	21H00142	H 1	600PP	345337
1784			0.34	69	SAI	1	TSH	+0.76	TSHTSH	0.5		N5432	reso	21H00142	H 1	600PP	345337
1785			0.14	106	MAI	2	TSH	+1.10	TSHTSH	0.3		N5432	reso	21H00142	H 1	600PP	345337
1786			0.15	116	MAI	1	TSH	+1.10	TSHTSH	0.3		N5432	reso	21H00142	H 1	600PP	345337
			2.11	182	INR	P 1	08C	+16.26	TECTEH			F1726	seco	21H00063	H 0	600UL	340882
	87	69	1.59	183	INR	P 1	TSC	+15.75	TECTEH			O8795	seco	21H00064	H 0	600UL	331933
1789	89	69	1.68	181	INR	P 1	08C	+20.52	TECTEH			F1726	seco	21H00063	H 0	600UL	340882
1790	91	69	19.07	175	DNT	P 1	09H	-0.06	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1791					NDF		09H	-0.06	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1792			1.74	177	INR	P 1	02C	+0.97	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
1793	99	69	1.92	184	INR	P 1	01H	+32.46	TECTEH			M7006	reso	21H00034	H 0	600UL	331933
1794	101	69			NDF		09H	-0.02	09H09H			W4892	prim	21H00169	H 6	600PP	345337
1795			58.96	176	DNT	P 1	09H	-0.02	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1796			0.39	84	MBM	5	VH	+13.44	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
1797	103	69	0.74	92	MBM	5	04H	+17.41	TECTEH			M7006	reso	21H00034	H 0	600UL	331933
1798			45.88	185	DNT	P 1	09H	-0.07	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1799	107	69	39.59	184	DNT	P 1	09H	+0.00	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1800	109	69	34.39	175	DNT	P 1	09H	-0.02	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1801			3.38	173	DNG	P 1	VC	+12.29	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1802	111	69			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1803					DIS	3	SBH	+24.27	SBHSTH			G9427	prim	21H00223	H10	500PP	326656
1804			1.85	201	PID	3	SBH	+24.27	SBHSTH			D3858	prim	21H00226	H999	500PP	326656
1805			0.22	85	MAI	1	TSH	+0.83	TSHTSH	0.6		L2157	reso	21H00128	H 1	600PP	345337
1806			0.14	97	MAI	2	TSH	+0.83	TSHTSH	0.5		L2157	reso	21H00128	H 1	600PP	345337
1807			0.13	101	PID	4	TSH	+0.83	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
1808			9.91	185	DNT	P 1	09H	+0.07	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1809	115	69	41.46	186	DNT	P 1	09H	+0.00	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1810			3.74	185	DNG	P 1	05C	+19.69	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1811	117	69	4.83	178	DNT	P 1	10C	+0.53	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
	119	69	5.36	188	DNG	P 1	10C	+1.99	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
	121	69	5.79	176	DNG	P 1	10C	+3.90	TECTEH			M2655	seco	21H00033	H 0	600UL	332253

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1814	30	70	8.89	180	DNG	P 1	06H	+21.58	TECTEH			M2655	seco	21H00076	H 0	600UL	331933
1815	50	70	4.44	179	DNG	P 1	02H	+27.37	TECTEH			M2655	seco	21H00076	H 0	600UL	331933
1816	64	70			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1817			0.17	112	PID	4	TSH	+0.58	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
1818			0.00	0	MAI	1	TSH	+0.58	TSHTSH	0.0		F3453	reso	21H00143	H 1	600PP	345281
1819			0.11	116	PRC	2	TSH	+0.58	TSHTSH			L2157	reso	21H00155	H 1	600PP	345337
1820			0.13	122	MAI	2	TSH	+0.58	TSHTSH	0.3		F3453	reso	21H00143	H 1	600PP	345281
1821	66	70	0.43	108	MBM	5	02C	+23.52	TECTEH			M7006	reso	21H00064	H 0	600UL	331933
1822	76	70	0.71	93	MBM	6	04C	+22.67	TECTEH			M7006	reso	21H00063	H 0	600UL	340882
1823	86	70	1.72	184	INR	P 1	08C	+18.07	TECTEH			F1726	seco	21H00063	H 0	600UL	340882
1824	90	70	2.23	181	DNG	P 1	08C	+20.99	TECTEH			F1726	seco	21H00063	H 0	600UL	340882
1825	92	70			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1826					DIS	3	SBH	+24.14	SBHSTH			G9427	prim	21H00223	H10	500PP	326656
1827			1.04	198	PID	3	SBH	+24.14	SBHSTH			D3858	prim	21H00226	H999	500PP	326656
1828			0.10	48	SAI	1	TSH	+0.47	TSHTSH	0.2		L2157	reso	21H00128	H 1	600PP	345337
1829			0.13	99	SAI	2	TSH	+0.47	TSHTSH	0.3		L2157	reso	21H00128	H 1	600PP	345337
1830			0.50	130	NQI	P 1	TSH	+0.68	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
1831			0.17	126	PID	4	TSH	+0.97	TSHTSH	080		M1680	reso	21H00151	H999	600PP	345281
1832			0.0	0	SAI	1	TSH	+0.97	TSHTSH	0.0		L2157	reso	21H00128	H 1	600PP	345337
			0.17	99	SAI	2	TSH	+0.97	TSHTSH	0.3		L2157	reso	21H00128	H 1	600PP	345337
			45.71	177	DNT	P 1	09H	-0.07	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1835	94	70			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1836			0.84	177	PID	3	SBH	+23.96	SBHSTH			D3858	prim	21H00226	H999	500PP	326656
1837					DIS	3	SBH	+23.96	SBHSTH			G9427	prim	21H00223	H10	500PP	326656
1838			0.24	93	MAI	2	TSH	+0.98	TSHTSH	0.7		L2157	reso	21H00129	H 1	600PP	345281
1839			0.25	98	PID	4	TSH	+0.98	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
1840			0.19	28	MAI	1	TSH	+0.98	TSHTSH	0.7		L2157	reso	21H00129	H 1	600PP	345281
1841			54.05	185	DNT	P 1	09H	-0.13	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1842					NDF		09H	-0.13	09H09H			D4576	seco	21H00167	H 6	600PP	345325
1843			2.10	190	DNG	P 1	02C	+3.38	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1844			2.55	191	DNG	P 1	02C	+4.45	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1845	102	70	187.2	176	DNT	P 1	09H	-0.02	DC TEH			A9608	reso	21H00079	H 0	600UL	340882
1846					NDF		09H	+0.00	09H09H			K5380	prim	21H00182	H 6	5602C	326184
1847					OBS		09H	+0.00	09H09H			W4892	prim	21H00167	H 3	600PP	345325
1848			115.5	176	DNT	P 1	09H	+0.00	TECTEH			M0945	seco	21H00093	H 0	600UL	331963
1849					OBS		09H	+0.00	09H09H			D9424	prim	21H00178	H 6	600PP	345339
1850			2.47	191	DNT	P 1	09C	+0.28	TECTEH			M0945	seco	21H00093	H 0	600UL	331963
1851	104	70	51.60	186	DNT	P 1	09H	+0.00	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1852					NDF		09H	+0.00	09H09H			D4576	seco	21H00167	H 6	600PP	345325
1853	108	70	5.15	185	DNG	P 1	05H	+8.80	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1854	114	70	18.89	176	DNT	P 1	09H	+0.04	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1855	122	70	5.02	176	DNT	P 1	10C	+0.47	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1856	124	70	3.69	183	DNG	P 1	02C	+26.78	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1857	126	70	1.06	68	MBM	5	TSH	+4.78	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
			0.93	89	MBM	6	03H	+24.29	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
			0.77	82	MBM	5	05H	+20.92	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
1860			1.84	189	INR	P 1	09H	+0.61	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
1861	134	70	0.55	2	IDM	2	TSH	+2.77	TSHTSH			F3453	reso	21H00171	H 1	600PP	345336
1862	41	71	2.73	186	DNT	P 1	VM	+1.55	TECTEH			M2655	seco	21H00076	H 0	600UL	331933

SG 21 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1863	43	71	9.26	183	DNG	P 1	DH	+8.06	TECTEH			O8795	seco	21H00075	H 0	600UL	340882
1864	49	71	2.67	182	DNT	P 1	VM	-1.72	TECTEH			M2655	seco	21H00076	H 0	600UL	331933
1865	67	71	1.73	173	INR	P 1	DH	+6.75	TECTEH			M7006	reso	21H00064	H 0	600UL	331933
1866	91	71	57.31	176	DNT	P 1	09H	-0.09	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1867					NDF		09H	-0.09	09H09H			K2032	seco	21H00182	H 6	5602C	326184
1868					OBS		09H	+0.00	09H09H			D9424	prim	21H00178	H 6	600PP	345339
1869			0.68	92	MBM	5	VM	+19.21	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
1870	95	71	2.09	174	DNG	P 1	TSC	+24.34	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1871	97	71	3.62	176	DNG	P 1	07H	+16.51	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1872			3.99	175	DNG	P 1	08H	+2.51	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1873			3.00	175	DNG	P 1	08H	+6.17	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1874			2.51	174	DNG	P 1	08H	+11.42	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1875			6.03	175	DNG	P 1	08H	+14.35	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1876			4.21	180	DNT	P 1	09H	+0.50	TECTEH			S4373	reso	21H00033	H 0	600UL	332253
1877			31.40	175	DNG	P 1	09H	+1.71	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1878			3.68	175	DNT	P 1	VM	-1.65	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
			5.37	175	DNG	P 1	VM	+3.24	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
			7.77	179	DNT	P 1	09C	-0.50	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1881			2.40	178	DNT	P 1	09C	+0.51	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1882			4.38	177	DNG	P 1	08C	+11.31	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1883			2.33	179	DNG	P 1	08C	+13.86	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1884			1.00	185	INR	P 1	08C	+15.21	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1885			12.31	176	DNG	P 1	08C	+16.29	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1886			1.53	174	INR	P 1	01C	+28.30	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
1887	99	71	35.18	176	DNT	P 1	09H	+0.17	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1888			2.50	172	DNG	P 1	01C	+8.29	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1889	101	71	29.36	188	DNT	P 1	09H	+0.00	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1890	103	71	68.10	175	DNT	P 1	09H	+0.04	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1891					NDF		09H	+0.04	09H09H			W4892	prim	21H00166	H 6	600PP	345337
1892	105	71	18.50	186	DNT	P 1	09H	+0.00	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1893	107	71	4.88	181	DNG	P 1	TSH	+13.94	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1894	109	71	5.10	184	DNG	P 1	VC	+12.50	TECTEH			M7006	reso	21H00034	H 0	600UL	331933
1895	111	71			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1896			0.20	116	SAI	2	TSH	+1.15	TSHTSH	0.4		L2157	reso	21H00128	H 1	600PP	345337
1897			0.21	143	SAI	1	TSH	+1.15	TSHTSH	0.5		L2157	reso	21H00128	H 1	600PP	345337
1898			0.48	120	PID	4	TSH	+1.15	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
1899			0.82	75	NQI	5	TSH	+2.26	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
1900			0.46	94	SAI	1	TSH	+2.59	TSHTSH	0.5		L2157	reso	21H00128	H 1	600PP	345337
1901			0.42	116	SAI	2	TSH	+2.59	TSHTSH	0.5		L2157	reso	21H00128	H 1	600PP	345337
1902	113	71	11.46	185	DNT	P 1	09H	+0.04	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1903	117	71	5.82	176	DNT	P 1	10C	+0.60	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
	119	71	3.08	185	DNT	P 1	09H	-0.09	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
			5.90	187	DNG	P 1	10C	+1.98	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1906	127	71	0.64	6	IDM	2	TSH	+4.68	TSHTSH			W4892	prim	21H00128	H 1	600PP	345337
1907	129	71	1.69	178	INR	P 1	VH	+26.81	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1908	133	71	0.20	73	PLP	9	TSH	+0.89	TSHTSH			H2949	seco	21H00171	H 1	600PP	345336
1909			0.57	9	IDM	2	TSH	+3.88	TSHTSH			F3453	reso	21H00171	H 1	600PP	345336

1910			8.99	180	DNG	P	1	10C	+15.06	TECTEH			M7006	reso	21H00068	H	0	600UL	331933
1911	137	71	0.46	84	MBM		5	TSH	+9.00	TEHTEC			A9608	reso	21C00060	H	0	600CS	341613

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 40

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1912	46	72	1.76	79	MBM		5	01H	+24.69	TECTEH			M7006	reso	21H00075	H	0	600UL	340882
1913	56	72	2.52	186	DNG	P	1	02C	+20.10	TECTEH			F1726	seco	21H00068	H	0	600UL	331933
1914	74	72	0.56	69	MBM		5	TSH	+15.41	TECTEH			M7006	reso	21H00063	H	0	600UL	340882
1915	80	72	2.79	182	DNT	P	1	VH	+0.11	TECTEH			M7006	reso	21H00064	H	0	600UL	331933
1916	82	72	2.88	178	DNG	P	1	04C	+22.05	TECTEH			F1726	seco	21H00063	H	0	600UL	340882
1917	88	72	1.44	185	INR	P	1	02H	-0.63	TECTEH			F1726	seco	21H00063	H	0	600UL	340882
1918			0.71	74	MBM		5	VM	+18.52	TECTEH			M7006	reso	21H00063	H	0	600UL	340882
1919	92	72	48.65	174	DNT	P	1	09H	-0.02	TECTEH			M2655	seco	21H00033	H	0	600UL	332253
1920					NDF			09H	-0.02	09H09H			D4576	seco	21H00167	H	6	600PP	345325
1921	94	72			TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
1922			0.14	88	SAI		2	TSH	+1.04	TSHTSH	0.2		L2157	reso	21H00129	H	1	600PP	345281
1923			0.12	99	PID		4	TSH	+1.04	TSHTSH	080		D8661	reso	21H00150	H999		600PP	345337
1924			0.17	46	SAI		1	TSH	+1.04	TSHTSH	0.2		L2157	reso	21H00129	H	1	600PP	345281
			51.90	187	DNT	P	1	09H	+0.00	TECTEH			M9715	seco	21H00034	H	0	600UL	331933
					NDF			09H	+0.00	09H09H			D4576	seco	21H00167	H	6	600PP	345325
1927			3.54	182	DNG	P	1	09C	+1.93	TECTEH			M9715	seco	21H00034	H	0	600UL	331933
1928	100	72	4.35	185	DNT	P	1	09H	-0.09	TECTEH			M9715	seco	21H00034	H	0	600UL	331933
1929	102	72	2.37	178	DNG	P	1	09H	+9.19	TECTEH			M2655	seco	21H00033	H	0	600UL	332253
1930	104	72			NDF			09H	-0.11	09H09H			W4892	prim	21H00166	H	6	600PP	345337
1931			20.26	186	DNT	P	1	09H	-0.11	TECTEH			M9715	seco	21H00034	H	0	600UL	331933
1932	116	72	0.50	85	MBM		5	02C	+32.22	TECTEH			M7006	reso	21H00034	H	0	600UL	331933
1933	118	72	0.70	82	MBM		5	03C	+35.77	TECTEH			C5542	reso	21H00033	H	0	600UL	332253
1934	122	72	0.92	65	MBM		6	08H	+5.55	TECTEH			C5542	reso	21H00033	H	0	600UL	332253
1935	124	72	2.94	182	DNG	P	1	10C	+7.08	TECTEH			M9715	seco	21H00034	H	0	600UL	331933
1936	128	72	0.88	148	DSI	P	1	10H	-0.07	TECTEH			D9424	prim	21H00034	H	0	600UL	331933
1937					NDF			10H	-0.07	10H10H			D4576	seco	21H00167	H	3	600PP	345325
1938	130	72	0.34	81	DSI	P	1	10H	-0.02	TECTEH			M2655	seco	21H00033	H	0	600UL	332253
1939					NDF			10H	-0.02	10H10H			D4576	seco	21H00167	H	3	600PP	345325
1940	132	72	0.15	74	PLP		9	TSH	+1.31	TSHTSH			H2949	seco	21H00171	H	1	600PP	345336
1941	134	72	6.98	75	PLP		9	TSH	+0.72	TSHTSH			B6768	prim	21H00171	H	1	600PP	345336
1942	136	72	1.04	9	IDM		2	TSH	+3.81	TSHTSH			F3453	reso	21H00171	H	1	600PP	345336
1943			5.65	186	DNG	P	1	01H	+33.72	TEHTEC			M9715	seco	21C00060	H	0	600CS	341613
1944			2.68	185	DNT	P	1	02H	-0.24	TEHTEC			M9715	seco	21C00060	H	0	600CS	341613
1945	138	72	0.74	75	MBM		5	03H	+11.15	TEHTEC			A9608	reso	21C00060	H	0	600CS	341613
1946	41	73	7.44	180	DNG	P	1	03C	+32.92	TECTEH			F1726	seco	21H00063	H	0	600UL	340882
1947	45	73	18.06	182	DNG	P	1	DH	+6.86	TECTEH			F1726	seco	21H00063	H	0	600UL	340882
1948	49	73	1.93	185	INR	P	1	05C	-1.78	TECTEH			F1726	seco	21H00063	H	0	600UL	340882
1949	53	73	0.92	56	MBM		6	01H	+15.14	TECTEH			M7006	reso	21H00063	H	0	600UL	340882
			2.22	183	DNG	P	1	03C	+3.87	TECTEH			F1726	seco	21H00063	H	0	600UL	340882
			2.81	182	DNG	P	1	02C	+14.91	TECTEH			F1726	seco	21H00063	H	0	600UL	340882
1952	59	73			TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
1953			0.00	0	SAI		1	TSH	+0.70	TSHTSH	0.0		A9608	reso	21H00139	H	1	600PP	345281
1954			0.12	125	PID		4	TSH	+0.70	TSHTSH	080		M1680	reso	21H00174	H999		600PP	345337
1955			0.12	119	SAI		2	TSH	+0.70	TSHTSH	0.2		A9608	reso	21H00139	H	1	600PP	345281

1956	71	73	0.48	73	MBM	5	04H	+3.81	TECTEH			M7006	reso	21H00063	H 0	600UL	340882
1957	77	73	0.81	86	MBM	6	02C	+32.26	TECTEH			M7006	reso	21H00064	H 0	600UL	331933
1958	87	73	3.43	183	DNG	P 1	08C	+19.00	TECTEH			O8795	seco	21H00064	H 0	600UL	331933
	103	73			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
			0.15	120	PID	4	TSH	+0.55	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 41

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
1961			0.0	0	SAI	1	TSH	+0.55	TSHTSH	0.0		L2157	reso	21H00128	H 1	600PP	345337
1962			0.12	112	SAI	2	TSH	+0.55	TSHTSH	0.2		L2157	reso	21H00128	H 1	600PP	345337
1963	107	73	7.35	183	DNT	P 1	09H	-0.04	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1964					NDF		09H	-0.04	09H09H			D4576	seco	21H00167	H 6	600PP	345325
1965	109	73	2.82	185	DNT	P 1	09H	+0.00	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1966			4.15	180	DNG	P 1	VC	+12.26	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1967	111	73	1.16	85	MBM	5	05H	+30.15	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
1968	113	73	3.69	183	DNG	P 1	09C	+19.24	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1969	115	73	3.36	175	DNG	P 1	09C	+19.99	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1970	121	73	0.43	7	IDM	2	TSH	+2.35	TSHTSH			W4892	prim	21H00128	H 1	600PP	345337
			0.43	8	IDM	2	TSH	+4.59	TSHTSH			W4892	prim	21H00128	H 1	600PP	345337
	36	74			TBP				TSHTSH	RMVTBS	ADDTBP	D3858	reso	21H00115	H 1	600PP	326403
1973			0.0	0	SAI	1	TSH	+1.08	TSHTSH	0.0		L2157	reso	21H00138	H 1	600PP	345337
1974			0.12	86	SAI	2	TSH	+1.08	TSHTSH	0.2		L2157	reso	21H00138	H 1	600PP	345337
1975			0.09	82	PID	4	TSH	+1.08	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
1976			0.08	84	PRC	2	TSH	+1.08	TSHTSH			L2157	reso	21H00155	H 1	600PP	345337
1977	48	74	1.19	80	MBM	6	03C	+33.84	TECTEH			M7006	reso	21H00061	H 0	600UL	340882
1978	52	74	0.44	65	MBM	5	05H	+7.96	TECTEH			M7006	reso	21H00061	H 0	600UL	340882
1979			1.27	58	MBM	6	06H	+15.76	TECTEH			M7006	reso	21H00061	H 0	600UL	340882
1980	62	74	0.70	78	MBM	5	03H	+31.65	TECTEH			M7006	reso	21H00061	H 0	600UL	340882
1981	64	74	1.91	65	MBM	6	01H	+5.13	TECTEH			M7006	reso	21H00061	H 0	600UL	340882
1982	68	74	34.42	185	DNG	P 1	TSH	+6.77	TECTEH			A6997	seco	21H00062	H 0	600UL	331933
1983	74	74	4.28	179	DNG	P 1	07H	+10.02	TECTEH			A6997	seco	21H00061	H 0	600UL	340882
1984	82	74	0.59	81	MBM	6	04C	+12.14	TECTEH			M7006	reso	21H00064	H 0	600UL	331933
1985	84	74			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
1986			0.85	201	PID	3	SBH	+23.95	SBHSTH			D3858	prim	21H00226	H999	500PP	326656
1987					DIS	3	SBH	+23.95	SBHSTH			G9427	prim	21H00223	H10	500PP	326656
1988			0.13	106	PID	4	TSH	+0.82	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
1989			0.00	0	SAI	1	TSH	+0.82	TSHTSH	0.0		A9608	reso	21H00139	H 1	600PP	345281
1990			0.12	89	SAI	2	TSH	+0.82	TSHTSH	0.2		A9608	reso	21H00139	H 1	600PP	345281
1991	86	74	3.53	179	DNG	P 1	07H	+22.20	TECTEH			F1726	seco	21H00063	H 0	600UL	340882
1992	92	74	4.47	174	DNT	P 1	09H	+0.09	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
1993	94	74	0.85	75	MBM	5	TSC	+27.89	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
1994	102	74	11.89	184	DNG	P 1	09H	+10.07	TECTEH			M9715	seco	21H00034	H 0	600UL	331933
1995	108	74	2.84	171	DNT	P 1	09H	-0.02	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
			2.23	172	DNG	P 1	VH	+4.10	TECTEH			M2655	seco	21H00033	H 0	600UL	332253
			2.11	173	DNG	P 1	03C	-2.08	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
1998	112	74	3.88	175	DNG	P 1	09C	+16.90	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
1999			2.81	178	DNG	P 1	09C	+17.49	TECTEH			C5542	reso	21H00033	H 0	600UL	332253
2000	118	74	0.50	7	IDM	2	TSH	+4.37	TSHTSH			W4892	prim	21H00128	H 1	600PP	345337
2001			0.70	74	MBM	5	02H	+11.64	TECTEH			M7006	reso	21H00034	H 0	600UL	331933

2002			0.64	82	MBM	5	02H	+13.46	TECTEH			M7006	reso	21H00034	H	0	600UL	331933
2003			0.41	71	MBM	5	02H	+15.71	TECTEH			M7006	reso	21H00034	H	0	600UL	331933
2004			0.67	41	MBM	5	02H	+19.87	TECTEH			M7006	reso	21H00034	H	0	600UL	331933
[illegible]			0.25	81	MBM	5	02H	+22.91	TECTEH			M7006	reso	21H00034	H	0	600UL	331933
[illegible]			0.57	64	MBM	5	02H	+25.10	TECTEH			M7006	reso	21H00034	H	0	600UL	331933
2007			0.50	81	MBM	5	02H	+26.66	TECTEH			M7006	reso	21H00034	H	0	600UL	331933
2008			1.00	85	MBM	5	02H	+28.04	TECTEH			M7006	reso	21H00034	H	0	600UL	331933
2009			0.52	61	MBM	5	02H	+29.06	TECTEH			M7006	reso	21H00034	H	0	600UL	331933

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 42

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2010			0.48	86	MBM	5	03H	+2.28	TECTEH			M7006	reso	21H00034	H	0 600UL	331933
2011			2.22	181	DNT	P 1	09H	+0.00	TECTEH			M9715	seco	21H00034	H	0 600UL	331933
2012	120	74	0.54	57	MBM	5	04H	+34.16	TECTEH			C5542	reso	21H00033	H	0 600UL	332253
2013	128	74	7.61	174	DNG	P 1	07C	+3.33	TECTEH			M2655	seco	21H00033	H	0 600UL	332253
2014	130	74	4.15	176	DNG	P 1	10C	+12.16	TECTEH			M2655	seco	21H00033	H	0 600UL	332253
2015	138	74	0.53	86	MBM	5	06H	+22.07	TEHTEC			A9608	reso	21C00060	H	0 600CS	341613
2016	35	75	12.62	181	DNT	P 1	VM	-1.97	TECTEH			A6997	seco	21H00062	H	0 600UL	331933
	37	75			TBP				TSHTSH	RMVTBS	ADDTBP	D3858	reso	21H00115	H	1 600PP	326403
			0.11	81	SAI	2	TSH	+1.06	TSHTSH	0.2		A9608	reso	21H00138	H	1 600PP	345337
2019			0.00	50	SAI	1	TSH	+1.06	TSHTSH	0.0		A9608	reso	21H00138	H	1 600PP	345337
2020			0.07	82	PRC	2	TSH	+1.06	TSHTSH			L2157	reso	21H00155	H	1 600PP	345337
2021			0.07	97	PID	4	TSH	+1.06	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
2022			4.17	186	DNG	P 1	04C	+22.58	TECTEH			A6997	seco	21H00061	H	0 600UL	340882
2023	49	75	2.21	182	DNT	P 1	VM	-1.77	TECTEH			A6997	seco	21H00062	H	0 600UL	331933
2024	51	75	2.78	177	DNG	P 1	02H	+6.81	TECTEH			A6997	seco	21H00061	H	0 600UL	340882
2025	53	75	2.56	183	DNG	P 1	04C	+25.81	TECTEH			A6997	seco	21H00062	H	0 600UL	331933
2026			2.63	190	DNG	P 1	04C	+26.11	TECTEH			F6623	reso	21H00062	H	0 600UL	331933
2027			2.32	183	DNG	P 1	04C	+26.84	TECTEH			A6997	seco	21H00062	H	0 600UL	331933
2028	71	75	3.01	185	DNG	P 1	TSH	+6.88	TECTEH			A6997	seco	21H00062	H	0 600UL	331933
2029			4.58	184	DNG	P 1	08C	+4.42	TECTEH			A6997	seco	21H00062	H	0 600UL	331933
2030	75	75			NDF		TSH	+0.90	TSHTSH			C3340	reso	21H00139	H	1 600PP	345281
2031			0.52	124	NQI	P 1	TSH	+0.90	TECTEH			A6997	seco	21H00062	H	0 600UL	331933
2032	81	75	2.54	181	DNG	P 1	08C	+13.71	TECTEH			A6997	seco	21H00061	H	0 600UL	340882
2033	83	75	6.32	184	DNG	P 1	05C	+14.14	TECTEH			A6997	seco	21H00062	H	0 600UL	331933
2034	89	75	0.38	81	MBM	5	02H	+23.29	TECTEH			M7006	reso	21H00061	H	0 600UL	340882
2035	101	75	2.12	181	DNG	P 1	01H	+30.33	TECTEH			M9715	seco	21H00034	H	0 600UL	331933
2036	107	75			TBS				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
2037			0.17	110	SAI	1	TSH	+0.48	TSHTSH	0.3		L2157	reso	21H00128	H	1 600PP	345337
2038			0.09	114	SAI	2	TSH	+0.48	TSHTSH	0.3		L2157	reso	21H00128	H	1 600PP	345337
2039			0.16	86	SAI	1	TSH	+0.67	TSHTSH	0.1		L2157	reso	21H00128	H	1 600PP	345337
2040			0.16	78	SAI	2	TSH	+0.67	TSHTSH	0.2		L2157	reso	21H00128	H	1 600PP	345337
2041			0.17	71	PID	4	TSH	+0.84	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
[illegible]			0.17	69	SAI	2	TSH	+0.84	TSHTSH	0.2		L2157	reso	21H00128	H	1 600PP	345337
			0.16	98	SAI	1	TSH	+0.84	TSHTSH	0.1		L2157	reso	21H00128	H	1 600PP	345337
2044			1.93	176	INR	P 1	02H	+6.28	TECTEH			C5542	reso	21H00033	H	0 600UL	332253
2045	113	75	4.20	183	DNG	P 1	01C	+35.40	TECTEH			M9715	seco	21H00034	H	0 600UL	331933
2046	115	75	8.03	175	DNG	P 1	09C	+20.62	TECTEH			M2655	seco	21H00033	H	0 600UL	332253
2047	117	75	5.06	180	DNT	P 1	10C	+0.51	TECTEH			M9715	seco	21H00034	H	0 600UL	331933

2048	125	75	8.56	184	DNG	P 1	01C	+12.44	TECTEH				M9715	seco	21H00034	H 0	600UL	331933
2049	129	75	2.38	181	DNT	P 1	10C	+0.31	TECTEH				M9715	seco	21H00030	H 0	600UL	331933
2050	131	75	0.41	78	MBM	5	01H	+26.67	TECTEH				M7006	reso	21H00029	H 0	600UL	332253
	133	75	1.74	80	MBM	6	05H	+6.95	TECTEH				M7006	reso	21H00068	H 0	600UL	331933
	40	76	2.59	182	DNT	P 1	VM	+1.18	TECTEH				A6997	seco	21H00061	H 0	600UL	340882
2053	46	76			INF		07C	+8.80	TECTEH	HR			N5432	reso	21H00061	H 0	600UL	340882
2054	52	76	7.22	4	INR	P 1	VM	+17.91	TECTEH				A6997	seco	21H00062	H 0	600UL	331933
2055	66	76			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
2056			0.14	112	SAI	2	TSH	+1.72	TSHTSH	0.3			L2157	reso	21H00138	H 1	600PP	345337
2057			0.16	119	SAI	1	TSH	+1.72	TSHTSH	0.3			L2157	reso	21H00138	H 1	600PP	345337
2058			0.15	118	PID	4	TSH	+1.72	TSHTSH	080			M1680	reso	21H00174	H999	600PP	345337

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 43

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2059	76	76	0.43	81	MBM	5	03H	+21.79	TECTEH			M7006	reso	21H00061	H 0	600UL	340882
2060	94	76	0.57	96	MBM	5	04H	+22.71	TECTEH			M7006	reso	21H00029	H 0	600UL	332253
2061	98	76			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
2062			0.66	181	PID	3	SBH	+23.14	SBHSTH			D3858	prim	21H00226	H999	500PP	326656
					DIS	3	SBH	+23.14	SBHSTH			P6179	seco	21H00224	H10	500PP	326656
[illegible]			0.0	0	SAI	1	TSH	+0.63	TSHTSH	0.0		L2157	reso	21H00129	H 1	600PP	345281
2065			0.12	123	SAI	2	TSH	+0.63	TSHTSH	0.3		L2157	reso	21H00129	H 1	600PP	345281
2066			0.18	104	PID	4	TSH	+0.63	TSHTSH	080		D8661	reso	21H00150	H999	600PP	345337
2067	112	76	5.97	185	DNG	P 1	09C	+18.05	TECTEH			L2157	reso	21H00030	H 0	600UL	331933
2068	130	76	0.57	69	MBM	5	05C	+18.23	TECTEH			M7006	reso	21H00029	H 0	600UL	332253
2069	140	76	3.39	223	NRH	2	TSH	+0.00	TEHTEC			A9608	reso	21C00060	H 0	600CS	341613
2070			0.49	72	MBM	5	01H	+8.16	TEHTEC			A9608	reso	21C00060	H 0	600CS	341613
2071			0.65	77	MBM	5	09H	+6.46	TEHTEC			A9608	reso	21C00060	H 0	600CS	341613
2072	39	77	0.25	61	INR	P 1	02H	-0.21	TECTEH			M7006	reso	21H00061	H 0	600UL	340882
2073			2.31	178	DNG	P 1	03C	+34.31	TECTEH			A6997	seco	21H00061	H 0	600UL	340882
2074	41	77	0.82	56	MBM	5	07H	+6.43	TECTEH			F6623	reso	21H00062	H 0	600UL	331933
2075	53	77	1.89	178	INR	P 1	07C	+15.27	TECTEH			A6997	seco	21H00061	H 0	600UL	340882
2076	55	77	2.31	184	DNG	P 1	TSH	+35.05	TECTEH			A6997	seco	21H00062	H 0	600UL	331933
2077	57	77			INF		DH	+15.55	TECTEH	HR		M7006	reso	21H00061	H 0	600UL	340882
2078			2.21	180	DNG	P 1	DH	+17.65	TECTEH			N5432	reso	21H00061	H 0	600UL	340882
2079	61	77	4.62	183	DNG	P 1	04C	+16.22	TECTEH			A6997	seco	21H00061	H 0	600UL	340882
2080	71	77	1.32	90	MBM	5	03C	+24.15	TECTEH			F6623	reso	21H00062	H 0	600UL	331933
2081	89	77	2.40	178	DNG	P 1	01H	+8.16	TECTEH			A6997	seco	21H00061	H 0	600UL	340882
2082	95	77	1.87	178	INR	P 1	TSC	+22.30	TECTEH			M7006	reso	21H00029	H 0	600UL	332253
2083	99	77	0.67	81	MBM	5	VC	+7.05	TECTEH			M7006	reso	21H00029	H 0	600UL	332253
2084					INF		VC	+8.21	TECTEH	HR		M7006	reso	21H00029	H 0	600UL	332253
2085	101	77	2.36	181	DNG	P 1	01C	+9.02	TECTEH			M9715	seco	21H00030	H 0	600UL	331933
2086	103	77	0.64	75	MBM	5	01H	+11.23	TECTEH			M7006	reso	21H00029	H 0	600UL	332253
2087	105	77	4.98	179	DNG	P 1	09C	+11.91	TECTEH			M9715	seco	21H00030	H 0	600UL	331933
	109	77	3.46	181	DNG	P 1	VC	+12.32	TECTEH			L2157	reso	21H00030	H 0	600UL	331933
	115	77	7.50	180	DNG	P 1	09C	+20.61	TECTEH			N2574	seco	21H00029	H 0	600UL	332253
2090	117	77	0.73	82	MBM	5	07H	+13.25	TECTEH			L2157	reso	21H00030	H 0	600UL	331933
2091	119	77	4.75	180	DNG	P 1	10C	+2.14	TECTEH			N2574	seco	21H00029	H 0	600UL	332253
2092			6.99	183	DNG	P 1	06C	+15.57	TECTEH			N2574	seco	21H00029	H 0	600UL	332253
2093	121	77	5.49	178	DNT	P 1	09H	+0.18	TECTEH			M9715	seco	21H00030	H 0	600UL	331933

2094	129	77	0.49	69	MBM	5	04H	+21.49	TECTEH			L2157	reso	21H00030	H	0	600UL	331933
2095	131	77	0.70	65	MBM	6	09H	+12.60	TECTEH			M7006	reso	21H00029	H	0	600UL	332253
2096			0.51	90	MBM	6	09H	+13.74	TECTEH			M7006	reso	21H00029	H	0	600UL	332253
	133	77	5.88	179	DNG	P 1	10C	+14.84	TECTEH			F1726	seco	21H00068	H	0	600UL	331933
	135	77	0.48	83	MBM	5	05H	+11.36	TEHTEC			C5542	reso	21C00059	H	0	600CS	341612
2099	36	78	3.69	192	DNG	P 1	DH	+13.14	TECTEH			F6623	reso	21H00062	H	0	600UL	331933
2100	38	78			TBS				TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
2101			0.00	0	SAI	1	TSH	+0.97	TSHTSH	0.0		A9608	reso	21H00138	H	1	600PP	345337
2102			0.14	86	SAI	2	TSH	+0.97	TSHTSH	0.2		A9608	reso	21H00138	H	1	600PP	345337
2103			0.11	53	PID	4	TSH	+0.97	TSHTSH	080		M1680	reso	21H00174	H999		600PP	345337
2104			2.12	179	DNT	P 1	VM	+1.77	TECTEH			A6997	seco	21H00061	H	0	600UL	340882
2105	40	78	2.79	193	INR	P 1	05H	+4.42	TECTEH			A6997	seco	21H00062	H	0	600UL	331933
2106	54	78	3.49	176	DNG	P 1	07H	+4.48	TECTEH			A6997	seco	21H00061	H	0	600UL	340882
2107	62	78			TBS				TSHTSH			D3858	reso	21H00115	H	1	600PP	326403

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 44

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2108			0.15	104	SCI	P 1	TSH	+0.09	TSHTSH	0.4		L2157	reso	21H00138	H	1 600PP	345337
			0.12	66	PID	P 1	TSH	+0.09	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
2110			0.24	81	SCI	1	TSH	+0.09	TSHTSH	0.4		L2157	reso	21H00138	H	1 600PP	345337
2111			0.15	105	SAI	2	TSH	+0.39	TSHTSH	0.4		L2157	reso	21H00138	H	1 600PP	345337
2112			0.19	63	SAI	1	TSH	+0.39	TSHTSH	0.3		L2157	reso	21H00138	H	1 600PP	345337
2113			0.13	92	SAI	2	TSH	+0.68	TSHTSH	0.3		L2157	reso	21H00138	H	1 600PP	345337
2114			0.25	72	SAI	1	TSH	+0.68	TSHTSH	0.2		L2157	reso	21H00138	H	1 600PP	345337
2115	70	78	4.85	359	INR	P 1	07C	+12.47	TECTEH			A6997	seco	21H00061	H	0 600UL	340882
2116	82	78	1.28	82	MBM	6	TSH	+2.36	TECTEH			F6623	reso	21H00062	H	0 600UL	331933
2117	86	78	0.47	75	MBM	5	01C	+33.77	TECTEH			N5432	reso	21H00061	H	0 600UL	340882
2118	90	78	2.57	180	DNG	P 1	08C	+22.04	TECTEH			A6997	seco	21H00061	H	0 600UL	340882
2119	92	78	3.84	178	DNT	P 1	09H	-0.07	TECTEH			M9715	seco	21H00030	H	0 600UL	331933
2120			3.24	176	DNT	P 1	09C	+0.24	TECTEH			M9715	seco	21H00030	H	0 600UL	331933
2121	94	78	0.16	79	PLP	9	TSC	+0.58	TSCTSC			D9424	prim	21C00030	C	2 600PP	345282
2122	96	78	2.18	177	DNG	P 1	02C	+31.74	TECTEH			N2574	seco	21H00029	H	0 600UL	332253
2123	104	78	1.27	76	MBM	6	05H	+26.81	TECTEH			L2157	reso	21H00030	H	0 600UL	331933
2124	112	78	2.13	177	DNG	P 1	03H	+10.86	TECTEH			N2574	seco	21H00029	H	0 600UL	332253
2125	116	78	2.64	178	DNG	P 1	02C	+16.80	TECTEH			M9715	seco	21H00030	H	0 600UL	331933
2126	118	78	0.53	65	MBM	6	08H	+7.08	TECTEH			M7006	reso	21H00029	H	0 600UL	332253
2127	122	78	1.18	78	MBM	5	07H	+10.52	TECTEH			M7006	reso	21H00029	H	0 600UL	332253
2128			0.91	84	MBM	5	09H	+8.31	TECTEH			M7006	reso	21H00029	H	0 600UL	332253
2129			1.33	110	DSI	P 1	10H	+0.04	TECTEH			J5670	prim	21H00029	H	0 600UL	332253
2130					NDF		10H	+0.04	10H10H			D4576	seco	21H00167	H	3 600PP	345325
2131			1.10	70	MBM	6	VC	+18.21	TECTEH			M7006	reso	21H00029	H	0 600UL	332253
2132					INF		VC	+19.60	TECTEH	HR		M7006	reso	21H00029	H	0 600UL	332253
2133	130	78	4.23	181	DNT	P 1	09H	+0.00	TECTEH			N2574	seco	21H00029	H	0 600UL	332253
	136	78	6.67	72	PLP	9	TSH	+0.27	TSHTSH			B6768	prim	21H00168	H	1 600PP	345335
	41	79			TBS				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
2136			0.0	0	SAI	1	TSH	+0.50	TSHTSH	0.0		L2157	reso	21H00139	H	1 600PP	345281
2137			0.17	83	SAI	2	TSH	+0.50	TSHTSH	0.2		L2157	reso	21H00139	H	1 600PP	345281
2138			0.19	83	PID	4	TSH	+0.50	TSHTSH	080		F6623	reso	21H00180	H999	600PP	345339
2139	43	79			INF		DH	+7.75	TECTEH	HR		A9608	reso	21H00061	H	0 600UL	340882

2140				6.89	184	INR	P	1	DH	+8.98	TECTEH			N5432	reso	21H00061	H	0	600UL	340882
2141				0.38	355	INR	P	1	DH	+16.44	TECTEH			N5432	reso	21H00061	H	0	600UL	340882
2142	45	79		2.16	187	DNG	P	1	TSH	+6.13	TECTEH			A6997	seco	21H00062	H	0	600UL	331933
	63	79				TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
				0.12	90	SAI		2	TSH	+0.61	TSHTSH	0.4		L2157	reso	21H00138	H	1	600PP	345337
[illegible]				0.14	113	PID		4	TSH	+0.61	TSHTSH	080		M1680	reso	21H00174	H999		600PP	345337
2146				0.16	62	SAI		1	TSH	+0.61	TSHTSH	0.4		L2157	reso	21H00138	H	1	600PP	345337
2147	65	79				TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
2148				0.22	101	PID		4	TSH	+0.56	TSHTSH	080		M1680	reso	21H00174	H999		600PP	345337
2149				0.20	70	SAI		1	TSH	+0.56	TSHTSH	0.3		L2157	reso	21H00139	H	1	600PP	345281
2150				0.20	102	SAI		2	TSH	+0.56	TSHTSH	0.3		L2157	reso	21H00139	H	1	600PP	345281
2151	67	79		1.22	61	MBM		6	04H	+31.85	TECTEH			N5432	reso	21H00061	H	0	600UL	340882
2152	75	79		0.34	72	MBM		5	06H	+5.08	TECTEH			N5432	reso	21H00061	H	0	600UL	340882
2153	79	79		0.69	88	MBM		5	03H	+30.12	TECTEH			N5432	reso	21H00061	H	0	600UL	340882
2154	81	79		0.36	53	INR	P	1	TSH	+0.89	TECTEH			S4373	reso	21H00062	H	0	600UL	331933
2155	91	79		0.61	85	MBM		6	05C	+33.77	TECTEH			M7006	reso	21H00029	H	0	600UL	332253
2156	95	79		0.19	86	PLP		9	TSC	+0.55	TSCTSC			D9424	prim	21C00030	C	2	600PP	345282

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2157			1.72	179	INR	P	1	TSC +23.26	TECTEH			N2574	seco	21H00029	H	0 600UL	332253
2158	101	79	2.31	180	DNT	P	1	DC -0.22	TECTEH			M9715	seco	21H00030	H	0 600UL	331933
2159	105	79	2.85	176	DNG	P	1	TSC +7.37	TECTEH			M9715	seco	21H00030	H	0 600UL	331933
2160	111	79	4.11	183	DNG	P	1	VH +3.10	TECTEH			N2574	seco	21H00029	H	0 600UL	332253
2161			5.73	180	DNG	P	1	09C +17.16	TECTEH			N2574	seco	21H00029	H	0 600UL	332253
2162	115	79	2.82	88	MBM		6	03H +36.26	TECTEH			M7006	reso	21H00029	H	0 600UL	332253
2163	117	79	3.58	182	DNT	P	1	10C +0.53	TECTEH			M9715	seco	21H00030	H	0 600UL	331933
2164	127	79	2.99	182	DNG	P	1	10C +9.52	TECTEH			N2574	seco	21H00029	H	0 600UL	332253
2165	129	79	5.34	182	DNT	P	1	10H -0.13	TECTEH			M9715	seco	21H00030	H	0 600UL	331933
2166			3.26	179	DNG	P	1	VH +28.51	TECTEH			M9715	seco	21H00030	H	0 600UL	331933
2167	131	79	2.66	180	DNG	P	1	10C +13.10	TECTEH			N2574	seco	21H00029	H	0 600UL	332253
2168	133	79	8.14	180	DNG	P	1	10C +14.85	TECTEH			F1726	seco	21H00068	H	0 600UL	331933
2169	135	79	4.37	186	DNG	P	1	VH +18.62	TEHTEC			N2574	seco	21C00059	H	0 600CS	341612
2170	137	79	6.56	67	PLP		9	TSH +0.28	TSHTSH			B6768	prim	21H00168	H	1 600PP	345335
2171	139	79	2.58	188	DNT	P	1	10C -0.62	TEHTEC			M9715	seco	21C00060	H	0 600CS	341613
2172	36	80	4.83	173	DNT	P	1	VM +1.19	TECTEH			A6997	seco	21H00062	H	0 600UL	331933
2173	42	80	2.84	178	DNG	P	1	TSH +18.07	TECTEH			A6997	seco	21H00061	H	0 600UL	340882
2174	86	80	4.01	178	DNG	P	1	03C +34.73	TECTEH			A6997	seco	21H00061	H	0 600UL	340882
2175	92	80			INF			08H +9.53	TECTEH	HR		L2157	reso	21H00030	H	0 600UL	331933
2176			3.90	184	DNG	P	1	08H +13.55	TECTEH			L2157	reso	21H00030	H	0 600UL	331933
2177			4.13	182	DNT	P	1	09C +0.35	TECTEH			M9715	seco	21H00030	H	0 600UL	331933
2178	110	80	0.48	84	MBM		5	02H +10.14	TECTEH			M7006	reso	21H00029	H	0 600UL	332253
2179	120	80	1.09	75	MBM		5	08H +10.18	TECTEH			M7006	reso	21H00029	H	0 600UL	332253
	122	80	0.36	94	DSI	P	1	10H +0.00	TECTEH			P2952	prim	21H00030	H	0 600UL	331933
					NDF			10H +0.00	10H10H			D4576	seco	21H00167	H	3 600PP	345325
2182			4.01	180	DNG	P	1	10C +4.91	TECTEH			M9715	seco	21H00030	H	0 600UL	331933
2183	128	80	1.53	91	MBM		6	07H +3.18	TECTEH			M7006	reso	21H00029	H	0 600UL	332253
2184			1.41	90	MBM		6	07H +8.97	TECTEH			M7006	reso	21H00029	H	0 600UL	332253
2185			1.16	81	MBM		6	VH +8.89	TECTEH			M7006	reso	21H00029	H	0 600UL	332253

2186	130	80	3.84	175	DNG	P	1	VM	+28.58	TECTEH			N2574	seco	21H00029	H	0	600UL	332253
2187	41	81	17.55	179	DNG	P	1	04C	+14.14	TECTEH			A6997	seco	21H00061	H	0	600UL	340882
2188	43	81	0.35	88	MBM		5	01H	+30.54	TECTEH			F6623	reso	21H00062	H	0	600UL	331933
[illegible]	45	81	2.23	183	DNG	P	1	02C	+5.89	TECTEH			A6997	seco	21H00061	H	0	600UL	340882
			2.56	185	DNG	P	1	02C	+21.69	TECTEH			A6997	seco	21H00061	H	0	600UL	340882
2191			2.95	183	DNG	P	1	02C	+22.87	TECTEH			A6997	seco	21H00061	H	0	600UL	340882
2192			2.87	182	DNG	P	1	02C	+31.69	TECTEH			A6997	seco	21H00061	H	0	600UL	340882
2193			2.14	182	DNG	P	1	02C	+34.59	TECTEH			A6997	seco	21H00061	H	0	600UL	340882
2194	53	81	2.90	184	DNG	P	1	04C	+4.94	TECTEH			A6997	seco	21H00061	H	0	600UL	340882
2195			2.63	181	DNG	P	1	04C	+10.86	TECTEH			A6997	seco	21H00061	H	0	600UL	340882
2196	57	81	0.58	109	INR		5	TSH	+7.10	TECTEH			M7006	reso	21H00061	H	0	600UL	340882
2197			0.50	82	MBM		5	TSC	+15.24	TECTEH			N5432	reso	21H00061	H	0	600UL	340882
2198	69	81	0.52	61	MBM		5	TSC	+5.80	TECTEH			N5432	reso	21H00061	H	0	600UL	340882
2199	81	81	6.77	181	DNG	P	1	08H	+4.93	TECTEH			A6997	seco	21H00061	H	0	600UL	340882
2200	85	81	0.58	72	MBM		5	TSH	+14.58	TECTEH			N5432	reso	21H00061	H	0	600UL	340882
2201	99	81	0.99	87	MBM		5	07H	+16.50	TECTEH			M7006	reso	21H00029	H	0	600UL	332253
2202	101	81	2.87	183	DNT	P	1	DC	-0.33	TECTEH			M9715	seco	21H00030	H	0	600UL	331933
2203	109	81	1.80	183	INR	P	1	09C	+0.22	TECTEH			L2157	reso	21H00030	H	0	600UL	331933
2204	113	81	0.91	91	MBM		6	TSH	+30.91	TECTEH			L2157	reso	21H00030	H	0	600UL	331933
2205	115	81	8.55	179	DNG	P	1	09C	+20.74	TECTEH			N2574	seco	21H00029	H	0	600UL	332253

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 46

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2206	117	81	3.88	182	DNT	P	1	10C	+0.55	TECTEH			M9715	seco	21H00030	H 0 600UL	331933
2207	119	81	3.87	181	DNT	P	1	10C	+0.56	TECTEH			N2574	seco	21H00029	H 0 600UL	332253
2208	123	81	1.53	130	DSI	P	1	10H	+0.06	TECTEH			J5670	prim	21H00029	H 0 600UL	332253
2209					NDF			10H	+0.06	10H10H			W4892	prim	21H00166	H 3 600PP	345337
2210	127	81			NDF			VM	+0.76	VM VM			K2032	seco	21H00182	H 4 5602C	326184
2211			0.61	86	NQI		5	VM	+0.76	TECTEH			N2574	seco	21H00029	H 0 600UL	332253
2212			4.74	183	DNG	P	1	10C	+9.34	TECTEH			N2574	seco	21H00029	H 0 600UL	332253
2213	129	81	2.20	177	DNT	P	1	10H	-0.31	TECTEH			M9715	seco	21H00030	H 0 600UL	331933
2214			2.99	182	DNT	P	1	10H	+0.24	TECTEH			M9715	seco	21H00030	H 0 600UL	331933
2215	137	81	6.95	251	PLP		9	TSH	+0.44	TSHTSH			B6768	prim	21H00168	H 1 600PP	345335
2216			2.81	188	DNG	P	1	07H	+23.50	TEHTEC			N2574	seco	21C00059	H 0 600CS	341612
2217	139	81	6.58	70	PLP		9	TSH	+0.31	TSHTSH			B6768	prim	21H00168	H 1 600PP	345335
2218			0.25	90	14	P	2	07H	+0.90	TEHTEC			K6388	prim	21C00060	H 0 600CS	341613
2219			0.38	122	WAR		2	DH	+1.80	DH VH			A9608	reso	21H00191	H 4 5602C	326187
2220			0.57	146	26	P	2	DH	+1.80	TEHTEC			A9608	reso	21C00060	H 0 600CS	341613
2221	40	82	3.10	185	DNT	P	1	VM	+1.12	TECTEH			F4645	seco	21H00057	H 0 600UL	340882
2222	50	82	0.70	95	MBM		5	TSH	+14.87	TECTEH			F6623	reso	21H00058	H 0 600UL	331933
2223			0.55	82	MBM		5	01H	+18.40	TECTEH			F6623	reso	21H00058	H 0 600UL	331933
2224	62	82			TBS					TSHTSH			D3858	reso	21H00115	H 1 600PP	326403
2225			0.09	86	PID		4	TSH	+0.72	TSHTSH	080		M1680	reso	21H00174	H999 600PP	345337
[illegible]			0.24	38	SAI		1	TSH	+0.72	TSHTSH	0.4		L2157	reso	21H00139	H 1 600PP	345281
			0.09	103	SAI		2	TSH	+0.72	TSHTSH	0.4		L2157	reso	21H00139	H 1 600PP	345281
2228	76	82	4.52	182	DNG	P	1	07H	+21.65	TECTEH			F4645	seco	21H00057	H 0 600UL	340882
2229			5.48	184	DNG	P	1	08H	+1.30	TECTEH			F4645	seco	21H00057	H 0 600UL	340882
2230	82	82	1.14	95	MBM		6	04C	+9.17	TECTEH			F6623	reso	21H00058	H 0 600UL	331933
2231	84	82			TBS					TSHTSH			D3858	reso	21H00115	H 1 600PP	326403

2232				0.00	75	SAI	1	TSH	+0.76	TSHTSH	0.0			A9608	reso	21H00138	H 1	600PP	345337
2233				0.13	73	SAI	2	TSH	+0.76	TSHTSH	0.2			A9608	reso	21H00138	H 1	600PP	345337
2234				0.12	90	PID	4	TSH	+0.76	TSHTSH	080			M1680	reso	21H00174	H999	600PP	345337
	92	82		2.23	183	DNT	P 1	09H	+0.04	TECTEH				M9715	seco	21H00030	H 0	600UL	331933
				2.81	178	DNT	P 1	VH	+2.01	TECTEH				M9715	seco	21H00030	H 0	600UL	331933
2237	96	82		2.95	178	DNG	P 1	09C	+3.79	TECTEH				M9715	seco	21H00030	H 0	600UL	331933
2238	108	82		10.15	181	DNT	P 1	09H	+0.00	TECTEH				M9715	seco	21H00030	H 0	600UL	331933
2239						NDF		09H	+0.00	09H09H				M7006	reso	21H00167	H 6	600PP	345325
2240				0.69	77	MBM	5	03C	+8.26	TECTEH				L2157	reso	21H00030	H 0	600UL	331933
2241	110	82		2.74	180	DNG	P 1	04C	+13.64	TECTEH				N2574	seco	21H00029	H 0	600UL	332253
2242	112	82		2.31	179	DNG	P 1	DH	+19.71	TECTEH				M9715	seco	21H00030	H 0	600UL	331933
2243				2.59	182	DNG	P 1	03C	+25.48	TECTEH				M9715	seco	21H00030	H 0	600UL	331933
2244				2.12	184	DNG	P 1	02C	+7.28	TECTEH				M9715	seco	21H00030	H 0	600UL	331933
2245				2.16	185	DNG	P 1	02C	+8.37	TECTEH				M9715	seco	21H00030	H 0	600UL	331933
2246				2.52	182	DNG	P 1	02C	+24.44	TECTEH				M9715	seco	21H00030	H 0	600UL	331933
2247	116	82		2.71	182	DNT	P 1	09H	+0.00	TECTEH				M9715	seco	21H00030	H 0	600UL	331933
2248	118	82		2.04	183	INR	P 1	10H	+0.81	TECTEH				M7006	reso	21H00029	H 0	600UL	332253
2249				3.30	180	DNG	P 1	10C	+1.05	TECTEH				N2574	seco	21H00029	H 0	600UL	332253
2250	124	82		3.04	180	DNG	P 1	10C	+7.04	TECTEH				M9715	seco	21H00030	H 0	600UL	331933
2251	130	82		0.63	83	MBM	6	03H	+5.88	TECTEH				M7006	reso	21H00029	H 0	600UL	332253
2252				2.00	91	MBM	5	02C	+33.23	TECTEH				M7006	reso	21H00029	H 0	600UL	332253
2253	132	82		1.86	180	INR	P 1	DH	+9.64	TECTEH				F1726	seco	21H00068	H 0	600UL	331933
2254				4.42	181	DNG	P 1	VM	+15.30	TECTEH				F1726	seco	21H00068	H 0	600UL	331933

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 47

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2255	134	82	8.94	75	PLP	9	TSH +0.52	TSHTSH			B6768	prim	21H00168	H 1	600PP	345335
2256	136	82	9.73	79	PLP	9	TSH +0.14	TSHTSH			B6768	prim	21H00168	H 1	600PP	345335
2257	140	82	2.25	189	INR	P 1	06C +17.84	TEHTEC			M9715	seco	21C00060	H 0	600CS	341613
2258	37	83	2.51	181	DNG	P 1	03H +21.51	TECTEH			A6997	seco	21H00058	H 0	600UL	331933
2259			2.38	182	DNG	P 1	03H +34.35	TECTEH			A6997	seco	21H00058	H 0	600UL	331933
2260			2.88	181	DNG	P 1	03H +35.67	TECTEH			A6997	seco	21H00058	H 0	600UL	331933
2261	39	83	5.05	181	DNT	P 1	VM -1.73	TECTEH			F6623	reso	21H00057	H 0	600UL	340882
2262	41	83			TBS			TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
2263			0.0	0	SAI	1	TSH +0.54	TSHTSH	0.0		L2157	reso	21H00139	H 1	600PP	345281
2264			0.11	107	SAI	2	TSH +0.54	TSHTSH	0.2		L2157	reso	21H00139	H 1	600PP	345281
2265			0.12	112	PID	4	TSH +0.54	TSHTSH	080		F6623	reso	21H00180	H999	600PP	345339
2266	43	83	0.65	73	MBM	5	02H +14.01	TECTEH			F6623	reso	21H00057	H 0	600UL	340882
2267	71	83	1.31	73	MBM	5	07C +15.36	TECTEH			F6623	reso	21H00058	H 0	600UL	331933
2268	73	83	3.42	182	DNG	P 1	07H +14.90	TECTEH			F4645	seco	21H00057	H 0	600UL	340882
2269	81	83	3.07	184	DNG	P 1	08C +13.09	TECTEH			F6623	reso	21H00057	H 0	600UL	340882
2270	83	83	0.42	92	MBM	5	TSH +36.76	TECTEH			F6623	reso	21H00058	H 0	600UL	331933
2271			2.53	187	DNG	P 1	08H +15.23	TECTEH			A6997	seco	21H00058	H 0	600UL	331933
	91	83	1.88	189	INR	P 1	09H +0.29	TECTEH			N2574	seco	21H00029	H 0	600UL	332253
			3.48	177	DNT	P 1	09C -0.59	TECTEH			N2574	seco	21H00029	H 0	600UL	332253
2274	93	83	2.67	185	DNG	P 1	08H +11.25	TECTEH			M9715	seco	21H00030	H 0	600UL	331933
2275			10.02	182	DNG	P 1	08H +12.95	TECTEH			M9715	seco	21H00030	H 0	600UL	331933
2276			3.89	177	DNG	P 1	08H +14.06	TECTEH			M9715	seco	21H00030	H 0	600UL	331933
2277			28.90	181	DNG	P 1	08H +14.79	TECTEH			M9715	seco	21H00030	H 0	600UL	331933

2278				16.20	182	DNG	P	1	08H	+15.42	TECTEH				M9715	seco	21H00030	H	0	600UL	331933
2279				6.77	183	DNT	P	1	09C	+0.49	TECTEH				M9715	seco	21H00030	H	0	600UL	331933
2280				2.87	179	DNG	P	1	08C	-1.82	TECTEH				M9715	seco	21H00030	H	0	600UL	331933
	99	83		0.90	81	MBM		5	07H	+17.87	TECTEH				M7006	reso	21H00029	H	0	600UL	332253
				2.01	181	DNG	P	1	01C	+11.24	TECTEH				N2574	seco	21H00029	H	0	600UL	332253
2283	109	83		3.40	179	DNG	P	1	VC	+12.29	TECTEH				L2157	reso	21H00030	H	0	600UL	331933
2284						INF			VC	+13.62	TECTEH	HR			L2157	reso	21H00030	H	0	600UL	331933
2285	113	83		2.22	174	DNT	P	1	09H	+0.16	TECTEH				M9715	seco	21H00030	H	0	600UL	331933
2286	115	83		5.36	181	DNG	P	1	09C	+20.67	TECTEH				N2574	seco	21H00029	H	0	600UL	332253
2287				2.79	178	DNG	P	1	04C	+21.31	TECTEH				N2574	seco	21H00029	H	0	600UL	332253
2288				2.69	184	DNG	P	1	04C	+22.19	TECTEH				N2574	seco	21H00029	H	0	600UL	332253
2289	117	83		3.47	185	DNT	P	1	10C	+0.50	TECTEH				M9715	seco	21H00030	H	0	600UL	331933
2290	119	83		8.23	180	DNG	P	1	10C	+2.20	TECTEH				N2574	seco	21H00029	H	0	600UL	332253
2291	123	83		1.49	128	DSI	P	1	10H	+0.02	TECTEH				J5670	prim	21H00029	H	0	600UL	332253
2292						NDF			10H	+0.02	10H10H				S8982	seco	21H00166	H	3	600PP	345337
2293				12.43	181	DNG	P	1	10C	+6.78	TECTEH				N2574	seco	21H00029	H	0	600UL	332253
2294	125	83		0.58	119	DSI	P	1	10H	+0.00	TECTEH				P2952	prim	21H00030	H	0	600UL	331933
2295						NDF			10H	+0.00	10H10H				D4576	seco	21H00167	H	3	600PP	345325
2296	127	83		0.70	79	MBM		5	07C	+4.32	TECTEH				M7006	reso	21H00029	H	0	600UL	332253
2297	133	83		5.73	179	DNG	P	1	10C	+14.99	TECTEH				F1726	seco	21H00068	H	0	600UL	331933
2298	40	84		3.36	183	DNT	P	1	VM	+1.41	TECTEH				F4645	seco	21H00057	H	0	600UL	340882
2299	46	84		2.51	183	DNG	P	1	05C	+2.99	TECTEH				F4645	seco	21H00057	H	0	600UL	340882
2300				2.30	189	DNG	P	1	04C	+31.78	TECTEH				F4645	seco	21H00057	H	0	600UL	340882
2301	50	84		0.80	107	MBM		5	TSH	+10.96	TECTEH				F6623	reso	21H00057	H	0	600UL	340882
2302	62	84				TBS					TSHTSH				D3858	reso	21H00115	H	1	600PP	326403
2303				0.09	89	PID		4	TSH	+0.59	TSHTSH	080			F6623	reso	21H00180	H999		600PP	345339

SG 21 -- All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 48

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2304			0.23	59	SAI	1	TSH	+0.59	TSHTSH	0.3		L2157	reso	21H00138	H 1	600PP	345337
2305			0.12	104	SAI	2	TSH	+0.59	TSHTSH	0.6		L2157	reso	21H00138	H 1	600PP	345337
2306	72	84			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
2307			0.0	0	SAI	1	TSH	+2.11	TSHTSH	0.0		L2157	reso	21H00139	H 1	600PP	345281
2308			0.12	120	PID	4	TSH	+2.11	TSHTSH	080		M1680	reso	21H00174	H999	600PP	345337
2309			0.16	106	SAI	2	TSH	+2.11	TSHTSH	0.2		L2157	reso	21H00139	H 1	600PP	345281
2310	74	84	8.12	183	DNG	P 1	07H	+18.74	TECTEH			F4645	seco	21H00057	H 0	600UL	340882
2311			2.46	186	DNT	P 1	03C	+0.93	TECTEH			F6623	reso	21H00057	H 0	600UL	340882
2312	76	84	10.89	180	DNG	P 1	07H	+22.89	TECTEH			F4645	seco	21H00057	H 0	600UL	340882
2313			6.54	183	DNG	P 1	08H	-1.47	TECTEH			F4645	seco	21H00057	H 0	600UL	340882
2314			4.65	184	DNT	P 1	08H	+1.28	TECTEH			F4645	seco	21H00057	H 0	600UL	340882
2315	82	84	0.57	73	MBM	5	TSH	+12.03	TECTEH			F6623	reso	21H00058	H 0	600UL	331933
2316	86	84	2.73	179	DNG	P 1	03H	+14.27	TECTEH			F4645	seco	21H00057	H 0	600UL	340882
2317			2.52	185	DNG	P 1	08H	+2.36	TECTEH			F4645	seco	21H00057	H 0	600UL	340882
	96	84	2.46	178	DNT	P 1	09C	+0.30	TECTEH			N2574	seco	21H00029	H 0	600UL	332253
	98	84	0.19	140	VOL	2	04H	+0.30	04H04H			F6623	reso	21H00178	H 3	600PP	345339
2320			0.59	64	DSI	P 1	04H	+0.33	TECTEH			P2952	prim	21H00030	H 0	600UL	331933
2321			3.61	180	INR	P 1	09C	+7.59	TECTEH			L2157	reso	21H00030	H 0	600UL	331933
2322	102	84	1.44	64	MBM	6	03H	+30.29	TECTEH			L2157	reso	21H00030	H 0	600UL	331933
2323	108	84	3.30	182	DNG	P 1	09H	+14.57	TECTEH			N2574	seco	21H00029	H 0	600UL	332253

2324	110	84	3.32	185	DNG	P	1	DH	+18.94	TECTEH			M9715	seco	21H00030	H	0	600UL	331933
2325			2.79	175	DNT	P	1	VH	+1.59	TECTEH			M9715	seco	21H00030	H	0	600UL	331933
2326	112	84	3.08	179	DNT	P	1	VC	-0.98	TECTEH			N2574	seco	21H00029	H	0	600UL	332253
			7.71	183	DNG	P	1	09C	+17.92	TECTEH			N2574	seco	21H00029	H	0	600UL	332253
	114	84	2.98	179	DNG	P	1	09C	+19.52	TECTEH			M9715	seco	21H00030	H	0	600UL	331933
2329	116	84	2.23	181	DNG	P	1	01H	+32.15	TECTEH			N2574	seco	21H00029	H	0	600UL	332253
2330	118	84	0.53	126	INR	P	1	10H	+0.14	TECTEH			L2157	reso	21H00030	H	0	600UL	331933
2331			2.56	178	DNG	P	1	10C	+0.98	TECTEH			L2157	reso	21H00030	H	0	600UL	331933
2332	124	84	4.84	181	DNG	P	1	VH	+29.34	TECTEH			N2574	seco	21H00029	H	0	600UL	332253
2333			3.91	183	DNG	P	1	10C	+6.71	TECTEH			N2574	seco	21H00029	H	0	600UL	332253
2334	126	84	1.33	84	MBM		6	07H	+14.58	TECTEH			L2157	reso	21H00030	H	0	600UL	331933
2335			4.17	179	DNG	P	1	10C	+8.81	TECTEH			M9715	seco	21H00030	H	0	600UL	331933
2336			2.12	91	MBM		6	02C	+24.94	TECTEH			L2157	reso	21H00030	H	0	600UL	331933
2337	130	84	0.45	90	MBM		6	TSH	+5.36	TECTEH			M7006	reso	21H00029	H	0	600UL	332253
2338			1.78	89	MBM		5	04C	+24.24	TECTEH			M7006	reso	21H00029	H	0	600UL	332253
2339	134	84	4.34	79	PLP		9	TSH	+0.32	TSHTSH			B6768	prim	21H00168	H	1	600PP	345335
2340			0.70	67	MBM		6	10C	+6.08	TECTEH			M7006	reso	21H00068	H	0	600UL	331933
2341			0.68	85	MBM		5	07C	+13.79	TECTEH			M7006	reso	21H00068	H	0	600UL	331933
2342	140	84	3.46	184	DNG	P	1	TSC	+24.14	TEHTEC			M9715	seco	21C00060	H	0	600CS	341613
2343	47	85	2.59	182	DNG	P	1	01C	+35.64	TECTEH			A6997	seco	21H00058	H	0	600UL	331933
2344	49	85	1.89	184	INR	P	1	TSC	+30.47	TECTEH			F4645	seco	21H00057	H	0	600UL	340882
2345	73	85	0.89	100	MBM		5	02H	+17.18	TECTEH			F6623	reso	21H00057	H	0	600UL	340882
2346			3.12	187	DNG	P	1	02C	+17.41	TECTEH			F4645	seco	21H00057	H	0	600UL	340882
2347	89	85	2.02	180	DNG	P	1	TSH	+36.60	TECTEH			F4645	seco	21H00057	H	0	600UL	340882
2348			0.76	89	MBM		5	02C	+28.10	TECTEH			F6623	reso	21H00057	H	0	600UL	340882
2349			0.88	99	MBM		5	01C	+22.27	TECTEH			F6623	reso	21H00057	H	0	600UL	340882
2350			0.82	94	MBM		5	01C	+35.74	TECTEH			F6623	reso	21H00057	H	0	600UL	340882
2351	91	85	12.70	179	DNT	P	1	09C	-0.15	TECTEH			L2157	reso	21H00030	H	0	600UL	331933
2352	93	85	1.33	89	MBM		6	04C	+27.49	TECTEH			M7006	reso	21H00029	H	0	600UL	332253

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 49

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2353			0.73	77	MBM		6	03C	+28.62	TECTEH			M7006	reso	21H00029	H 0	600UL	332253
2354	101	85	1.40	181	INR	P	1	03H	+0.79	TECTEH			M7006	reso	21H00029	H 0	600UL	332253
2355			2.55	182	DNT	P	1	09H	-0.21	TECTEH			N2574	seco	21H00029	H 0	600UL	332253
2356	103	85	0.63	81	MBM		5	02H	+24.21	TECTEH			L2157	reso	21H00030	H 0	600UL	331933
2357	113	85			INF			09C	+16.66	TECTEH	HR		A9608	reso	21H00029	H 0	600UL	332253
2358			4.38	180	DNG	P	1	09C	+19.26	TECTEH			N2574	seco	21H00029	H 0	600UL	332253
2359	115	85	6.06	180	DNG	P	1	09C	+20.87	TECTEH			M9715	seco	21H00030	H 0	600UL	331933
2360	117	85	2.19	182	DNG	P	1	08H	+15.54	TECTEH			N2574	seco	21H00029	H 0	600UL	332253
2361			4.61	182	DNT	P	1	10C	+0.55	TECTEH			N2574	seco	21H00029	H 0	600UL	332253
2362			3.50	181	INR	P	1	10C	+1.19	TECTEH			N2574	seco	21H00029	H 0	600UL	332253
2363			6.49	175	INR	P	1	10C	+2.10	TECTEH			N2574	seco	21H00029	H 0	600UL	332253
	119	85			INF			DC	+10.27	TECTEH	HR		L2157	reso	21H00030	H 0	600UL	331933
			9.05	182	DNG	P	1	10C	+2.19	TECTEH			L2157	reso	21H00030	H 0	600UL	331933
2366	125	85	1.12	89	MBM		5	01C	+35.81	TECTEH			M7006	reso	21H00029	H 0	600UL	332253
2367	40	86	8.83	182	DNT	P	1	VM	+1.43	TECTEH			N2574	seco	21H00035	H 0	600UL	340947
2368	56	86	5.57	181	DNT	P	1	VM	+2.08	TECTEH			N2574	seco	21H00035	H 0	600UL	340947
2369	86	86	7.91	3	INR	P	1	08C	+20.88	TECTEH			C5542	reso	21H00036	H 0	600UL	340881

2370	88	86	1.95	187	INR	P1	TSC	+22.81	TECTEH			S4373	reso	21H00035	H	0	600UL	340947
2371	90	86	3.57	189	DNG	P 1	08C	+7.09	TECTEH			N2574	seco	21H00035	H	0	600UL	340947
2372	106	86	2.58	190	INR	P 1	01C	+33.19	TECTEH			C5542	reso	21H00008	H	0	600UL	332255
	112	86	3.54	183	DNG	P 1	09H	-0.88	TECTEH			D3858	reso	21H00007	H	0	600UL	340910
			4.91	180	DNT	P 1	09H	-0.39	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
[illegible]			5.34	182	DNT	P 1	09H	+0.74	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
2376	132	86	9.59	82	PLP	9	TSH	+0.83	TSHTSH			B6768	prim	21H00168	H	1	600PP	345335
2377	134	86	9.36	83	PLP	9	TSH	+0.78	TSHTSH			B6768	prim	21H00168	H	1	600PP	345335
2378			4.56	184	DNG	P 1	10C	+14.93	TEHTEC			M9715	seco	21C00060	H	0	600CS	341613
2379	37	87	0.72	67	MBM	5	01H	+5.51	TECTEH			C5542	reso	21H00036	H	0	600UL	340881
2380	41	87	30.65	177	DNG	P 1	07C	+8.75	TECTEH			N2574	seco	21H00035	H	0	600UL	340947
2381			26.59	178	DNG	P 1	07C	+9.71	TECTEH			N2574	seco	21H00035	H	0	600UL	340947
2382	45	87	2.01	179	DNT	P 1	VM	-1.94	TECTEH			N2574	seco	21H00035	H	0	600UL	340947
2383	53	87	1.20	86	MBM	5	03C	+30.32	TECTEH			L2157	reso	21H00035	H	0	600UL	340947
2384	63	87	0.43	76	MBM	5	VM	+20.83	TECTEH			C5542	reso	21H00036	H	0	600UL	340881
2385			0.57	79	MBM	5	06C	+19.52	TECTEH			C5542	reso	21H00036	H	0	600UL	340881
2386	67	87	4.08	182	DNT	P 1	08C	+0.68	TECTEH			N5877	seco	21H00036	H	0	600UL	340881
2387	69	87	3.24	180	DNG	P 1	08C	+2.64	TECTEH			N2574	seco	21H00035	H	0	600UL	340947
2388	77	87	1.82	178	INR	P 1	07H	+7.22	TECTEH			N2574	seco	21H00035	H	0	600UL	340947
2389	83	87	2.66	185	DNG	P 1	05H	+3.55	TECTEH			N5877	seco	21H00036	H	0	600UL	340881
2390	87	87	2.25	189	DNG	P 1	VM	+11.97	TECTEH			N5877	seco	21H00036	H	0	600UL	340881
2391			2.61	186	DNG	P 1	VM	+13.10	TECTEH			N5877	seco	21H00036	H	0	600UL	340881
2392	89	87	4.30	180	DNG	P 1	08C	+20.64	TECTEH			N2574	seco	21H00035	H	0	600UL	340947
2393	101	87	11.87	182	DNT	P 1	09H	+0.02	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
2394					NDF		09H	+0.02	09H09H			R3710	prim	21H00179	H	6	600PP	345336
2395	113	87	3.00	179	DNG	P 1	04H	+6.61	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
2396			3.53	181	DNG	P 1	04H	+12.13	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
2397	117	87	9.65	180	DNT	P 1	10C	+0.67	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
2398			2.37	187	DNG	P 1	05C	+27.32	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
	119	87	0.66	86	DSI	P 1	10H	-0.04	TECTEH			A6997	seco	21H00008	H	0	600UL	332255
					NDF		10H	-0.04	10H10H			R3710	prim	21H00179	H	3	600PP	345336
2401			7.34	184	DNG	P 1	DC	+36.86	TECTEH			A6997	seco	21H00008	H	0	600UL	332255

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 50

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2402	125	87				NDF	10H	-0.04	10H10H			R3710	prim	21H00179	H 3	600PP	345336
2403			1.23	116	DSI	P 1	10H	-0.04	TECTEH			D9573	prim	21H00007	H 0	600UL	340910
2404	129	87	2.39	185	DNT	P 1	10C	+0.34	TECTEH			S8982	seco	21H00007	H 0	600UL	340910
2405	133	87	2.14	181	DNG	P 1	01C	+23.90	TEHTEC			N2574	seco	21C00059	H 0	600CS	341612
2406	36	88	0.93	91	MBM	5	05C	+18.59	TECTEH			C5542	reso	21H00036	H 0	600UL	340881
2407	40	88	2.58	187	DNT	P 1	VM	+1.00	TECTEH			N5877	seco	21H00036	H 0	600UL	340881
2408	46	88	0.78	81	MBM	5	05C	+4.54	TECTEH			L2157	reso	21H00035	H 0	600UL	340947
2409	74	88	4.84	180	DNG	P 1	08C	+7.44	TECTEH			N2574	seco	21H00035	H 0	600UL	340947
	92	88	3.68	176	DNT	P 1	09C	+0.37	TECTEH			S8982	seco	21H00007	H 0	600UL	340910
	94	88	4.44	181	DNG	P 1	VC	+7.61	TECTEH			A6997	seco	21H00008	H 0	600UL	332255
2412	110	88	2.09	182	DNG	P 1	01C	+26.10	TECTEH			A6997	seco	21H00008	H 0	600UL	332255
2413	112	88	8.15	183	DNT	P 1	05C	+0.60	TECTEH			S8982	seco	21H00007	H 0	600UL	340910
2414	120	88	7.10	179	DNG	P 1	VC	+18.62	TECTEH			S8982	seco	21H00007	H 0	600UL	340910
2415	124	88	2.66	175	DNG	P 1	VC	+19.16	TECTEH			S8982	seco	21H00007	H 0	600UL	340910

2416	130	88	0.23	100	VOL	1	TSC	+2.59	TSCTSC			S4373	reso	21C00020	C 2	600PP	340923
2417			0.95	81	MBM	5	TSC	+2.81	TECTEH			C5542	reso	21H00008	H 0	600UL	332255
2418	136	88	3.81	179	DNG	P 1	03C	+12.46	TEHTEC			N2574	seco	21C00059	H 0	600CS	341612
[illegible]	41	89	6.20	182	DNG	P 1	DH	+8.97	TECTEH			N2574	seco	21H00035	H 0	600UL	340947
			0.82	91	MBM	5	05C	+2.06	TECTEH			L2157	reso	21H00035	H 0	600UL	340947
[illegible]			0.71	80	MBM	5	05C	+4.51	TECTEH			L2157	reso	21H00035	H 0	600UL	340947
2422	45	89	2.18	184	DNG	P 1	04C	+14.55	TECTEH			N2574	seco	21H00035	H 0	600UL	340947
2423			2.65	184	DNG	P 1	04C	+25.32	TECTEH			N2574	seco	21H00035	H 0	600UL	340947
2424			3.25	182	DNG	P 1	04C	+25.94	TECTEH			N2574	seco	21H00035	H 0	600UL	340947
2425	47	89	2.21	183	DNG	P 1	04C	+6.03	TECTEH			N5877	seco	21H00036	H 0	600UL	340881
2426	51	89	4.92	180	DNT	P 1	VM	+0.00	TECTEH			N5877	seco	21H00036	H 0	600UL	340881
2427	73	89	2.28	183	DNG	P 1	03H	+9.10	TECTEH			N2574	seco	21H00035	H 0	600UL	340947
2428	83	89	2.66	189	DNG	P 1	06H	+5.69	TECTEH			N5877	seco	21H00036	H 0	600UL	340881
2429	99	89	0.54	85	MBM	5	VM	+20.48	TECTEH			C5542	reso	21H00008	H 0	600UL	332255
2430			0.54	78	MBM	5	TSC	+32.53	TECTEH			C5542	reso	21H00008	H 0	600UL	332255
2431	105	89	4.47	184	DNG	P 1	09C	+11.37	TECTEH			S8982	seco	21H00007	H 0	600UL	340910
2432	107	89			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
2433			0.18	106	SAI	2	TSH	+1.02	TSHTSH	0.2		A9608	reso	21H00159	H 1	600PP	345337
2434			0.28	100	SAI	1	TSH	+1.02	TSHTSH	0.2		A9608	reso	21H00159	H 1	600PP	345337
2435			0.14	102	PID	4	TSH	+1.02	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
2436	115	89	5.82	183	DNG	P 1	09C	+20.64	TECTEH			A6997	seco	21H00008	H 0	600UL	332255
2437			8.61	179	DNT	P 1	07C	+1.13	TECTEH			A6997	seco	21H00008	H 0	600UL	332255
2438	117	89	9.48	181	DNT	P 1	10C	+0.60	TECTEH			S8982	seco	21H00007	H 0	600UL	340910
2439	121	89	0.69	118	INR	P 1	TSH	+7.91	TECTEH			D3858	reso	21H00007	H 0	600UL	340910
2440			0.70	77	MBM	6	02H	+26.00	TECTEH			C5542	reso	21H00007	H 0	600UL	340910
2441	125	89	0.84	83	MBM	5	04H	+24.37	TECTEH			C5542	reso	21H00007	H 0	600UL	340910
2442	127	89	4.01	178	DNG	P 1	VH	+2.49	TECTEH	LOCOK		D3858	reso	21H00008	H 0	600UL	332255
2443			2.75	174	DNG	P 1	VH	+3.71	TECTEH			A6997	seco	21H00008	H 0	600UL	332255
2444			3.42	178	DNG	P 1	VH	+7.22	TECTEH			A6997	seco	21H00008	H 0	600UL	332255
	135	89	2.14	186	INR	P 1	09H	-0.26	TEHTEC			A9608	reso	21C00060	H 0	600CS	341613
	139	89			TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
2447			7.03	80	PLP	9	TSH	+0.29	TSHTSH			B6768	prim	21H00168	H 1	600PP	345335
2448			0.50	84	WAR	2	08H	+1.04	08H09H			L2157	reso	21H00190	H 3	5602C	326187
2449			1.32	95	40	P 2	08H	+1.17	TEHTEC			D3858	reso	21C00060	H 0	600CS	341613
2450			0.43	81	PID	2	08H	+1.17	08H09H			D3858	reso	21H00191	H999	5602C	326187

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 51

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2451			2.72	185	DNG	P 1	VH	+3.27	TEHTEC			M9715	seco	21C00060	H 0	600CS	341613
2452	36	90	3.96	181	DNG	P 1	06H	+13.31	TECTEH			N5877	seco	21H00036	H 0	600UL	340881
2453			4.85	182	DNG	P 1	06H	+15.57	TECTEH			N5877	seco	21H00036	H 0	600UL	340881
2454	52	90	0.68	88	MBM	5	06C	+18.85	TECTEH			L2157	reso	21H00035	H 0	600UL	340947
2455	56	90	2.80	92	MBM	5	03H	+25.68	TECTEH			L2157	reso	21H00035	H 0	600UL	340947
[illegible]	68	90			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
			0.20	123	SAI	2	TSH	+2.10	TSHTSH	0.5		C5542	reso	21H00136	H 1	600PP	345335
2458			0.33	32	SAI	1	TSH	+2.10	TSHTSH	0.8		C5542	reso	21H00136	H 1	600PP	345335
2459			0.24	127	PID	4	TSH	+2.10	TSHTSH	080		A9608	reso	21H00184	H999	600PP	345336
2460			0.79	69	MBM	5	03H	+22.72	TECTEH			L2157	reso	21H00035	H 0	600UL	340947
2461			0.74	86	MBM	5	03H	+34.95	TECTEH			L2157	reso	21H00035	H 0	600UL	340947

2462	70	90	2.92	2	INR	P	1	DH	+4.62	TECTEH			C5542	reso	21H00036	H	0	600UL	340881
2463	74	90	4.23	186	DNT	P	1	VH	+1.53	TECTEH			S4373	reso	21H00036	H	0	600UL	340881
2464	92	90	4.05	182	DNT	P	1	09C	+0.29	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
	94	90	0.48	66	MBM	5		05C	+9.05	TECTEH			C5542	reso	21H00008	H	0	600UL	332255
	100	90	2.70	187	DNG	P	1	06H	+16.23	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
2467	104	90	3.04	184	DNG	P	1	VM	+2.76	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
2468	108	90	4.01	180	DNG	P	1	09H	+13.69	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
2469	110	90	2.85	186	DNG	P	1	07C	+10.70	TECTEH			A6997	seco	21H00008	H	0	600UL	332255
2470			2.95	179	DNG	P	1	07C	+11.17	TECTEH			A6997	seco	21H00008	H	0	600UL	332255
2471	112	90	3.31	182	DNG	P	1	04C	+8.53	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
2472			2.99	181	DNG	P	1	04C	+9.15	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
2473	120	90	9.67	181	DNG	P	1	VC	+19.01	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
2474			1.08	78	MBM	5		05C	+25.09	TECTEH			C5542	reso	21H00007	H	0	600UL	340910
2475	122	90	5.01	183	DNG	P	1	10C	+5.03	TECTEH			A6997	seco	21H00008	H	0	600UL	332255
2476	130	90	0.78	78	MBM	5		03H	+16.92	TECTEH			C5542	reso	21H00008	H	0	600UL	332255
2477			3.58	180	DNG	P	1	DC	+41.41	TECTEH			A6997	seco	21H00008	H	0	600UL	332255
2478	134	90	3.23	183	DNG	P	1	10C	+14.81	TEHTEC			M9715	seco	21C00060	H	0	600CS	341613
2479	138	90	6.52	84	PLP	9		TSH	+0.38	TSHTSH			B6768	prim	21H00168	H	1	600PP	345335
2480	140	90	9.28	83	PLP	9		TSH	+0.28	TSHTSH			B6768	prim	21H00168	H	1	600PP	345335
2481			2.05	188	DNG	P	1	09C	+20.80	TEHTEC			C5542	reso	21C00060	H	0	600CS	341613
2482	35	91	4.29	181	DNT	P	1	VM	-2.00	TECTEH			C5542	reso	21H00036	H	0	600UL	340881
2483	41	91			TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
2484			0.09	60	PID	4		TSH	+0.83	TSHTSH	080		M1680	reso	21H00174	H999		600PP	345337
2485			0.10	68	SAI	2		TSH	+0.83	TSHTSH	0.2		C5542	reso	21H00136	H	1	600PP	345335
2486			0.00	0	SAI	1		TSH	+0.83	TSHTSH	0.0		S4373	reso	21H00136	H	1	600PP	345335
2487	43	91	3.80	84	MBM	6		02H	+22.69	TECTEH			C5542	reso	21H00036	H	0	600UL	340881
2488	65	91			TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
2489			0.0	0	SAI	1		TSH	+1.14	TSHTSH	0.0		L2157	reso	21H00137	H	1	600PP	345334
2490			0.14	74	PID	4		TSH	+1.14	TSHTSH	080		M1680	reso	21H00174	H999		600PP	345337
			0.13	102	SAI	2		TSH	+1.14	TSHTSH	0.2		L2157	reso	21H00137	H	1	600PP	345334
	71	91	1.27	192	INR	P	1	08C	+2.92	TECTEH			N2574	seco	21H00035	H	0	600UL	340947
2493			2.39	187	DNG	P	1	08C	+4.41	TECTEH			N2574	seco	21H00035	H	0	600UL	340947
2494	73	91	0.36	87	MBM	5		VM	+20.91	TECTEH			C5542	reso	21H00036	H	0	600UL	340881
2495	87	91	1.10	178	INR	P	1	VM	-1.88	TECTEH			N5877	seco	21H00036	H	0	600UL	340881
2496			4.33	178	DNT	P	1	08C	+0.26	TECTEH			N5877	seco	21H00036	H	0	600UL	340881
2497			2.86	179	DNG	P	1	08C	+12.23	TECTEH			N5877	seco	21H00036	H	0	600UL	340881
2498	91	91	4.89	178	DNT	P	1	09C	-0.71	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
2499	93	91	2.61	181	DNG	P	1	09C	+1.09	TECTEH			D3858	reso	21H00007	H	0	600UL	340910

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 52

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2500	101	91	4.88	178	DNG	P	1	01C	+17.90	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
2501	109	91	2.12	182	DNG	P	1	VC	+12.53	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
	113	91	3.28	182	DNG	P	1	04C	+20.14	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
	117	91	4.53	185	DNT	P	1	10C	+0.49	TECTEH			S8982	seco	21H00007	H	0	600UL	340910
2504	119	91	6.20	182	DNG	P	1	10C	+2.13	TECTEH			A6997	seco	21H00008	H	0	600UL	332255
2505	123	91	5.02	189	DNT	P	1	02C	-0.27	TECTEH			A6997	seco	21H00008	H	0	600UL	332255
2506	125	91	0.40	66	MBM	5		09C	+18.87	TECTEH			C5542	reso	21H00007	H	0	600UL	340910
2507	127	91			INF			DH	+15.72	TECTEH	HR		C5542	reso	21H00008	H	0	600UL	332255

2508				0.92	84	MBM	5	DH	+17.06	TECTEH				C5542	reso	21H00008	H 0	600UL	332255
2509	131	91		6.26	181	DNG	P 1	VC	+41.71	TECTEH				A6997	seco	21H00008	H 0	600UL	332255
2510	133	91		9.20	79	PLP	9	TSH	+0.31	TSHTSH				B6768	prim	21H00168	H 1	600PP	345335
	139	91		8.98	81	PLP	9	TSH	+0.28	TSHTSH				B6768	prim	21H00168	H 1	600PP	345335
				0.66	187	IDM	2	TSH	+3.10	TSHTSH				S4373	reso	21H00168	H 1	600PP	345335
2513	34	92		5.66	181	DNG	P 1	04C	+35.01	TECTEH				N5877	seco	21H00036	H 0	600UL	340881
2514	38	92				TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
2515				0.00	0	SAI	1	TSH	+0.86	TSHTSH	0.0			C5542	reso	21H00136	H 1	600PP	345335
2516				0.09	99	PID	4	TSH	+0.86	TSHTSH	080			M1680	reso	21H00174	H999	600PP	345337
2517				0.08	78	SAI	2	TSH	+0.86	TSHTSH	0.3			C5542	reso	21H00136	H 1	600PP	345335
2518				1.00	49	MBM	5	07H	+8.45	TECTEH				C5542	reso	21H00036	H 0	600UL	340881
2519	44	92		0.57	69	MBM	5	TSC	+10.30	TECTEH				L2157	reso	21H00035	H 0	600UL	340947
2520	52	92		0.45	79	MBM	5	01H	+8.36	TECTEH				L2157	reso	21H00035	H 0	600UL	340947
2521	70	92		0.57	47	MBM	6	01C	+9.41	TECTEH				C5542	reso	21H00040	H 0	600UL	340881
2522	72	92		2.22	186	DNG	P 1	08C	+5.61	TECTEH				A9574	seco	21H00039	H 0	600UL	340947
2523	74	92		5.86	182	DNG	P 1	08C	+7.29	TECTEH				C5542	reso	21H00040	H 0	600UL	340881
2524	76	92		6.02	182	DNG	P 1	07H	+13.70	TECTEH				A9574	seco	21H00039	H 0	600UL	340947
2525				3.91	183	DNG	P 1	07H	+16.45	TECTEH				A9574	seco	21H00039	H 0	600UL	340947
2526				10.01	181	DNG	P 1	07C	+5.91	TECTEH				A9574	seco	21H00039	H 0	600UL	340947
2527				5.76	181	DNG	P 1	07C	+15.66	TECTEH				A9574	seco	21H00039	H 0	600UL	340947
2528	78	92		3.14	182	DNG	P 1	08C	+11.01	TECTEH				A9574	seco	21H00039	H 0	600UL	340947
2529	96	92		5.09	183	DNG	P 1	09C	+4.50	TECTEH				S8982	seco	21H00007	H 0	600UL	340910
2530	108	92		2.65	177	DNG	P 1	02H	+3.77	TECTEH				S8982	seco	21H00007	H 0	600UL	340910
2531	112	92		1.71	180	INR	P 1	09C	+18.18	TECTEH				C5542	reso	21H00007	H 0	600UL	340910
2532	114	92		0.31	95	INR	10	TSC	+3.14	TSCTSC				C5542	reso	21C00017	C 2	600PP	345292
2533	116	92		0.58	159	INR	P 1	06C	-0.26	TECTEH				C5542	reso	21H00007	H 0	600UL	340910
2534				0.73	80	MBM	5	04C	+21.58	TECTEH				C5542	reso	21H00007	H 0	600UL	340910
2535	118	92		3.36	181	DNG	P 1	01H	+3.81	TECTEH				A6997	seco	21H00008	H 0	600UL	332255
2536				1.19	103	MBM	5	05H	+26.22	TECTEH				C5542	reso	21H00008	H 0	600UL	332255
				2.12	182	DNG	P 1	10C	+1.06	TECTEH				A6997	seco	21H00008	H 0	600UL	332255
[illegible]	120	92		7.86	180	DNG	P 1	VC	+18.90	TECTEH				S8982	seco	21H00007	H 0	600UL	340910
2539	124	92		0.47	83	MBM	6	08H	+2.69	TECTEH				C5542	reso	21H00007	H 0	600UL	340910
2540				2.36	184	DNG	P 1	VH	+29.40	TECTEH				S8982	seco	21H00007	H 0	600UL	340910
2541	126	92		1.22	132	DSI	P 1	10H	-0.06	TECTEH				P5436	prim	21H00008	H 0	600UL	332255
2542						NDF		10H	-0.06	10H10H				R3710	prim	21H00179	H 3	600PP	345336
2543	134	92		4.45	184	DNG	P 1	TSC	+4.81	TEHTEC				M9715	seco	21C00060	H 0	600CS	341613
2544	140	92		5.60	181	DNG	P 1	10C	+3.16	TEHTEC				M9715	seco	21C00060	H 0	600CS	341613
2545	41	93		7.45	182	DNG	P 1	DH	+9.12	TECTEH				A9574	seco	21H00039	H 0	600UL	340947
2546	51	93		1.00	93	MBM	5	03C	+32.17	TECTEH				C5542	reso	21H00040	H 0	600UL	340881
2547	67	93		6.60	182	DNT	P 1	08C	+0.61	TECTEH				O8795	seco	21H00040	H 0	600UL	340881
2548	73	93		0.43	76	MBM	5	TSH	+13.29	TECTEH				C5542	reso	21H00039	H 0	600UL	340947

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 53

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
	81	93	3.12	182	DNG	P 1	08C	+13.61	TECTEH			A9574	seco	21H00039	H 0	600UL	340947
2550	85	93	1.22	30	MBM	6	03C	+16.46	TECTEH			C5542	reso	21H00039	H 0	600UL	340947
2551	89	93	2.21	182	DNG	P 1	08C	+20.75	TECTEH			A9574	seco	21H00039	H 0	600UL	340947
2552	93	93	3.74	179	DNG	P 1	09C	+1.21	TECTEH			S8982	seco	21H00007	H 0	600UL	340910
2553	97	93	5.80	177	DNG	P 1	02C	+22.54	TECTEH			S8982	seco	21H00007	H 0	600UL	340910

2554			2.74	176	DNG	P	1	02C	+23.74	TECTEH				S8982	seco	21H00007	H	0	600UL	340910
2555			6.76	177	DNG	P	1	02C	+29.69	TECTEH				S8982	seco	21H00007	H	0	600UL	340910
2556			2.83	175	DNG	P	1	02C	+33.33	TECTEH				S8982	seco	21H00007	H	0	600UL	340910
[illegible]			4.16	177	DNG	P	1	02C	+34.50	TECTEH				S8982	seco	21H00007	H	0	600UL	340910
	109	93	2.23	182	DNT	P	1	09H	+0.02	TECTEH				S8982	seco	21H00007	H	0	600UL	340910
2559			2.19	179	DNG	P	1	VC	+13.77	TECTEH				S8982	seco	21H00007	H	0	600UL	340910
2560	111	93	1.03	186	INR	P	1	09C	+14.87	TECTEH				C5542	reso	21H00008	H	0	600UL	332255
2561	115	93			NDF			09H	+0.13	09H09H				R3710	prim	21H00179	H	3	600PP	345336
2562			0.41	106	DSI	P	1	09H	+0.13	TECTEH				P5436	prim	21H00008	H	0	600UL	332255
2563	119	93	5.83	185	DNG	P	1	10C	+2.36	TECTEH				A6997	seco	21H00008	H	0	600UL	332255
2564			2.26	177	DNG	P	1	02C	+23.26	TECTEH				A6997	seco	21H00008	H	0	600UL	332255
2565	121	93			NDF			10H	+0.02	10H10H				F3453	reso	21H00179	H	3	600PP	345336
2566			0.53	82	DSI	P	1	10H	+0.02	TECTEH				J9815	prim	21H00007	H	0	600UL	340910
2567			7.98	180	DNG	P	1	10C	+3.68	TECTEH				S8982	seco	21H00007	H	0	600UL	340910
2568	131	93	2.32	177	DNT	P	1	10H	-0.21	TECTEH				A6997	seco	21H00008	H	0	600UL	332255
2569	135	93	3.61	183	DNG	P	1	10C	+15.79	TEHTEC				M9715	seco	21C00060	H	0	600CS	341613
2570	137	93	5.71	70	PLP		9	TSH	+1.54	TSHTSH				B6768	prim	21H00168	H	1	600PP	345335
2571	139	93	2.47	184	DNG	P	1	10C	+19.07	TEHTEC				M9715	seco	21C00060	H	0	600CS	341613
2572	38	94			TBS					TSHTSH				D3858	reso	21H00115	H	1	600PP	326403
2573			0.30	121	SAI		1	TSH	+0.96	TSHTSH	0.5			L2157	reso	21H00137	H	1	600PP	345334
2574			0.28	117	PID		4	TSH	+0.96	TSHTSH	080			F6623	reso	21H00176	H999		600PP	345339
2575			0.28	110	SAI		2	TSH	+0.96	TSHTSH	0.7			L2157	reso	21H00137	H	1	600PP	345334
2576			1.47	82	MBM		6	03H	+27.92	TECTEH				C5542	reso	21H00040	H	0	600UL	340881
2577	40	94	3.33	181	DNT	P	1	VM	+1.20	TECTEH				S4373	reso	21H00039	H	0	600UL	340947
2578	52	94	0.69	91	MBM		5	01C	+17.69	TECTEH				C5542	reso	21H00039	H	0	600UL	340947
2579	60	94			TBS					TSHTSH				D3858	reso	21H00115	H	1	600PP	326403
2580			0.20	100	SAI		2	TSH	+0.74	TSHTSH	0.5			C5542	reso	21H00136	H	1	600PP	345335
2581			0.32	67	SAI		1	TSH	+0.74	TSHTSH	0.5			C5542	reso	21H00136	H	1	600PP	345335
2582			0.27	97	PID		4	TSH	+0.74	TSHTSH	080			M1680	reso	21H00174	H999		600PP	345337
			0.82	46	NQI	P	1	TSH	+0.80	TECTEH				A9574	seco	21H00039	H	0	600UL	340947
[illegible]	76	94	2.70	4	INR	P	1	08H	-0.75	TECTEH				C5542	reso	21H00040	H	0	600UL	340881
2585	78	94	4.30	183	DNG	P	1	08H	+10.90	TECTEH				A9574	seco	21H00039	H	0	600UL	340947
2586			5.89	184	DNG	P	1	08C	+10.86	TECTEH				A9574	seco	21H00039	H	0	600UL	340947
2587			0.71	87	MBM		5	02C	+34.78	TECTEH				C5542	reso	21H00039	H	0	600UL	340947
2588			0.57	74	MBM		5	TSC	+30.17	TECTEH				C5542	reso	21H00039	H	0	600UL	340947
2589	82	94	0.40	81	INR	P	1	TSH	+1.15	TECTEH				C5542	reso	21H00039	H	0	600UL	340947
2590			3.61	176	DNG	P	1	06H	+18.13	TECTEH				A9574	seco	21H00039	H	0	600UL	340947
2591	100	94	0.48	95	MBM		5	03C	+13.90	TECTEH				C5542	reso	21H00007	H	0	600UL	340910
2592			0.75	94	MBM		5	02C	+17.46	TECTEH				C5542	reso	21H00007	H	0	600UL	340910
2593			0.69	86	MBM		5	01C	+21.41	TECTEH				C5542	reso	21H00007	H	0	600UL	340910
2594	102	94	3.28	182	DNG	P	1	09H	+8.45	TECTEH				A6997	seco	21H00008	H	0	600UL	332255
2595	110	94	0.43	88	MBM		5	05C	+20.46	TECTEH				C5542	reso	21H00008	H	0	600UL	332255
2596	114	94	2.22	176	DNG	P	1	VC	+3.26	TECTEH				A6997	seco	21H00008	H	0	600UL	332255
2597	120	94	7.49	181	DNG	P	1	VC	+18.55	TECTEH				S8982	seco	21H00007	H	0	600UL	340910

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 54

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2598	122	94	3.09	185	DNG	P	1	02C	+30.27	TECTEH			A6997	seco	21H00008	H 0 600UL	332255
2599			3.68	186	DNG	P	1	02C	+33.51	TECTEH			A6997	seco	21H00008	H 0 600UL	332255

2600	130	94	9.67	181	INR	P	1	02H	+14.91	TECTEH				A6997	seco	21H00012	H	0	600UL	332255
2601			6.11	180	INR	P	1	03H	+15.41	TECTEH				A6997	seco	21H00012	H	0	600UL	332255
2602	138	94	4.24	75	PLP		9	TSH	+1.36	TSHTSH				B6768	prim	21H00168	H	1	600PP	345335
	35	95	3.34	178	DNG	P	1	TSH	+18.32	TECTEH				A9574	seco	21H00039	H	0	600UL	340947
			2.91	182	DNT	P	1	VM	-1.92	TECTEH				A9574	seco	21H00039	H	0	600UL	340947
2605	39	95			TBS					TSHTSH				D3858	reso	21H00115	H	1	600PP	326403
2606			0.04	57	PID		4	TSH	+1.06	TSHTSH	080			F6623	reso	21H00176	H999		600PP	345339
2607			0.05	94	SAI		2	TSH	+1.06	TSHTSH	0.2			C5542	reso	21H00136	H	1	600PP	345335
2608			0.00	0	SAI		1	TSH	+1.06	TSHTSH	0.0			C5542	reso	21H00136	H	1	600PP	345335
2609	41	95	8.86	178	DNG	P	1	DH	+8.73	TECTEH				O8795	seco	21H00040	H	0	600UL	340881
2610			3.37	183	DNG	P	1	01C	+19.87	TECTEH				O8795	seco	21H00040	H	0	600UL	340881
2611	55	95	0.76	87	MBM		5	05H	+12.44	TECTEH				C5542	reso	21H00039	H	0	600UL	340947
2612	57	95	4.35	178	DNG	P	1	07H	+14.25	TECTEH				O8795	seco	21H00040	H	0	600UL	340881
2613	59	95			TBS					TSHTSH				D3858	reso	21H00115	H	1	600PP	326403
2614			0.19	99	SAI		2	TSH	+0.80	TSHTSH	0.4			C5542	reso	21H00136	H	1	600PP	345335
2615			0.23	112	PID		4	TSH	+0.80	TSHTSH	080			M1680	reso	21H00174	H999		600PP	345337
2616			0.25	77	SAI		1	TSH	+0.80	TSHTSH	0.4			C5542	reso	21H00136	H	1	600PP	345335
2617	81	95	3.09	183	DNG	P	1	08C	+13.36	TECTEH				A9574	seco	21H00039	H	0	600UL	340947
2618	89	95	4.06	181	DNG	P	1	08C	+20.48	TECTEH				A9574	seco	21H00039	H	0	600UL	340947
2619	91	95	3.08	177	DNT	P	1	09C	-0.65	TECTEH				S8982	seco	21H00011	H	0	600UL	340910
2620	93	95	2.56	180	DNT	P	1	09C	+0.02	TECTEH				S8982	seco	21H00011	H	0	600UL	340910
2621	99	95	6.40	178	DNT	P	1	DC	-0.35	TECTEH				S8982	seco	21H00011	H	0	600UL	340910
2622	103	95	2.52	176	DNG	P	1	01H	+37.16	TECTEH				S8982	seco	21H00011	H	0	600UL	340910
2623	109	95	2.36	181	DNG	P	1	VC	+11.94	TECTEH				N2574	seco	21H00035	H	0	600UL	340947
2624			2.09	181	DNG	P	1	VC	+12.55	01CTEH				A6997	seco	21H00012	H	0	600UL	332255
2625			4.96	6	INR	P	1	VC	+13.54	TECTEH				N2574	seco	21H00035	H	0	600UL	340947
2626	117	95	0.81	100	MBM		6	04H	+7.14	TECTEH				L2157	reso	21H00035	H	0	600UL	340947
2627			1.00	92	MBM		6	04H	+7.23	01CTEH				L2157	reso	21H00012	H	0	600UL	332255
2628	123	95	2.74	183	DNT	P	1	03H	-0.22	TECTEH				S8982	seco	21H00011	H	0	600UL	340910
	129	95	0.72	90	MBM		5	09C	+8.93	TECTEH				M7006	reso	21H00011	H	0	600UL	340910
			1.52	87	MBM		5	02C	+11.73	TECTEH				M7006	reso	21H00011	H	0	600UL	340910
2631	139	95	4.93	183	DNG	P	1	10C	+18.97	TEHTEC				M9715	seco	21C00060	H	0	600CS	341613
2632	40	96	3.51	184	DNT	P	1	VM	+1.22	TECTEH				O8795	seco	21H00040	H	0	600UL	340881
2633	46	96	0.73	106	INR		6	02H	+2.45	TECTEH				A9574	seco	21H00039	H	0	600UL	340947
2634			0.67	95	MBM		6	02H	+2.57	TECTEH				C5542	reso	21H00039	H	0	600UL	340947
2635			1.84	180	INR	P	1	TSC	+33.02	TECTEH				A9574	seco	21H00039	H	0	600UL	340947
2636	50	96	0.64	80	MBM		5	04C	+26.80	TECTEH				C5542	reso	21H00039	H	0	600UL	340947
2637	56	96			TBP					TSHTSH	RMVTBS	ADDTBP		D3858	reso	21H00115	H	1	600PP	326403
2638			0.07	54	PID		4	TSH	+2.11	TSHTSH	080			M1680	reso	21H00174	H999		600PP	345337
2639			0.05	80	SAI		2	TSH	+2.11	TSHTSH	0.2			C5542	reso	21H00136	H	1	600PP	345335
2640			0.00	0	SAI		1	TSH	+2.11	TSHTSH	0.0			C5542	reso	21H00136	H	1	600PP	345335
2641	66	96	0.67	76	MBM		5	07H	+20.82	TECTEH				C5542	reso	21H00039	H	0	600UL	340947
2642	74	96	5.49	179	DNG	P	1	08C	+7.39	TECTEH				A9574	seco	21H00039	H	0	600UL	340947
2643	78	96	3.69	181	DNG	P	1	08C	+10.92	TECTEH				A9574	seco	21H00039	H	0	600UL	340947
2644	80	96	0.56	72	MBM		5	08H	+7.36	TECTEH				C5542	reso	21H00040	H	0	600UL	340881
2645	82	96			TBS					TSHTSH				D3858	reso	21H00115	H	1	600PP	326403
2646			0.13	69	PID		4	TSH	+1.38	TSHTSH	080			A9608	reso	21H00184	H999		600PP	345336

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 55

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N

2647			0.11	96	SAI	2	TSH	+1.38	TSHTSH	0.2			L2157	reso	21H00137	H 1	600PP	345334
2648			0.15	103	SAI	1	TSH	+1.38	TSHTSH	0.3			L2157	reso	21H00137	H 1	600PP	345334
[illegible]	92	96	2.02	178	DNT	P 1	09H	-0.02	TECTEH				S8982	seco	21H00011	H 0	600UL	340910
[illegible]			2.80	177	DNT	P 1	09C	+0.24	TECTEH				S8982	seco	21H00011	H 0	600UL	340910
2651	102	96	2.53	177	DNG	P 1	09H	+9.17	TECTEH				M7006	reso	21H00011	H 0	600UL	340910
2652	108	96	2.34	184	DNG	P 1	09H	-1.20	TECTEH				N2574	seco	21H00035	H 0	600UL	340947
2653	112	96	2.87	182	DNG	P 1	09C	+18.08	01CTEH				A6997	seco	21H00012	H 0	600UL	332255
2654			2.94	185	DNG	P 1	09C	+18.10	TECTEH				L2157	reso	21H00035	H 0	600UL	340947
2655	114	96	3.92	180	DNG	P 1	09C	+19.42	TECTEH				S8982	seco	21H00011	H 0	600UL	340910
2656	120	96			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
2657			0.31	101	SVI	1	TSH	+0.03	TSHTSH	0.2	0.2		S4373	reso	21H00163	H 1	600PP	345335
2658			0.16	98	PID	4	TSH	+0.03	TSHTSH	080			F3453	reso	21H00177	H999	600PP	345336
2659			0.24	71	SVI	2	TSH	+0.03	TSHTSH	0.2	0.3		S4373	reso	21H00163	H 1	600PP	345335
2660			6.74	181	DNG	P 1	VC	+18.57	TECTEH				S8982	seco	21H00011	H 0	600UL	340910
2661			2.92	181	DNG	P 1	VC	+20.18	TECTEH				S8982	seco	21H00011	H 0	600UL	340910
2662	122	96			NDF		TSH	+23.15	TSH01H				R3710	prim	21H00179	H 3	600PP	345336
2663			1.09	72	NQI	5	TSH	+23.15	TECTEH				L2157	reso	21H00012	H 0	600UL	332255
2664			1.20	77	MBM	5	03H	+28.11	TECTEH				L2157	reso	21H00012	H 0	600UL	332255
2665			0.86	75	MBM	5	04H	+25.73	TECTEH				L2157	reso	21H00012	H 0	600UL	332255
2666			1.04	78	MBM	5	02C	+37.64	TECTEH				L2157	reso	21H00012	H 0	600UL	332255
2667	128	96	2.75	186	INR	P 1	03H	+0.34	TECTEH				M7006	reso	21H00011	H 0	600UL	340910
2668	39	97	2.93	4	INR	P 1	VM	-1.66	TECTEH				O8795	seco	21H00040	H 0	600UL	340881
2669	41	97	7.93	183	DNG	P 1	DH	+8.77	TECTEH				A9574	seco	21H00039	H 0	600UL	340947
2670	77	97			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
2671			0.15	130	PID	4	TSH	+0.77	TSHTSH	080			F3453	reso	21H00175	H999	600PP	345339
2672			0.24	78	SAI	1	TSH	+0.77	TSHTSH	0.3			L2157	reso	21H00137	H 1	600PP	345334
2673			0.14	104	SAI	2	TSH	+0.77	TSHTSH	0.5			L2157	reso	21H00137	H 1	600PP	345334
2674	83	97	0.50	77	MBM	5	02H	+31.82	TECTEH				C5542	reso	21H00040	H 0	600UL	340881
	87	97			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
			0.15	80	SAI	2	TSH	+1.15	TSHTSH	0.3			L2157	reso	21H00137	H 1	600PP	345334
2677			0.13	79	PID	4	TSH	+1.15	TSHTSH	080			F3453	reso	21H00175	H999	600PP	345339
2678			0.18	88	SAI	1	TSH	+1.15	TSHTSH	0.3			L2157	reso	21H00137	H 1	600PP	345334
2679	91	97	2.77	176	DNG	P 1	TSC	+5.19	TECTEH				S8982	seco	21H00011	H 0	600UL	340910
2680	97	97	1.66	57	MBM	6	01H	+16.07	TECTEH				M7006	reso	21H00011	H 0	600UL	340910
2681			3.05	178	DNG	P 1	07C	+6.29	TECTEH				S8982	seco	21H00011	H 0	600UL	340910
2682	103	97	2.64	175	DNG	P 1	01H	+28.74	TECTEH				A6997	seco	21H00012	H 0	600UL	332255
2683	109	97	1.92	184	INR	P 1	01H	+22.57	TECTEH				S8982	seco	21H00011	H 0	600UL	340910
2684			2.29	181	DNG	P 1	VC	+13.24	TECTEH				S8982	seco	21H00011	H 0	600UL	340910
2685	113	97	0.35	48	DSI	P 1	09C	+0.19	TECTEH				S8982	seco	21H00011	H 0	600UL	340910
2686					NDF		09C	+0.19	09C09C				F6623	reso	21C00083	C 4	600PP	345344
2687	121	97	2.62	185	DNG	P 1	TSH	+16.47	TECTEH				S8982	seco	21H00011	H 0	600UL	340910
2688			2.20	185	DNG	P 1	TSH	+19.26	TECTEH				S8982	seco	21H00011	H 0	600UL	340910
2689	125	97			NDF		10H	-0.02	10H10H				R3710	prim	21H00179	H 3	600PP	345336
2690			0.28	109	DSI	P 1	10H	-0.02	TECTEH				S8982	seco	21H00011	H 0	600UL	340910
2691			6.09	180	DNG	P 1	10C	+5.72	TECTEH				S8982	seco	21H00011	H 0	600UL	340910
2692	127	97	2.32	81	MBM	6	TSH	+11.01	TECTEH				L2157	reso	21H00012	H 0	600UL	332255
2693	129	97	0.75	69	MBM	5	01C	+28.83	TECTEH				M7006	reso	21H00011	H 0	600UL	340910
2694	135	97	6.34	74	PLP	9	TSH	+0.50	TSHTSH				B6768	prim	21H00168	H 1	600PP	345335
2695	137	97	7.23	75	PLP	9	TSH	+0.41	TSHTSH				B6768	prim	21H00168	H 1	600PP	345335

SG 21 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP,

PLANT: CCNPP

UNIT: 2

SG: 21

MAY. 17,2001 13:47

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
			0.21	78	PLP	9	TSC	+0.61	TSCTSC			F6623	reso	21C00039	C 2	600PP	345328
2697	30	98	0.61	92	MBM	5	01H	+6.24	TECTEH			C5542	reso	21H00040	H 0	600UL	340881
2698	32	98	0.46	83	MBM	5	04C	+22.25	TECTEH			C5542	reso	21H00039	H 0	600UL	340947
2699	40	98	3.07	187	DNT	P 1	VM	+1.21	TECTEH			O8795	seco	21H00040	H 0	600UL	340881
2700	54	98	0.41	76	MBM	5	04C	+22.06	TECTEH			C5542	reso	21H00039	H 0	600UL	340947
2701	60	98			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
2702			0.28	117	NQI	P 1	TSH	+0.78	TECTEH			D6502	prim	21H00039	H 0	600UL	340947
2703			0.24	62	MAI	1	TSH	+0.89	TSHTSH	0.3		L2157	reso	21H00137	H 1	600PP	345334
2704			0.15	96	PID	4	TSH	+0.89	TSHTSH	080		A9608	reso	21H00184	H999	600PP	345336
2705			0.17	89	MAI	2	TSH	+0.89	TSHTSH	0.4		L2157	reso	21H00137	H 1	600PP	345334
2706	74	98	1.68	88	MBM	6	04H	+9.22	TECTEH			M7006	reso	21H00044	H 0	600UL	340881
2707			0.88	62	MBM	6	05H	+10.35	TECTEH			M7006	reso	21H00044	H 0	600UL	340881
2708			2.64	181	DNG	P 1	VC	+2.34	TECTEH			H2949	seco	21H00044	H 0	600UL	340881
2709			6.06	183	DNG	P 1	08C	+7.33	TECTEH			H2949	seco	21H00044	H 0	600UL	340881
2710			4.10	186	DNG	P 1	08C	+11.14	TECTEH			H2949	seco	21H00044	H 0	600UL	340881
2711	86	98	3.25	184	DNG	P 1	02C	+26.13	TECTEH			H2949	seco	21H00044	H 0	600UL	340881
2712	96	98			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
2713			0.09	99	PID	4	TSH	+0.79	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
2714			0.32	71	MAI	1	TSH	+0.79	TSHTSH	0.2		A9608	reso	21H00161	H 1	600PP	345335
2715			0.14	104	MAI	2	TSH	+0.79	TSHTSH	0.2		A9608	reso	21H00161	H 1	600PP	345335
2716	106	98	2.55	182	DNG	P 1	09H	+12.40	TECTEH			A6997	seco	21H00012	H 0	600UL	332255
2717	108	98	1.90	181	INR	P 1	02H	+4.16	TECTEH			S8982	seco	21H00011	H 0	600UL	340910
2718					NDF		09C	+0.15	09C09C			F6623	reso	21C00083	C 4	600PP	345344
2719			0.48	144	DSI	P 1	09C	+0.15	TECTEH			S8982	seco	21H00011	H 0	600UL	340910
2720			0.61	102	MBM	5	08C	+9.37	TECTEH			M7006	reso	21H00011	H 0	600UL	340910
	112	98	0.61	71	MBM	5	04H	+6.98	TECTEH			M7006	reso	21H00011	H 0	600UL	340910
			0.57	82	MBM	5	07H	+8.05	TECTEH			M7006	reso	21H00011	H 0	600UL	340910
2723			0.64	85	MBM	5	07H	+15.57	TECTEH			M7006	reso	21H00011	H 0	600UL	340910
2724			0.63	103	INR	6	08H	+13.34	TECTEH			S4373	reso	21H00011	H 0	600UL	340910
2725			0.75	57	MBM	6	03C	+34.70	TECTEH			M7006	reso	21H00011	H 0	600UL	340910
2726	120	98	7.55	180	DNG	P 1	VC	+18.98	TECTEH			S8982	seco	21H00011	H 0	600UL	340910
2727	124	98	0.63	89	MBM	5	03H	+22.08	TECTEH			M7006	reso	21H00011	H 0	600UL	340910
2728	130	98	19.26	178	DNG	P 1	TSC	+13.39	TECTEH			A6997	seco	21H00012	H 0	600UL	332255
2729	132	98	0.62	100	MBM	6	03H	+29.52	TEHTEC			C5542	reso	21C00059	H 0	600CS	341612
2730	136	98	0.18	78	PLP	9	TSC	+0.50	TSCTSC			F6623	reso	21C00038	C 2	600PP	345284
2731	37	99	4.68	178	DNG	P 1	TSH	+12.62	TECTEH			H2949	seco	21H00044	H 0	600UL	340881
2732			5.01	179	DNG	P 1	01H	+32.17	TECTEH			H2949	seco	21H00044	H 0	600UL	340881
2733	43	99	4.77	182	DNG	P 1	VM	-1.19	TECTEH			N5877	seco	21H00043	H 0	600UL	340947
2734	45	99	1.43	152	DSI	P 1	VM	-1.66	TECTEH			M7006	reso	21H00044	H 0	600UL	340881
2735					NDF		VM	-1.66	VM VM			O1057	prim	21C00084	H 5	5602C	326280
2736	61	99	0.34	75	MBM	5	01H	+25.16	TECTEH			M7006	reso	21H00044	H 0	600UL	340881
2737	65	99	0.41	74	MBM	5	TSH	+31.76	TECTEH			M7006	reso	21H00044	H 0	600UL	340881
2738	83	99	0.39	77	MBM	5	TSH	+34.54	TECTEH			M7006	reso	21H00044	H 0	600UL	340881
2739	85	99	0.49	76	MBM	6	02H	+16.31	TECTEH			L2157	reso	21H00043	H 0	600UL	340947
2740	93	99	2.23	181	DNT	P 1	09C	+0.61	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2741			2.00	183	DNG	P 1	07C	+18.84	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2742	97	99	3.07	184	DNG	P 1	08H	+11.03	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2743			5.95	181	DNG	P 1	08H	+12.73	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2744			3.54	177	DNG	P 1	08H	+14.03	TECTEH			T7451	seco	21H00015	H 0	600UL	340910

SG 21 - All Calls (Excluding NDD and retest codes)

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2745			5.24	180	DNG	P 1	08H	+15.00	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2746			2.15	182	DNG	P 1	08H	+16.44	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2747			4.77	181	DNG	P 1	08H	+17.51	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2748			4.61	181	DNG	P 1	08H	+19.65	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2749			3.18	182	DNT	P 1	09H	-0.90	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2750			2.92	184	DNT	P 1	09H	-0.52	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2751			5.92	180	DNT	P 1	09H	+0.22	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2752			1.80	183	INR	P 1	09C	-0.40	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2753			3.49	182	DNT	P 1	09C	+0.70	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2754	99	99	4.73	179	DNG	P 1	09H	+1.84	TECTEH			D4576	seco	21H00016	H 0	600UL	332255
2755					INF		09H	+2.99	TECTEH	HR		C3340	reso	21H00016	H 0	600UL	332255
2756	101	99	0.52	131	23	P 2	VH	-0.64	TECTEH			P5436	prim	21H00015	H 0	600UL	340910
2757			0.40	89	19	P 2	VM	+1.93	TECTEH			P5436	prim	21H00015	H 0	600UL	340910
2758			3.02	178	DNG	P 1	02C	+23.90	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2759			2.71	175	DNG	P 1	01C	+6.19	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2760	107	99	1.96	180	INR	P 1	VM	+2.96	TECTEH			F6623	reso	21H00016	H 0	600UL	332255
2761	109	99	2.01	181	DNG	P 1	VC	+13.77	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2762	113	99			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
2763			0.38	58	SAI	1	TSH	+0.80	TSHTSH	0.6		C5542	reso	21H00161	H 1	600PP	345335
2764			0.29	108	PID	4	TSH	+0.80	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
2765			0.26	118	SAI	2	TSH	+0.80	TSHTSH	0.8		C5542	reso	21H00161	H 1	600PP	345335
2766	115	99	2.01	184	DNG	P 1	09H	+20.84	TECTEH			D4576	seco	21H00016	H 0	600UL	332255
			1.12	82	MBM	5	VH	+6.14	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
[illegible]			0.98	74	MBM	5	VH	+7.92	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
2769	119	99	2.48	176	DNG	P 1	VM	+30.38	TECTEH			D4576	seco	21H00016	H 0	600UL	332255
2770			2.57	173	DNT	P 1	VC	+1.90	TECTEH			D4576	seco	21H00016	H 0	600UL	332255
2771			5.35	176	INR	P 1	10C	+1.64	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
2772	121	99	5.20	181	DNG	P 1	10C	+3.81	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2773	125	99	2.03	175	DNG	P 1	03H	+23.36	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2774	32	100	1.43	94	MBM	5	02C	+33.29	TECTEH			L2157	reso	21H00043	H 0	600UL	340947
2775	74	100	0.45	74	MBM	5	04H	+2.64	TECTEH			M7006	reso	21H00044	H 0	600UL	340881
2776			3.83	184	DNG	P 1	08H	+7.06	TECTEH			H2949	seco	21H00044	H 0	600UL	340881
2777	76	100	2.44	183	DNG	P 1	08H	+9.06	TECTEH			N5877	seco	21H00043	H 0	600UL	340947
2778	78	100	2.50	188	DNG	P 1	06H	+15.51	TECTEH			H2949	seco	21H00044	H 0	600UL	340881
2779	80	100	16.93	178	DNG	P 1	03C	+28.17	TECTEH			N5877	seco	21H00043	H 0	600UL	340947
2780	82	100			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
2781			0.08	90	SAI	2	TSH	+0.68	TSHTSH	0.2		A9608	reso	21H00137	H 1	600PP	345334
2782			0.00	0	SAI	1	TSH	+0.68	TSHTSH	0.0		A9608	reso	21H00137	H 1	600PP	345334
2783			0.09	105	PID	4	TSH	+0.68	TSHTSH	080		F3453	reso	21H00175	H999	600PP	345339
2784	92	100	3.12	179	DNG	P 1	02C	+21.16	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2785	94	100			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
2786			0.57	59	NQI	P 1	TSH	+0.92	TECTEH			D4576	seco	21H00016	H 0	600UL	332255
2787			0.28	73	MAI	1	TSH	+1.03	TSHTSH	0.2		A9608	reso	21H00162	H 1	600PP	345334
2788			0.12	88	MAI	2	TSH	+1.03	TSHTSH	0.2		A9608	reso	21H00162	H 1	600PP	345334
2789			0.12	101	PID	4	TSH	+1.03	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
2790			2.91	94	MBM	5	04C	+5.91	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
2791	98	100	3.56	178	DNG	P 1	07C	+10.03	TECTEH			D4576	seco	21H00016	H 0	600UL	332255
[illegible]	100	100	4.16	189	DNG	P 1	TSH	+12.86	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
			0.48	74	MBM	5	03C	+3.38	TECTEH			C5542	reso	21H00015	H 0	600UL	340910

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 58

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2794			0.44	52	MBM	5	03C	+6.70	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2795			0.84	86	MBM	5	03C	+16.30	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2796			0.43	93	MBM	5	03C	+18.93	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2797			0.48	93	MBM	5	03C	+19.85	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2798			0.44	109	MBM	5	02C	+30.05	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2799			0.57	85	MBM	5	02C	+31.92	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2800			0.35	111	MBM	5	02C	+32.82	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2801			0.40	104	MBM	5	02C	+34.09	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2802			0.64	81	MBM	5	02C	+34.84	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2803			0.49	89	MBM	5	02C	+35.98	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2804	102	100	0.95	103	MBM	5	07H	+11.77	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
2805	104	100			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
2806			0.10	87	PID	4	TSH	+0.61	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
2807			0.12	72	SAI	2	TSH	+0.61	TSHTSH	0.2		C5542	reso	21H00161	H 1	600PP	345335
2808			0.00	0	SAI	1	TSH	+0.61	TSHTSH	0.0		C5542	reso	21H00161	H 1	600PP	345335
2809			0.00	0	SAI	1	TSH	+0.84	TSHTSH	0.2		C5542	reso	21H00161	H 1	600PP	345335
2810			0.06	87	SAI	2	TSH	+0.84	TSHTSH	0.2		C5542	reso	21H00161	H 1	600PP	345335
2811	106	100	3.85	175	DNG	P 1	01H	+20.81	TECTEH			D4576	seco	21H00016	H 0	600UL	332255
2812	112	100	1.70	192	INR	P 1	07C	+6.96	TECTEH			D3858	reso	21H00015	H 0	600UL	340910
			0.72	54	MBM	6	05C	+5.80	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
[illegible]			0.36	97	INR	10	TSC	+2.28	TSCTSC			C5542	reso	21C00017	C 2	600PP	345292
2815	116	100	1.93	186	INR	P 1	VH	+28.39	TECTEH			D3858	reso	21H00015	H 0	600UL	340910
2816	120	100	3.11	181	DNT	P 1	10H	-0.04	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2817			0.83	95	MBM	5	VH	+3.83	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2818			2.22	89	MBM	5	VH	+13.59	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2819			0.94	98	MBM	5	VH	+16.07	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2820			0.46	81	MBM	5	VH	+21.49	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2821			7.21	183	DNG	P 1	VC	+18.70	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2822			0.62	98	MBM	5	06C	+22.53	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2823	122	100	3.16	175	DNG	P 1	VC	+3.09	TECTEH			D4576	seco	21H00016	H 0	600UL	332255
2824			4.90	181	INR	P 1	10C	+4.45	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
2825	124	100	4.60	181	DNG	P 1	10C	+6.55	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2826	126	100	3.31	174	DNG	P 1	06H	+11.90	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
2827	128	100	3.93	181	DNG	P 1	10H	+16.22	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2828	130	100	0.30	81	INR	9	TSC	+0.23	TSCTSC			C5542	reso	21C00018	C 2	600PP	345299
2829	31	101			TBP				TSHTSH	RMVTBS	ADDTBP	D3858	reso	21H00115	H 1	600PP	326403
2830			0.10	90	PID	4	TSH	+1.46	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
2831			0.15	88	SAI	2	TSH	+1.46	TSHTSH	0.2		F3453	reso	21H00140	H 1	600PP	345335
2832			0.00	0	SAI	1	TSH	+1.46	TSHTSH	0.0		F3453	reso	21H00140	H 1	600PP	345335
2833	33	101			TBP				TSHTSH	RMVTBS	ADDTBP	D3858	reso	21H00115	H 1	600PP	326403
2834			0.12	122	SAI	2	TSH	+1.85	TSHTSH	0.2		L2157	reso	21H00137	H 1	600PP	345334
2835			0.00	0	SAI	1	TSH	+1.85	TSHTSH	0.0		L2157	reso	21H00137	H 1	600PP	345334
2836			0.13	133	PID	4	TSH	+1.85	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
2837	41	101	9.30	184	DNG	P 1	DH	+8.73	TECTEH			H2949	seco	21H00043	H 0	600UL	340947
[illegible]	51	101	0.82	82	MBM	5	06H	+2.80	TECTEH			M7006	reso	21H00044	H 0	600UL	340881
	57	101	3.17	177	DNG	P 1	02C	+8.20	TECTEH			H2949	seco	21H00043	H 0	600UL	340947
2840	59	101	2.53	190	DNG	P 1	02H	+35.70	TECTEH			H2949	seco	21H00044	H 0	600UL	340881
2841			2.14	185	DNG	P 1	06C	+20.54	TECTEH			H2949	seco	21H00044	H 0	600UL	340881
2842			0.59	66	INR	5	02C	+27.36	TECTEH			M7006	reso	21H00044	H 0	600UL	340881

SG 21 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2843	71	101	2.08	191	INR	P 1	05C	-0.68	TECTEH			H2949	seco	21H00044	H 0	600UL	340881
2844	89	101	2.00	179	DNG	P 1	TSH	+21.05	TECTEH			N5877	seco	21H00043	H 0	600UL	340947
2845	93	101	1.78	75	MBM	6	03H	+2.11	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2846	97	101	0.48	73	MBM	5	07C	+21.10	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2847			2.58	176	DNT	P 1	03C	-0.52	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2848	101	101	2.94	178	DNG	P 1	04C	+8.45	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2849	103	101	0.52	93	MBM	5	03H	+15.77	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
2850	109	101	4.46	2	INR	P 1	VC	+13.20	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2851	117	101	3.88	185	DNT	P 1	10H	-0.07	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2852	119	101	1.09	70	MBM	5	08H	+9.17	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
2853			3.21	173	DNG	P 1	04C	+2.28	TECTEH			D4576	seco	21H00016	H 0	600UL	332255
2854	121	101	5.88	185	DNT	P 1	10H	-0.02	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2855	129	101	4.97	19	IDM	2	TSH	+3.80	TSHTSH			B6768	prim	21H00161	H 1	600PP	345335
2856	22	102	0.75	84	MBM	5	01H	+9.78	TECTEH			L2157	reso	21H00101	H 0	600UL	331963
2857			0.49	69	MBM	5	01H	+11.85	TECTEH			L2157	reso	21H00101	H 0	600UL	331963
2858			0.50	78	MBM	5	03H	+5.20	TECTEH			L2157	reso	21H00101	H 0	600UL	331963
			0.75	77	MBM	5	03H	+16.63	TECTEH			L2157	reso	21H00101	H 0	600UL	331963
			0.28	148	VOL	2	04H	+1.99	04H05H			F3453	reso	21H00179	H 3	600PP	345336
2861			0.67	67	MBM	5	04H	+4.80	TECTEH			L2157	reso	21H00101	H 0	600UL	331963
2862			0.44	65	NQI	5	04H	+5.36	TECTEH			L2157	reso	21H00101	H 0	600UL	331963
2863			0.26	142	VOL	2	04H	+5.48	04H05H			F3453	reso	21H00179	H 3	600PP	345336
2864			0.50	77	MBM	5	04H	+34.74	TECTEH			L2157	reso	21H00101	H 0	600UL	331963
2865			0.18	118	VOL	2	04H	+35.16	04H05H			F3453	reso	21H00179	H 3	600PP	345336
2866			0.56	69	MBM	5	04H	+36.34	TECTEH			L2157	reso	21H00101	H 0	600UL	331963
2867			0.21	144	VOL	2	04H	+36.75	04H05H			F3453	reso	21H00179	H 3	600PP	345336
2868			0.66	82	MBM	5	03C	+21.36	TECTEH			L2157	reso	21H00101	H 0	600UL	331963
2869	24	102	7.64	181	DNT	P 1	VM	+1.68	TECTEH			M9715	seco	21H00101	H 0	600UL	331963
2870			7.78	181	DNG	P 1	06C	+12.32	TECTEH			M9715	seco	21H00101	H 0	600UL	331963
2871			3.83	181	DNG	P 1	06C	+15.62	TECTEH			M9715	seco	21H00101	H 0	600UL	331963
2872	26	102	0.82	80	MBM	6	04H	+20.47	TECTEH			M7006	reso	21H00100	H 0	600UL	340988
2873			0.86	82	MBM	6	04H	+21.75	TECTEH			M7006	reso	21H00100	H 0	600UL	340988
2874	36	102	0.53	96	MBM	5	01H	+13.46	TECTEH			M7006	reso	21H00044	H 0	600UL	340881
2875			1.09	79	MBM	6	04H	+12.75	TECTEH			M7006	reso	21H00044	H 0	600UL	340881
2876			3.16	181	DNT	P 1	VM	+1.64	TECTEH			H2949	seco	21H00044	H 0	600UL	340881
2877	42	102	0.96	86	MBM	5	01C	+19.54	TECTEH			L2157	reso	21H00043	H 0	600UL	340947
2878	48	102	2.13	183	DNG	P 1	03C	+24.36	TECTEH			H2949	seco	21H00043	H 0	600UL	340947
2879	70	102	7.64	179	DNG	P 1	07H	+7.01	TECTEH			H4599	seco	21H00043	H 0	600UL	340947
2880			4.34	186	DNG	P 1	07H	+7.48	TECTEH			H4599	seco	21H00043	H 0	600UL	340947
2881			11.64	179	DNG	P 1	07H	+15.57	TECTEH			H4599	seco	21H00043	H 0	600UL	340947
2882					INF		DH	+27.89	TECTEH	HR		L2157	reso	21H00043	H 0	600UL	340947
2883			5.42	183	DNG	P 1	DH	+30.29	TECTEH			H4599	seco	21H00043	H 0	600UL	340947
			3.86	179	DNT	P 1	07C	+0.59	TECTEH			H4599	seco	21H00043	H 0	600UL	340947
			4.17	182	DNT	P 1	07C	+1.20	TECTEH			H4599	seco	21H00043	H 0	600UL	340947
2886			6.37	179	DNG	P 1	07C	+3.12	TECTEH			H4599	seco	21H00043	H 0	600UL	340947
2887			8.02	180	DNG	P 1	07C	+4.12	TECTEH			H4599	seco	21H00043	H 0	600UL	340947
2888			13.37	178	DNG	P 1	07C	+9.55	TECTEH			H4599	seco	21H00043	H 0	600UL	340947
2889	72	102	0.89	95	MBM	5	01H	+6.54	TECTEH			M7006	reso	21H00044	H 0	600UL	340881

2890	74	102	3.72	184	DNG	P 1	08C	+7.32	TECTEH				H4599	seco	21H00043	H 0	600UL	340947
2891	76	102	2.62	184	DNG	P 1	08H	+9.33	TECTEH				H4599	seco	21H00043	H 0	600UL	340947

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 60

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2892	84	102	4.49	186	DNG	P 1	VM	+14.35	TECTEH			H4599	seco	21H00043	H 0	600UL	340947
2893	86	102	2.89	183	DNG	P 1	02C	+17.63	TECTEH			H4599	seco	21H00043	H 0	600UL	340947
2894	92	102	0.68	87	MBM	5	05H	+23.79	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2895			1.71	179	INR	P 1	01C	+35.94	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2896	120	102	7.01	177	DNG	P 1	VC	+18.88	TECTEH			D4576	seco	21H00016	H 0	600UL	332255
2897	122	102	14.90	180	DNT	P 1	10H	-0.02	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2898			2.43	182	DNT	P 1	10H	+0.44	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2899	126	102	4.35	183	DNG	P 1	TSH	+14.99	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2900	130	102	0.23	70	PLP	9	TSC	+0.43	TSCTSC			N2574	seco	21C00016	C 2	600PP	345299
2901	23	103	0.78	75	MBM	5	01H	+28.26	TECTEH			M7006	reso	21H00100	H 0	600UL	340988
2902	31	103	4.85	184	DNG	P 1	01H	+18.73	TECTEH			M2655	seco	21H00100	H 0	600UL	340988
2903			4.81	189	DNG	P 1	04C	+33.97	TECTEH			M2655	seco	21H00100	H 0	600UL	340988
2904			0.59	76	MBM	5	01C	+8.95	TECTEH			M7006	reso	21H00100	H 0	600UL	340988
			0.62	85	MBM	5	TSC	+9.10	TECTEH			M7006	reso	21H00100	H 0	600UL	340988
			0.46	87	MBM	5	TSC	+15.14	TECTEH			M7006	reso	21H00100	H 0	600UL	340988
2907	41	103	10.14	184	DNG	P 1	TSH	+12.26	TECTEH			F7467	seco	21H00048	H 0	600UL	340881
2908	47	103	2.64	181	DNG	P 1	02C	+11.42	TECTEH			F7467	seco	21H00048	H 0	600UL	340881
2909	65	103	0.81	66	MBM	5	TSH	+15.42	TECTEH			L2157	reso	21H00043	H 0	600UL	340947
2910	67	103	0.62	92	MBM	5	02H	+12.57	TECTEH			M7006	reso	21H00044	H 0	600UL	340881
2911			0.60	91	MBM	5	03H	+1.64	TECTEH			M7006	reso	21H00044	H 0	600UL	340881
2912	79	103			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
2913			0.16	105	PID	4	TSH	+2.01	TSHTSH	080		F3453	reso	21H00175	H999	600PP	345339
2914			0.12	108	SAI	2	TSH	+2.01	TSHTSH	0.2		F3453	reso	21H00140	H 1	600PP	345335
2915			0.00	0	SAI	1	TSH	+2.01	TSHTSH	0.0		F3453	reso	21H00140	H 1	600PP	345335
2916	89	103	5.80	180	DNT	P 1	04C	-0.15	TECTEH			H4599	seco	21H00043	H 0	600UL	340947
2917	93	103	0.60	71	MBM	6	05H	+22.16	TECTEH			C5542	reso	21H00015	H 0	600UL	340910
2918	103	103	2.44	177	DNT	P 1	09H	+0.02	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2919	109	103	0.45	81	MBM	5	02H	+23.92	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
2920	113	103	2.68	181	INR	P 1	09C	+18.85	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
2921	115	103	3.05	179	DNG	P 1	08C	+21.33	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2922	117	103	9.56	183	INR	P 1	10C	+0.33	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
2923	119	103	2.98	181	DNG	P 1	10C	+2.01	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
2924	121	103	0.88	51	MBM	5	09H	+14.28	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
2925			4.40	180	DNG	P 1	VM	+28.22	TECTEH			D4576	seco	21H00016	H 0	600UL	332255
2926			0.76	66	MBM	6	04C	+7.91	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
2927	20	104	3.19	183	DNG	P 1	06H	+12.30	TECTEH			M9715	seco	21H00101	H 0	600UL	331963
2928	24	104	6.50	182	DNT	P 1	VM	+1.84	TECTEH			L2157	reso	21H00101	H 0	600UL	331963
2929			6.10	179	DNG	P 1	06C	+12.17	TECTEH			M9715	seco	21H00101	H 0	600UL	331963
			2.75	179	DNG	P 1	03C	+35.91	TECTEH			M9715	seco	21H00101	H 0	600UL	331963
	36	104	3.34	177	DNG	P 1	TSC	+7.06	TECTEH			F7467	seco	21H00048	H 0	600UL	340881
2932	40	104	0.63	75	MBM	5	06H	+8.18	TECTEH			M7006	reso	21H00048	H 0	600UL	340881
2933	64	104	2.78	187	DNG	P 1	05C	+32.99	TECTEH			F7467	seco	21H00048	H 0	600UL	340881
2934			0.32	77	MBM	5	01C	+14.66	TECTEH			M7006	reso	21H00048	H 0	600UL	340881
2935	70	104	0.49	75	MBM	5	DH	+27.66	TECTEH			M7006	reso	21H00047	H 0	600UL	340947

2936			0.49	81	MBM	5	DH	+28.72	TECTEH			M7006	reso	21H00047	H	0	600UL	340947
2937	72	104	0.71	79	MBM	5	07C	+9.22	TECTEH			M7006	reso	21H00048	H	0	600UL	340881
2938	76	104	1.99	181	INR	P 1	07H	+21.68	TECTEH			M7006	reso	21H00047	H	0	600UL	340947
	78	104	3.42	184	DNG	P 1	08C	+10.73	TECTEH			M7006	reso	21H00047	H	0	600UL	340947
	92	104			NDF		09H	+0.26	09H09H			R3710	prim	21H00179	H	6	600PP	345336

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 61

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2941			8.96	179	DNT	P 1	09H	+0.27	TECTEH			T7451	seco	21H00015	H	0 600UL	340910
2942	98	104	2.40	174	DNG	P 1	01H	+8.60	TECTEH			D4576	seco	21H00016	H	0 600UL	332255
2943	104	104	0.74	87	MBM	5	01H	+25.23	TECTEH			C5542	reso	21H00015	H	0 600UL	340910
2944	120	104	6.14	181	DNG	P 1	VC	+18.93	TECTEH			C5542	reso	21H00015	H	0 600UL	340910
2945	124	104	3.60	184	DNT	P 1	10H	-0.02	TECTEH			T7451	seco	21H00015	H	0 600UL	340910
2946	126	104			INF		TSH	+0.54	TSHTSH	HR		M7006	reso	21H00162	H	1 600PP	345334
2947	130	104	0.38	76	PLP	9	TSH	+0.60	TSHTSH			K2032	seco	21H00162	H	1 600PP	345334
2948	17	105	11.74	184	DNG	P 1	06H	+8.93	TECTEH			M2655	seco	21H00100	H	0 600UL	340988
2949			12.33	180	DNG	P 1	06H	+10.60	TECTEH			M2655	seco	21H00100	H	0 600UL	340988
2950			7.48	179	DNT	P 1	DH	+1.87	TECTEH			M2655	seco	21H00100	H	0 600UL	340988
	21	105	0.36	85	MBM	5	04H	+26.27	TECTEH			M7006	reso	21H00100	H	0 600UL	340988
			0.77	84	MBM	5	03C	+17.23	TECTEH			M7006	reso	21H00100	H	0 600UL	340988
2953			0.36	72	MBM	5	TSC	+36.61	TECTEH			M7006	reso	21H00100	H	0 600UL	340988
2954	35	105	0.58	93	MBM	5	02H	+17.27	TECTEH			M7006	reso	21H00047	H	0 600UL	340947
2955			1.43	84	MBM	5	03H	+25.80	TECTEH			M7006	reso	21H00047	H	0 600UL	340947
2956	37	105	0.60	79	MBM	5	TSH	+28.52	TECTEH			M7006	reso	21H00048	H	0 600UL	340881
2957			0.67	80	MBM	5	01C	+21.04	TECTEH			M7006	reso	21H00048	H	0 600UL	340881
2958			0.77	83	MBM	5	01C	+22.31	TECTEH			M7006	reso	21H00048	H	0 600UL	340881
2959	49	105	2.80	178	DNG	P 1	04C	+2.83	TECTEH			F7467	seco	21H00048	H	0 600UL	340881
2960			2.38	175	DNG	P 1	04C	+4.08	TECTEH			F7467	seco	21H00048	H	0 600UL	340881
2961	57	105	27.00	179	DNG	P 1	02C	+9.01	TECTEH			F7467	seco	21H00048	H	0 600UL	340881
2962	61	105	0.99	92	MBM	5	04H	+7.07	TECTEH			M7006	reso	21H00048	H	0 600UL	340881
2963			7.39	178	DNG	P 1	DH	+5.16	TECTEH			F7467	seco	21H00048	H	0 600UL	340881
2964	65	105	0.57	66	MBM	5	01H	+33.03	TECTEH			M7006	reso	21H00048	H	0 600UL	340881
2965	87	105	0.37	66	MBM	5	06C	+7.44	TECTEH			M7006	reso	21H00048	H	0 600UL	340881
2966	99	105	2.95	4	INR	P 1	02C	+6.23	TECTEH			C3340	reso	21H00016	H	0 600UL	332255
2967	111	105	4.76	180	INR	P 1	09C	+17.37	TECTEH			C3340	reso	21H00016	H	0 600UL	332255
2968	113	105	0.75	85	MBM	5	VC	+18.30	TECTEH			C5542	reso	21H00015	H	0 600UL	340910
2969	115	105	3.47	177	INR	P 1	09C	+20.93	TECTEH			C3340	reso	21H00016	H	0 600UL	332255
2970			2.72	184	INR	P 1	09C	+21.41	TECTEH			C3340	reso	21H00016	H	0 600UL	332255
2971	117	105	6.32	181	DNT	P 1	10C	+0.56	TECTEH			T7451	seco	21H00015	H	0 600UL	340910
2972	119	105	1.05	183	INR	P 1	DH	+13.21	TECTEH			D4576	seco	21H00016	H	0 600UL	332255
2973			4.38	170	DNG	P 1	DH	+15.99	TECTEH			D4576	seco	21H00016	H	0 600UL	332255
2974			5.19	180	INR	P 1	10C	+2.35	TECTEH			C3340	reso	21H00016	H	0 600UL	332255
2975			0.52	176	INR	P 1	10C	+4.15	TECTEH			D4576	seco	21H00016	H	0 600UL	332255
			4.46	178	INR	P 1	10C	+4.92	TECTEH			C3340	reso	21H00016	H	0 600UL	332255
	125	105	0.66	88	INR	6	TSC	+2.35	TECTEH			C5542	reso	21H00015	H	0 600UL	340910
2978	127	105	0.74	72	MBM	5	02H	+15.51	TECTEH			C3340	reso	21H00016	H	0 600UL	332255
2979			0.81	84	MBM	5	03H	+28.22	TECTEH			C3340	reso	21H00016	H	0 600UL	332255
2980	12	106	9.32	182	DNG	P 1	06H	+8.25	TECTEH			M9715	seco	21H00101	H	0 600UL	331963
2981	14	106	4.23	179	DNG	P 1	06H	+9.04	TECTEH			M2655	seco	21H00100	H	0 600UL	340988

2982			3.52	177	DNT	P	1	VM	-1.57		TECTEH				M2655	seco	21H00100	H 0	600UL	340988
2983	18	106	0.58	218	PVN		2	TSC	-5.99	TO+3.13	TSCTSC				M0945	seco	21C00026	C 2	600PP	340923
2984	20	106	3.60	184	DNG	P	1	06H	+11.95		TECTEH				M9715	seco	21H00101	H 0	600UL	331963
	24	106	6.65	182	DNT	P	1	VM	+1.78		TECTEH				L2157	reso	21H00101	H 0	600UL	331963
			6.11	180	DNG	P	1	06C	+12.10		TECTEH				M9715	seco	21H00101	H 0	600UL	331963
2987	28	106	0.77	69	MBM		5	01H	+12.64		TECTEH				L2157	reso	21H00101	H 0	600UL	331963
2988	42	106			INF			02C	+30.78		TECTEH	HR			M7006	reso	21H00047	H 0	600UL	340947
2989			0.73	88	MBM		5	02C	+30.88		TECTEH				M7006	reso	21H00047	H 0	600UL	340947

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 62

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
2990	70	106			INF		DH	+27.45	TECTEH	HR		M7006	reso	21H00047	H 0	600UL	340947
2991			2.01	183	DNG	P	1	DH	+29.99	TECTEH		F7467	seco	21H00047	H 0	600UL	340947
2992	86	106	2.94	182	DNG	P	1	02C	+23.83	TECTEH		F7467	seco	21H00047	H 0	600UL	340947
2993	88	106			TBS					TSHTSH		D3858	reso	21H00115	H 1	600PP	326403
2994			0.00	0	SAI		1	TSH	+0.53	TSHTSH	0.0	F3453	reso	21H00140	H 1	600PP	345335
2995			0.07	101	SAI		2	TSH	+0.53	TSHTSH	0.2	F3453	reso	21H00140	H 1	600PP	345335
2996			0.15	102	PID		4	TSH	+0.84	TSHTSH	080	A9608	reso	21H00184	H999	600PP	345336
			0.13	101	MAI		1	TSH	+0.84	TSHTSH	0.3	F3453	reso	21H00140	H 1	600PP	345335
			0.16	102	MAI		2	TSH	+0.84	TSHTSH	0.3	F3453	reso	21H00140	H 1	600PP	345335
2999	92	106	2.26	179	DNT	P	1	09H	-0.24	TECTEH		T7451	seco	21H00015	H 0	600UL	340910
3000	98	106	2.09	175	DNG	P	1	TSC	+32.84	TECTEH		D4576	seco	21H00016	H 0	600UL	332255
3001	100	106	0.56	32	INR	P	1	09H	+0.15	TECTEH		A9608	reso	21H00015	H 0	600UL	340910
3002					NDF			09C	+0.15	09C09C		F6623	reso	21C00083	C 4	600PP	345344
3003			0.55	142	DSI	P	1	09C	+0.15	TECTEH		A9608	reso	21H00015	H 0	600UL	340910
3004	104	106	5.43	4	INR	P	1	09C	+13.14	TECTEH		T7451	seco	21H00015	H 0	600UL	340910
3005	112	106	4.18	181	DNG	P	1	09C	+18.52	TECTEH		T7451	seco	21H00015	H 0	600UL	340910
3006	116	106	4.11	182	DNG	P	1	VH	+29.49	TECTEH		T7451	seco	21H00015	H 0	600UL	340910
3007			10.17	184	DNG	P	1	VM	+1.90	TECTEH		T7451	seco	21H00015	H 0	600UL	340910
3008			8.32	187	DNG	P	1	VM	+2.75	TECTEH		T7451	seco	21H00015	H 0	600UL	340910
3009			3.01	182	DNG	P	1	VM	+3.30	TECTEH		T7451	seco	21H00015	H 0	600UL	340910
3010			4.30	182	DNG	P	1	VM	+4.42	TECTEH		T7451	seco	21H00015	H 0	600UL	340910
3011	120	106	7.27	183	DNG	P	1	VC	+18.92	TECTEH		T7451	seco	21H00015	H 0	600UL	340910
3012	124	106	0.98	93	MBM		5	09C	+4.18	TECTEH		C5542	reso	21H00015	H 0	600UL	340910
3013	126	106	2.21	178	DNG	P	1	TSH	+22.05	TECTEH		C3340	reso	21H00016	H 0	600UL	332255
3014			2.18	181	DNG	P	1	05H	+10.20	TECTEH		D4576	seco	21H00016	H 0	600UL	332255
3015	130	106	0.30	79	PLP		9	TSH	+0.10	TSHTSH		K2032	seco	21H00162	H 1	600PP	345334
3016			0.92	78	MBM		6	VC	+22.15	TECTEH		C3340	reso	21H00016	H 0	600UL	332255
3017	7	107	2.02	183	DNG	P	1	01C	+6.71	TECTEH		M9715	seco	21H00101	H 0	600UL	331963
3018			3.40	183	DNG	P	1	01C	+10.83	TECTEH		M9715	seco	21H00101	H 0	600UL	331963
3019			2.88	186	DNG	P	1	01C	+14.81	TECTEH		L2157	reso	21H00101	H 0	600UL	331963
3020			3.60	182	DNG	P	1	TSC	+23.22	TECTEH		M9715	seco	21H00101	H 0	600UL	331963
3021	17	107	4.20	180	DNG	P	1	DC	-1.42	TECTEH		M2655	seco	21H00100	H 0	600UL	340988
			8.41	178	DNG	P	1	06C	+10.44	TECTEH		M2655	seco	21H00100	H 0	600UL	340988
	21	107	3.39	183	DNT	P	1	02C	-0.75	TECTEH		M2655	seco	21H00100	H 0	600UL	340988
3024	37	107	2.48	181	DNG	P	1	06C	+4.32	TECTEH		T2170	seco	21H00052	H 0	600UL	340950
3025	45	107			TBP					TSHTSH	RMVTBS	D3858	reso	21H00115	H 1	600PP	326403
3026			0.08	125	SAI		2	TSH	+1.90	TSHTSH	0.3	F3453	reso	21H00144	H 1	600PP	345335
3027			0.00	0	SAI		1	TSH	+1.90	TSHTSH	0.0	F3453	reso	21H00144	H 1	600PP	345335

3028			0.06	90	SAI	2	TSH	+2.27	TSHTSH	0.2			F3453	reso	21H00144	H 1	600PP	345335
3029			0.00	0	SAI	1	TSH	+2.27	TSHTSH	0.0			F3453	reso	21H00144	H 1	600PP	345335
3030			0.08	93	PID	4	TSH	+2.27	TSHTSH	080			F3453	reso	21H00177	H999	600PP	345336
	47	107	0.44	72	MBM	5	06H	+5.98	TECTEH				M7006	reso	21H00047	H 0	600UL	340947
	59	107	0.83	73	MBM	6	04C	+5.81	TECTEH				M7006	reso	21H00047	H 0	600UL	340947
3033	71	107	1.61	85	MBM	5	05H	+4.55	TECTEH				M7006	reso	21H00047	H 0	600UL	340947
3034			2.14	88	MBM	5	06H	+20.66	TECTEH				M7006	reso	21H00047	H 0	600UL	340947
3035			3.72	182	DNG	P 1	08C	+4.45	TECTEH				F7467	seco	21H00047	H 0	600UL	340947
3036	81	107			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3037			0.13	121	PID	4	TSH	+0.33	TSHTSH	080			F3453	reso	21H00175	H999	600PP	345339
3038			0.16	80	SAI	1	TSH	+0.33	TSHTSH	0.3			C5542	reso	21H00141	H 1	600PP	345334

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 63

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3039			0.12	117	SAI	2	TSH	+0.33	TSHTSH	0.3		C5542	reso	21H00141	H 1	600PP	345334
3040	101	107	3.49	181	DNG	P 1	01C	+16.14	TECTEH			D4576	seco	21H00016	H 0	600UL	332255
3041	113	107	4.52	180	INR	P 1	09C	+18.56	TECTEH			M1680	reso	21H00016	H 0	600UL	332255
3042	117	107	3.49	189	INR	P 1	10C	+0.44	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
	119	107	5.56	182	DNG	P 1	10C	+2.05	TECTEH			T7451	seco	21H00015	H 0	600UL	340910
	121	107	0.59	62	INR	5	TSC	+2.05	TECTEH			C3340	reso	21H00016	H 0	600UL	332255
3045	125	107	5.53	181	DNT	P 1	10H	-0.24	TECTEH			D4576	seco	21H00016	H 0	600UL	332255
3046	131	107	0.26	76	PLP	9	TSH	+0.23	TSHTSH			K2032	seco	21H00162	H 1	600PP	345334
3047	6	108	5.65	181	DNT	P 1	VM	-0.03	TECTEH			M9715	seco	21H00101	H 0	600UL	331963
3048			4.64	179	DNT	P 1	VM	+0.28	TECTEH			M9715	seco	21H00101	H 0	600UL	331963
3049	18	108	4.12	179	DNG	P 1	03C	+36.67	TECTEH			M9715	seco	21H00101	H 0	600UL	331963
3050	26	108	0.82	71	MBM	5	05C	+23.08	TECTEH			L2157	reso	21H00101	H 0	600UL	331963
3051	36	108	24.98	178	DNG	P 1	TSH	+28.76	TECTEH			M2655	seco	21H00100	H 0	600UL	340988
3052			2.37	179	DNT	P 1	VM	+1.29	TECTEH			M2655	seco	21H00100	H 0	600UL	340988
3053	42	108	4.17	190	DNG	P 1	02H	+17.79	TECTEH			T2170	seco	21H00052	H 0	600UL	340950
3054	72	108	7.89	183	DNG	P 1	01H	+16.20	TECTEH			H2949	seco	21H00051	H 0	600UL	340947
3055			4.09	183	DNG	P 1	01H	+18.40	TECTEH			H2949	seco	21H00051	H 0	600UL	340947
3056	74	108	4.93	181	DNG	P 1	08C	+7.25	TECTEH			T2170	seco	21H00052	H 0	600UL	340950
3057	86	108	4.15	175	DNG	P 1	VH	+26.37	TECTEH			T2170	seco	21H00052	H 0	600UL	340950
3058	92	108	3.55	187	DNT	P 1	09C	-0.56	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3059			5.44	181	DNT	P 1	09C	+0.30	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3060	94	108	2.42	179	DNG	P 1	09C	+2.16	TECTEH			H4599	seco	21H00022	H 0	600UL	332255
3061	98	108	4.00	184	DNG	P 1	09C	+6.02	TECTEH			H4599	seco	21H00022	H 0	600UL	332255
3062			4.52	184	DNG	P 1	09C	+7.25	TECTEH			H4599	seco	21H00022	H 0	600UL	332255
3063	108	108	3.51	6	IDM	2	TSH	+1.87	TSHTSH			B6768	prim	21H00161	H 1	600PP	345335
3064			1.95	7	IDM	2	TSH	+2.59	TSHTSH			B6768	prim	21H00161	H 1	600PP	345335
3065	110	108	5.47	181	DNG	P 1	09C	+16.97	TECTEH			H4599	seco	21H00022	H 0	600UL	332255
3066	112	108	2.37	184	DNG	P 1	09C	+17.39	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3067	118	108	2.75	180	DNG	P 1	10H	+1.02	TECTEH			S4373	reso	21H00022	H 0	600UL	332255
	120	108	8.41	182	DNG	P 1	VC	+19.30	TECTEH			C5542	reso	21H00021	H 0	600UL	340910
	128	108	1.23	43	MBM	6	04H	+24.95	TECTEH			C5542	reso	21H00021	H 0	600UL	340910
3070			0.98	82	MBM	5	TSC	+32.34	TECTEH			C5542	reso	21H00021	H 0	600UL	340910
3071	130	108	1.00	86	MBM	5	VH	+11.70	TECTEH			D8661	reso	21H00022	H 0	600UL	332255
3072	132	108	3.92	181	DNT	P 1	10H	+0.02	TEHTEC			D4576	seco	21C00061	H 0	600CS	341612
3073	13	109	2.77	178	DNG	P 1	TSH	+18.99	TECTEH			M2655	seco	21H00100	H 0	600UL	340988

3074	17	109			INF		DC	-1.89	TECTEH	HR		D3858	reso	21H00101	H 0	600UL	331963
3075			5.81	181	DNT	P 1	DC	+1.93	TECTEH			L2157	reso	21H00101	H 0	600UL	331963
3076			7.38	178	DNG	P 1	06C	+10.23	TECTEH			M9715	seco	21H00101	H 0	600UL	331963
[illegible]	19	109			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
[illegible]			0.97	217	PID	3	SBH	+22.61	SBHSTH			D3858	prim	21H00226	H999	500PP	326656
[illegible]					DIS	3	SBH	+22.61	SBHSTH			P6179	seco	21H00225	H10	500PP	326656
3080			0.12	144	PID	4	TSH	+1.33	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
3081			0.00	0	SAI	1	TSH	+1.33	TSHTSH	0.0		F3453	reso	21H00144	H 1	600PP	345335
3082			0.09	101	SAI	2	TSH	+1.33	TSHTSH	0.7		F3453	reso	21H00144	H 1	600PP	345335
3083			0.09	108	SAI	2	TSH	+1.83	TSHTSH	0.3		F3453	reso	21H00144	H 1	600PP	345335
3084			0.00	0	SAI	1	TSH	+1.83	TSHTSH	0.0		F3453	reso	21H00144	H 1	600PP	345335
3085	21	109	4.17	184	DNG	P 1	06H	+12.68	TECTEH			M9715	seco	21H00101	H 0	600UL	331963
3086	37	109	1.28	74	MBM	6	01H	+11.73	TECTEH			C5542	reso	21H00102	H 0	600UL	340988
3087	59	109	0.56	76	MBM	5	01H	+29.84	TECTEH			M7006	reso	21H00052	H 0	600UL	340950

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 64

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3088			0.53	86	MBM	5	04H	+10.28	TECTEH			M7006	reso	21H00052	H 0	600UL	340950
	67	109	3.96	180	DNT	P 1	08C	+0.75	TECTEH			T2170	seco	21H00052	H 0	600UL	340950
	71	109	4.83	179	DNG	P 1	08C	+4.41	TECTEH			T2170	seco	21H00052	H 0	600UL	340950
3091			5.15	9	INR	P 1	08C	+4.90	TECTEH			T2170	seco	21H00052	H 0	600UL	340950
3092	83	109	0.39	85	MBM	5	07H	+15.78	TECTEH			M7006	reso	21H00052	H 0	600UL	340950
3093	87	109	0.68	69	MBM	5	02H	+27.00	TECTEH			M7006	reso	21H00052	H 0	600UL	340950
3094	95	109	14.88	179	DNT	P 1	09H	-0.20	TECTEH			H4599	seco	21H00022	H 0	600UL	332255
3095					NDF		09H	-0.20	09H09H			R3710	prim	21H00179	H 6	600PP	345336
3096	101	109	3.28	183	DNG	P 1	08C	+13.08	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3097	105	109	0.33	11	IDM	2	TSH	+4.40	TSHTSH			N2574	seco	21H00161	H 1	600PP	345335
3098	109	109	3.61	175	DNT	P 1	02H	+0.69	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3099	115	109	4.39	174	DNG	P 1	TSC	+9.60	TECTEH			H4599	seco	21H00022	H 0	600UL	332255
3100	119	109	4.14	183	DNG	P 1	02C	+21.69	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3101	4	110	0.52	79	MBM	5	02H	+21.59	06HTEH			F3453	reso	21H00095	H 9	600UL	340988
3102	20	110	7.85	181	DNG	P 1	06H	+11.94	TECTEH			A9574	seco	21H00102	H 0	600UL	340988
3103	22	110	0.68	88	MBM	5	02C	+26.21	TECTEH			C5542	reso	21H00102	H 0	600UL	340988
3104	70	110	0.89	75	MBM	5	02C	+2.16	TECTEH			L2157	reso	21H00051	H 0	600UL	340947
3105			1.08	77	MBM	5	02C	+8.99	TECTEH			L2157	reso	21H00051	H 0	600UL	340947
3106	74	110	2.47	184	DNG	P 1	08C	+7.65	TECTEH			H2949	seco	21H00051	H 0	600UL	340947
3107	82	110			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3108			0.14	108	MAI	2	TSH	+0.59	TSHTSH	0.4		F3453	reso	21H00140	H 1	600PP	345335
3109			0.17	53	MAI	1	TSH	+0.59	TSHTSH	0.3		F3453	reso	21H00140	H 1	600PP	345335
3110			0.15	97	PID	4	TSH	+0.59	TSHTSH	080		A9608	reso	21H00184	H999	600PP	345336
3111	92	110	4.56	183	DNG	P 1	07H	+20.35	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3112			5.02	183	DNG	P 1	07H	+20.79	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3113			8.10	182	DNG	P 1	07H	+23.61	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
[illegible]			4.78	178	DNG	P 1	07H	+24.76	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
[illegible]			5.57	184	DNT	P 1	08H	-1.17	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3116			8.59	182	DNT	P 1	08H	-0.67	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3117			17.85	183	DNT	P 1	08H	-0.13	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3118			14.89	182	DNT	P 1	08H	+0.61	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3119			9.01	181	DNG	P 1	08H	+1.29	TECTEH			A9574	seco	21H00021	H 0	600UL	340910

3120			4.43	186	INR	P 1	08H	+1.84	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3121			2.42	182	DNG	P 1	08H	+6.09	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3122			2.88	184	DNG	P 1	08H	+9.95	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
[illegible]			1.49	185	INR	P 1	08H	+15.37	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
			10.43	184	DNG	P 1	08H	+15.86	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3125			7.90	179	DNT	P 1	09C	-0.06	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3126			9.36	183	DNT	P 1	09C	+0.35	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3127			45.67	181	DNG	P 1	09C	+0.88	TECTEH			S4373	reso	21H00021	H 0	600UL	340910
3128			2.40	183	DNG	P 1	08C	+3.88	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3129			3.35	179	DNG	P 1	08C	+10.54	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3130			3.77	184	INR	P 1	08C	+10.88	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3131			19.34	183	DNG	P 1	08C	+11.68	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3132			23.20	181	DNG	P 1	08C	+12.34	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3133			14.96	181	DNG	P 1	08C	+13.76	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3134			3.74	183	DNG	P 1	08C	+14.68	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3135			2.21	181	DNG	P 1	08C	+16.07	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3136	98	110	2.96	20	DSI	P 1	09H	+0.00	TECTEH			B4165	prim	21H00022	H 0	600UL	332255

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 65

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3137					NDF		09H	+0.00	09H09H			F3453	reso	21H00179	H 3	600PP	345336
3138	108	110	3.33	180	DNG	P 1	09C	+14.17	TECTEH			A9574	seco	21H00021	H 0	600UL	340910
3139	118	110	8.68	177	DNT	P 1	10H	+0.00	TECTEH			H4599	seco	21H00022	H 0	600UL	332255
3140	120	110	0.46	47	INR	5	02H	+25.75	TECTEH			S4373	reso	21H00021	H 0	600UL	340910
3141			7.99	179	DNG	P 1	VC	+19.17	TECTEH			C5542	reso	21H00021	H 0	600UL	340910
3142	19	111			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3143			0.30	52	SAI	1	TSH	+0.20	TSHTSH	0.3		N5432	reso	21H00145	H 1	600PP	345334
3144			0.28	118	PID	4	TSH	+0.20	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
3145			0.21	114	SAI	2	TSH	+0.20	TSHTSH	0.6		N5432	reso	21H00145	H 1	600PP	345334
3146	21	111	0.80	86	MBM	5	01H	+37.01	TECTEH			C5542	reso	21H00102	H 0	600UL	340988
3147			2.86	182	DNG	P 1	06H	+12.72	TECTEH			A9574	seco	21H00102	H 0	600UL	340988
3148	25	111	2.21	186	DNT	P 1	VM	-2.18	TECTEH			A9574	seco	21H00102	H 0	600UL	340988
3149	35	111	1.32	98	MBM	5	03H	+23.20	TECTEH			C5542	reso	21H00102	H 0	600UL	340988
3150	45	111			TBP				TSHTSH	RMVTBS	ADDTBP	D3858	reso	21H00115	H 1	600PP	326403
3151			0.11	79	SAI	2	TSH	+1.04	TSHTSH	0.2		N5432	reso	21H00145	H 1	600PP	345334
3152			0.00	0	SAI	1	TSH	+1.04	TSHTSH	0.0		N5432	reso	21H00145	H 1	600PP	345334
3153			0.07	84	PID	4	TSH	+1.04	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
3154	55	111	0.66	68	MBM	5	02H	+19.41	TECTEH			M7006	reso	21H00052	H 0	600UL	340950
3155			0.44	91	MBM	5	02H	+23.78	TECTEH			M7006	reso	21H00052	H 0	600UL	340950
3156			0.40	64	MBM	5	02H	+33.23	TECTEH			M7006	reso	21H00052	H 0	600UL	340950
3157			0.46	74	MBM	5	03H	+3.02	TECTEH			M7006	reso	21H00052	H 0	600UL	340950
3158	77	111	2.37	180	DNG	P 1	08C	+9.89	TECTEH			H2949	seco	21H00051	H 0	600UL	340947
3159	101	111	0.43	94	DSI	P 1	09C	+0.21	TECTEH			B4165	prim	21H00022	H 0	600UL	332255
[illegible]					NDF		09C	+0.21	09C09C			F6623	reso	21C00083	C 4	600PP	345344
	107	111	0.72	61	MBM	5	05H	+28.72	TECTEH			C5542	reso	21H00021	H 0	600UL	340910
3162	113	111	1.12	72	MBM	6	VC	+12.99	TECTEH			D8661	reso	21H00022	H 0	600UL	332255
3163	133	111	5.44	86	PLP	9	TSH	+0.36	TSHTSH			B6768	prim	21H00168	H 1	600PP	345335
3164			4.66	183	DNG	P 1	10C	+13.87	TEHTEC			T2170	seco	21C00062	H 0	600CS	341613
3165	4	112	4.09	177	DNT	P 1	VM	-2.62	06HTEC			D4576	seco	21C00064	C 0	600CS	341612

3166			1.17	359	INR	P	1	VM	-2.05	06HTEC			D4576	seco	21C00064	C	0	600CS	341612
3167			2.71	177	INR	P	1	VM	-1.20	06HTEC			A9608	reso	21C00064	C	0	600CS	341612
3168			4.03	178	DNG	P	1	VM	-1.11	06HTEC			A9608	reso	21C00064	C	0	600CS	341612
3169			3.17	181	INR	P	1	VM	-0.10	06HTEC			D4576	seco	21C00064	C	0	600CS	341612
	16	112			TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
3171			0.15	97	MAI		2	TSH	+0.51	TSHTSH	0.8		N5432	reso	21H00145	H	1	600PP	345334
3172			0.16	45	MAI		1	TSH	+0.51	TSHTSH	0.2		N5432	reso	21H00145	H	1	600PP	345334
3173			0.14	104	PID		4	TSH	+0.51	TSHTSH	080		F3453	reso	21H00177	H999		600PP	345336
3174	36	112	3.65	182	DNG	P	1	VM	+2.36	TECTEH			C5542	reso	21H00102	H	0	600UL	340988
3175	44	112	0.61	74	MBM		5	TSH	+21.81	TECTEH			C5542	reso	21H00102	H	0	600UL	340988
3176	52	112	0.84	86	MBM		5	04C	+19.95	TECTEH			L2157	reso	21H00051	H	0	600UL	340947
3177	54	112	0.65	70	MBM		5	01H	+26.13	TECTEH			M7006	reso	21H00052	H	0	600UL	340950
3178	60	112	0.69	86	MBM		6	01C	+22.51	TECTEH			L2157	reso	21H00051	H	0	600UL	340947
3179	74	112	4.65	182	DNG	P	1	08C	+7.36	TECTEH			T2170	seco	21H00052	H	0	600UL	340950
3180	98	112	2.26	186	DNG	P	1	02H	+21.32	TECTEH			H4599	seco	21H00022	H	0	600UL	332255
3181	104	112	5.60	188	DNG	P	1	TSH	+10.82	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3182	116	112	1.94	180	INR	P	1	VH	+28.58	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3183	120	112	3.86	180	DNT	P	1	10H	+0.02	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3184			7.88	182	DNG	P	1	VC	+18.29	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3185	130	112	10.10	85	PLP		9	TSH	+0.18	TSHTSH			K2032	seco	21H00162	H	1	600PP	345334

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 66

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3186			0.56	6	IDM		2	TSH +1.99	TSHTSH			K2032	seco	21H00162	H	1 600PP	345334
3187			0.89	58	MBM		5	TSH +11.97	TECTEH			D8661	reso	21H00022	H	0 600UL	332255
3188	7	113			TBS				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
3189			0.22	63	SAI		1	TSH +0.53	TSHTSH	0.3		F3453	reso	21H00144	H	1 600PP	345335
3190			0.12	105	PID		4	TSH +0.53	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
3191			0.12	72	SAI		2	TSH +0.53	TSHTSH	0.3		F3453	reso	21H00144	H	1 600PP	345335
3192			0.00	0	MAI		1	TSH +0.76	TSHTSH	0.0		F3453	reso	21H00144	H	1 600PP	345335
3193			0.08	71	MAI		2	TSH +0.76	TSHTSH	0.2		F3453	reso	21H00144	H	1 600PP	345335
3194	15	113			TBS				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
3195			0.24	107	PID		4	TSH +0.51	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
3196			0.00	0	MAI		1	TSH +0.51	TSHTSH	0.0		F3453	reso	21H00144	H	1 600PP	345335
3197			0.24	108	MAI		2	TSH +0.51	TSHTSH	0.4		F3453	reso	21H00144	H	1 600PP	345335
3198			0.00	0	MAI		1	TSH +0.84	TSHTSH	0.0		F3453	reso	21H00144	H	1 600PP	345335
3199			0.12	61	MAI		2	TSH +0.84	TSHTSH	0.3		F3453	reso	21H00144	H	1 600PP	345335
3200	17	113	6.01	177	DNT	P	1	VM +1.75	TECTEH			C5542	reso	21H00102	H	0 600UL	340988
3201	23	113			TBS				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
3202			0.13	88	PID		4	TSH +0.42	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
3203			0.00	0	SAI		1	TSH +0.42	TSHTSH	0.0		F3453	reso	21H00144	H	1 600PP	345335
3204			0.13	83	SAI		2	TSH +0.42	TSHTSH	0.2		F3453	reso	21H00144	H	1 600PP	345335
3205			0.83	88	MBM		5	05H +34.09	TECTEH			C5542	reso	21H00102	H	0 600UL	340988
3206			0.66	81	MBM		5	05C +35.76	TECTEH			C5542	reso	21H00102	H	0 600UL	340988
	35	113	3.94	184	DNG	P	1	TSC +32.20	TECTEH			A9574	seco	21H00102	H	0 600UL	340988
3208	43	113	1.12	78	MBM		6	TSH +36.56	TECTEH			C5542	reso	21H00102	H	0 600UL	340988
3209			1.00	77	MBM		6	02H +35.99	TECTEH			C5542	reso	21H00102	H	0 600UL	340988
3210	61	113	4.01	177	DNG	P	1	01H +21.96	TECTEH			H2949	seco	21H00051	H	0 600UL	340947
3211	73	113	1.57	80	MBM		6	06H +1.60	TECTEH			L2157	reso	21H00051	H	0 600UL	340947

3212	83	113	0.97	104	INR	6	TSH	+26.64	TECTEH			L2157	reso	21H00051	H	0	600UL	340947
3213	87	113	0.58	72	MBM	6	VH	+17.04	TECTEH			L2157	reso	21H00051	H	0	600UL	340947
3214	97	113	2.23	182	DNG	P 1	08H	+17.98	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3215			22.51	181	DNT	P 1	09H	-0.07	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
			3.88	180	DNG	P 1	08C	+17.54	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3217			12.49	182	DNG	P 1	08C	+18.54	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3218	107	113	2.93	177	DNG	P 1	01H	+33.14	TECTEH			H4599	seco	21H00022	H	0	600UL	332255
3219	113	113	0.76	68	MBM	6	TSC	+21.58	TECTEH			C5542	reso	21H00021	H	0	600UL	340910
3220	121	113	0.80	72	MBM	5	TSC	+2.42	TECTEH			C5542	reso	21H00021	H	0	600UL	340910
3221	123	113	1.81	85	MBM	6	08C	+21.08	TECTEH			D8661	reso	21H00022	H	0	600UL	332255
3222	131	113	2.38	177	DNT	P 1	10H	+0.04	TECTEH			H4599	seco	21H00022	H	0	600UL	332255
3223	6	114	3.32	182	DNT	P 1	VM	-0.05	TECTEH			L2157	reso	21H00106	H	0	600UL	331889
3224			6.23	182	DNG	P 1	VM	+4.42	TECTEH			F4645	seco	21H00106	H	0	600UL	331889
3225	8	114			TBS				TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
3226			0.00	0	SAI	1	TSH	+0.15	TSHTSH	0.0		F3453	reso	21H00144	H	1	600PP	345335
3227			0.10	118	SAI	2	TSH	+0.15	TSHTSH	0.2		F3453	reso	21H00144	H	1	600PP	345335
3228			0.00	0	SAI	1	TSH	+0.40	TSHTSH	0.0		F3453	reso	21H00144	H	1	600PP	345335
3229			0.13	115	PID	4	TSH	+0.40	TSHTSH	080		F3453	reso	21H00177	H999		600PP	345336
3230			0.13	102	SAI	2	TSH	+0.40	TSHTSH	0.2		F3453	reso	21H00144	H	1	600PP	345335
3231			0.61	59	MBM	5	01H	+16.64	TECTEH			M7006	reso	21H00105	H	0	600UL	340988
3232	22	114	0.63	82	MBM	5	05H	+32.63	TECTEH			L2157	reso	21H00106	H	0	600UL	331889
3233	34	114	1.11	65	MBM	5	02H	+11.52	TECTEH			L2157	reso	21H00106	H	0	600UL	331889
3234	40	114	6.16	182	DNT	P 1	VM	+1.49	TECTEH			T2170	seco	21H00105	H	0	600UL	340988

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 67

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3235	74	114	6.14	182	DNG	P 1	08C	+7.45	TECTEH			T2170	seco	21H00052	H	0 600UL	340950
3236	76	114	0.36	131	INR	P 1	TSH	+0.69	TECTEH			L2157	reso	21H00051	H	0 600UL	340947
3237	82	114	3.29	184	DNT	P 1	DH	-1.52	TECTEH			T2170	seco	21H00052	H	0 600UL	340950
3238	86	114			TBS				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
3239			0.00	0	SAI	1	TSH	+0.61	TSHTSH	0.0		D3858	reso	21H00141	H	1 600PP	345334
3240			0.07	86	SAI	2	TSH	+0.61	TSHTSH	0.2		D3858	reso	21H00141	H	1 600PP	345334
3241			0.12	98	PID	4	TSH	+0.97	TSHTSH	080		A9608	reso	21H00184	H999	600PP	345336
3242			0.14	89	SAI	2	TSH	+0.97	TSHTSH	0.2		D3858	reso	21H00141	H	1 600PP	345334
3243			0.00	0	SAI	1	TSH	+0.97	TSHTSH	0.0		D3858	reso	21H00141	H	1 600PP	345334
3244	120	114	9.19	181	DNG	P 1	VC	+18.25	TECTEH			A9574	seco	21H00021	H	0 600UL	340910
3245	124	114	10.26	180	DNG	P 1	TSH	+37.43	TECTEH			A9574	seco	21H00021	H	0 600UL	340910
3246			0.93	74	INR	5	TSC	+4.50	TECTEH			O1057	prim	21H00021	H	0 600UL	340910
3247	128	114	4.19	183	DNG	P 1	10C	+1.28	TECTEH			A9574	seco	21H00021	H	0 600UL	340910
3248	130	114	2.63	176	DNT	P 1	10H	+0.02	TECTEH			O8795	seco	21H00022	H	0 600UL	332255
3249	1	115			TBP				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
3250			0.77	34	SAI	2	06H	+8.83	06C06H	0.1	PWSCC	D8661	reso	21C00096	C	3 560FH	345361
3251			0.81	25	PID	2	06H	+8.83	06C06H			H4599	seco	21C00099	C999	560FH	326506
[illegible]	15	115	4.62	185	DNG	P 1	02C	+29.48	TECTEH			F4645	seco	21H00106	H	0 600UL	331889
	19	115			TBS				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
3254			0.15	118	MAI	2	TSH	+0.33	TSHTSH	0.4		F3453	reso	21H00144	H	1 600PP	345335
3255			0.00	0	MAI	1	TSH	+0.33	TSHTSH	0.0		F3453	reso	21H00144	H	1 600PP	345335
3256			0.17	111	PID	4	TSH	+0.33	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
3257			0.00	0	SAI	1	TSH	+0.56	TSHTSH	0.0		F3453	reso	21H00144	H	1 600PP	345335

3258			0.06	131	SAI	2	TSH	+0.56	TSHTSH	0.2		F3453	reso	21H00144	H	1	600PP	345335
3259	27	115			TBS				TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
3260			0.12	106	MAI	2	TSH	+0.66	TSHTSH	0.3		F3453	reso	21H00144	H	1	600PP	345335
[illegible]			0.15	92	PID	4	TSH	+0.66	TSHTSH	080		F3453	reso	21H00177	H999		600PP	345336
			0.14	81	MAI	1	TSH	+0.66	TSHTSH	0.3		F3453	reso	21H00144	H	1	600PP	345335
3263	41	115	5.26	186	DNG	P 1	DH	+8.77	TECTEH			T2170	seco	21H00105	H	0	600UL	340988
3264	55	115	0.35	94	MBM	5	04H	+11.54	TECTEH			M7006	reso	21H00056	H	0	600UL	340950
3265	65	115	0.36	83	INR	6	01C	+24.23	TECTEH			L2157	reso	21H00055	H	0	600UL	340947
3266	67	115	2.80	182	DNT	P 1	08C	+0.67	TECTEH			T2170	seco	21H00056	H	0	600UL	340950
3267	73	115	7.64	188	INR	P 1	DH	+3.82	TECTEH			L2157	reso	21H00051	H	0	600UL	340947
3268	87	115	2.16	186	DNG	P 1	TSC	+3.68	TECTEH			H2949	seco	21H00051	H	0	600UL	340947
3269	101	115	4.10	179	DNG	P 1	08C	+8.71	TECTEH			O8795	seco	21H00022	H	0	600UL	332255
3270			2.86	177	DNG	P 1	08C	+19.23	TECTEH			O8795	seco	21H00022	H	0	600UL	332255
3271	107	115	2.96	181	DNG	P 1	08H	+6.08	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3272			10.20	182	DNG	P 1	08H	+7.12	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3273			2.85	185	INR	P 1	08H	+7.76	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3274			2.88	179	DNG	P 1	08C	+11.24	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3275			8.57	181	DNG	P 1	08C	+12.17	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3276			4.05	182	DNG	P 1	08C	+12.53	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3277			2.54	181	DNG	P 1	08C	+13.60	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3278			3.68	180	DNG	P 1	08C	+16.01	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3279			5.36	180	DNG	P 1	08C	+16.98	TECTEH			A9574	seco	21H00021	H	0	600UL	340910
3280	109	115	1.93	179	INR	P 1	VH	+2.53	TECTEH			O8795	seco	21H00022	H	0	600UL	332255
3281	113	115	3.27	180	DNT	P 1	09H	-0.25	TECTEH			O8795	seco	21H00022	H	0	600UL	332255
3282	24	116	0.63	90	MBM	6	05C	+36.63	TECTEH			M7006	reso	21H00105	H	0	600UL	340988
3283	34	116	1.23	84	MBM	5	03H	+25.04	TECTEH			L2157	reso	21H00106	H	0	600UL	331889

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 68

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3284			1.04	96	MBM	5	03C	+20.83	TECTEH			L2157	reso	21H00106	H	0 600UL	331889
3285	40	116	9.54	181	DNT	P 1	VM	+1.55	TECTEH			T2170	seco	21H00105	H	0 600UL	340988
3286	54	116	4.91	184	DNG	P 1	07H	+8.11	TECTEH			T2170	seco	21H00056	H	0 600UL	340950
3287			2.94	180	DNT	P 1	03C	+1.82	TECTEH			T2170	seco	21H00056	H	0 600UL	340950
3288			8.23	181	DNG	P 1	02C	+2.22	TECTEH			T2170	seco	21H00056	H	0 600UL	340950
3289	64	116	2.04	177	DNG	P 1	01C	+18.91	TECTEH			T7451	seco	21H00055	H	0 600UL	340947
3290	86	116	5.49	180	DNG	P 1	08H	+18.26	TECTEH			T7451	seco	21H00055	H	0 600UL	340947
3291	106	116	0.66	88	MBM	5	TSC	+11.97	TECTEH			D8661	reso	21H00022	H	0 600UL	332255
3292	112	116	1.26	92	INR	6	03H	+25.56	TECTEH			O1057	prim	21H00021	H	0 600UL	340910
3293	114	116	0.58	73	MBM	6	TSH	+6.48	TECTEH			D8661	reso	21H00022	H	0 600UL	332255
3294			1.38	71	MBM	6	01H	+23.64	TECTEH			D8661	reso	21H00022	H	0 600UL	332255
3295	1	117			TBP				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
3296			0.92	41	SAI	2	06H	+9.17	06C06H	0.1	PWSCC	D8661	reso	21C00096	C	3 560FH	345361
3297			0.63	24	PID	2	06H	+9.17	06C06H			J9815	prim	21C00099	C999	560FH	326506
[illegible]	15	117			TBP				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
			0.11	105	PID	4	TSH	+0.29	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
3300			0.00	0	MAI	1	TSH	+0.29	TSHTSH	0.0		F3453	reso	21H00144	H	1 600PP	345335
3301			0.19	106	MAI	2	TSH	+0.29	TSHTSH	0.3		F3453	reso	21H00144	H	1 600PP	345335
3302			0.00	0	SVI	1	DH	+0.64	05H06C	0.0		F6623	reso	21H00215	H	2 5602C	340983
3303			0.23	127	PID	2	DH	+0.64	05H06C			M9715	seco	21H00220	H999	5602C	340983

3304			0.18	114	SVI	2	DH	+0.64	05H06C	0.3			F6623	reso	21H00215	H 2	5602C	340983
3305	17	117			INF		DC	-1.86	TECTEH	HR			M7006	reso	21H00105	H 0	600UL	340988
3306			7.51	179	DNT	P 1	DC	+1.89	TECTEH				T2170	seco	21H00105	H 0	600UL	340988
[illegible]	21	117			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
			0.20	98	SAI	2	TSH	+0.19	TSHTSH	0.3			N5432	reso	21H00145	H 1	600PP	345334
[illegible]			0.36	28	SAI	1	TSH	+0.19	TSHTSH	0.3			N5432	reso	21H00145	H 1	600PP	345334
3310			0.19	87	PID	4	TSH	+0.19	TSHTSH	080			F3453	reso	21H00177	H999	600PP	345336
3311	55	117	1.03	95	MBM	6	07C	+3.64	TECTEH				M7006	reso	21H00056	H 0	600UL	340950
3312	69	117	1.92	187	INR	P 1	07H	-1.42	TECTEH				L2157	reso	21H00055	H 0	600UL	340947
3313	85	117	0.88	90	MBM	6	01H	+10.23	TECTEH				L2157	reso	21H00055	H 0	600UL	340947
3314	87	117	2.19	181	DNG	P 1	TSC	+6.32	TECTEH				T2170	seco	21H00056	H 0	600UL	340950
3315	97	117	2.98	174	DNG	P 1	01C	+7.80	TECTEH				O8795	seco	21H00022	H 0	600UL	332255
3316	109	117	1.66	187	INR	P 1	02H	+13.03	TECTEH				C5542	reso	21H00021	H 0	600UL	340910
3317	113	117	1.00	108	MBM	5	04H	+13.26	TECTEH				C5542	reso	21H00021	H 0	600UL	340910
3318	121	117	7.70	182	DNG	P 1	10C	+3.53	TECTEH				A9574	seco	21H00021	H 0	600UL	340910
3319	14	118	0.43	140	INR	P 1	TSH	+3.63	TECTEH				A9608	reso	21H00106	H 0	600UL	331889
3320			1.10	87	MBM	5	02C	+5.45	TECTEH				L2157	reso	21H00106	H 0	600UL	331889
3321	18	118	5.85	182	DNG	P 1	VM	+4.25	TECTEH				L2157	reso	21H00106	H 0	600UL	331889
3322			4.15	182	DNG	P 1	06C	+11.94	TECTEH				L2157	reso	21H00106	H 0	600UL	331889
3323	68	118	0.53	82	MBM	6	01C	+6.71	TECTEH				L2157	reso	21H00055	H 0	600UL	340947
3324	74	118			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3325			0.07	102	PID	4	TSH	+0.77	TSHTSH	080			A9608	reso	21H00184	H999	600PP	345336
3326			0.06	108	SAI	2	TSH	+0.77	TSHTSH	0.2			F3453	reso	21H00144	H 1	600PP	345335
3327			0.00	0	SAI	1	TSH	+0.77	TSHTSH	0.0			F3453	reso	21H00144	H 1	600PP	345335
3328			5.46	182	DNG	P 1	08C	+7.76	TECTEH				T7451	seco	21H00055	H 0	600UL	340947
3329	78	118			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3330			0.15	141	PID	4	TSH	+0.64	TSHTSH	080			A9608	reso	21H00184	H999	600PP	345336
3331			0.00	0	MAI	1	TSH	+0.64	TSHTSH	0.0			F3453	reso	21H00144	H 1	600PP	345335
3332			0.13	124	MAI	2	TSH	+0.64	TSHTSH	0.5			F3453	reso	21H00144	H 1	600PP	345335

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 69

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3333			0.00	0	MAI	1	TSH	+1.15	TSHTSH	0.0		F3453	reso	21H00144	H 1	600PP	345335
3334			0.09	84	MAI	2	TSH	+1.15	TSHTSH	0.6		F3453	reso	21H00144	H 1	600PP	345335
3335	94	118	2.29	179	DNG	P 1	02H	+6.04	TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3336			1.05	90	MBM	5	05H	+19.45	TECTEH			L2157	reso	21H00026	H 0	600UL	332255
3337	98	118	4.38	183	DNG	P 1	07H	+18.42	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3338			2.92	181	DNG	P 1	06C	+11.89	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3339	106	118	10.99	180	DNG	P 1	08H	+13.28	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3340	110	118	1.25	87	MBM	5	VH	+19.27	TECTEH			C3340	reso	21H00090	H 0	600UL	340988
3341	126	118	2.39	182	DNG	P 1	VH	+29.81	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3342	7	119	2.56	179	DNG	P 1	06H	+9.93	TECTEH			F4645	seco	21H00106	H 0	600UL	331889
3343	17	119			INF		DC	-2.01	TECTEH	HR		M7006	reso	21H00105	H 0	600UL	340988
[illegible]			6.85	177	DNT	P 1	DC	+2.00	TECTEH			T2170	seco	21H00105	H 0	600UL	340988
			7.80	179	DNG	P 1	06C	+10.33	TECTEH			T2170	seco	21H00105	H 0	600UL	340988
3346	25	119	0.47	60	MBM	5	03H	+7.38	TECTEH			M7006	reso	21H00105	H 0	600UL	340988
3347	27	119	0.38	39	17	P 2	VM	+1.79	TECTEH			F4645	seco	21H00106	H 0	600UL	331889
3348	41	119	5.82	182	DNG	P 1	DH	+8.67	TECTEH			T2170	seco	21H00105	H 0	600UL	340988
3349	67	119	3.54	181	DNT	P 1	08C	+0.66	TECTEH			T7451	seco	21H00055	H 0	600UL	340947

3350	83	119				TBS					TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3351			0.00	0	MAI	1	TSH	+1.05			TSHTSH	0.0		F3453	reso	21H00144	H 1	600PP	345335
3352			0.15	83	MAI	2	TSH	+1.05			TSHTSH	0.2		F3453	reso	21H00144	H 1	600PP	345335
[illegible]			0.00	0	MAI	1	TSH	+1.25			TSHTSH	0.0		F3453	reso	21H00144	H 1	600PP	345335
[illegible]			0.14	87	MAI	2	TSH	+1.25			TSHTSH	0.4		F3453	reso	21H00144	H 1	600PP	345335
3355			0.11	98	PID	4	TSH	+1.25			TSHTSH	080		F3453	reso	21H00175	H999	600PP	345339
3356	101	119	4.50	184	DNT	P 1	09H	-0.77			TECTEH			F7467	seco	21H00025	H 0	600UL	340910
3357			2.64	183	DNG	P 1	09C	+1.68			TECTEH			F7467	seco	21H00025	H 0	600UL	340910
3358			4.99	184	DNG	P 1	08C	+10.98			TECTEH			F7467	seco	21H00025	H 0	600UL	340910
3359			4.52	180	DNG	P 1	08C	+16.64			TECTEH			F7467	seco	21H00025	H 0	600UL	340910
3360			12.69	183	DNG	P 1	08C	+17.53			TECTEH			F7467	seco	21H00025	H 0	600UL	340910
3361	115	119	0.99	62	MBM	6	04H	+29.23			TECTEH			L2157	reso	21H00026	H 0	600UL	332255
3362			2.05	79	MBM	6	08C	+12.85			TECTEH			L2157	reso	21H00026	H 0	600UL	332255
3363	117	119	5.72	179	DNT	P 1	10H	-0.27			TECTEH			F7467	seco	21H00025	H 0	600UL	340910
3364			3.76	184	DNT	P 1	10C	+0.29			TECTEH			F7467	seco	21H00025	H 0	600UL	340910
3365	123	119	2.03	178	DNG	P 1	TSH	+10.48			TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3366			1.48	180	INR	P 1	10C	+4.53			TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3367	125	119	3.07	185	DNG	P 1	05H	+7.85			TECTEH			F7467	seco	21H00025	H 0	600UL	340910
3368	127	119	2.29	182	DNG	P 1	04C	+36.71			TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3369	12	120			TBS						TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3370			0.12	85	SAI	2	TSH	+1.04			TSHTSH	0.4		N5432	reso	21H00148	H 1	600PP	345335
3371			0.16	44	SAI	1	TSH	+1.04			TSHTSH	0.2		N5432	reso	21H00148	H 1	600PP	345335
3372			0.08	74	PID	4	TSH	+1.04			TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
3373	18	120			INF		DH	+4.71			TECTEH	HR		L2157	reso	21H00106	H 0	600UL	331889
3374			5.61	180	DNT	P 1	VM	-2.00			TECTEH			L2157	reso	21H00106	H 0	600UL	331889
3375			4.87	181	DNG	P 1	VM	+2.66			TECTEH			F4645	seco	21H00106	H 0	600UL	331889
3376			5.43	181	DNG	P 1	VM	+3.95			TECTEH			F4645	seco	21H00106	H 0	600UL	331889
3377			6.22	180	DNT	P 1	DC	-1.31			TECTEH			L2157	reso	21H00106	H 0	600UL	331889
3378			4.16	182	DNT	P 1	DC	+1.46			TECTEH			F4645	seco	21H00106	H 0	600UL	331889
					INF		06C	+9.68			TECTEH	HR		L2157	reso	21H00106	H 0	600UL	331889
[illegible]			4.50	180	DNG	P 1	06C	+11.01			TECTEH			F4645	seco	21H00106	H 0	600UL	331889
3381			6.28	181	DNG	P 1	06C	+14.14			TECTEH			F4645	seco	21H00106	H 0	600UL	331889

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 70

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3382			5.47	180	DNG	P 1	06C	+16.14	TECTEH			F4645	seco	21H00106	H 0	600UL	331889
3383	20	120			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3384			0.11	117	SAI	2	TSH	+0.20	TSHTSH	0.2		N5432	reso	21H00148	H 1	600PP	345335
3385			0.00	0	SAI	1	TSH	+0.20	TSHTSH	0.0		N5432	reso	21H00148	H 1	600PP	345335
3386			0.10	127	PID	4	TSH	+0.20	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
3387	22	120			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3388			0.17	59	PID	4	TSH	+0.36	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
3389			0.15	59	SAI	2	TSH	+0.36	TSHTSH	0.2		F3453	reso	21H00149	H 1	600PP	345334
[illegible]			0.00	0	SAI	1	TSH	+0.36	TSHTSH	0.0		F3453	reso	21H00149	H 1	600PP	345334
	28	120	1.53	59	MBM	6	TSH	+31.98	TECTEH			M7006	reso	21H00105	H 0	600UL	340988
3392	64	120	0.53	78	MBM	5	01H	+5.24	TECTEH			M7006	reso	21H00105	H 0	600UL	340988
3393	68	120			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3394			0.17	113	PID	4	TSH	+0.78	TSHTSH	080		F3453	reso	21H00175	H999	600PP	345339
3395			0.31	50	MAI	1	TSH	+0.78	TSHTSH	0.5		N5432	reso	21H00148	H 1	600PP	345335

3396				0.13	108	MAI	2	TSH	+0.78	TSHTSH	0.5			N5432	reso	21H00148	H 1	600PP	345335
3397				0.13	71	SAI	2	TSH	+1.31	TSHTSH	0.2			N5432	reso	21H00148	H 1	600PP	345335
3398				0.00	0	SAI	1	TSH	+1.31	TSHTSH	0.0			N5432	reso	21H00148	H 1	600PP	345335
[illegible]				0.72	83	MBM	5	03C	+10.15	TECTEH				M7006	reso	21H00105	H 0	600UL	340988
[illegible]	76	120		2.87	179	DNG	P 1	08C	-1.65	TECTEH				F4645	seco	21H00106	H 0	600UL	331889
3401				3.96	180	DNG	P 1	07C	+19.79	TECTEH				F4645	seco	21H00106	H 0	600UL	331889
3402				6.31	178	DNG	P 1	07C	+22.11	TECTEH				F4645	seco	21H00106	H 0	600UL	331889
3403	88	120				TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3404				0.13	81	SAI	2	TSH	+0.63	TSHTSH	0.2			N5432	reso	21H00148	H 1	600PP	345335
3405				0.14	94	PID	4	TSH	+0.63	TSHTSH	080			A9608	reso	21H00184	H999	600PP	345336
3406				0.00	0	SAI	1	TSH	+0.63	TSHTSH	0.0			N5432	reso	21H00148	H 1	600PP	345335
3407	94	120				TBP				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3408				0.11	102	PID	4	TSH	+0.63	TSHTSH	080			F3453	reso	21H00177	H999	600PP	345336
3409				0.00	0	SAI	1	TSH	+0.63	TSHTSH	0.0			C5542	reso	21H00157	H 1	600PP	345335
3410				0.14	110	SAI	2	TSH	+0.63	TSHTSH	0.2			C5542	reso	21H00157	H 1	600PP	345335
3411				3.83	185	DNG	P 1	08C	+6.04	TECTEH				C5542	reso	21H00025	H 0	600UL	340910
3412	100	120		2.66	179	DNG	P 1	03H	+16.64	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3413	106	120		4.14	176	DNG	P 1	01C	+28.26	TECTEH				F7467	seco	21H00025	H 0	600UL	340910
3414	108	120		2.48	183	DNT	P 1	09H	-0.25	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3415	110	120		3.15	179	DNG	P 1	01H	+23.93	TECTEH				F7467	seco	21H00025	H 0	600UL	340910
3416	112	120				NDF		09H	+0.04	09H09H				R3710	prim	21H00179	H 3	600PP	345336
3417				0.38	60	DSI	P 1	09H	+0.04	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3418				2.04	187	DNG	P 1	TSC	+15.76	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3419				2.10	188	DNG	P 1	TSC	+29.81	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3420	114	120		0.44	74	MBM	5	02C	+28.80	TECTEH				M1680	reso	21H00025	H 0	600UL	340910
3421	118	120		0.73	73	MBM	5	02H	+6.29	TECTEH				C5542	reso	21H00025	H 0	600UL	340910
3422				1.10	103	MBM	6	08H	+7.96	TECTEH				C5542	reso	21H00025	H 0	600UL	340910
3423	126	120		4.53	185	DNG	P 1	06H	+3.57	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3424				1.72	188	INR	P 1	10H	-0.20	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
				3.97	184	DNG	P 1	10C	+7.09	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
[illegible]	1	121		0.48	60	MBM	6	05H	+29.76	06HTEH				F3453	reso	21H00099	H 9	600UL	331963
3427						INF		05H	+30.90	06HTEH	HR			F3453	reso	21H00099	H 9	600UL	331963
3428	5	121		8.58	181	DNG	P 1	06C	+3.99	06HTEC				D4576	seco	21C00064	C 0	600CS	341612
3429	9	121		3.19	177	DNG	P 1	VM	-2.03	TECTEH				M7006	reso	21H00105	H 0	600UL	340988
3430				16.18	181	DNG	P 1	06C	+6.10	TECTEH				M7006	reso	21H00105	H 0	600UL	340988

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 71

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3431	13	121	5.71	181	DNT	P 1	VM	-0.07	TECTEH			M7006	reso	21H00105	H 0	600UL	340988
3432	17	121			INF		DC	-2.03	TECTEH	HR		M7006	reso	21H00105	H 0	600UL	340988
3433			5.45	176	DNT	P 1	DC	+1.94	TECTEH			T2170	seco	21H00105	H 0	600UL	340988
3434			5.20	179	DNG	P 1	06C	+10.40	TECTEH			T2170	seco	21H00105	H 0	600UL	340988
3435	27	121	0.82	91	MBM	6	TSH	+12.09	TECTEH			L2157	reso	21H00106	H 0	600UL	331889
[illegible]			0.40	83	MBM	5	TSH	+34.21	TECTEH			L2157	reso	21H00106	H 0	600UL	331889
	59	121			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3438			0.10	92	SAI	2	TSH	+0.70	TSHTSH	0.2		F3453	reso	21H00149	H 1	600PP	345334
3439			0.00	0	SAI	1	TSH	+0.70	TSHTSH	0.0		F3453	reso	21H00149	H 1	600PP	345334
3440			0.00	0	MAI	1	TSH	+0.98	TSHTSH	0.0		F3453	reso	21H00149	H 1	600PP	345334
3441			0.13	98	PID	4	TSH	+0.98	TSHTSH	080		F6623	reso	21H00176	H999	600PP	345339

3442				0.13	76	MAI	2	TSH	+0.98	TSHTSH	0.4		F3453	reso	21H00149	H 1	600PP	345334
3443	65	121				INF	5	DH	+25.78	TECTEH	HR		M7006	reso	21H00105	H 0	600UL	340988
3444				0.56	71	MBM	5	DH	+27.22	TECTEH			M7006	reso	21H00105	H 0	600UL	340988
3445	79	121				TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
				0.00	0	SAI	1	TSH	+0.64	TSHTSH	0.0		F3453	reso	21H00149	H 1	600PP	345334
3447				0.12	127	SAI	2	TSH	+0.64	TSHTSH	0.3		F3453	reso	21H00149	H 1	600PP	345334
3448				0.17	132	PID	4	TSH	+0.64	TSHTSH	080		F6623	reso	21H00176	H999	600PP	345339
3449	93	121		0.62	80	MBM	5	VH	+22.85	TECTEH			C5542	reso	21H00025	H 0	600UL	340910
3450	101	121		2.12	184	DNG	P 1	01H	+24.97	TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3451	105	121		6.04	186	DNT	P 1	09H	-0.26	TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3452						NDF		09H	-0.26	09H09H			R3710	prim	21H00179	H 6	600PP	345336
3453	107	121		5.15	180	DNT	P 1	09H	-0.33	TECTEH			F7467	seco	21H00025	H 0	600UL	340910
3454	111	121		1.32	84	MBM	6	DH	+9.99	TECTEH			C5542	reso	21H00025	H 0	600UL	340910
3455	117	121		3.14	182	DNT	P 1	10C	+0.15	TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3456	119	121				TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3457				1.35	63	SVI	2	TSH	+26.48	TSH01H	0.3		M7006	reso	21H00179	H 3	600PP	345336
3458				2.78	156	SVI	1	TSH	+26.48	TSH01H	0.3		M7006	reso	21H00179	H 3	600PP	345336
3459				1.18	69	PID	4	TSH	+26.48	TSH01H	080		N5432	reso	21H00185	H999	600PP	345336
3460				2.23	123	NQI	P 1	TSH	+26.91	TECTEH			F7467	seco	21H00025	H 0	600UL	340910
3461	121	121		5.24	184	DNG	P 1	10H	+1.14	TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3462	123	121		0.66	40	MBM	5	TSC	+2.55	TECTEH			C5542	reso	21H00025	H 0	600UL	340910
3463	125	121				NDF		07H	+21.95	07H08H			R3710	prim	21H00179	H 3	600PP	345336
3464				0.75	79	NQI	5	07H	+21.95	TECTEH			L2157	reso	21H00026	H 0	600UL	332255
3465	6	122				OBS		06H	+2.80	06HTEH			M0945	seco	21H00109	H 0	600UL	340988
3466						OBS		06C	+8.01	06CTEC			B6768	prim	21C00064	H 0	600CS	341612
3467	12	122				TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3468				0.17	88	SAI	2	TSH	+0.77	TSHTSH	0.4		N5432	reso	21H00148	H 1	600PP	345335
3469				0.17	87	PID	4	TSH	+0.77	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
3470				0.00	0	SAI	1	TSH	+0.77	TSHTSH	0.0		N5432	reso	21H00148	H 1	600PP	345335
	14	122		0.75	86	MBM	5	TSH	+34.41	TECTEH			L2157	reso	21H00110	H 0	600UL	331889
[illegible]	16	122		0.37	83	MBM	5	01H	+23.39	TECTEH			L2157	reso	21H00109	H 0	600UL	340988
3473	20	122				TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3474				0.23	81	MAI	2	TSH	+0.20	TSHTSH	0.4		N5432	reso	21H00148	H 1	600PP	345335
3475				0.27	81	PID	4	TSH	+0.20	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
3476				0.20	50	MAI	1	TSH	+0.20	TSHTSH	0.4		N5432	reso	21H00148	H 1	600PP	345335
3477	22	122				TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3478				0.14	73	PID	4	TSH	+0.28	TSHTSH	080		F3453	reso	21H00177	H999	600PP	345336
3479				0.14	93	MAI	2	TSH	+0.28	TSHTSH	0.4		F3453	reso	21H00149	H 1	600PP	345334

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 72

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3480			0.00	0	MAI	1	TSH	+0.28	TSHTSH	0.0		F3453	reso	21H00149	H 1	600PP	345334
3481			0.00	0	SAI	2	TSH	+0.53	TSHTSH	0.0		F3453	reso	21H00149	H 1	600PP	345334
[illegible]			0.14	110	SAI	2	TSH	+0.53	TSHTSH	0.2		F3453	reso	21H00149	H 1	600PP	345334
	36	122	5.11	182	DNT	P 1	VM	-1.21	TECTEH			M0945	seco	21H00109	H 0	600UL	340988
3484	56	122			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3485			0.14	85	PID	4	TSH	+0.78	TSHTSH	080		F6623	reso	21H00176	H999	600PP	345339
3486			0.00	0	SAI	1	TSH	+0.78	TSHTSH	0.0		N5432	reso	21H00148	H 1	600PP	345335
3487			0.17	93	SAI	2	TSH	+0.78	TSHTSH	0.2		N5432	reso	21H00148	H 1	600PP	345335

3488	66	122	0.61	144	INR	5	TSH	+0.62	TECTEH				D3858	reso	21H00109	H 0	600UL	340988
3489	78	122	1.97	185	INR	P 1	08C	+10.51	TECTEH				M0945	seco	21H00109	H 0	600UL	340988
3490	90	122			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3491			0.00	0	SAI	3	TSH	+0.32	TSHTSH	0.0			F6623	reso	21H00176	H 1	600PP	345339
			0.11	88	SAI	4	TSH	+0.32	TSHTSH	0.2			F6623	reso	21H00176	H 1	600PP	345339
3493			0.14	107	PID	4	TSH	+0.32	TSHTSH	080			A9608	reso	21H00184	H999	600PP	345336
3494	92	122	5.42	178	DNG	P 1	02C	+22.37	TECTEH				F7467	seco	21H00025	H 0	600UL	340910
3495			7.97	174	DNG	P 1	TSC	+8.83	TECTEH				F7467	seco	21H00025	H 0	600UL	340910
3496	94	122	3.07	184	DNG	P 1	TSH	+10.78	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3497			2.19	182	DNG	P 1	04H	+28.02	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3498	108	122			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3499			0.09	66	PID	4	TSH	-0.19	TSHTSH	080			F3453	reso	21H00177	H999	600PP	345336
3500			0.12	17	SAI	2	TSH	-0.19	TSHTSH	0.38	PWSCC		M7006	reso	21H00158	H 1	600PP	345334
3501			0.46	7	SAI	1	TSH	-0.19	TSHTSH	0.38	PWSCC		S4373	reso	21H00158	H 1	600PP	345334
3502	114	122	1.24	79	MBM	5	02C	+33.68	TECTEH				C5542	reso	21H00025	H 0	600UL	340910
3503	116	122	2.23	187	DNG	P 1	08C	+5.62	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3504	120	122	3.23	178	DNG	P 1	08H	+20.56	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3505	7	123	3.20	182	DNG	P 1	06H	+10.04	TECTEH				F7467	seco	21H00110	H 0	600UL	331889
3506	11	123			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3507			0.31	110	PID	4	TSH	+0.53	TSHTSH	080			F3453	reso	21H00177	H999	600PP	345336
3508			0.36	83	SAI	2	TSH	+0.53	TSHTSH	0.4			F3453	reso	21H00149	H 1	600PP	345334
3509			0.10	122	SAI	1	TSH	+0.53	TSHTSH	0.4			F3453	reso	21H00149	H 1	600PP	345334
3510	17	123	4.80	179	DNT	P 1	DC	+2.21	TECTEH				M0945	seco	21H00109	H 0	600UL	340988
3511			5.29	179	DNG	P 1	06C	+10.60	TECTEH				M0945	seco	21H00109	H 0	600UL	340988
3512	19	123			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3513			0.17	82	SAI	2	TSH	+0.12	TSHTSH	0.2			F3453	reso	21H00149	H 1	600PP	345334
3514			0.21	77	PID	4	TSH	+0.12	TSHTSH	080			F3453	reso	21H00177	H999	600PP	345336
3515			0.11	84	SAI	1	TSH	+0.12	TSHTSH	0.2			F3453	reso	21H00149	H 1	600PP	345334
3516	21	123			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
			0.26	49	MAI	1	TSH	+0.15	TSHTSH	0.3			N5432	reso	21H00148	H 1	600PP	345335
[illegible]			0.16	91	MAI	2	TSH	+0.15	TSHTSH	0.4			N5432	reso	21H00148	H 1	600PP	345335
3519			0.13	100	PID	4	TSH	+0.15	TSHTSH	080			F3453	reso	21H00177	H999	600PP	345336
3520	23	123			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3521			0.09	102	SAI	2	TSH	+0.53	TSHTSH	0.5			F3453	reso	21H00149	H 1	600PP	345334
3522			0.00	0	SAI	1	TSH	+0.53	TSHTSH	0.0			F3453	reso	21H00149	H 1	600PP	345334
3523			0.11	114	PID	4	TSH	+0.53	TSHTSH	080			F3453	reso	21H00177	H999	600PP	345336
3524	25	123			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3525			0.22	118	MAI	2	TSH	+0.38	TSHTSH	0.4			N5432	reso	21H00148	H 1	600PP	345335
3526			0.25	124	PID	4	TSH	+0.38	TSHTSH	080			F3453	reso	21H00177	H999	600PP	345336
3527			0.55	55	MAI	1	TSH	+0.38	TSHTSH	0.4			N5432	reso	21H00148	H 1	600PP	345335
3528			0.46	79	NQI	P 1	TSH	+0.39	TECTEH				D9573	prim	21H00109	H 0	600UL	340988

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 73

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
	31	123	0.50	83	MBM	5	05H +12.48	TECTEH			L2157	reso	21H00110	H 0	600UL	331889
3530	35	123	0.70	87	MBM	6	03C +25.36	TECTEH			L2157	reso	21H00110	H 0	600UL	331889
3531	47	123	3.12	183	DNG	P 1	05H +15.97	TECTEH			F7467	seco	21H00110	H 0	600UL	331889
3532			2.22	181	DNG	P 1	02C +18.72	TECTEH			F7467	seco	21H00110	H 0	600UL	331889
3533	49	123	2.81	182	DNG	P 1	02C +14.45	TECTEH			M0945	seco	21H00109	H 0	600UL	340988

3534	51	123	0.67	78	MBM	6	04H	+10.03		TECTEH				L2157	reso	21H00109	H 0 600UL	340988
3535	55	123	0.93	78	MBM	5	06H	+19.47		TECTEH				F6623	reso	21H00055	H 0 600UL	340947
3536	77	123	1.03	82	MBM	5	01C	+30.09		TECTEH				F6623	reso	21H00055	H 0 600UL	340947
3537	81	123	0.55	81	MBM	5	05H	+22.02		TECTEH				L2157	reso	21H00055	H 0 600UL	340947
			1.60	79	MBM	5	05H	+25.14		TECTEH				L2157	reso	21H00055	H 0 600UL	340947
3539			0.41	71	MBM	5	05H	+34.81		TECTEH				L2157	reso	21H00055	H 0 600UL	340947
3540					INF		08C	+12.89		TECTEH	HR			L2157	reso	21H00055	H 0 600UL	340947
3541			4.13	182	DNG	P 1	08C	+17.69		TECTEH				T7451	seco	21H00055	H 0 600UL	340947
3542			0.59	81	NQI	5	02C	+14.35		TECTEH				L2157	reso	21H00055	H 0 600UL	340947
3543					NDF		02C	+14.35		02C03C				F6623	reso	21C00083	C 4 600PP	345344
3544	87	123	3.10	182	DNG	P 1	08C	+19.07		TECTEH				T7451	seco	21H00055	H 0 600UL	340947
3545	91	123	4.27	181	DNG	P 1	08C	+19.97		TECTEH				F7467	seco	21H00025	H 0 600UL	340910
3546	101	123	2.65	81	MBM	6	VC	+3.00	TO+4.31	TECTEH				C5542	reso	21H00025	H 0 600UL	340910
3547	103	123	2.22	176	DNT	P 1	09H	-0.38		TECTEH				M2655	seco	21H00026	H 0 600UL	332255
3548	107	123	0.56	84	MBM	5	05C	+11.76		TECTEH				L2157	reso	21H00026	H 0 600UL	332255
3549	117	123	4.56	183	DNT	P 1	10C	+0.34		TECTEH				F7467	seco	21H00025	H 0 600UL	340910
3550	119	123	0.81	10	IDM	2	TSH	+1.80		TSHTSH				M9715	seco	21H00158	H 1 600PP	345334
3551			6.51	187	DNG	P 1	DC	+9.36		TECTEH				M2655	seco	21H00026	H 0 600UL	332255
3552	8	124	2.57	181	DNG	P 1	TSH	+13.58		TECTEH				M0945	seco	21H00109	H 0 600UL	340988
3553	14	124	0.29	109	DSI	P 1	06H	-0.62		TECTEH				A9608	reso	21H00110	H 0 600UL	331889
3554					NDF		06H	-0.62		05H06C				H4599	seco	21H00212	H 2 5602C	340983
3555	16	124	13.01	179	DNG	P 1	VM	+3.78		TECTEH				M0945	seco	21H00109	H 0 600UL	340988
3556	20	124			TBS					TSHTSH				D3858	reso	21H00115	H 1 600PP	326403
3557			0.15	41	MAI	1	TSH	+0.20		TSHTSH	0.2			N5432	reso	21H00148	H 1 600PP	345335
3558			0.15	124	PID	4	TSH	+0.20		TSHTSH	080			F3453	reso	21H00177	H999 600PP	345336
3559			0.15	91	MAI	2	TSH	+0.20		TSHTSH	0.3			N5432	reso	21H00148	H 1 600PP	345335
3560	24	124			TBS					TSHTSH				D3858	reso	21H00115	H 1 600PP	326403
3561			0.12	98	SAI	2	TSH	+0.59		TSHTSH	0.1			N5432	reso	21H00148	H 1 600PP	345335
3562			0.00	0	SAI	1	TSH	+0.59		TSHTSH	0.0			N5432	reso	21H00148	H 1 600PP	345335
			0.16	71	PID	4	TSH	+0.59		TSHTSH	080			F3453	reso	21H00177	H999 600PP	345336
	30	124			TBS					TSHTSH				D3858	reso	21H00115	H 1 600PP	326403
3565			0.12	95	SAI	2	TSH	+0.19		TSHTSH	0.1			N5432	reso	21H00148	H 1 600PP	345335
3566			0.00	0	SAI	1	TSH	+0.19		TSHTSH	0.0			N5432	reso	21H00148	H 1 600PP	345335
3567			0.33	34	SAI	1	TSH	+0.44		TSHTSH	0.2			N5432	reso	21H00148	H 1 600PP	345335
3568			0.18	104	PID	4	TSH	+0.44		TSHTSH	080			F3453	reso	21H00177	H999 600PP	345336
3569			0.18	101	SAI	2	TSH	+0.44		TSHTSH	0.2			N5432	reso	21H00148	H 1 600PP	345335
3570			0.09	95	SAI	2	TSH	+0.73		TSHTSH	0.2			N5432	reso	21H00148	H 1 600PP	345335
3571			0.0	0	SAI	1	TSH	+0.73		TSHTSH	0.0			N5432	reso	21H00148	H 1 600PP	345335
3572	50	124	2.04	181	DNG	P 1	TSC	+9.34		TECTEH				M0945	seco	21H00109	H 0 600UL	340988
3573	60	124			TBS					TSHTSH				D3858	reso	21H00115	H 1 600PP	326403
3574			0.14	110	PID	4	TSH	+0.58		TSHTSH	080			F6623	reso	21H00176	H999 600PP	345339
3575			0.00	0	SAI	1	TSH	+0.58		TSHTSH	0.0			F3453	reso	21H00149	H 1 600PP	345334
3576			0.13	108	SAI	2	TSH	+0.58		TSHTSH	0.3			F3453	reso	21H00149	H 1 600PP	345334
3577			0.78	120	NQI	P 1	TSH	+0.60		TECTEH				W4892	prim	21H00110	H 0 600UL	331889

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 74

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3578	62	124			NDF		TSH	+0.65	TSHTSH			C3340	reso	21H00148	H 1	600PP	345335
3579			0.25	100	NQI	P 1	TSH	+0.65	TECTEH			D9573	prim	21H00109	H 0	600UL	340988

3580	66	124			NDF		TSH	+0.45	TSHTSH				C3340	reso	21H00148	H 1	600PP	345335
3581			0.25	120	NQI	P 1	TSH	+0.45	TECTEH				D9573	prim	21H00109	H 0	600UL	340988
3582	72	124			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3583			0.00	0	SAI	1	TSH	+1.16	TSHTSH	0.0			N5432	reso	21H00148	H 1	600PP	345335
			0.12	99	PID	4	TSH	+1.16	TSHTSH	080			F6623	reso	21H00176	H999	600PP	345339
3585			0.13	87	SAI	2	TSH	+1.16	TSHTSH	0.2			N5432	reso	21H00148	H 1	600PP	345335
3586			4.73	181	DNG	P 1	08C	+5.50	TECTEH				M0945	seco	21H00109	H 0	600UL	340988
3587	92	124	4.61	185	INR	P 1	09C	+0.34	TECTEH				F7467	seco	21H00025	H 0	600UL	340910
3588	102	124	2.92	180	DNG	P 1	04H	+13.35	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3589			1.93	185	INR	P 1	VH	+27.93	TECTEH				L2157	reso	21H00026	H 0	600UL	332255
3590	106	124	2.62	180	DNG	P 1	01C	+6.71	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3591	110	124	2.49	186	DNT	P 1	03H	+0.69	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3592	112	124	1.07	71	MBM	6	02C	+3.85	TECTEH				C5542	reso	21H00025	H 0	600UL	340910
3593	116	124	0.91	68	MBM	5	04H	+22.22	TECTEH				C5542	reso	21H00025	H 0	600UL	340910
3594	11	125	0.44	79	MBM	5	01C	+9.60	TECTEH				L2157	reso	21H00110	H 0	600UL	331889
3595	17	125			INF		06C	+9.66	TECTEH	HR			L2157	reso	21H00109	H 0	600UL	340988
3596			5.62	178	DNG	P 1	06C	+10.74	TECTEH				M0945	seco	21H00109	H 0	600UL	340988
3597			0.65	86	MBM	5	TSC	+24.43	TECTEH				L2157	reso	21H00109	H 0	600UL	340988
3598	41	125	3.58	185	DNG	P 1	DH	+8.86	TECTEH				M0945	seco	21H00109	H 0	600UL	340988
3599	43	125	0.74	75	26	P 2	01C	+0.60	TECTEH				W4892	prim	21H00110	H 0	600UL	331889
3600	49	125	0.58	91	MBM	5	02H	+25.32	TECTEH				L2157	reso	21H00109	H 0	600UL	340988
3601			4.28	181	DNG	P 1	DH	+19.74	TECTEH				M0945	seco	21H00109	H 0	600UL	340988
3602			11.15	181	DNG	P 1	VM	+2.71	TECTEH				M0945	seco	21H00109	H 0	600UL	340988
3603			3.60	184	DNT	P 1	07C	-0.95	TECTEH				M0945	seco	21H00109	H 0	600UL	340988
3604	83	125	2.92	183	DNG	P 1	08C	+15.33	TECTEH				F7467	seco	21H00110	H 0	600UL	331889
3605	85	125	2.33	181	DNG	P 1	08C	+17.16	TECTEH				M0945	seco	21H00109	H 0	600UL	340988
3606			2.02	185	DNG	P 1	06C	+16.89	TECTEH				M0945	seco	21H00109	H 0	600UL	340988
3607	87	125	0.56	73	MBM	5	01H	+27.82	TECTEH				L2157	reso	21H00109	H 0	600UL	340988
3608			2.93	184	INR	P 1	08C	+17.96	TECTEH				M0945	seco	21H00109	H 0	600UL	340988
	89	125	2.26	184	INR	P 1	08C	+20.27	TECTEH				M0945	seco	21H00109	H 0	600UL	340988
			0.69	82	MBM	5	06C	+15.29	TECTEH				L2157	reso	21H00109	H 0	600UL	340988
3611			0.61	89	MBM	5	06C	+22.49	TECTEH				L2157	reso	21H00109	H 0	600UL	340988
3612	93	125	5.51	182	DNG	P 1	07C	+13.78	TECTEH				F7467	seco	21H00025	H 0	600UL	340910
3613	107	125	2.32	173	DNG	P 1	02H	+24.45	TECTEH				F7467	seco	21H00025	H 0	600UL	340910
3614	111	125	5.64	181	DNG	P 1	09C	+15.91	TECTEH				C5542	reso	21H00025	H 0	600UL	340910
3615	113	125	7.87	184	DNT	P 1	09H	-0.19	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3616			5.07	177	DNT	P 1	02C	-1.23	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3617			3.14	181	DNG	P 1	01C	+11.24	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3618			2.32	181	DNG	P 1	01C	+11.63	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3619			4.78	178	DNG	P 1	01C	+34.80	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3620			5.27	177	DNG	P 1	01C	+35.21	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3621	115	125	4.88	180	DNT	P 1	09H	-0.32	TECTEH				F7467	seco	21H00025	H 0	600UL	340910
3622	117	125	6.97	187	DNT	P 1	10C	+0.27	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3623	121	125	4.31	185	DNG	P 1	10C	+3.66	TECTEH				M2655	seco	21H00026	H 0	600UL	332255
3624	12	126	2.12	186	DNG	P 1	TSH	+18.21	TECTEH				T7451	seco	21H00055	H 0	600UL	340947
3625	20	126			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3626			0.21	90	MAI	4	TSH	+0.21	TSHTSH	0.4			F3453	reso	21H00152	H 1	600PP	345335

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final , PAGE 75

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N

3627			0.00	0	MAI	3	TSH	+0.21	TSHTSH	0.0			F3453	reso	21H00152	H 1	600PP	345335
3628			0.20	127	PID	4	TSH	+0.21	TSHTSH	080			M7006	reso	21H00165	H999	600PP	345335
3629			3.87	182	DNG	P 1	06H	+12.70	TECTEH				T7451	seco	21H00055	H 0	600UL	340947
	24	126	0.22	8	IDM	4	TSH	+1.75	TSHTSH				F3453	reso	21H00152	H 1	600PP	345335
3631	26	126			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3632			0.22	100	SAI	4	TSH	+0.85	TSHTSH	0.5			F3453	reso	21H00152	H 1	600PP	345335
3633			0.23	60	SAI	3	TSH	+0.85	TSHTSH	0.3			F3453	reso	21H00152	H 1	600PP	345335
3634			0.24	95	PID	4	TSH	+0.85	TSHTSH	080			M7006	reso	21H00165	H999	600PP	345335
3635	44	126			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3636			0.33	73	NQI	P 1	TSH	+0.48	TECTEH				T2170	seco	21H00056	H 0	600UL	340950
3637			0.10	48	MAI	2	TSH	+0.67	TSHTSH	0.4			F3453	reso	21H00114	H 1	600PP	326415
3638			0.00	0	MAI	1	TSH	+0.67	TSHTSH	0.0			F3453	reso	21H00114	H 1	600PP	326415
3639			0.09	105	PID	4	TSH	+0.67	TSHTSH	080			F3453	reso	21H00152	H999	600PP	345335
3640	46	126			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3641			0.14	63	SAI	3	TSH	+0.89	TSHTSH	0.4			F3453	reso	21H00152	H 1	600PP	345335
3642			0.10	115	SAI	4	TSH	+0.89	TSHTSH	0.3			F3453	reso	21H00152	H 1	600PP	345335
3643			0.10	87	PID	4	TSH	+0.89	TSHTSH	080			M7006	reso	21H00165	H999	600PP	345335
3644	48	126			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3645			0.20	100	MAI	4	TSH	+0.41	TSHTSH	0.5			F3453	reso	21H00152	H 1	600PP	345335
3646			0.23	119	PID	4	TSH	+0.41	TSHTSH	080			M7006	reso	21H00165	H999	600PP	345335
3647			0.00	0	MAI	3	TSH	+0.41	TSHTSH	0.0			F3453	reso	21H00152	H 1	600PP	345335
3648			0.18	124	PID	4	TSH	+0.56	TSHTSH	080			M7006	reso	21H00165	H999	600PP	345335
3649			0.15	123	MAI	4	TSH	+0.56	TSHTSH	0.8			F3453	reso	21H00152	H 1	600PP	345335
3650			0.00	0	MAI	3	TSH	+0.56	TSHTSH	0.0			F3453	reso	21H00152	H 1	600PP	345335
3651	58	126			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3652			0.14	111	MAI	2	TSH	+0.59	TSHTSH	0.5			F3453	reso	21H00114	H 1	600PP	326415
3653			0.31	136	MAI	1	TSH	+0.59	TSHTSH	0.5			F3453	reso	21H00114	H 1	600PP	326415
3654			0.13	104	PID	4	TSH	+0.59	TSHTSH	080			F3453	reso	21H00152	H999	600PP	345335
	84	126	6.19	176	DNT	P 1	DC	-0.09	TECTEH				D4576	seco	21H00088	H 0	600UL	340988
	90	126	1.94	182	INR	P 1	08C	+11.65	TECTEH				D4576	seco	21H00088	H 0	600UL	340988
3657	102	126	1.19	54	MBM	6	02H	+12.53	TECTEH				L2157	reso	21H00026	H 0	600UL	332255
3658					NDF		VH	+1.51	VH VM				J9815	prim	21H00191	H 4	5602C	326187
3659			0.40	66	20	P 2	VH	+1.51	TECTEH				M8912	prim	21H00026	H 0	600UL	332255
3660	116	126	0.68	71	MBM	5	02H	+13.52	TECTEH				L2157	reso	21H00026	H 0	600UL	332255
3661	7	127	0.70	69	MBM	6	03H	+4.55	TECTEH				F6623	reso	21H00089	H 0	600UL	331899
3662	13	127	0.67	76	MBM	5	02C	+22.34	TECTEH				F3453	reso	21H00088	H 0	600UL	340988
3663	17	127	5.47	177	DNG	P 1	VM	+4.51	TECTEH				D4576	seco	21H00088	H 0	600UL	340988
3664	21	127	4.12	179	DNG	P 1	06H	+12.66	TECTEH				F7467	seco	21H00089	H 0	600UL	331899
3665	25	127			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3666			0.18	83	MAI	2	TSH	+0.40	TSHTSH	0.4			F6623	reso	21H00121	H 1	600PP	326403
3667			0.19	121	PID	4	TSH	+0.40	TSHTSH	080			F3453	reso	21H00152	H999	600PP	345335
3668			0.30	111	MAI	1	TSH	+0.40	TSHTSH	0.3			F6623	reso	21H00121	H 1	600PP	326403
3669	35	127	0.70	88	MBM	5	VM	+5.24	TECTEH				F3453	reso	21H00088	H 0	600UL	340988
3670	41	127	4.44	184	DNG	P 1	DH	+8.92	TECTEH				D4576	seco	21H00088	H 0	600UL	340988
3671	43	127	5.05	174	DNG	P 1	DH	+2.94	TECTEH				D4576	seco	21H00088	H 0	600UL	340988
3672	57	127			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
3673			0.28	88	PID	4	TSH	+0.60	TSHTSH	080			F3453	reso	21H00152	H999	600PP	345335
3674			0.26	82	SAI	2	TSH	+0.60	TSHTSH	0.4			F3453	reso	21H00120	H 1	600PP	326415
3675			0.47	50	SAI	1	TSH	+0.60	TSHTSH	0.4			F3453	reso	21H00120	H 1	600PP	326415

SG 21 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP,

PLANT: CCNPP

UNIT: 2

SG: 21

MAY. 17,2001 13:47

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
	61	127			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3677			0.06	122	PID	4	TSH	+0.94	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3678			0.08	92	SAI	2	TSH	+0.94	TSHTSH	0.1		D8661	reso	21H00121	H 1	600PP	326403
3679			0.07	84	SAI	1	TSH	+0.94	TSHTSH	0.1		D8661	reso	21H00121	H 1	600PP	326403
3680	77	127	4.19	181	DNG	P 1	08C	+9.57	TECTEH			F7467	seco	21H00089	H 0	600UL	331899
3681	83	127	3.74	180	DNG	P 1	08C	+15.35	TECTEH			D4576	seco	21H00088	H 0	600UL	340988
3682	87	127	2.13	183	DNG	P 1	TSH	+30.95	TECTEH			D4576	seco	21H00088	H 0	600UL	340988
3683			2.38	187	DNG	P 1	06H	+7.74	TECTEH			D4576	seco	21H00088	H 0	600UL	340988
3684					INF		08C	+18.08	TECTEH	HR		M1680	reso	21H00088	H 0	600UL	340988
3685			3.79	180	DNG	P 1	08C	+19.12	TECTEH			D4576	seco	21H00088	H 0	600UL	340988
3686	89	127	0.46	89	MBM	5	04H	+25.30	TECTEH			F3453	reso	21H00088	H 0	600UL	340988
3687	93	127	3.13	183	DNG	P 1	09C	+1.26	TECTEH			F7467	seco	21H00025	H 0	600UL	340910
3688	99	127	0.49	97	MBM	5	01C	+33.67	TECTEH			L2157	reso	21H00026	H 0	600UL	332255
3689	103	127	2.13	185	DNG	P 1	09H	+9.88	TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3690	105	127	1.28	20	IDM	4	TSH	-0.40	TSHTSH			F3453	reso	21H00173	H 1	600PP	345336
3691	107	127	1.87	183	INR	P 1	09H	-0.26	TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3692	113	127	2.53	178	DNG	P 1	02C	+1.28	TECTEH			F7467	seco	21H00025	H 0	600UL	340910
3693	6	128	9.05	182	DNT	P 1	VM	-0.56	TECTEH			F6623	reso	21H00089	H 0	600UL	331899
3694	12	128	12.34	181	DNG	P 1	06H	+7.52	TECTEH			D4576	seco	21H00088	H 0	600UL	340988
3695			13.84	178	DNG	P 1	VM	+2.93	TECTEH			D4576	seco	21H00088	H 0	600UL	340988
3696	26	128			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3697			0.10	53	SCI	1	TSH	+0.05	TSHTSH	0.3		F6623	reso	21H00121	H 1	600PP	326403
3698			0.09	100	PID	P 1	TSH	+0.05	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3699			0.12	101	SCI	P 1	TSH	+0.05	TSHTSH	0.2		F6623	reso	21H00121	H 1	600PP	326403
3700	58	128			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
			0.00	0	SAI	1	TSH	+0.66	TSHTSH	0.0		F3453	reso	21H00120	H 1	600PP	326415
			0.09	90	SAI	2	TSH	+0.66	TSHTSH	0.2		F3453	reso	21H00120	H 1	600PP	326415
3703			0.14	95	SAI	2	TSH	+0.93	TSHTSH	0.3		F3453	reso	21H00120	H 1	600PP	326415
3704			0.19	29	SAI	1	TSH	+0.93	TSHTSH	0.3		F3453	reso	21H00120	H 1	600PP	326415
3705			0.12	107	PID	4	TSH	+0.93	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3706	76	128	2.99	181	DNG	P 1	08C	+9.01	TECTEH			F7467	seco	21H00089	H 0	600UL	331899
3707	82	128			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3708			0.10	99	PID	4	TSH	+0.49	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3709			0.00	0	SAI	1	TSH	+0.49	TSHTSH	0.0		F3453	reso	21H00120	H 1	600PP	326415
3710			0.11	64	SAI	2	TSH	+0.49	TSHTSH	0.2		F3453	reso	21H00120	H 1	600PP	326415
3711	94	128	2.32	184	DNG	P 1	05H	+13.84	TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3712	96	128	0.62	93	MBM	5	04H	+20.88	TECTEH			C5542	reso	21H00025	H 0	600UL	340910
3713	112	128	1.75	185	INR	P 1	04H	+12.49	TECTEH			F7467	seco	21H00025	H 0	600UL	340910
3714	17	129	7.01	182	DNG	P 1	06C	+10.13	TECTEH			F7467	seco	21H00089	H 0	600UL	331899
3715	31	129	2.44	180	DNG	P 1	DH	+11.52	TECTEH			F7467	seco	21H00089	H 0	600UL	331899
3716	41	129			INF		DH	+6.93	TECTEH	HR		M1680	reso	21H00088	H 0	600UL	340988
3717			5.86	183	DNG	P 1	DH	+8.97	TECTEH			D4576	seco	21H00088	H 0	600UL	340988
3718	43	129			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3719			0.14	102	SAI	2	TSH	+0.89	TSHTSH	0.2		F3453	reso	21H00120	H 1	600PP	326415
3720			0.11	102	PID	4	TSH	+0.89	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3721			0.00	0	SAI	1	TSH	+0.89	TSHTSH	0.0		F3453	reso	21H00120	H 1	600PP	326415
3722	67	129			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3723			0.08	95	MAI	2	TSH	+0.94	TSHTSH	0.5		F6623	reso	21H00121	H 1	600PP	326403
3724			0.10	53	MAI	1	TSH	+0.94	TSHTSH	0.3		F6623	reso	21H00121	H 1	600PP	326403

SG 21 - All Calls (Excluding NDD and retest codes)

PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3725			0.10	101	PID	4	TSH	+0.94	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3726	73	129	1.74	182	INR	P 1	08C	+5.53	TECTEH			D4576	seco	21H00088	H 0	600UL	340988
3727	77	129	2.70	180	DNG	P 1	08C	+9.63	TECTEH			F7467	seco	21H00089	H 0	600UL	331899
3728			0.53	82	NQI	5	02C	+27.15	TECTEH			F6623	reso	21H00089	H 0	600UL	331899
3729					NDF		02C	+27.15	02C03C			K5380	prim	21C00095	C 4	5602C	326280
3730			1.58	94	INR	6	01C	+31.96	TECTEH			F7467	seco	21H00089	H 0	600UL	331899
3731	79	129			NDF		TSC	+1.03	TSCTSC			S4373	reso	21C00011	C 2	600PP	345292
3732			0.28	111	NQI	P 1	TSC	+1.03	TECTEH			D4576	seco	21H00088	H 0	600UL	340988
3733	81	129	3.19	182	DNG	P 1	08C	+13.06	TECTEH			F7467	seco	21H00089	H 0	600UL	331899
3734	107	129	2.25	178	DNG	P 1	01H	+34.55	TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3735	117	129	4.47	185	DNT	P 1	10C	+0.15	TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3736	12	130	1.19	76	MBM	6	01H	+36.47	TECTEH			C5542	reso	21H00087	H 0	600UL	331899
3737			1.26	113	INR	P 1	02H	+1.04	TECTEH			C5542	reso	21H00087	H 0	600UL	331899
3738	28	130	0.63	72	MBM	5	01C	+13.34	TECTEH			C5542	reso	21H00087	H 0	600UL	331899
3739	30	130	0.73	79	MBM	5	TSH	+13.90	TECTEH			C5542	reso	21H00086	H 0	600UL	340988
3740			0.70	64	MBM	5	TSH	+29.63	TECTEH			C5542	reso	21H00086	H 0	600UL	340988
3741			4.14	183	DNT	P 1	VM	+1.32	TECTEH			D4576	seco	21H00086	H 0	600UL	340988
3742	38	130	0.50	84	MBM	5	01H	+6.19	TECTEH			C5542	reso	21H00086	H 0	600UL	340988
3743			0.61	73	MBM	5	01H	+15.65	TECTEH			C5542	reso	21H00086	H 0	600UL	340988
3744			0.73	83	MBM	5	02H	+11.97	TECTEH			C5542	reso	21H00086	H 0	600UL	340988
3745	44	130			TBP				TSHTSH	BMVTBS	ADDTBP	D3858	reso	21H00115	H 1	600PP	326403
3746			0.18	103	SAI	2	TSH	+0.80	TSHTSH	0.4		F6623	reso	21H00121	H 1	600PP	326403
			0.21	98	PID	4	TSH	+0.80	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
[illegible]			0.21	49	SAI	1	TSH	+0.80	TSHTSH	0.3		F6623	reso	21H00121	H 1	600PP	326403
3749	66	130			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3750			0.95	81	MBM	5	TSH	+0.89	TECTEH			C5542	reso	21H00086	H 0	600UL	340988
3751			0.10	115	MAI	2	TSH	+0.93	TSHTSH	0.3		F3453	reso	21H00120	H 1	600PP	326415
3752			0.00	0	MAI	1	TSH	+0.93	TSHTSH	0.0		F3453	reso	21H00120	H 1	600PP	326415
3753			0.07	85	PID	4	TSH	+0.93	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3754	72	130	4.02	183	DNG	P 1	08C	+4.51	TECTEH			C5542	reso	21H00087	H 0	600UL	331899
3755	76	130	3.81	183	DNG	P 1	08C	+8.88	TECTEH			H4599	seco	21H00087	H 0	600UL	331899
3756	78	130	0.66	91	MBM	5	07H	+24.00	TECTEH			C5542	reso	21H00086	H 0	600UL	340988
3757	90	130	1.66	52	MBM	6	TSC	+23.50	TECTEH			C5542	reso	21H00086	H 0	600UL	340988
3758	94	130	1.01	187	INR	P 1	02H	+6.16	TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3759	98	130	8.44	183	DNT	P 1	VM	-1.07	TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3760	102	130	2.34	177	DNG	P 1	03H	+15.04	TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3761	106	130	0.23	91	MBM	5	04H	+5.53	TECTEH			L2157	reso	21H00026	H 0	600UL	332255
3762	116	130	1.90	186	INR	P 1	VM	-1.73	TECTEH			M2655	seco	21H00026	H 0	600UL	332255
3763	13	131	0.59	100	NQI	5	05H	+15.32	TECTEH			D3858	reso	21H00086	H 0	600UL	340988
3764			0.18	135	VOL	2	05H	+15.44	05H06C			F3453	reso	21H00197	H 2	5602C	326187
3765	17	131	3.24	185	DNG	P 1	04C	+28.42	TECTEH			D4576	seco	21H00086	H 0	600UL	340988
3766	19	131	5.50	177	DNG	P 1	01C	+10.39	TECTEH			D4576	seco	21H00086	H 0	600UL	340988
3767	29	131	0.85	68	MBM	6	02C	+7.22	TECTEH			C5542	reso	21H00086	H 0	600UL	340988
3768	31	131	2.59	182	DNG	P 1	04C	+29.12	TECTEH			H4599	seco	21H00087	H 0	600UL	331899
3769	41	131			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3770			0.00	0	SAI	1	TSH	+0.80	TSHTSH	0.0		F3453	reso	21H00120	H 1	600PP	326415
3771			0.16	101	PID	4	TSH	+0.80	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
[illegible]			0.22	75	SAI	2	TSH	+0.80	TSHTSH	0.4		F3453	reso	21H00120	H 1	600PP	326415
	49	131	3.48	177	DNG	P 1	VM	+2.74	TECTEH			D4576	seco	21H00086	H 0	600UL	340988

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3774	63	131			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3775			0.06	136	SAI	2	TSH	+1.05	TSHTSH	0.3		F3453	reso	21H00120	H 1	600PP	326415
3776			0.15	87	SAI	1	TSH	+1.05	TSHTSH	0.2		F3453	reso	21H00120	H 1	600PP	326415
3777			0.11	131	PID	4	TSH	+1.05	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3778	75	131	1.95	185	INR	P 1	05H	+9.28	TECTEH			D4576	seco	21H00086	H 0	600UL	340988
3779	79	131	2.21	184	DNG	P 1	08C	+11.59	TECTEH			D4576	seco	21H00086	H 0	600UL	340988
3780	81	131	2.72	183	DNG	P 1	08C	+12.98	TECTEH			H4599	seco	21H00087	H 0	600UL	331899
3781	83	131	3.16	180	DNG	P 1	08C	+15.11	TECTEH			D4576	seco	21H00086	H 0	600UL	340988
3782	89	131	0.78	54	MBM	5	VM	+17.90	TECTEH			C5542	reso	21H00086	H 0	600UL	340988
3783	93	131	2.51	182	DNG	P 1	07H	+18.81	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3784			5.41	180	DNG	P 1	07H	+23.36	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3785			5.70	181	DNG	P 1	08H	-1.40	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3786			8.88	180	DNT	P 1	08H	-0.60	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3787			25.62	180	DNT	P 1	08H	+0.88	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3788			9.04	181	DNG	P 1	08H	+1.57	TECTEH			C3340	reso	21H00090	H 0	600UL	340988
3789			12.96	184	DNG	P 1	08H	+11.41	TECTEH			C3340	reso	21H00090	H 0	600UL	340988
3790			10.37	184	DNG	P 1	08H	+12.12	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3791			65.06	178	DNG	P 1	08H	+13.16	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3792			2.84	359	INR	P 1	09C	-2.26	TECTEH			C3340	reso	21H00090	H 0	600UL	340988
			5.77	179	DNT	P 1	09C	-0.04	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
			69.65	179	DNG	P 1	09C	+1.53	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3795			2.63	181	DNG	P 1	08C	+6.75	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3796			7.75	183	DNG	P 1	08C	+7.66	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3797			3.91	178	DNG	P 1	08C	+18.12	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3798			19.28	182	DNG	P 1	08C	+19.07	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3799			8.00	183	DNG	P 1	08C	+20.34	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3800	101	131	0.87	184	INR	P 1	01H	+25.69	TECTEH			C5542	reso	21H00031	H 0	600UL	340910
3801			3.19	180	DNT	P 1	09H	-0.02	TECTEH			M2655	seco	21H00031	H 0	600UL	340910
3802			2.61	180	DNG	P 1	08C	+20.29	TECTEH			M2655	seco	21H00031	H 0	600UL	340910
3803	4	132			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3804			0.00	0	SVI	1	TSH	+0.17	TSHTSH	0.0	0.0	S4373	reso	21H00123	H 1	600PP	326403
3805			0.12	98	PID	4	TSH	+0.17	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3806			0.16	99	SVI	2	TSH	+0.17	TSHTSH	0.3	0.4	S4373	reso	21H00123	H 1	600PP	326403
3807	24	132	2.15	181	DNT	P 1	VM	+1.67	TECTEH			H4599	seco	21H00087	H 0	600UL	331899
3808	28	132	0.64	90	MBM	5	TSH	+21.29	TECTEH			C5542	reso	21H00087	H 0	600UL	331899
3809	58	132			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3810			0.00	0	SAI	1	TSH	+0.34	TSHTSH	0.0		F3453	reso	21H00120	H 1	600PP	326415
3811			0.08	68	SAI	2	TSH	+0.34	TSHTSH	0.3		F3453	reso	21H00120	H 1	600PP	326415
3812			0.19	92	PID	4	TSH	+0.54	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3813			0.22	104	SAI	2	TSH	+0.54	TSHTSH	0.3		F3453	reso	21H00120	H 1	600PP	326415
3814			0.22	68	SAI	1	TSH	+0.54	TSHTSH	0.3		F3453	reso	21H00120	H 1	600PP	326415
3815	76	132	4.65	185	DNG	P 1	08C	+9.08	TECTEH			H4599	seco	21H00087	H 0	600UL	331899
3816	78	132	2.80	179	DNG	P 1	08H	+9.99	TECTEH			D4576	seco	21H00086	H 0	600UL	340988
3817	82	132	2.00	182	DNG	P 1	TSH	+12.24	TECTEH			D4576	seco	21H00086	H 0	600UL	340988
3818	100	132	0.70	19	IDM	2	TSH	-3.76	TSHTSH			F3453	reso	21H00153	H 1	600PP	345335
			4.80	184	DNT	P 1	09H	-0.06	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3820	104	132	0.51	94	MBM	5	04C	+15.52	TECTEH			F6623	reso	21H00091	H 0	600UL	331899
3821	106	132	19.91	183	DNT	P 1	09H	+0.04	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3822	112	132	0.34	76	MBM	5	TSH	+6.23	TECTEH			F6623	reso	21H00091	H 0	600UL	331899

SG 21 - All Calls (Excluding NDD and retest codes)

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 79

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3823	9	133			TBP				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3824			0.33	96	PID	2	VM	-0.34	05H06C			D3858	reso	21H00197	H 2	5602C	326187
3825			0.95	104	30	P 2	VM	-0.34	TECTEH			D3858	reso	21H00086	H 0	600UL	340988
3826			0.27	103	PID	2	VM	-0.26	06H06C			K5380	prim	21H00214	H999	5602C	340983
3827	17	133	7.05	181	DNG	P 1	06H	+9.97	TECTEH			D4576	seco	21H00086	H 0	600UL	340988
3828			5.63	180	DNT	P 1	DH	+1.95	TECTEH			D4576	seco	21H00086	H 0	600UL	340988
3829	35	133			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3830			0.14	112	PID	4	TSH	+0.38	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3831			0.15	94	SAI	2	TSH	+0.38	TSHTSH	0.2		F6623	reso	21H00122	H 1	600PP	326415
3832			0.00	0	SAI	1	TSH	+0.38	TSHTSH	0.0		F6623	reso	21H00122	H 1	600PP	326415
3833			0.14	65	SAI	2	TSH	+0.56	TSHTSH	0.2		F6623	reso	21H00122	H 1	600PP	326415
3834			0.00	0	SAI	1	TSH	+0.56	TSHTSH	0.0		F6623	reso	21H00122	H 1	600PP	326415
3835	71	133	3.10	181	INR	P 1	08C	+4.66	TECTEH			N5877	seco	21H00094	H 0	600UL	340988
3836	75	133	4.09	183	INR	P 1	08C	+8.06	TECTEH			C3340	reso	21H00094	H 0	600UL	340988
3837	87	133	2.25	179	INR	P 1	08C	+19.45	TECTEH			N5877	seco	21H00094	H 0	600UL	340988
3838	93	133	0.66	72	MBM	5	08H	+4.31	TECTEH			C5542	reso	21H00031	H 0	600UL	340910
			0.73	68	MBM	6	08H	+9.16	TECTEH			C5542	reso	21H00031	H 0	600UL	340910
			2.76	178	DNG	P 1	09C	+1.26	TECTEH			M2655	seco	21H00031	H 0	600UL	340910
3841	95	133	0.82	82	MBM	5	04C	+26.38	TECTEH			F6623	reso	21H00091	H 0	600UL	331899
3842	97	133	2.50	183	DNG	P 1	08H	+4.28	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3843	99	133	0.52	95	MBM	5	TSC	+27.38	TECTEH			F6623	reso	21H00091	H 0	600UL	331899
3844	113	133	0.46	198	INR	P 1	09C	+16.71	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3845	30	134			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3846			0.17	91	PID	4	TSH	+0.47	TSHTSH	080		M7006	reso	21H00165	H999	600PP	345335
3847			0.14	90	SAI	2	TSH	+0.47	TSHTSH	0.32		D3858	reso	21H00122	H 1	600PP	326415
3848			0	0	SAI	1	TSH	+0.47	TSHTSH	0.00		D3858	reso	21H00122	H 1	600PP	326415
3849	80	134	0.64	40	MBM	5	03H	+19.59	TECTEH			C5542	reso	21H00087	H 0	600UL	331899
3850			0.65	75	MBM	5	05H	+1.94	TECTEH			C5542	reso	21H00087	H 0	600UL	331899
3851	88	134	3.22	181	DNG	P 1	08C	+19.50	TECTEH			H4599	seco	21H00087	H 0	600UL	331899
3852	96	134	4.51	178	DNG	P 1	09C	+3.74	TECTEH			M2655	seco	21H00031	H 0	600UL	340910
3853	98	134	0.87	94	MBM	5	08H	+10.99	TECTEH			F6623	reso	21H00091	H 0	600UL	331899
3854	100	134	0.71	90	MBM	5	06H	+11.65	TECTEH			C3340	reso	21H00090	H 0	600UL	340988
3855	104	134	2.70	180	DNT	P 1	09H	-0.11	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3856			1.01	80	MBM	5	03C	+20.99	TECTEH			C3340	reso	21H00090	H 0	600UL	340988
3857			0.77	76	MBM	6	03C	+29.68	TECTEH			C3340	reso	21H00090	H 0	600UL	340988
3858	110	134	0.23	6	IDM	2	TSH	+1.46	TSHTSH			F3453	reso	21H00153	H 1	600PP	345335
3859	112	134	2.04	190	DNT	P 1	09H	+0.52	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3860			2.66	184	DNG	P 1	VH	+28.75	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3861	15	135			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3862			0.07	64	SAI	1	TSH	+0.61	TSHTSH	0.3		F6623	reso	21H00122	H 1	600PP	326415
3863			0.10	92	PID	4	TSH	+0.61	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
[illegible]			0.12	104	SAI	2	TSH	+0.61	TSHTSH	0.3		F6623	reso	21H00122	H 1	600PP	326415
	17	135	7.61	180	DNT	P 1	DC	+1.87	TECTEH			F4645	seco	21H00083	H 0	600UL	340988
3866			7.80	178	DNG	P 1	06C	+10.38	TECTEH			F4645	seco	21H00083	H 0	600UL	340988
3867	79	135	1.09	45	MBM	6	TSH	+25.07 TO+31.20	TECTEH			C5542	reso	21H00083	H 0	600UL	340988
3868			0.38	146	VOL	2	01H	+0.40	01H01H			F3453	reso	21H00179	H 3	600PP	345336
3869			0.66	116	DSI	P 1	01H	+0.47	TECTEH			J9815	prim	21H00083	H 0	600UL	340988

3870			0.18	105	VOL	2	01H	+3.22		01H01H	ENCODE			M7006	reso	21H00179	H 3	600PP	345336
3871			0.67	80	MBM	5	01H	+3.37		TECTEH				C5542	reso	21H00083	H 0	600UL	340988

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 80

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3872	95	135	1.13	17	IDM	2	TSH	-1.82		TSHTSH			F3453	reso	21H00153	H 1	600PP	345335
3873	97	135	0.68	77	MBM	5	01H	+35.14		TECTEH			C3340	reso	21H00090	H 0	600UL	340988
3874	107	135	0.40	6	IDM	2	TSH	+2.41		TSHTSH			F3453	reso	21H00153	H 1	600PP	345335
3875			0.29	6	IDM	2	TSH	+3.69		TSHTSH			F3453	reso	21H00153	H 1	600PP	345335
3876	8	136	0.44	42	INR	5	02H	+20.38		TECTEH			C3340	reso	21H00094	H 0	600UL	340988
3877	26	136	0.69	79	MBM	5	01H	+17.69		TECTEH			C3340	reso	21H00094	H 0	600UL	340988
3878			0.54	75	MBM	5	02C	+29.32		TECTEH			C3340	reso	21H00094	H 0	600UL	340988
3879	30	136	0.71	82	MBM	5	01C	+32.39		TECTEH			C3340	reso	21H00094	H 0	600UL	340988
3880			0.45	56	MBM	5	01C	+33.51		TECTEH			C3340	reso	21H00094	H 0	600UL	340988
3881	32	136	4.75	192	INR	P 1	06H	+23.57		TECTEH			N5877	seco	21H00094	H 0	600UL	340988
3882	60	136			TBS					TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3883			0.10	91	PID	4	TSH	+0.19		TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3884			0.00	0	SAI	1	TSH	+0.18		TSHTSH	0.0		F3453	reso	21H00123	H 1	600PP	326403
			0.12	92	SAI	2	TSH	+0.18		TSHTSH	0.2		F3453	reso	21H00123	H 1	600PP	326403
	66	136	4.21	181	DNG	P 1	TSC	+18.45		TECTEH			F4645	seco	21H00083	H 0	600UL	340988
3887	78	136	3.80	179	DNG	P 1	08C	+10.70		TECTEH			F4645	seco	21H00083	H 0	600UL	340988
3888	82	136	2.64	184	DNG	P 1	08C	+14.41		TECTEH			F4645	seco	21H00083	H 0	600UL	340988
3889	92	136	2.10	179	DNT	P 1	VM	+1.82		TECTEH			M2655	seco	21H00031	H 0	600UL	340910
3890			4.41	174	DNG	P 1	09C	+1.28		TECTEH			M2655	seco	21H00031	H 0	600UL	340910
3891	98	136	6.61	181	DNG	P 1	01C	+10.59		TECTEH			H2949	seco	21H00091	H 0	600UL	331899
3892	9	137	0.74	76	MBM	5	05C	+36.37		TECTEH			C5542	reso	21H00083	H 0	600UL	340988
3893	21	137	0.71	59	MBM	5	01H	+11.22		TECTEH			C5542	reso	21H00083	H 0	600UL	340988
3894	31	137			TBS					TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3895			0.15	83	SAI	2	TSH	+0.22		TSHTSH	0.2		F6623	reso	21H00122	H 1	600PP	326415
3896			0.07	32	SAI	1	TSH	+0.22		TSHTSH	0.2		F6623	reso	21H00122	H 1	600PP	326415
3897			0.21	51	MAI	1	TSH	+1.37		TSHTSH	0.3		F6623	reso	21H00122	H 1	600PP	326415
3898			0.17	101	PID	4	TSH	+1.37		TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3899			0.17	92	MAI	2	TSH	+1.37		TSHTSH	0.4		F6623	reso	21H00122	H 1	600PP	326415
3900	49	137	2.65	179	DNG	P 1	04C	+20.85		TECTEH			F4645	seco	21H00083	H 0	600UL	340988
3901	63	137	0.72	86	MBM	5	04H	+29.55		TECTEH			C5542	reso	21H00082	H 0	600UL	331899
3902			2.57	180	DNG	P 1	07H	+24.01		TECTEH			D4576	seco	21H00082	H 0	600UL	331899
3903	69	137	2.49	181	DNG	P 1	03H	+9.76		TECTEH			F4645	seco	21H00083	H 0	600UL	340988
3904	75	137	5.50	182	DNG	P 1	08C	+7.97		TECTEH			D4576	seco	21H00082	H 0	600UL	331899
3905	79	137	0.83	81	MBM	5	TSH	+36.64		TECTEH			C5542	reso	21H00082	H 0	600UL	331899
3906			1.10	85	MBM	5	07H	+21.98		TECTEH			C5542	reso	21H00082	H 0	600UL	331899
3907			0.41	76	MBM	5	06C	+5.24		TECTEH			C5542	reso	21H00082	H 0	600UL	331899
3908	83	137	0.57	98	MBM	5	TSH	+3.70		TECTEH			C5542	reso	21H00082	H 0	600UL	331899
3909			0.75	89	MBM	5	VH	+22.32		TECTEH			C5542	reso	21H00082	H 0	600UL	331899
[illegible]	89	137	2.88	179	DNG	P 1	TSC	+35.55		TECTEH			F4645	seco	21H00083	H 0	600UL	340988
	95	137	2.13	179	DNG	P 1	TSC	+27.12		TECTEH			M1680	reso	21H00091	H 0	600UL	331899
3912	99	137	2.28	180	DNG	P 1	04H	+13.12		TECTEH			H2949	seco	21H00091	H 0	600UL	331899
3913			0.42	13	INR	P 1	04C	+5.65	TO+7.66	TECTEH			F6623	reso	21H00091	H 0	600UL	331899
3914			0.18	22	INR	P 1	03C	+31.35	TO+32.69	TECTEH			F6623	reso	21H00091	H 0	600UL	331899
3915	101	137	3.14	177	DNT	P 1	09H	+0.20		TECTEH			D4576	seco	21H00090	H 0	600UL	340988

3916	103	137	2.16	187	DNG	P	1	01C	+6.21	TECTEH			H2949	seco	21H00091	H	0	600UL	331899
3917	4	138	12.83	182	DNT	P	1	VM	+0.00	06HTEC			D4576	seco	21C00064	C	0	600CS	341612
3918	6	138	12.35	182	DNG	P	1	06H	+5.34	TECTEH			F4645	seco	21H00083	H	0	600UL	340988
3919	12	138			TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
			0.63	154	PID		3	SBH	+22.38	SBHSTH			D3858	prim	21H00226	H999		500PP	326656

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 81

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3921					DIS		3	SBH	+22.38	SBHSTH			P6179	seco	21H00225	H10	500PP	326656
3922			0.24	100	SAI		2	TSH	+0.77	TSHTSH	0.3		F6623	reso	21H00122	H	1	600PP	326415
3923			0.15	84	PID		4	TSH	+0.77	TSHTSH	080		F3453	reso	21H00152	H999		600PP	345335
3924			0.37	57	SAI		1	TSH	+0.77	TSHTSH	0.3		F6623	reso	21H00122	H	1	600PP	326415
3925			0.14	89	SAI		2	TSH	+1.06	TSHTSH	0.2		F6623	reso	21H00122	H	1	600PP	326415
3926			0.00	0	SAI		1	TSH	+1.06	TSHTSH	0.0		F6623	reso	21H00122	H	1	600PP	326415
3927			0.16	92	SAI		2	TSH	+1.24	TSHTSH	0.3		F6623	reso	21H00122	H	1	600PP	326415
3928			0.18	52	SAI		1	TSH	+1.24	TSHTSH	0.2		F6623	reso	21H00122	H	1	600PP	326415
3929			0.11	78	SAI		2	TSH	+2.76	TSHTSH	0.4		F6623	reso	21H00122	H	1	600PP	326415
3930			0.00	0	SAI		1	TSH	+2.76	TSHTSH	0.0		F6623	reso	21H00122	H	1	600PP	326415
	52	138			TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
			0.23	100	SAI		2	TSH	+0.45	TSHTSH	0.4		F3453	reso	21H00123	H	1	600PP	326403
3933			0.21	104	PID		4	TSH	+0.45	TSHTSH	080		F3453	reso	21H00152	H999		600PP	345335
3934			0.33	61	SAI		1	TSH	+0.45	TSHTSH	0.3		F3453	reso	21H00123	H	1	600PP	326403
3935	56	138	4.20	183	DNG	P	1	03C	+11.53	TECTEH			D4576	seco	21H00082	H	0	600UL	331899
3936	60	138			TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
3937			0.10	113	PID		4	TSH	+0.15	TSHTSH	080		F3453	reso	21H00152	H999		600PP	345335
3938			0.00	0	SAI		1	TSH	+0.15	TSHTSH	0.0		F3453	reso	21H00123	H	1	600PP	326403
3939			0.10	123	SAI		2	TSH	+0.15	TSHTSH	0.2		F3453	reso	21H00123	H	1	600PP	326403
3940			0.99	76	MBM		5	VM	+11.58	TECTEH			C5542	reso	21H00082	H	0	600UL	331899
3941			0.82	77	MBM		5	VM	+13.00	TECTEH			C5542	reso	21H00082	H	0	600UL	331899
3942			0.51	51	MBM		5	VM	+15.38	TECTEH			C5542	reso	21H00082	H	0	600UL	331899
3943	62	138	1.11	63	MBM		5	VM	+26.04	TECTEH			C5542	reso	21H00083	H	0	600UL	340988
3944	64	138	3.98	175	DNG	P	1	07C	+32.66	TECTEH			D4576	seco	21H00082	H	0	600UL	331899
3945	72	138	2.96	183	DNG	P	1	04C	+21.70	TECTEH			D4576	seco	21H00082	H	0	600UL	331899
3946	76	138	2.08	179	DNT	P	1	08C	-0.09	TECTEH			D4576	seco	21H00082	H	0	600UL	331899
3947			5.70	183	DNG	P	1	08C	+9.06	TECTEH			D4576	seco	21H00082	H	0	600UL	331899
3948	94	138	0.76	89	MBM		6	TSC	+16.72	TECTEH			C3340	reso	21H00090	H	0	600UL	340988
3949	100	138	11.36	179	DNT	P	1	09H	-0.43	TECTEH			H2949	seco	21H00091	H	0	600UL	331899
3950			19.10	181	DNT	P	1	09H	+0.52	TECTEH			H2949	seco	21H00091	H	0	600UL	331899
3951			3.54	183	DNG	P	1	TSC	+12.39	TECTEH			H2949	seco	21H00091	H	0	600UL	331899
3952	104	138	3.11	179	DNG	P	1	08H	+13.98	TECTEH			M2655	seco	21H00031	H	0	600UL	340910
3953			6.16	175	DNG	P	1	08H	+16.68	TECTEH			M2655	seco	21H00031	H	0	600UL	340910
3954			5.27	176	DNT	P	1	09H	-0.02	TECTEH			M2655	seco	21H00031	H	0	600UL	340910
3955			2.16	170	DNT	P	1	09H	+0.56	TECTEH			M2655	seco	21H00031	H	0	600UL	340910
			8.28	177	DNG	P	1	09H	+1.42	TECTEH			M2655	seco	21H00031	H	0	600UL	340910
	17	139	0.52	83	MBM		5	05H	+32.56	TECTEH			C5542	reso	21H00077	H	0	600UL	332251
3958			0.95	93	MBM		5	01C	+19.01	TECTEH			C5542	reso	21H00077	H	0	600UL	332251
3959	43	139	8.03	178	DNG	P	1	07H	+9.05	TECTEH			D4576	seco	21H00077	H	0	600UL	332251
3960	49	139	2.68	179	DNG	P	1	05C	+12.49	TECTEH			D4576	seco	21H00077	H	0	600UL	332251
3961			3.35	176	DNG	P	1	04C	+15.77	TECTEH			D4576	seco	21H00077	H	0	600UL	332251

3962	53	139	0.67	94	MBM	5	02C	+22.90	TECTEH			C5542	reso	21H00078	H 0	600UL	331899
3963	55	139	1.99	183	INR	P 1	04C	+14.69	TECTEH			D4576	seco	21H00077	H 0	600UL	332251
3964	59	139			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3965			0.15	94	PID	4	TSH	+0.20	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
			0.19	27	SAI	1	TSH	+0.20	TSHTSH	0.2		F6623	reso	21H00122	H 1	600PP	326415
3967			0.16	96	SAI	2	TSH	+0.20	TSHTSH	0.3		F6623	reso	21H00122	H 1	600PP	326415
3968	67	139	1.57	86	MBM	6	06C	+16.51	TECTEH			C5542	reso	21H00081	H 0	600UL	332251
3969	69	139	0.70	69	MBM	5	05C	+11.56	TECTEH			C5542	reso	21H00082	H 0	600UL	331899

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 82

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
3970	89	139	0.54	60	MBM	5	04C	+36.98	TECTEH			C5542	reso	21H00083	H 0	600UL	340988
3971			2.98	182	DNG	P 1	TSC	+31.70	TECTEH			F4645	seco	21H00083	H 0	600UL	340988
3972	91	139	2.62	187	DNT	P 1	02C	-0.79	TECTEH			H2949	seco	21H00091	H 0	600UL	331899
3973	93	139	0.82	71	MBM	5	07H	+22.06	TECTEH			C3340	reso	21H00090	H 0	600UL	340988
3974			0.82	37	MBM	6	08H	+20.60	TECTEH			C3340	reso	21H00090	H 0	600UL	340988
3975	2	140	0.44	87	MBM	5	TSH	+8.34	06HTEH			F3453	reso	21H00099	H 9	600UL	331963
3976			0.68	55	MBM	6	TSH	+13.86	06HTEH			F3453	reso	21H00099	H 9	600UL	331963
	6	140	3.88	179	DNG	P 1	05H	+35.57	TECTEH			D4576	seco	21H00077	H 0	600UL	332251
	10	140			TBP				TSHTSH	SVISLV	ADDTBP	D3858	reso	21H00115	H 1	600PP	326403
3979			1.15	79	SVI	3	SBH	+2.14	SBHSTH			D3858	prim	21H00225	H10	500PP	326656
3980			1.24	253	PID	3	SBH	+2.14	SBHSTH			D3858	prim	21H00226	H999	500PP	326656
3981			0.00	0	SAI	1	TSH	+0.74	TSHTSH	0.0		F6623	reso	21H00122	H 1	600PP	326415
3982			0.15	108	SAI	2	TSH	+0.74	TSHTSH	0.2		F6623	reso	21H00122	H 1	600PP	326415
3983			0.14	102	PID	4	TSH	+0.74	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3984	28	140			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3985			0.08	127	SAI	1	TSH	+0.73	TSHTSH	0.2		F6623	reso	21H00122	H 1	600PP	326415
3986			0.14	122	PID	4	TSH	+0.73	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3987			0.13	120	SAI	2	TSH	+0.73	TSHTSH	0.3		F6623	reso	21H00122	H 1	600PP	326415
3988			0.70	63	MBM	5	TSH	+31.05	TECTEH			C5542	reso	21H00077	H 0	600UL	332251
3989	38	140	3.96	177	DNT	P 1	VM	-1.58	TECTEH			D4576	seco	21H00077	H 0	600UL	332251
3990	50	140			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
3991			0.19	47	SAI	1	TSH	+0.44	TSHTSH	0.3		F6623	reso	21H00122	H 1	600PP	326415
3992			0.16	141	PID	4	TSH	+0.44	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
3993			0.15	127	SAI	2	TSH	+0.44	TSHTSH	0.6		F6623	reso	21H00122	H 1	600PP	326415
3994	58	140	2.11	175	DNG	P 1	04C	+27.34	TECTEH			D4576	seco	21H00077	H 0	600UL	332251
3995	70	140	1.40	184	INR	P 1	03H	+14.59	TECTEH			D4576	seco	21H00077	H 0	600UL	332251
3996	84	140	4.32	180	DNG	P 1	08H	+15.50	TECTEH			A9608	reso	21H00078	H 0	600UL	331899
3997	94	140	0.37	131	INR	P 1	02H	-0.38	TECTEH			C3340	reso	21H00090	H 0	600UL	340988
3998	98	140	3.93	181	DNT	P 1	09H	+0.50	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
3999	5	141	15.98	182	DNT	P 1	VM	+0.73	04HTEC			N2574	seco	21C00069	C 0	580SF	339357
4000					OBS		06C	+7.74	06CTEC			A9608	reso	21C00064	C 0	600CS	341612
4001	17	141	6.53	177	DNG	P 1	06H	+10.10	TECTEH			D4576	seco	21H00077	H 0	600UL	332251
[illegible]			5.20	174	DNG	P 1	DH	+1.72	TECTEH			D4576	seco	21H00077	H 0	600UL	332251
	29	141	1.77	29	MBM	5	TSC	+22.19	TECTEH			C5542	reso	21H00077	H 0	600UL	332251
4004	31	141			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
4005			0.18	88	SAI	2	TSH	+0.53	TSHTSH	0.5		F6623	reso	21H00122	H 1	600PP	326415
4006			0.23	123	SAI	1	TSH	+0.53	TSHTSH	0.4		F6623	reso	21H00122	H 1	600PP	326415
4007			0.20	122	PID	4	TSH	+0.93	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335

4008			0.37	115	MAI	1	TSH	+0.93	TSHTSH	0.4			F6623	reso	21H00122	H 1	600PP	326415
4009			0.19	115	MAI	2	TSH	+0.93	TSHTSH	0.5			F6623	reso	21H00122	H 1	600PP	326415
4010	39	141			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
4011			0.11	86	MAI	2	TSH	+0.45	TSHTSH	0.5			F6623	reso	21H00122	H 1	600PP	326415
			0.10	116	PID	4	TSH	+0.45	TSHTSH	080			F3453	reso	21H00152	H999	600PP	345335
[illegible]			0.00	0	MAI	1	TSH	+0.45	TSHTSH	0.0			F6623	reso	21H00122	H 1	600PP	326415
4014	47	141			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
4015			0.12	92	PID	4	TSH	+0.67	TSHTSH	080			F3453	reso	21H00152	H999	600PP	345335
4016			0.00	0	SAI	1	TSH	+0.67	TSHTSH	0.0			F6623	reso	21H00122	H 1	600PP	326415
4017			0.12	97	SAI	2	TSH	+0.67	TSHTSH	0.3			F6623	reso	21H00122	H 1	600PP	326415
4018	49	141	2.65	181	DNG	P 1	02C	+6.40	TECTEH				A9608	reso	21H00078	H 0	600UL	331899

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 83

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4019			2.56	182	DNG	P 1	02C	+17.39	TECTEH			F4645	seco	21H00078	H 0	600UL	331899
4020	61	141	0.96	94	MBM	5	04H	+2.48	TECTEH			C5542	reso	21H00078	H 0	600UL	331899
4021	65	141	3.40	181	DNG	P 1	DH	+15.09	TECTEH			N5877	seco	21H00094	H 0	600UL	340988
4022	73	141	0.30	88	MBM	5	07H	+12.96	TECTEH			C5542	reso	21H00078	H 0	600UL	331899
	85	141	2.25	181	DNG	P 1	TSC	+23.41	TECTEH			A9608	reso	21H00078	H 0	600UL	331899
	87	141	3.25	179	DNG	P 1	08C	+18.55	TECTEH			D3858	reso	21H00077	H 0	600UL	332251
4025	89	141	4.62	176	DNT	P 1	01C	-1.19	TECTEH			D4576	seco	21H00077	H 0	600UL	332251
4026	36	142	4.39	184	DNT	P 1	VM	+1.96	TECTEH			A9608	reso	21H00078	H 0	600UL	331899
4027			0.66	86	MBM	5	05C	+1.69	TECTEH			C5542	reso	21H00078	H 0	600UL	331899
4028	38	142			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
4029			0.12	94	SAI	2	TSH	+0.53	TSHTSH	0.3		F6623	reso	21H00122	H 1	600PP	326415
4030			0.12	86	PID	4	TSH	+0.53	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
4031			0.09	46	SAI	1	TSH	+0.53	TSHTSH	0.3		F6623	reso	21H00122	H 1	600PP	326415
4032	42	142			TBS				TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
4033			0.10	84	PID	4	TSH	+0.57	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
4034			0.29	49	SAI	1	TSH	+0.57	TSHTSH	0.3		F6623	reso	21H00122	H 1	600PP	326415
4035			0.11	82	SAI	2	TSH	+0.57	TSHTSH	0.2		F6623	reso	21H00122	H 1	600PP	326415
4036			2.84	178	DNG	P 1	DH	+9.67	TECTEH			D4576	seco	21H00077	H 0	600UL	332251
4037			3.36	177	DNG	P 1	DH	+12.91	TECTEH			C5542	reso	21H00077	H 0	600UL	332251
4038	50	142	3.39	184	DNG	P 1	06C	+3.85	TECTEH			D4576	seco	21H00077	H 0	600UL	332251
4039	78	142	2.04	176	DNG	P 1	01H	+16.67	TECTEH			D4576	seco	21H00077	H 0	600UL	332251
4040			6.71	175	DNT	P 1	DC	+0.96	TECTEH			D4576	seco	21H00077	H 0	600UL	332251
4041	80	142	3.80	184	DNG	P 1	07H	+20.23	TECTEH			A9608	reso	21H00078	H 0	600UL	331899
4042			4.22	183	DNG	P 1	07H	+20.80	TECTEH			A9608	reso	21H00078	H 0	600UL	331899
4043			2.94	178	DNG	P 1	07H	+21.32	TECTEH			A9608	reso	21H00078	H 0	600UL	331899
4044			6.32	181	DNG	P 1	07H	+21.75	TECTEH			A9608	reso	21H00078	H 0	600UL	331899
4045			5.14	180	DNG	P 1	07H	+24.31	TECTEH			A9608	reso	21H00078	H 0	600UL	331899
4046			2.94	182	DNG	P 1	07C	+10.57	TECTEH			A9608	reso	21H00078	H 0	600UL	331899
4047			7.01	183	DNG	P 1	07C	+24.62	TECTEH			A9608	reso	21H00078	H 0	600UL	331899
[illegible]	88	142	15.77	180	DNG	P 1	08H	+6.51	TECTEH			A9608	reso	21H00078	H 0	600UL	331899
			6.91	183	DNG	P 1	08H	+17.35	TECTEH			A9608	reso	21H00078	H 0	600UL	331899
[illegible]			5.37	184	DNG	P 1	08H	+19.67	TECTEH			A9608	reso	21H00078	H 0	600UL	331899
4051	98	142	6.01	178	DNG	P 1	TSH	+25.70	TECTEH			M2655	seco	21H00031	H 0	600UL	340910
4052	100	142	10.94	182	DNG	P 1	08C	+8.26	TECTEH			D4576	seco	21H00090	H 0	600UL	340988
4053			11.54	181	DNG	P 1	08C	+9.79	TECTEH			D4576	seco	21H00090	H 0	600UL	340988

4054			5.66	179	DNG	P	1	08C	+11.63	TECTEH			D4576	seco	21H00090	H	0	600UL	340988
4055			4.48	180	DNG	P	1	08C	+12.27	TECTEH			D4576	seco	21H00090	H	0	600UL	340988
4056	7	143	0.77	88	MBM		5	05C	+13.52	TECTEH			C5542	reso	21H00077	H	0	600UL	332251
4057	39	143			TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
			0.16	111	SAI		2	TSH	+0.16	TSHTSH	0.3		F6623	reso	21H00122	H	1	600PP	326415
[illegible]			0.28	60	SAI		1	TSH	+0.16	TSHTSH	0.3		F6623	reso	21H00122	H	1	600PP	326415
4060			0.17	126	PID		4	TSH	+0.16	TSHTSH	080		F3453	reso	21H00152	H999		600PP	345335
4061			2.99	179	DNT	P	1	VM	-1.48	TECTEH			D4576	seco	21H00077	H	0	600UL	332251
4062	47	143	4.80	176	DNG	P	1	06C	+18.91	TECTEH			D4576	seco	21H00077	H	0	600UL	332251
4063	57	143	3.94	187	DNG	P	1	TSC	+5.87	TECTEH			A9608	reso	21H00078	H	0	600UL	331899
4064	59	143	1.96	180	INR	P	1	03H	+12.64	TECTEH			D4576	seco	21H00077	H	0	600UL	332251
4065			4.83	179	DNT	P	1	VM	-1.56	TECTEH			D4576	seco	21H00077	H	0	600UL	332251
4066	63	143			TBS					TSHTSH			D3858	reso	21H00115	H	1	600PP	326403
4067			0.00	0	SCI		1	TSH	-0.08	TSHTSH	0.0		F6623	reso	21H00122	H	1	600PP	326415

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 84

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4068			0.12	85	SCI	P	1	TSH -0.08	TSHTSH	0.4		F6623	reso	21H00122	H	1 600PP	326415
			0.19	40	PID	P	1	TSH -0.08	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
			0.65	81	MBM		5	05H +11.51	TECTEH			C5542	reso	21H00077	H	0 600UL	332251
4071			3.44	177	DNG	P	1	07C +24.08	TECTEH			D4576	seco	21H00077	H	0 600UL	332251
4072			0.66	69	MBM		5	04C +7.31	TECTEH			C5542	reso	21H00077	H	0 600UL	332251
4073	75	143	0.84	65	MBM		5	03C +31.43	TECTEH			C5542	reso	21H00077	H	0 600UL	332251
4074	79	143	0.70	85	MBM		5	VM +4.87	TECTEH			C5542	reso	21H00077	H	0 600UL	332251
4075	83	143	0.49	179	IDM		2	TSH +2.96	TSHTSH			F6623	reso	21H00122	H	1 600PP	326415
4076			2.02	182	DNG	P	1	08C +1.61	TECTEH			D4576	seco	21H00077	H	0 600UL	332251
4077			1.74	184	INR	P	1	07C +21.89	TECTEH			D4576	seco	21H00077	H	0 600UL	332251
4078	95	143	5.36	178	DNG	P	1	06H +16.90	TECTEH			H2949	seco	21H00091	H	0 600UL	331899
4079	99	143	1.22	85	MBM		6	02C +25.77	TECTEH			C3340	reso	21H00090	H	0 600UL	340988
4080	4	144	0.30	72	MBM		5	02H +24.60	06HTEH			F3453	reso	21H00095	H	9 600UL	340988
4081	32	144			TBS				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
4082			0.20	93	PID		4	TSH +0.50	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
4083			0.22	85	MAI		1	TSH +0.50	TSHTSH	0.3		F6623	reso	21H00127	H	1 600PP	326403
4084			0.22	98	MAI		2	TSH +0.50	TSHTSH	0.3		F6623	reso	21H00127	H	1 600PP	326403
4085			0.99	117	MBM		5	03C +2.35	TECTEH			C5542	reso	21H00078	H	0 600UL	331899
4086	68	144	0.29	82	MBM		5	DH +20.37	TECTEH			C5542	reso	21H00072	H	0 600UL	331899
4087	72	144	3.65	180	DNG	P	1	07C +10.04	TECTEH			A9574	seco	21H00072	H	0 600UL	331899
4088	88	144	0.63	80	MBM		5	TSH +2.97	TECTEH			C5542	reso	21H00072	H	0 600UL	331899
4089			0.21	113	VOL		2	TSH +3.16	TSHTSH			F3453	reso	21H00123	H	1 600PP	326403
4090			9.47	179	DNG	P	1	TSH +17.02	TECTEH			A9574	seco	21H00072	H	0 600UL	331899
4091	31	145			TBS				TSHTSH			D3858	reso	21H00115	H	1 600PP	326403
4092			0.16	90	SAI		2	TSH +0.78	TSHTSH	0.5		L2157	reso	21H00126	H	1 600PP	326415
4093			0.24	70	SAI		1	TSH +0.78	TSHTSH	0.5		L2157	reso	21H00126	H	1 600PP	326415
4094			0.15	94	PID		4	TSH +0.78	TSHTSH	080		F3453	reso	21H00152	H999	600PP	345335
	55	145	4.67	180	DNG	P	1	VM +20.49	TECTEH			A9574	seco	21H00072	H	0 600UL	331899
[illegible]	59	145	2.07	181	DNG	P	1	03H +14.20	TECTEH			A9574	seco	21H00072	H	0 600UL	331899
4097	73	145	0.83	91	MBM		5	TSH +35.62	TECTEH			M7006	reso	21H00071	H	0 600UL	332251
4098	89	145	4.06	179	DNG	P	1	TSC +30.83	TECTEH			N2574	seco	21H00071	H	0 600UL	332251
4099	93	145	0.50	85	22	P	2	VC -0.98	TECTEH			D4576	seco	21H00090	H	0 600UL	340988

4100			3.52	32	NRC	2	TSC	+0.00	TECTEH				C3340	reso	21H00090	H 0	600UL	340988
4101	10	146			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
4102			0.12	73	SAI	2	TSH	+0.34	TSHTSH	0.3			L2157	reso	21H00126	H 1	600PP	326415
4103			0.12	110	PID	4	TSH	+0.34	TSHTSH	080			F3453	reso	21H00152	H999	600PP	345335
			0.00	0	SAI	1	TSH	+0.34	TSHTSH	0.0			L2157	reso	21H00126	H 1	600PP	326415
[illegible]			0.0	0	SAI	1	TSH	+0.81	TSHTSH	0.0			L2157	reso	21H00126	H 1	600PP	326415
4106			0.10	93	SAI	2	TSH	+0.81	TSHTSH	0.2			L2157	reso	21H00126	H 1	600PP	326415
4107	20	146			TBS				TSHTSH				D3858	reso	21H00115	H 1	600PP	326403
4108			0.21	94	PID	4	TSH	+0.91	TSHTSH	080			F3453	reso	21H00152	H999	600PP	345335
4109			0.23	66	MAI	1	TSH	+0.91	TSHTSH	0.3			F6623	reso	21H00127	H 1	600PP	326403
4110			0.22	96	MAI	2	TSH	+0.91	TSHTSH	0.6			F6623	reso	21H00127	H 1	600PP	326403
4111			1.56	69	MBM	6	05H	+14.01	TECTEH				C5542	reso	21H00072	H 0	600UL	331899
4112	22	146	4.20	177	DNG	P 1	05C	+15.72	TECTEH				N2574	seco	21H00071	H 0	600UL	332251
4113	36	146	2.09	186	DNT	P 1	07H	+0.02	TECTEH				N2574	seco	21H00071	H 0	600UL	332251
4114	42	146	4.83	176	DNG	P 1	TSH	+22.88	TECTEH				A9574	seco	21H00072	H 0	600UL	331899
4115	50	146	5.08	179	DNG	P 1	01C	+5.23	TECTEH				A9574	seco	21H00072	H 0	600UL	331899
4116	92	146	9.21	182	DNG	P 1	08H	+6.22	TECTEH				D4576	seco	21H00090	H 0	600UL	340988

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 85

	ROW	COL	VOLTS	DEG	PCT	CHN	PLAN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE	SIZE	PROBE S/N
4117			5.35	178	DNG	P 1	08H	+7.09	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4118			5.86	183	DNG	P 1	08H	+7.67	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4119			5.54	178	DNG	P 1	08H	+8.53	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4120			3.11	175	DNG	P 1	08H	+10.13	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4121			3.46	176	DNG	P 1	08H	+13.27	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4122			4.20	177	DNG	P 1	08H	+14.04	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4123			4.25	176	DNG	P 1	08H	+14.57	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4124			3.10	175	DNG	P 1	08H	+15.90	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4125			5.00	175	DNG	P 1	08H	+17.37	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4126			3.28	186	DNG	P 1	08H	+18.65	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4127			4.81	186	DNG	P 1	08H	+20.20	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4128			3.74	183	DNG	P 1	08H	+21.05	TECTEH			C3340	reso	21H00090	H 0	600UL			340988
4129			7.65	185	INR	P 1	08H	+22.15	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4130			7.65	182	DNT	P 1	09H	-0.36	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4131			7.25	178	DNT	P 1	08C	-0.74	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4132			6.51	178	DNT	P 1	08C	+0.32	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4133			16.54	180	DNT	P 1	08C	+1.25	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4134			12.36	182	DNG	P 1	08C	+13.73	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4135			4.50	181	DNG	P 1	08C	+14.04	TECTEH			C3340	reso	21H00090	H 0	600UL			340988
4136			4.01	178	DNG	P 1	08C	+15.95	TECTEH			D4576	seco	21H00090	H 0	600UL			340988
4137	5	147	0.36	75	MBM	5	03H	+8.60	06HTEH			F3453	reso	21H00095	H 9	600UL			340988
4138	11	147			INF		06C	+9.57	TECTEH	HR		M7006	reso	21H00071	H 0	600UL			332251
4139			1.40	86	NQI	5	06C	+12.23	TECTEH			D3858	reso	21H00071	H 0	600UL			332251
[illegible]					NDF		06C	+12.23	05H06C			M7006	reso	21H00202	H 2	5602C			326244
	21	147	0.56	54	MBM	5	TSC	+2.31	TECTEH			M7006	reso	21H00071	H 0	600UL			332251
[illegible]	27	147	4.46	185	DNG	P 1	06C	+18.09	TECTEH			A9574	seco	21H00072	H 0	600UL			331899
4143			0.69	88	MBM	5	TSC	+4.92	TECTEH			C5542	reso	21H00072	H 0	600UL			331899
4144	29	147	5.80	182	DNT	P 1	VM	-1.55	TECTEH			N2574	seco	21H00071	H 0	600UL			332251
4145	37	147	5.97	182	DNT	P 1	VM	-1.64	TECTEH			N2574	seco	21H00071	H 0	600UL			332251

4146	67	147	0.80	39	MBM	5	06C	+7.18	TECTEH			C5542	reso	21H00072	H	0	600UL	331899
4147	91	147	0.40	14	IDM	2	TSH	+2.41	TSHTSH			F3453	reso	21H00153	H	1	600PP	345335
4148			2.46	181	DNG	P 1	08H	+7.82	TECTEH			D4576	seco	21H00090	H	0	600UL	340988
4149			2.33	183	DNG	P 1	08C	+16.23	TECTEH			D4576	seco	21H00090	H	0	600UL	340988
	2	148	1.42	83	MBM	6	03C	+35.72	06CTEC			C5542	reso	21C00065	C	1	600CS	341613
4151	14	148			TBP				TSHTSH	RMVTBS	ADDTBP	D3858	reso	21H00115	H	1	600PP	326403
4152			0.16	115	PID	4	TSH	+0.24	TSHTSH	080		F3453	reso	21H00152	H999		600PP	345335
4153			0.13	26	SAI	1	TSH	+0.24	TSHTSH	0.3		L2157	reso	21H00126	H	1	600PP	326415
4154			0.14	89	SAI	2	TSH	+0.24	TSHTSH	0.3		L2157	reso	21H00126	H	1	600PP	326415
4155			0.68	77	MBM	5	01H	+6.70	TECTEH			M7006	reso	21H00071	H	0	600UL	332251
4156	24	148	3.77	179	DNT	P 1	VM	+1.83	TECTEH			N2574	seco	21H00071	H	0	600UL	332251
4157			2.76	182	DNG	P 1	06C	+11.88	TECTEH			N2574	seco	21H00071	H	0	600UL	332251
4158	30	148	0.53	90	MBM	5	03H	+21.62	TECTEH			C5542	reso	21H00072	H	0	600UL	331899
4159	32	148	2.32	183	DNG	P 1	06H	+22.00	TECTEH			N2574	seco	21H00071	H	0	600UL	332251
4160	17	149	0.70	80	MBM	5	04H	+29.04	TECTEH			A9608	reso	21H00069	H	0	600UL	332251
4161			1.09	80	MBM	5	04H	+31.57	TECTEH			A9608	reso	21H00069	H	0	600UL	332251
4162			5.42	179	DNG	P 1	06H	+9.60	TECTEH			M2655	seco	21H00069	H	0	600UL	332251
4163			5.64	179	DNT	P 1	DH	+1.77	TECTEH			M2655	seco	21H00069	H	0	600UL	332251
4164	19	149			TBP				TSHTSH	RMVTBS	ADDTBP	D3858	reso	21H00115	H	1	600PP	326403
4165			0.18	113	PID	4	TSH	+0.17	TSHTSH	080		F3453	reso	21H00152	H999		600PP	345335

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 86

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4166			0.21	82	SAI	2	TSH +0.17	TSHTSH	0.3		F6623	reso	21H00127	H 1	600PP	326403
4167			0.07	63	SAI	1	TSH +0.17	TSHTSH	0.2		F6623	reso	21H00127	H 1	600PP	326403
4168	31	149	0.84	88	MBM	5	TSH +28.13	TECTEH			C5542	reso	21H00070	H 0	600UL	331934
4169			1.50	187	INR	P 1	04C +32.23	TECTEH			O8795	seco	21H00070	H 0	600UL	331934
4170	45	149	1.13	85	MBM	5	03C +10.25	TECTEH			A9608	reso	21H00069	H 0	600UL	332251
4171	47	149	3.47	178	DNG	P 1	02H +22.61	TECTEH			O8795	seco	21H00070	H 0	600UL	331934
4172			4.62	179	DNG	P 1	07H +17.16	TECTEH			O8795	seco	21H00070	H 0	600UL	331934
4173	49	149	2.78	179	DNG	P 1	04C +15.17	TECTEH			M2655	seco	21H00069	H 0	600UL	332251
4174	65	149	0.86	87	MBM	5	02H +9.15	TECTEH			A9608	reso	21H00069	H 0	600UL	332251
4175	67	149	0.25	87	PLP	9	TSC +0.29	TSCTSC			B4052	prim	21C00006	C 2	600PP	340835
4176	75	149	1.32	115	MBM	6	02H +24.99	TECTEH			C5542	reso	21H00070	H 0	600UL	331934
4177	81	149	7.17	183	DNG	P 1	07C +15.62	TECTEH			M2655	seco	21H00069	H 0	600UL	332251
4178	83	149	0.74	80	MBM	6	05C +29.86	TECTEH			C5542	reso	21H00070	H 0	600UL	331934
4179	85	149	0.34	71	PLP	9	TSC +0.82	TSCTSC			B4052	prim	21C00005	C 2	600PP	345348
4180	87	149	1.00	85	MBM	5	06H +19.55	TECTEH			A9608	reso	21H00069	H 0	600UL	332251
4181	2	150	0.53	63	MBM	5	04H +21.32	06HTEH			F3453	reso	21H00099	H 9	600UL	331963
4182			4.70	175	DNT	P 1	VM -0.15	06HTEC			T7451	seco	21C00065	C 1	600CS	341613
4183	6	150			TBP			TSHTSH			D3858	reso	21H00115	H 1	600PP	326403
4184			0.00	0	SAI	1	06H +0.67	05H06C	0.0		M1680	reso	21H00202	H 2	5602C	326244
4185			0.37	71	SAI	2	06H +0.67	05H06C	0.3		F3453	reso	21H00202	H 2	5602C	326244
[illegible]			0.26	70	PID	2	06H +0.67	06H06C			K5380	prim	21H00214	H999	5602C	340983
	10	150	1.11	82	MBM	5	03H +20.15	TECTEH			C5542	reso	21H00070	H 0	600UL	331934
[illegible]	12	150	1.01	91	PPS	P 1	06H +5.19	05H06C			I3805	seco	21H00202	H 2	5602C	326244
4189	20	150			TBP			TSHTSH	RMVTBS	ADDTBP	D3858	reso	21H00115	H 1	600PP	326403
4190			0.16	81	SAI	1	TSH +0.28	TSHTSH	0.3		L2157	reso	21H00126	H 1	600PP	326415
4191			0.14	116	SAI	2	TSH +0.28	TSHTSH	0.2		L2157	reso	21H00126	H 1	600PP	326415

4192			0.13	94	PID	4	TSH	+0.28	TSHTSH	080		F3453	reso	21H00152	H999	600PP		345335	
4193			6.93	184	DNG	P 1	06C	+12.09	TECTEH			M2655	seco	21H00069	H 0	600UL		332251	
4194	44	150	2.38	177	DNG	P 1	02C	+11.40	TECTEH			M2655	seco	21H00069	H 0	600UL		332251	
4195	46	150	1.06	79	MBM	5	01H	+16.06	TECTEH			C5542	reso	21H00070	H 0	600UL		331934	
			0.55	75	MBM	5	TSC	+21.17	TECTEH			C5542	reso	21H00070	H 0	600UL		331934	
	60	150	2.88	180	DNG	P 1	06H	+7.80	TECTEH			M2655	seco	21H00069	H 0	600UL		332251	
4198	64	150	0.45	73	MBM	5	02C	+10.64	TECTEH			A9608	reso	21H00069	H 0	600UL		332251	
4199	66	150	0.38	85	PLP	9	TSC	+0.28	TSCTSC			B4052	prim	21C00006	C 2	600PP		340835	
4200	72	150	2.78	180	DNG	P 1	08C	+5.28	TECTEH			M2655	seco	21H00069	H 0	600UL		332251	
4201			4.78	183	DNG	P 1	08C	+8.70	TECTEH			M2655	seco	21H00069	H 0	600UL		332251	
4202			4.06	182	DNG	P 1	08C	+9.14	TECTEH			M2655	seco	21H00069	H 0	600UL		332251	
4203			3.21	180	DNG	P 1	08C	+9.99	TECTEH			M2655	seco	21H00069	H 0	600UL		332251	
4204			7.85	183	DNG	P 1	08C	+10.69	TECTEH			M2655	seco	21H00069	H 0	600UL		332251	
4205	76	150	1.53	183	INR	P 1	07H	+17.04	TECTEH			A9608	reso	21H00069	H 0	600UL		332251	
4206			2.05	181	DNT	P 1	VM	+1.40	TECTEH			M2655	seco	21H00069	H 0	600UL		332251	
4207			6.64	183	DNG	P 1	07C	+14.36	TECTEH			M2655	seco	21H00069	H 0	600UL		332251	
4208	80	150	4.88	7	INR	P 1	07H	+22.31	TECTEH			A9608	reso	21H00069	H 0	600UL		332251	
4209	84	150	0.39	71	PLP	9	TSC	+0.79	TSCTSC			B4052	prim	21C00005	C 2	600PP		345348	
4210	9	151	0.36	78	16	P 2	DH	+0.39	TECTEH	LOC.OK		C3340	reso	21H00069	H 0	600UL		332251	
4211			0.38	139	WAR	2	DH	+0.85	05H06C	LOC.OK		C3340	reso	21H00214	H 2	5602C		340983	
4212			0.23	14	11	P 2	VM	-1.90	TECTEH			C3340	reso	21H00069	H 0	600UL		332251	
4213			0.21	121	WAR	2	VM	-1.80	05H06C			K5380	prim	21H00214	H 2	5602C		340983	
4214	17	151	5.72	181	DNT	P 1	DH	+2.00	TECTEH			M2655	seco	21H00069	H 0	600UL		332251	

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4215	21	151	0.74	77	MBM	5	04H	+16.81	TECTEH			A9608	reso	21H00069	H 0	600UL	332251
4216	23	151	1.20	89	MBM	5	05C	+26.31	TECTEH			C5542	reso	21H00070	H 0	600UL	331934
4217			2.35	85	MBM	6	TSC	+8.08	TECTEH			C5542	reso	21H00070	H 0	600UL	331934
4218			1.91	168	INR	P 1	TSC	+8.13	TECTEH			C5542	reso	21H00070	H 0	600UL	331934
4219			2.44	170	DNG	P 1	TSC	+12.51	TECTEH			O8795	seco	21H00070	H 0	600UL	331934
4220	31	151	1.03	89	MBM	5	01C	+18.63	TECTEH			C5542	reso	21H00070	H 0	600UL	331934
4221	35	151	4.28	176	DNG	P 1	DC	+1.79	TECTEH			C5542	reso	21H00070	H 0	600UL	331934
4222	37	151	0.59	96	MBM	5	02C	+24.22	TECTEH			A9608	reso	21H00069	H 0	600UL	332251
4223	43	151	2.59	2	INR	P 1	04C	+5.70	TECTEH			O8795	seco	21H00070	H 0	600UL	331934
4224	51	151	0.64	82	MBM	5	04H	+9.66	TECTEH			C5542	reso	21H00070	H 0	600UL	331934
4225	61	151	0.83	79	MBM	5	TSH	+36.88	TECTEH			A9608	reso	21H00069	H 0	600UL	332251
4226	75	151	4.26	173	DNG	P 1	05H	+9.70	TECTEH			O8795	seco	21H00070	H 0	600UL	331934
4227	79	151	1.28	180	INR	P 1	08H	+10.09	TECTEH			O8795	seco	21H00070	H 0	600UL	331934
4228			2.21	181	DNG	P 1	08H	+10.95	TECTEH			O8795	seco	21H00070	H 0	600UL	331934
4229	81	151			TBP				TSHTSH	SSI		D3858	reso	21H00115	H 1	600PP	326403
4230	83	151			TBP				TSHTSH	SSI		D3858	reso	21H00115	H 1	600PP	326403
4231	24	152	3.61	184	DNT	P 1	VM	+1.78	TECTEH			M2655	seco	21H00069	H 0	600UL	332251
[illegible]			2.79	181	DNG	P 1	06C	+11.89	TECTEH			M2655	seco	21H00069	H 0	600UL	332251
	72	152	2.86	184	DNG	P 1	08C	+5.35	TECTEH			M7006	reso	21H00065	H 0	600UL	332251
[illegible]	78	152			TBP				TSHTSH	SSI		D3858	reso	21H00115	H 1	600PP	326403
4235			0.79	100	MBM	5	04C	+16.92	TECTEH			M7006	reso	21H00066	H 0	600UL	340950
4236	80	152			TBP				TSHTSH	SSI		D3858	reso	21H00115	H 1	600PP	326403
4237	5	153	14.97	184	DNT	P 1	VM	+0.68	05HTEC			N2574	seco	21C00069	C 0	580SF	339357

4238					OBS		06C	+10.29	06CTEC				B6768	prim	21C00064	C 0	600CS	341612
4239	9	153	0.61	73	MBM	5	01H	+5.18	TECTEH				M7006	reso	21H00065	H 0	600UL	332251
4240	17	153			PBC				TECTEH	IDOK			D3858	reso	21H00094	H 0	600UL	340988
4241					PRC				TSHTSH				D3858	reso	21H00179	H 1	600PP	345336
[illegible]			0.33	59	NQI	P 1	TSH	+3.10	TECTSH				W2096	prim	21H00065	H 0	600UL	332251
[illegible]					NDF		TSH	+3.10	TSHTSH	ENCODE			S4373	reso	21H00130	H 1	600PP	345335
4244			7.54	180	DNT	P 1	DH	+2.04	TECTEH				C3340	reso	21H00094	H 0	600UL	340988
4245	35	153	0.50	73	MBM	5	01H	+13.23	TECTEH				M7006	reso	21H00065	H 0	600UL	332251
4246			1.87	189	INR	P 1	05C	+0.32	TECTEH				M2655	seco	21H00065	H 0	600UL	332251
4247	39	153	6.43	179	DNT	P 1	VM	-1.61	TECTEH				M2655	seco	21H00065	H 0	600UL	332251
4248			1.78	183	INR	P 1	01C	-0.55	TECTEH				M2655	seco	21H00065	H 0	600UL	332251
4249	57	153	2.02	189	DNG	P 1	05C	+24.48	TECTEH				H2949	seco	21H00066	H 0	600UL	340950
4250	75	153			TBP				TSHTSH	SSI			D3858	reso	21H00115	H 1	600PP	326403
4251	77	153			TBP				TSHTSH	SSI			D3858	reso	21H00115	H 1	600PP	326403
4252	16	154	1.19	70	MBM	6	TSC	+4.77	TECTEH				M7006	reso	21H00066	H 0	600UL	340950
4253	18	154	4.29	181	DNG	P 1	06C	+10.10	TECTEH				M2655	seco	21H00065	H 0	600UL	332251
4254	22	154	2.99	179	DNG	P 1	TSH	+15.33	TECTEH				M2655	seco	21H00065	H 0	600UL	332251
4255			2.77	182	DNG	P 1	06C	+12.44	TECTEH				M2655	seco	21H00065	H 0	600UL	332251
4256	24	154	3.05	180	DNT	P 1	VM	+1.63	TECTEH				H2949	seco	21H00066	H 0	600UL	340950
4257			2.60	181	DNG	P 1	06C	+11.98	TECTEH				H2949	seco	21H00066	H 0	600UL	340950
4258	36	154	3.39	187	DNG	P 1	01C	+32.07	TECTEH				H2949	seco	21H00066	H 0	600UL	340950
4259	56	154	2.62	178	DNG	P 1	07H	+9.91	TECTEH				H2949	seco	21H00066	H 0	600UL	340950
4260	74	154			TBP				TSHTSH	SSI			D3858	reso	21H00115	H 1	600PP	326403
4261	17	155	6.77	179	DNT	P 1	DH	+1.98	TECTEH				M2655	seco	21H00065	H 0	600UL	332251
4262	25	155	1.66	82	MBM	5	02H	+33.60	TECTEH				M7006	reso	21H00065	H 0	600UL	332251
4263			0.92	76	MBM	5	03H	+10.82	TECTEH				M7006	reso	21H00065	H 0	600UL	332251

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 88

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4264			0.95	86	MBM	5	03H	+11.59	TECTEH			M7006	reso	21H00065	H 0	600UL	332251
4265			1.07	86	MBM	5	03H	+22.63	TECTEH			M7006	reso	21H00065	H 0	600UL	332251
4266	39	155	2.04	182	DNT	P 1	VM	-1.81	TECTEH			H2949	seco	21H00066	H 0	600UL	340950
4267			0.65	79	MBM	5	TSC	+10.81	TECTEH			M7006	reso	21H00066	H 0	600UL	340950
4268	53	155	3.29	180	DNT	P 1	03C	-0.55	TECTEH			M2655	seco	21H00065	H 0	600UL	332251
4269					INF		02C	+38.31	TECTEH	HR		M7006	reso	21H00065	H 0	600UL	332251
4270	71	155	4.98	181	DNG	P 1	TSC	+9.57	TECTEH			M2655	seco	21H00065	H 0	600UL	332251
4271	73	155			TBP				TSHTSH	SSI		D3858	reso	21H00115	H 1	600PP	326403
4272			2.13	181	DNG	P 1	TSH	+30.11	TECTEH			M2655	seco	21H00065	H 0	600UL	332251
4273			2.67	181	DNT	P 1	07H	+0.99	TECTEH			M2655	seco	21H00065	H 0	600UL	332251
4274	10	156	2.83	183	DNG	P 1	05H	+16.86	TECTEH			H2949	seco	21H00066	H 0	600UL	340950
4275	24	156	3.53	180	DNT	P 1	VM	+1.68	TECTEH			M2655	seco	21H00065	H 0	600UL	332251
4276			3.01	182	DNG	P 1	06C	+11.95	TECTEH			M2655	seco	21H00065	H 0	600UL	332251
4277			0.85	93	MBM	6	04C	+28.22	TECTEH			M7006	reso	21H00065	H 0	600UL	332251
[illegible]			1.16	59	MBM	6	04C	+30.37	TECTEH			M7006	reso	21H00065	H 0	600UL	332251
[illegible]	32	156	0.73	88	MBM	5	05H	+33.21	TECTEH			M7006	reso	21H00065	H 0	600UL	332251
[illegible]			0.90	79	MBM	5	01C	+33.19	TECTEH			M7006	reso	21H00065	H 0	600UL	332251
4281	36	156	5.13	185	DNG	P 1	DH	+12.75	TECTEH			M2655	seco	21H00065	H 0	600UL	332251
4282			2.75	185	DNG	P 1	06C	+15.20	TECTEH			M2655	seco	21H00065	H 0	600UL	332251
4283	54	156	7.24	182	DNG	P 1	TSH	+31.62	TECTEH			H2949	seco	21H00066	H 0	600UL	340950

4284	1	157	2.44	182	DNT	P 1	06C	-0.24	06CTEC				C5542	reso	21C00065	C 1	600CS	341613
4285	7	157	3.62	176	DNG	P 1	06C	+7.19	TECTEH				H2949	seco	21H00066	H 0	600UL	340950
4286			2.72	178	DNG	P 1	06C	+8.15	TECTEH				H2949	seco	21H00066	H 0	600UL	340950
4287	9	157	0.64	78	MBM	5	02C	+19.48	TECTEH				M7006	reso	21H00065	H 0	600UL	332251
	13	157	3.10	179	DNT	P 1	VM	-0.19	TECTEH				M2655	seco	21H00065	H 0	600UL	332251
	17	157	5.72	181	DNT	P 1	DH	+2.00	TECTEH				M2655	seco	21H00065	H 0	600UL	332251
4290	19	157	1.58	77	MBM	6	04C	+28.65	TECTEH				M7006	reso	21H00066	H 0	600UL	340950
4291	21	157	2.90	86	MBM	6	04C	+30.01	TECTEH				M7006	reso	21H00065	H 0	600UL	332251
4292	27	157	0.44	75	MBM	5	05H	+5.49	TECTEH				M7006	reso	21H00066	H 0	600UL	340950
4293	29	157	0.52	30	INR	P 1	02H	+0.31	TECTEH				N5877	seco	21H00094	H 0	600UL	340988
4294			0.44	29	INR	P 1	02H	+0.31	TEC01H				W2096	prim	21H00065	H 0	600UL	332251
4295	43	157	2.08	183	DNG	P 1	02H	+20.08	TECTEH				H2949	seco	21H00066	H 0	600UL	340950
4296	49	157	7.35	184	DNG	P 1	VM	+2.87	TECTEH				M2655	seco	21H00065	H 0	600UL	332251
4297					INF		VM	+4.14	TECTEH	HR			M7006	reso	21H00065	H 0	600UL	332251
4298	55	157	6.14	182	DNG	P 1	TSC	+17.97	TECTEH				H2949	seco	21H00066	H 0	600UL	340950
4299			3.09	62	MBM	6	TSC	+18.17	TECTEH				M7006	reso	21H00066	H 0	600UL	340950
4300	59	157	3.10	182	DNG	P 1	06H	+8.34	TECTEH				H2949	seco	21H00066	H 0	600UL	340950
4301	12	158	2.80	189	DNT	P 1	VM	+0.21	TECTEH				H2949	seco	21H00066	H 0	600UL	340950
4302			0.58	87	MBM	6	04C	+16.61	TECTEH				M7006	reso	21H00066	H 0	600UL	340950
4303	14	158	2.38	178	DNT	P 1	VM	+1.71	TECTEH				M2655	seco	21H00065	H 0	600UL	332251
4304	22	158	0.12	87	PLP	9	TSC	+0.72	TSCTSC				F4645	seco	21C00004	C 2	600PP	340699
4305	24	158	4.22	181	DNT	P 1	VM	+1.55	TECTEH				H2949	seco	21H00066	H 0	600UL	340950
4306			3.53	181	DNG	P 1	06C	+12.06	TECTEH				H2949	seco	21H00066	H 0	600UL	340950
4307			0.25	81	PLP	9	TSC	+0.98	TSCTSC				J5670	prim	21C00003	C 2	600PP	345348
4308	26	158	4.76	179	DNG	P 1	VM	+19.77	TECTEH				M2655	seco	21H00065	H 0	600UL	332251
4309	36	158	2.50	181	DNT	P 1	VM	+1.71	TECTEH				H2949	seco	21H00066	H 0	600UL	340950
4310	58	158	0.88	66	MBM	5	01H	+26.22	TECTEH				C3340	reso	21H00094	H 0	600UL	340988
4311	60	158	3.77	188	DNG	P 1	DH	+23.79	TECTEH				T2170	seco	21H00060	H 0	600UL	340950
4312	5	159	10.86	180	DNT	P 1	VM	+0.00	06HTEC				D4576	seco	21C00064	C 0	600CS	341612

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 89

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4313	21	159	0.31	82	PLP	9	TSC	+0.33	TSCTSC			N2574	seco	21C00002	C 2	600PP	340699
4314	23	159	0.28	84	PLP	9	TSC	+0.59	TSCTSC			M2655	seco	21C00013	C 2	600PP	345292
4315	29	159	6.97	179	DNT	P 1	VM	+1.79	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4316			6.24	181	DNG	P 1	VM	+2.79	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4317	31	159	2.28	183	DNG	P 1	DH	+11.22	TECTEH			T2170	seco	21H00060	H 0	600UL	340950
4318	41	159	2.70	185	DNG	P 1	04C	+22.51	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4319			2.31	182	DNG	P 1	01C	+34.83	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4320	49	159	2.33	179	DNT	P 1	06H	+0.53	DH TEH			C3340	reso	21H00094	H 0	600UL	340988
4321			11.58	184	DNT	P 1	07H	-0.92	DH TEH			C3340	reso	21H00094	H 0	600UL	340988
4322			12.67	184	DNT	P 1	07H	-0.83	TEHTEC			D4576	seco	21C00063	H 0	580UL	287747
4323					OBS		DH	+3.34	DH TEH			W2096	prim	21H00094	H 0	600UL	340988
[illegible]					OBS		VM	-13.17	VM TEC			S4373	reso	21C00064	H 0	600CS	341612
			16.48	181	DNT	P 1	VM	+2.00	VM TEC			S4373	reso	21C00064	H 0	600CS	341612
[illegible]			17.89	178	DNT	P 1	VM	+2.23	TEHTEC			D4576	seco	21C00063	H 0	580UL	287747
4327			11.39	180	DNG	P 1	06C	+8.39	VM TEC			S4373	reso	21C00064	H 0	600CS	341612
4328			9.74	178	DNG	P 1	06C	+8.44	TEHTEC			D4576	seco	21C00063	H 0	580UL	287747
4329			7.49	179	DNG	P 1	06C	+9.95	TEHTEC			D4576	seco	21C00063	H 0	580UL	287747

4330			8.53	181	DNG	P 1	06C	+10.00	VM TEC			S4373	reso	21C00064	H 0	600CS	341612
4331	51	159	2.35	185	DNG	P 1	07C	+11.90	TECTEH			T2170	seco	21H00060	H 0	600UL	340950
4332	57	159			INF		TSH	+0.70	TSHTSH	HR		A9608	reso	21H00132	H 1	600PP	345335
4333	59	159	3.44	180	DNG	P 1	06H	+9.53	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
			2.08	174	DNT	P 1	VM	-1.95	TECTEH			F6623	reso	21H00059	H 0	600UL	340947
	24	160	0.71	84	MBM	5	04H	+28.86	TECTEH			F6623	reso	21H00059	H 0	600UL	340947
4336			5.30	178	DNT	P 1	VM	+1.82	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4337			4.48	182	DNG	P 1	06C	+12.42	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4338			1.18	92	MBM	5	02C	+33.85	TECTEH			F6623	reso	21H00059	H 0	600UL	340947
4339	26	160	7.25	180	DNG	P 1	06C	+17.32	TECTEH			T2170	seco	21H00060	H 0	600UL	340950
4340			0.87	82	MBM	5	05C	+26.44	TECTEH			F6623	reso	21H00060	H 0	600UL	340950
4341			0.22	69	PLP	9	TSC	+0.29	TSCTSC			N2574	seco	21C00002	C 2	600PP	340699
4342	28	160	2.21	180	DNG	P 1	DH	+9.42	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4343	36	160	0.70	59	MBM	5	02H	+7.60	TECTEH			F6623	reso	21H00059	H 0	600UL	340947
4344			1.99	174	INR	P 1	VM	+2.21	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4345	38	160	0.13	87	PLP	9	TSH	+0.53	TSHTSH			L2157	reso	21H00133	H 1	600PP	345334
4346	44	160	0.47	73	MBM	5	TSC	+27.63	TECTEH			F6623	reso	21H00059	H 0	600UL	340947
4347	54	160	3.60	180	DNG	P 1	05C	+36.22	TECTEH			T2170	seco	21H00060	H 0	600UL	340950
4348	56	160	2.51	182	DNT	P 1	VM	+2.02	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4349	17	161	7.07	178	DNT	P 1	VM	+1.22	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4350	35	161	3.71	178	DNG	P 1	04C	+36.48	TECTEH			T2170	seco	21H00060	H 0	600UL	340950
4351	39	161	3.06	182	DNG	P 1	03H	+4.11	TECTEH			T2170	seco	21H00060	H 0	600UL	340950
4352			3.29	188	DNG	P 1	03H	+13.56	TECTEH			T2170	seco	21H00060	H 0	600UL	340950
4353	43	161	0.67	77	MBM	5	06H	+16.07	TECTEH			F6623	reso	21H00060	H 0	600UL	340950
4354	49	161	6.17	180	DNG	P 1	05H	+31.86	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4355			3.72	182	DNG	P 1	05H	+32.92	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4356			2.04	186	DNG	P 1	05H	+34.49	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4357			7.64	183	DNG	P 1	05H	+36.95	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4358			7.16	185	DNG	P 1	06H	+1.98	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
			17.81	182	DNG	P 1	06H	+11.77	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
			21.43	180	DNG	P 1	06H	+13.47	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4361			6.13	178	DNG	P 1	DH	+3.87	TECTEH			F6623	reso	21H00059	H 0	600UL	340947

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 90

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N
4362	12	162	0.73	78	NQI	5	TSH	+14.02	TECTEH			F6623	reso	21H00059	H 0	600UL	340947
4363					NDF		TSH	+14.02	TSH01H			K5380	prim	21H00181	H 3	600PP	345336
4364	16	162	0.25	75	PLP	9	TSC	+0.28	TSCTSC			M2655	seco	21C00013	C 2	600PP	345292
4365	20	162	10.74	181	DNG	P 1	06H	+12.20	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4366	24	162	1.15	91	MBM	5	05H	+1.90	TECTEH			F6623	reso	21H00059	H 0	600UL	340947
4367			6.50	178	DNT	P 1	VM	+1.77	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4368			5.66	178	DNG	P 1	06C	+12.35	TECTEH			T7451	seco	21H00059	H 0	600UL	340947
4369	26	162	7.39	180	DNG	P 1	06C	+17.32	TECTEH			T2170	seco	21H00060	H 0	600UL	340950
[illegible]	38	162	0.27	81	PLP	9	TSH	+0.47	TSHTSH			L2157	reso	21H00133	H 1	600PP	345334
	15	163	0.32	76	PLP	9	TSC	+0.29	TSCTSC			D3858	reso	21C00001	C 2	600PP	345348
	17	163	6.26	178	DNT	P 1	DC	+2.19	TECTEH			F6623	reso	21H00059	H 0	600UL	340947
4373	27	163	0.16	128	VOL	2	02H	+8.31	02H03H			F3453	reso	21H00179	H 3	600PP	345336
4374			0.94	66	NQI	5	02H	+8.53	TECTEH			F6623	reso	21H00060	H 0	600UL	340950
4375	29	163	0.31	10	INR	P 1	TSH	+0.73	TECTEH			K6388	prim	21H00059	H 0	600UL	340947

4376			2.22	180	DNG	P	1	05C	+10.93	TECTEH			T7451	seco	21H00059	H	0	600UL	340947
4377	39	163	0.64	88	MBM		5	02H	+7.42	TECTEH			F6623	reso	21H00060	H	0	600UL	340950
4378	4	164	2.30	181	DNG	P	1	03H	+7.19	06HTEH			A9574	seco	21H00095	H	9	600UL	340988
4379	10	164	6.01	176	DNG	P	1	DH	+1.87	TECTEH			T7451	seco	21H00059	H	0	600UL	340947
	12	164	0.21	109	VOL		2	05H	+7.82	05H06C			L2157	reso	21H00209	H	2	5602C	326260
	14	164	2.32	181	DNG	P	1	06C	+8.65	TECTEH			T7451	seco	21H00059	H	0	600UL	340947
4382	38	164	2.04	188	DNG	P	1	01H	+29.46	TECTEH			T7451	seco	21H00059	H	0	600UL	340947
4383			2.20	181	DNG	P	1	02H	+20.16	TECTEH			T7451	seco	21H00059	H	0	600UL	340947
4384			2.67	179	DNG	P	1	02H	+31.05	TECTEH			T7451	seco	21H00059	H	0	600UL	340947
4385			2.72	186	DNG	P	1	02H	+32.11	TECTEH			T7451	seco	21H00059	H	0	600UL	340947
4386			3.21	181	DNT	P	1	VM	+1.37	TECTEH			T7451	seco	21H00059	H	0	600UL	340947
4387			0.51	113	20	P	2	VM	+1.80	TECTEH			F6623	reso	21H00059	H	0	600UL	340947
4388	15	165	2.06	181	DNG	P	1	01C	+4.71	TECTEH			T7451	seco	21H00059	H	0	600UL	340947
4389	21	165	2.07	189	DNG	P	1	02C	+6.50	TECTEH			T2170	seco	21H00060	H	0	600UL	340950
4390	29	165	0.68	56	MBM		5	03H	+19.64	TECTEH			F6623	reso	21H00059	H	0	600UL	340947
4391	10	166	0.38	88	NQI		5	02H	+29.33	TECTEH			F6623	reso	21H00060	H	0	600UL	340950
4392					NDF			02H	+29.33	02H03H			R3710	prim	21H00179	H	3	600PP	345336
4393	12	166	12.21	181	DNG	P	1	06H	+7.76	TECTEH			T7451	seco	21H00059	H	0	600UL	340947
4394	5	167	16.72	181	DNT	P	1	VM	+0.00	06HTEC			D4576	seco	21C00064	C	0	600CS	341612
4395	11	167	0.27	80	MBM		5	02H	+6.60	TECTEH			F6623	reso	21H00060	H	0	600UL	340950
4396	13	167	2.65	186	DNG	P	1	DH	+2.48	TECTEH			T7451	seco	21H00059	H	0	600UL	340947
4397			2.65	187	DNT	P	1	VM	-1.75	TECTEH			F6623	reso	21H00059	H	0	600UL	340947
4398	15	167	5.35	177	DNG	P	1	TSH	+33.14	TECTEH			T7451	seco	21H00059	H	0	600UL	340947
4399			0.48	161	INR	P	1	DH	-0.17	TECTEH			F6623	reso	21H00059	H	0	600UL	340947

SG 21 - All Calls (Excluding NDD and retest codes)

SG2

UTILITY: CONSTELLATION ENERGY GROUP, MAY. 17,2001 13:47
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0301_Final PAGE 91

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE	PROBE S/N

QUERY REPORT SUMMARY:

QUERY PARAMETER	ENTRIES	TUBES
0 to 100 Percent	26	23
ADR Indication Code	1	1
BLG Indication Code	0	0
CUD Indication Code	0	0
DEP Indication Code	0	0
DIS Indication Code	14	14

DNG	Indication Code	1259	869
DNI	Indication Code	1	1
DNT	Indication Code	484	411
DRI	Indication Code	0	0
DSI	Indication Code	36	35
DTI	Indication Code	0	0
ETL	Indication Code	0	0
EXP	Indication Code	0	0
GEO	Indication Code	1	1
IDC	Indication Code	0	0
IDM	Indication Code	30	26
INF	Indication Code	52	48
INR	Indication Code	240	217
LDE	Indication Code	0	0
LPI	Indication Code	1	1
MAI	Indication Code	150	68
MBM	Indication Code	841	625
MCI	Indication Code	2	1
MMI	Indication Code	0	0
MSI	Indication Code	0	0
MVI	Indication Code	0	0
NDF	Indication Code	112	107
NQI	Indication Code	55	52
NRC	Indication Code	1	1
NRH	Indication Code	2	2
NSY	Indication Code	0	0
OBS	Indication Code	42	18
PBC	Indication Code	2	2
PID	Indication Code	266	247
PLP	Indication Code	58	57
PPS	Indication Code	1	1
PRC	Indication Code	7	7
PSP	Indication Code	0	0
PTS	Indication Code	0	0
PVN	Indication Code	2	2
SAI	Indication Code	404	179
SCI	Indication Code	14	7
SVI	Indication Code	9	5
TBP	Indication Code	51	51
TBS	Indication Code	210	210
UDE	Indication Code	0	0
VOL	Indication Code	20	16
WAR	Indication Code	5	4

TOTAL ENTRIES: 4399

TOTAL TUBES: 2132