

January 5, 1990

Mr. Percy M. Beard, Jr.  
Senior Vice President,  
Nuclear Operations  
Florida Power Corporation  
ATTN: Manager, Nuclear Operations  
Licensing  
P. O. Box 219-NA-2I  
Crystal River, Florida 32629

Dear Mr. Beard:

SUBJECT: CRYSTAL RIVER UNIT 3 - ENVIRONMENTAL ASSESSMENT OF EXEMPTION  
REQUEST FROM 10 CFR PART 50, APPENDIX A, GENERAL DESIGN CRITERION-2  
(TAC NO. 74373)

Enclosed is a copy of an "Environmental Assessment and Finding of No Significant Impact" for your information. This assessment relates to your letter dated December 12, 1989, as supplemented on December 22, 1989, which requested an exemption from the requirements of 10 CFR Part 50, Appendix A, General Design Criterion-2 with regard to tornado missile protection of the emergency diesel generators.

This notice is being forwarded to the Office of the Federal Register for publication.

Sincerely,

Original signed by

Harley Silver, Project Manager  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc w/enclosure:  
See next page

DISTRIBUTION w/enclosure

Docket File	HSilver	SVarga 14/E/4	BGrimes 9/A/2
NRC & LPDRs	ACRS (10)	DMiller	MSinkule RII
PD22 Rdg File	GPA/PA	OGC(info)	HBerkow
EJordan MNBB-3302	GLainas 14/H/3		

OFOI  
1/1

9001160032 900105  
PDR ADDCK 05000302  
PDC

OFC	: LA: PDII-2	: PM: PDII-2	: D: PDII-2	: OGC	:	:
NAME	: DMiller	: HSilver	: HBerkow	: <i>Tehle w/ connection</i>	:	:
DATE	: 1/4/90	: 1/4/90	: 1/8/90	: 1/5/90	:	:

*more as marked*

CP-3

Mr. P. M. Beard  
Florida Power Corporation

Crystal River Unit No. 3 Nuclear  
Generating Plant

cc:

Mr. A. H. Stephens  
General Counsel  
Florida Power Corporation  
MAC - A5D  
P. O. Box 14042  
St. Petersburg, Florida 33733

State Planning and Development  
Clearinghouse  
Office of Planning and Budget  
Executive Office of the Governor  
The Capitol Building  
Tallahassee, Florida 32301

Mr. P. F. McKee, Director  
Nuclear Plant Operations  
Florida Power Corporation  
P. O. Box 219-NA-2C  
Crystal River, Florida 32629

Chairman  
Board of County Commissioners  
Citrus County  
110 North Apopka Avenue  
Inverness, Florida 32650

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
1700 Rockville Pike, Suite 525  
Rockville, Maryland 20852

Mr. Rolf C. Widell, Director  
Nuclear Operations Site Support  
Florida Power Corporation  
P.O. Box 219-NA-2I  
Crystal River, Florida 32629

Senior Resident Inspector  
Crystal River Unit 3  
U.S. Nuclear Regulatory Commission  
15760 West Powerline Street  
Crystal River, Florida 32629

Mr. Gary L. Boldt  
Vice President, Nuclear Production  
Florida Power Corporation  
P. O. Box 219-SA-2C  
Crystal River, Florida 32629

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street N.W., Suite 2900  
Atlanta, Georgia 30323

Mr. Jacob Daniel Nash  
Office of Radiation Control  
Department of Health and  
Rehabilitative Services  
1317 Winewood Blvd.  
Tallahassee, Florida 32399-0700

Administrator  
Department of Environmental Regulation  
Power Plant Siting Section  
State of Florida  
2600 Blair Stone Road  
Tallahassee, Florida 32301

Attorney General  
Department of Legal Affairs  
The Capitol  
Tallahassee, Florida 32304

UNITED STATES NUCLEAR REGULATORY COMMISSIONFLORIDA POWER CORPORATIONDOCKET NO. 50-302ENVIRONMENTAL ASSESSMENT AND  
FINDING OF NO SIGNIFICANT IMPACT

The U. S. Nuclear Regulatory Commission is considering issuance of an exemption from the requirements of Appendix A to 10 CFR Part 50 to Florida Power Corporation, (the licensee), for the Crystal River Unit 3 Nuclear Generating Plant located in Crystal River, Florida.

ENVIRONMENTAL ASSESSMENTIdentification of Proposed Action:

The proposed exemption would allow temporary relief from the requirements of General Design Criterion-2 (GDC-2) for the Crystal River Unit 3 Nuclear Generating Plant with regard to a portion of the tornado missile protection for the emergency diesel generators.

The Need for the Proposed Action:

The proposed exemption is needed in order to permit completion of highly desirable upgrades to the emergency diesel generators without unduly extending the next scheduled refueling outage (Refuel 7). The proposed exemption would permit part of the preparatory work to be accomplished prior to plant shutdown for the outage.

Environmental Impacts of the Proposed Action:

The proposed exemption does not involve any measurable environmental impacts during normal operation since the plant configuration is changed only minimally and plant operation is not changed. The likelihood of tornado missile damage during the time the exemption would be in effect which would

9001160033 900105  
PDR ADOCK 05000302  
P PDC

affect equipment required to operate to avoid radiological impact is low. Thus, the proposed exemption would not significantly affect the probability or consequences of potential reactor accidents and would not otherwise affect radiological plant effluents. Consequently, the Commission concludes that there are no significant radiological impacts associated with the proposed exemption.

With regard to potential non-radiological impacts, the proposed exemption involves features located entirely within the restricted area as defined in 10 CFR Part 20. It does not affect non-radiological plant effluents and has no other environmental impact. Therefore, the staff concludes that there are no significant non-radiological environmental impacts associated with the proposed exemption.

Alternatives to the Proposed Action:

Since the staff has concluded that there are no measurable environmental impacts associated with the proposed exemption, any alternatives with equal or greater environmental impact need not be evaluated. The principal alternative to the exemption would be to require strict compliance with GDC-2. Such action would not significantly enhance the protection of the environment, and would result in a significant loss of power to the licensee, as the next refueling outage would have to be extended considerably.

Alternative Use of Resources:

This action does not involve the use of any resources not previously considered in the Final Environmental Statement for the Crystal River Unit 3 Nuclear Generating Plant.

Agencies and Persons Consulted:

The NRC staff reviewed the licensee's request and did not consult other agencies or persons.

FINDING OF NO SIGNIFICANT IMPACT

Based upon the foregoing environmental assessment, the staff concludes that the proposed action would not have a significant effect on the quality of the human environment and has determined, therefore, not to prepare an environmental impact statement for the proposed exemption.

For further details with respect to this action, see the application dated December 12, 1989, as supplemented on December 22, 1989, which is available for public inspection at the Commission's Public Document Room, 2120 L Street, N.W., Washington, D.C. and at the Crystal River Public Library, 668 N.W. First Avenue, Crystal River, Florida 32629.

Dated at Rockville, Maryland, this 5th day of January 1990.

FOR THE NUCLEAR REGULATORY COMMISSION

*Bart C. Buckley*  
Bart C. Buckley, Acting Director  
Project Directorate II-2  
Division of Reactor Projects I/II  
Office of Nuclear Reactor Regulation