

DISTRIBUTION: TERA
 Docket File NSIC
 NRC PDR ORB#4 Rdg
 L PDR NRR Rdg
 Docket No. 50-302 HDenton
 ECase
 RHartfield
 Bennington
 DEisenhut
 Mr. J. A. Hancock
 Director, Nuclear Operations
 Florida Power Corporation
 P. O. Box 14042
 Mail Stop C-4
 St. Petersburg, Florida 33733

RPurple
 JRoe
 RTedesco
 TNovak
 GLainas
 RIngram
 PERickson
 RReid
 OELD
 IE-3
 ACRS-16
 BJones-4
 JMurray
 CMiles
 SECY EBlackwood
 RDiggs Hornstein
 AEOD Gray File

OCTOBER 24 1980

Dear Mr. Hancock:

SUBJECT: ORDER FOR MODIFICATION OF LICENSE CONCERNING ENVIRONMENTAL QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT

Ref. (a) Commission Memorandum and Order of May 23, 1980 (80-CLI-21)
 Ref. (b) Inspection and Enforcement Bulletin Supplement No. 2 to IEB-79-01B, September 30, 1980.

This letter transmits an Order for Modification of License which changes the Technical Specifications for Facility Operating License No. DPR-72 for the Crystal River Unit No. 3 Nuclear Generating Plant. This change is a result of Ref. (a) which required the staff to codify the documentation requirements for the qualification of safety-related electrical equipment. A copy of the Order is being filed with the Office of the Federal Register for publication.

The deadline of November 1, 1980 for submittal of the qualification information is not changed by this Order. Some additional information regarding the file is contained in Ref. (b). Questions regarding this Order should be directed through your Project Manager.

Sincerely,

Original Signed By

Robert W. Reid, Chief
 Operating Reactors Branch #4
 Division of Licensing

Enclosure:
 Order for Modification
 of License

cc w/enclosure: See next page

CP 3

8011140 630

GD

OFFICE	ORB#4:DL	ORB#4:DL	C-ORB#4:DL	ORB#4:DL	D:DL
SURNAME	RIngram	PERickson	RReid	MWilliams	DEisenhut
DATE	10/24/80	10/24/80	10/24/80	10/24/80	10/24/80



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

October 24, 1980

Docket No. 50-302

Mr. J. A. Hancock
Director, Nuclear Operations
Florida Power Corporation
P. O. Box 14042
Mail Stop C-4
St. Petersburg, Florida 33733

Dear Mr. Hancock:

SUBJECT: ORDER FOR MODIFICATION OF LICENSE CONCERNING ENVIRONMENTAL
QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT

Ref. (a) Commission Memorandum and Order of May 23, 1980 (80-CLI-21)
Ref. (b) Inspection and Enforcement Bulletin Supplement No. 2 to
IEB-79-01B, September 30, 1980.

This letter transmits an Order for Modification of License which changes the Technical Specifications for Facility Operating License No. DPR-72 for the Crystal River Unit No. 3 Nuclear Generating Plant. This change is a result of Ref. (a) which required the staff to codify the documentation requirements for the qualification of safety-related electrical equipment. A copy of the Order is being filed with the Office of the Federal Register for publication.

The deadline of November 1, 1980 for submittal of the qualification information is not changed by this Order. Some additional information regarding the file is contained in Ref. (b). Questions regarding this Order should be directed through your Project Manager.

Sincerely,

Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosure:
Order for Modification
of License

cc w/enclosure: See next page

Crystal River Unit No. 3
Florida Power Corporation

50-302

cc w/enclosure(s):

Mr. S. A. Brandimore
Vice President and General Counsel
P. O. Box 14042
St. Petersburg, Florida 33733

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 420, 7735 Old Georgetown Road
Bethesda, Maryland 20014

Mr. Wilbur Langely, Chairman
Board of County Commissioners
Citrus County
Iverness, Florida 36250

Mr. Tom Stetka, Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 2110
Crystal River, Florida 32629

U. S. Environmental Protection Agency
Region IV Office
ATTN: EIS COORDINATOR
345 Courtland Street, N.E.
Atlanta, Georgia 30308

Bureau of Intergovernmental Relations
660 Apalachee Parkway
Tallahassee, Florida 32304

Director, Criteria and Standards
Division
Office of Radiation Programs (ANR-460)
U. S. Environmental Protection Agency
Washington, D. C. 20460

Crystal River Public Library
Crystal River, Florida 32629

Mr. J. Shreve
The Public Counsel
Room 4 Holland Bldg.
Tallahassee, Florida 32304

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Dr. William R. Stratton
Los Alamos Scientific Lab
Box 503
Los Alamos, New Mexico 87544

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of
FLORIDA POWER CORPORATION, ET AL
(Crystal River Unit No. 3 Nuclear
Generating Plant)

Docket No. 50-302

ORDER FOR MODIFICATION OF LICENSE

I.

Florida Power Corporation (licensee) and eleven other co-owners are the holders of Facility Operating License No. DPR-72, which authorizes the operation of the Crystal River Unit No. 3 Nuclear Generating Plant, at steady state reactor power levels not in excess of 2452 megawatts thermal (rated power). The facility consists of a pressurized water reactor located at the licensee's site in Citrus County, Florida.

II.

On November 4, 1977, the Union of Concerned Scientists (UCS) filed with the Commission a "Petition for Emergency and Remedial Relief." The petition sought action in two areas: fire protection for electrical cables, and environmental qualification of electrical components. By Memorandum and Order dated April 13, 1978 (7 NRC 400), the Commission denied certain aspects of the petition and, with respect to other aspects, ordered the NRC staff to take several related actions. UCS filed a Petition for Reconsideration on May 2, 1978. By Memorandum and Order, dated May 23, 1980, the Commission reaffirmed its April 13, 1978 decision regarding the possible shutdown of operating reactors. However, the Commission's May 23, 1980 decision directed licensees and the NRC staff to undertake certain actions.

8011140 638

- 2 -

With respect to environmental qualification of safety-related electrical equipment, the Commission determined that the provisions of the two staff documents - the Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines) and NUREG-0588, "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment," December 1979 (copies attached) "form the requirements which licensees and applicants must meet in order to satisfy those aspects of 10 CFR Part 50, Appendix A General Design Criterion (GDC-4), which relate to environmental qualifications of safety-related electrical equipment." The Commission directed, for replacement parts in operating plants, "unless there are sound reasons to the contrary, the 1974 standard in NUREG-0588 will apply." The Commission also directed the staff to complete its review of the information sought from licensees by Bulletin 79-01B¹ and to complete its review of environmental qualification of safety-related electrical equipment in all operating plants, including the publication of Safety Evaluation Reports, by February 1, 1981. The Commission imposed a deadline that, "by no later than June 30, 1982 all safety-related electrical equipment in all operating plants shall be qualified to the DOR Guidelines or NUREG-0588."

¹ Bulletin 79-01B was not sent to licensees for plants under review as part of the staff's Systematic Evaluation Program. The information sought by Bulletin 79-01B was requested from these licensees by a series of letters and meetings during the months of February and March, 1980.

The Commission requested the staff to, "keep the Commission and the public apprised of any further findings of incomplete environmental qualification of safety-related electrical equipment, along with corrective actions taken or planned," and requested the staff to provide bi-monthly progress reports to the Commission.

The Commission further directed that, "In order to leave no room for doubt on this issue, the staff is to prepare additional Technical Specifications for all operating plants which codify the documentation requirement paragraph of the Guidelines (paragraph 8.0)." The staff was directed to add these documentation requirements to each license after they were approved by the Commission.

The Commission also pointed out that the various deadlines imposed in its Order, "do not excuse a licensee from the obligation to modify or replace inadequate equipment promptly."

III.

The Commission has approved the Technical Specification provisions set forth in Section IV below which specify documentation requirements and which specifically impose on the licensee the requirement of the Commission's May 23, 1980 Memorandum and Order that by no later than June 30, 1982 all safety-related electrical equipment shall be qualified to the DOR Guidelines or NUREG-0588.

The information developed during the Commission review of the UCS Petition emphasizes the importance of prompt completion of the upgrading of

- 4 -

environmental qualification of safety-related electrical equipment to conform to the DOR Guidelines or NUREG-0588 and of adequate documentation of equipment qualifications. The deadlines set forth in the Commission's Memorandum and Order dated May 23, 1980, assure that such upgrading will be accomplished promptly. In order to assure prompt completion of necessary qualification work or replacement of unqualified components, if necessary, in conformance with the requirements of the Commission's Memorandum and Order dated May 23, 1980, and to provide complete and adequate documentation as promptly as possible, such upgrading and documentation work must commence immediately. Therefore, I have concluded that the public health, safety and interest require this Order for Modification of License to be effective immediately.

IV.

Accordingly, pursuant to the Atomic Energy Act of 1954, as amended, and the Commission's Rules and Regulations in 10 CFR Parts 2 and 50, IT IS ORDERED THAT EFFECTIVE IMMEDIATELY Facility Operating License No. DPR-72 is hereby amended to add the following provisions to the Appendix A Technical Specifications.

- (a) "By no later than June 30, 1982, all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588, "Interim Staff Position on Environmental

Qualification of Safety-Related Electrical Equipment," December 1979. Copies of these documents are attached to Order for Modification of License DPR-72 dated October 24, 1980.

- (b) "By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified."

To effectuate the foregoing, appropriate pages for incorporation into the Technical Specifications are attached to this Order.

V.


The licensee or any person whose interest may be affected by this Order may request a hearing within 20 days of the date of publication of this Order in the Federal Register. Any request for a hearing will not stay the effective date of this Order. Any request for a hearing shall be addressed to the Director, Office of Nuclear Reactor Regulation, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555. A copy of the request should also be sent to the Executive Legal Director, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, and to S. A. Brandimore, Vice President and General Counsel, P. O. Box 14042, St. Petersburg, Florida 33733, attorney for the licensee.

If a hearing is held concerning this Order, the issues to be considered at the hearing shall be:

- a. whether the licensee should be required to have the environmental qualification records referred to in Section IV, above, available at a central location by no later than December 1, 1980; and
- b. whether all safety-related electrical equipment should be qualified as required in Section IV, above, by no later than June 30, 1982.

Operation of the facility on terms consistent with this Order is not stayed by the pendency of any proceedings on the Order.

FOR THE NUCLEAR REGULATORY COMMISSION


Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Effective Date: October 24, 1980
Bethesda, Maryland

Attachments:

1. Technical Specification Pages
2. Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors
3. NUREG-0588, Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment.

ADMINISTRATIVE CONTROLS

- e. Records of gaseous and liquid radioactive material released to the environs.
- f. Records of transient or operational cycles for those facility components identified in Table 5.7.-1.
- g. Records of training and qualification for current members of the plant staff.
- h. Records of inservice inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities required by the QA Manual.
- j. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10 CFR 50.59.
- k. Records of meetings of the PRC and NGRC.
- l. Records for Environmental Qualification which are covered under the provisions of paragraph 6.13.

6.11 RADIATION PROTECTION PROGRAM

Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

6.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.203(c) (2) of 10 CFR 20:

- a. A High Radiation Area in which the intensity of radiation is greater than 100 mrem/hr but less than 1000 mrem/hr shall be barricaded and conspicuously posted as a High Radiation Area and entrance thereto shall be controlled by issuance of a Radiation Work Permit and any individual or group of individuals permitted to enter such areas shall be provided with a radiation monitoring device which continuously indicates the radiation dose rate in the area.
- b. A High Radiation Area in which the intensity of radiation is greater than 1000 mrem/hr shall be subject to the provisions of 6.12.1a above, and in addition locked doors shall be provided to prevent unauthorized entry into such areas. The keys shall be maintained under the administrative control of the Health Physics Supervisor with one key assigned to the administrative control of Shift Supervisor on duty.

ADMINISTRATIVE CONTROLS

6.13 ENVIRONMENTAL QUALIFICATION

6.13.1 By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of License DPR-72 dated October 24, 1980.

6.13.2 By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.