

## 5.0 ADMINISTRATIVE CONTROLS

### 5.9 Reporting Requirements (Continued)

13. EMF-1961(P)(A), "Statistical Setpoint/Transient Methodology for CE Reactors, Siemens Power Corporation," approved version as specified in the COLR.
14. XN-NF-621(P)(A), "Exxon Nuclear DNB Correlation for PWR Fuel Designs," approved version as specified in the COLR.
15. ANF-89-151(P)(A), "ANF-RELAP Methodology for Pressurized Water Reactors: Analysis of Non-LOCA Chapter 15 Events," approved version as specified in the COLR.
16. EMF-92-153(P)(A) and Supplement 1, "HTP: Departure from Nucleate Boiling Correlation for High Thermal Performance Fuel," approved version as specified in the COLR.
17. XN-NF-82-49(P)(A), Supplement 1, "Exxon Nuclear Company Evaluation Model Revised EXEM PWR Small Break Model," approved version as specified in the COLR.
18. EMF-2087(P)(A), "SEM/PWR-98: ECCS Evaluation Model for PWR LBLOCA Applications," approved version as specified in the COLR.
19. ANF-84-73 Appendix B (P)(A), "Advanced Nuclear Fuels Methodology for Pressurized Water Reactors: Analysis of Chapter 15 Events," Advanced Nuclear Fuels Corporation, approved version as specified in the COLR.
20. EMF-84-093(P)(A), "Steam Line Break Methodology for PWRs," Siemens Power Corporation, approved version as specified in the COLR.
21. EMF-2328(P)(A), "PWR Small Break LOCA Evaluation Model, S-RELAP5 Based," Framatome ANP, Inc., approved version as specified in the COLR.
22. EMF-96-029(P)(A) Volume 1, EMF-96-029(P)(A) Volume 2, EMF-96-029(P)(A) Attachment, "Reactor Analysis System for PWRs, Volume 1, Volume 2, and Attachment," Framatome ANP, Inc., approved version as specified in the COLR.
23. EMF-2310(P)(A), "SRP Chapter 15 Non-LOCA Methodology for Pressurized Water Reactors," Framatome ANP, Inc., approved version as specified in the COLR.

- c. The core operating limits shall be determined so that all applicable limits of the safety analysis are met. The Core Operating Limits Report, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Region IV Administrator and Senior Resident Inspector.

Order 07/24/80

## 5.0 ADMINISTRATIVE CONTROLS

### 5.10 Records Retention

5.10.1 Records shall be retained as described in the Quality Assurance Program.

### 5.11 Radiation Protection Program

Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

5.11.1 In lieu of the "control device" required by paragraph 20.1601(a) of 10 CFR Part 20, and as an alternative method allowed under § 20.1601(c), each high radiation area (as defined in § 20.1601) in which the intensity of radiation is 1000 mrem/hr or less shall be barricaded and conspicuously posted as a high radiation area and entrance thereto shall be controlled by required issuance of a Radiation Work Permit.\* Any individual or group of individuals permitted to enter such areas shall be provided with or accompanied by one or more of the following:

- a. A radiation monitoring device which continuously indicates the radiation dose rate in the area.
- b. A radiation monitoring device which continuously integrates the radiation dose rate in the area and alarms when a preset integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rate level in the area has been established and personnel have been made knowledgeable of them.
- c. An individual qualified in radiation protection procedures who is equipped with a radiation dose rate monitoring device. This individual shall be responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance at the frequency specified by the Manager-Radiation Protection (MRP) in the Radiation Work Permit.

5.11.2 The requirements of 5.11.1, above, shall also apply to each high radiation area in which the intensity of radiation is greater than 1000 mrem/hr\*\* but less than 500 rads/hr\*\*\* (Restricted High Radiation Area). In addition, locked doors shall be provided to prevent unauthorized entry into such areas and the keys shall be maintained under the administrative control of the Shift Manager on duty and/or the MRP with the following exception:

- a. In lieu of the above, for accessible localized Restricted High Radiation Areas located in large areas such as containment, where no lockable enclosure exists in the immediate vicinity to control access to the Restricted High Radiation Area and no such enclosure can be readily constructed, then the Restricted High Radiation Area shall be:

---

\*Radiation Protection personnel shall be exempt from the RWP issuance requirement during the performance of their assigned radiation protection duties, provided they comply with approved radiation protection procedures for entry into high radiation areas.

\*\*At 30 centimeters (12 inches) from the radiation source or from any surface penetrated by the radiation.

\*\*\*At 1 meter from the radiation source or from any surface penetrated by the radiation.