

March 7, 2002

Mr. A Christopher Bakken III, Senior Vice President  
Indiana Michigan Power Company  
Nuclear Generation Group  
500 Circle Drive  
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNIT 2 - 30-DAY REPORT OF LOSS-OF-COOLANT ACCIDENT EVALUATION MODEL CHANGES (TAC NO. MB4038)

Dear Mr. Bakken:

By letter dated February 4, 2002, pursuant to 10 CFR 50.46, the Indiana Michigan Power Company (the licensee) submitted a 30-day report of loss-of-coolant accident (LOCA) model changes affecting the peak cladding temperature (PCT) for Donald C. Cook Nuclear Plant, Unit 2. The letter describes the current assessments against the large-break LOCA analysis of record and a demonstration that the PCT value remains below 2200 degrees Fahrenheit, as required by 10 CFR 50.46. The letter also reported updated assessments of analyses-of-record in addition to previously identified analysis errors and changes.

The Nuclear Regulatory Commission (NRC) staff has reviewed the letter and the licensee's actions. The NRC staff finds that each action described in the letter was performed in accordance with the requirements of 10 CFR 50.46(a)(3)(ii), and therefore is acceptable. The NRC staff also find, the licensee's proposed schedule for reanalysis of the large-break LOCA acceptable.

Sincerely,

*/RA/*

John F. Stang, Senior Project Manager, Section 1  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-316

cc: See next page

March 7, 2002

Mr. A Christopher Bakken III, Senior Vice President  
Indiana Michigan Power Company  
Nuclear Generation Group  
500 Circle Drive  
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNIT 2 - 30-DAY REPORT OF LOSS-OF-COOLANT ACCIDENT EVALUATION MODEL CHANGES (TAC NO. MB4038)

Dear Mr. Bakken:

By letter dated February 4, 2002, pursuant to 10 CFR 50.46, the Indiana Michigan Power Company (the licensee) submitted a 30-day report of loss-of-coolant accident (LOCA) model changes affecting the peak cladding temperature (PCT) for Donald C. Cook Nuclear Plant, Unit 2. The letter describes the current assessments against the large-break LOCA analysis of record and a demonstration that the PCT value remains below 2200 degrees Fahrenheit, as required by 10 CFR 50.46. The letter also reported updated assessments of analyses-of-record in addition to previously identified analysis errors and changes.

The Nuclear Regulatory Commission (NRC) staff has reviewed the letter and the licensee's actions. The NRC staff finds that each action described in the letter was performed in accordance with the requirements of 10 CFR 50.46(a)(3)(ii), and therefore is acceptable. The NRC staff also find, the licensee's proposed schedule for reanalysis of the large-break LOCA acceptable.

Sincerely,  
*/RA/*

John F. Stang, Senior Project Manager, Section 1  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-316

cc: See next page

DISTRIBUTION

PUBLIC

PDIII-1 Reading

WReckley

JStang

THarris

OGC

ACRS

AVegel, RIII

\*See previous concurrence

|        |            |                                 |               |           |
|--------|------------|---------------------------------|---------------|-----------|
| OFFICE | PDIII-1/PM | PDIII-1/LA                      | PDIII-1/SC(A) | SRXB      |
| NAME   | JStang     | THarris <i>/RA/ by RBouling</i> | WReckley      | SE Input* |
| DATE   | 03/07/02   | 03/07/02                        | 03/07/02      | 02/26/02  |

ADAMS Accession No. ML020650015

OFFICIAL RECORD COPY

Donald C. Cook Nuclear Plant, Units 1 and 2

cc:

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, IL 60532-4351

Attorney General  
Department of Attorney General  
525 West Ottawa Street  
Lansing, MI 48913

Township Supervisor  
Lake Township Hall  
P.O. Box 818  
Bridgman, MI 49106

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
7700 Red Arrow Highway  
Stevensville, MI 49127

David W. Jenkins, Esquire  
Indiana Michigan Power Company  
Nuclear Generation Group  
One Cook Place  
Bridgman, MI 49106

Mayor, City of Bridgman  
P.O. Box 366  
Bridgman, MI 49106

Special Assistant to the Governor  
Room 1 - State Capitol  
Lansing, MI 48909

Joseph E. Pollock  
Plant Manager  
Indiana Michigan Power Company  
Nuclear Generation Group  
One Cook Place  
Bridgman, MI 49106

Michigan Department of Environmental  
Quality  
DWRPD/RPS  
Nuclear Facilities Unit  
Constitution Hall  
P. O. Box 30630  
Lansing, MI 48909-8130

Scot A. Greenlee  
Director, Nuclear Technical Services  
Indiana Michigan Power Company  
Nuclear Generation Group  
500 Circle Drive  
Buchanan, MI 49107

David A. Lochbaum  
Union of Concerned Scientists  
1616 P Street NW, Suite 310  
Washington, DC 20036-1495

Site Vice President  
Indiana Michigan Power Company  
Nuclear Generation Group  
One Cook Place  
Bridgman, MI 49106

Michael W. Rencheck, Vice President  
Strategic Business Improvements  
Indiana Michigan Power Company  
Nuclear Generation Group  
500 Circle Drive  
Buchanan, MI 49107