

444 South 16th Street Mall Omaha NE 68102-2247

> February 7, 2002 LIC-02-0015

U. S. Nuclear Regulatory Commission ATTN.: Document Control Desk Washington, DC 20555

Reference: Docket No. 50-285

SUBJECT: Transmittal of Changes to Emergency Plan Implementing Procedures (EPIP) and Emergency Planning Forms (EPF)

In accordance with 10 CFR 50.54(q), 10 CFR 50, Appendix E, Section V, and 10 CFR 50.4(b)(5), please find EPF and EPIP change packages enclosed for the Document Control Desk (holder of Copy 165) and the NRC Region IV Plant Support Branch Secretary (holder of Copies 154 and 155).

The document update instructions and summary of changes are included on the Confirmation of Transmittal form (Form EP-1) attached to each controlled copy change package. Please return the Confirmation of Transmittal forms by March 14th, 22nd, and April 4th, 2002 respectively.

The revised documents included in the enclosed package are:

FC-EPF Index page 1 of 2 issued 01/15/02 FC-EPF-14 R10 issued 01/15/02

EPIP Index page 1 of 2 issued 01/23/02 EPIP-EOF-6 R32 issued 01/23/02

EPIP Index page 1 of 2 issued 02/04/02 EPIP-OSC-2 R40 issued 02/04/02 EPIP-TSC-1 R22 issued 02/04/02



U. S. Nuclear Regulatory Commission LIC-02-0015 Page 2

If you have any questions regarding the enclosed changes, please contact Mr. Carl Simmons at (402) 533-6430.

Sincerely,

MTFrans

M. T. Frans Manager Nuclear Licensing

MTF/ash

Enclosures

 c: Plant Support Branch Secretary (2 sets) Alan Wang, NRC Project Manager (w/o enclosures) W. C. Walker, NRC Senior Resident Inspector (w/o enclosures) Winston & Strawn (w/o enclosures)

OMAHA PUBLIC POWER DISTRICT

Confirmation of Transmittal for Emergency Planning Documents/Information

Radiological Emergency Response Plan (RERP)	n Emergency Planning Procedures Sorres (EPF)
Emergency Planning Department Manual (EPDM)	Other Emergency Planning Document(s)/
Transmitted to:	ja Ja
Name:Document Control DeskCopy No:Plant Support Branch SecretaryCopy No:Plant Support Branch SecretaryCopy No: 1	165 Date: 154 55
The following document(s) / information is forwardedREMOVE SECTIONINSFC-EPF Index page 1 of 2 issued 11/29/01FC-FC-EPF-14 R9 issued 09/04/01FC-	for your manual: E <u>RT SECTION</u> EPF Index page 1 of 2 issued 01/15/02 EPF-14 R10 issued 01/15/02
Summary of Changes: FC-EPF-14 was revised to clarify that an ERO position na	me needs to be included.
	Supervisor - Emergency Planning
I hereby acknowledge receipt of the above documents/info manuals. Signature:	rmation and have included them in my assigned Date:
Please sign above and return by 03/14/02 to:	Karma Boone Fort Calhoun Station, FC-2-1 Omaha Public Power District 444 South 16 th Street Mall Omaha, NE 68102-2247
NOTE: If the document(s)/information contained in this transm or has been transferred to another individuals, please fill out th	ittal is no longer requested or needed by the recipient, e information below.
 Document(s)/Information No Longer Requested/Needed Document(s)/Information Transferred to: 	
Name: Mailing Addre	ss:

Fort Calhour	Page 1 of 2	
[•] C-EPF-1	Alert Notification System Accidental Activation Report Form	R7 11-29-01
FC-EPF-2	Offsite Monitoring Log	R3 03-15-01
FC-EPF-3	Administration of Potassium Iodide Tablets	R1 11-07-00
FC-EPF-4 NCR	Radiological Emergency Team Briefing Checklist	R2 12-13-94
FC-EPF-5	Emergency Worker Extension	R3 03-26-98
FC-EPF-6	Estimated Exposure Worksheet	R4 11-07-00
FC-EPF-7	Estimated Exposure Log	R2 04-01-98
FC-EPF-8	Sample Worksheet	R5 08-10-95a
FC-EPF-9	OSC 24-Hour Staffing Schedule	R12 08-24-00
FC-EPF-10	CR/TSC 24-Hour Staffing Schedule	R14 08-24-00
C-EPF-11	EOF 24-Hour Staffing Schedule	R10 08-24-00
FC-EPF-12	MRC 24 Hour Staffing Schedule	R2 08-05-99
FC-EPF-13	Emergency Response Organization Log Sheet	R0 01-17-91
FC-EPF-14	Emergency Response Organization Assignment Form	R10 01-15-02
FC-EPF-15	Drill Exercise Comment Form	R3 07-11-97a
FC-EPF-17	Pager Response Follow Up Questionnaire	R3 11-06-99
FC-EPF-19	Process and Area Monitor Locations	R6 09-01-94
FC-EPF-20	Site Boundary/Owner Control Area	R1 07-29-97
FC-EPF-21	Fort Calhoun Station Sector Map	R2 05-15-97
FC-EPF-27	Onsite/Offsite Dose Comparison Data Record (Using Eagle Program)	R3 11-07-00
∽C-EPF-29	Estimation of Unmonitored Release Rates	R1 12-30-93
* Computer	Generated	01/15/02 7:48 AM

Distribution Authorized

. جند :

> This procedure does not contain any proprietary information, or such information has been censored. This issue may be released to the public document room. Proprietary information includes personnel names, company telephone numbers, and any information, which could impede emergency response.

FORT CALHOUN STATION EMERGENCY PLAN FORM

EMERGENCY RESPONSE ORGANIZATION ASSIGNMENT FORM

Section 1: Type of Change	
[] New Assignment: (Position)	
[] Delete From: (Position)	
[] Other Changes: (Position)	Reason:
Section 2: Employee Data/Concurrence	
Full Name (include middle initial):	Employee No:
Department Name/Number:	PID No:
Employee Signature:	Print:
Department Head Signature:	Print:
Responsible MGMT. Contact (Per NAI-10):	Print:
Forward to the Supervisor - Er	nergency Planning
Section 3: Initial Assignment	
[] N/A Supervisor-EP Approval:	Date:
ERO Roster Updated By:	Date:
Team Color: [] Red [] White[] Blue	
NOTE: A member of the EP Group will review with the assigned	e the steps and requirements needed to be taken to
qualify for their assigned position. EP Reviewer: Date:	Target Completion Date:
qualify for their assigned position. EP Reviewer: Date: [] N/A Emergency Preparedness Training Completed on:	Target Completion Date: [] 90 day training requirement [] 6 month training requirement
qualify for their assigned position. EP Reviewer: Date: [] N/A Emergency Preparedness Training Completed on: [] N/A TLD Issued on:	Target Completion Date: [] 90 day training requirement [] 6 month training requirement
qualify for their assigned position. EP Reviewer: Date: [] N/A Emergency Preparedness Training Completed on: [] N/A TLD Issued on: [] N/A SCBA Qualification Completed on:	Target Completion Date: [] 90 day training requirement [] 6 month training requirement
qualify for their assigned position. EP Reviewer: Date: [] N/A Emergency Preparedness Training Completed on: [] N/A TLD Issued on: [] N/A SCBA Qualification Completed on: [] N/A FCS Site Access Badge Issued:	Target Completion Date: [] 90 day training requirement [] 6 month training requirement [] YES [] NO Slot Number:
qualify for their assigned position. EP Reviewer: Date: [] N/A Emergency Preparedness Training Completed on: [] N/A TLD Issued on: [] N/A SCBA Qualification Completed on: [] N/A FCS Site Access Badge Issued: Fitness For Duty Program Initiated: Fitness	Target Completion Date: [] 90 day training requirement [] 6 month training requirement [] YES [] NO Slot Number: [] YES [] NO
qualify for their assigned position. EP Reviewer: Date: [] N/A Emergency Preparedness Training Completed on: [] N/A TLD Issued on: [] N/A SCBA Qualification Completed on: [] N/A SCBA Qualification Completed on: [] N/A FCS Site Access Badge Issued: Fitness For Duty Program Initiated: Supervisor's CBOP Training Completed:	Target Completion Date: [] 90 day training requirement [] 6 month training requirement [] YES [] NO [] YES [] NO [] YES [] NO [] YES [] NO
qualify for their assigned position. EP Reviewer: Date: [] N/A Emergency Preparedness Training Completed on: [] N/A TLD Issued on: [] N/A SCBA Qualification Completed on: [] N/A SCBA Qualification Completed on: [] N/A FCS Site Access Badge Issued: Fitness For Duty Program Initiated: Supervisor's CBOP Training Completed: Section 5: Final Approval	Target Completion Date: [] 90 day training requirement [] 6 month training requirement [] YES [] NO Slot Number: [] YES [] NO [] YES [] NO
qualify for their assigned position. EP Reviewer: Date: [] N/A Emergency Preparedness Training Completed on: [] N/A TLD Issued on: [] N/A TLD Issued on: [] N/A SCBA Qualification Completed on: [] N/A SCBA Qualification Completed on: [] N/A FCS Site Access Badge Issued: Fitness For Duty Program Initiated: Supervisor's CBOP Training Completed: Section 5: Final Approval The Above Change(s) Approved by Supervisor-Emergency Planning:	Target Completion Date: []90 day training requirement []6 month training requirement []YES []NO Slot Number: []YES []NO []YES []NO []YES []NO Date:
qualify for their assigned position. EP Reviewer: Date: [] N/A Emergency Preparedness Training Completed on: [] N/A TLD Issued on: [] N/A SCBA Qualification Completed on: [] N/A SCBA Qualification Completed on: [] N/A FCS Site Access Badge Issued: Fitness For Duty Program Initiated: Supervisor's CBOP Training Completed: Section 5: Final Approval The Above Change(s) Approved by Supervisor-Emergency Planning: Section 6: Final Status Update	Target Completion Date: [] 90 day training requirement [] 6 month training requirement [] YES [] NO [] YES [] NO [] YES [] NO [] YES [] NO Date:
qualify for their assigned position. EP Reviewer: Date: [] N/A Emergency Preparedness Training Completed on: [] N/A TLD Issued on: [] N/A TLD Issued on: [] N/A SCBA Qualification Completed on: [] N/A SCBA Qualification Completed on: [] N/A FCS Site Access Badge Issued: Fitness For Duty Program Initiated: Supervisor's CBOP Training Completed: Section 5: Final Approval The Above Change(s) Approved by Supervisor-Emergency Planning: Section 6: Final Status Update [] N/A ERO Roster Updated to Status 1 (Individual has bered by (Circle one):	Target Completion Date: [] 90 day training requirement [] 6 month training requirement [] YES [] NO Slot Number: [] YES [] NO [] YES [] NO Date: en instructed to obtain an ERO ID card) or status 2
qualify for their assigned position. EP Reviewer: Date: [] N/A Emergency Preparedness Training Completed on: [] N/A TLD Issued on: [] N/A TLD Issued on: [] N/A SCBA Qualification Completed on: [] N/A SCBA Qualification Completed on: [] N/A FCS Site Access Badge Issued: Fitness For Duty Program Initiated: Supervisor's CBOP Training Completed: Section 5: Final Approval The Above Change(s) Approved by Supervisor-Emergency Planning: Section 6: Final Status Update [] N/A ERO Roster Updated to Status 1 (Individual has being by (Circle one): Emergency Planning REP: Emergency Planning REP:	Target Completion Date: [] 90 day training requirement [] 6 month training requirement [] YES [] NO Slot Number: [] YES [] NO [] YES [] NO Date: Date:
qualify for their assigned position. EP Reviewer: Date: [] N/A Emergency Preparedness Training Completed on: [] N/A TLD Issued on: [] N/A SCBA Qualification Completed on: [] N/A SCBA Qualification Completed on: [] N/A SCBA Qualification Completed on: [] N/A FCS Site Access Badge Issued: Fitness For Duty Program Initiated: Supervisor's CBOP Training Completed: Section 5: Final Approval The Above Change(s) Approved by Supervisor-Emergency Planning: Section 6: Final Status Update [] N/A ERO Roster Updated to Status 1 (Individual has been by (Circle one): Emergency Planning REP: Emergency Planning REP: [] N/A Employee deleted from ERO Roster (instruct individual has been by (Circle one):	Target Completion Date: [] 90 day training requirement [] 6 month training requirement [] YES [] NO Slot Number: [] YES [] NO [] YES [] NO Date: en instructed to obtain an ERO ID card) or status 2 Date: dual to turn in ERO ID card) by:
qualify for their assigned position. EP Reviewer: Date: [] N/A Emergency Preparedness Training Completed on: [] N/A TLD Issued on: [] N/A SCBA Qualification Completed on: [] N/A SCBA Qualification Completed on: [] N/A SCBA Qualification Completed on: [] N/A FCS Site Access Badge Issued: Fitness For Duty Program Initiated: Supervisor's CBOP Training Completed: Section 5: Final Approval The Above Change(s) Approved by Supervisor-Emergency Planning: Section 6: Final Status Update [] N/A ERO Roster Updated to Status 1 (Individual has beauby (Circle one): Emergency Planning REP: Emergency Planning REP: [] N/A Employee deleted from ERO Roster (instruct individual has beauby (Emergency Planning REP:	Target Completion Date: [] 90 day training requirement [] 6 month training requirement [] YES [] NO Slot Number: [] YES [] NO [] YES [] NO [] YES [] NO Date: Date: dual to turn in ERO ID card) by: Date:

OMAHA PUBLIC POWER DISTRICT

Confirmation of Transmittal for Emergency Planning Documents/Information

Radiological Emergency Response Plan (RERP)	Focedures Emergency Planning Forms (EPF)				
Emergency Planning Department Manual (EPDM)	Other Emergency Planning Document(s)/ Information				
Transmitted to:	'. 7				
Name: Document Control Desk Copy No: 11 Plant Support Branch Secretary Copy No: 11 Plant Support Branch Secretary Copy No: 15	55 Date: 54 5				
The following document(s) / information is forwarded for your manual:REMOVE SECTIONINSERT SECTIONEPIP Index page 1 of 2 issued 01/23/02EPIP Index page 1 of 2 issued 02/04/02EPIP-OSC-2 R39 issued 05/17/01EPIP-OSC-2 R40 issued 02/04/02EPIP-TSC-1 R21 issued 08/24/00EPIP-TSC-1 R22 issued 02/04/02					

Summary of Changes:

EPIP-OSC-2 was revised to add instructions for the Shift Radiation Protection Tech and Chemist to place the TSC HVAC System in the "Filtered Mode".

EPIP-TSC-1 was revised to clarify the instructions on securing and placing the TSC HVAC System in the "Filtered Mode" and in the "Normal Mode".

Supervisor - Emergency Planning

I hereby acknowledge receipt of the above documents/information and have included them in my assigned manuals.
Signature: _____ Date:_____

Please sign above and return by 04/04/02 to:

Karma Boone Fort Calhoun Station, FC-2-1 Omaha Public Power District 444 South 16th Street Mall Omaha, NE 68102-2247

NOTE: If the document(s)/information contained in this transmittal is no longer requested or needed by the recipient, or has been transferred to another individuals, please fill out the information below.

Document(s)/Information No Longer Requested/Needed

Document(s)/Information Transferred to:

Name:

Mailing Address:

Fort Calhoun S	Page 1 of 2					
EMERGENCY PLAN IMPLEMENTING PROCEDURE INDEX						
EPIP-OSC-1	Emergency Classification	R34 09-14-00				
EPIP-OSC-2	Command and Control Position Actions/Notifications	R40 02-04-02				
EPIP-OSC-9	Emergency Team Briefings	R7 12-09-99				
EPIP-OSC-15	Communicator Actions	R22 10-24-00				
EPIP-OSC-21	Activation of the Operations Support Center	R11 11-27-01				
EPIP-TSC-1	Activation of the Technical Support Center	R22 0-04-02				
EPIP-TSC-2	Catastrophic Flooding Preparations	(R0 03-22-95)				
	REINSTATED	R2 02-06-96				
EPIP-TSC-8	Core Damage Assessment	R14 01-19-01				
EPIP-EOF-1	Activation of the Emergency Operations Facility	R12 08-24-00a				
EPIP-EOF-3	Offsite Monitoring	R17 12-07-01				
EPIP-EOF-6	Dose Assessment	R32 01-23-02				
EPIP-EOF-7	Protective Action Guidelines	R13 10-31-00b				
EPIP-EOF-10	Warehouse Personnel Decontamination Station Operation	R10 01-13-00a				
EPIP-EOF-11	Dosimetry Records, Exposure Extensions and Habitability	R18 09-18-97b				
EPIP-EOF-19	Recovery Actions	R7 09-30-98				
EPIP-EOF-21	Potassium Iodide Issuance	R4 11-07-00				
EPIP-EOF-23	Emergency Response Message System	R5 10-12-99				
EPIP-EOF-24	EOF Backup Alert Notification System Activation	R3 09-09-99				
EPIP-RR-11	Technical Support Center Director Actions	R14 02-29-00				
EPIP-RR-13	Reactor Safety Coordinator Actions	R14 12-09-99				
_						

02/04/02 9:39 AM

DO NOT DISTRIBUTE

Fort Calhoun Station Unit No. 1 This procedure contains proprietary information, which may not be released to the public document room. This issue may only be used for internal NRC copies of the Fort Calhoun Station RERP or EPIP manuals. A censored version has been supplied for the public document room.

EPIP-OSC-2

EMERGENCY PLAN IMPLEMENTING PROCEDURE

Title: COMMAND AND CONTROL POSITION ACTIONS/NOTIFICATIONS

FC-68 Number: EC 29389

Reason for Change: Add instruction for the Shift RP and Chemist to place the TSC HVAC System in the FILTERED MODE. Required by a commitment made in LIC-01-0109.

Requestor: M. Reller

Preparer: M. Reller

COMMAND AND CONTROL POSITION ACTIONS/NOTIFICATIONS

NON-SAFETY RELATED

1. PURPOSE

1.1 This procedure provides guidance to the Command and Control position for implementing the Emergency Plan, making required notifications, transferring Command and Control, performing classification upgrades/downgrades and event terminations.

2. REFERENCES/COMMITMENT DOCUMENTS

- 2.1 SO-R-1, "Reportability Determination"
- 2.2 10 CFR 50.72, "Immediate Notification Requirements for Operating Nuclear Power Reactors
- 2.3 EPIP-OSC-1, "Emergency Classification"
- 2.4 EPIP-OSC-15, "Communicator Actions"
- 2.5 EPIP-EOF-6, "Dose Assessment"
- 2.6 EPIP-EOF-7, "Protective Action Guidelines"
- 2.7 EPIP-EOF-11, "Dosimetry Records, Exposure Extensions, and Habitability"
- 2.8 EPIP-EOF-21, "Potassium lodide Issuance"
- 2.9 EPIP-EOF-19, "Recovery Actions"
- 2.10 EPIP-TSC-1, "Activation of the Technical Support Center"
- 2.11 EPIP-EOF-1, "Activation of the Emergency Operations Facility"
- 2.12 OI-ERFCS-1, "Emergency Response Facility Computer System"
- 2.13 FC-1188, "Emergency Notification Form"
- 2.14 FC-EPF-38, "Blair Industrial Park Co-Op, Event Notification Form"
- 2.15 Emergency Telephone Book

- 2.16 Commitments (other than Ongoing)
 - AR 10026, NRC-89-0232
 - AR 07071, LIC-88-0726
- 2.17 Ongoing Commitments
 - AR 30816, LIC-01-0189
- 3. DEFINITIONS
 - 3.1 ANS "Alert Notification System" The system of sirens maintained in OPPD's designated EPZ (Emergency Planning Zone).
 - 3.2 BLAIR INDUSTRIAL PARK CO-OP: EMERGENCY NOTIFICATION SYSTEM An organization of industries including Fort Calhoun Station that have banded together to form a warning system to notify member industries and the Washington County Dispatch Center of a potential or actual release of toxic chemicals and/or hazardous material from its facility.

- 3.3 CODE SYSTEM A system devised by members of the Blair Industrial Park Co-Op to classify events that have occurred at the initiating facilities site. These codes are:
 - CODE BLUE: A minor emergency or problem such as a fire, explosion, gas or liquid release, unusual noise or odor, abnormal or extended flaring activity or other internal event has occurred which may be visible or detectable by off-site people, but which presents NO OFFSITE THREAT and requires no protective actions. The situation is under control.
 - CODE GREEN: An emergency such as a fire, explosion, gas or liquid release or other event has occurred which affects plant operations and/or has the potential to escalate to a more serious emergency. THE SITUATION IS NOT UNDER CONTROL BUT POSES NO IMMEDIATE OFFSITE THREAT. The Washington County EOC may activate.
 - CODE YELLOW: A serious accident such as a fire, explosion, gas or liquid or other event has occurred or is imminent which seriously affects plant operations and/or poses a threat to residents or industries in the immediate vicinity of the affected industry. THE SITUATION IS NOT UNDER CONTROL AND ONSITE PROTECTIVE ACTIONS WILL BE NECESSARY. The Washington County EOC would activate.
 - CODE RED: A severe emergency such as fire, explosion, gas or liquid release or other event has occurred or is imminent which seriously affects plant operations and/or offsite areas well beyond site boundaries. THE SITUATION IS NOT UNDER CONTROL AND PROTECTIVE ACTIONS FOR NEIGHBORING INDUSTRIES AND RESIDENTS ARE NECESSARY. The Washington County EOC would fully activate at a safe location.
- 3.4 COMMAND AND CONTROL POSITION The Shift Manager, Control Room Coordinator, Site Director or Emergency Director currently charged with the authorities and responsibilities for directing the emergency response.
- 3.5 EALs "Emergency Action Levels"
- 3.6 EAS "Emergency Alert System". A mass-media system providing information and instructions to the general public in the event of a nuclear or other public emergency.
- 3.7 EOF "Emergency Operations Facility".
- 3.8 ERDS "Emergency Response Data System". The system that transmits selected plant parameter data to the NRC Operations Center.
- 3.9 ERF "Emergency Response Facility". The Control Room, TSC, OSC and EOF maintained for emergency response.

- 3.10 ERO "Emergency Response Organization".
- 3.11 FTS-ENS phones NRC notification system phones, , FTS- "Federal Telecommunications System", ENS- "Emergency Notification System".
- 3.12 GE "General Emergency".
- 3.13 KFAB Designated Local Primary One (LP1) Emergency Alert Station located in Omaha, NE.
- 3.14 NOUE "Notification of Unusual Event".
- 3.15 NRC "Nuclear Regulatory Commission".
- 3.16 OSC "Operations Support Center".
- 3.17 PARs "Protective Action Recommendations".
- 3.18 RELEASE OF RADIOACTIVE MATERIAL Any discharge of radioactive effluent to the environment that is a result of, or associated with, the emergency event.
- 3.19 SAE "Site Area Emergency".
- 3.20 TSC "Technical Support Center".

4. PREREQUISITES

4.1 An emergency has been declared or is to be reported per EPIP-OSC-1, Emergency Classification.

5. <u>PROCEDURE</u>

NOTE: Once an event has been declared, notifications must be made within the time requirements of the applicable attachment.

- 5.1 IF no Emergency has been declared and conditions for a classification level occurred but no longer exist (per EPIP-OSC-1), THEN the event must be **reported** as follows:
 - 5.1.1 Notify both states using the commercial line. Call Iowa at 1-515-281-3231 (24 hour #) and Nebraska at 1-402-471-7430 (normal hours) or 1-402-471-4545 (after hours).
 - 5.1.2 Request that each state have the appropriate duty officer contact the Control Room at 1-402-533-6623 for a report on the event.

PAGE CONTAINS PRIVACY AND/OR PROPRIETARY INFORMATION

- 5.1.3 Notify the NRC using the FTS-ENS phone (commercial line is a backup) per SO-R-1.
- 5.1.4 **DO NOT** complete an Attachment 6.1, but log information in the Control Room Log as necessary.
- 5.2 IF while in a declared emergency, conditions for a higher emergency classification were exceeded but have since been abated or otherwise been resolved prior to declaration, THEN the event must be **reported** as follows:
 - 5.2.1 Perform the notifications described in Attachments 6.1, 6.2 or 6.3 for the states, counties and the NRC for the current classification.
 - 5.2.2 Inform the states, counties and the NRC that a higher classification existed, but was not declared, what conditions existed that caused the emergency classification, and inform them of the time that the higher classification existed.
- 5.3 Record any additional documentation in FC-EPF-13, Emergency Response Organization Log Sheet, or the Control Room Log.
- 5.4 **IN THE CONTROL ROOM:** Perform notifications using Attachment 6.1.
- 5.5 **IN THE TSC OR EOF:** Perform notifications using Attachment 6.2 (TSC) or 6.3 (EOF).
- 5.6 IF an upgrade or downgrade of the emergency classification occurs prior to completion of the checklist, THEN perform the following:
 - 5.6.1 Complete state/county notifications for the former classification.
 - 5.6.2 Begin another Notification Attachment for the new classification.
- 5.7 Complete Attachment 6.7 when performing reliefs.
- 5.8 Retain all documentation (logs, calculation sheets, notes, etc.) generated or used during the emergency.
- 5.9 At the termination, deliver all documentation to the CR Communicator, or Admin Logistics position for your facility.

6. ATTACHMENTS

6.1 Notification Checklist for the Control Room

- 6.2 Notification Checklist for the TSC
- 6.3 Notification Checklist for the EOF
- 6.4 ERO Activation Announcement
- 6.5 Classification Announcement
- 6.6 Emergency Termination Guidelines
- 6.7 Relief Checklist
- 6.8 Command and Control Position Responsibilities
- 6.9 Classifying and Reporting events to the Blair Industrial Park Co-Op

FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE					EPII PAGE	P-OSC-2 7 OF 29
		Attachment 6.1	Notification Checklist for t	the Control Room	Ра	ge 1 of 5
Classific	ation		□ Site Area	Declared at		
		🗋 Alert	General	EAL #	Date	1 ime
Commai	nd an	d Control:				
Relief: (c	comple	ete Attachment 6.7)		Ti	me	
NOTE: Control (The f positi	ollowing steps are or on may modify the se	dered in a suggested sequ equence, if necessary.	ence, but the Comr	nand ar	nd
NOTE: FILTERI and the FILTERI	Fort (ED M Shift ED M	Calhoun station made ODE with 30 minutes Chemistry Technicia ODE.	e a commitment to place the of a LOCA. Both the Shift have been trained to place	e TSC HVAC Syste It Radiation Protecti ce the TSC HVAC S	m in th on Tecl System	e hnician in the TIME
					<u>v</u> _	
1. Dire	ct the	:				
• 5 1	Shift (Notific	Communicator to repo cations	ort to the Control Room an	d perform		
• 9	Shift (Chemistry Technician	to report to Control Room	and perform dose		
• S	Shift I MODI	RP Technician to plac E and perform Contro	e the TSC HVAC System I Room Habitability Check	in the FILTERED s [AR 30816] .		
2. Is El	RO to	be activated?				
Yes	2.1	Instruct Communica	tor to activate the ERO.			
	2.2	Perform plant annou	Incement per Attachment	6.4.		
	2.3	Go to Step 4.				
No		Go to Step 3.				

FC EN	FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE				
	Attachment 6.1				
			✓	TIME	
3.	ls a Man	agement Notification (NOUE only) desired?			
	Yes 3.1	Direct Communicator to do a Management notification.			
	3.2	Perform a plant announcement, using information from the Management Notification tab in the Emergency Planning Activation Instruction Booklet.			
	3.3 Have Communicator make the above announcement to Training Center and Administration Building.				
	No				
NC che bet	DTE: If the ecklist, en: fore begin	e emergency classification changes prior to completion of this sure the state and county notifications are initiated as a minimum ning another checklist.			
4.	Within 15	minutes of the emergency declaration you must:			
	4.1	Complete required sections of the Emergency Notification Form (FC-1188)			
	4.2	Ensure the Communicator notifies the states and counties using the completed Emergency Notification Form.			
5.	5. Has the ERO been activated? [AR 10026]				
	Yes 5.1 Make a plant announcement for the current classification (if not done in Step 2) using Attachment 6.5.				
	5.2	Have Communicator make an announcement to Training Center and Administration Building (if not done in Step 2).			

No Go to Step 6.

FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE			EP PAGI	IP-OSC-2 E 9 OF 29
		Attachment 6.1	P	age 3 of 5
			⊻	TIME
6. Is a Sit Emerge	e Evacua ency)? [A	tion to North Omaha necessary (required at General R 10026]		
Yes 6.	1 Perfoi	m a plant announcement per Attachment 6.5.	·······	
6.	2 Have and A	Communicator make an announcement to Training Center dministration Building, using Evacuation Route checked.		
No	Go to	Step 7.		
7. Was a require	plant/site d at Alert	evacuation directed (plant evacuation at a minimum or higher)? [AR 10026]		
Yes 7.	1 Have	on shift crew place accountability badges in box.		
7.	2 Assig relieve	n a person to log personnel in/out of the Control Room until ed by the Accountability Clerk.		
No	Go to	Step 8.		
NOTE : NF FTS-ENS a request is i	RC contac at the EO made to t	t should be maintained from at least one facility. The F can be patched in with the Control Room/TSC line if a he NRC.		
8. Immed the sta (comm	iately (no tes and c ercial pho	t later than one hour from declaration) after notification of ounties contact the NRC using the FTS-ENS phone one is the backup)		
8.	1 Has N	IRC previously been notified?		
	Yes	Then as a minimum report the classification, time and reason.		
	No	First report to the NRC, use NRC Form 361 (SO-R-1).		
8.2	2 Is clas	ssification an Alert or higher?		
	Yes	Direct the STA to activate the ERDS system using OI-ERFCS-1.		
	No	Go to Step 9.		

~^^

~

FO EM	FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE			P-OSC-2 10 OF 29
		Attachment 6.1	Pa	ige 4 of 5
			\checkmark	TIME
9.	Use Attac Co-op.	chment 6.9 to prepare the notification for the Blair Industrial Park		
10.	Ensure th approved	ne communicator updates the states and counties using an Emergency Notification Form (FC-1188)		
	•	At least hourly (from the time of the last notification) and on an hourly basis until event termination Within 15 minutes of a PAR change		
11.	Have the	states requested that we activate the ANS (sirens)?		
	Yes 11.1	Contact the Emergency Director and request activation.		
	No	Go to Step 12.		
12.	Has the s Emergen	state or county requested that Fort Calhoun Station activate the cy Alert System (EAS)?		
	Yes 12.1	Get the applicable EAS Message number from the state and county.		
	12.2	For the Primary message direct the Communicator to contact the National Weather Service using the Emergency Activations Booklet.		
	12.3	For all follow-up messages have the Communicator contact KFAB and give them the selected EAS message number for the requesting state.		
	No	Go to Step 13.		
13.	Review c	onditions for upgrade or downgrade criteria.		<u></u>

FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE			P-OSC-2 11 OF 29
	Attachment 6.1		
		✓	TIME
14. Is emerge	ency termination possible?		
Yes 14.1	Review Attachment 6.6 for termination guidelines.	<u></u>	
14.2	Complete and approve the termination Emergency Notification Form (FC-1188).		
14.3	Verify all data on the Emergency Notification Form is accurate.	<u></u>	
14.4	14.4 Direct the Communicator to notify the states and counties using the Emergency Notification Form.		
	NOTE : If a Sub Area 1 evacuation was ordered Blair Industrial Park Co-Op facilities may not be staffed.		
14.5	Was the Blair Industrial Park Co-Op notified?		
	Yes Reactivate the system and inform Co-Op members of the event termination.		
	No Go to Step 14.6.		
14.6	14.6 Notify the NRC using the FTS-ENS phone (commercial line is backup).		
14.7 Announce Emergency termination using:			
	 Plant Gai-Tronics Facility PA system MOP network for all other Emergency Response Facilities 		
No Rev	iew this list and repeat applicable steps as required.		

FO EM	RT (IERG	CALH(SENC)	OUN STATION Y PLAN IMPLEMENT	TING PROCEDURE		EPII PAGE 1	P-OSC-2 2 OF 29
			Attachment	6.2 - Notification Checklist for	the TSC	Pa	ge 1 of 4
Cla	issific	cation		🗌 Site Area	Declared a	t	1
			🗌 Alert	🗌 General	EAL #	Date	Time
Co	mma	nd an	d Control:				
Re	lief: (comple	ete Attachment 6.7)		Т	ime	
NO Coi	TE: ntrol	The f position	ollowing steps are on on may modify the se	dered in a suggested sequence equence, if necessary.	e, but the Com	mand ar	id
sta	te an	if the	nty notifications are i	nitiated as a minimum before l	on of this check beginning anoth	klist, ens her chec	ure the klist.
						✓	TIME
1.	With	nin 15	minutes of the emerg	gency declaration you must:			
		1.1	Complete required s (FC-1188)	ections of the Emergency Not	ification Form		
		1.2	Ensure the COP Co using the completed	mmunicator notifies the states Emergency Notification Form	and counties		
2.	ls a Eme	Site E ergend	Evacuation to North C cy)? [AR 10026]	maha necessary (required at	General		
	Yes	2.1	Go to Attachment 6. used, (primary or alt	5, to determine the evacuation ernate) and the announcemen	route to be t to be made.		
		2.2	Direct the COP Com announcement foun Instruction Booklet to Building.	nmunicator to make the evacua d in the Emergency Planning A o the Training Center and Adm	ation Activations ninistration		
	No	2.3	Make a plant annou	ncement per Attachment 6.5.	[AR 10026]		
		2.4	Direct the COP Com no site evacuation for Instruction Booklet to Building.	municator to make the annour ound in the Emergency Plannir o the Training Center and Adm	ncement for ng Activations ninistration		

FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE			EP PAGE	IP-OSC-2 13 OF 29	
			Attachment 6.2	P	age 2 of 4
				∠	TIME
3.	Has plan	t/site acc	countability been established?		
	Yes	Go to S	Step 4.		
	No 3.1	Ensure personi	CR/OSC/TSC Accountability Clerks are logging nel in/out (if OSC/TSC are activated).		
	3.2	Ensure accoun	that the TSC Security Coordinator initiates the tability procedure, if the TSC is activated.		
	3.3	Ensure Control	the accountability completion time is documented in the Room Log.		<u> </u>
NC FT rec	DTE: NRC S-ENS at quest is m	contact the EOF ade to the	should be maintained from at least one facility. The can be patched in with the Control Room/TSC line if a e NRC.		
4.	Immedia the state phone (c	tely (not l s and cou ommercia	later than one hour from declaration) after notification of unties ensure the NRC is contacted using the FTS-ENS al phone is the backup)		
	4.1	As a mi	inimum, report new classification time and reason.		
	4.2	Is new	classification Alert or higher?		
		Yes	Ensure the Control Room activated the ERDS using OI-ERFCS-1.		
		Νο	Go to Step 5.		
5.	Direct the B	e Control lair Indus	Room to use Attachment 6.9 to prepare the notification trial Park Co-Op.		
6.	 Ensure the COP Communicator updates the states and counties using an approved Emergency Notification Form (FC-1188) 				
	 At least hourly (from the time of the last notification) and on an hourly basis thereafter Within 15 minutes of a PAR change 				

FO EN	EF PAGE	PIP-OSC-2 14 OF 29				
	Attachment 6.2				age 3 of 4	
				\checkmark	TIME	
7.	Have	e the	states requested that we activate the ANS (sirens)?			
	Yes	7.1	Contact the EOF Emergency Director and request ANS activation.		<u> </u>	
	No		Go to Step 8.			
8.	Has Eme	a sta rgeno	te or county requested that Fort Calhoun Station activate the cy Alert System (EAS)?			
	Yes	8.1	Get the applicable EAS Message number from the state and county.			
		8.2	For the preliminary message direct the COP Communicator to contact the National Weather Service using the Emergency Activations Booklet.			
		8.3	For all follow-up messages have the COP Communicator contact KFAB and give them the selected EAS message number for the requesting state.	<u></u>		
	No		Go to Step 9.			
9.	Perio	odical	ly review conditions for event upgrade or downgrade criteria.		. <u> </u>	
10. Is emergency termination possible?						
	Yes	10.1	Review Attachment 6.6 for termination guidelines.			
		10.2	Complete and approve the termination Emergency Notification Form (FC-1188).			
		10.3	Verify that all Emergency Notification Form data is correct.	<u> </u>		
		10.4	Direct the COP Communicator to notify the states and counties using the Emergency Notification Form.			

FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE	EPI PAGE	IP-OSC-2 15 OF 29
Attachment 6.2	Pa	age 4 of 4
	✓	TIME
NOTE : If a Sub Area 1 evacuation was ordered, Blair Industrial Park Co-Op facilities may not be staffed.		
10.5 Was the Blair Industrial Park Co-Op notified?		
Yes Have the Control Room inform Co-Op members of the event termination.		
No Go to Step 10.6.		
10.6 Notify the NRC using the FTS-ENS phone (commercial line is backup).		
10.7 Announce Emergency termination using:		
 Plant Gai-Tronics Facility PA system MOP network for all other Emergency Response Facilities 		
No Review this list and repeat applicable steps as required.		

FORT CALHOU EMERGENCY F	EPIP-OSC- PAGE 16 OF 2							
	Attachment 6.3 - Notification Checklist for the EOF							
Classification:	□ NOUE	🗋 Site Area	Declared at _	/				
	□ Alert	General	EAL#_					
Command and (Control:							
Relief: (complete Attachment 6.7) Time								
NOTE: The follo Control position	owing steps are may modify the	ordered in a suggested se sequence, if necessary.	equence, but the Comm	and and				

NOTE: If the emergency classification changes prior to completion of this checklist, ensure the state and county notifications are initiated as a minimum before beginning another checklist.

				✓	TIME
1.	With	nin 15	minutes of the emergency declaration you must:		
		1.1	Complete required sections of the Emergency Notification Form.		
		1.2	Ensure the COP Communicator notifies the states and counties using the completed Emergency Notification Form.		
2.	ls a Eme	Site E ergeno	Evacuation to North Omaha necessary (required at General cy)? [AR 10026]		
	Yes	2.1	Go to Attachment 6.5, to determine the evacuation route to be used, (primary or secondary) and the announcement to be made.		
		2.2	Direct the COP Communicator to make the evacuation announcement found in the Emergency Planning Activations Instructions Booklet to the Training Center/Administration Building.		
	No	2.3	Direct the Control Room to make plant announcement per Attachment 6.5. [AR 10026]		
		2.4	Direct the COP Communicator to make the announcement for no site evacuation found in the Emergency Planning Activations Instruction Booklet to the Training Center and Administration Building.		

FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE	EPIP-OSC-2 PAGE 17 OF 29				
Attachment 6.3	Page 2 of 4				
	✓ <u>TIME</u>				
3. Has plant/site accountability been established? (AR 10026)					
Yes Go to Step 4.					
No 3.1 Direct Site Director to initiate personnel accountability.					
NOTE : NRC contact should be maintained from at least one facility. The FTS-ENS at the EOF can be patched in with the Control Room/TSC line if a request is made to the NRC.					
 Immediately (not later than one hour from declaration) after notification of the states and counties ensure the NRC is contacted using the FTS-ENS phone (commercial phone is the backup) 					
4.1 As a minimum, report new classification time and reason.					
4.2 Is new classification Alert or higher?					
Yes Ensure the Control Room activated the ERDS using OI-ERFCS-1.	<u> </u>				
No Go to Step 5.					
 Direct the Control Room to use Attachment 6.9 to prepare the notification for the Blair Industrial Park Co-Op. 					
 Ensure the COP Communicator updates the states and counties using an approved Emergency Notification Form (FC-1188). 					
 At least hourly (from the time of the last notification) and on an hourly basis thereafter until event termination Within 15 minutes of a PAR change 					
 Ensure that the staffs of each facility are given timely updates on any significant change in plant or release status, even if the emergency classification remains unchanged. 					

~

FO EM	RT C IERG	EP PAGE	P-OSC-2 18 OF 29		
	Attachment 6.3				age 3 of 4
				\checkmark	TIME
8.	Have	e the	states requested that we activate the ANS (sirens)?		
	Yes	8.1	Direct the Administrative Logistics Manager to activate the ANS activation.		·
	No		Go to Step 9.		
9.	Has Eme	a sta rgeno	te or county requested that Fort Calhoun Station activate the cy Alert System (EAS)?		
	Yes	9.1	Get the applicable EAS Message number from the state or county.		
		9.2	For the preliminary message direct the COP Communicator to contact the National Weather Service using the Emergency Activations Booklet.		
		9.3	For all follow-up messages have the COP Communicator contact KFAB and give them the selected EAS message number for the requesting state.		
	No		Go to Step 10.		
10.	Perio	odical	ly review conditions for event upgrade or downgrade criteria.		
11.	ls er	nerge	ncy termination possible?		
	Yes	11.1	Review Attachment 6.6 for termination guidelines.		
		11.2	Verify that Emergency Notification Form (FC-1188) data is correct.		
		11.3	Complete and approve the termination Emergency Notification Form.		
		11.4	Direct the COP Communicator to notify the states and counties using the Emergency Notification Form.		

FORT CALHOUN ST EMERGENCY PLAN	EPIP-OSC- PAGE 19 OF 2				
	Pa	age 4 of 4			
		✓	TIME		
NOTE : Park C	If a Sub Area 1 evacuation was ordered, Blair Industrial o-Op facilities may not be staffed.				
11.5 Was th	e Blair Industrial Park Co-Op notified?				
Yes	Have the Control Room inform Co-Op members of the event termination.				
No	Go to Step 11.6.				
11.6 Notify t backup					
11.7 Direct tusing:					
● PI ● Fa ● M	ant Gai-Tronics acility PA system OP network for all other Emergency Response Facilities				
No Review this list and repeat applicable steps as required.					

FORT CALHOUN STATION
EMERGENCY PLAN IMPLEMENTING PROCEDURE

()

Attachment 6.4 - ERO Activation Announcement

1.	Select from the options below, the information to be announced.	
2.	Notify Security if a plant/site evacuation is planned.	
3.	Sound the Emergency Alarm for approximately 30 seconds.	
4.	Read the selected announcement over the Gai-Tronics.	
5.	Again sound the Emergency Alarm for approximately 30 seconds.	
6.	Again read the selected announcement over the Gai-Tronics.	

ANNOUNCEMENT

"Attention all personnel...Attention all personnel...A(n) (Classification) has been declared, due to ... (state reason) ... All Emergency Response Organization personnel report to their assigned facility immediately...Personnel in the Radiation Controlled Area proceed to the RCA Access Point...No eating, drinking, smoking or chewing is allowed anywhere in THE OWNER CONTROLLED AREA until further notice...All other personnel:

Optional:	NOUE	 Continu	e with normal duties
Optional: Required:	NOUE Alert Site Area	 Evacuat Security	e to the Admin Building using the South Access Point
Optional:	Alert Site Area	 Evacuat	e to the North Omaha Power Station using the:
rtequireu.	General		PRIMARY Route. (No release, or release with wind direction ≥57° and <304°)
			ALTERNATE Route. (wind direction from ≥304° or <57° with known release)

Attachment 6.5 - Classification Announcement

		<u>(⁄)</u>
NC info Err	DTE : The Site Director and the Emergency Director should select the ormation to be announced and direct the Control Room to sound the nergency Alarm and make the Gai-tronics announcements.	
1.	Select, from the options below, the information to be announced.	
2.	Notify Security if a plant/site evacuation is planned.	
3.	Sound the Emergency Alarm for approximately 30 seconds.	
4.	Read the selected announcement over the Gai-Tronics.	<u> </u>
5.	Sound the Emergency Alarm for approximately 30 seconds (second time).	
6.	Read the selected announcement over the Gai-Tronics (second time).	
7	At the EOE, verify that the above steps have been completed	

At the EOF, verify that the above steps have been completed using the Operations Liaison Circuit or other communication.

ANNOUNCEMENT

"Attention all personnel...Attention all personnel...A(n) <u>(Classification)</u> has been declared, due to...(<u>state reason</u>)...No eating, drinking, smoking or chewing is allowed anywhere in THE OWNER CONTROLLED AREA until further notice"... (Continue only if a plant/site evacuation is required)

"All Non-Emergency Response personnel must:

Optional: NOUE _____ Evacuate to the Administration Building using the South Required: Alert Site Area

Optional:	Alert Site Area	 Evacuate f	o the North Omaha Power Station using the:
Required:	General		PRIMARY Route. (No release, or release with wind direction $\ge 57^{\circ}$ and $<304^{\circ}$)

____ ALTERNATE Route. (wind direction from ≥304° or <57° with known release)

EPIP-OSC-2 PAGE 22 OF 29

Attachment 6.6 - Emergency Termination Guidelines Page 1 of 2

NOTE: Prior to recommending establishment of recovery operations (if necessary) and termination of the Emergency Response Organization, the following conditions should be considered.

- 1. A Recovery Operations Manager has been designated per EPIP-EOF-19 if extensive recovery actions are needed to return the plant or environs to a pre-accident status.
- 2. Radiation Protection personnel are/have been monitoring access to any radiologically controlled areas of the plant necessary for recovery operations.

5. Emergency termination recommendations have been discussed with the NRC Operations Center.

COMMENTS:

- -- --

EPIP-OSC-2 PAGE 23 OF 29

	Attachment 6.6	Page 2 of 2
6.	The states of Nebraska and lowa and the counties have been notified of the pe termination.	nding
7.	The transition from Emergency to Recovery phase has been discussed with the Recovery Operations Manager and an initial recovery operations meeting has b scheduled, if needed.	designated een
	COMMENTS:	
Ad	ditional Discussions/Comments:	
		·,

EPIP-OSC-2 PAGE 24 OF 29

Attachment 6.7 - Relief Checklist [AR 07071] Page 1 of 2

NOTE: Prior to assuming Command and Control of an emergency, Steps 1 through 8 of the following steps must be completed.

		(\checkmark)
1.	Review/Discuss cause of the emergency condition.	
2.	Review/Discuss current status of the emergency condition and classification level.	
3.	Review/Discuss current plant status.	
4.	Review/Discuss each step of current Notification Checklist (Attachments 6.1, 6.2 or 6.3), including any county/state/NRC notifications made and determine any steps NOT yet performed.	
5.	Review and discuss when next FC-1188 should be sent to state/counties.	
6.	Determine activation status of the ERO and ERF facilities:	
	Control Room:□ ERO Positions ActivatedTSC:□ Activated□ In ProgressOSC:□ Activated□ In ProgressEOF:□ Activated□ In ProgressMRC:□ Activated□ In Progress	
7.	Determine current status of dose assessment, habitability checks, radiological surveys and other tasks being performed by the Emergency Response Organization.	
8.	Determine if position being relieved is ready to complete the transfer of Command and Control.	
9.	WHEN both positions are ready, THEN perform the transfer of Command and Control.	
1 0.	Announce your name, and who has Command and Control to the lead personnel in the following facilities, if staffed:	
	Control Room, TSC, OSC, EOF and MRC.	

EPIP-OSC-2 PAGE 25 OF 29

Attachment 6.7

- Page 2 of 2
- 11. Sign your name, title and the relief time in the "Relief" space of the Notification Checklist. Initiate the appropriate Notification Checklist if transfer is between facilities.
- 12. Log relief information in the Command and Control position log.

Attachment 6.8 - Command and Control Position Responsibilities

The following responsibilities <u>CAN NOT BE DELEGATED</u> by the Command and Control position. The responsibility of their completion rests with the Command and Control position until relieved by another qualified individual or the emergency is terminated. The Command and Control position may assign other personnel to assist in conducting the actions necessary.

- 1. Overall COMMAND AND CONTROL of the Emergency Response Organization.
- 2. Ensuring the proper **CLASSIFICATION AND DECLARATION** of the emergency situation is made in accordance with EPIP-OSC-1 and is periodically reviewed to determine if the classification should be upgraded, downgraded or terminated.
- 3. Ensuring all required **NOTIFICATIONS** are made to appropriate state, local and federal officials.
- 4. Ensuring any appropriate **PROTECTIVE ACTION RECOMMENDATIONS** (PARs) are provided to offsite officials.
- 5. Authorizing OPPD emergency worker exposure extensions beyond the Federal Radiation Protection Guidance.
- 6. Authorizing issuance of Potassium lodide for OPPD emergency workers.

The Command and Control position also has the following responsibilities which may be delegated to other personnel, as necessary.

- 7. Request for assistance from federal agencies.
- 8. Authorizing any emergency information to be released to the media or the general public.
- 9. Coordinating the transfer of emergency information from the Emergency Response Organization (ERO) to other OPPD and outside organizations called upon to assist.
- 10. Ensuring a timely and complete turnover of information to any qualified relief.
- 11. Providing information to authorized representatives of the states of Nebraska, and Iowa, and associated local governments.
- 12. Ensuring plant operations are in compliance with Technical Specifications. If deviations are necessary to protect the public health and safety, they must be approved, as a minimum, by a senior licensed operator, prior to taking the action.

Attachment 6.9 - Classifying and Reporting Events to the Blair Industrial Park Co-Op Page 1 of 3

NOTE: The purpose of this attachment is to keep members of the Blair Industrial Park Co-Op aware of significant events that have occurred at the Fort Calhoun Station. It is intended that the system be used for notification of emergency situations which have or are anticipated to have visibility or impact beyond the Fort Calhoun station property lines. These situations may include, but are not limited to:

- Any gas or chemical leaks of significant magnitude
- Any radiation leaks of significant magnitude
- Any "news worthy" information (such as major fires, explosions, large medical response, etc.) which could result in news media interviewing neighboring industries
- Any plant evolutions resulting in large noises or having a visual impact which can be heard or seen by the public
- 1. INITIAL ASSESSMENT

NOTE: FC-EPF-38 is designed to aid you in gathering data prior to contacting members of the Co-Op. Existing FC-1188 and/or SO-R-1 can be used to provide the necessary information.

1.1 If notified of an onsite toxic chemical/hazardous material or radiological release, complete Sections 3, 5, 6 and 7 of FC-EPF-38. If all the information is not known, leave that section blank. <u>DO NOT GIVE UNVERIFIED INFORMATION</u>.

NOTE: Assistance in classification may be obtained from the Shift Chemist.

2. EVENT CLASSIFICATION

2.1 Report the event as classified (NOUE, ALERT, SITE AREA or GENERAL EMERGENCY) in Section 2 of FC-EPF-38.
Attachment 6.9

Page 2 of 3

NOTE: If the involved chemical is not listed, or further information on chemicals is desired refer to SO-G-106, "Hazardous Material Chemical Assessment and Emergency Response Guidelines", the Material Safety Data Sheet, if available, or The North American Emergency Response Guidebook.

NOTE: If the involved chemical is not listed below, refer to the North American Emergency Response Guidebook for guidelines.

- 2.2 If the involved chemical is one of the following, consider it a SMALL HAZARD:
 - Acetylene
 - Amerzine
 - Chemtreat
 - Ethanolamine
 - Diesel Fuel
 - Hydrazine
 - Hydrogen
- 2.3 Use the guide below to classify the event class. The four codes are further defined in the definitions section of this procedure:

CODE HAZARD POTENTIAL CONDITIONS

Blue	Small or large	Situation under control - NO offsite threat
Green	Small or large	Situation NOT under control - No immediate offsite threat
Yellow	Large	Situation NOT under control - Onsite protective actions will be needed
Red	Large	Situation NOT under control - Protective actions for neighboring industries and residents needed

EPIP-OSC-2 PAGE 29 OF 29

Attachment 6.9

Page 3 of 3

NOTE: All members of the Co-Op are staffed 24 hours per day except Kelly Ryan and Agro. MACC may not have staff onsite on some weekends and/or holidays.

NOTE: Alternate emergency numbers and routine day to day contact numbers for all Co-Op members and other vital agencies may be found in the Emergency Phone Book under the Blair Industrial Co-Op tab.

NOTE: All Notifications to the Blair Industrial Park Co-Op should be made through the Control Room if possible.

3. NOTIFICATIONS

- 3.1 Obtain the instructions marked "Blair Industrial Park Co-Op Notification" from the Emergency Planning Activation Instructions Booklet.
- 3.2 Direct the Communicator to perform the Blair Industrial Park Co-Op Notifications.
- 3.3 If event is on-going, update the Blair Industrial Park Co-Op members as conditions warrant.

WP8

Distribution Authorized

Fort Calhoun Station Unit No. 1 This procedure does not contain any proprietary information, or such information has been censored. This issue may be released to the public document room. Proprietary information includes personnel names, company telephone numbers, and any information, which could impede emergency response.

EPIP-OSC-2

EMERGENCY PLAN IMPLEMENTING PROCEDURE

Title: COMMAND AND CONTROL POSITION ACTIONS/NOTIFICATIONS

FC-68 Number: EC 29389

Reason for Change: Add instruction for the Shift RP and Chemist to place the TSC HVAC System in the FILTERED MODE. Required by a commitment made in LIC-01-0109.

Requestor: M. Reller

Preparer: M. Reller

COMMAND AND CONTROL POSITION ACTIONS/NOTIFICATIONS

NON-SAFETY RELATED

1. PURPOSE

1.1 This procedure provides guidance to the Command and Control position for implementing the Emergency Plan, making required notifications, transferring Command and Control, performing classification upgrades/downgrades and event terminations.

2. REFERENCES/COMMITMENT DOCUMENTS

- 2.1 SO-R-1, "Reportability Determination"
- 2.2 10 CFR 50.72, "Immediate Notification Requirements for Operating Nuclear Power Reactors
- 2.3 EPIP-OSC-1, "Emergency Classification"
- 2.4 EPIP-OSC-15, "Communicator Actions"
- 2.5 EPIP-EOF-6, "Dose Assessment"
- 2.6 EPIP-EOF-7, "Protective Action Guidelines"
- 2.7 EPIP-EOF-11, "Dosimetry Records, Exposure Extensions, and Habitability"
- 2.8 EPIP-EOF-21, "Potassium lodide Issuance"
- 2.9 EPIP-EOF-19, "Recovery Actions"
- 2.10 EPIP-TSC-1, "Activation of the Technical Support Center"
- 2.11 EPIP-EOF-1, "Activation of the Emergency Operations Facility"
- 2.12 OI-ERFCS-1, "Emergency Response Facility Computer System"
- 2.13 FC-1188, "Emergency Notification Form"
- 2.14 FC-EPF-38, "Blair Industrial Park Co-Op, Event Notification Form"
- 2.15 Emergency Telephone Book

- 2.16 Commitments (other than Ongoing)
 - AR 10026, NRC-89-0232
 - AR 07071, LIC-88-0726
- 2.17 Ongoing Commitments
 - AR 30816, LIC-01-0189

3. <u>DEFINITIONS</u>

- 3.1 ANS "Alert Notification System" The system of sirens maintained in OPPD's designated EPZ (Emergency Planning Zone).
- 3.2 BLAIR INDUSTRIAL PARK CO-OP: EMERGENCY NOTIFICATION SYSTEM An organization of industries including Fort Calhoun Station that have banded together to form a warning system to notify member industries and the Washington County Dispatch Center of a potential or actual release of toxic chemicals and/or hazardous material from its facility.

- 3.3 CODE SYSTEM A system devised by members of the Blair Industrial Park Co-Op to classify events that have occurred at the initiating facilities site. These codes are:
 - CODE BLUE: A minor emergency or problem such as a fire, explosion, gas or liquid release, unusual noise or odor, abnormal or extended flaring activity or other internal event has occurred which may be visible or detectable by off-site people, but which presents NO OFFSITE THREAT and requires no protective actions. The situation is under control.
 - CODE GREEN: An emergency such as a fire, explosion, gas or liquid release or other event has occurred which affects plant operations and/or has the potential to escalate to a more serious emergency. THE SITUATION IS NOT UNDER CONTROL BUT POSES NO IMMEDIATE OFFSITE THREAT. The Washington County EOC may activate.
 - CODE YELLOW: A serious accident such as a fire, explosion, gas or liquid or other event has occurred or is imminent which seriously affects plant operations and/or poses a threat to residents or industries in the immediate vicinity of the affected industry. THE SITUATION IS NOT UNDER CONTROL AND ONSITE PROTECTIVE ACTIONS WILL BE NECESSARY. The Washington County EOC would activate.
 - CODE RED: A severe emergency such as fire, explosion, gas or liquid release or other event has occurred or is imminent which seriously affects plant operations and/or offsite areas well beyond site boundaries. THE SITUATION IS NOT UNDER CONTROL AND PROTECTIVE ACTIONS FOR NEIGHBORING INDUSTRIES AND RESIDENTS ARE NECESSARY. The Washington County EOC would fully activate at a safe location.
- 3.4 COMMAND AND CONTROL POSITION The Shift Manager, Control Room Coordinator, Site Director or Emergency Director currently charged with the authorities and responsibilities for directing the emergency response.
- 3.5 EALs "Emergency Action Levels"
- 3.6 EAS "Emergency Alert System". A mass-media system providing information and instructions to the general public in the event of a nuclear or other public emergency.
- 3.7 EOF "Emergency Operations Facility".
- 3.8 ERDS "Emergency Response Data System". The system that transmits selected plant parameter data to the NRC Operations Center.
- 3.9 ERF "Emergency Response Facility". The Control Room, TSC, OSC and EOF maintained for emergency response.

- 3.10 ERO "Emergency Response Organization".
- 3.11 FTS-ENS phones NRC notification system phones, , FTS- "Federal Telecommunications System", ENS- "Emergency Notification System".
- 3.12 GE "General Emergency".
- 3.13 KFAB Designated Local Primary One (LP1) Emergency Alert Station located in Omaha, NE.
- 3.14 NOUE "Notification of Unusual Event".
- 3.15 NRC "Nuclear Regulatory Commission".
- 3.16 OSC "Operations Support Center".
- 3.17 PARs "Protective Action Recommendations".
- 3.18 RELEASE OF RADIOACTIVE MATERIAL Any discharge of radioactive effluent to the environment that is a result of, or associated with, the emergency event.
- 3.19 SAE "Site Area Emergency".
- 3.20 TSC "Technical Support Center".

4. PREREQUISITES

4.1 An emergency has been declared or is to be reported per EPIP-OSC-1, Emergency Classification.

5. <u>PROCEDURE</u>

NOTE: Once an event has been declared, notifications must be made within the time requirements of the applicable attachment.

- 5.1 IF no Emergency has been declared and conditions for a classification level occurred but no longer exist (per EPIP-OSC-1), THEN the event must be **reported** as follows:
 - 5.1.1 Notify both states using the commercial line. Call lowa at (24 hour #) and Nebraska at (normal hours) or (after hours).
 - 5.1.2 Request that each state have the appropriate duty officer contact the Control Room at for a report on the event.

- 5.1.3 Notify the NRC using the FTS-ENS phone (commercial line is a backup) per SO-R-1.
- 5.1.4 **DO NOT** complete an Attachment 6.1, but log information in the Control Room Log as necessary.
- 5.2 IF while in a declared emergency, conditions for a higher emergency classification were exceeded but have since been abated or otherwise been resolved prior to declaration, THEN the event must be **reported** as follows:
 - 5.2.1 Perform the notifications described in Attachments 6.1, 6.2 or 6.3 for the states, counties and the NRC for the current classification.
 - 5.2.2 Inform the states, counties and the NRC that a higher classification existed, but was not declared, what conditions existed that caused the emergency classification, and inform them of the time that the higher classification existed.
- 5.3 Record any additional documentation in FC-EPF-13, Emergency Response Organization Log Sheet, or the Control Room Log.
- 5.4 **IN THE CONTROL ROOM:** Perform notifications using Attachment 6.1.
- 5.5 **IN THE TSC OR EOF:** Perform notifications using Attachment 6.2 (TSC) or 6.3 (EOF).
- 5.6 IF an upgrade or downgrade of the emergency classification occurs prior to completion of the checklist, THEN perform the following:
 - 5.6.1 Complete state/county notifications for the former classification.
 - 5.6.2 Begin another Notification Attachment for the new classification.
- 5.7 Complete Attachment 6.7 when performing reliefs.
- 5.8 Retain all documentation (logs, calculation sheets, notes, etc.) generated or used during the emergency.
- 5.9 At the termination, deliver all documentation to the CR Communicator, or Admin Logistics position for your facility.

6. ATTACHMENTS

6.1 Notification Checklist for the Control Room

- 6.2 Notification Checklist for the TSC
- 6.3 Notification Checklist for the EOF
- 6.4 ERO Activation Announcement
- 6.5 Classification Announcement
- 6.6 Emergency Termination Guidelines
- 6.7 Relief Checklist
- 6.8 Command and Control Position Responsibilities
- 6.9 Classifying and Reporting events to the Blair Industrial Park Co-Op

FORT CALHO EMERGENCY	UN STATION PLAN IMPLEMEN	TING PROCEDURE		EPIP-OSC-2 PAGE 7 OF 29
	Attachment 6.1	- Notification Checkli	st for the Control Room	Page 1 of 5
Classification:		🛛 Site Area	Declared at	/
	□ Alert	General	EAL #	
Command and	Control:			
Relief: (complete	e Attachment 6.7)		Ti	me
NOTE: The fo Control position	llowing steps are on n may modify the s	rdered in a suggested equence, if necessar	I sequence, but the Comr y.	nand and
NOTE: Fort Calhoun station made a commitment to place the TSC HVAC System in the FILTERED MODE with 30 minutes of a LOCA. Both the Shift Radiation Protection Technician and the Shift Chemistry Technician have been trained to place the TSC HVAC System in the				
				✓ TIME
1. Direct the:				
Shift Control	ommunicator to rep	oort to the Control Ro	om and perform	
 Shift Cl 	nemistry Technicia	n to report to Control	Room and perform dose	
 Shift RI MODE 	ment P Technician to pla and perform Contr	ce the TSC HVAC Sy ol Room Habitability (/stem in the FILTERED Checks [AR 30816] .	<u> </u>
2. Is ERO to	pe activated?			
Yes 2.1	nstruct Communic	ator to activate the El	૨૦.	
2.2	Perform plant anno	uncement per Attach	ment 6.4.	<u> </u>
2.3	Go to Step 4.			

No Go to Step 3.

FO EN	FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE			EPIP-OSC-2 PAGE 8 OF 29	
			Attachment 6.1	Pa	ge 2 of 5
				<u>√</u>	TIME
3.	ls a M	lana	gement Notification (NOUE only) desired?		
	Yes	3.1	Direct Communicator to do a Management notification.		
	3	3.2	Perform a plant announcement, using information from the Management Notification tab in the Emergency Planning Activation Instruction Booklet.		
	3	3.3	Have Communicator make the above announcement to Training Center and Administration Building.		
	No		Go to Step 4.		
NOTE : If the emergency classification changes prior to completion of this checklist, ensure the state and county notifications are initiated as a minimum before beginning another checklist.					
4.	Withir	า 15	minutes of the emergency declaration you must:		
	4	1.1	Complete required sections of the Emergency Notification Form (FC-1188)		
	4	1.2	Ensure the Communicator notifies the states and counties using the completed Emergency Notification Form.		
5.	5. Has the ERO been activated? [AR 10026]				
	Yes (5.1	Make a plant announcement for the current classification (if not done in Step 2) using Attachment 6.5.		
	5	5.2	Have Communicator make an announcement to Training Center and Administration Building (if not done in Step 2).		

No Go to Step 6.

FC EN	FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE				
			Attachment 6.1	P	age 3 of 5
				∠	TIME
6.	ls a Site Emergen	Evacuatio icy)? [AR	on to North Omaha necessary (required at General 10026]		
	Yes 6.1	Perform	a plant announcement per Attachment 6.5.		
	6.2	Have C and Adı	ommunicator make an announcement to Training Center ministration Building, using Evacuation Route checked.		
	No	Go to S	tep 7.		
7.	Was a plant/site evacuation directed (plant evacuation at a minimum required at Alert or higher)? [AR 10026]				
	Yes 7.1	Have or	n shift crew place accountability badges in box.		
	7.2	Assign relieved	a person to log personnel in/out of the Control Room until I by the Accountability Clerk.		
	No	Go to S	tep 8.		
NC FT rec	DTE: NRC S-ENS at quest is ma	contact the EOF ade to the	should be maintained from at least one facility. The can be patched in with the Control Room/TSC line if a NRC.		
8.	Immedia the state (commer	tely (not I s and coເ cial phon	ater than one hour from declaration) after notification of Inties contact the NRC using the FTS-ENS phone e is the backup)		
	8.1	Has NR	C previously been notified?		
		Yes	Then as a minimum report the classification, time and reason.		
		No	First report to the NRC, use NRC Form 361 (SO-R-1).		
	8.2	ls class	ification an Alert or higher?		
		Yes	Direct the STA to activate the ERDS system using OI-ERFCS-1.		
		No	Go to Step 9.		

۔ میں

~

FO EM	RT CALHO ERGENC`	EPI PAGE	P-OSC-2 10 OF 29	
		Attachment 6.1	Pa	age 4 of 5
			\checkmark	TIME
9.	Use Attac Co-op.	hment 6.9 to prepare the notification for the Blair Industrial Park		
10.	Ensure th approved	e communicator updates the states and counties using an Emergency Notification Form (FC-1188)		
	•	At least hourly (from the time of the last notification) and on an hourly basis until event termination Within 15 minutes of a PAR change		
11.	Have the	states requested that we activate the ANS (sirens)?		
	Yes 11.1	Contact the Emergency Director and request activation.		
	No	Go to Step 12.		
12.	Has the s Emergend	tate or county requested that Fort Calhoun Station activate the cy Alert System (EAS)?		
	Yes 12.1	Get the applicable EAS Message number from the state and county.		
	12.2	For the Primary message direct the Communicator to contact the National Weather Service using the Emergency Activations Booklet.		
	12.3	For all follow-up messages have the Communicator contact KFAB and give them the selected EAS message number for the requesting state.		
	No	Go to Step 13.		
13.	Review co	onditions for upgrade or downgrade criteria.		

FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE	EPIP-OSC-2 PAGE 11 OF 29
Attachment 6.1	Page 5 of 5
	✓ <u>TIME</u>
14. Is emergency termination possible?	
Yes 14.1 Review Attachment 6.6 for termination guide	elines.
14.2 Complete and approve the termination Emer Form (FC-1188).	rgency Notification
14.3 Verify all data on the Emergency Notification	n Form is accurate.
14.4 Direct the Communicator to notify the states the Emergency Notification Form.	and counties using
NOTE : If a Sub Area 1 evacuation was orde Park Co-Op facilities may not be staffed.	ered Blair Industrial
14.5 Was the Blair Industrial Park Co-Op notified	?
Yes Reactivate the system and inform (the event termination.	Co-Op members of
No Go to Step 14.6.	
14.6 Notify the NRC using the FTS-ENS phone (o backup).	commercial line is
14.7 Announce Emergency termination using:	
 Plant Gai-Tronics Facility PA system MOP network for all other Emergency F 	Response Facilities
No Review this list and repeat applicable steps as re	equired.

FO EM	RT C IERG	ALHO	DUN STATION Y PLAN IMPLEMEN ⁻	TING PROCEDURE			EPII PAGE 1	P-OSC-2 12 OF 29
			Attachment	6.2 - Notification Che	cklist for the	e TSC	Pa	ge 1 of 4
Cla	issific	cation	: 🗌 NOUE	□ Site Area □ General		Declared at	Date	/ Time
Со	mma	nd an	d Control:					
Re	lief: (comple	ete Attachment 6.7)			Ti	me	
NO Col NO	TE: ntrol	The for position	ollowing steps are or on may modify the se emergency classifica	dered in a suggested equence, if necessary ation changes prior to	sequence, l	out the Comr	mand ar	nd sure the
sta	te an	a cou	nty notifications are i	nitiated as a minimum	i betore beg	jinning anoth	ier chec	
	1.4.1.1.1	·			,		<u>√</u>	
1.	vv itr	iin 15	minutes of the emer	gency declaration you	must:			
		1.1	Complete required s (FC-1188)	ections of the Emerge	ency Notifica	ation Form		
		1.2	Ensure the COP Co using the completed	mmunicator notifies th Emergency Notificati	ne states an on Form.	d counties		<u></u>
2.	ls a Eme	Site E ergend	Evacuation to North C cy)? [AR 10026])maha necessary (req	uired at Ge	neral		
	Yes	2.1	Go to Attachment 6. used, (primary or alt	5, to determine the evernate) and the annot	vacuation ro	ute to be be made.		
		2.2	Direct the COP Con announcement foun Instruction Booklet t Building.	nmunicator to make th d in the Emergency P o the Training Center	e evacuatio Ianning Acti and Admini	n vations stration		
	No	2.3	Make a plant annou	ncement per Attachm	ent 6.5. [Af	R 10026]		
		2.4	Direct the COP Com no site evacuation for Instruction Booklet t Building.	nmunicator to make th ound in the Emergenc o the Training Center	e announce y Planning / and Admini	ement for Activations stration		

FC EN	ORT CALH	OUN ST Y PLAN	ATION IMPLEMENTING PROCEDURE	EP PAGE	IP-OSC-2 13 OF 29
			Attachment 6.2	Pa	age 2 of 4
				∠	TIME
3.	Has plan	t/site acc	countability been established?		
	Yes	Go to S	Step 4.		
	No 3.1	Ensure person	CR/OSC/TSC Accountability Clerks are logging nel in/out (if OSC/TSC are activated).		
	3.2	Ensure accoun	that the TSC Security Coordinator initiates the tability procedure, if the TSC is activated.		
	3.3	Ensure Control	the accountability completion time is documented in the Room Log.		
NC FT rec	DTE: NRC S-ENS at quest is ma	contact the EOF ade to th	should be maintained from at least one facility. The can be patched in with the Control Room/TSC line if a e NRC.		
4.	Immediat the states phone (co	tely (not s and co ommerci	later than one hour from declaration) after notification of unties ensure the NRC is contacted using the FTS-ENS al phone is the backup)		
	4.1	As a m	inimum, report new classification time and reason.		
	4.2	ls new	classification Alert or higher?		
		Yes	Ensure the Control Room activated the ERDS using OI-ERFCS-1.		
		No	Go to Step 5.		
5.	Direct the for the Bl	e Control air Indus	Room to use Attachment 6.9 to prepare the notification trial Park Co-Op.		
6.	Ensure the approved	ne COP (I Emerge	Communicator updates the states and counties using an ency Notification Form (FC-1188)		
	•	At leas hourly l Within	t hourly (from the time of the last notification) and on an basis thereafter 15 minutes of a PAR change		

_

FO EM	RT C ERG	ALH(ENC`	DUN STATION Y PLAN IMPLEMENTING PROCEDURE	EP PAGE	IP-OSC-2 14 OF 29
			Attachment 6.2	Pa	age 3 of 4
				\checkmark	TIME
7.	Have	e the	states requested that we activate the ANS (sirens)?		
	Yes	7.1	Contact the EOF Emergency Director and request ANS activation.		
	No		Go to Step 8.		
8.	Has Eme	a sta rgeno	te or county requested that Fort Calhoun Station activate the cy Alert System (EAS)?		
	Yes	8.1	Get the applicable EAS Message number from the state and county.		
		8.2	For the preliminary message direct the COP Communicator to contact the National Weather Service using the Emergency Activations Booklet.		
		8.3	For all follow-up messages have the COP Communicator contact KFAB and give them the selected EAS message number for the requesting state.		
	No		Go to Step 9.		
9.	Perio	odical	ly review conditions for event upgrade or downgrade criteria.		
10.	ls en	nerge	ncy termination possible?		
	Yes	10.1	Review Attachment 6.6 for termination guidelines.		
		10.2	Complete and approve the termination Emergency Notification Form (FC-1188).		
		10.3	Verify that all Emergency Notification Form data is correct.		
		10.4	Direct the COP Communicator to notify the states and counties using the Emergency Notification Form.		

FORT CALHO	OUN STA Y PLAN II	TION MPLEMENTING PROCEDURE	EPI PAGE	P-OSC-2 15 OF 29
		Attachment 6.2	Pa	ige 4 of 4
			∠	TIME
	NOTE: Park Co-	If a Sub Area 1 evacuation was ordered, Blair Industrial -Op facilities may not be staffed.		
10.5	Was the	Blair Industrial Park Co-Op notified?		
	Yes	Have the Control Room inform Co-Op members of the event termination.		
	No	Go to Step 10.6.		
10.6	Notify the backup).	e NRC using the FTS-ENS phone (commercial line is		
10.7	Annound	ce Emergency termination using:		
	PlanFacMO	nt Gai-Tronics ility PA system P network for all other Emergency Response Facilities		
No Rev	view this li	ist and repeat applicable steps as required.		

FORT CALHOU EMERGENCY F	IN STATION PLAN IMPLEME	NTING PROCEDURE	F	EPIP-OSC-2 AGE 16 OF 29
	Attachme	nt 6.3 - Notification Check	list for the EOF	Page 1 of 4
Classification:	□ NOUE	□ Site Area	Declared at	/
	🗌 Alert	🗌 General	EAL#_	Date Lime
Command and (Control:			
Relief: (complete	Attachment 6.7)		Tir	ne

NOTE: The following steps are ordered in a suggested sequence, but the Command and Control position may modify the sequence, if necessary.

NOTE: If the emergency classification changes prior to completion of this checklist, ensure the state and county notifications are initiated as a minimum before beginning another checklist.

				⊻	<u>TIME</u>
1.	Witł	nin 15	minutes of the emergency declaration you must:		
		1.1	Complete required sections of the Emergency Notification Form.		
		1.2	Ensure the COP Communicator notifies the states and counties using the completed Emergency Notification Form.		
2.	 Is a Site Evacuation to North Omaha necessary (required at General Emergency)? [AR 10026] 				
	Yes	2.1	Go to Attachment 6.5, to determine the evacuation route to be used, (primary or secondary) and the announcement to be made.		
		2.2	Direct the COP Communicator to make the evacuation announcement found in the Emergency Planning Activations Instructions Booklet to the Training Center/Administration Building.		
	No	2.3	Direct the Control Room to make plant announcement per Attachment 6.5. [AR 10026]		
		2.4	Direct the COP Communicator to make the announcement for no site evacuation found in the Emergency Planning Activations Instruction Booklet to the Training Center and Administration Building.		

FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE	EPIP-OSC-2 PAGE 17 OF 29
Attachment 6.3	Page 2 of 4
	<u>✓ TIME</u>
3. Has plant/site accountability been established? (AR 10026)	
Yes Go to Step 4.	
No 3.1 Direct Site Director to initiate personnel accountability.	
NOTE : NRC contact should be maintained from at least one facility. The FTS-ENS at the EOF can be patched in with the Control Room/TSC line if request is made to the NRC.	a
 Immediately (not later than one hour from declaration) after notification the states and counties ensure the NRC is contacted using the FTS-EN phone (commercial phone is the backup) 	of NS
4.1 As a minimum, report new classification time and reason.	
4.2 Is new classification Alert or higher?	
Yes Ensure the Control Room activated the ERDS using OI-ERFCS-1.	g
No Go to Step 5.	
 Direct the Control Room to use Attachment 6.9 to prepare the notificati for the Blair Industrial Park Co-Op. 	on
Ensure the COP Communicator updates the states and counties using approved Emergency Notification Form (FC-1188).	an
 At least hourly (from the time of the last notification) and on a hourly basis thereafter until event termination Within 15 minutes of a PAR change 	an
 Ensure that the staffs of each facility are given timely updates on any significant change in plant or release status, even if the emergency classification remains unchanged. 	

FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE			EPI PAGE	P-OSC-2 18 OF 29	
			Attachment 6.3	Pa	ige 3 of 4
				\checkmark	TIME
8.	Have	e the	states requested that we activate the ANS (sirens)?		
	Yes	8.1	Direct the Administrative Logistics Manager to activate the ANS activation.		
	No		Go to Step 9.		
9.	Has Eme	a stat rgenc	te or county requested that Fort Calhoun Station activate the cy Alert System (EAS)?		
	Yes	9.1	Get the applicable EAS Message number from the state or county.		
		9.2	For the preliminary message direct the COP Communicator to contact the National Weather Service using the Emergency Activations Booklet.		
		9.3	For all follow-up messages have the COP Communicator contact KFAB and give them the selected EAS message number for the requesting state.		
	No		Go to Step 10.		
10.	Perio	odical	ly review conditions for event upgrade or downgrade criteria.		
11.	ls er	nerge	ency termination possible?		
	Yes	11.1	Review Attachment 6.6 for termination guidelines.		
		11.2	Verify that Emergency Notification Form (FC-1188) data is correct.		
		11.3	Complete and approve the termination Emergency Notification Form.		
		11.4	Direct the COP Communicator to notify the states and counties using the Emergency Notification Form.		

FORT CALHOU EMERGENCY F	EPIP-OSC- PAGE 19 OF 2			
	Atta	achment 6.3	Pa	ige 4 of 4
			\checkmark	<u>TIME</u>
N 0 Pa	OTE: If a Sub Area 1 evacu ark Co-Op facilities may not	uation was ordered, Blair Industrial be staffed.		
11.5 W	as the Blair Industrial Park	Co-Op notified?		
Ye	es Have the Control Ro event termination.	oom inform Co-Op members of the		
N	o Go to Step 11.6.			
11.6 No ba	otify the NRC using the FTS ackup).	S-ENS phone (commercial line is		
11.7 Di us	rect the Site Director to ann sing:	nounce the emergency termination		
•	Plant Gai-Tronics Facility PA system MOP network for all othe	er Emergency Response Facilities		
No Review	this list and repeat applicat	ble steps as required.		

()

Attachment 6.4 - ERO Activation Announcement

1.	Select from the options below, the information to be announced.	
2.	Notify Security if a plant/site evacuation is planned.	
3.	Sound the Emergency Alarm for approximately 30 seconds.	
4.	Read the selected announcement over the Gai-Tronics.	
5.	Again sound the Emergency Alarm for approximately 30 seconds.	
6.	Again read the selected announcement over the Gai-Tronics.	

ANNOUNCEMENT

"Attention all personnel...Attention all personnel...A(n) (Classification) has been declared, due to ... (state reason) ... All Emergency Response Organization personnel report to their assigned facility immediately...Personnel in the Radiation Controlled Area proceed to the RCA Access Point...No eating, drinking, smoking or chewing is allowed anywhere in THE OWNER CONTROLLED AREA until further notice...All other personnel:

Optional:	NOUE	 Continue	with normal duties
Optional: Required:	NOUE Alert Site Area	 Evacuate Security	to the Admin Building using the South Access Point
Optional:	Alert Site Area	 Evacuate	to the North Omaha Power Station using the:
Requirea:	General	I	PRIMARY Route. (No release, or release with vind direction ≥57° and <304°)
			ALTERNATE Route. (wind direction from ≥304° or <57° with known release)

<u>(⁄)</u>

Attachment 6.5 - Classification Announcement

NOTE : The Site Director and the Emergency Director should select the	
information to be announced and direct the Control Room to sound the	
Emergency Alarm and make the Gai-tronics announcements.	

1.	Select, from the options below, the information to be announced.	
2.	Notify Security if a plant/site evacuation is planned.	
3.	Sound the Emergency Alarm for approximately 30 seconds.	
4.	Read the selected announcement over the Gai-Tronics.	
5.	Sound the Emergency Alarm for approximately 30 seconds (second time).	
6.	Read the selected announcement over the Gai-Tronics (second time).	
7.	At the EOF, verify that the above steps have been completed using the Operations Liaison Circuit or other communication.	

ANNOUNCEMENT

"Attention all personnel...Attention all personnel...A(n) (Classification) has been declared, due to...(state reason)...No eating, drinking, smoking or chewing is allowed anywhere in THE OWNER CONTROLLED AREA until further notice"... (Continue only if a plant/site evacuation is required)

"All Non-Emergency Response personnel must:

Optional: Required:	NOUE Alert Site Area	 Evacuate Security A	to the Administration Building using the South Access Point
Optional:	Alert Site Area	 Evacuate	to the North Omaha Power Station using the:
Required.	General		PRIMARY Route. (No release, or release with wind direction ≥57° and <304°)
			ALTERNATE Route. (wind direction from \ge 304° or <57° with known release)

EPIP-OSC-2 PAGE 22 OF 29

Attachment 6.6 - Emergency Termination Guidelines Page 1 of 2

NOTE: Prior to recommending establishment of recovery operations (if necessary) and termination of the Emergency Response Organization, the following conditions should be considered.

- 1. A Recovery Operations Manager has been designated per EPIP-EOF-19 if extensive recovery actions are needed to return the plant or environs to a pre-accident status.
- 2. Radiation Protection personnel are/have been monitoring access to any radiologically controlled areas of the plant necessary for recovery operations.

COMMENTS: 3. Off-site conditions allow access of personnel and needed support resources to the plant. COMMENTS: 4. Plant status with respect to Technical Specifications has been evaluated by the Command and Control position **OR** Technical Support personnel if ERO was activated. COMMENTS:

5. Emergency termination recommendations have been discussed with the NRC Operations Center.

COMMENTS:

EPIP-OSC-2 PAGE 23 OF 29

	Attachment 6.6	Page 2 of 2
6.	The states of Nebraska and Iowa and the counties have been notified of the petermination.	ending
7	The transition from Encourses to Decourse above here here discussed with the	
1.	Recovery Operations Manager and an initial recovery operations meeting has l scheduled, if needed.	e designated been
Ad	Iditional Discussions/Comments:	
		••••••••••••••••••••••••••••••••••••••

FORT	CALHO	UN ST.	ATIO	N		
EMER	GENCY	PLAN	IMPL	EMENTING	PROCE	JURE

EPIP-OSC-2 PAGE 24 OF 29

Attachment 6.7 - Relie	f Checklist [AR 07071]	Page 1 of 2
------------------------	------------------------	-------------

NOTE: Prior to assuming Command and Control of an emergency, Steps 1 through 8 of the following steps must be completed.

		(\checkmark)				
1.	Review/Discuss cause of the emergency condition.					
2.	Review/Discuss current status of the emergency condition and classification level.					
3.	Review/Discuss current plant status.					
4.	. Review/Discuss each step of current Notification Checklist (Attachments 6.1, 6.2 or 6.3), including any county/state/NRC notifications made and determine any steps NOT yet performed.					
5.	Review and discuss when next FC-1188 should be sent to state/counties.					
6.	Determine activation status of the ERO and ERF facilities:					
	Control Room:□ ERO Positions ActivatedTSC:□ Activated□ In ProgressOSC:□ Activated□ In ProgressEOF:□ Activated□ In ProgressMRC:□ Activated□ In Progress					
7.	⁷ . Determine current status of dose assessment, habitability checks, radiological surveys and other tasks being performed by the Emergency Response Organization.					
8.	 Determine if position being relieved is ready to complete the transfer of Command and Control. 					
9.	. WHEN both positions are ready, THEN perform the transfer of Command and Control.					
10.	Announce your name, and who has Command and Control to the lead personnel in the following facilities, if staffed:					
	Control Room, TSC, OSC, EOF and MRC.					

.

Attachment 6.7

Page 2 of 2

- 11. Sign your name, title and the relief time in the "Relief" space of the Notification Checklist. Initiate the appropriate Notification Checklist if transfer is between facilities.
- 12. Log relief information in the Command and Control position log.

Attachment 6.8 - Command and Control Position Responsibilities

The following responsibilities <u>CAN NOT BE DELEGATED</u> by the Command and Control position. The responsibility of their completion rests with the Command and Control position until relieved by another qualified individual or the emergency is terminated. The Command and Control position may assign other personnel to assist in conducting the actions necessary.

- 1. Overall **COMMAND AND CONTROL** of the Emergency Response Organization.
- 2. Ensuring the proper **CLASSIFICATION AND DECLARATION** of the emergency situation is made in accordance with EPIP-OSC-1 and is periodically reviewed to determine if the classification should be upgraded, downgraded or terminated.
- 3. Ensuring all required **NOTIFICATIONS** are made to appropriate state, local and federal officials.
- 4. Ensuring any appropriate **PROTECTIVE ACTION RECOMMENDATIONS** (PARs) are provided to offsite officials.
- 5. Authorizing OPPD emergency worker exposure extensions beyond the Federal Radiation Protection Guidance.
- 6. Authorizing issuance of Potassium lodide for OPPD emergency workers.

The Command and Control position also has the following responsibilities which may be delegated to other personnel, as necessary.

- 7. Request for assistance from federal agencies.
- 8. Authorizing any emergency information to be released to the media or the general public.
- 9. Coordinating the transfer of emergency information from the Emergency Response Organization (ERO) to other OPPD and outside organizations called upon to assist.
- 10. Ensuring a timely and complete turnover of information to any qualified relief.
- 11. Providing information to authorized representatives of the states of Nebraska, and Iowa, and associated local governments.
- 12. Ensuring plant operations are in compliance with Technical Specifications. If deviations are necessary to protect the public health and safety, they must be approved, as a minimum, by a senior licensed operator, prior to taking the action.

Attachment 6.9 - Classifying and Reporting Events to the Blair Industrial Park Co-Op Page 1 of 3

NOTE: The purpose of this attachment is to keep members of the Blair Industrial Park Co-Op aware of significant events that have occurred at the Fort Calhoun Station. It is intended that the system be used for notification of emergency situations which have or are anticipated to have visibility or impact beyond the Fort Calhoun station property lines. These situations may include, but are not limited to:

- Any gas or chemical leaks of significant magnitude
- Any radiation leaks of significant magnitude
- Any "news worthy" information (such as major fires, explosions, large medical response, etc.) which could result in news media interviewing neighboring industries
- Any plant evolutions resulting in large noises or having a visual impact which can be heard or seen by the public
- 1. INITIAL ASSESSMENT

NOTE: FC-EPF-38 is designed to aid you in gathering data prior to contacting members of the Co-Op. Existing FC-1188 and/or SO-R-1 can be used to provide the necessary information.

1.1 If notified of an onsite toxic chemical/hazardous material or radiological release, complete Sections 3, 5, 6 and 7 of FC-EPF-38. If all the information is not known, leave that section blank. <u>DO NOT GIVE UNVERIFIED INFORMATION</u>.

NOTE: Assistance in classification may be obtained from the Shift Chemist.

2. EVENT CLASSIFICATION

2.1 Report the event as classified (NOUE, ALERT, SITE AREA or GENERAL EMERGENCY) in Section 2 of FC-EPF-38.

Attachment 6.9

Page 2 of 3

NOTE: If the involved chemical is not listed, or further information on chemicals is desired refer to SO-G-106, "Hazardous Material Chemical Assessment and Emergency Response Guidelines", the Material Safety Data Sheet, if available, or The North American Emergency Response Guidebook.

NOTE: If the involved chemical is not listed below, refer to the North American Emergency Response Guidebook for guidelines.

- 2.2 If the involved chemical is one of the following, consider it a SMALL HAZARD:
 - Acetylene
 - Amerzine
 - Chemtreat
 - Ethanolamine
 - Diesel Fuel
 - Hydrazine
 - Hydrogen
- 2.3 Use the guide below to classify the event class. The four codes are further defined in the definitions section of this procedure:

CODE	HAZARD POTENTIA	L CONDITIONS
Blue	Small or large	Situation under control - NO offsite threat
Green	Small or large	Situation NOT under control - No immediate offsite threat
Yellow	Large	Situation NOT under control - Onsite protective actions will be needed
Red	Large	Situation NOT under control - Protective actions for neighboring industries and residents needed

EPIP-OSC-2 PAGE 29 OF 29

Attachment 6.9

Page 3 of 3

NOTE: All members of the Co-Op are staffed 24 hours per day except Kelly Ryan and Agro. MACC may not have staff onsite on some weekends and/or holidays.

NOTE: Alternate emergency numbers and routine day to day contact numbers for all Co-Op members and other vital agencies may be found in the Emergency Phone Book under the Blair Industrial Co-Op tab.

NOTE: All Notifications to the Blair Industrial Park Co-Op should be made through the Control Room if possible.

3. NOTIFICATIONS

- 3.1 Obtain the instructions marked "Blair Industrial Park Co-Op Notification" from the Emergency Planning Activation Instructions Booklet.
- 3.2 Direct the Communicator to perform the Blair Industrial Park Co-Op Notifications.
- 3.3 If event is on-going, update the Blair Industrial Park Co-Op members as conditions warrant.

WP8

Distribution Authorized

Fort Calhoun Station Unit No. 1 This procedure does not contain any proprietary information, or such information has been censored. This issue may be released to the public document room. Proprietary information includes personnel names, company telephone numbers, and any information, which could impede emergency response.

EPIP-TSC-1

EMERGENCY PLAN IMPLEMENTING PROCEDURE

Title: ACTIVATION OF THE TECHNICAL SUPPORT CENTER

FC-68 Number: EC 29390

Reason for Change: Clarify instructions on Securing, Placing the TSC HVAC System in the FILTERED MODE, and in the NORMAL MODE. This Change is required due to EC 28898.

Requestor: Mark Reller

Preparer: Mark Reller

ISSUED: 02-04-02 3:00 pm

ACTIVATION OF THE TECHNICAL SUPPORT CENTER

NON-SAFETY RELATED

1. PURPOSE

1.1 This procedure provides a checklist to provide guidance for activation and deactivation of the Technical Support Center (TSC).

2. <u>REFERENCES/COMMITMENT DOCUMENTS</u>

None

3. DEFINITIONS

- 3.1 Activated minimum staffing and basic setup requirements have been attained to allow the TSC to provide limited support to the Control Room.
- 3.2 Augmented A facility is augmented when all augmenting and minimum staffing positions are filled.

4. PREREQUISITES

None

5. PROCEDURE

NOTE: The Site Director or TSC Director is responsible for completion of this procedure. They may assign this task to other members of the TSC staff.

- 5.1 Upon reporting to the TSC, activate the TSC using Attachment 6.1.
- 5.2 Upon event termination, deactivate the TSC per Attachment 6.2.

6. ATTACHMENTS

- 6.1 Checklist for Activation of the TSC
- 6.2 Checklist for Deactivation of the TSC
- 6.3 Activation/Deactivation of the TSC Air and Area Radiation Monitors
- 6.4 Operation of the TSC HVAC System

EPIP-TSC-1 PAGE 2 OF 6

Attachment 6.1 - Checklist For Activation of the TSC Page 1 of 2

NOTE: It is the goal of Omaha Public Power District (OPPD) to activate the TSC within one hour following declaration of an Alert or higher classification. In the event of adverse weather and/or other conditions that may limit or slow response, either manmade or natural, it is understood that staffing time may exceed this goal.

		(\checkmark)	INIT/TIME
1.	Contact the Control Room to determine if there is a toxic gas threat in the vicinity of Fort Calhoun Station.		
	1.1 If YES , secure the TSC HVAC system per Attachment 6.4, Step 3.		
	1.2 If NO , place the TSC HVAC System in the FILTERED MODE per Attachment 6.4, Step 1.		/
2.	Verify the following minimum staffing positions are available.		
	 Site Director Protective Measures Coordinator TSC COP Communicator Reactor Safety Coordinator 		/
3.	Ensure that the volume buttons on both Gai-tronics are turned up.		/
4.	Using the Gai-Tronics, announce the following message:		
	4.1 "Attention all personnelAttention all personnelThis is <u>(Insert name and position)</u> . All personnel deposit their accountability badges in the proper accountability box near their facility.		
	4.2 Repeat the message above.		/
5.	Open all TSC room doors.		/
6.	Post "NO EATING/DRINKING/SMOKING OR CHEWING" signs in the TSC Room 115 and near the entrance door.		/
7.	In Room 118, unlock the aperture card file using the key from the key box, and turn on the aperture card reader/printer.		/
8.	Synchronize TSC clocks with ERF Computer.		/

FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE		EPIP-TSC-1 PAGE 3 OF 6		
Attachment 6.1 (continued)		Page 2 of 2		
	<u>(⁄)</u>	INIT/TIME		
When Steps 2 through 8 are complete, make the following announcement on the TSC PA system:				
This is <u>(insert name and position)</u> the TSC is activated. Command and Control for the emergency is in the <u>name of</u> <u>facility</u> at this time. No eating, drinking, smoking or chewing is allowed in the TSC until further notice.		/		
10. Notify the Control Room, OSC and EOF that the TSC is activated.		/		
11. Verify radiological habitability per EPIP-EOF-11.		/		
12. Initiate operation of the TSC Air Monitor and Area Radiation Monitor per Attachment 6.3.		/		
13. Within one hour of the initial emergency declaration, verify the following augmenting staff are present:				
 Field Teams (2 Technicians, 2 Drivers) I&C/Electrical Systems Engineer Operations Liaison Primary System Engineer 				
14. After one hour determine TSC positions are filled.				
14.1 If any positions are not filled, based on the nature of the emergency determine if that position is required.				
14.2 Request assistance from the TSC staff in contacting additional staff.		/		

-

I

I
Attachment 6.2 - Checklist for Deactivation of the TSC

Upon termination of emergency activities, the following actions should be completed to restore the TSC:

		INIT/TIME
•	Place emergency kits in the Emergency Gear Locker.	/
•	Properly restore all computer systems to their standby mode.	/
٠	Turn off the writeboard system.	/
•	Deactivate the TSC Air Monitor and Area Radiation Monitor per Attachment 6.3.	/
•	Place the TSC HVAC System in the NORMAL MODE per Attachment 6.4, Step 2.	/
•	Remove all posted signs within the TSC.	/
•	Turn in all logs, paperwork, procedures, etc. to the Administrative Logistics Coordinator.	/
•	Turn off the aperture card reader/printer, and relock the aperture card file.	/
•	Restock all Emergency Kits	//
•	Relock all room doors.	/

EPIP-TSC-1 PAGE 5 OF 6

Attachment 6.3 - Activation/Deactivation of the TS	SC Air and Area Radiation Monitors
--	------------------------------------

				<u>(⁄)</u>	INIT/TIME
1.	To a follov	To activate the Air and Area Radiation Monitors, perform the following:			
	1.1	Enter Room 109 (the ERF computer system room).			
	1.2	Plug in and turn on the Area Radiation Monitor as necessary.			
	1.3	Plug in and turn on the PING Monitor as necessary.			
	1.4	Allow the PING to stabilize for several minutes, clearing the initial alarms as necessary.			
	1.5	5 Check both units on a routine basis during the emergency to ensure habitability is being maintained.		•	
	1.6	If either monitor alarms at any time during startup or operation, perform the following:			
		1.6.1	Reset the alarm by pressing the reset/acknowledge button.		
		1.6.2	If alarm resounds, read the affected meter and call a Radiation Protection Technician for further instructions.		
2.	To deactivate the Air and Area Radiation Monitors, perform the following:				
	2.1	 Obtain permission from the Radiological Operations Coordinator to secure this equipment. If permission is granted, unplug both units. 			
	2.2				
	2.3	If permis inform th	sion is not granted, leave equipment operating and le Control Room.		1

FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE				EPIP-TSC-1 PAGE 6 OF 6
		Attachment 6.4 - Operation of the TSC HVAC Syste	m	Page 1 of 1
			<u>(√)</u>	INIT/TIME
1.	Placi	ng the TSC HVAC in the FILTERED MODE.		
	1.1	On panel AI-200A (in TSC Room 109) ensure the Air Handler, VA-107 is ON as indicated by the red light above the VA-107, TSC Ventilation Unit Start/Stop Pushbuttons. If VA-107 is not ON, start VA-107 with the START push button.		
	1.2	Ensure the Charcoal Filter Fan, VA-109, Charcoal Filter Fan Selector Switch, is in AUTO.		
	1.3	Place the TSC Ventilation Charcoal Filtered Air Toggle Switch is in the ON position.	-	//
2.	Placing the TSC HVAC in the NORMAL MODE.			
	2.1	On panel AI-200A (in TSC Room 109), place the TSC Ventilation Charcoal Filtered Air Toggle Switch in OFF.		
	2.2	Verify VA-109, Charcoal Filter Fan Selector Switch is in AUTO and VA-107 in ON as indicated by red light above VA-107, TSC Ventilation Unit Start/Stop Pushbuttons.		/
3.	Securing the TSC HVAC System.			
	3.1	On panel AI-200A (in TSC Room 109), ensure or place the TSC Ventilation Charcoal Filtered Air Toggle Switch in the OFF position.		
	3.2	Place the Air Handler, VA-107 in OFF by pushing the VA-107, TSC Ventilation Unit Stop pushbutton AND verify the red light above the VA-107, TSC Ventilation Unit Start/Stop pushbuttons is off.		

	FORM EP-1
Rev.	6 (04/29/99)

OMAHA PUBLIC POWER DISTRICT

Confirmation of Transmittal for Emergency Planning Documents/Information

Radiological Emergency Response Plan (RERP)	Plan Emergency Planning 9 Procedures Forms (EPF)			
Emergency Planning Department Manual (EPDM)	Other Emergency Planning Document(s)/ Information			
Transmitted to:				
Name: Document Control Desk Copy No: Plant Support Branch Secretary Copy No: Plant Support Branch Secretary Copy No:	165 Date: 154 155			
The following document(s) / information is forwarded for your manual:REMOVE SECTIONINSERT SECTIONEPIP Index page 1 of 2 issued 12/07/01EPIP Index page 1 of 2 issued 01/23/02EPIP-EOF-6 R31 issued 07/02/01EPIP-EOF-6 R32 issued 01/23/02				
Summary of Changes:				
EPIP-EOF-6 was revised to clarify instructions on how to use the Imminent Release function in EAGLE and a note was added instructing the user to use a stand alone fax when the network is slow or unavailable.				
	and the			
	Supervisor - Emergency Planning			
I hereby acknowledge receipt of the above documents/information and have included them in my assigned manuals.				
Signature:	Date:			
Please sign above and return by <u>03/22/02</u> to:	Karma Boone Fort Calhoun Station, FC-2-1 Omaha Public Power District 444 South 16 th Street Mall Omaha, NE 68102-2247			
NOTE: If the document(s)/information contained in this transmittal is no longer requested or needed by the recipient, or has been transferred to another individuals, please fill out the information below.				
Document(s)/Information No Longer Requested/Needed Document(s)/Information Transferred to:				
Name: Mailing Addre	ss:			
	5°10.000			

Fort Calhoun Station Pag					
EMERGENCY PLAN IMPLEMENTING PROCEDURE INDEX					
- EPIP-OSC-1	Emergency Classification	R34 09-14-00			
EPIP-OSC-2	Command and Control Position Actions/Notifications	R39 05-17-01			
EPIP-OSC-9	Emergency Team Briefings	R7 12-09-99			
EPIP-OSC-15	Communicator Actions	R22 10-24-00			
EPIP-OSC-21	Activation of the Operations Support Center	R11 11-27-01			
EPIP-TSC-1	Activation of the Technical Support Center	R21 08-24-00a			
EPIP-TSC-2	Catastrophic Flooding Preparations DELETED (05-09-95) REINSTATED	(R0 03-22-95)			
		R2 02-06-96			
EPIP-TSC-8	Core Damage Assessment	R14 01-19-01			
EPIP-EOF-1	Activation of the Emergency Operations Facility	R12 08-24-00a			
EPIP-EOF-3	Offsite Monitoring	R17 12-07-01			
EPIP-EOF-6	Dose Assessment	R32 01-23-02			
EPIP-EOF-7	Protective Action Guidelines	R13 10-31-00b			
EPIP-EOF-10	Warehouse Personnel Decontamination Station Operation	R10 01-13-00a			
EPIP-EOF-11	Dosimetry Records, Exposure Extensions and Habitability	R18 09-18-97b			
EPIP-EOF-19	Recovery Actions	R7 09-30-98			
EPIP-EOF-21	Potassium Iodide Issuance	R4 11-07-00			
EPIP-EOF-23	Emergency Response Message System	R5 10-12-99			
EPIP-EOF-24	EOF Backup Alert Notification System Activation	R3 09-09-99			
EPIP-RR-11	Technical Support Center Director Actions	R14 02-29-00			
EPIP-RR-13	Reactor Safety Coordinator Actions	R14 12-09-99			
NT		01/23/02 7:26 AM			

WP8

Distribution Authorized

Fort Calhoun Station Unit No. 1 This procedure does not contain any proprietary information, or such information has been censored. This issue may be released to the public document room. Proprietary information includes personnel names, company telephone numbers, and any information, which could impede emergency response.

.

EPIP-EOF-6

EMERGENCY PLAN IMPLEMENTING PROCEDURE

Title: DOSE ASSESSMENT

FC-68 Number: EC 28905

Reason for Change: Add note telling when to use fax. Clarify instructions on how to use imminent release. (CR 200103341)

Requestor: M. Reller

Preparer: M. Reller

DOSE ASSESSMENT

NON-SAFETY RELATED

1. PURPOSE

1.1 This procedure provides instructions for performing dose assessment for Ventilation Stack releases, Main Steam Line/Condenser Off-Gas releases, Containment leakage and Radwaste Building releases. It also provides instruction for estimating unmonitored release rates, and performing liquid release assessment.

2. REFERENCES/COMMITMENT DOCUMENTS

- 2.1 EPIP-EOF-7, Protective Action Guidelines
- 2.2 OI-ERFCS-1, Operation of the Emergency Response Facilities Computer System
- 2.3 CH-SMP-PA-0005, Monitoring of Gaseous Effluent Releases Via the Auxiliary Building Ventilation Duct Pathway
- 2.4 Technical Data Book TDB-IV.8, Area Monitor Setpoints
- 2.5 User's Guide for EAGLE 5.00
 - 2.6 Engineering Analysis EA-FC-90-038, Manual Dose Assessment
 - 2.7 Engineering Analysis EA-FC-90-105, Ingestion Pathway
 - 2.8 Engineering Analysis EA-FC-90-035, EAGLE Radiological Parameters
 - 2.9 Engineering Analysis EA-FC-93-066, EAGLE 4.0 Dose Calculation Methodology
 - 2.10 Calculation FC-06179, TEDE and CDE conversion factors for offsite dose calculation
 - 2.11 Commitments (other than Ongoing)
 - AR 10029, IER-89-24
 - AR 13302, IER-92-20
 - AR 17061, LIC-95-0049/LIC-95-0230
 - 2.12 Protective Measure Basis Document, CHP-00-038, September 28, 2000

3. **DEFINITIONS**

- 3.1 DELTA T (Δ T) TEMPERATURE the temperature difference between 10 and 60 meters, in units of centigrade. The value displayed on the ERFCS equates to a 100 Δ T[(T @ 60m T @ 10m) x 2].
- 3.2 DURATION OF RELEASE the time in hours the release is expected to continue.
- 3.3 DOSE the amount of ionizing radiation that results from an amount of energy being absorbed in the human body, in units of Rem.
- 3.4 DOSE RATE Dose per unit time, in units of Rem/hour.
- 3.5 ERFCS Emergency Response Facility Computer System.
- 3.6 IMMINENT RELEASE An impending release of the radioactive gas in Containment.
- 3.7 CDE Committed Dose Equivalent.
- 3.8 TEDE Total Effective Dose Equivalent.
- 3.9 COMMAND AND CONTROL POSITION: The position that is currently in charge of the emergency response, either the Shift Supervisor, Control Room Coordinator, Site Director or Emergency Director.
- 3.10 RELEASE RATE (Q) the emission rate of the effluent in units of Curies per second from the release point.

4. PREREQUISITES

4.1 A radioactive release is suspected, imminent, or known to be in progress.

5. PROCEDURE

NOTE: If on-site meteorological data is not available, contact the National Weather Service (number in the Emergency Phone Book), and request wind speed and direction. For night time (sunset to sunrise) with no precipitation, use a ΔT of +2.0 and a stability class F. For all other conditions, use a ΔT of -1.0 and a stability class D.

- 5.1 To perform dose assessments in the Control Room, use Attachment 6.1.
- 5.2 To perform dose assessments in the TSC, use Attachment 6.2.
- 5.3 To perform dose assessments in the EOF, use Attachment 6.3.

- 5.4 When needed, perform dose assessments and updates to the states at least every 60 minutes. It is the goal of the Fort Calhoun Station to attempt to provide assessments and updates at 15 minute intervals. (AR 13302)
- 5.5 Retain all documentation (logs, assessments, etc.) generated or used during the emergency. At the termination, deliver all documentation to the TSC Administrative Logistics Coordinator in the TSC, or the EOF Administrative Logistics Manager in the EOF.

6. ATTACHMENTS

- 6.1 Dose Assessment in the Control Room
- 6.2 Dose Assessment in the TSC
- 6.3 Dose Assessment in the EOF
- 6.4 Computerized Dose Assessment
- 6.5 Unmonitored Release Assessments

Attachment 6.1 - Dose Assessment In The Control Room Page 1 of 4

- 1. Sign in on the Accountability Roster and put on the Personnel Identification Badge.
- 2. Using information from the Control Room as needed and AI-33A, B and C or ERFCS pages 197, 360 and 361 evaluate and determine the release pathways for dose assessment as follows:

NOTE: The sample Control Module for RM-052 must be in the VENT position (monitoring the Auxiliary Building Vent Stack) in order to be used for dose assessment.

NOTE: RM-062/063 are the preferred process monitors to be used for dose assessment on the Auxiliary Building Vent Stack. RM-062 is normally in-service and RM-063 is normally in Standby. When RM-062 count rate exceeds 5.0 E+06 cpm or if RM-063 exceeds 5.0 E-3 μ C/cc; sample flow will automatically shift from RM-062 to RM-063 and the alarm "RM-063 AUX BLDG VENT STACK IN SERVICE" will annunciate on AI-33C. When RM-063 radiation level drops below 5.0 E-3 μ C/cc, sample flow will shift to RM-062 and RM-063 will shift to Standby.

- 2.1 Evaluate the Auxiliary Building Vent Stack release pathway using RM-052, RM-062 and RM-063.
 - 2.1.1 If RM-052 or RM-062 is in High Alarm, determine the source of the release to the Auxiliary Building Vent Stack.
 - If the source of the release can be determined to be only from Condenser Off-gas (i.e. Off-gas is aligned to Auxiliary Building Vent Stack and there are no other release sources to the Auxiliary Building Vent Stack), then use an Iodine/Noble Gas Ratio of 0.003 for the Auxiliary Building Vent Stack release.
 - Otherwise, use the default Iodine/Noble Gas Ratio of 0.02.
- 2.2 Evaluate the Condenser/Main Steam release pathway using RM-057, RM-064 and whether or not a primary to secondary leak has been confirmed.
 - 2.2.1 If RM-057 is in High Alarm or if a primary to secondary leak is confirmed, request that RM-064 be placed in service on the affected Main Steam Line.
 - 2.2.2 If RM-057 is in High Alarm or if a primary to secondary leak is confirmed and if Condenser Off-gas is being vented directly to the atmosphere via the Turbine Building Roof, request that Condenser Off-gas be aligned to the Auxiliary Building Vent Stack.

Attachment 6.1 (continued)

Page 2 of 4

- 2.2.3 If RM-057 is in High Alarm or if a primary to secondary leak is confirmed and Condenser Off-gas is being vented directly to the atmosphere via the Turbine Building Roof, perform dose assessment using Condenser Off-gas a release pathway, a flow rate of 340 scfm, and use an Iodine/Noble Gas Ratio of 0.003.
- 2.2.4 If a primary to secondary leak is confirmed and RM-057 is not operable or is over ranged, and Condenser Off-gas is not aligned to the Auxiliary Building Vent Stack, this is an unmonitored release.
- 2.2.5 If there is a confirmed primary to secondary leak, and FW-10 is receiving steam from the affected Steam Generator, or the atmospheric Steam Dump Valve HCV-1040 is OPEN or a Steam Safety is lifting on the affected side, and RM-064 count rate is above the back ground count rate as listed in TDB-IV.7, use an Iodine/Noble Gas Ratio of 0.003.
- 2.2.6 If there is a confirmed primary to secondary leak, and FW-10 is receiving steam from the affected Steam Generator, or the atmospheric Steam Dump Valve HCV-1040 is OPEN or a Steam Safety is lifting on the affected side, and RM-064 count rate is less than or equal to the background count rate as listed in TDB-IV.7, this is unmonitored release.
- 2.3 Evaluate the Containment Leakage release pathway using Containment Area Monitors.

NOTE: If containment leakage is suspected to be greater than designed Containment leakage of 1.5 scfm, and the leakage is from the Containment to the stack or from the Containment to Controlled Areas of the Auxiliary Building to the Auxiliary Building Vent Stack, consideration may be given not to count the release twice if dose assessment will be performed from the Auxiliary Building Vent Stack.

- 2.3.1 If Containment Area Monitors RM-070 through RM-075 are in High Alarm or RM-091A and B read 1.0 R/hr or higher, perform dose assessment using Containment leakage as a release pathway.
- 2.3.2 **IF** any area monitors indicate > 1000 times the background listed in TDB-IV.8, **THEN** inform the Command and Control position for classification information.
- 2.4 Evaluate the Radwaste Building Stack as a release pathway using RM-043
 - 2.4.1 If RM-043 is in High Alarm, perform dose assessment using the Radiological Waste Building Vent Stack as a release pathway.

Attachment 6.1 (continued)

Page 3 of 4

- 2.5 Evaluate the liquid release pathways as follows:
 - 2.5.1 If RM-055, Overboard Discharge Monitor is reading greater than the High Alarm Setpoint as listed in TDB-IV.7 and the overboard discharge flow is not isolated, then a liquid release assessment must be performed.
 - 2.5.2 If either RM-054A or RM-054B Steam Generator Blowdown Monitors are reading greater than the High Alarm Setpoint as listed in TDB-IV.7 and blowdown flow is not isolated from the Steam Generator(s) with a primary to secondary leak, then a liquid release assessment must be performed.
- 2.6 Determine if there are any potentially unmonitored releases.
- 3. Perform dose assessment for monitored release pathways using Attachment 6.4 and for unmonitored release pathways per Attachment 6.5.
- 4. Review/Distribution

NOTE: The PAR information generated by EAGLE is for OPPD decision maker's information only. Actual PARs are determined by the Command and Control position. The PAR Information Worksheet should be one of the tools used for guidance in determining PARs.

- 4.1 If Command and Control is in the Control Room
 - 4.1.1 Have the Command and Control position review the PAR Information Worksheet and the Update Report to Offsite Authorities.

NOTE: If a dose assessment results in a change in classification or a PAR change, ensure that the states are notified by the CR Communicator using an approved Emergency Notification form (FC-1188) prior to faxing the Update Report to Offsite Authorities.

NOTE: If the Network is down or faxing is slow consider using the stand-alone fax machine.

- 4.1.2 If the Command and Control position approves the assessment:
 - Click the "Fax/Distribute" button at the bottom of the Release Information Screen
 - Select the proper distribution list(s)
 - Click "OK"

Attachment 6.1 (continued)

Page 4 of 4

4.2 If Command and Control is in the TSC:

- 4.2.1 Fax unsigned PAR Information Worksheet and Update Report to State and County Authorities to the TSC.
- 4.2.2 Inform the TSC Protective Measures Coordinator of the transmittal.
- 4.2.3 Record transmittal time.

Attachment 6.2 - Dose Assessment In The Technical Support Center Page 1 of 3

NOTE: Dose assessment will only be performed in the TSC in the event that the EAGLE equipment in the Control Room is unavailable or inoperable. The TSC EAGLE equipment may also be used as a backup to the equipment located at the EOF.

- 1. Sign in on the Accountability Roster.
- 2. Inform the Protective Measures Coordinator that you will be performing dose assessment in the TSC.
- 3. Using information from the Control Room as needed and AI-33A, B and C or ERFCS pages 197, 360 and 361 evaluate and determine the release pathways for dose assessment as follows:

NOTE: The sample Control Module for RM-052 must be in the VENT position (monitoring the Auxiliary Building Vent Stack) in order to be used for dose assessment.

NOTE: RM-062/063 are the preferred process monitors to be used for dose assessment on the Auxiliary Building Vent Stack. RM-062 is normally in-service and RM-063 is normally in Standby. When RM-062 count rate exceeds 5.0 E+06 cpm or if RM-063 exceeds 5.0 E-3 μ C/cc; sample flow will automatically shift from RM-062 to RM-063 and the alarm "RM-063 AUX BLDG VENT STACK IN SERVICE" will annunciate on AI-33C. When RM-063 radiation level drops below 5.0 E-3 μ C/cc, sample flow will shift to RM-062 and RM-063 will shift to Standby.

- 3.1 Evaluate the Auxiliary Building Vent Stack release pathway using RM-052, RM-062 and RM-063.
 - 3.1.1 If RM-052 or RM-062 is in High Alarm, determine the source of the release to the Auxiliary Building Vent Stack.
 - IF the source of the release can be determined to be only from Condenser Off-gas (i.e. Off-gas is aligned to Auxiliary Building Vent Stack and there are no other release sources to the Auxiliary Building Vent Stack), THEN use an Iodine/Noble Gas Ratio of 0.003 for the Auxiliary Building Vent Stack release.
 - Otherwise, use the default lodine/Noble Gas Ratio of 0.02.
- 3.2 Evaluate the Condenser/Main Steam release pathway using RM-057, RM-064 and whether or not a primary to secondary leak has been confirmed.
 - 3.2.1 If RM-057 is in High Alarm or if a primary to secondary leak is confirmed, request that RM-064 be placed in service on the affected Main Steam Line.

EPIP-EOF-6 PAGE 9 OF 31

Attachment 6.2 (continued)

Page 2 of 3

- 3.2.2 If RM-057 is in High Alarm or if a primary to secondary leak is confirmed and if Condenser Off-gas is being vented directly to the atmosphere via the Turbine Building Roof, request that Condenser Off-gas be aligned to the Auxiliary Building Vent Stack.
- 3.2.3 If RM-057 is in High Alarm or if a primary to secondary leak is confirmed and Condenser Off-gas is being vented directly to the atmosphere via the Turbine Building Roof, perform dose assessment using Condenser Off-gas a release pathway, a flow rate of 340 scfm, and use an Iodine/Noble Gas Ratio of 0.003.
- 3.2.4 If a primary to secondary leak is confirmed and RM-057 is not operable or is over ranged, and Condenser Off-gas is not aligned to the Auxiliary Building Vent Stack, this is an unmonitored release.
- 3.2.5 If there is a confirmed primary to secondary leak, and FW-10 is receiving steam from the affected Steam Generator, or the atmospheric Steam Dump Valve HCV-1040 is OPEN or a Steam Safety is lifting on the affected side, and RM-064 count rate is above the back ground count rate as listed in TDB-IV.7, use an Iodine/Noble Gas Ratio of 0.003.
- 3.2.6 If there is a confirmed primary to secondary leak, and FW-10 is receiving steam from the affected Steam Generator, or the atmospheric Steam Dump Valve HCV-1040 is OPEN or a Steam Safety is lifting on the affected side, and RM-064 count rate is less than or equal to the background count rate as listed in TDB-IV.7, this is unmonitored release.
- 3.3 Evaluate the Containment Leakage release pathway using Containment Area Monitors

NOTE: If containment leakage is suspected to be greater than designed Containment leakage of 1.5 scfm, and the leakage is from the Containment to the stack or from the Containment to Controlled Areas of the Auxiliary Building to the Auxiliary Building Vent Stack, consideration may be given not to count the release twice if dose assessment will be performed from the Auxiliary Building Vent Stack.

- 3.3.1 If Containment Area Monitors RM-070 through RM-075 are in High Alarm or RM-091A and B read 1.0 R/hr or higher, perform dose assessment using Containment leakage as a release pathway.
- 3.3.2 **IF** any area monitors indicate > 1000 times the background listed in TDB-IV.8, **THEN** inform the Command and Control position for classification information.

Attachment 6.2 (continued)

Page 3 of 3

- 3.4 Evaluate the Radwaste Building Stack as a release pathway using RM-043
 - 3.4.1 If RM-043 is in High Alarm, perform dose assessment using the Radiological Waste Building Vent Stack as a release pathway.
- 3.5 Evaluate the liquid release pathways as follows:
 - 3.5.1 IF RM-055, Overboard Discharge Monitor is reading greater than the High Alarm Setpoint as listed in TDB-IV.7 and the overboard discharge flow is not isolated, then a liquid release assessment must be performed.
 - 3.5.2 If either RM-054A or RM-054B Steam Generator Blowdown Monitors are reading greater than the High Alarm Setpoint as listed in TDB-IV.7 and blowdown flow is not isolated from the Steam Generator(s) with a primary to secondary leak, then a liquid release assessment must be performed.
- 3.6 Determine if there are any potentially unmonitored releases.
- 4. Perform dose assessment for monitored release pathways using Attachment 6.4 and for unmonitored release pathways per Attachment 6.5.
- 5. Review

NOTE: The PAR information generated by EAGLE is for OPPD decision maker's information only. Actual PARs are determined by the Command and Control position. The PAR Information Worksheet should be one of the tools used for guidance in determining PARs.

- 5.1 Obtain a printout of the PAR Information Worksheet and the Update Report to Offsite Authorities.
- 5.2 Forward printouts to the Protective Measures Coordinator.
- 6. Provide detailed briefing to oncoming shift relief of emergency conditions and dose assessment status.

Attachment 6.3 - Dose Assessment in the Emergency Operation Facility

Page 1 of 4

- 1. **IF** dose assessments are being performed in the Control Room, **THEN** contact the technician in the Control Room performing dose assessment and review all previous assessments using the fax copies.
- IF dose assessments are being performed in the TSC, THEN contact the technician performing dose assessment in the TSC and review all previous assessments using the fax copies.
- 3. Standby to transfer dose assessment from the Control Room (or TSC) to the EOF, as directed by the Protective Measures Manager.
- 4. When directed to take over dose assessment, inform the technician in the Control Room (or TSC) of your actions.
- 5. Using information from the Control Room as needed and AI-33A, B and C or ERFCS pages 197, 360 and 361 evaluate and determine the release pathways for dose assessment as follows:

NOTE: The sample Control Module for RM-052 must be in the VENT position (monitoring the Auxiliary Building Vent Stack) in order to be used for dose assessment.

NOTE: RM-062/063 are the preferred process monitors to be used for dose assessment on the Auxiliary Building Vent Stack. RM-062 is normally in-service and RM-063 is normally in Standby. When RM-062 count rate exceeds 5.0 E+06 cpm or if RM-063 exceeds 5.0 E-3 μ C/cc; sample flow will automatically shift from RM-062 to RM-063 and the alarm "RM-063 AUX BLDG VENT STACK IN SERVICE" will annunciate on AI-33C. When RM-063 radiation level drops below 5.0 E-3 μ C/cc, sample flow will shift to RM-062 and RM-063 will shift to Standby.

- 5.1 Evaluate the Auxiliary Building Vent Stack release pathway using RM-052, RM-062 and RM-063.
 - 5.1.1 If RM-052 or RM-062 is in High Alarm, determine the source of the release to the Auxiliary Building Vent Stack.
 - IF the source of the release can be determined to be only from Condenser Off-gas (i.e. Off-gas is aligned to Auxiliary Building Vent Stack and there are no other release sources to the Auxiliary Building Vent Stack), THEN use an Iodine/Noble Gas Ratio of 0.003 for the Auxiliary Building Vent Stack release.
 - Otherwise, use the default lodine/Noble Gas Ratio of 0.02.

Attachment 6.3 (continued)

Page 2 of 4

- 5.2 Evaluate the Condenser/Main Steam release pathway using RM-057, RM-064 and whether or not a primary to secondary leak has been confirmed.
 - 5.2.1 If RM-057 is in High Alarm or if a primary to secondary leak is confirmed, request that RM-064 be placed in service on the affected Main Steam Line.
 - 5.2.2 If RM-057 is in High Alarm or if a primary to secondary leak is confirmed and if Condenser Off-gas is being vented directly to the atmosphere via the Turbine Building Roof, request that Condenser Off-gas be aligned to the Auxiliary Building Vent Stack.
 - 5.2.3 If RM-057 is in High Alarm or if a primary to secondary leak is confirmed and Condenser Off-gas is being vented directly to the atmosphere via the Turbine Building Roof, perform dose assessment using Condenser Off-gas a release pathway, a flow rate of 340 scfm, and use an Iodine/Noble Gas Ratio of 0.003.
 - 5.2.4 If a primary to secondary leak is confirmed and RM-057 is not operable or is over ranged, and Condenser Off-gas is not aligned to the Auxiliary Building Vent Stack, this is an unmonitored release.
 - 5.2.5 If there is a confirmed primary to secondary leak, and FW-10 is receiving steam from the affected Steam Generator, or the atmospheric Steam Dump Valve HCV-1040 is OPEN or a Steam Safety is lifting on the affected side, and RM-064 count rate is above the back ground count rate as listed in TDB-IV.7, use an Iodine/Noble Gas Ratio of 0.003.
 - 5.2.6 If there is a confirmed primary to secondary leak, and FW-10 is receiving steam from the affected Steam Generator, or the atmospheric Steam Dump Valve HCV-1040 is OPEN or a Steam Safety is lifting on the affected side, and RM-064 count rate is less than or equal to the background count rate as listed in TDB-IV.7, this is unmonitored release.

Attachment 6.3 (continued)

Page 3 of 4

5.3 Evaluate the Containment Leakage release pathway using Containment Area Monitors

NOTE: If containment leakage is suspected to be greater than designed Containment leakage of 1.5 scfm, and the leakage is from the Containment to the stack or from the Containment to Controlled Areas of the Auxiliary Building to the Auxiliary Building Vent Stack, consideration may be given not to count the release twice if dose assessment will be performed from the Auxiliary Building Vent Stack.

- 5.3.1 If Containment Area Monitors RM-070 through RM-075 are in High Alarm or RM-091A and B read 1.0 R/hr or higher, perform dose assessment using Containment leakage as a release pathway.
- 5.3.2 **IF** any area monitors indicate > 1000 times the background listed in TDB-IV.8, **THEN** inform the Command and Control position for classification information.
- 5.4 Evaluate the Radwaste Building Stack as a release pathway using RM-043
 - 5.4.1 If RM-043 is in High Alarm, perform dose assessment using the Radiological Waste Building Vent Stack as a release pathway.
- 5.5 Evaluate the liquid release pathways as follows:
 - 5.5.1 If RM-055, Overboard Discharge Monitor is reading greater than the High Alarm Setpoint as listed in TDB-IV.7 and the overboard discharge flow is not isolated, then a liquid release assessment must be performed.
 - 5.5.2 If either RM-054A or RM-054B Steam Generator Blowdown Monitors are reading greater than the High Alarm Setpoint as listed in TDB-IV.7 and blowdown flow is not isolated from the Steam Generator(s) with a primary to secondary leak, then a liquid release assessment must be performed.
- 5.6 Determine if there are any potentially unmonitored releases.
- 6. Perform dose assessment for monitored release pathways using Attachment 6.4 and for unmonitored release pathways per Attachment 6.5.

EPIP-EOF-6 PAGE 14 OF 31

4

Attachment 6.3 (continued)

Page 4 of 4

7. Review

NOTE: The PAR information generated by EAGLE is for OPPD decision maker's information only. Actual PARs are determined by the Command and Control position. The PAR Information Worksheet should be one of the tools used for guidance in determining PARs.

- 7.1 Obtain a printout of the PAR Information Worksheet and the Update report to Offsite Authorities.
- 7.2 Forward printouts to the Dose Assessment Coordinator.
- 8. Provide detailed briefing to oncoming shift relief of emergency conditions and dose assessment status.

Attachment 6.4 - Computerized Dose Assessment

Page 1 of 8

- 1. Logging on to EAGLE
 - 1.1 Is terminal on, with EAGLE Main Menu page showing?
 - 1.1.1 YES Select operational mode (emergency, drill or test), proceed to Step 1.2.
 - NO Re-boot the system, user name for each terminal is on the monitor, password for all machines is "eagle".

NOTE: If another terminal has network "Control" and is performing dose assessment, Coordinate the network synchronization accordingly. At the EOF work with the EOF Dose Assessment Coordinator to insure a smooth transfer of dose assessment responsibilities.

- 1.2 Verifying network status and control.
 - 1.2.1 Click "View Network Status" a window will open showing the status of each EAGLE network terminal.
 - 1.2.2 To take control of the network (with someone at other PC, preferred method):
 - Have person in control click the "Release Control" button
 - Click the "Take Control"
 - Click "Exit"
 - 1.2.3 To take control when no one is at the other PC:
 - Click "Override Control"
 - Click "Refresh"
 - Click "Exit"
 - 1.2.4 The blue lettering at the top of the EAGLE Main Menu screen should say "Network Mode/Control".

EPIP-EOF-6 PAGE 16 OF 31

Attachment 6.4 (continued)

Page 2 of 8

CAUTION

IF process monitor reading increases by 50% while performing an assessment, or the Command and Control position requests an immediate assessment, **THEN** complete the current assessment and immediately start another. **[AR 10029]**

2. Performing Dose Assessment

NOTE: While EAGLE does have graphic capabilities, typically this function will only be performed at the EOF.

- 2.1 Click "Atmospheric Diffusion and Dose Calculations" button.
- 2.2 From the Change Plume Segment Number screen:

NOTE: It is possible to redo a plume by selecting that number at this point. All data for that plume and other sequential plumes will be lost.

- 2.2.1 Enter "1" to start new plume series or the next sequential number to continue the current series.
- 2.2.2 Click "OK".
- 2.3 From the EAGLE Screen select:
 - 2.3.1 Click "Control Options" to select:
 - Run Mode (Normal Dose Projection, is the default)
 - Release Duration (4 hours is the default)
 - 2.3.2 Click "OK".
 - 2.3.3 If desired, click "Current Segment Time and Date" to gain another opportunity to change the plume number.

Attachment 6.4 (continued)

Page 3 of 8

NOTE: There are four release points listed at this point. To simplify this procedure, guidance will only be given for the Auxiliary Building Stack. The method for doing other release paths is similar. Reference the EAGLE Help menu or the EAGLE 5.0 User Manual if you need assistance with these pathways.

NOTE: For Condenser Off-gas releases, use a condenser ejector flow-rate of 340 cfm.

NOTE: For Condenser Main Steam releases, use an Iodine/Noble Gas Ratio of 0.003.

- 2.3.4 Click "Aux Bldg Stk" or appropriate button to enter release data:
 - Select the appropriate option (the method described here will use radiation monitor data)
 - Select the appropriate Rad Monitor
 - Enter the current rad monitor value, click accept
 - Enter the current Auxiliary Building Vent Stack flow (default is 72500), click "OK"
 - Click "Change Iodine/Noble Gas Ratio", if needed, enter desired value (default is 2 e-2), click "Accept;
 - If properly entered click "OK"
 - Click "Return To Dose Calcs"
- 2.3.5 Repeat Step 2.3.4 for each release path.
- 2.3.6 Click "Change Met Parameters"

EPIP-EOF-6 PAGE 18 OF 31

Attachment 6.4 (continued)

Page 4 of 8

NOTE: For early dose assessments use the defaults for Atmospheric Mixing Conditions and Atmospheric Stability Class Method. The Protective Measures Group in the EOF should review weather conditions and adjust assessments accordingly once the EOF has assumed command and control and dose assessment.

- Select the appropriate Atmospheric Mixing Condition (Unlimited Mixing Conditions is Default), enter the Mixing Height in meters.
- Select the appropriate Atmospheric Stability Class (Delta T Method is default). If you chose other than the default enter Sigma Theta in degrees Celsius.

NOTE: Use the most positive Delta-T and the slowest wind speed.

- Enter wind speed and direction, the ambient temperature and the appropriate Delta-T in the spaces provided.
- Once data is properly entered, click "OK"
- 2.4 Calculation
 - 2.4.1 From the EAGLE screen click "Calculate". A red box will appear confirming the plume number which is being calculated.

NOTE: When EAGLE is done calculating the "Output Menu" box will be operational.

- 2.5 Viewing Calculated Results
 - 2.5.1 Click "Output Menu"

Attachment 6.4 (continued)

Page 5 of 8

- 2.5.2 From the "EAGLE Output Menu" screen click on "Release/Dose Assessment Information"
 - The "Data Input" sub-page will appear allowing you to verify that the correct data was used for calculations (Click on the "Recommendations" sub-page to verify rad monitor inputs and flows)
 - Click on the "Projections" sub-page to get EAGLE Calculated results in TEDE and CDE at the Site Boundary, 2 miles, 5 miles and 10 miles. (any "Projected Integrated Dose (REM)) that require protective actions per EPIP-EOF-7 will be highlighted in red)
 - Click on the "Recommendation" sub-page to view EAGLE recommended Protective Action Recommendations (PARs)

2.6 Printing

- 2.6.1 Click "Distribute"
- 2.6.2 Click "Print" after it is highlighted

NOTE: A window will open and ask a "Dose Assessment Report", a PARs Worksheet" or "Both".

- 2.6.3 Click the option you prefer (normally both).
- 2.6.4 Go to the proper attachment in this procedure for your facility for distribution and approval guidance.
- 2.7 Follow-up Actions
 - 2.7.1 To go to the next plume segment
 - Click "Return to Output Menu"
 - From the "EAGLE Output Menu" screen click "Go To Next Plume Segment"
 - Click "Run Next Segment"
 - Go to Step 2.3 and follow guidance as needed to change inputs, as conditions require

Attachment 6.4 (continued)

Page 6 of 8

- 3. Imminent Release Assessment
 - 3.1 Entering data
 - 3.1.1 From the main menu click "Atmospheric Diffusion Assessment and Dose Calculations".
 - 3.1.2 At the Plume Segment Number screen:
 - Enter the appropriate plume number
 - Click "OK"
 - 3.1.3 At the EAGLE Screen select Control Options:
 - Select "Imminent Release Option"
 - Click "OK"
 - 3.1.4 At the Containment Imminent Release Screen, select:
 - Change Release Time; to change the time until release
 - Change Containment Flow; to change Containment Pressure
 - Change Radiological Data; to enter data from rad monitors or isotopes
 - Hours after accident
 - Click "OK"
 - 3.1.5 Click "Calculate Initial Release Rates", to get "Projected Release Rates" in Ci/sec.

Attachment 6.4 (continued)

Page 7 of 8

- 3.1.6 Click Perform Straight-line Gaussian Projection:
 - At the prompt select the release duration, click "OK"
 - Enter the meteorological information, click "OK"
 - The Plume Centerline Values Based on Straight-line Gaussian Diffusion Model will be displayed. Click "ok"
 - At the Imminent Release screen, click "Exit"
 - At the Dose Calculation screen the Straight Line Gaussian numbers calculated for the Imminent Release with a decayed source term will be displayed for Containment Leakage.
 - Click the "Change Met Parameters" button
 - The "Change Met Parameters" screen will appear with the values used for the Imminent Release Calculation
 - Click "ok" to accept or change as desired.
 - You may now calculate plumes based on the Imminent Release parameters
- 3.1.7 To return EAGLE to the default spectrum after doing an Imminent Release Calculation
 - Click "Contamn Leak"
 - From the Change Release Rate Screen
 - Click "No Release"
 - Click "Change Isotopic Spectrum"
 - Click "Reset All To Default Spectrum"
 - Click "OK"
 - You may now enter data based on the Default Spectrum.

Attachment 6.4 (continued)

Page 8 of 8

4. Liquid Release Assessment

- 4.1 Entering Data
 - 4.1.1 From the Main EAGLE Menu Select "Tabular Displays of Dose Calculations".
 - 4.1.2 From that menu select the "Liquid Effluent Isotopic Activity Display".
 - 4.1.3 At the "Projected Isotopic Activity at MUD Intake Structure Screen" enter:
 - Liquid flow rate (available from the Control Room)
 - River flow rate
 - The isotopic activity (obtain from Chemistry)
 - Click "Calculate Projected Activity" button
 - 4.1.4 Hard copies of all EAGLE screens may be made by
 - With Microsoft Word open and minimized and the EAGLE window active
 - Simultaneously hit the "Alt" and "Print Screen" buttons
 - Maximize Microsoft Word
 - Click "Edit"
 - Click "Paste"
 - 4.1.5 If the results exceed the EPA limits ensure that Command and Control position reports results to:
 - MUD dispatcher
 - Nebraska Emergency Management Agency

5. Errors

- 5.1 If an error message should appear:
 - 5.1.1 Follow the on screen instructions.
 - 5.1.2 If errors cannot be corrected, or other problems arise, reboot the system.
 - 5.1.3 If the problem is still not corrected, perform dose assessment on another EAGLE terminal.
 - 5.1.4 If printer fails, manually record dose assessment results on a FC-1188 form.
- 6. Graphic and Tabular displays and further guidance on dose assessment are explained in the EAGLE 5.0 User's Guide and the EAGLE help menu.

EPIP-EOF-6 PAGE 23 OF 31

Attachment 6.5 - Determining Unmonitored Release Rates Page 1 of 9

NOTE: For determining projected release rates from the Ventilation Stack when RM-062/52 and 63 are off-scale/not available, refer to CH-SMP-PA-0005.

NOTE: For determining projected release rates from the Main Steam/Condenser Off-gas system when RM-057/64 are off-scale/not available, use Section 1

NOTE: For determining projected release rates from Containment when RM-091A/B and RM-070 through RM-075 are off-scale/not available, use Section 2.

NOTE: For determining actual release rates using Field Team data, use Section 3.

- 1. For unmonitored releases via Condenser Off-gas/Main Steam System:
 - 1.1 If RM-057 is off-scale or is not operable, and Condenser Off-gas is vented to the atmosphere via the Turbine Building Roof, perform dose assessment using RM-064 and a main steam flow in lbm/hr from the affected Steam Generator (ERFCS page 353) per the following criteria:
 - 1.1.1 If RM-064 is reading at or below background, use one (1) net count per minute (NCPM) for the RM-064 reading, an Iodine/Noble Gas Ratio of 0.003 and Attachment 6.4 to perform dose assessment.
 - 1.1.2 If RM-064 is reading above background, use the indicated reading on RM-064, and Iodine/Noble Gas Ratio of 0.003 and Attachment 6.4 to perform dose assessment.
 - 1.1.3 If RM-064 is off-scale high or is not operable, go to Section 1.3 below.
 - 1.2 For unmonitored releases via FW-10, the Atmospheric Dump Valve (HCV-1040) or a Main Steam Safety Valve, perform dose assessment per the following criteria:
 - 1.2.1 If RM-064 is reading at or below background use one (1) net count per minute (NCPM) for the RM-064 reading, a flow rate as determined from EAGLE, an Iodine/Noble Gas Ratio of 0.003, and Attachment 6.4 to perform dose assessment.
 - 1.2.2 If RM-064 is reading above background, use the indicated reading on RM-064, a flow rate as determined from EAGLE, an Iodine/Noble Gas Ratio of 0.003 and Attachment 6.4 to perform dose assessment.
 - 1.2.3 If RM-064 is off-scale high or is not operable, go to Section 1.3 below.

Attachment 6.5 (continued)

Page 2 of 9

- 1.3 If RM-064 goes off-scale high or is otherwise known to be inoperable, perform the following:
 - 1.3.1 Obtain direct radiation readings on the main steam lines in Room 81. Refer to Figure 6.5.1 for reading locations.
 - 1.3.2 If the dose rate is between 0 and 100 mRem/hr, use the following equation to calculate the TEDE release rate:

QTEDE = (17.5) (Contact Dose Rate in mRem/hr)

1.3.3 If the dose rate is >100 mRem/hr, use the following equation to calculate the TEDE release rate:

 $Q_{\text{TEDE}} = (5)$ (Contact Dose Rate in mRem/hr)

1.3.4 Multiply the Q_{TEDE} from Step 1.3.2 or 1.3.3 by the following to obtain the Noble Gas, Iodine and Particulate release rate in Ci/sec:

 (Q_{TEDE}) (0.981) = Noble Gas Release Rate in Ci/sec

 (Q_{TEDE}) (0.003) = Iodine Release Rate in Ci/sec

 (Q_{TEDE}) (0.009) = Particulate Release Rate in Ci/sec

- 1.3.5 Input the Noble Gas, Iodine and Particulate Release Rate into EAGLE dose assessment program to obtain the dose and dose rate results. (AR 17061)
- 2. Containment Leakage
 - 2.1 If all Containment Area Radiation Monitors are off-scale or inoperable, perform the following:
 - 2.1.1 Obtain direct radiation readings on containment penetrations C-2 or H-4. Refer to Figures 6.5.2 and 6.5.3 for reading locations.
 - 2.1.2 Multiply this penetration reading by the Containment Multiplication Factor (CMF) using Figure 6.5.4, to determine an equivalent area monitor reading.
 - 2.1.3 Insert the area monitor reading into the EAGLE dose assessment procedure to obtain the dose and dose rate results.

Attachment 6.5 (continued)

Page 3 of 9

3. Determining Actual Release Rates from Field Team Data

NOTE: Field Teams must be dispatched, and data from the approximate plume centerline must be available in order to complete this procedure. The Field Team Specialist should be consulted for Field Team data.

- 3.1 Obtain FC-EPF-29 and collect the following data:
 - 3.1.1 Date and time.
 - 3.1.2 Downwind distance (in miles) to the sampling location.
 - 3.1.3 Wind direction
 - 3.1.4 Delta temperature (ΔT)
 - 3.1.5 Wind speed
 - 3.1.6 Diffusion factor $(\chi\mu/Q)$ Using Figure 6.5.5, determine the projected diffusion factor, based on time of day and downwind distance. During transitional periods, use the more conservative, or smaller, value.
 - 3.1.7 Dose rate reported from the field team in Rem/hr.
 - 3.1.8 Iodine air concentration reported from the field team in µCi/cc.
 - 3.1.9 Particulate air concentration reported from the field team in μ Ci/cc.
 - 3.1.10 Noble gas release rate from dose rate (QNG in Ci/sec) Multiply the wind speed (Step 3.1.5) by the dose rate (Step 3.1.7) and by the factor provided, then divide the result by $\chi\mu/Q$ (Step 3.1.6).
 - 3.1.11 Iodine release rate from QNG (in Ci/sec) Multiply the noble gas release rate (Step 3.1.10) by the factor provided.
 - 3.1.12 Iodine release rate from air sample data (in Ci/sec) -If desired, this method may be used if iodine air sample date is available from the Field Teams. Multiply the wind speed (Step 3.1.5) by the iodine concentration (Step 3.1.8), then divide the result by the $\chi\mu/Q$ (Step 3.1.6).
 - 3.1.13 Particulate release rate from air sample data (in Ci/sec) Multiply the wind speed (Step 3.1.5) by the particulate concentration (Step 3.1.9), then divide the result by the $\chi\mu/Q$ (Step 3.1.6).

EPIP-EOF-6 PAGE 26 OF 31

Attachment 6.5 (continued)

Page 4 of 9

- 3.2 Input Of Results
 - 3.2.1 Upon completion of the calculations, input the release rate data into the EAGLE dose assessment procedure to obtain any dose and dose rate data as needed.
- 3.3 Follow-up Actions
 - 3.3.1 Sign the assessment form and indicate the time completed.

.

Attachment 6.5 (continued)

Page 5 of 9

Figure 6.5.1 - Main Steam Headers Radiation Dose Measurement Point Locations



EPIP-EOF-6 PAGE 28 OF 31

Attachment 6.5 (continued)

Page 6 of 9

Figure 6.5.2 - Auxiliary Building - Plant Elevation 1007'-0" & 1013'-0



Attachment 6.5 (continued)

Page 7 of 9

Figure 6.5.3 - Auxiliary Building - Plant Elevation 1036'-0



Attachment 6.5 (continued)

Page 8 of 9




FORT CALHOUN STATION EMERGENCY PLAN IMPLEMENTING PROCEDURE

Attachment 6.5 (continued)

Page 9 of 9





.