

SDC and Coolant Circulation – Low Water Level  
3.9.5

3.9 REFUELING OPERATIONS

3.9.5 Shutdown Cooling (SDC) and Coolant Circulation – Low Water Level

LCO 3.9.5 Two SDC loops shall be OPERABLE, and one SDC loop shall be in operation.

- NOTES-----
1. The required SDC loop may be removed from operation for  $\leq 1$  hour per 8 hour period, provided no operations are permitted that would cause reduction of the Reactor Coolant System boron concentration.
  2. One required SDC loop may be inoperable for up to 2 hours for surveillance testing, provided the other SDC loop is OPERABLE and in operation.
- 

APPLICABILITY: MODE 6 with the water level < 23 ft above the top of reactor vessel flange.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One SDC loop inoperable.	A.1 Initiate action to restore SDC loop to OPERABLE status.	Immediately
	<u>OR</u>	
	A.2 Initiate action to establish $\geq 23$ ft of water above the top of reactor vessel flange.	Immediately