Docket No. 50-341

Mr. B. Ralph Sylvia
Senior Vice President - Nuclear
Operations
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

DISTRIBUTION
Docket File
NRC PDR
PD31 Plan Gray
GHolahan
MVirgilio
PShuttleworth
JStang
OGC

Local PDr BGrimes ACRS (10) GPA/PA

Dear Mr. Sylvia:

SUBJECT: FERMI-2 - TRANSMITTAL OF ENVIRONMENTAL ASSESSMENT (TAC NO. 72755)

Enclosed is a copy of an "Environmental Assessment and Finding of No Significant Impact" for your information. This assessment relates to your application dated March 10, 1989, to revise the Technical Specifications (TS) by removing the Traversing Incore Probe (TIP) Purge System Primary Containment Isolation Valve from the TS. The subject penetration will be sealed closed with a qualified welded cap and leak tested per 10 CFR Part 50, Appendix 3 during the first refueling outage.

The assessment has been sent to the Office of the Federal Register for publication.

Sincerely,

Martin Same

John F. Stang, Project Manager Project Directorate III-1 Division of Reactor Projects - III, IV, V & Special Projects Office of Nuclear Reactor Regulation

Enclosure: As stated

cc w/enclosure: See next page

FERMI 2 EA TAC 72755

9909050 365 PDR ADOCK 890824 05000341 PDR

LA/PD31:DRSF PShuttleworth 08/Q/89 PM/RDS1:DRSF JState 08 No 789 (A)D/PD31:DRSP LYandeligthoma C8/2/89 06C MU 08/15/89

OFFICIAL RECORD COPY

AM.



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555 August 24, 1989

Docket No. 50-341

Mr. B. Ralph Sylvia
Senior Vice President - Nuclear
Operations
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

Dear Mr. Sylvia:

SUBJECT: FERMI-2 - TRANSMITTAL OF ENVIRONMENTAL ASSESSMENT (TAC NC. 72755)

Enclosed is a copy of an "Environmental Assessment and Finding of No Significant Impact" for your information. This assessment relates to your application dated March 10, 1989, to revise the Technical Specifications (TS) by removing the Traversing Incore Probe (TIP) Purge System Primary Containment Isolation Valve from the TS. The subject penetration will be sealed closed with a qualified welded cap and leak tested per 10 CFR Part 50, Appendix J during the first refueling outage.

The assessment has been sent to the Office of the Federal Register for publication.

Sincerely,

Gohn F. Stang, Project Manager Project Directorate III-1 Division of Reactor Projects - III, IV, V & Special Projects

Office of Nuclear Reactor Regulation

Enclosure: As stated

cc w/enclosure:
See next page

Mr. B. Ralph Sylvia Detroit Edison Company

cc:

Mr. Ronald C. Callen Adv. Planning Review Section Michigan Public Service Commission 6545 Mercantile Way P. O. Box 30221 Lansing, Michigan 48909

John Flynn, Esq. Senior Attorney Detroit Edison Company 2000 Second Avenue Detroit, Michigan 48226

Nuclear Facilities and Environmental Monitoring Section Office Division of Radiological Health P. O. Box 30035 Lansing, Michigan 48909

Mr. Walt Rogers U.S. Nuclear Regulatory Commission Resident Inspector's Office 6450 W. Dixie Highway Newport, Michigan 48166

Monroe County Office of Civil Preparedness 963 South Raisinville Monroe, Michigan 48161

Regional Administrator, Region III U.S. Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, Illinois 60137 Fermi-2 Facility

Ms. Lynn Goodman
Supervisor - Licensing
Detroit Edison Company
Fermi Unit 2
6400 North Dixie Highway
Newport, Michigan 48166

U.S. NUCLEAR REGULATORY COMMISSION

DETROIT EDISON COMPANY

WOLVERINE POWER SUPPLY COOPERATIVE, INC.

DOCKET NO. 50-341

FERMI-2

ENVIRONMENTAL ASSESSMENT AND FINDING OF

NO SIGNIFICANT IMPACT

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-43, issued to the Detroit Edison Company (DECo) and the Wolverine Power Supply Cooperative, Incorporated (the licensees) for the operation of Fermi-2 located in Monroe County, Michigan.

ENVIRONMENTAL ASSESSMENT

<u>Identification of Proposed Action</u>:

The proposed amendment would revise the Technical Specifications (TS) for Primary Containment Isolation Valves by removing the Traversing Incore Probe (TIP) Purge System Primary Containment Isolation Valve from the TS.

The proposed action is in accordance with the licensees' application for amendment dated March 10, 1989.

The Need for the Proposed Action:

The proposed changes to the TS are required in order to reflect the elimination of the TIP Purge System Primary Containment Isolation Valves from the plant design. The purge system is being modified to achieve compliance with General Design Criterion 56 of Appendix A of 10 CFR 50.

Environmental Impacts of the Proposed Action:

The Commission has completed its evaluation of the proposed revision to the TS. The proposed revision would reflect the elimination of the TIP Purge

System Primary Containment Isolation Valves and the sealing of the associated penetration with a qualified welded cap which will be leak tested per 10 CFR Part 50, Appendix J. This will reduce the probability of leakage during an accident from this potential leakage path. In addition, a reduction in occupational radiation exposure can be expected because of lower maintenance, inspection and testing requirements of the new design. Therefore, the proposed changes do not increase the probability or consequences of any accidents, no changes are being made in the types of any effluents that may be released offsite, and there is no significant increase in the allowable individual or cumulative occupational radiation exposure. Accordingly, the Commission concludes that this proposed action would result in no significant radiological impact and could result in the reduction of the radiological impacts.

With regard to potential nonradiological impacts, the proposed changes to the TS involve systems located within the restricted area as defined in 10 CFR Part 20. They do not affect nonradiological plant effluents and have no other environmental impact. Therefore, the Commission concludes that there are no significant nonradiological environmental impacts associated with the proposed amendment.

The Notice of Consideration of Issuance of Amendment and Opportunity for Hearing in connection with this action was published in the FEDERAL REGISTER on August 1, 1989 (54 FR 31750). No request for hearing or petition for leave to intervene was filed following this notice.

Alternative to the Proposed Action:

Because the Commission has concluded that there is no significant environmental impact associated with the proposed amendment, any alternative would have either no or greater environmental impact. The principal

alternative would be to deny the requested amendment. This would prevent the design modifications and thus prevent compliance with General Design Criterion 56. Alternative Use of Resources:

This action involves no use of resources not previously considered in connection with the "Final Environmental Statement Related to Operation of Fermi-2," dated August 1981.

Agencies and Persons Consulted

The Commission's staff reviewed the licensees' request and did not consult other agencies or persons.

FINDING OF NO SIGNIFICANT IMPACT

The Commission has determined not to prepare an environmental impact statement for the proposed license amendment.

Based upon the foregoing environmental assessment, the Commission concludes that the proposed action will not have a significant effect on the quality of the human environment.

For further details with respect to this action, see the application for amendment dated March 10, 1989, which is available for public inspection at the Commission's Public Document Room, 2120 L Street, N.W., Washington, D.C., and at the Monroe County Library System, 3700 South Custer Road, Monroe, Michigan 48161.

Dated at Rockville, Maryland, this 24th of August 1989.

FOR THE NUCLEAR REGULATORY COMMISSION

Albert W. De Agazio, Acting Director

albert m. dbelgann

Project Directorate III-1

Division of Reactor Projects - III,

IV, V & Special Projects

Office of Nuclear Reactor Regulation