



**Pacific Gas and
Electric Company**

Gregory M. Rueger
Senior Vice President-
Generation and
Chief Nuclear Officer

US Mail:
Mail Code B32
Pacific Gas and Electric Company
PO Box 770000
San Francisco, CA 94177-0001

Overnight Mail:
Mail Code B32
Pacific Gas and Electric Company
77 Beale Street, 32nd Floor
San Francisco, CA 94105-1814

415.973.4684
Fax: 415.973.2313

February 26, 2002

PG&E Letter DCL-02-020

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Docket No. 50-275, OL-DPR-80
Docket No. 50-323, OL-DPR-82
Diablo Canyon Units 1 and 2
Supplement 1 to License Amendment Request 01-04
Revision To Technical Specifications 3.9.4 Containment Penetrations

Dear Commissioners and Staff:

On October 17, 2001, in Letter DCL-01-104, PG&E submitted License Amendment Request (LAR) 01-04, "Revision To Technical Specifications 3.9.4 Containment Penetrations." That LAR proposed to revise the limiting condition for operation for Technical Specification (TS) 3.9.4, "Containment Penetrations," to allow the equipment hatch, both personnel air lock doors and both emergency air lock doors to remain open, and penetration flow path(s) providing direct access from the containment atmosphere to the outside atmosphere to be unisolated under administrative control, during core alterations and movement of irradiated fuel assemblies.

Subsequent to submittal of LAR 01-04, the NRC asked if weather conditions could necessitate closure of the containment equipment hatch. Although the historic severe weather patterns for Diablo Canyon Power Plant do not require consideration of tornados as part of the design basis, severe weather conditions might occur at the site that could necessitate closure of the equipment hatch. To address this concern PG&E will establish procedural direction requiring closure of the equipment hatch during any such severe weather conditions. Guidance will also be included in the bases for TS 3.9.4 in accordance with TS 5.5.14, as part of implementation of the license amendment.

This additional commitment does not effect the results of the safety evaluation and the no significant hazards determination previously transmitted in PG&E

A001

Document Control Desk
February 26, 2002
Page 2



Letter DCL 01-104, "License Amendment Request 01-04, 'Revision to Technical Specification 3.9.4 Containment Penetrations,'" dated October 17, 2001.

Sincerely,


Gregory M. Rueger
Senior Vice President - Generation and Chief Nuclear Officer


cc: Edgar Bailey, DHS
Ellis W. Merschoff
David L. Proulx
Girija S. Shukla
Diablo Distribution

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of PACIFIC GAS AND ELECTRIC COMPANY Diablo Canyon Power Plant Units 1 and 2) Docket No. 50-275) Facility Operating License) No. DPR-80)) Docket No. 50-323) Facility Operating License) No. DPR-82
--	---


AFFIDAVIT

Gregory M. Rueger, of lawful age, first being duly sworn upon oath says that he is Senior Vice President - Generation and Chief Nuclear Officer of Pacific Gas and Electric Company; that he has executed Supplement 1 to License Amendment Request 01-04 on behalf of said company with full power and authority to do so; that he is familiar with the content thereof; and that the facts stated therein are true and correct to the best of his knowledge, information, and belief.



 Gregory M. Rueger
 Senior Vice President – Generation and Chief Nuclear Officer

Subscribed and sworn to before me this 27 day of February, 2002



 Notary Public,
 County of San Francisco
 State of California

