



Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc.
Indian Point Energy Center
295 Broadway, Suite 1
P.O. Box 249
Buchanan, NY 10511-0249

March 1, 2002

Re: Indian Point Unit No. 2
Docket No. 50-247
NL 02-024

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Stop 0-P1-17
Washington, D.C. 20555-0001

SUBJECT: Indian Point Unit 2 Technical Specification Bases Changes

Entergy Nuclear Operations, Inc. hereby submits changes that have been made to the Indian Point Unit 2 Technical Specification (TS) Bases. These changes have been processed in accordance with the provisions of 10CFR50.59.

Description of Changes

The Bases for TS 2.2, "Safety Limit: Reactor Coolant System Pressure," have been revised to correct an incorrect description of the reactor high pressure trip. License Amendment 159 changed the reactor high pressure trip setpoint in TS 2.3.

The Bases for TS 3.7, "Auxiliary Electrical Systems," have been revised to clarify the discussion of the fuel storage requirements for the Emergency Diesel Generators.

The attachment provides the replacement pages for the TS Bases. There are no commitments contained in this submittal. Should you or your staff have any questions regarding this submittal, please contact Mr. John F. McCann, Manager, Nuclear Safety and Licensing at (914) 734-5074.

Sincerely,

A handwritten signature in black ink that reads "Fred Dacimo".

Fred Dacimo
Vice President – Operations
Indian Point 2

Attachment

cc: See page 2

A 001

Hubert J. Miller
Regional Administrator
US Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Patrick D. Milano, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
US Nuclear Regulatory Commission
Mail Stop O-8-2C
Washington, DC 20555

NRC Senior Resident Inspector
US Nuclear Regulatory Commission
PO Box 38
Buchanan, NY 10511

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, NY 10511

Mr. Paul Eddy
NYS Department of Public Service
3 Empire Plaza
Albany, NY 12223

Mr. William F. Flynn
NYS ERDA
Corporate Plaza West
286 Washington Ave. Extension
Albany, NY 12223-6399

ATTACHMENT TO NL 02-024

REVISED TECHNICAL SPECIFICATION BASES PAGES

Affected pages:

2.2-1

3.7-6

3.7-7

3.7-8

3.7-9

ENERGY NUCLEAR OPERATIONS, INC
INDIAN POINT UNIT NO. 2
DOCKET NO. 50-247

2.2 SAFETY LIMIT: REACTOR COOLANT SYSTEM PRESSURE

Applicability

Applies to the maximum limit on Reactor Coolant System pressure.

Objective

To maintain the integrity of the Reactor Coolant System and to prevent the release of excessive amounts of fission product activity to the containment.

Specification

The Reactor Coolant System pressure shall not exceed 2735 psig with fuel assemblies installed in the reactor vessel.

Basis

The Reactor Coolant System ⁽¹⁾ serves as a barrier preventing radionuclides contained in the reactor coolant from reaching the atmosphere. In the event of a fuel cladding failure the Reactor Coolant System is the primary barrier against the release of fission products. By establishing a system pressure limit, the continued integrity of the Reactor Coolant System is assured. The maximum transient pressure allowable in the Reactor Coolant System pressure vessel under the ASME Code, Section III is 110% of design pressure. The maximum transient pressure allowable in the Reactor Coolant System piping, valves and fittings under USAS Section B31.1 is 120% of design pressure. Thus, the safety limit of 2735 psig (110% of design pressure) has been established.

The settings of the power operated relief valves (2335 psig)⁽²⁾ and the reactor high pressure trip (2363 psig)⁽²⁾ have been established to assure that the Reactor Coolant System pressure limit is never reached and that the system pressure does not exceed the design limits of the fuel cladding.

In addition, the Reactor Coolant System safety valves⁽³⁾ are sized to prevent system pressure from exceeding the design pressure by more than 10 percent (2735)

Services Company (RESCO) plant. The RESCO plant alone does not have the capability to supply all expected loads for Indian Point 2 and 3 and connected customer loads supplied by the Buchanan 13.8 kV substation. Therefore, the RESCO plant can not be used to satisfy 3.7.A.1 or 3.7.B.2.a.

The plant auxiliary equipment is arranged electrically so that multiple items receive their power from different sources. The charging pumps are supplied from the 480-volt buses Nos. 3A, 5A, and 6A. The five containment fans are divided among the 480-volt buses. The two residual heat pumps are on separate 480-volt buses. Valves are supplied from separate motor control centers.

The station auxiliary transformer or a gas turbine is capable of providing sufficient power for plant startup. The station auxiliary transformer can supply the required plant auxiliary power during normal operation.

There are two 13.8/6.9 kV transformers which can be used to supply 6.9 kV power to Indian Point 2. One transformer is associated with Feeder 13W92 and Indian Point 2, the other is associated with Feeder 13W93 and Indian Point 3. Each transformer is capable of supplying maximum safeguards loads and safe shutdown loads for both Indian Point 2 and 3 taken simultaneously. While during normal operation each unit will take credit for its associated transformer, during the time frame required to perform scheduled maintenance or to replace failed equipment both units may take credit for the same 13.8/6.9 kV transformer. Neither 13.8/6.9 kV transformer is capable of supplying all auxiliaries for either unit. Therefore, the automatic transfer of 6.9 kV buses 1, 2, 3 and 4 is defeated when the 13.8 kV source is supplying power to buses 5 and 6.

The bus arrangements specified for operation ensure that power is available to an adequate number of safeguards auxiliaries. With additional switching, more equipment could be out of service without infringing on safety.

Two diesel generators have sufficient capacity to start and run, within design ratings, the minimum required equipment. If one diesel is inoperable, the minimum required equipment associated with the remaining two diesels must be operable. Equipment that is not required such as a third non-essential service water pump, a third charging pump or a third component cooling water pump associated with the remaining two diesels is not required to be operable when a diesel is inoperable as long as the remaining two diesels can not be overloaded by this configuration. Component Cooling Pump 22 can not be inoperable while either Diesel Generator 21 or 23 is out of service because this configuration would overload one of the remaining two diesels.

The basis for the minimum total required fuel oil quantity is to provide for operation of two diesel generators for 7 days. The specified minimum quantity of fuel oil is based on operation of two diesel generators for 7 days at the maximum load profile permitted by the diesel generator rating. Each diesel is rated for operation for 0.5 hours of operation out of any 24 hours at 2300 kW plus 2.0 hours of operation out of any 24 hours at 2000 kW with the remaining 21.5 hours of operation out of any twenty four hours at 1750 kW. Operation of the diesel generators at the maximum load profile ratings bounds the postulated accident load profile. Using this maximum load profile and the associated fuel consumption rates, the total fuel oil consumed by 2 diesel generators for 168 hours is approximately 43,500 gallons. This quantity of fuel oil necessary to operate two diesel generators is conservatively less than the specified minimum fuel oil requirement of 48,000 gallons by approximately 4,500 gallons.

There are three onsite fuel oil storage tanks adjacent to the diesels. Each tank has an associated fuel oil transfer pump, which has the capability to automatically feed two of the three diesels through either of two redundant supply headers. If one of the three storage tanks is not available, there is sufficient fuel oil available in the remaining two tanks to run two diesels at the maximum load profile for at least 45 hrs. Similarly, if three diesels are available, there is sufficient fuel oil in the three associated storage tanks for at least 45 hours of operation at the maximum load profile. Additional fuel oil suitable for use in the diesel generators will be stored either onsite or at the Buchanan Substation. If one EDG storage tank or transfer pump is unavailable, the remaining tanks or pumps with the additional 29,000 gallons of fuel oil can supply the two diesels if required to supply at least minimum engineered safeguards equipment for at least 160 hours.⁽²⁾ Commercial oil supplies and trucking facilities exist to assure deliveries within one day's notice.

If a diesel generator is out of service due to planned maintenance or testing, testing of the remaining diesel generators is not required. In this case, testing is not required because a planned emergency diesel generator maintenance or testing outage does not directly affect the availability or reliability of the remaining emergency diesel generators and is not indicative of a potential failure in the remaining emergency diesel generators.

One battery charger shall be in service on each battery so that the batteries will always be at full charge in anticipation of a loss-of-ac power incident. This ensures that adequate dc power will be available for starting the emergency diesel generators and other emergency uses.

The plant can be safely shut down without the use of offsite power since all vital loads (safety systems, instruments, etc.) can be supplied from the emergency diesel generators.

Any two of three diesel generators, the station auxiliary transformer or the separate 13.8 to 6.9 kV transformer are each capable of supplying the minimum safeguards loads and therefore provide separate sources of power immediately available for operation of these loads. Thus, the power supply system meets the single failure criteria required of the safety systems.

Three (3) gas turbine generators are directly available to the Indian Point site. One is located onsite (GT-1) and two additional units are located at the adjacent Buchanan Substation (GT-2 and GT-3). One gas turbine generator is more than adequate to provide an additional contingency of backup electrical power for maintaining the plant in a safe shutdown condition. The specified gas turbine generator minimum fuel inventory of 54,200 gallons assures that one gas turbine generator will be capable of supplying more than the maximum electrical load for the Indian Point Unit No. 2 alternate safe shutdown power supply system (i.e., 750 kW) for at least three (3) days. Commercial oil supplies and trucking facilities exist to assure deliveries of additional fuel oil within one day's notice.

Conditions of a system-wide blackout could result in a unit trip. Since normal offsite power supplies as required in Specification 3.7.A are not available for startup, it is desirable to be able to blackstart this unit with onsite power supplies as a first step in restoring the system to an operable status and restoring power to customers for essential service. Specification 3.7.D.1 provides for startup using the onsite gas turbine to supply the 6.9 kV loads and the diesels to supply the 480-volt loads. Tie breakers between the 6.9 kV and 480-volt systems are open so that the diesels would not be jeopardized in the event of any incident and would be able to continue to supply 480-volt safeguards power. The scheme consists of starting two reactor coolant pumps, one condensate pump, 2 circulating water pumps and necessary auxiliaries to bring the unit up to approximately 10% power. At this point, loads can be assumed by the main generator and power supplied to the system in an orderly and routine manner.

Specification 3.7.D.2 is identical with normal start-up requirements as in Specification 3.7.A except that offsite power is supplied exclusively from gas turbines with a minimum total power of 37 MW (nameplate rating), which is sufficient to carry out normal plant startup.

As a result of an investigation of the effect components, that might become submerged following a LOCA, may have on ECCS, containment isolation, and other safety-related functions, a fuse and a locked-open circuit breaker were provided on the electrical feeder to emergency lighting panel 218 inside containment. With the circuit breaker in the open position, containment electrical penetration H-70 is de-energized during the accident condition. Personnel access to containment may be required during power operation. Since

it is highly improbable that a LOCA would occur during this short period of time, the circuit breaker may be closed during that time to provide emergency lighting inside containment for personnel safety.

When the 138 kV source of offsite power is out of service, the automatic transfer of 6.9 kV Buses 1, 2, 3 and 4 to offsite power after a unit trip could result in overloading of the 20 MVA 13.8 kV/6.9 kV auto-transformer. Accordingly, the intent of Specification 3.7.B.4 is to prevent the automatic transfer when only the 13.8 kV source of offsite power is available. However, this specification is not intended to preclude subsequent manual operations or bus transfers once sufficient loads have been stripped to assure that the 20 MVA auto-transformer will not be overloaded by these manual actions.

References

- (1) UFSAR Section 8.2.1
- (2) UFSAR Section 8.2.3